

**Proposed Revisions to Water Quality Rules and Regulations, Design and Construction
Standards for Public Water Supplies**

Analysis of Comments Received on October 17, 2019



March 18, 2020

Prepared by:
Wyoming Department of Environmental Quality
Water Quality Division
Water and Wastewater Program

Commenter:

Water and Waste Advisory Board

Comments and Responses

Water and Waste Advisory Board: The Board recommended clarifying what kind of report is required for the acidization of public water supply wells in Section 9(b)(ii)(D).

Department Response: WDEQ/WQD considered the comment and revised the passage to state that the required report is a well construction report.