




# Department of Environmental Quality

*To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.*




Mark Gordon, Governor



Todd Parfitt, Director

**TO:** Steve Lenz, Chairman, Environmental Quality Council

**FROM:** Todd Parfitt, Director, Department of Environmental Quality 

**DATE:** August 31, 2022

**SUBJECT:** Hearing Request for Water Quality Rules Chapter 12

The Department of Environmental Quality (Department), Water Quality Division (WQD) is proposing revisions to Chapter 12, Design and Construction Standards for Public Water Supplies, and is requesting that the Environmental Quality Council review the proposal and consider the adoption of these rules at your November 15, 2022 hearing.

The Water Quality Division presented the proposed revisions to the Water and Waste Advisory Board (WWAB) as follows:

- The WQD presented proposed revisions to the WWAB on December 21, 2021.
  - The December 21, 2021 discussion focused on comments received during the public comment period that began on November 21, 2021 and comments from WWAB members.
  - The WWAB requested a 45-day extension of the public comment period and voted unanimously to not recommend that WQD proceed to EQC for rulemaking.
  - The public comments are included in the enclosed document “Analysis of Comments Received Prior to February 14, 2022 Notice Period End Date related to the December 21, 2021 and March 15, 2022 Water and Waste Advisory Board Meetings.”
  - The WWAB comments are included in the enclosed document “Water and Waste Advisory Board Comments, December 21, 2021 Meeting, Chapter 12.”
- Following the December 21, 2021 WWAB meeting, the WQD:
  - Provided additional notice of the comment period extension;
  - Provided each commenter with the comment analysis and an offer to discuss any outstanding concerns;
  - Followed up with each commenter to review and discuss the comment analysis and address any questions or remaining concerns; and
  - Conducted a webinar to discuss an overview of the proposed revisions and an additional online question and answer session to provide further opportunity for commenters to note concerns or questions.
- The WQD presented the proposed updated revisions to the WWAB on March 15, 2022.
  - The March 15, 2022 discussion focused on the response to public comments and response to WWAB comments.

200 West 17th Street, Cheyenne, WY 82002 · <http://deq.wyoming.gov> · Fax (307) 635-1784

ADMIN/OUTREACH  
(307) 777-7937

ABANDONED MINES  
(307) 777-6145

AIR QUALITY  
(307) 777-7391

INDUSTRIAL SITING  
(307) 777-7369

LAND QUALITY  
(307) 777-7756

SOLID & HAZ. WASTE  
(307) 777-7752

WATER QUALITY  
(307) 777-7781

- One member of the public, Wyoming Association of Rural Water Systems, provided comments during the March 15 meeting, included in the enclosed document “Analysis of Comments Received at the March 15, 2022 Water and Waste Advisory Board Meeting.”
- The WWAB noted areas on which they still had concerns, identified in the enclosed document, “Water and Waste Advisory Board Comments, March 15, 2022 Meeting.”
- The WWAB unanimously voted to not recommend that WQD proceed with the rulemaking to the EQC and asked to see it again at their next meeting or a special meeting to address WWAB comments.
- The WWAB stated that they did not think another public comment period was necessary prior to Chapter 12 being re-presented to the WWAB.
- The WQD presented proposed revisions to the WWAB at a special meeting held on May 3, 2022.
  - The May 3, 2022 discussion focused on the changes made to the Chapter since the March 15, 2022 meeting.
  - The WWAB noted areas on which they still had concerns, identified in the enclosed document, “Water and Waste Advisory Board Comments, May 3, 2022 Meeting.”
  - The WWAB voted 2-2 on the motion to advise WQD to continue to the EQC with the changes made to Chapter 12 at the March 15 and May 3, 2022 meetings.

The Department sought and has been granted approval by the Governor's Office on August 19, 2022 to proceed with the proposed rule. The Department provided supplemental information to the Governor's Office, identified in the enclosed document, “Supplemental Information Related to Proposed Rules for Wyoming Department of Environmental Quality, Water Quality, Chapter 12.”

The enclosed statement of principal reasons for adoption and public notice summarize the nature of the revisions.

We have enclosed one hard copy of the rule package including:

- Water Quality Rules Chapter 12, clean copy
- Water Quality Rules Chapter 12, strike and underline copy
- Statement of Principal Reasons for Adoption
- Governor Gordon's permission to proceed memo signed April 6, 2022
- Notice of Intent to Adopt Rules
- Takings Checklist and accompanying analysis
- Attorney General's Statutory Authority Review
- Supplemental Information Related to Proposed Rules for Wyoming Department of Environmental Quality, Water Quality, Chapter 12
- December 21, 21 Meeting transcript
- Analysis of Comments Received Prior to February 14, 2022 Notice Period End Date related to the December 21, 2021 and March 15, 2022 Water and Waste Advisory Board Meetings.

- Water and Waste Advisory Board Comments, December 21, 2021 Meeting, Chapter 12
- March 15, 2022 Meeting transcript
- Analysis of Comments Received at the March 15, 2022 Water and Waste Advisory Board Meeting
- Water and Waste Advisory Board Comments, March 15, 2022 Meeting
- May 3, 2022 Meeting transcript
- Water and Waste Advisory Board Comments, May 3, 2022 Meeting

cc: Jennifer Zygmunt, WQD Administrator  
Gina Thompson, WQD

Enclosures

## CHAPTER 12

### Design and Construction Standards for Public Water Supplies

#### Section 1. Authority.

These standards are promulgated pursuant to the Wyoming Environmental Quality Act, specifically, § 35-11-302.

#### Section 2. Applicability.

(a) This Chapter contains the minimum standards for the design and construction of public water supplies that are required to obtain a permit under Wyoming Statute (W.S.) § 35-11-301(a)(iii) and Water Quality Rules Chapter 3.

(i) All applicants for a Water Quality Rules Chapter 3 permit to construct, install, modify, or operate a public water supply facility shall comply with all minimum standards of this Chapter.

(ii) No permit to construct, install, modify, or operate a public water supply facility shall be issued to a facility that does not comply with the minimum standards of this Chapter.

(iii) All public water supply facilities shall be constructed, installed, and operated in accordance with permits issued pursuant to this Chapter.

(b) The construction, installation, or modification of any component of a public water supply facility requires a permit to construct.

#### Section 3. Timing of Compliance with These Regulations.

Any facility covered by an individual or general permit issued pursuant to Water Quality Rules, Chapter 3, prior to the effective date of this Chapter shall remain covered under that permit. New construction or modification of existing permitted facilities must obtain authorization under a new permit, in accordance with Water Quality Rules Chapter 3, Section 4(d) or Section 5(e), subject to the requirements of this Chapter.

#### Section 4. Incorporation By Reference of Recommended Standards for Water Works 2018 Edition.

(a) This Chapter incorporates sections of the Recommended Standards for Water Works, A Report of the Water Supply Committee of the Great Lakes--Upper Mississippi River Board of State and Provincial Public Health and Environmental Managers, 2018 Edition, referred to as "2018 TSS," as noted in Section 8(a), Section 9(a), Section 10(a), Section 11(a), Section 12(a), Section 13(a), Section 14(a), Section 15(a), Section 16(a), Section 17(a), and Section 19(a)(lviii) of this Chapter.

47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91

(b) The State term “Administrator” shall replace the term “reviewing authority” used in the Recommended Standards for Water Works 2018 Edition.

(c) The State term “shall” shall replace the term “should” used in the Recommended Standards for Water Works 2018 Edition.

**Section 5. Definitions.**

(a) The following definitions supplement those contained in W.S. § 35-11-103 of the Wyoming Environmental Quality Act.

(b) “Auxiliary source of supply” means any water supply on or available to the water user's system other than an approved public water supply acceptable to the water supplier. These auxiliary waters may include water from another supplier's public potable water supply or any natural source(s), such as a well, spring, river, stream, harbor, and so forth; used waters; or industrial fluids. These waters may be contaminated or polluted, they may be objectionable or they may be from a water source that the water supplier is uncertain of sanitary control.

(c) “Average daily demand” means the total annual water use divided by the number of days the system was in operation.

(d) “Backflow” means the undesirable reversal of flow of water or mixtures of water and other liquids, gases, or other substances into the distribution system of the public water supply from any other source or sources.

(e) “Backflow incident” means any identified backflow to a public water supply distribution system or to the potable water piping within the water user's system benefitting from a water service connection to the public water supply distribution system.

(f) “Back-pressure” means a form of backflow caused when the pressure of the water user’s system is greater than that of the water supply system whether caused by a pump, elevated tank, elevated piping, boiler, pressurized process, pressurized irrigation system, or air pressure.

(g) “Back-siphonage” means a form of backflow caused by negative or reduced pressure in the water supply system whether caused by loss of pressure due to high water demands, a line break, or excessive firefighting flows.

(h) “Calculated Dose” means the reduction equivalent dose (RED) calculated using the dose-monitoring equation that was developed through validation testing.

(i) “Contamination” means an impairment of a public water supply by the introduction or admission of any foreign substance that degrades the quality of the potable water or creates a health hazard.

92 (j) “Cross-connection” means any actual or potential connection between a potable  
93 water supply and any other source or system through which it is possible to introduce  
94 contamination into the system.

95  
96 (k) “Degree of hazard” means either a high or low hazard situation where a substance  
97 may be introduced into a public water supply through a cross-connection. The degree of hazard  
98 or threat to public health is determined by a hazard classification.

99  
100 (l) “Domestic services” means services using potable water for ordinary living  
101 processes.

102  
103 (m) “Dual check” means a device conforming to American Association of Sanitary  
104 Engineers (ASSE) Standard #1024 consisting of two independently acting check valves.

105  
106 (n) “Groundwater source” includes all water obtained from dug, drilled, bored, jetted,  
107 or driven wells; springs that are developed so that the water does not flow on the ground and that  
108 are protected to preclude the entrance of surface contamination; and collection wells.

109  
110 (o) “Hazard classification” means a determination by a Hazard Classification  
111 Surveyor as to high hazard or low hazard and the potential cause of backflow as either back-  
112 pressure or back-siphonage.

113  
114 (p) “Hazard Classification Survey” means inspection of a premises to identify the  
115 potable water systems, the location of any potential cross-connections to the potable water  
116 systems, the hazard of the potential backflow, the physical identification of any backflow devices  
117 or methods present, and the inspection status of any backflow devices or methods recorded and  
118 certified by a qualified Hazard Classification Surveyor.

119  
120 (q) “Hazard Classification Surveyor” means an individual certified by the USC-  
121 Foundation for Cross-Connection Control and Hydraulic Research as Cross Connection Control  
122 Specialist (USC-FCCCHR), the ASSE as a Cross-Connection Control Surveyor, or another state  
123 certification program submitted with the permit application and approved by the Administrator,  
124 or an individual who is a water distribution system operator also certified as a backflow device  
125 tester employed by the public water supplier for the service where the survey is being conducted.

126  
127 (r) “High hazard” means a situation created when any substance that is or may be  
128 introduced into a public water supply poses a threat to public health through poisoning, the  
129 spread of disease or pathogenic organisms, or any other public health concern.

130  
131 (s) “Isolated” when referring to cross-connections means the properly approved  
132 backflow prevention devices have been installed at each point of cross-connection within the  
133 water user's system.

134  
135 (t) “Low hazard” means a situation created when any substance that is or may be  
136 introduced into a public water supply does not pose a threat to public health but that does  
137 adversely affect the aesthetic quality of the potable water.

138  
139  
140  
141  
142  
143  
144  
145  
146  
147  
148  
149  
150  
151  
152  
153  
154  
155  
156  
157  
158  
159  
160  
161  
162  
163  
164  
165  
166  
167  
168  
169  
170  
171  
172  
173  
174  
175  
176  
177  
178  
179  
180  
181

(u) “Maximum daily demand” means the demand for water exerted on the system over a period of 24 consecutive hours, for the period during which such demand is greatest.

(v) “Maximum hourly demand” means the highest single-hour demand exerted on the system. This may or may not occur on the maximum day.

(w) “Mechanical sludge equipment” means the equipment used to physically remove solids from a water treatment process. This may include mechanical drives that use scrapers or differential water levels to collect the sludge.

(x) “Mineralized water” means any water containing more than 500 mg/L total dissolved solids.

(y) “Minor field change” means any in-field adjustment due to previously unknown physical constraints of the project site that do not affect the project’s scope. Minor field changes still allow full compliance with the requirements of this Chapter and are shown on the submitted, post-construction as-built plan set for the Division in red.

(zz) “Primary disinfection” means disinfection that kills or inactivates bacteria, viruses, and other potentially harmful organisms in drinking water.

(aa) “Reduction Equivalent Dose” means the ultraviolet (UV) dose derived by entering the log inactivation measured during full-scale reactor testing into the UV dose-response curve that was derived through collimated beam testing. RED values are always specific to the challenge microorganism used during experimental testing and the validation test conditions for full-scale reactor testing.

(bb) “Required Dose” means the UV dose in units of mJ/cm<sup>2</sup> req needed to achieve the target log inactivation for the target pathogen.

(cc) “Secondary disinfection” means disinfection that provides longer lasting water treatment as the water moves through pipes to consumers.

(dd) “Stabilized drawdown” means a water level that has not fluctuated by more than plus or minus 0.5 foot for each 100 feet of water in the well over at least a six-hour period of constant pumping flow rate. The water column is measured from pre-test static water level to the top of the deepest water bearing fracture that contributes at least 10 percent of total well yield, and plotted measurements that have not shown a trend of decreasing water level.

(ee) “Surface water source” includes all tributary streams and drainage basins, natural lakes, and artificial reservoirs or impoundments upstream from the point of the water supply intake.

182 (ff) “Validated Dose” means the UV dose in units of mJ/cm<sup>2</sup> delivered by the UV  
 183 reactor as determined through validation testing that is compared to the required dose to  
 184 determine log inactivation credit.

185  
 186 (gg) “Water service connection” means any water line or pipe connected to a  
 187 distribution supply main or pipe for the purpose of conveying water to a water user's system.  
 188

189 (hh) “Water supplier” means any entity that owns or operates a public water supply,  
 190 whether public or private.

191  
 192 (ii) “Water user” means any entity, whether public or private, with a water service  
 193 connection to a public water supply and includes customers of a public water supplier.  
 194

195 (jj) “Water user's system” means that portion of the user's water system between the  
 196 water service connection and the point of use. This system includes all pipes, conduits, tanks,  
 197 fixtures, and appurtenances used to convey, store, or use water provided by the public water  
 198 supply.  
 199

200 **Section 6. Facilities and Systems not Specifically Covered by these Standards.**  
 201

202 (a) Each application for a permit to construct a facility under this section shall be  
 203 evaluated on a case-by-case basis using the best available technology. The Administrator may  
 204 approve applications demonstrating the constructed facility can meet the purpose of the  
 205 Wyoming Environmental Quality Act and this Chapter.  
 206

207 (b) The following information shall be included with the application for a permit to  
 208 construct, install, modify, or operate a public water supply facility not specifically covered by  
 209 these standards:  
 210

211 (i) Data obtained from:

212 (A) A full scale, comparable installation that demonstrates the  
 213 acceptability of the design; or  
 214

215 (B) A pilot plant operated under the design condition for a sufficient  
 216 length of time to demonstrate the acceptability of the design; or  
 217

218 (C) A theoretical evaluation of the design that demonstrates a  
 219 reasonable probability the facility will meet the design objectives.  
 220

221 (ii) An evaluation of the flexibility of making corrective changes to the  
 222 constructed facility in the event it does not function as planned.  
 223

224 (c) If an applicant wishes to construct a pilot plant to provide the data necessary to  
 225 meet the requirements of this Section, the applicant must obtain a permit to construct.  
 226  
 227



**Section 7. Permits, Permit Application, and Recordkeeping Requirements.**

(a) Applications for a permit to construct, install, modify, or operate a public water supply shall comply with the requirements of Water Quality Rules Chapter 3, Section 6.

(b) The application shall include the following components:

(i) An engineering design report that meets the requirements of Section 9 of this Chapter;

(ii) A construction plan that meets the applicable requirements of Sections 8, 10, 11, 12, 13, 14, 15, 16, and 17 of this Chapter;

(iii) An operation and maintenance plan that meets the requirements of Section 18 of this Chapter; and

(iv) Any additional information required by the Administrator.

(c) The application and components required by this Chapter shall be submitted to the Division in a format required by the Administrator.

(d) The application shall include certification under penalty of perjury that the applicant has secured and will maintain permission for Department personnel and their invitees to access the facility, including permission to:

(i) Access the land where the facility is located;

(ii) Collect resource data as defined by W.S. § 6-3-414(e)(iv); and

(iii) Enter and cross all properties necessary to access the facility if the facility cannot be directly accessed from a public road.

(e) Sections of permit applications that represent engineering work shall be sealed, signed, and dated by a licensed professional engineer as required by W.S. § 33-29-601.

(f) Sections of permit applications that represent geologic work shall be sealed, signed, and dated by a licensed professional geologist as required by W.S. § 33-41-115.

(g) The Administrator may allow an alternative two-step permitting and application procedure for wells and water storage tank project applicants that meet the following requirements:

(i) For applications that include wells, the Department will issue one permit with the following phased authorizations:

273 (A) The issued permit will authorize the well to be constructed,  
274 developed, and tested;

275  
276 (B) Applicants shall then submit well test data and water quality data  
277 for Administrator review; and

278  
279 (C) Upon the Administrator’s approval of the well test data and water  
280 quality data, the Director shall modify the issued permit to authorize connection of the  
281 distribution system to the well.

282  
283 (iii) Applicants for water storage tanks may follow an alternative procedure  
284 when the final plans and specifications for the tank cannot be submitted with the initial permit  
285 application due to project bidding constraints. In these instances, the Department will issue a  
286 permit through the following phased authorizations:

287  
288 (A) The issued permit will authorize the project to initiate the bidding  
289 process. Applicants shall ensure the project bidding documentation includes a requirement that  
290 the final water storage tank design complies with the requirements of this Chapter.

291  
292 (B) Applicants shall then submit final documentation and  
293 specifications for the water storage tank that demonstrate the design is consistent with the  
294 requirements of this Chapter. Upon the Administrator’s approval of the final tank documentation  
295 specifications, the Director shall modify the issued permit to authorize the construction of the  
296 water storage tank and foundation.

297  
298 (iv) Applicants that use phased authorization procedures in this paragraph (g)  
299 shall request a pre-application meeting with the applicable Division district engineer prior to  
300 submission of the permit application package to ensure efficient coordination of the submittals of  
301 all reports, plans, and specifications, and Division review timelines.

302  
303 **Section 8. Plans and Specifications.**

304  
305 (a) 2018 TSS, part 1.2-1.2.2(r), plans; 1.3-1.3(e), specifications; 1.4-1.4(m), design  
306 criteria; 1.5, revisions to approved plans; and 1.6, additional information required; are herein  
307 incorporated by reference.

308  
309 (b) All plans for waterworks and treatment facilities shall also include the name of  
310 the real estate owner, the owner of the project, and the location of the project.

311  
312 (c) Plans for transmission and distribution lines shall include:

313  
314 (i) The information required in paragraph (a) of this Section;

315  
316 (ii) A detailed plan view at a legible scale of each reach of the water line  
317 showing all existing and proposed streets, adjacent structures, physical features, and existing  
318 locations of utilities that indicates:

319  
320  
321  
322  
323  
324  
325  
326  
327  
328  
329  
330  
331  
332  
333  
334  
335  
336  
337  
338  
339  
340  
341  
342  
343  
344  
345  
346  
347  
348  
349  
350  
351  
352  
353  
354  
355  
356  
357  
358  
359  
360  
361  
362  
363

(A) The location and size of all water lines, valves, access manholes, air-vacuum release stations, thrust blocking, and other appurtenances; and

(B) Pertinent elevations.

(iii) Profiles of all water lines that are shown on the same sheet as the plan view at legible horizontal and vertical scales and that show:

(A) Profiles of:

(I) Existing and finished surfaces;

(II) Pipe size and material; and

(III) Valve size, material, and type.

(B) The location of all special features such as access manholes, concrete encasements, casing pipes, blowoff valves, and air-vacuum relief valves.

(iv) Special detail drawings scaled and dimensioned to show the following:

(A) The bottom of the stream, the elevation of the high- and low-water levels, and other topographical features at points where the water line:

(I) Is located within 10 feet of streams or lakes; or

(II) Crosses streams or lakes.

(B) A cross-section drawing of the pipe bedding; and

(C) Additional features of the pipe or its installation that are not otherwise covered by specifications.

(v) The location of any sewer lines within 30 feet horizontally of water lines. Sewers that cross water lines shall be shown on the profile drawings.

(d) Plans for storage tanks, pumping stations, and water treatment facilities shall show the relation of the proposed project to the remainder of the system and shall include:

(i) The information required in paragraph (a) of this Section;

(ii) The seal and signature of the Wyoming Professional Engineer providing the design;

- 364 (iii) The site location and layout including:  
 365  
 366 (A) Topographic and physical features, including embankments;  
 367  
 368 (B) The proposed arrangement of pumping or treatment units;  
 369  
 370 (C) Existing facilities;  
 371  
 372 (D) Existing and proposed piping and valving arrangements;  
 373  
 374 (E) The route to access the facility;  
 375  
 376 (F) The power supply;  
 377  
 378 (G) Fencing; and  
 379  
 380 (H) The proposed location of clearwells, waste ponds, and sludge  
 381 ponds.  
 382  
 383 (iv) Schematic flow diagram(s) and hydraulic profile(s) for facility-treated  
 384 water;  
 385  
 386 (v) A flow diagram for sludge and wastewater flows; and  
 387  
 388 (vi) Plan(s) and section view(s) of each treatment facility process unit with  
 389 specific construction details, features, and pertinent elevations including but not limited to the  
 390 following:  
 391  
 392 (A) Inlet and outlet devices;  
 393  
 394 (B) Baffles;  
 395  
 396 (C) Valves;  
 397  
 398 (D) Arrangement of automatic control devices;  
 399  
 400 (E) Mixers;  
 401  
 402 (F) Motors;  
 403  
 404 (G) Chemical feeders;  
 405  
 406 (H) Sludge scrapers;  
 407  
 408 (I) Sludge disposal; or  
 409

- 410 (J) Other mechanical devices.
- 411
- 412 (e) Plans for well construction shall include:
- 413
- 414 (i) The information required in paragraph (a) of this Section;
- 415
- 416 (ii) Assembled order, size, and length of casing and liners;
- 417
- 418 (iii) The well test method and allowable tolerance;
- 419
- 420 (iv) The locations of all caisson construction joints and porthole assemblies on
- 421 drawings, if a radial water collector is proposed;
- 422
- 423 (v) From the ground surface to the total depth of the drilled borehole, the
- 424 elevation and designation of geological formations, water levels, formations penetrated, and
- 425 other details to describe the proposed well completely;
- 426
- 427 (vi) Screen locations, size of screen openings, and screen intervals;
- 428
- 429 (vii) The location of any blast charges, if available; and
- 430
- 431 (viii) Existing well test data, including:
- 432
- 433 (A) Test pump capacity-head characteristics;
- 434
- 435 (B) Static water level;
- 436
- 437 (C) Depth of test pump setting;
- 438
- 439 (D) Time of starting and ending each test cycle;
- 440
- 441 (E) Pumping rate;
- 442
- 443 (F) Pumping water level;
- 444
- 445 (G) Drawdown; and
- 446
- 447 (H) Water recovery rate and levels.
- 448
- 449 (f) Plans for water lines, pump stations, treatment facilities, wells, storage, or
- 450 additions/modifications to existing systems or facilities shall be accompanied by technical
- 451 specifications that include:
- 452
- 453 (i) The information required in paragraph (a) of this Section;
- 454
- 455 (ii) Identification of construction materials;

- 456  
457 (iii) When applicable, the type, size, strength, operating characteristics, rating  
458 or requirements for all mechanical and electrical equipment, including machinery, valves, piping,  
459 electrical apparatus, wiring, and meters; laboratory fixtures and equipment; operating tools;  
460 special appurtenances; and chemicals;  
461  
462 (iv) Construction and installation procedure for materials and equipment;  
463  
464 (v) Requirements and tests of materials and equipment to meet design  
465 standards;  
466  
467 (vi) Performance tests for the operation of completed works and component  
468 units;  
469  
470 (vii) Specialized requirements for tests, analyses, disinfection techniques, and  
471 other special needs;  
472  
473 (viii) A demonstration that all water service connections will be provided with  
474 backflow prevention devices in accordance with the requirements of Section 16(m) of this  
475 Chapter; and  
476  
477 (ix) If technical specifications have been independently permitted by the  
478 Department for statewide use, the title, date, and permit approval identification number in lieu of  
479 providing technical specifications.  
480

481 **Section 9 Engineering Design Report.**  
482

- 483 (a) 2018 TSS, parts 1.1.1-1.1.1(d), engineers report, general information; 1.1.2-  
484 1.1.2(c), engineers report, extent of water works system; 1.1.4-1.1.4(c), engineers report, soil,  
485 groundwater conditions, and foundation problems; 1.1.5-1.1.5(f), engineers report, water use  
486 data; 1.1.6-1.1.6(b), engineers report, flow requirements; 1.1.7.1-1.1.7.1(f), engineers report,  
487 surface water sources; 1.1.7.2-1.1.7.2(g), engineers report, groundwater; 1.1.8, engineers report,  
488 proposed treatment processes; 1.1.9, engineers report, sewerage system available; 1.1.10,  
489 engineers report, waste disposal; 1.1.15-1.1.15(d), engineers report, pumping facilities; 1.1.16-  
490 1.1.16(c), engineers report, storage facilities; and 1.1.17-1.1.17(d), engineers report, security,  
491 contingency planning, and emergency preparedness; are herein incorporated by reference.  
492  
493 (b) An engineering design report shall be submitted with each application and shall  
494 include the following required elements:  
495  
496 (i) The information required in paragraph (a) of this Section;  
497  
498 (ii) A description by narrative, analyses, and calculations of the project  
499 purpose and intent in order to support the project plans and specifications;  
500

- 501                   (iii)    A description of known or suspected problems, needs, or requirements,  
502 and the reasoning used to arrive at the proposed solution;  
503
- 504                   (iv)    An identification of problems and solutions related to but not limited to  
505 the following:  
506
- 507                           (A)    Water quantity and quality;  
508
- 509                           (B)    Compliance with the Safe Drinking Water Act, 42 U.S.C. §300f et  
510 seq.; and
- 511
- 512                           (C)    Operational requirements, redundancy, maintenance, and  
513 reliability.  
514
- 515                   (v)    A determination of the degree of hazard of all known or anticipated water  
516 service connections to be connected to the proposed project. A hazard classification shall be  
517 identified for each connection and recommended mitigation measures shall be described for each  
518 hazard.  
519
- 520           (c)    The engineering design report for all new water distribution system extensions  
521 shall include the following required elements:  
522
- 523                   (i)    The information required in paragraph (a) of this Section;  
524
- 525                   (ii)   A description of the service area including scaled vicinity plan map(s) of  
526 the project with regard to adjacent and proposed development, elevations, and topographic  
527 features; and  
528
- 529                   (iii)   Current and projected system water use data and flow requirements to  
530 include maximum hourly demand and per capita maximum daily flows;  
531
- 532                   (iv)   Information on fire protection and fire flow capabilities of the proposed  
533 system.  
534
- 535           (d)    The engineering design report for all treatment facilities shall include the  
536 following required elements:  
537
- 538                   (i)    The information required in paragraph (a) of this Section;  
539
- 540                   (ii)   A description of the facility site and location, including a scaled site plan,  
541 and:  
542
- 543                           (A)    Present and projected facility property boundaries;  
544
- 545                           (B)    Flood protection indicating predicted elevation of 25- and 100-year  
546 flood stages;

- 547  
548 (C) Present and proposed access for the purpose of operation,  
549 maintenance, and compliance inspection;  
550  
551 (D) Distances from:  
552  
553 (I) Current habitation;  
554  
555 (II) The closest major treated water transmission line;  
556  
557 (III) The closest treated water storage facility; and  
558  
559 (IV) The water source.  
560  
561 (E) Fencing and security;  
562  
563 (F) Topographic features and contours with indicated datum; and  
564  
565 (G) Soil and subsurface geological characteristics, including a soils  
566 investigation report of the proposed site suitable for structural design of the proposed facilities.  
567  
568 (iii) A description of the service area, including scaled vicinity plan map(s) of  
569 the project with regard to adjacent and proposed development, elevations, and topographic  
570 features;  
571  
572 (iv) A detailed description of the recycle flows and procedures for reclamation  
573 of recycle streams; and  
574  
575 (v) A detailed description of disposal techniques for settled solids, including a  
576 description of the ultimate disposal of sludge.  
577  
578 (e) Engineering design reports for new surface water sources shall include the  
579 following required elements:  
580  
581 (i) The information required in paragraph (a) of this Section;  
582  
583 (ii) A description of water quantity available during average and driest years  
584 of record that contains details of:  
585  
586 (A) Any diversion records; and  
587  
588 (B) Diversion dams, impoundments, or reservoirs that may impact  
589 design considerations or long-term water availability.  
590



591 (iii) A tabulation of water quality data that describes the biological,  
592 radiological, and chemical water quality sufficient to determine necessary treatment processes  
593 that:

594  
595 (A) For surface water source testing, include at least one sampling  
596 event during spring runoff and at least one sampling event during late summer or early fall low  
597 flow; and

598  
599 (B) Includes data that are sufficient for the Division to determine that  
600 the processes safely and reliably comply with water quality standards required by 40 CFR Part  
601 141.

602  
603 (f) Engineering design reports for new groundwater sources shall include:

604 (i) The information required in paragraph (a) of this Section;

605 (ii) A description of the geology of the aquifer(s) and overlying strata;

606  
607 (iii) Tabulated water quality testing data for biological, radiological, and  
608 chemical water quality sufficient to determine necessary treatment processes and sufficient for  
609 the Administrator to determine that the processes safely and reliably meet water quality  
610 standards required by 40 CFR Part 141;

611  
612 (iv) If known, a summary of the likely drilling and completion challenges that  
613 will be faced, including a description of the engineering design, management, monitoring, and  
614 drilling and completion practices that will be used to successfully construct the well in  
615 accordance with this Chapter; and

616  
617 (v) For wells that will be drilled through multiple aquifers, applicants shall  
618 request a pre-application meeting with the applicable Division district engineer to discuss:

619 (A) The boring advancement, well sealing, well development, and  
620 methods used to determine the adequacy of the well seal; and

621 (B) The methods that will be used to overcome lost circulation, bore  
622 instability, and deviations from vertical alignment.

623  
624 (g) Engineering design reports for conversion of an existing well into a public water  
625 supply well shall include the following required elements:

626 (i) The information required in paragraph (a) of this Section;

627 (ii) The information required in paragraph (f) of this Section;

628 (iii) The submission of the State Engineer's Office (SEO) Statement of  
629 Completion and Description of Well; and  
630  
631  
632  
633  
634  
635  
636

637  
638 (iv) A video log of the well inspection accompanied by a written description of  
639 the location, shape, and estimated size of any holes, breaches, corroded areas in the casing, if  
640 any, that includes:

641  
642 (A) If any damage to the casing is found, a description of how  
643 defective areas will be repaired and if there is a need for additional well bond logging; or  
644

645 (B) If well bond logging is not recommended, a description of the  
646 technical justification and an alternative means of certifying the adequacy of the well seal to  
647 protect the water source.  
648

649 (h) Engineering design reports for new water treatment facilities shall include the  
650 following required elements:

651  
652 (i) The information required in paragraph (a) of this Section;  
653

654 (ii) A description of all water treatment chemical requirements, including  
655 dosage and feed rates, delivery, handling, and storage;  
656

657 (iii) A description of automatic operation and control systems, including basic  
658 operation, manual override operation, and maintenance requirements; and  
659

660 (iv) A description of the on-site laboratory facilities and a summary of those  
661 tests to be conducted on-site. If no on-site laboratory is provided, a description of plant control  
662 and water quality testing requirements, and where the testing will be conducted shall be included.  
663

664 (i) Engineering design reports for water treatment facility modifications shall  
665 describe:

666  
667 (i) The information required in paragraph (a) of this Section;  
668

669 (ii) The purpose of the facility modification;  
670

671 (iii) All proposed new equipment, tankage, and chemical treatment processes,  
672 including a description of the modification's effect on treatment system reliability, water  
673 quantity and quality; and  
674

675 (iv) A listing of the new equipment design criteria and the associated  
676 chemicals.  
677

678 (j) Engineering design reports for water main upsizing or looping projects shall  
679 describe the purpose of the water main upsizing or looping project and shall include the  
680 following required elements:

681  
682 (i) The information required in paragraph (a) of this Section;

683  
684  
685  
686  
687  
688  
689  
690  
691  
692  
693  
694  
695  
696  
697  
698  
699  
700  
701  
702  
703  
704  
705  
706  
707  
708  
709  
710  
711  
712  
713  
714  
715  
716  
717  
718  
719  
720  
721  
722  
723  
724  
725  
726  
727  
728

(ii) Hydraulic analysis that demonstrates how peak hour, average day, maximum day, and maximum day plus fire flows, if fire flows are available, will be improved by upsizing; and

(iii) A table that summarizes the hydraulic model results.

(k) Engineering design reports for water main removal and replacements shall describe the purpose of the replacement and identify the existing main size, material type, and condition, and shall include the following required elements:

(i) The information required in paragraph (a) of this Section;

(ii) For any main replacement(s), the replacement main size, material type, and dimension ratio;

(iii) For projects that consist of main replacements in multiple discrete locations, an aerial image that shows all replacement pipeline segments, including new valves, with called-out pipe diameters and lengths;

(iv) A description of the protective measures that will be taken at locations where the new water main will cross a sewer or storm sewer when standard horizontal and vertical separations cannot be met; and

(v) For projects where asbestos cement may be encountered, a discussion of the disposal, or abandonment method to be used.

(l) Engineering design reports for new water mains shall describe the purpose of the new water main and shall include the information required in paragraph (a) of this Section. If the water main will provide service to a new development the engineering design report shall include the following required elements:

(i) The modeling result from a hydraulic analysis that demonstrates that the design will meet the requirements of Section 16(d)(i-ii) of this Chapter;

(ii) A demonstration that the hydraulic model was calibrated based on existing fire hydrant test flow data, when available, or based on modeling; and

(iii) Identification of any impacts the new fire flow demand will have on finished storage and pumping systems over the required fire flow duration.

**Section 10. Design Requirements for Preliminary Treatment and Redundancy.**

(a) 2018 TSS, parts 2.9-2.9(c), monitoring equipment; 2.10, sample taps; 2.11, facility water supply; and 2.14, piping color code are herein incorporated by reference.

729 (b) The proposed design shall demonstrate that the capacity of the water treatment or  
730 water production system is designed for the maximum daily demand at the design year based on  
731 historical usage records.

732  
733 (i) Where water use records are not available to establish water use, the  
734 design shall include an equivalent per capita water use of at least 125 gallons per day (gpd) for  
735 average daily water demand and 340 gpd for maximum daily water demand.

736  
737 (ii) The plant capacity design shall demonstrate consideration of:  
738  
739 (A) Maximum daily water demand;  
740  
741 (B) Agricultural water use;  
742  
743 (C) Industrial water use; and  
744  
745 (D) Filter backwash quantities. In the absence of data, filter backwash  
746 quantity shall be five percent of the maximum daily demand.

747  
748 (c) The structural design shall demonstrate consideration of:

749  
750 (i) The seismic zone;  
751  
752 (ii) Groundwater; and  
753  
754 (iii) Soil support that demonstrates:

755  
756 (A) The applicant has conducted soils investigations or has included  
757 documentation of adequate previous soils investigations used to develop the structural design;

758  
759 (B) Basin slabs have been designed to successfully resist the  
760 hydrostatic uplift pressure or include an area dewatering system; and

761  
762 (C) Consideration of long-span breakage in basins designed to resist  
763 uplift.

764  
765 (d) Proposed treatment facilities locations shall demonstrate that:

766  
767 (i) No sources of pollution will affect the quality of the water supply or  
768 treatment system;

769  
770 (ii) The facility location is not within 500 feet of landfills, garbage dumps, or  
771 wastewater treatment systems; and  
772

773 (iii) All treatment process structures, mechanical equipment, and electrical  
774 equipment will be protected, accessible, and remain fully operational during the maximum flood  
775 of record or the 100-year flood, whichever is greater.  
776

777 (e) Proposed treatment shall demonstrate that the facility will produce potable water  
778 that is bacteriologically, chemically, radiologically, and physically safe, as required by 40 CFR  
779 Part 141.  
780

781 (f) Designs for proposed treatment facilities with 100,000 gpd capacity and over shall  
782 include duplicate units, as a minimum, for chemical feed, flocculation, clarification,  
783 sedimentation, filtration, and disinfection.  
784

785 (g) Designs for proposed treatment facilities under 100,000 gpd capacity shall  
786 include:  
787

788 (i) Duplicate units as described in paragraph (f) of this Section; or  
789

790 (ii) Finished water system storage equal to twice the maximum daily demand;  
791 and  
792

793 (iii) Demonstration of consideration of plant design flexibility to account for  
794 future changes in source water quality, unexpected need to modify process piping, service area  
795 expansion, changing treatment technologies, and equipment life cycles and upgrades.  
796

797 (h) All treatment facility pumping shall provide the maximum daily demand flow  
798 with the largest single-unit not in service. Finished water pumping in combination with finished  
799 water storage that floats on the distribution systems shall provide the maximum hourly demand  
800 with the largest single-unit not in service. For designs that include fire protection, pumping, and  
801 finished water storage that floats on the system shall provide the fire demand plus the maximum  
802 daily demand, or the maximum hourly demand, whichever is greater.  
803

804 (i) Where the finished water storage volume that floats on the distribution system is  
805 not capable of supplying the maximum daily demand, the proposed design shall include  
806 alternative power for the finished water pumps that demonstrates:  
807

808 (i) The combined finished water storage volume and pumping capacity  
809 supplied by alternative power will be at least adequate to provide the maximum daily demand;  
810 and  
811

812 (ii) The alternative power source will include engine generators, engine drive  
813 pumps, or a second independent electrical supply that will provide sufficient power to run the  
814 system.  
815

816 (j) Process equipment, filters and appurtenances, disinfection, chemical feed and  
817 storage, electrical and controls, and pipe galleries shall be located in suitable structures.  
818

819 (k) All equipment not required to be in or on open basins, such as clarifier drives and  
820 flocculators, shall be located in heated, lighted, and ventilated structures.

821  
822 (l) Piping shall be buried below frost level, placed in heated structures, or provided  
823 with heat and insulated.

824  
825 (m) Structure entrances shall be above grade.

826  
827 (n) Selected construction materials shall provide water tightness, corrosion  
828 protection, and resistance to weather variations.

829  
830 (o) NSF/ANSI/CAN 61-2020/NSF/ANSI/CAN 600-2021 certified coatings used to  
831 protect structures, equipment, and piping shall be suitable for atmospheres containing moisture  
832 and low concentrations of chlorine.

833  
834 (p) Surfaces exposed in chemical areas shall be protected from chemical attack.

835  
836 (q) Paints shall not contain lead, mercury, or other toxic metals or chemicals.

837  
838 (r) All enclosed spaces shall be provided with forced ventilation, except pumping  
839 station wetwells or clearwells that meet the following requirements:

840  
841 (i) In areas where there are open treatment units exposed to the room,  
842 ventilation shall be provided to limit relative humidity to less than 85 percent but not less than  
843 six air changes per hour; and

844  
845 (ii) Ventilation in electrical and equipment rooms shall limit the temperature  
846 rise in the room to less than 15 degrees Fahrenheit above ambient with at least six air changes  
847 per hour.

848  
849 (s) Service transformers and other critical electrical equipment shall be located above  
850 the 100-year flood and above grade. Transformers shall be located so that they are remote or  
851 protected by substantial barriers from traffic. Motor controls shall be located in superstructures  
852 and in rooms that do not contain corrosive atmospheres.

853  
854 (t) All treatment facilities shall have a flow-measuring device provided for raw water  
855 influent and clear well effluent and each shall provide totalized flow. The accuracy of the device  
856 shall be at least plus or minus two percent of span and shall meet the following requirements:

857  
858 (i) Automatic controls shall be designed to permit manual override; and

859  
860 (ii) The meter shall also record the instantaneous flow rate.

861  
862 (u) Water treatment plants with a capacity of 500,000 gpd or more shall be provided  
863 with continuous water turbidimeters (including recorders) that demonstrate compliance with the

864 Guidance Manual for Compliance with the Surface Water Treatment Rules, Turbidity  
865 Provisions.

866

867 **Section 11. Source Development.**

868

869 (a) 2018 TSS, parts 3.1.4.1-3.1.4.1(i), surface water, structures, design of intake  
870 structures; 3.1.4.3-3.1.4.3(f) surface water, structures, offstream raw water storage reservoir;  
871 3.1.6-3.1.6.3, surface water, impoundments and reservoirs; 3.2.3.2, groundwater, location,  
872 continued sanitary protection; 3.2.4-3.2.4.14(b)(4), groundwater, general well construction;  
873 3.2.5-3.2.5.4, groundwater, testing and records; 3.2.6.1-3.2.6.1(c), groundwater, aquifer types  
874 and construction methods--special conditions, sand or gravel wells; 3.2.6.2-3.2.6.2(b)(7),  
875 groundwater, aquifer types and construction methods--special conditions, gravel pack material;  
876 3.2.6.4-3.2.6.4(d), groundwater, aquifer types and construction methods--special conditions,  
877 infiltration lines; 3.2.6.5-3.2.6.5(b), groundwater, aquifer types and construction methods--  
878 special conditions, limestone or sandstone wells; 3.2.7.3-3.2.7.3(c)(3), groundwater, well pumps,  
879 discharge piping and appurtenances, discharge piping; 3.2.7.4-3.2.7.4(d), groundwater, well  
880 pumps, discharge piping and appurtenances, pitless well units; 3.2.7.6, groundwater, well pumps,  
881 discharge piping and appurtenances, casing vent; 3.2.7.7-3.2.7.7(b), groundwater, well pumps,  
882 discharge piping and appurtenances, water level measurement; 3.2.7.8-3.2.7.8(b), groundwater,  
883 well pumps, discharge piping and appurtenances, observation wells; are herein incorporated by  
884 reference.

885

886 (b) Surface water intake structures that operate in the winter shall be capable of  
887 minimizing the formation of ice on the intake.

888

889 (c) Transmission lines and interconnecting process piping shall be capable of  
890 withstanding the forces and conditions they will be subject to and comply with the following  
891 specifications for water service, as applicable:

892

893 (i) AWWA C200;

894

895 (ii) AWWA C207;

896

897 (iii) AWWA C208;

898

899 (iv) AWWA C220;

900

901 (v) AWWA C228;

902

903 (vi) AWWA C300;

904

905 (vii) AWWA C301;

906

907 (viii) AWWA C302;

908

909 (ix) AWWA C303;

- 910
- 911 (x) AWWA C304;
- 912
- 913 (xi) AWWA C900;
- 914
- 915 (xii) AWWA C901;
- 916
- 917 (xiii) AWWA C903;
- 918
- 919 (xiv) AWWA C904;
- 920
- 921 (xv) AWWA C906;
- 922
- 923 (xvi) AWWA C907;
- 924
- 925 (xvii) AWWA C909;
- 926
- 927 (xviii) AWWA C950;
- 928
- 929 (xix) ASTM A53;
- 930
- 931 (xx) ASTM A134;
- 932
- 933 (xxi) ASTM A135;
- 934
- 935 (xxii) ASTM A139;
- 936
- 937 (xxiii) ASTM D2846;
- 938
- 939 (xxiv) ASTM F480;
- 940
- 941 (xxv) ASTM F645;
- 942
- 943 (xxvi) ASTM F877;
- 944
- 945 (xxvii) ASTM F23891;
- 946
- 947 (xxviii) ASTM F2806;
- 948
- 949 (xxix) ASTM F2855;
- 950
- 951 (xxx) ASTM F2969;
- 952
- 953 (xxxi) API 5L:
- 954 (A) Grade B;
- 955



- 956
- 957 (B) Grade X42;
- 958
- 959 (C) Grade X46;
- 960
- 961 (D) Grade X52;
- 962
- 963 (E) Grade X56;
- 964
- 965 (F) Grade X60;
- 966
- 967 (G) Grade X65;
- 968
- 969 (H) Grade X70; or
- 970
- 971 (I) Grade X80.
- 972

973 (d) Designs shall not include any customer service connection from the raw water  
 974 transmission line to the treatment plant unless there are provisions to treat the water to meet the  
 975 requirements of this Chapter, or the sole purpose of the service is for irrigation or agricultural  
 976 water use. For irrigation agricultural services, applicants shall conduct a hazard classification and  
 977 implement appropriate backflow prevention.

978

979 (e) Designs that include groundwater source development shall comply with the  
 980 following requirements:

981 (i) Proposed designs shall include a minimum of:

982 (A) Two wells that are each capable of supplying the average daily  
 983 demand with the largest producing well out of service;

984 (B) One well and finished water storage that together equal twice the  
 985 maximum daily demand; or

986 (C) For public water supplies that are not community water systems or  
 987 nontransient noncommunity water systems, as determined by the Administrator, one well that is  
 988 capable of supplying the maximum daily demand.

989 (ii) Wells shall maintain the following minimum isolation distances:

990 (A) If domestic wastewater is the only wastewater present and the  
 991 design domestic sewage flow is less than 2,000 gpd, the following minimum isolation distance  
 992 shall be maintained:

993

994

995

996

997

998

999

1000 Table 1. Isolation Distances for Domestic Sewage Flows Less than 2,000 gpd

1001

<u>Source of Domestic Wastewater</u>	<u>Minimum Distance to Well</u>
Storm and Sanitary Sewer Collection Systems	50 feet
Septic tank	100 feet
Absorption system	200 feet

1002  
 1003 (B) If domestic wastewater is the only wastewater present and the  
 1004 design domestic sewage flow is greater than 2,000 gpd but less than 10,000 gpd, the following  
 1005 minimum isolation distances shall be maintained:  
 1006

1007 Table 2. Isolation Distances for Domestic Sewage Flows Greater than 2,000 gpd

<u>Source of Domestic Wastewater</u>	<u>Minimum Distance to Well</u>
Storm and Sanitary Sewer Collection Systems	50 feet
Septic tank	100 feet
Absorption system	500 feet

1008  
 1009 (C) If domestic wastewater is the only wastewater present and the  
 1010 design domestic sewage flow is greater than 10,000 gallons per day or non-domestic wastewater  
 1011 is present the required isolation distance shall be determined by a subsurface study, in  
 1012 accordance with the requirements of Water Quality Rules Chapter 3, Section 17(b), but shall not  
 1013 be less than those required in Tables 1 and 2 of this Section.  
 1014

1015 (iii) Wells shall maintain the following minimum isolation distances from  
 1016 buildings and property lines:  
 1017

1018 (A) When a well is outside of a building, the well shall be located so  
 1019 that the the surface casing has a clearance radius of a minimum of 10 feet horizontally and will  
 1020 clear any projection from the building;  
 1021

1022 (B) When a well is located inside a building:  
 1023

1024 (I) The top of the casing and any other well opening shall not  
 1025 terminate in the basement of the building, or in any pit or space that is below natural ground  
 1026 surface unless the well is completed with a properly protected submersible pump or provided  
 1027 with provisions for drainage to the ground surface that is not subject to flooding by surface  
 1028 water;  
 1029

1030 (II) Wells located in a structure shall be accessible to pull the  
 1031 casing, pipe, or pump; and  
 1032

1033 (III) The structure shall have overhead access.  
 1034

1035 (C) Wells shall be located at least 50 feet from any property line.

1036  
1037  
1038  
1039  
1040  
1041  
1042  
1043  
1044  
1045  
1046  
1047  
1048  
1049  
1050  
1051  
1052  
1053  
1054  
1055  
1056  
1057  
1058  
1059  
1060  
1061  
1062  
1063  
1064  
1065  
1066  
1067  
1068  
1069  
1070  
1071  
1072  
1073  
1074  
1075  
1076  
1077  
1078  
1079

(iv) Applicants for wells shall complete testing and maintain records as follows:

(A) Yield and drawdown tests shall be performed on every production well after construction or subsequent treatment and prior to placement of the permanent pump. The test methods shall be clearly indicated in the specifications. The test pump capacity, at maximum anticipated drawdown, shall be at least 1.5 times the design rate anticipated. The well shall be test pumped at the desired yield (design capacity) of the well for at least 24 consecutive hours after stabilized drawdown. Alternatively, the well may be pumped at a rate of 150 percent of the desired yield for at least six continuous hours after stabilized drawdown.

(B) Every well shall be tested for plumbness and alignment in accordance with AWWA A100.

(v) In addition to meeting the requirements of Section 8 of this Chapter, plans for wells developed through acidizing activities shall also include the following elements:

(A) Information on the geology of the area that contains descriptions of:

(I) Known or potential faults, fractures, springs, karst features (such as sinkholes and other similar features) within a one-mile radius of the proposed well; and

(II) Faults and fractures that may extend from the acidized zone into overlying and underlying geologic formations and a description of any measures that will be taken to ensure that the acidized solution does not migrate into any of those geologic formations.

(B) For wells developed within a radius of one mile of existing wells, applicants shall submit plans that analyze the risk and mitigation measures to be taken to prevent impacts to those wells and the risk and mitigation measures for any potential effects to each existing well;

(C) Existing information on the location of other wells (such as water supply, oil and gas, mineral development wells) within a one-mile radius of the proposed well, including any wells that intercept the acidized zone, and for wells that intercept the acidized zone:

(I) An analysis of whether or not those wells that intercept the acidized zone have been properly plugged and abandoned;

(II) An analysis of whether or not those wells have been properly cased and cemented; and

1080 (III) A description of what measures will be or have been taken  
1081 to prevent the acidized solution from migrating vertically in the annular space or casing of the  
1082 existing wells into overlying or underlying geologic formations.

1083  
1084 (D) A description of the borehole drilling phase and what measures  
1085 will be taken to minimize the introduction of lost circulation materials into aquifers when  
1086 encountering under-pressured geologic formations or other factors that may lead to a loss of  
1087 circulation;

1088  
1089 (E) A description of the acid injection process and the measures that  
1090 will be taken to ensure that injection pressures do not create fractures in the overlying and  
1091 underlying geologic formations and through which the acidized solution may migrate;

1092  
1093 (F) A description of the volume and content of the acid and any other  
1094 chemical compounds to be used during acidizing activities, including the management of the acid  
1095 and chemical compounds prior to acidizing and final disposition of any acid, water, or chemical  
1096 mixtures recovered from the well after acidizing activities are completed;

1097  
1098 (G) A description of the measures that will be or have been taken to  
1099 ensure that the recovery of the acidized solution is of sufficient duration and volume to eliminate  
1100 the potential for acidic impacts to other wells completed within the injection zone; and

1101  
1102 (H) A description of the methods to be performed to establish the  
1103 placement and integrity of the annular seal and casing prior to acidization of the well.

1104  
1105 (vi) During any well construction or modification, the well and surrounding  
1106 area shall be adequately protected to prevent any groundwater contamination. Surface water shall  
1107 be diverted away from the construction area.

1108  
1109 (vii) All wells shall comply with the following construction standards:

1110  
1111 (A) Dug wells shall be constructed according to the State Engineer's  
1112 standards;

1113  
1114 (B) Drilled, driven, jetted, or bored wells shall have an unperforated  
1115 casing that extends from a minimum of 12 inches above the concrete surface and 18 inches  
1116 above natural ground surface and the design shall demonstrate compliance with Water Quality  
1117 Rules, Chapter 26, Section 8;

1118  
1119 (C) In gravel-packed wells or artificial filter-packed wells, aquifers  
1120 containing inferior quality water shall be sealed by pressure grouting, or with special packers or  
1121 seals, to prevent such water from moving vertically in gravel-packed portions of the well.  
1122 Gravel-packed wells shall meet the following sealing requirements:

1123

1124 (I) If a permanent surface casing is not installed, the annular  
1125 opening between the casing and the drill hole shall be sealed in the top 10 feet with concrete or  
1126 cement grout; or

1127  
1128 (II) If a permanent surface casing is installed, it shall extend to  
1129 a depth of at least 10 feet. The annular opening between this outer casing and the inner casing  
1130 shall be covered with a metal or cement seal.

1131  
1132 (D) When naturally flowing water is encountered in a well,  
1133 unperforated casing shall extend into the confining layer overlying the water-bearing zone. This  
1134 casing shall be adequately sealed with cement grout into the confining zone and shall extend at  
1135 least 10 feet into the target aquifer to prevent both surface and subsurface leakage from the  
1136 water-bearing zone. The method of construction shall be such that during the placing of the grout  
1137 and the time required for it to set, no water shall flow through or around the annular space  
1138 outside the casing, and no water pressure sufficient to disturb the grout prior to final set shall  
1139 occur. Drilling operations shall not be continued into the water-bearing zone until the grout has  
1140 set completely. If leakage occurs around the well casing or adjacent to the well, the well shall be  
1141 recompleted with any seals, packers, or casing necessary to eliminate the leakage completely.

1142  
1143 (I) Flowing wells shall be constructed to control the flow of  
1144 water from the well. The well grouting shall be engineered to prevent the movement of water  
1145 along the well casing and to prevent the migration of pressurized water into upper aquifers. A  
1146 flow control device shall be installed into the wellhead to control the flow of water from the well.  
1147 The well discharge or overflow line installations must connect to the well casing at least 12  
1148 inches above ground and be valved. The size of the air gap between the overflow line from the  
1149 well to drainage structure shall be twice the diameter of the well overflow pipe. Overflow water  
1150 must be drained and diverted to prevent ponding around the well casing.

1151  
1152 (II) There shall be no direct connection between any discharge  
1153 pipe and a sewer or other source of pollution.

1154  
1155 (E) If mineralized water or water known to be polluted is encountered  
1156 during the construction of a well, the aquifer or aquifers containing such inferior quality of water  
1157 shall be adequately cased or sealed off to prevent water from entering the well and to prevent  
1158 water from moving up or down the annular space.

1159  
1160 (I) For wells that penetrate multiple aquifers, mineralized  
1161 water shall be excluded from the well if water is taken from other, non-mineralized aquifers.

1162  
1163 (II) Applicants that propose to use mineralized water as a  
1164 public water supply shall demonstrate that any necessary treatment will comply with the drinking  
1165 water quality standards required by 40 CFR Part 141.

1166  
1167 (F) Existing oil or gas wells, private water wells, or exploration test  
1168 holes that can be completed to conform to all minimum construction standards required by this

1169 Chapter may be converted for use as a public water supply well. The permit application shall  
1170 identify all actions to be completed to achieve compliance with this Chapter.

1171  
1172 (viii) The minimum grout thickness for public water supply wells shall be  
1173 determined in accordance with AWWA Standard A100, part 4.7.8.3.

1174  
1175 (ix) Well seals shall meet the following requirements:

1176  
1177 (A) The annular space shall be sealed to protect against contamination  
1178 or pollution by the entrance of surface or shallow subsurface waters; and

1179  
1180 (B) Annular seals shall be installed to provide protection for the casing  
1181 against corrosion, to ensure the structural integrity of the casing, and to stabilize the upper  
1182 formation.

1183  
1184 (x) Upper terminal well designs that include a concrete floor shall  
1185 demonstrate a slope of one inch per foot away from the casing.

1186  
1187 (xi) Well pumps shall be located at a point above the top of the well screen.

1188  
1189 (xii) An accessible check valve that is not located in the pump column shall be  
1190 installed in the discharge line of each well between the pump and the shut-off valve. Additional  
1191 check valves shall be located in the pump column as necessary to prevent negative pressures on  
1192 the discharge piping.

1193  
1194 (xiii) A pitless adaptor or well house shall be used where needed to protect the  
1195 water system from freezing.

1196  
1197 (xiv) A frost pit may be used only in conjunction with a properly protected  
1198 pitless adaptor.

1199  
1200 (xv) Wells with diameters that are greater than four inches shall be equipped  
1201 with an air line for water level measurements or, in the case of a flowing artesian well, with a  
1202 pressure gauge that will indicate pressure.

1203  
1204 (xvi) An instantaneous and totalizing flow meter equipped with nonvolatile  
1205 memory shall be installed on the discharge line of each well in accordance with the  
1206 manufacturer's specifications. Meters installed on systems with variable frequency drives shall  
1207 be capable of accurately reading the full range of flow rates.

1208  
1209 (xvii) Test wells and groundwater sources that are sealed for plugging and  
1210 abandonment in accordance with requirements of Water Quality Rules Chapter 26, Section 11  
1211 shall be sealed by filling with neat cement grout. The filling materials shall be applied to the well  
1212 hole through a pipe, or tremie.

1213

1214 (xviii) Designs for groundwater sources that are subject to 40 CFR  
1215 141.402(a)(1)(i) and either 40 CFR 141.402(a)(1)(ii) or 40 CFR 141.402(a)(1)(iii) shall  
1216 demonstrate compliance with 40 CFR 141.402(e).

1217  
1218 (f) Facilities that include spring development shall meet the following requirements:  
1219

1220 (i) Spring collection systems shall be constructed to collect spring water  
1221 while preventing contamination of the source from the ground surface or other contaminant  
1222 sources.

1223  
1224 (ii) Seepage springs shall have a trench for the collection site that extends at  
1225 least six inches into the impervious layer, but not entirely through the impervious layer.  
1226 Concentrated springs shall be developed down to bedrock.

1227  
1228 (iii) A bed of clean and disinfected rock that extends the width of the spring  
1229 from which water is being collected shall be installed at the collection site.

1230  
1231 (iv) The collection site shall:  
1232

1233 (A) Be covered with 60 mil plastic sheeting or an equivalent puncture-  
1234 proof and water-proof barrier; and  
1235

1236 (B) Be protected from damage during back-fill and re-grading of the  
1237 site to the original surface elevation with protective fabric or sand.  
1238

1239 (v) Collecting walls shall be:  
1240

1241 (A) Constructed immediately downstream of the collection site; and  
1242

1243 (B) Made of concrete, or other material that meets the requirements of  
1244 Section 15(b)(ii) of this Chapter;  
1245

1246 (vi) The spring water collection pipe shall be installed in accordance with the  
1247 USDA NRCS Part 631 National Engineering Handbook, Chapter 32, part 631.3201(b)(iii) for  
1248 delivery pipes and shall meet the following requirements:  
1249

1250 (A) The size of the collection pipe shall be sufficient to convey the  
1251 flow of the spring; and  
1252

1253 (B) Pipe material and appurtenances shall comply with allowable well  
1254 construction material for water distribution in accordance with the standards listed in paragraph  
1255 (c) of this Section.  
1256

1257 (vii) Appropriate bedding and cover material shall protect the spring collection  
1258 system from damage and freezing.  
1259

1260 (viii) The Administrator shall determine the spring protection area, based on the  
 1261 information submitted in the engineering design report required by Section 8 of this Chapter,  
 1262 which shall be no less than the isolation distances in (e)(ii) of this Section. The Administrator  
 1263 may require additional setback distances if the engineering design report demonstrates the  
 1264 additional distance is required to prevent contamination of the source from the ground surface or  
 1265 other contaminant sources.

1266  
 1267 (ix) All potential sources of contamination shall be removed from the spring  
 1268 protection area.

1269  
 1270 (x) The spring collection site shall include fencing or other protective features  
 1271 that are constructed and secured to exclude large animals and unauthorized persons from  
 1272 entering the protection area.

1273  
 1274 (A) Fencing shall be designed to withstand animals and snow loading.  
 1275 Other protective systems may be proposed.

1276  
 1277 (B) Fencing shall include an entry point to allow access by authorized  
 1278 persons for inspection and maintenance activities.

1279  
 1280 (xi) The spring collection site shall include a diversion ditch that is constructed  
 1281 on the upstream side of the spring collection site to route surface water flows away from the  
 1282 collection area. The diversion ditch shall be located a minimum of 10 feet away from the  
 1283 collection wall.

1284  
 1285 (xii) The spring collection site shall be equipped to disinfect water prior to  
 1286 distribution and shall include sampling ports before and after the disinfection application point.  
 1287 The equipment shall be maintained and available to operate for its intended use.

1288  
 1289 (xiii) Spring box designs shall comply Section 15(a), (b), (f-j), and (l) of this  
 1290 Chapter. Combined spring box and finished water storage designs shall comply with Section 15  
 1291 of this Chapter.

1292  
 1293 (xiv) All designs for the spring collector box and collecting walls shall be  
 1294 performed by a Wyoming registered professional engineer. The plans or contractor furnished  
 1295 information shall be signed and sealed by a Wyoming registered professional engineer.

1296  
 1297 **Section 12. Treatment.**

1298  
 1299 (a) 2018 TSS, parts 4.2.1(b), presedimentation, inlets; 4.2.1(c), presedimentation,  
 1300 bypass; 4.2.2, coagulation; 4.2.2(a), coagulation, mixing; 4.2.2(b), coagulation, equipment;  
 1301 4.2.2(c), coagulation, location; 4.2.4(b), sedimentation, inlet devices; 4.2.4(c), sedimentation,  
 1302 velocity; 4.2.4(d)-4.2.4(d)(4), sedimentation, outlet devices; 4.3.1.1, rapid rate gravity filters,  
 1303 pretreatment; 4.3.1.4-4.3.1.4(o), rapid rate gravity filters, structural details and hydraulics;  
 1304 4.3.1.6(a), filter material, total depth; 4.3.1.6(b), filter material, uniformity coefficient; 4.3.1.6(c),  
 1305 filter material, minimum; 4.3.1.6(d)(1)-4.3.1.6(d)(1)(f), filter material, types of filter media,



1306 anthracite; 4.3.1.6(d)(2)-4.3.1.6(d)(2)(.d), filter material, types of filter media, sand filter;  
 1307 4.3.1.6(d)(4)-4.3.1.6(d)(4)(.d), filter material, types of filter media, granular activated carbon  
 1308 (GAC); 4.3.1.6(e)(1)-4.3.1.6(e)(1)(.b), filter material, support media, topedo sand; 4.3.3.6-  
 1309 4.3.3.6(b), diatomaceous earth filtration, pre-coat; 4.3.3.7-4.3.3.7(c), diatomaceous earth  
 1310 filtration, body feed; 4.3.3.8-4.3.3.8(e), diatomaceous earth filtration, filtration; 4.3.3.10(a)(1),  
 1311 diatomaceous earth filtration, appurtenances, sampling taps; 4.3.3.10(a)(2), diatomaceous earth  
 1312 filtration, appurtenances, loss of head; 4.3.3.10(a)(3), diatomaceous earth filtration,  
 1313 appurtenances, rate of flow indicator; 4.3.3.10(a)(4), diatomaceous earth filtration,  
 1314 appurtenances, throttling valve; 4.3.4.2, slow sand filters, number; 4.3.4.4, slow sand filters, rates  
 1315 of filtration; 4.3.4.5, slow sand filters, underdrains; 4.3.4.6-4.3.4.6(e), slow sand filters, filter  
 1316 material; 4.3.4.7, slow sand filters, filter gravel; 4.3.4.8, slow sand filters, depth of water on filter  
 1317 beds; 4.3.4.9(b) and (e), slow sand filters, control appurtenances; 4.3.4.9(f), slow sand filters,  
 1318 control appurtenances; 4.4.1(a), disinfection, contact time, CT, and point(s) of application;  
 1319 4.4.1(b), disinfection, contact time, CT, and point(s) of application; 4.4.3(a)-(d), disinfection,  
 1320 testing equipment; 4.4.4.3, chlorine, automatic switch-over; 4.4.4.7, chlorine, cross-connection  
 1321 protection; 4.4.4.8, chlorine, pipe material; 4.4.5, chloramines; 4.4.6.1, ozone, design  
 1322 considerations; 4.4.6.2, ozone, feed gas preparation; 4.4.6.3, ozone, ozone generator; 4.4.6.4,  
 1323 ozone, ozone contactors; 4.4.6.5, ozone, ozone destruction unit; 4.4.6.6, ozone, piping materials;  
 1324 4.4.6.7, ozone, joints and connections; 4.4.6.8, ozone, instrumentation; 4.4.6.9, ozone, alarms;  
 1325 4.4.6.11, ozone, construction considerations; 4.5.1, softening, lime or lime-soda process; 4.5.1.1,  
 1326 softening, lime or lime-soda process, hydraulics; 4.5.1.3, softening, lime or lime-soda process,  
 1327 chemical feed point; 4.5.1.4, softening, lime or lime-soda process, rapid mix; 4.5.1.5, softening,  
 1328 lime or lime-soda process, stabilization; 4.5.1.6-4.5.1.6(b), softening, lime or lime-soda process,  
 1329 sludge collection; 4.5.1.7, softening, lime or lime-soda process, sludge disposal; 4.5.1.8,  
 1330 softening, lime or lime-soda process, disinfection; 4.5.1.9, softening, lime or lime-soda process,  
 1331 plant start-up; 4.5.2.1, cation exchange process, pre-treatment requirements; 4.5.2.2, cation  
 1332 exchange process, design; 4.5.2.3, cation exchange process, design; 4.5.2.4, cation exchange  
 1333 process, depth of resin; 4.5.2.5, cation exchange process, flow rates; 4.5.2.7, cation exchange  
 1334 process, underdrains and supporting gravel; 4.5.2.8, cation exchange process, brine distribution;  
 1335 4.5.2.9, cation exchange process, cross-connection control; 4.5.2.10, cation exchange process,  
 1336 bypass piping and equipment; 4.5.2.11, cation exchange process, additional limitations;  
 1337 4.5.2.13(a)-4.5.2.13(f), cation exchange process, brine and salt storage tanks; 4.5.2.14, cation  
 1338 exchange process, salt and brine storage capacity; 4.5.2.15, cation exchange process, brine pump  
 1339 or eductor; 4.5.2.18, cation exchange process, construction materials; 4.5.2.19, cation exchange  
 1340 process, housing; 4.5.3, water quality test equipment; 4.6, anion exchange treatment; 4.6.1, anion  
 1341 exchange treatment, pre-treatment requirements; 4.6.2-4.6.2(b), anion exchange treatment,  
 1342 design; 4.6.3, anion exchange treatment, exchange capacity; 4.6.4, anion exchange treatment,  
 1343 number of units; 4.6.5, anion exchange treatment, type of resin; 4.6.6, anion exchange treatment,  
 1344 flow rates; 4.6.7, anion exchange treatment, free board; 4.6.8-4.6.8(b), anion exchange treatment,  
 1345 miscellaneous appurtenances; 4.6.9, anion exchange treatment, cross-connection control; 4.6.10,  
 1346 anion exchange treatment, construction materials; 4.6.11, anion exchange treatment, housing;  
 1347 4.6.12, anion exchange treatment, pre-conditioning of the resin; 4.6.13, anion exchange  
 1348 treatment, waste disposal; 4.6.14, anion exchange treatment, water quality test equipment; 4.7,  
 1349 aeration; 4.7.1-4.7.1(i), aeration, natural draft aeration; 4.7.2-4.7.2(l), aeration, forced or induced  
 1350 draft aeration; 4.7.3-4.7.3(e), aeration, spray aeration; 4.7.4-4.7.4(b), aeration, pressure  
 1351 aeration; 4.7.5, aeration, packed tower aeration; 4.7.5.1-4.7.5.1(f), aeration, packed tower

1352 aeration, process design; 4.7.5.2-4.7.5.2(b), aeration, packed tower aeration, materials of  
 1353 construction; 4.7.5.3-4.7.5.3(l), aeration, packed tower aeration, water flow system; 4.7.5.4-  
 1354 4.7.5.4(f), aeration, packed tower aeration, air flow system; 4.7.5.5-4.7.5.5(m), aeration, packed  
 1355 tower aeration, other features that shall be provided; 4.7.5.6-4.7.5.6(b), aeration, packed tower  
 1356 aeration, environmental factors; 4.7.6, aeration, other methods of aeration; 4.7.7, aeration,  
 1357 protection of aerators; 4.7.8, aeration, disinfection; 4.7.9, aeration, bypass; 4.7.10, aeration,  
 1358 corrosion control; 4.7.11, aeration, quality control; 4.8, iron and manganese control; 4.8.1, iron  
 1359 and manganese control, removal by oxidation, detention and filtration, oxidation; 4.8.1.2, iron  
 1360 and manganese control, removal by oxidation, detention and filtration, detention; 4.8.1.3, iron  
 1361 and manganese control, removal by oxidation, detention and filtration, filtration; 4.8.2, iron and  
 1362 manganese control, removal by the lime-soda softening process; 4.8.3-4.8.3(f), iron and  
 1363 manganese control, removal by manganese coated media filtration; 4.8.4, iron and manganese  
 1364 control, removal by ion exchange; 4.8.6-4.8.6(d), iron and manganese control, sequestration by  
 1365 polyphosphates; 4.8.7-4.8.7(e), iron and manganese control, sequestration by sodium silicates;  
 1366 4.8.8, iron and manganese control, sampling taps; 4.9.3-4.9.3(e), stabilization and corrosion  
 1367 control, carbon dioxide addition; 4.9.5(c)-4.9.5(c)(9), stabilization and corrosion control,  
 1368 phosphates, design; 4.9.6, stabilization and corrosion control, pH/alkalinity adjustment; 4.9.6.1,  
 1369 stabilization and corrosion control, pH/alkalinity adjustment; 4.9.6.1(a), stabilization and  
 1370 corrosion control, pH/alkalinity adjustment, chemicals; 4.9.6.1(a)(1.), stabilization and corrosion  
 1371 control, pH/alkalinity adjustment, chemicals, caustic soda; 4.9.6.1(a)(2.), stabilization and  
 1372 corrosion control, pH/alkalinity adjustment, chemicals, soda ash; 4.9.6.1(a)(3.), stabilization and  
 1373 corrosion control, pH/alkalinity adjustment, chemicals, lime; 4.9.6.1(a)(4.), stabilization and  
 1374 corrosion control, pH/alkalinity adjustment, chemicals, sodium bicarbonate; 4.9.6.1(b)-  
 1375 4.9.6.1(b)(4.), stabilization and corrosion control, pH/alkalinity adjustment, simultaneous  
 1376 compliance; 4.9.6.1(c)-4.9.6.1(c)(4.), stabilization and corrosion control, pH/alkalinity  
 1377 adjustment, alkalinity/pH adjustment systems; 4.10, taste and odor control; 4.10.1, taste and odor  
 1378 control, flexibility; 4.10.2, taste and odor control, chlorination; 4.10.3, taste and odor control,  
 1379 chlorine dioxide; 4.10.4-4.10.4(f), taste and odor control, powdered activated carbon; 4.10.8,  
 1380 taste and odor control, potassium permanganate; 4.11, membrane technologies for public water  
 1381 supplies; 4.11.1-4.11.1(c), membrane technologies for public water supplies, pilot  
 1382 study/preliminary investigations; 4.11.2, membrane technologies for public water supplies,  
 1383 general design considerations; 4.11.2(a), membrane technologies for public water supplies,  
 1384 general design considerations, pretreatment; 4.11.2(b), membrane technologies for public water  
 1385 supplies, general design considerations, materials; 4.11.2(c), membrane technologies for public  
 1386 water supplies, general design considerations, useful life of membranes; 4.11.2(d), membrane  
 1387 technologies for public water supplies, general design considerations, membrane integrity and  
 1388 finished water monitoring; 4.11.2(e), membrane technologies for public water supplies, general  
 1389 design considerations, bypass water; 4.11.2(f)-4.11.2(f)(6.), membrane technologies for public  
 1390 water supplies, general design considerations, membrane cleaning; 4.11.2(g), membrane  
 1391 technologies for public water supplies, general design considerations, controls; 4.11.2(h)-  
 1392 4.11.2(h)(13.), membrane technologies for public water supplies, general design considerations,  
 1393 alarms; 4.11.2(i), membrane technologies for public water supplies, general design  
 1394 considerations, compressed air; 4.11.2(j), membrane technologies for public water supplies,  
 1395 general design considerations, operation frequency; 4.11.2(k), membrane technologies for public  
 1396 water supplies, general design considerations, cross connection control; 4.11.2(l)-4.11.2(l)(4.),  
 1397 membrane technologies for public water supplies, general design considerations, redundancy of

1398 critical components; 4.11.3-4.11.3(h), membrane technologies for public water supplies, systems  
1399 treating surface water or GWUDI; 5.4.7-5.4.7(f), specific chemicals, fluoride; 5.4.8, specific  
1400 chemicals, activated carbon; 9.3, precipitative softening sludge; 9.3(a)-9.3(a)(2.), precipitative  
1401 softening sludge, lagoons; 9.4.1-9.4.1(h), alum sludge, lagoons; 9.5, red water waste; 9.5.1-  
1402 9.5.1(k), red water waste, sand filters; 9.5.2-9.5.2(g), red water waste, lagoons; 9.5.3, red water  
1403 waste, discharge to community sanitary sewer; are herein incorporated by reference.

1404

1405 (b) The capacity of the water treatment or water production system shall be designed  
1406 for the maximum daily demand at the design year.

1407

1408 (c) Presedimentation shall be required for raw waters that have episodes of turbidity  
1409 in excess of 1,000 Nephelometric turbidity units (NTU) for a period of one week or longer.

1410

1411 (d) Basins shall meet the following requirements:

1412

1413 (i) Basins without mechanical sludge collection equipment shall have a  
1414 minimum detention time of three days;

1415

1416 (ii) Basins with mechanical sludge collection equipment shall have a  
1417 minimum detention time of three hours;

1418

1419 (iii) Basins shall have a bottom slope to drain of ¼ inch per foot without  
1420 mechanical sludge collection equipment and two inches per foot with mechanical sludge  
1421 collection equipment; and

1422

1423 (iv) Basins shall have a minimum of one, eight-inch drain line to completely  
1424 dewater the facility.

1425

1426 (e) Rapid dispersal of chemicals throughout the water shall be accomplished by  
1427 mechanical mixers, jet mixers, static mixers, or hydraulic jump and shall meet the following  
1428 requirements:

1429

1430 (i) For mechanical mixers, the minimum  $Gt$  (velocity gradient (sec<sup>-1</sup>) x  $t$   
1431 (sec)) provided at maximum daily flow shall be 27,000;

1432

1433 (ii) The detention time in a flash mixing chamber shall not exceed 30 seconds  
1434 at maximum daily flow conditions; and

1435

1436 (iii) The basin shall have a drain.

1437

1438 (f) Flocculation shall comply with the following requirements:

1439

1440 (i) Mechanical flocculators shall be used for low-velocity agitation of  
1441 chemically treated water.

1442

1443 (ii) The minimum detention time of 10 minutes shall be provided.

- 1444  
1445 (iii) Basins shall have a minimum of one drain line to dewater the facility.  
1446  
1447 (iv) The velocity gradient (G value) shall be adjustable through the use of  
1448 variable speed drives. The velocity gradient for single basin systems shall be 30 sec<sup>-1</sup>, 20 sec<sup>-1</sup>  
1449 in the final basin of a two-stage system, and 10 sec<sup>-1</sup> in the final basin of a three-stage system.  
1450  
1451 (v) The tip speed for a single-speed drive system shall not exceed 3 feet per  
1452 second (ft/sec). Variable speed drives shall provide tip speeds between 0.5 and 3.0 ft/sec.  
1453  
1454 (vi) The velocity of flocculated water through pipes or conduits to settling  
1455 basins shall not be less than 0.5 ft/sec or greater than 1.5 ft/sec.  
1456  
1457 (g) Sedimentation basins shall comply with the following requirements:  
1458  
1459 (i) The maximum diameter in circular basins shall be 80 feet.  
1460  
1461 (ii) The minimum basin side water depth shall be eight feet if mechanical  
1462 sludge collection equipment is provided or basin sludge hopper segments are less than 100  
1463 square feet in surface area and 15 feet if basins are manually cleaned.  
1464  
1465 (iii) The outer walls of the settling basin shall extend at least 12 inches above  
1466 the surrounding ground and provide at least 12 inches of freeboard to the water surface. Where  
1467 the basin walls are less than four feet above the surrounding ground, a fence or other debris  
1468 barrier shall be provided on the wall.  
1469  
1470 (iv) Basin bottoms shall slope toward the drain at not less than one inch per  
1471 foot where mechanical sludge collection equipment is provided and ¼ inch per foot where no  
1472 mechanical sludge collection equipment is provided.  
1473  
1474 (v) The basin overflow rate shall not exceed 1,000 gpd/ft<sup>2</sup> at design  
1475 conditions.  
1476  
1477 (vi) Mechanical sludge collection shall be provided if settleable organics are  
1478 present in the water or the source water exceeds secondary maximum contaminant levels  
1479 identified at 40 CFR 143.3.  
1480  
1481 (vii) Pipes for removing sludge shall not be less than six inches in diameter and  
1482 arranged to facilitate cleaning. Valves on sludge lines shall be located outside the tank.  
1483  
1484 (h) Facilities with softening sedimentation or clarification for softened groundwater  
1485 sources shall meet the following requirements:  
1486  
1487 (i) The basin overflow rate shall not exceed 21,000 gpd/ft<sup>2</sup> at the design flow;  
1488 and  
1489

1490 (ii) Mechanical sludge removal shall be provided and shall be designed to  
1491 handle a load of 40 lbs/ft of collector scraper arm length.

1492

1493 (i) Solids contact units are acceptable for combined softening and clarification of  
1494 well water where water quality characteristics are not variable and flow rates are uniform and  
1495 consistent. Solids contact units shall meet the requirements of paragraphs (c) and (e) of this  
1496 Section and may be considered under the following circumstances:

1497

1498 (i) Solids contact units may be considered for use as clarifiers without  
1499 softening when they are designed as conventional sedimentation units; and

1500

1501 (ii) Solids contact units may be used for other treatment processes such as  
1502 rapid mixing or flocculation when the individual components of the units are designed for that  
1503 specific treatment process.

1504

1505 (j) Tube clarifiers that are horizontal or steeply inclined may be used when designed  
1506 as follows:

1507

1508 (i) The maximum flow rate shall be less than 2.0 gpm/ft<sup>2</sup> based on the surface  
1509 area of the basin covered by the tubes;

1510

1511 (ii) The top of the tubes shall be more than 12 inches from the underside of  
1512 the launder and more than 18 inches from the water surface and the spacing of the effluent  
1513 launder shall not be more than three times the distance from the water surface to the top of the  
1514 tube modules;

1515

1516 (iii) Sludge shall be removed using 45-degree or steeper hoppers bottoms,  
1517 mechanical devices that move the sludge to hoppers, or devices that remove settled sludge from  
1518 the basin floor using differential hydraulic level; and

1519

1520 (iv) A method of tube cleaning shall be provided that may include provisions  
1521 for a rapid reduction in clarifier water surface elevation, a water jet spray system, or an air scour  
1522 system. If cleaning is automatic, controls shall cease clarifier operation during tube cleaning and  
1523 a 20-minute rest period.

1524

1525 (k) Filtration systems shall comply with the following requirements:

1526

1527 (i) Vertical or horizontal pressure filters shall not be used on surface waters.  
1528 Pressure filters may be used for groundwater filtration, including iron and manganese removal;

1529

1530 (A) Slow rate sand filters may be used when maximum turbidity is less  
1531 than 50 NTU and the turbidity present is not caused by colloidal clay; and

1532

1533 (B) Maximum color shall not exceed 30 units.

1534

1535 (ii) Washwater troughs shall comply with the following requirements:

- 1536  
 1537  
 1538 filter area;
- 1539  
 1540 (B) The minimum distance between the bottom of the trough and the  
 1541 top of the unexpanded media shall be 12 inches;
- 1542  
 1543 (C) The minimum distance between the weir of the trough and the  
 1544 unexpanded media shall be 30 inches;
- 1545  
 1546 (D) There shall be no more than six feet clear distance between  
 1547 troughs;
- 1548  
 1549 (E) The trough and wastewater line shall be sized for a filter backwash  
 1550 rate of 20 gpm/ft<sup>2</sup> plus a surface wash rate of 2 gpm/ft<sup>2</sup>;
- 1551  
 1552 (F) The backwash system shall be sized to provide a minimum  
 1553 backwash flowrate of 20 gpm/ft<sup>2</sup> or a rate necessary to provide a 50 percent expansion of the  
 1554 filter bed;
- 1555  
 1556 (G) The system and wash water storage shall be designed to provide  
 1557 two, 20-minute washes in rapid succession and shall meet the following requirements:
- 1558  
 1559 (I) If only one filter is provided, the backwash system needs to  
 1560 provide only one 20-minute backwash; and
- 1561  
 1562 (II) If pumps are used to convey water to the filter(s) or to the  
 1563 wash water tank, two equivalent pumps shall be provided.
- 1564  
 1565 (H) Washwater shall be filtered and disinfected;
- 1566  
 1567 (I) The washwater rate shall be controlled on the main wash water line  
 1568 and the flowrates shall be metered and indicated;
- 1569  
 1570 (J) Air-assisted backwash systems may be used when the design  
 1571 precludes disturbing the gravel support and the minimum flowrate for air-assisted backwash shall  
 1572 be 12 gpm/ft<sup>2</sup>;
- 1573  
 1574 (K) A surface wash system shall be provided and shall meet the  
 1575 following requirements:
- 1576  
 1577 (I) The system shall be capable of supplying 0.5 gpm/ft<sup>2</sup> for a  
 1578 system with rotating arms and 2 gpm/ft<sup>2</sup> for fixed nozzles, at a minimum pressure of 50 psi; and
- 1579  
 1580 (II) The surface wash can be air-assisted.
- 1581

1582 (L) Both backwash and surface wash supply systems shall be provided  
 1583 with adequate backflow prevention;

1584  
 1585 (iii) Single media beds shall use either clean crushed anthracite or a sand and  
 1586 anthracite mixture, the media shall have an effective size of 0.45 – 0.55 mm and a uniformity  
 1587 coefficient not greater than 1.65, and shall meet the following requirements:

1588  
 1589 (A) When gravel is used as supporting media, it shall consist of coarse  
 1590 aggregate in which most of it is round and of similar size and shape;

1591  
 1592 (B) Gravel as supporting media shall have sufficient strength and  
 1593 hardness to resist degradation during handling and use, be free of harmful materials and exceed  
 1594 the minimum density requirements; and

1595  
 1596 (C) The gravel shall also comply with AWWA B100 specifications.

1597  
 1598 (iv) Dual media coal sand filters shall consist of a coarse layer of coal not less  
 1599 than 15 inches deep above a layer of fine sand not less than eight inches deep on a torpedo sand  
 1600 or garnet layer of support not less than three inches on gravel support.

1601  
 1602 (v) Filter bottoms and strainer systems shall be limited to pipe, perforated pipe  
 1603 laterals, tile block, and perforated tile block. Perforated plate bottoms or plastic nozzles shall not  
 1604 be used.

1605  
 1606 (vi) Every filter shall have:

1607  
 1608 (A) Influent and effluent taps;

1609  
 1610 (B) A head loss gauge;

1611  
 1612 (C) An indicating effluent turbidimeter;

1613  
 1614 (D) A waste drain for draining the filter component to waste;

1615  
 1616 (E) A filter rate flow meter;

1617  
 1618 (F) Polymer feed facilities including polymer mixing, storage tank and  
 1619 at least one feed pump for each filter compartment; and

1620  
 1621 (G) Recorders on the turbidimeters if the facility has a capacity in  
 1622 excess of 0.5 MGD.

1623  
 1624 (vii) Filter rate control shall be such that the filter is not surged. The filter rate  
 1625 of flow shall not change more than 0.3gpm/ft<sup>2</sup> per minute. A filter that stops and restarts during a  
 1626 cycle shall have a filter-to-waste system installed. Declining flow rate filters shall not be used

1627 unless the flow rate for each filter is controlled to a rate less than allowed in paragraph (j)(iii) of  
1628 this Section and there are four more individual filters.

1629  
1630 (viii) A filter to waste cycle shall be provided after the filter backwash  
1631 operation. The filter to waste cycle shall be at least 10 minutes.

1632  
1633 (ix) Multi-media filter beds shall contain a depth of fine media made up of  
1634 anthracite (specific gravity 1.5), silica sand (specific gravity 2.6), and garnet sand or ilemite  
1635 (specific gravity 4.2-4.5). The bed depths and distribution shall be determined by the water  
1636 quality and shall meet the following requirements:

1637  
1638 (A) There shall not be less than 10 inches of fine sand and 24 inches of  
1639 anthracite;

1640  
1641 (B) The relative size of the media shall be such that the hydraulic  
1642 grading of the material during backwash will result in a pore space that progressively goes from  
1643 coarse to fine in the direction of flow;

1644  
1645 (C) The multi-media shall be supported on two layers of special high-  
1646 density gravel placed above the conventional silica gravel supporting bed;

1647  
1648 (D) The special gravel shall have a specific gravity not less than 4.2;

1649  
1650 (E) The bottom layer shall consist of particles passing U.S. Standard 5  
1651 mesh sieves and retained in U.S. Standard 12 mesh sieves and shall be 1 ½ inches thick; and

1652  
1653 (F) The top layer shall consist of particles passing U.S. Standard 12  
1654 mesh sieves and retained in U.S. Standard 20 mesh sieves and shall be 1 ½ inches thick.

1655  
1656 (x) Diatomaceous earth filtration shall comply with the following  
1657 requirements:

1658  
1659 (A) Diatomaceous earth filters may be used under the following  
1660 circumstances:

1661  
1662 (I) To remove turbidity from surface waters where turbidities  
1663 entering the filters do not exceed 10 NTU and where total raw water coliforms do not exceed 100  
1664 organisms/100 mL;

1665  
1666 (II) Where the raw water quality exceeds the previously  
1667 mentioned limits when flocculation and sedimentation are used preceding the filters; and

1668  
1669 (III) To remove iron from groundwaters.

1670  
1671 (B) The proposed diatomaceous earth filtration shall include pressure  
1672 or vacuum type units; and



1673  
1674  
1675  
1676  
1677  
1678  
1679  
1680  
1681  
1682  
1683  
1684  
1685  
1686  
1687  
1688  
1689  
1690  
1691  
1692  
1693  
1694  
1695  
1696  
1697  
1698  
1699  
1700  
1701  
1702  
1703  
1704  
1705  
1706  
1707  
1708  
1709  
1710  
1711  
1712  
1713  
1714  
1715  
1716

(C) A precoating system shall be provided.

(D) The proposed diatomaceous earth filtration shall include a continuous monitoring turbidimeter with recorder on each filter effluent for plants treating surface water.

(l) All designs that propose supplies of surface water, groundwater under the direct influence of surface water, and groundwater that does not meet 40 CFR Part 141 or where other treatment is provided, shall include disinfection via one of the following methods:

(i) Chlorine;

(ii) Chloramines, recommended only for secondary disinfection;

(iii) Chlorine dioxide;

(iv) Ozone;

(v) Ultraviolet light; or

(vi) Other disinfecting agents that demonstrate reliable application equipment is available and that include testing procedures for a residual that is recognized in Standard Methods for the Examination of Water and Wastewater 2018.

(m) All designs that require disinfection shall demonstrate that:

(i) The system will maintain a detectable residual throughout the distribution system; and

(ii) The applicant has considered the formation of disinfection byproducts when selecting the disinfection.

(n) Disinfection equipment shall comply with the following requirements:

(i) Chlorination equipment shall comply with NSF/ANSI/CAN 61-2020/NSF/ANSI/CAN 600-2021 and the following requirements:

(A) Positive displacement pumps shall be provided for solution feed gas chlorinators or hypochlorite feeders;

(B) The chlorine solution injector/diffuser shall provide a rapid and thorough mix with all the water being treated;

1717 (C) If the application point is to a pipeline discharging to a clearwell,  
 1718 the chlorine shall be added to the center of the pipe at least 10 pipe diameters upstream of the  
 1719 discharge into the clearwell;

1720  
 1721 (D) Gas chlorinators shall comply with the following requirements:  
 1722

1723 (I) The injector/eductor shall be selected based on solution  
 1724 pressure, injector water flowrate, feed point backpressure, and chlorine solution line length and  
 1725 size;

1726  
 1727 (II) The maximum feed point backpressure shall not exceed  
 1728 110 psi unless a chlorine solution pump is used; and

1729  
 1730 (III) Gauges shall be provided for chlorine solution pressure,  
 1731 feed water pressure, and chlorine gas pressure or vacuum.

1732  
 1733 (E) Standby equipment of sufficient capacity shall be available to  
 1734 replace the largest chlorinator unit. Well systems providing no treatment other than disinfection  
 1735 are exempt from the requirements of this paragraph (E) and are not required to provide standby  
 1736 chlorination equipment.

1737  
 1738 (ii) Points of application and contact time shall comply with the following  
 1739 requirements:

1740  
 1741 (A) Filtration types shall comply with the contact time and minimum  
 1742 chlorine residuals required in Table 3 of this Section after the appropriate baffling factor has  
 1743 been applied to the reactor. Contact times assume a baffling factor of 0.1 unless documentation  
 1744 justifying the use of a higher baffling factor is provided. Contact time requirements are based on  
 1745 worst-case operating conditions of water temperature of 32.9 degrees Fahrenheit and pH of 9.

1746  
 1747

Table 3. Required Contact Time and Residual by Filtration Type

<b>Filtration Type</b>	<b>Required Contact Time (minutes), 0.4 mg/L minimum chlorine residual</b>	<b>Required Contact Time (minutes), 1.0 mg/L minimum chlorine residual</b>
Conventional Filtration	162.5	73
Direct Filtration, Bag or Cartridge Filtration, Slow Sand Filtration, Diatomaceous Earth Filtration	325	146
Membrane Filtration (MF or UF)	30	12

1748  
 1749  
 1750 (B) When chlorine is applied to a groundwater source to maintain a  
 1751 residual, no contact time is required.

1752  
 1753  
 1754  
 1755  
 1756  
 1757  
 1758  
 1759  
 1760  
 1761  
 1762  
 1763  
 1764  
 1765  
 1766  
 1767  
 1768  
 1769  
 1770  
 1771  
 1772  
 1773  
 1774  
 1775  
 1776  
 1777  
 1778  
 1779  
 1780  
 1781  
 1782  
 1783  
 1784  
 1785  
 1786  
 1787  
 1788  
 1789  
 1790  
 1791  
 1792  
 1793  
 1794  
 1795  
 1796  
 1797

(o) Systems that propose disinfection via ultraviolet light shall comply with the following requirements:

(i) Proposed designs for ultraviolet light shall include the following information in the ultraviolet reactor influent water quality analysis:

- (A) Influent temperature (degrees Fahrenheit);
- (B) UV transmittance (UVT) at a reported wavelength of 254 nm and a pathlength of 1 cm;
- (C) A description of the UVT range over a 12-month period;
- (D) Total hardness (mg/L as CaCO<sub>3</sub>);
- (E) pH;
- (F) Alkalinity (mg/L as CaCO<sub>3</sub>);
- (G) Total iron (mg/L) influent < 0.3mg/L;
- (H) Calcium (mg/L); and
- (I) Total manganese (mg/L) influent <0.03 mg/L

(ii) Proposed designs for ultraviolet disinfection systems shall include the following information:

- (A) The maximum, average, and minimum flowrates;
- (B) A matrix that identifies paired flow and ultraviolet treatment values;
- (C) A description of the organisms targeted for inactivation;
- (D) Log inactivation requirements;
- (E) Operating approach (UV intensity vs. calculated dose);
- (F) Maximum and minimum operating pressures;
- (G) Maximum pressure at the UV reactor;
- (H) UV system redundancy;
- (I) Lamp cleaning strategy;

- 1798  
1799 (J) Mercury trap for broken UV lamps;  
1800  
1801 (K) Maximum headloss through the UV reactor;  
1802  
1803 (L) A demonstration that the UV reactor(s) shall be hydrostatically  
1804 tested to 1.5 times the rated operating pressure;  
1805  
1806 (M) A demonstration that the UV reactor(s) shall be designed to ensure  
1807 that plant personnel can change lamps and the UV intensity meter without draining the reactor;  
1808 and  
1809  
1810 (N) A demonstration that the units shall meet NSF/ANSI/CAN  
1811 Standard 61.  
1812  
1813 (iii) Ultraviolet treatment systems shall be designed to comply with the  
1814 Ultraviolet Disinfection Guidance Manual for the Final LT2ESWTR and the following dose  
1815 requirements:  
1816  
1817 (A) The UV disinfection system shall deliver a validated dose that  
1818 meets or exceeds the required dose at the end of lamp life, with fouled sleeves.  
1819  
1820 (B) The minimum required validated dose used for system design shall  
1821 incorporate a Combined Age and Fouling Factor (CAF), calculated as:  
1822  
1823 
$$\text{CAF} = \text{EOLL} \times \text{FF}.$$
  
1824  
1825 EOLL is the ratio of the lamp output at the end of life relative to the new  
1826 lamp output  
1827  
1828 FF is the fouling factor.  
1829  
1830 (C) The EOLL shall be 75 percent of the new lamp output.  
1831  
1832 (D) The FF shall be:  
1833  
1834 (I) 0.5 for UV systems with no sleeve wiping system;  
1835  
1836 (II) 0.75 for UV systems with mechanical wiping only; or  
1837  
1838 (III) 0.95 for UV systems with a combined online chemical and  
1839 mechanical cleaning.  
1840  
1841 (E) The validated dose that meets or exceeds the required dose shall be  
1842 delivered under maximum flow and design (UVT) condition, when the larger UV unit is out of  
1843 service.

- 1844  
1845 (iv) Ultraviolet disinfection shall comply with the following validation  
1846 requirements:  
1847  
1848 (A) The applicant shall submit the manufacturer’s bioassay validation  
1849 report for the proposed UV reactor with the permit application;  
1850  
1851 (B) The bioassay testing and results shall demonstrate validation by an  
1852 independent third party in full compliance with the Ultraviolet Disinfection Guidance Manual for  
1853 the Final LT2ESWTR;  
1854  
1855 (C) The owner and engineer shall submit a certification to the  
1856 Administrator if validation requirements are adjusted and identify each of the equipment and  
1857 system modifications required to ensure that the appropriate dosage is provided for the  
1858 inactivation requirements;  
1859  
1860 (D) Bioassay testing shall evaluate reactor performance over the range  
1861 of:  
1862  
1863 (I) Flowrates (maximum, average, and minimum);  
1864  
1865 (II) UVT from 70 percent to 98 percent (measured at 254 nm, 1  
1866 cm path length); and  
1867  
1868 (III) RED at maximum flowrate and design UVT conditions.  
1869  
1870 (E) The bioassay testing shall incorporate the range of design and  
1871 operating conditions described in paragraph (o)(i) of this Section for UV Light;  
1872  
1873 (F) Extrapolations to flowrates, UV transmittance values, or UV doses  
1874 outside the range actually tested, are not permitted; and  
1875  
1876 (G) Bioassay testing shall also verify that the head loss generated by  
1877 the proposed reactor is less than or equal to the specified limits.  
1878  
1879 (v) Ultraviolet disinfection hydraulics shall comply with the following  
1880 requirements:  
1881  
1882 (A) The inlet and outlet piping configuration to the UV reactor shall  
1883 result in a UV dose delivery that is equal to or greater than the dose delivered when the UV  
1884 reactor was validated;  
1885  
1886 (B) If the UV reactor validation is performed off-site, the applicant  
1887 shall refer to the validation report to determine the validated inlet and outlet conditions that apply  
1888 to the site-specific requirements; and  
1889

1890 (C) Ultraviolet hydraulic piping shall comply with at least one of the  
1891 following requirements:

1892  
1893 (I) The piping configuration shall consist of a minimum of 10  
1894 pipe diameters of straight pipe upstream and five pipe diameters of straight pipe downstream of  
1895 the UV reactors, with additional pipe diameters above the minimum if required by the  
1896 manufacturer's guidelines for electromagnetic or other flowmeter installation;

1897  
1898 (II) The inlet and outlet piping configurations shall be identical  
1899 to those constructed for the UV reactor validation; or

1900  
1901 (III) If on-site validation or custom off-site validation is  
1902 planned, the inlet and outlet piping hydraulics must be designed according to the manufacturer's  
1903 recommendations and to accommodate any site-specific constraints.

1904  
1905 (vi) Ultraviolet control and measurement instrumentation for each reactor shall  
1906 comply with the following requirements:

1907  
1908 (A) Each reactor shall be capable of measuring UV intensity and lamp  
1909 status (on/off);

1910  
1911 (B) For systems that use the calculated dose monitoring strategy, each  
1912 reactor shall be capable of measuring or calculating the UV transmittance;

1913  
1914 (C) Piping for each UV reactor shall be sized and configured in  
1915 accordance with the validated operating conditions and maintain equal head loss through each  
1916 reactor over the range of validated flowrates. Each UV reactor shall not be by-passed;

1917  
1918 (D) Each UV reactor train shall have a dedicated flow meter to confirm  
1919 the validated operating conditions;

1920  
1921 (E) UV lamps in the UV reactor shall be submerged at all times during  
1922 operation;

1923  
1924 (F) The specific configuration of the UV reactor(s) within a facility  
1925 will dictate the use of air release, air/vacuum, or combination air valves to prevent air pockets  
1926 and negative pressure conditions and the design shall verify that the UV manufacturer was  
1927 consulted to determine any equipment-specific air release and pressure control valve  
1928 requirements;

1929  
1930 (G) Each UV reactor shall have the piping configured so that it can be  
1931 isolated and removed from service while the other UV reactor(s) remain in service; and

1932  
1933 (H) A booster pump shall be used if the head loss constraints indicate  
1934 that a pump is necessary. The UV reactor shall be sized accordingly.

1935

1936 (vii) The applicant shall describe the dose monitoring strategy and the  
1937 operational approach for the UV reactor that complies with the approaches described in  
1938 Ultraviolet Disinfection Guidance Manual for the Final LT2ESWTR, part 3.5.2.

1939  
1940 (viii) The cleaning system for each UV reactor shall comply with the following  
1941 requirements:

1942  
1943 (A) Each UV reactor shall be equipped with an automatic online  
1944 mechanical lamp sleeve cleaning system and may include optional chemical cleaning;

1945  
1946 (B) The UV sensor shall include mechanical cleaning capabilities with  
1947 an automatically initiated and controlled cleaning cycle; and

1948  
1949 (C) The UV reactor(s) shall be fully operational and shall provide  
1950 validated dose requirements during system cleaning.

1951  
1952 (ix) The minimum spare parts kept at a facility shall include the following:

1953  
1954 (A) 20 percent of the UV Lamps;

1955  
1956 (B) Five percent of the lamp sleeves; and

1957  
1958 (C) One UV intensity sensor.

1959  
1960 (p) Facilities that propose disinfection via fluoridation and defluoridation shall  
1961 comply with the following requirements:

1962  
1963 (i) Fluoride storage designs shall demonstrate that:

1964  
1965 (A) Fluoride storage tanks shall be covered;

1966  
1967 (B) All other storage shall be inside a building; and

1968  
1969 (C) Storage tanks of hydrofluorosilicic acid shall be vented to the  
1970 atmosphere at a point outside the building.

1971  
1972 (ii) Fluoride feed equipment shall meet the following requirements:

1973  
1974 (A) There shall be scales or weight loss recorders for dry chemical  
1975 feeds and the feeders shall be accurate to within five percent of any desired feed rate;

1976  
1977 (B) The application of hydrofluorosilicic acid, if into a horizontal pipe,  
1978 shall be in the lower half of the pipe;

1979  
1980 (C) Fluoride compounds shall not be added before lime soda or ion  
1981 exchange softening;

- 1982  
 1983 (D) A fluoride solution shall be applied by a positive displacement  
 1984 pump;  
 1985 (E) The solution shall not be injected into a point of negative pressure;  
 1986  
 1987 (F) All fluoride feed lines and dilution water lines shall be isolated  
 1988 from the potable water supplies by either an air gap above the solution tank or a reduced pressure  
 1989 principal backflow preventer;  
 1990  
 1991 (G) Water used for sodium fluoride solution shall have a hardness not  
 1992 exceeding 45 mg/L; and  
 1993  
 1994 (H) Flow meters for treated water flow and fluoride solution water  
 1995 shall be provided.  
 1996  
 1997 (iii) Provisions shall be made to allow the transfer of dry fluoride compounds  
 1998 from shipping containers to storage bins or hoppers that minimize the quantity of fluoride dust  
 1999 that enters the room where the equipment is installed and shall meet the following requirements:  
 2000  
 2001 (A) The transfer system shall be equipped with an exhaust fan and dust  
 2002 filter that places the hopper or storage bin under negative pressure;  
 2003  
 2004 (B) Air exhausted from fluoride handling equipment shall discharge  
 2005 through a dust filter to the atmosphere outside the building and shall not discharge within 50 feet  
 2006 of a fresh air intake for the building; and  
 2007  
 2008 (C) A floor drain shall be provided for cleaning equipment and  
 2009 maintenance.  
 2010  
 2011 (iv) The following methods are acceptable for fluoride removal:  
 2012  
 2013 (A) Activated alumina may be used in open gravity filters or pressure  
 2014 filter tanks;  
 2015  
 2016 (B) The minimum media depth shall be five feet;  
 2017  
 2018 (C) The loading rate shall not exceed 4 gpm/ft<sup>2</sup>;  
 2019  
 2020 (D) The mesh size for the alumina media shall be between #28 and  
 2021 #48;  
 2022  
 2023 (E) Media regeneration facilities shall be provided and shall include  
 2024 both weak caustic and weak acid systems; and  
 2025  
 2026 (F) Bone char filtration or lime softening with magnesium addition  
 2027 may be used.



- 2028  
2029 (v) Water that is unstable due either to natural causes or to subsequent  
2030 treatment shall be stabilized.  
2031  
2032 (vi) Facilities shall have the capability of feeding both acid and alkalinity.  
2033  
2034 (vii) Unstable water created by ion exchange softening shall be stabilized by an  
2035 alkali feed.  
2036  
2037 (viii) Laboratory equipment shall be provided to determine the effectiveness of  
2038 stabilization treatment. This shall include testing equipment for hardness, calcium, alkalinity, pH,  
2039 and magnesium at a minimum.  
2040  
2041 (q) Taste and odor control equipment shall comply with the following requirements:  
2042  
2043 (i) Open or closed, granular activated carbon adsorption units may be used to  
2044 absorb organics for taste and odor control, subject to the following requirements:  
2045  
2046 (A) The loading rate shall not exceed 10 gpm/ft<sup>2</sup>;  
2047  
2048 (B) The minimum empty bed contact time shall be 20 minutes;  
2049  
2050 (C) The pH of the water shall be less than 9.0 with a turbidity of less  
2051 than 2 NTU when using packed beds;  
2052  
2053 (D) There shall be provisions for moving the carbon to and from the  
2054 contactors;  
2055  
2056 (E) Contactors may be upflow or downflow design. A single unit is  
2057 acceptable for countercurrent upflow designs. Downflow designs shall have two or more parallel  
2058 units;  
2059  
2060 (F) Contactors shall be designed as open gravity or pressure bed;  
2061  
2062 (G) Pressure contactors shall have an air-vacuum relief valve fitted  
2063 with a stainless-steel screen to prevent plugging;  
2064  
2065 (H) The contactor materials of construction shall be concrete, steel, or  
2066 fiberglass-reinforced plastic and shall meet the following requirements:  
2067  
2068 (I) Steel vessels shall be protected against corrosion; and  
2069  
2070 (II) Inlet and outlet screens shall be made of stainless steel or  
2071 other suitable materials.  
2072

2073 (I) There shall be provisions for flow reversal and bed expansion that  
2074 meet the following requirements:

2075  
2076 (I) Backwashing facilities shall provide up to 50 percent bed  
2077 expansion; and

2078  
2079 (II) Backwashing facilities shall meet the backwash criteria as  
2080 rapid filters.

2081  
2082 (ii) If ozone is used for taste and odor control, there shall be at least 10  
2083 minutes of contact time to complete all reactions and the minimum applied feed rate of ozone  
2084 shall be 1 mg/L, or the design shall identify a contact time and feed rate that demonstrate the  
2085 application of ozone will not cause an exceedance of the maximum contaminant levels identified  
2086 at 40 CFR 143.3.

2087  
2088 (r) Designs that include the addition of phosphates for stabilization and corrosion  
2089 control shall demonstrate the evaluation of reactions with aluminum and impacts on wastewater  
2090 treatment plants to overcome the secondary impacts of phosphates that may potentially limit  
2091 their use.

2092  
2093 (s) Designs that propose anion-exchange treatment shall include a pH/alkalinity feed  
2094 system unless other wise approved by the Administrator.

2095  
2096 (t) Microscreens shall comply with the following requirements:

2097  
2098 (i) A microscreen shall be allowed as a supplement to treatment, but it shall  
2099 not be used in place of filtration or coagulation;

2100  
2101 (ii) The screen shall be capable of removing suspended matter from the water  
2102 by straining;

2103  
2104 (iii) Screens shall be made of corrosion-resistant material;

2105  
2106 (iv) Bypass piping around the unit shall be provided;

2107  
2108 (v) There shall be protection against back siphonage when potable water is  
2109 used for washing the screen; and

2110  
2111 (vi) Wash water shall be wasted and not recycled to the microscreen.

2112  
2113 (u) Membrane technologies shall comply with the following requirements:

2114  
2115 (i) Proposed membrane treatment processes shall comply with the  
2116 requirements of Section 6 of this Chapter. Protocols for pilot plant testing shall incorporate  
2117 guidance or procedures from the US EPA Membrane Filtration Guidance Manual, Chapter 6.  
2118

2119 (ii) All proposed membrane filters shall demonstrate third-party validation for  
2120 the removal of Giardia or Cryptosporidium. Removal efficiency shall be determined through  
2121 challenge testing as outlined in the US EPA Membrane Filtration Guidance Manual and one of  
2122 the following:

2123  
2124 (A) Membranes that are used as final compliance filters of a multiple  
2125 treatment barrier approach shall meet the requirements of 40 CFR Part 141; or

2126  
2127 (B) All surface water or groundwater under direct influence (GWUDI)  
2128 systems using membrane technology shall demonstrate minimum disinfection that meets 4.0-log  
2129 virus inactivation.

2130  
2131 (v) Facilities that propose bag and cartridge filters shall comply with the procedures  
2132 identified in Section 6 of this Chapter and the following requirements:

2133  
2134 (i) Filter performance will be based on Cryptosporidium oocyst removal;

2135  
2136 (ii) The filter shall demonstrate at least a 3-log removal of particle size 1  
2137 micron and above with an associated log reduction credit of 2-logs for Giardia and  
2138 Cryptosporidium;

2139  
2140 (iii) Removal efficiency shall be determined through challenge testing as  
2141 outlined in Toolbox Guidance Manual, Chapter 8 and NSF/ANSI 419-2018;

2142  
2143 (iv) The performance demonstration shall be specific to the corresponding  
2144 housing and type or model of filter. Any other combination of housing and filter that could be  
2145 used for treatment shall also demonstrate filter efficiency;

2146  
2147 (v) Applicants shall include documentation that the proposed bag or cartridge  
2148 filter has received third-party validation for the removal of Giardia and Cryptosporidium;

2149  
2150 (vi) Filter and housing specifications shall include a description of the  
2151 materials of construction, surface area per filter, and the minimum and maximum operating  
2152 pressure, and the specifications shall meet the requirements of NSF/ANSI 419-2018 and the  
2153 Toolbox Guidance Manual, Chapter 8;

2154  
2155 (vii) System components such as housing, bags, cartridges, gaskets, and O-  
2156 rings shall comply with NSF/ANSI/CAN 61 for leaching of contaminants;

2157  
2158 (viii) A means for monitoring the performance of the filter shall be provided and  
2159 shall include at a minimum flow meters and valves, pressure gauges, and sample taps;

2160  
2161 (ix) The proposed design shall specify chemical compatibility limitations;

2162  
2163 (x) A minimum of two filter housings shall be provided;

2164

2165 (xi) Bag or cartridge filters that are used as final compliance filters of a  
2166 multiple treatment barrier approach shall meet the requirements of 40 CFR Part 141; and  
2167

2168 (xii) All surface water or GWUDI systems using bag or cartridge filter  
2169 technology shall provide at minimum disinfection that meets 4.0-log virus inactivation and 1.0-  
2170 log Giardia inactivation or shall demonstrate that combined filtration and disinfection will  
2171 provide 3-log removal.  
2172

2173 (w) Pre-engineered water treatment plants shall comply with the following  
2174 requirements:  
2175

2176 (i) Pre-engineered water treatment plants shall be permitted on a case-by-case  
2177 basis for specific process applications and flow rates. Multiple units may be installed in parallel  
2178 to accommodate flow rates;  
2179

2180 (ii) Pre-engineered water treatment plant equipment shall be designed in  
2181 accordance with NSF/ANSI/CAN 61 and NSF/ANSI/CAN 372;  
2182

2183 (iv) Pre-engineered water treatment plants shall comply with the procedures in  
2184 Section 6 of this Chapter to obtain data that demonstrates the treatment effectiveness of the  
2185 treatment for the source water and the proposed application; and  
2186

2187 (v) Each component and process of the pre-engineered water treatment plant  
2188 shall demonstrate compliance with the applicable design criteria of the respective treatment  
2189 processes of this Chapter.  
2190

2191 (x) Wastes shall be handled and disposed of as follows:  
2192

2193 (i) The sanitary and laboratory waste from water treatment plants, pumping  
2194 stations, or well systems, shall not be recycled to any part of the water plant, and shall be  
2195 discharged directly into a sanitary sewer when feasible or a permitted on-site disposal system;  
2196

2197 (ii) Brine waste from ion exchange plants, demineralization plants, and other  
2198 similar facilities may not be recycled to the water plant and shall meet the following  
2199 requirements:  
2200

2201 (A) Where discharging to a sanitary sewer, a holding tank shall be  
2202 provided to prevent the overloading of the sewer and interference with the waste treatment  
2203 process; and  
2204

2205 (B) Where disposal to an off-site waste treatment system is proposed,  
2206 the sewer and treatment facility shall have the required capacity and dilution capability.  
2207

2208 (iii) Acceptable methods of treatment and disposal of lime softening sludge  
2209 are:  
2210

- 2211 (A) Sludge lagoons, provided that the design of sludge lagoons  
2212 includes:  
2213  
2214 (I) The location of the lagoon shall be protected from the 100-  
2215 year flood;  
2216  
2217 (II) A means of diverting surface water runoff so that it does  
2218 not flow into the lagoon;  
2219  
2220 (III) The freeboard shall be a minimum of three feet;  
2221  
2222 (IV) An adjustable decanting device for recycling the overflow;  
2223 and  
2224  
2225 (V) An accessible effluent sampling point.  
2226  
2227 (B) Land application of liquid lime softening sludge that demonstrates  
2228 compliance with Water Quality Rules Chapter 11, Part E;  
2229  
2230 (C) Disposal at a landfill;  
2231  
2232 (D) Mechanical dewatering of sludge may be used;  
2233  
2234 (E) Recalcination of sludge may be used; and  
2235  
2236 (F) Lime sludge drying beds shall not be allowed.  
2237  
2238 (iv) Acceptable methods of treatment and disposal of alum sludge are as  
2239 follows:  
2240  
2241 (A) Lagoons may be used as storage and interim disposal. Lagoons  
2242 used for storage shall have a volume of at least 100,000 gallons for every 1,000,000 gpd of  
2243 facility water treating capacity.  
2244  
2245 (B) Alum sludge may be discharged to the sanitary sewer only when  
2246 the system is capable of handling the waste and with the approval of the owner of the sewer  
2247 system.  
2248  
2249 (C) Mechanical dewatering may be used.  
2250  
2251 (D) Alum sludge drying beds may be used.  
2252  
2253 (E) Alum sludge may be acid-treated and recovered.  
2254  
2255 (F) Disposal at a landfill.  
2256

2257 (v) Designs that propose disposal of waste filter wash water from iron and manganese  
 2258 removal plants that include sand filters shall demonstrate the inclusion of a separate structure,  
 2259 unless otherwise approved by the Administrator.  
 2260

2261 **Section 13. Chemical Application.**  
 2262

2263 (a) 2018 TSS, parts 5.0.2(f), chemical application, general, chemical application;  
 2264 5.0.3-5.0.3(h), chemical application, general, general equipment design; 5.1.2-5.1.2(e)(4.),  
 2265 chemical application, feed equipment, control; 5.1.3-5.1.3(c), chemical application, feed  
 2266 equipment, dry chemical feeders; 5.1.4-5.1.4(d), chemical application, feed equipment, positive  
 2267 displacement solution feed pumps; 5.1.5-5.1.5(d), chemical application, feed equipment, liquid  
 2268 chemical feeders-siphon control; 5.1.6-5.1.6(d), chemical application, feed equipment, cross-  
 2269 connection control; 5.1.8-5.1.8(e), chemical application, feed equipment, in-plant water supply;  
 2270 5.1.9(a)(1-3), (b), and (d), chemical application, feed equipment, storage of chemicals; 5.1.10-  
 2271 5.1.10(j), chemical application, feed equipment, bulk liquid storage tanks; 5.1.11-5.1.11(h),  
 2272 chemical application, feed equipment, day tanks; 5.1.12-5.1.12(e), chemical application, feed  
 2273 equipment, feed lines; 5.1.13-5.1.3(d); chemical application, feed equipment, handling; 5.1.14-  
 2274 5.1.14(b), chemical application, feed equipment, housing; 5.3.2, operator safety, respiratory  
 2275 protection equipment; 5.3.3, operator safety, chlorine gas leak detection; 5.4.1(d)(1-5) and (7-  
 2276 10), (f), and (h), specific chemicals, chlorine gas; 5.4.1(f) and (h), 5.4.2-5.4.2(b), specific  
 2277 chemicals, acids and caustics; 5.4.3-5.4.3(c)(5.), specific chemicals, sodium chlorite; 5.4.4-  
 2278 5.4.4(b)(5.), specific chemicals, sodium hypochlorite; are herein incorporated by reference.  
 2279

2280 (b) Chemical application facility designs shall comply with the following  
 2281 requirements:  
 2282

2283 (i) A separate feeder shall be used for each chemical applied; and  
 2284

2285 (ii) Chemical storage tanks shall be constructed of materials that are resistant  
 2286 to the chemicals stored. Tanks shall maintain structural integrity while in use.  
 2287

2288 (c) Chemical application facilities shall include an alarm for high effluent turbidity,  
 2289 low chlorine residual, and chlorine leaks when chlorine gas is used. The alarm shall be located at  
 2290 an attended location.  
 2291

2292 **Section 14. Pumping Facilities**  
 2293

2294 (a) 2018 TSS, parts 6.1-6.1.1(e), location; 6.2, 6.2(b-e), pumping stations; 6.2.1-  
 2295 6.2.1(d), pumping stations, suction well; 6.2.2, 6.2.2(a-b), pumping stations, equipment  
 2296 servicing; 6.3.2, pumps, pump priming; 6.6.1, appurtenances, valves; 6.6.3-6.6.3(d),  
 2297 appurtenances, gauges and meters; 6.6.4-6.6.4(b), appurtenances, water seals; 6.6.5,  
 2298 appurtenances, controls; 6.6.6, appurtenances, standby power; are herein incorporated by  
 2299 reference.  
 2300

2301 (b) Stairways or ladders shall be provided between all floors and in pits or  
 2302 compartments that must be entered.

2303  
2304  
2305  
2306  
2307  
2308  
2309  
2310  
2311  
2312  
2313  
2314  
2315  
2316  
2317  
2318  
2319  
2320  
2321  
2322  
2323  
2324  
2325  
2326  
2327  
2328  
2329  
2330  
2331  
2332  
2333  
2334  
2335  
2336  
2337  
2338  
2339  
2340  
2341  
2342  
2343  
2344  
2345  
2346

- (c) Pumping facilities shall be heated to maintain a minimum temperature of 40 degrees Fahrenheit if typically unoccupied and 50 degrees Fahrenheit if normally occupied.
- (d) Pumping station ventilation designs shall demonstrate that:
  - (i) All areas of the pumping station that are accessible shall be ventilated;
  - (ii) Ventilation may be continuous or intermittent;
  - (iii) Drywell ventilation shall provide:
    - (A) At least six air changes per hour if continuous; and
    - (B) At least 30 air changes per hour if intermittent with an automatic start upon operator entry into the area.
  - (iv) Wetwell ventilation shall provide 12 continuous air changes per hour or 60 intermittent air changes per hour and be designed to permit the use of portable blowers that will exhaust the space and supply fresh air during the access periods.
- (e) Dehumidification equipment shall be provided in below-ground pumping stations. The equipment shall be sized to maintain a dewpoint at least two degrees Fahrenheit below the coldest anticipated temperature of the water to be conveyed in the pipes.
- (f) All pumping stations that are manned four or more hours per day shall be provided with potable water, lavatory, and toilet facilities. The waste shall be discharged to the sanitary sewer or an on-site waste treatment system.
- (g) Pump design shall comply with the following requirements:
  - (i) At least two pumps shall be provided. With the largest pump out of service, the remaining pump or pumps shall be capable of providing the maximum pumping capacity of the system.
  - (ii) Pumps shall be selected such that the net positive suction head required (NPSHR) is less than the net positive suction head available (NPSHA) minus four feet based on hydraulic conditions and the altitude of the pump installation. If this condition cannot be satisfied, a means of priming shall be provided.
  - (iii) A surge analysis shall be provided to demonstrate if surge protection devices will be needed to protect the piping. Pressure relief valves are not acceptable as surge control.

2347 (iv) The calculated total dynamic head for pumping units shall be based on  
2348 pipe friction, pressure losses from pipe entrances, exits, appurtenances (such as valves and  
2349 bends), and static head at the design flow.

2350  
2351 (v) The station shall have a flow rate indicator and totalizing meter, and a  
2352 method of recording the total water pumped.

2353  
2354 (h) Booster pumps shall comply with the following requirements:

2355  
2356 (i) Booster pumps shall not produce less than 5 psi in suction lines. If the  
2357 suction line has service connections, the pressure shall be at least 35 psi during normal operation  
2358 and shall have a low-pressure cutoff switch to maintain at least 20 psi.

2359  
2360 (ii) For booster pumps used for fire suppression, no person shall install or  
2361 maintain a water service connection to any premises where a fire pump has been installed on the  
2362 service line to or within such premises unless the pump is equipped with one of the following:

2363  
2364 (A) A low suction throttling valve or pilot-operated valve installed in  
2365 the discharge piping that maintains positive pressure in the suction piping while monitoring  
2366 pressure in the suction piping through a sensing line. The valve shall throttle the discharge of the  
2367 pump when necessary so that suction pressure will not be reduced below 20 psi gauge when the  
2368 pump is operating; or

2369  
2370 (B) A variable-speed suction limiting control that is used to maintain a  
2371 minimum positive suction pressure at the pump inlet by reducing the pump driver speed while  
2372 monitoring pressure in the suction piping through a sensing line. The limiting control shall be set  
2373 so that the suction pressure will not be reduced below 20 psi gauge while the pump is operating.

2374  
2375 (iii) Automatic or remote-controlled pumps shall have a range between the  
2376 start and cutoff pressure that will prevent the pump from cycling more than one start every 15  
2377 minutes.

2378  
2379 (iv) In-line booster pumps shall be accessible for maintenance. There shall be  
2380 access openings, as needed, to allow the removal of the pump.

2381  
2382 (v) Individual home booster pumps shall not be allowed for any individual  
2383 service from the public water supply main.

2384  
2385 (vi) Un-manned or remotely controlled pump stations shall have an alarm at an  
2386 operator attended location for any conditions that may affect the continuous delivery of water.

2387  
2388 (i) Pumping facility valves shall comply with the following requirements:

2389  
2390 (i) Air release valves shall be provided where the pipe crown is dropped in  
2391 elevation. The discharge pipe from the valve shall have a minimum of an 8-inch air gap and shall  
2392 be covered with a #24 mesh non-corrodible screen.



2393  
2394 (ii) Each pump shall either have an individual suction line or the suction lines  
2395 shall be manifolded such that they demonstrate similar hydraulic and operating conditions.  
2396

2397 **Section 15. Finished Water Storage**  
2398

2399 (a) 2018 TSS, parts 7.0.1-7.0.1(c), sizing; 7.0.2-7.0.2(b), location of finished water  
2400 storage structures; 7.0.3, protection from contamination; 7.0.4, security; 7.0.5, drains; 7.0.6,  
2401 stored water age; 7.0.10-7.0.10(f), roof and sidewall; 7.0.17-7.0.17(c), painting and/or cathodic  
2402 protection; are herein incorporated by reference.  
2403

2404 (b) Finished water storage structures shall comply with the following requirements:  
2405

2406 (i) Water storage structures shall comply with the following standards for  
2407 storage tanks, standpipes, ground storage reservoirs that are described in AWWA M42,  
2408 clearwells, and elevated storage:  
2409

- 2410 (A) AWWA D100;
- 2411
- 2412 (B) AWWA D102;
- 2413
- 2414 (C) AWWA D103;
- 2415
- 2416 (D) AWWA D104;
- 2417
- 2418 (E) AWWA D106;
- 2419
- 2420 (F) AWWA D107;
- 2421
- 2422 (G) AWWA D108;
- 2423
- 2424 (H) AWWA D110;
- 2425
- 2426 (I) AWWA D115;
- 2427
- 2428 (J) AWWA D120; and
- 2429
- 2430 (K) AWWA D121.

2431  
2432 (ii) All tank and foundation design shall be performed by a Wyoming  
2433 registered professional engineer. The plans or contractor-furnished information shall be signed  
2434 and sealed by a Wyoming registered professional engineer.  
2435

2436 (iii) All new or modified water storage tanks shall have the inlet and outlet  
2437 connections separated from each other as much as is practical.  
2438

- 2439 (c) Storage facility designs shall demonstrate:  
2440  
2441 (i) The average daily demand will require a daily fill of 20 percent of the total  
2442 storage volume for surface water sources and 10 percent for groundwater sources.  
2443  
2444 (ii) For designs that demonstrate the storage tank has a small daily demand  
2445 and a high fire water storage requirement, or the storage tank water age average is greater than  
2446 two days, the design shall demonstrate that a volume equal to at least 20 percent of the tank  
2447 volume will be delivered to the storage tank each time pumping is initiated.  
2448  
2449 (iii) For designs with well systems that provide a minimum of two wells that  
2450 can supply either the maximum hourly demand or the fire demand, whichever is greater, storage  
2451 is not required. These systems shall demonstrate that they will provide alternative power for the  
2452 finished water pumps.  
2453  
2454 (d) Storage structure design shall eliminate short-circuiting.  
2455  
2456 (e) The minimum inlet velocity shall be 10 ft/sec unless demonstration of employed  
2457 mixing system or lower inlet velocity addresses disinfection by-product formation, stratification,  
2458 stagnation, freezing, and other water age issues.  
2459  
2460 (f) Overflow and drain lines shall:  
2461  
2462 (i) Be protected with a mechanical device such as:  
2463  
2464 (A) A sealed flapper valve or duckbill valve; or  
2465  
2466 (B) A #24 mesh non-corrodible screen.  
2467  
2468 (ii) For overflow lines that are protected with a mechanical device, include  
2469 installation of a #4 mesh non-corrodible screen or finer to prevent the entrance of birds or  
2470 rodents;  
2471  
2472 (iii) For overflow lines that are protected with #24 mesh non-corrodible screen,  
2473 demonstrate prevention of screen clogging that would lead to structural storage tank damage;  
2474  
2475 (iv) Include installation of the screen within the overflow line at a location that  
2476 is not susceptible to vandalism and that allows for the overflow line to be operational during an  
2477 overflow event;  
2478  
2479 (v) Provide access to the screen with the smallest openings for replacement;  
2480 and  
2481  
2482 (vi) Demonstrate that the screen with the smallest openings will be the  
2483 outermost screen.  
2484

2485 (g) Overflow designs shall demonstrate the provisions that will be included to prevent  
2486 mechanical devices from freezing shut.

2487  
2488 (h) Overflow lines shall not be considered as vents.  
2489

2490 (i) Vents shall be designed to protect the tank from contaminants including but not  
2491 limited to surface water, stormwater runoff, insects, rodents, and birds.

2492  
2493 (i) All openings shall be protected with #24 mesh non-corrodible screen or a  
2494 combination of #24 mesh and coarser mesh non-corrodible screen.

2495  
2496 (ii) The design shall demonstrate consideration of site conditions, freezing,  
2497 frosting, and provide justification including precautions for snow depth.

2498  
2499 (A) The design shall demonstrate consideration of frost-free or frost-  
2500 proof vents; and

2501  
2502 (B) The design shall demonstrate consideration of pressure/vacuum,  
2503 frost-proof release vents that will need to protect openings with #24 mesh non-corrodible screen.

2504  
2505 (j) Down-turned vent openings shall be at least 24 inches above the nearest  
2506 horizontal surface.

2507  
2508 (k) Elevated tanks shall be designed to remove snow via tank geometry to prevent  
2509 snow build-up clogging vents.

2510  
2511 (l) Vent designs shall include calculations that verify the required volume of flow is  
2512 achievable through the proposed vent pipe and screen combination.

2513  
2514 (m) Finished water plant water storage shall comply with the following requirements:

2515  
2516 (i) Clearwell storage shall be sized, in conjunction with distribution system  
2517 storage, to relieve the filter of having to follow fluctuations in water use. Where water is pumped  
2518 from clearwell storage to the system, an overflow shall be provided.

2519  
2520 (ii) If unfinished water is stored in compartments adjacent to finished water,  
2521 the unfinished and finished water shall be separated by double walls.

2522  
2523 (iii) Receiving basins and wetwells shall be designed as finished water storage  
2524 structures and shall comply with the requirements of this Section.

2525  
2526 **Section 16. Distribution Systems.**  
2527

2528 (a) 2018 TSS, parts 8.2-8.2.4(b), system design; 8.3, valves; 8.4-8.4.4(d), hydrants;  
2529 8.5-8.5.2(c), air relief valves; 8.6, valve, meter, and blow-off chambers; 8.7.3, installation of  
2530 water mains, cover; 8.7.4, installation of water mains, blocking; 8.7.6, installation of water

2531 mains, pressure and leakage testing; 8.7.7, installation of water mains, disinfection; 8.7.8,  
 2532 installation of water mains, external corrosion; 8.7.9, installation of water mains, separation from  
 2533 other utilities; 8.8.2-8.8.2(b), separation distances from contamination sources, parallel  
 2534 installation; 8.8.3-8.8.3(b), separation distances from contamination sources, crossings; 8.8.6,  
 2535 separation distances from contamination sources, sewer manholes, inlets, and structures; 8.9.1,  
 2536 surface water crossings, above-water crossings; 8.9.2-8.9.2(c); surface water crossings, under  
 2537 water crossings; 8.11.1, water services and plumbing, plumbing; 8.12, service meters; are herein  
 2538 incorporated by reference.

2539

2540 (b) Distribution systems shall be constructed of commercial pipe that conforms to the  
 2541 following standards:

2542

2543 (i) PVC pipe:

2544

2545 (A) Less than four inches diameter, ASTM D 2241; or

2546

2547 (B) Four inches and larger diameter, AWWA C900.

2548

2549 (ii) Ductile iron, AWWA C151;

2550

2551 (iii) Fiberglass pressure pipe, AWWA C950;

2552

2553 (iv) Polyethylene pipe:

2554

2555 (A) ¾ inch through three inches diameter, AWWA C901;

2556

2557 (B) Four inches through 65 inches diameter, AWWA C906; or

2558

2559 (v) Other material submitted with the permit application and approved by the  
 2560 Administrator.

2561

2562 (c) Flanged piping shall not be allowed for buried pipe except for connection to  
 2563 valves.

2564

2565 (d) New water mains shall be sized after the hydraulic analysis required by Section  
 2566 9(l)(i) of this Chapter and the design shall demonstrate that:

2567

2568 (i) At maximum day demand plus current State of Wyoming-required fire  
 2569 flow, or the fire flow of an authority having jurisdiction, the pressure in the municipal  
 2570 distribution system will not fall below 20 pounds per square inch (psi); and

2571

2572 (ii) The normal system working pressure shall be greater than 35 psi.

2573

2574 (e) When fire protection is provided, the water main system shall be designed to also  
 2575 serve fire flows.

2576

- 2577 (f) Hydrants shall:  
 2578  
 2579 (i) Have hydrant leads that are a minimum of six inches in diameter;  
 2580  
 2581 (ii) Have valves installed;  
 2582  
 2583 (iii) Be protected from freezing at hydrant leads and barrels;  
 2584  
 2585 (iv) Where groundwater levels are above the gravel drain area, hydrants shall  
 2586 be pumped dry or otherwise dewatered and hydrant weep holes shall not be used; and  
 2587  
 2588 (v) Have drains that are not connected to or located within 10 feet of a  
 2589 sanitary sewer or storm drain.  
 2590  
 2591 (g) Fire hydrants or active service taps may be substituted for air relief in 6- and 8-  
 2592 inch lines.  
 2593  
 2594 (h) Where excavation is performed for distribution systems:  
 2595  
 2596 (i) The trench bottom shall be excavated for the bell of the pipe;  
 2597  
 2598 (ii) All rock shall be removed within six inches of the pipe; and  
 2599  
 2600 (iii) The trench shall be dewatered for all work.  
 2601  
 2602 (i) Distribution system bedding for rigid pipe shall be designed in accordance with  
 2603 ASTM C12 Classes A, B, or C. Flexible pipe bedding shall be designed in accordance with  
 2604 ASTM D2321 Class I, II, or III.  
 2605  
 2606 (j) Distribution system pipe shall be joined to ensure a watertight fitting and installed  
 2607 in accordance with the following standards, as applicable:  
 2608  
 2609 (i) For ductile iron pipe, AWWA C600;  
 2610  
 2611 (ii) For PVC pipe, AWWA M23; and  
 2612  
 2613 (iii) For HDPE pipe, AWWA M55.  
 2614  
 2615 (k) Backfill for distribution systems shall:  
 2616  
 2617 (i) Be performed without disturbing pipe alignment;  
 2618  
 2619 (ii) Not contain debris, frozen material, unstable material, or large clods;  
 2620  
 2621 (iii) Not contain rocks or stones that are greater than three inches in diameter  
 2622 within two feet of pipe; and

- 2623  
 2624 (iv) Be compacted to a density equal to or greater than the surrounding soil.  
 2625  
 2626 (l) Distribution systems shall meet the following requirements for separation of water  
 2627 mains from sanitary and storm sewers:  
 2628  
 2629 (i) Where the minimum vertical or horizontal separation distances required  
 2630 by incorporation by reference of 2018 TSS parts 8.8.2 and 8.8.3 of paragraph (a) of this Section  
 2631 cannot be met, the sewer or water line shall be placed in a separate conduit pipe or meet the  
 2632 flow-fill requirements of paragraphs (ii) and (iii) of this Paragraph (l);  
 2633  
 2634 (ii) Flow-fill for pipelines shall comply with the following:  
 2635  
 2636 (A) Cement-treated fill, non-shrink backfill, low-density concrete  
 2637 backfill, or structural backfill may be used as flow-fill when the material has a 28-day  
 2638 compressive strength of 30-60 psi;  
 2639  
 2640 (B) The pipe to be encased shall be laid on a four to six-inch of bed of  
 2641 washed gravel that has been widened, with the walls of the trench benched away from the center-  
 2642 line of the trench, so the pipe is uniformly supported over the length or supported on blocks no  
 2643 further than 10 feet apart;  
 2644  
 2645 (C) The flow-fill and washed gravel or blocks shall rest on an  
 2646 undisturbed trench bottom;  
 2647  
 2648 (D) The pipe shall not move laterally or float during placement of the  
 2649 flow-fill and the line and grade of the pipe shall be maintained; and  
 2650  
 2651 (E) The flow-fill shall extend from trench sidewall to trench sidewall  
 2652 and extend at least two inches above the top of the pipe.  
 2653  
 2654 (iii) Flow-fill for pipe crossings shall comply with the following:  
 2655  
 2656 (A) To the extent possible, there shall be no joints or taps within nine  
 2657 feet of the crossing;  
 2658  
 2659 (B) The flow-fill shall extend from undisturbed earth at the bottom of  
 2660 the lower pipe to at least two inches above the top of the upper pipe;  
 2661  
 2662 (C) The block of flow-fill shall be wide enough to ensure the structural  
 2663 integrity of the installation; and  
 2664  
 2665 (D) Pipes that cross one another shall be separated by a minimum of  
 2666 two inches when encased in flow-fill.  
 2667  
 2668 (m) Cross-connections shall comply with the following requirements:

2669  
2670 (i) There shall be no water service connection installed or maintained  
2671 between a public water supply and any water user whereby unsafe water or contamination may  
2672 backflow into the public water supply.  
2673

2674 (A) To protect all public water supplies from the possibility of the  
2675 introduction of contamination due to cross-connections, the water supplier shall:  
2676

2677 (I) Require backflow prevention devices for each water service  
2678 connection in accordance with Table 4 of this Section, with the exception of (B)(I) residential  
2679 water service connections and (B)(II) domestic non-residential water service connections;  
2680

2681 (II) Take appropriate actions that may include:  
2682

2683 1. Immediate disconnection for any water user that  
2684 fails to maintain a properly installed backflow prevention device; or  
2685

2686 2. Compliance with other measures as identified in  
2687 this Section.  
2688

2689 (III) Any high hazard non-residential connection to any public  
2690 water supply shall be protected by the backflow prevention device required by Table 4.  
2691

2692 (IV) Water suppliers shall establish record keeping and  
2693 management procedures to ensure that requirements of this regulation for installation and  
2694 maintenance of backflow prevention devices are being met.  
2695

2696 (B) The method of backflow control, selected from Table 4, shall be  
2697 determined based upon the degree of hazard of the cross-connection and the cause of the  
2698 potential backflow. Hazards shall be classified as high hazard or low hazard. The potential cause  
2699 of the backflow shall be identified as being back-siphonage or back-pressure.  
2700

2701 (I) Residential water service connections shall be considered  
2702 to be low hazard back-siphonage connections unless determined otherwise by a Hazard  
2703 Classification.  
2704

2705 (II) Domestic non-residential water service connections (such  
2706 as schools without laboratories, churches, office buildings, warehouses, and motels) shall be  
2707 considered to be low hazard back-pressure connections unless determined otherwise by a Hazard  
2708 Classification conducted by the water supplier.  
2709

2710 (III) Any water user's system with an auxiliary source of supply  
2711 shall be considered to be a high hazard, back-pressure cross-connection. A reduced pressure  
2712 principle backflow device shall be installed at the water service connection to any water user's  
2713 system with an auxiliary source of supply.  
2714

2715 (IV) All water loading stations shall be considered high hazard  
2716 connections. A device, assembly, or method consistent with Table 4 shall be provided.

2717  
2718 (V) Non-domestic commercial or industrial water service  
2719 connections (such as restaurants, refineries, chemical mixing facilities, sewage treatment plants,  
2720 mortuaries, laboratories, laundries, dry cleaners, irrigation systems, and facilities producing or  
2721 using hazardous substances) shall be considered to be high hazard back-pressure connections  
2722 unless determined otherwise by a Hazard Classification. For some of these service connections, a  
2723 Hazard Classification may result in a determination of a back-siphonage or low hazard  
2724 classification. The backflow prevention device required shall be appropriate to the degree of  
2725 hazard established by the Hazard Classification. Where potential high hazards exist within the  
2726 non-residential water user's system, even though such high hazards may be isolated at the point  
2727 of use, an approved backflow prevention device shall be installed and maintained at the water  
2728 service connection.

2729  
2730 (C) Determination of the hazard classification of a water service  
2731 connection is the responsibility of the water supplier. The water supplier may require the water  
2732 user to furnish a Hazard Classification Survey to be used to determine the Hazard Classification.

2733  
2734 (D) Hazard Classification Surveys that have been conducted by Hazard  
2735 Classification Surveyors that have been certified by another state certification program shall  
2736 include the following information for Administrator approval:

2737  
2738 (I) Documentation that indicates the Hazard Classification  
2739 Surveyor has received certification from the regulatory agency that issued the current  
2740 certification that states the name of the Hazard Classification Surveyor, the status of their  
2741 certification, the date originally issued, the expiration date, and the classification for which the  
2742 Hazard Classification Surveyor is certified; and

2743  
2744 (II) Any disciplinary action imposed against the applicant; if  
2745 any.

2746  
2747 (E) All backflow prevention devices shall be in-line serviceable  
2748 (repairable), in-line testable except for devices meeting ASSE 1024, and installed in accordance  
2749 with manufacturer instructions and applicable plumbing codes.

2750  
2751 (F) All backflow prevention devices must have a certification by an  
2752 approved third-party certification agency. Approved certification agencies are:

2753  
2754 (I) American Society of Sanitary Engineers (ASSE);

2755  
2756 (II) International Association of Plumbing/Mechanical officials  
2757 (IAPMO); and

2758  
2759 (III) Foundation for Cross-Connection Control and Hydraulic  
2760 Research, University Of Southern California (USC-FCCCHR).



2761  
 2762 (G) Backflow prevention devices at water service connections shall be  
 2763 inspected and certified by a certified backflow assembly tester at the time of installation.  
 2764 Certification of the assembly tester shall be by one of the following:

- 2765  
 2766 (I) The American Society of Sanitary Engineers (ASSE); or  
 2767  
 2768 (II) American Backflow Prevention Association (ABPA).  
 2769

2770 (H) Backflow prevention devices installed at high hazard non-  
 2771 residential cross-connections shall be inspected and tested on an annual basis by a certified  
 2772 backflow assembly tester.  
 2773

2774 (I) If any device is found to be defective or functioning improperly, it  
 2775 shall be immediately repaired or replaced. Failure to make necessary repairs to a backflow  
 2776 prevention device will be cause for the water service connection to be terminated.  
 2777

2778 (J) All public water suppliers shall report any high hazard backflow  
 2779 incident within seven days to the Division. The backflow incident shall be reported on a form  
 2780 provided by the Administrator.  
 2781

2782 (ii) Neither steam condensate nor cooling water from engine jackets or other  
 2783 heat exchange devices shall be returned to the public water supply after it has passed through the  
 2784 water service connection.  
 2785  
 2786

Table 4. Backflow Prevention Devices, Assemblies and Methods

Device, Assembly, or Method	Degree of Hazard				Notes
	Low Hazard		High Hazard		
	Back- Siphonage	Back- Pressure	Back- Siphonage	Back- Pressure	
Airgap	X	X	X	X	See Note 1 and Note 2
Atmospheric Vacuum Breaker	X		X		Not allowed under continuous pressure
Spill-proof Pressure-type Vacuum	X		X		
Double Check Valve Backflow Preventer	X	X			
Pressure Vacuum Breaker	X		X		

Reduced Pressure Principal Backflow	X	X	X	X	See Note 2,
Dual Check	X				Restricted to residential services

2787  
 2788  
 2789  
 2790  
 2791  
 2792  
 2793  
 2794  
 2795  
 2796  
 2797  
 2798  
 2799  
 2800  
 2801  
 2802  
 2803  
 2804  
 2805  
 2806  
 2807  
 2808  
 2809  
 2810  
 2811  
 2812  
 2813  
 2814  
 2815  
 2816  
 2817  
 2818  
 2819  
 2820  
 2821  
 2822

Note 1: Minimum Airgap for Water Distribution. For spouts with an effective opening diameter of ½ inch or less, the minimum airgap when the discharge is not affected by side walls shall be one inch. The minimum airgap when the discharge is affected by sidewalls shall be 1 ½ inches. For effective openings greater than ½ inch, the minimum airgap shall be two times the effective opening diameter when the discharge is not affected by sidewalls. The minimum airgap when the discharge is affected by sidewalls shall be three times the effective opening diameter.

Note 2: Extreme Hazards. In the case of any water user’s system where, in the opinion of the water supplier or the Administrator, an undue health threat is posed because of the presence of extremely toxic substances or potential back pressures in excess of the design working pressure of the device, the water supplier may require an airgap at the water service connection to protect the public water system.

**Section 17. Laboratory Requirements.**

(a) 2018 TSS, parts 2.8.1-2.8.1(h), testing equipment, is herein incorporated by reference.

(b) Test procedures for analysis of monitoring samples shall conform to the Standard Methods for the Examination of Water and Wastewater.

(c) All treatment plants shall have the capability to perform or contract for the self-monitoring analytical work required by the Safe Drinking Water Act, 42 U.S.C. §300f et seq. All plants shall, in addition, be capable of performing or contracting the analytical work required to ensure good management and control of plant operation and performance.

(d) All laboratories used for the tests, analysis, and monitoring required by this Section shall meet the following requirements:

(i) The laboratory shall be located away from vibrating machinery or equipment that might have adverse effects on the performance of laboratory instruments or the analyst and shall be designed to prevent adverse effects from vibration.

(ii) Walls shall have an easily cleaned, durable, and impervious surface.

2823 (iii) Cabinet and storage space shall be provided for dust-free storage of  
 2824 instruments and glassware. Benchttop height shall be 30 inches. Benchttops shall be field joined  
 2825 into a continuous surface with acid, alkali, and solvent-resistant cement.

2826  
 2827 (iv) Fume hoods shall be provided where reflux or heating of toxic or  
 2828 hazardous materials is required. A hood shall not be situated near a doorway unless a secondary  
 2829 means of exit is provided. All fume hood switches, electrical outlets, and utility and baffle  
 2830 adjustment handles shall be located outside the hood. Light fixtures shall be explosion-proof. 24-  
 2831 hour continuous exhaust capability shall be provided. Exhaust fans shall be explosion-proof.

2832  
 2833 (v) The laboratory shall have a minimum of two sinks per 400 square feet (not  
 2834 including cup sinks). Sinks shall be double well with drainboards and shall be made of epoxy  
 2835 resin or plastic. All water fixtures shall have reduced pressure zone backflow preventers. Traps  
 2836 shall be constructed of glass, plastic, or lead and be accessible for cleaning.

2837  
 2838 (vi) Distilled water shall conform to the quality specified by Standard Methods  
 2839 for the Examination of Water and Wastewater 2018.

2840  
 2841 (e) Portable testing equipment shall be provided where necessary for operational  
 2842 control testing.

2843  
 2844 **Section 18. Operation and Maintenance Manuals.**

2845  
 2846 (a) Each new or modified treatment or pumping facility shall have an operation and  
 2847 maintenance manual (O & M Manual) located at the facility. The manuals shall provide the  
 2848 following information as a minimum:

2849  
 2850 (i) Introduction;

2851  
 2852 (ii) Description of facilities and unit processes within the plant from influent  
 2853 structures through effluent structures;

2854  
 2855 (A) The size, capacity, model number (where applicable), and intended  
 2856 loading rate of facilities and unit processes;

2857  
 2858 (B) A description of each unit, including the function, controls,  
 2859 lubrication, and maintenance schedule;

2860  
 2861 (C) A description of start-up operations, routine operations, abnormal  
 2862 operations, emergency or power outage operations, bypass procedures, and safety;

2863  
 2864 (D) Flow diagrams of the entire process, as well as individual unit  
 2865 processes that show the flow options under the various operational conditions listed in paragraph  
 2866 (a)(ii) of this Section; and  
 2867

2868 (E) The design criteria for each unit process, including the number,  
2869 type, capacity, sizes, and other relevant information.

2870  
2871 (iii) Plant control system;

2872  
2873 (iv) Utilities and systems;

2874  
2875 (v) Emergency procedures, including:

2876  
2877 (A) Details of emergency operations procedures for possible  
2878 foreseeable emergencies, such as power outage, equipment failure, development of unsafe  
2879 conditions, and other emergency conditions;

2880  
2881 (B) Emergency operations valve positions, flow control settings, and  
2882 other information to ensure continued operation of the facility at maximum possible efficiency  
2883 during emergencies; and

2884  
2885 (C) Emergency notification procedures to be followed to protect health  
2886 and safety under various emergency conditions.

2887  
2888 (vi) Permit requirements and other regulatory requirements;

2889  
2890 (vii) Staffing needs;

2891  
2892 (viii) Index of manufacturers' manuals;

2893  
2894 (ix) Index of equipment maintenance manuals; and

2895  
2896 (x) General information on safety in and around the plant and its components,  
2897 including the following safety information:

2898  
2899 (A) Each unit process discussion shall include applicable safety  
2900 procedures and precautions; and

2901  
2902 (B) For unit processes or operations having extreme hazards (such as  
2903 chlorine and closed tanks), the discussion shall detail appropriate protection, rescue procedures,  
2904 and necessary safety equipment.

2905  
2906 (b) Administrator approval of the final O & M Manual is required prior to plant  
2907 startup.

2908  
2909 (c) Public water supply facilities shall have an equipment maintenance manual  
2910 located at the facility for each piece of equipment. Each equipment maintenance manual shall:

2911  
2912 (i) Have a typewritten table of contents for each volume arranged in a  
2913 systematic order;

- 2914  
 2915 (ii) Include the following general contents:  
 2916  
 2917 (A) Product data;  
 2918  
 2919 (B) Drawings;  
 2920  
 2921 (C) Written text as required to supplement product data for the  
 2922 particular installation;  
 2923  
 2924 (D) Copies of each warranty, bond, and service contract issued;  
 2925  
 2926 (E) Descriptions of unit and component parts;  
 2927  
 2928 (F) Operating procedures;  
 2929  
 2930 (G) Maintenance procedures and schedules;  
 2931  
 2932 (H) Service and lubrication schedule;  
 2933  
 2934 (I) Sequence of control operation;  
 2935  
 2936 (J) Parts list; and  
 2937  
 2938 (K) Recommended spare parts list.  
 2939  
 2940 (iii) Include a section on troubleshooting that shall include:  
 2941  
 2942 (A) Typical operation problems and solutions; and  
 2943  
 2944 (B) A telephone number for factory troubleshooting assistance.  
 2945  
 2946 (iv) Meet the requirements of the engineer and contractor for installation and  
 2947 startup of equipment.  
 2948

2949 **Section 19. Incorporation by Reference.**

- 2950  
 2951 (a) The following codes, standards, rules, and regulations referenced in this Chapter  
 2952 are incorporated by reference:

- 2953  
 2954 (i) American National Standards Institute/National Sanitation Foundation  
 2955 Standard 53, Drinking Water Treatment Units - Health Effects (2019), referred to as “NSF/ANSI  
 2956 53,” available at <https://webstore.ansi.org/Standards/NSF/NSFANSI532020>;  
 2957

- 2958 (ii) American National Standards Institute/National Sanitation Foundation  
 2959 Standard 55, Ultraviolet Microbiological Water Treatment Systems (2020), referred to as  
 2960 “NSF/ANSI 55,” available at <https://webstore.ansi.org/Standards/NSF/NSFANSI552021>;  
 2961
- 2962 (iii) American National Standards Institute/National Sanitation Foundation  
 2963 Standard 61, Drinking Water System Components - Health Effects NSF/ANSI/CAN 61-  
 2964 2020/NSF/ANSI/CAN 600-2021, referred to as “NSF/ANSI/CAN 61-2020/NSF/ANSI/CAN  
 2965 600-2021,” available at <https://webstore.ansi.org/Standards/NSF/NSFANSI612021600>;  
 2966
- 2967 (iv) American National Standards Institute/National Sanitation Foundation  
 2968 Standard 372, Drinking Water System Components-Lead Content 372-20, referred to as  
 2969 “NSF/ANSI/CAN 372-20,” available at  
 2970 <https://webstore.ansi.org/Standards/NSF/NSFANSI3722020>;  
 2971
- 2972 (v) American National Standards Institute/National Sanitation Foundation  
 2973 Standard 419, Public Drinking Water Equipment Performance – Filtration, referred to as  
 2974 “NSF/ANSI 419-2018,” available at  
 2975 <https://webstore.ansi.org/Standards/NSF/NSFANSI4192018>;  
 2976
- 2977 (vi) American Petroleum Institute Specification 5L, Line Pipe, Forty-Sixth  
 2978 Edition (2019), referred to as “API 5L,” available at  
 2979 [https://www.techstreet.com/api/standards/api-spec-5l?gateway\\_code=api&product\\_id=2010552](https://www.techstreet.com/api/standards/api-spec-5l?gateway_code=api&product_id=2010552);  
 2980
- 2981 (vii) American Water Works Association Standard A100, Water Wells, A100-  
 2982 20, referred to as “AWWA A100-20,” available at  
 2983 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/83080725>;  
 2984
- 2985 (viii) American Water Works Association Standard C200, Steel Water Pipe, 6  
 2986 In. (150 mm) and Larger, C200-17 (2017), referred to as “AWWA C200,” available at  
 2987 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/63106282>;  
 2988
- 2989 (ix) American Water Works Association Standard C300, Reinforced Concrete  
 2990 Pressure Pipe, Steel-Cylinder Type, C300-11 (2011), referred to as “AWWA C300,” available at  
 2991 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/59483818>;  
 2992
- 2993 (x) American Water Works Association Standard C301, Prestressed Concrete  
 2994 Pressure Pipe, Steel-Cylinder Type, C301-14 (2014), referred to as “AWWA C301,” available at  
 2995 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/81647229>;  
 2996
- 2997 (xi) American Water Works Association Standard C600, Installation of  
 2998 Ductile-Iron Mains and Their Appurtenances, C600-10 (2010), referred to as “AWWA C600,”  
 2999 available at <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/25724>;  
 3000
- 3001 (xii) American Water Works Association Standard C601, AWWA Standard for  
 3002 Disinfecting Water Mains, C601-81 (1981), referred to as “AWWA C601,” available at  
 3003 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/18646>;

3004  
3005 (xiii) American Water Works Association Standard C652, Disinfection of Water  
3006 Storage Facilities, C652 (2011), referred to as “AWWA C652,” available at  
3007 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/81912774>;  
3008

3009 (xiv) American Water Works Association Standard C900, Polyvinyl Chloride  
3010 (PVC) Pressure Pipe and Fabricated Fittings, 4 In. Through 12 In. (100 mm through 300 mm),  
3011 for Water Transmission and Distribution, C900-07 (2007), referred to as “AWWA C900,”  
3012 available at <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/18943>;  
3013

3014 (xv) American Water Works Association Standard C901, Polyethylene (PE)  
3015 Pressure Pipe and Tubing, 3/4 in. (19 mm) through 3 in. (76 mm), for Water Service, C901- 20  
3016 (2020), referred to as “AWWA C901,” available at  
3017 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/86488411>;  
3018

3019 (xvi) American Water Works Association Standard C906, Polyethylene (PE)  
3020 Pressure Pipe and Fittings, 4 in. through 65 In. (100 mm Through 1,650 mm), for Waterworks,  
3021 C906-21 (2021), referred to as “AWWA C906,” available at  
3022 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/105341623>;  
3023

3024 (xvii) American Water Works Association Standard C950, Fiberglass Pressure  
3025 Pipe, C950-13 (2013), referred to as “AWWA C950,” available at  
3026 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/34040472>;  
3027

3028 (xviii) American Water Works Association Standard D100, Welded Carbon Steel  
3029 Tanks for Water Storage, D100-11 (2011), referred to as “AWWA D100-11,” available at  
3030 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/28162>;  
3031

3032 (xvix) American Water Works Association Standard D102, Coating Steel Water-  
3033 Storage Tanks, D102-17 (2017), referred to as “AWWA D102-21,” available at  
3034 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/92298590>;  
3035

3036 (xx) American Water Works Association Standard D103, Factory-Coated  
3037 Bolted Carbon Steel Tanks for Water Storage, D103-19, referred to as “AWWA D103-19,”  
3038 available at [https://engage.awwa.org/PersonifyEbusiness/Store/Product-](https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/80453600)  
3039 [Details/productId/80453600](https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/80453600);  
3040

3041 (xxi) American Water Works Association Standard D104-17, Automatically  
3042 Controlled, Impressed-Current Cathodic Protection for the Interior of Steel Water Storage,  
3043 referred to as “AWWA D104-17,” available at  
3044 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/65522513>;  
3045

3046 (xxii) American Water Works Association Standard D106-20, Sacrificial anode  
3047 Cathodic Protection Systems for the Interior Submerged Surfaces of Steel Water Storage Tanks,  
3048 referred to as “AWWA D106-20,” available at  
3049 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/84700967>;

3050  
3051 (xxiii) American Water Works Association Standard D107-16, Composite  
3052 Elevated Tanks for Water Storage, referred to as “AWWA D107-16,” available at  
3053 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/54635993>;  
3054  
3055 (xxiv) American Water Works Association Standard D108-19, Aluminum Dome  
3056 Roofs for Water Storage Facilities, referred to as “AWWA D108-19,” available at  
3057 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/80933896>;  
3058  
3059 (xxv) American Water Works Association Standard D110-13 (R18), Wire- and  
3060 Strand-Wound, Circular, Prestressed Concrete Water Tanks, referred to as “AWWA D110-13  
3061 (R18),” available at [https://engage.awwa.org/PersonifyEbusiness/Store/Product-](https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/72304450)  
3062 [Details/productId/72304450](https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/72304450);  
3063  
3064 (xxvi) American Water Works Association Standard D115-20, Tendon-  
3065 Prestressed Concrete Water Tanks, referred to as “AWWA D115-20,” available at  
3066 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/83072907>;  
3067  
3068 (xxvii) American Water Works Association Standard D120-19, Thermosetting  
3069 Fiberglass-Reinforced Plastic Tanks, referred to as “AWWA D120-19,” available at  
3070 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/79004100>;  
3071  
3072 (xxviii) American Water Works Association Standard D121-12, Bolted  
3073 Aboveground Thermosetting Fiberglass Reinforced Plastic Panel-Type Tanks for Water Storage,  
3074 referred to as “AWWA D121-12,” available at  
3075 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/29429>;  
3076  
3077 (xxix) American Water Works Association Standard M23-20, PVC Pipe –  
3078 Design and Installation, Third Edition, M23, referred to as “AWWA M23-20,” available at  
3079 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/81145714>;  
3080  
3081 (xxx) American Water Works Association Standard M55-20, PE Pipe-Design  
3082 and Installation, Second Edition, M55, referred to as “M55-20,” available at  
3083 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/84701177>;  
3084  
3085 (xxxi) American Water Works Association Manual M42, Steel Water Storage  
3086 Tanks, 2013, referred to as “AWWA M42,” available at  
3087 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/36253113>;  
3088  
3089 (xxxii) American National Standards Institute ASSE Standard 1024, Dual Check  
3090 Backflow Preventers, ASSE 1024-17 (2017), referred to as “ASSE 1024,” available at  
3091 <https://webstore.ansi.org/Standards/ASSE-Sanitary/ASSEStandard10242017>;  
3092  
3093 (xxxiii) ASTM International Standard A53, Standard Specification for Pipe, Steel,  
3094 Black and Hot-Dipped, Zinc-Coated, Welded and Seamless, A53M-18 (2018), referred to as  
3095 “ASTM A53, available at [https://www.astm.org/a0053\\_a0053m-18.html](https://www.astm.org/a0053_a0053m-18.html);



- 3096  
3097 (xxxiv) ASTM International Standard A134, Standard Specification for Pipe,  
3098 Steel, Electric-Fusion (Arc)-Welded (Sizes NPS 16 and Over), A134M-18 (2018), referred to as  
3099 “ASTM A134,” available at <https://webstore.ansi.org/standards/astm/astma134a134m18>;  
3100
- 3101 (xxxv) ASTM International Standard A135, Standard Specification for Electric-  
3102 Resistance-Welded Steel Pipe, A135M-19 (2019), referred to as “ASTM A135,” available at  
3103 <https://webstore.ansi.org/standards/astm/astma135a135m19>;  
3104
- 3105 (xxxvi) ASTM International Standard ASTM A139 / A139M – 16, Standard  
3106 Specification for Electric-Fusion (Arc)-Welded Steel Pipe (NPS 4 and Over), (2016), referred to  
3107 as “ASTM A139,” available at [https://www.astm.org/a0139\\_a0139m-16.html](https://www.astm.org/a0139_a0139m-16.html);  
3108
- 3109 (xxxvii) ASTM International Standard A409, Standard Specification for  
3110 Welded Large Diameter Austenitic Steel Pipe for Corrosive or High-Temperature Service,  
3111 A409M-15 (2015), referred to as “ASTM A409,” available at  
3112 <https://webstore.ansi.org/Standards/ASTM/ASTMA409A409M15>;  
3113
- 3114 (xxxviii) ASTM International Standard C12, Standard Practice for Installing  
3115 Vitrified Clay Pipe Lines, C12-17 (2017), referred to as “ASTM C12,” available at  
3116 <https://webstore.ansi.org/standards/astm/astmc1217>;  
3117
- 3118 (xxxix) ASTM International Standard C14, Standard Specification for  
3119 Nonreinforced Concrete Sewer, Storm Drain, and Culvert Pipe, C14-15a (2015), referred to as  
3120 “ASTM C14,” available at  
3121 [https://webstore.ansi.org/standards/astm/astmc1415a?gclid=Cj0KCQiA95aRBhCsARIsAC2xvfxIaQ66MqCuC40LMUwG0WMe0kbvHUvuxW6F3Nc7jy92bGyVdNFHiaoaAo-uEALw\\_wcB](https://webstore.ansi.org/standards/astm/astmc1415a?gclid=Cj0KCQiA95aRBhCsARIsAC2xvfxIaQ66MqCuC40LMUwG0WMe0kbvHUvuxW6F3Nc7jy92bGyVdNFHiaoaAo-uEALw_wcB);  
3122  
3123
- 3124 (xl) ASTM International Standard C76, Standard Specification for Reinforced  
3125 Concrete Culvert, Storm Drain, and Sewer Pipe, C76-19a (2019), referred to as “ASTM C76,”  
3126 available at <https://webstore.ansi.org/Standards/ASTM/ASTMC7619a>;  
3127
- 3128 (xli) ASTM International Standard D2321, Standard Practice for Underground  
3129 Installation of Thermoplastic Pipe for Sewers and Other Gravity-Flow Applications, D2321-18  
3130 (2018), referred to as “ASTM D2321,” available at  
3131 <https://webstore.ansi.org/Standards/ASTM/ASTMD232118>;  
3132
- 3133 (xlii) ASTM International Standard D2846, Standard Specification for  
3134 Chlorinated Poly(Vinyl Chloride) (CPVC) Plastic Hot- and Cold-Water Distribution Systems,  
3135 ASTM D2846/D2846M-19A (2019), referred to as “ASTM D2846,” available at  
3136 <https://webstore.ansi.org/Standards/ASTM/ASTMD2846D2846M19a>;  
3137
- 3138 (xlili) ASTM International Standard D2996, Standard Specification for  
3139 Filament-Wound “Fiberglass” (Glass-Fiber-Reinforced Thermosetting-Resin) Pipe, D2996-17  
3140 (2017), referred to as “ASTM D2996,” available at  
3141 <https://webstore.ansi.org/Standards/ASTM/ASTMD299617>;

3142  
3143 (xlv) ASTM International Standard D2997, Standard Specification for  
3144 Centrifugally Cast “Fiberglass” (Glass-Fiber-Reinforced Thermosetting-Resin) Pipe, D2997-15  
3145 (2015), referred to as “ASTM D2997,” available at  
3146 <https://webstore.ansi.org/Standards/ASTM/ASTMD299715>;

3147  
3148 (xlv) ASTM International Standard D3517, Standard Specification for  
3149 “Fiberglass” (Glass-Fiber-Reinforced Thermosetting-Resin) Pressure Pipe, D3517-19 (2019),  
3150 referred to as “ASTM D3517,” available at  
3151 <https://webstore.ansi.org/Search/Find?in=1&st=ASTM+D3517-19>;

3152  
3153 (xlvi) ASTM International Standard F480, Standard Specification for  
3154 Thermoplastic Well Casing Pipe and Couplings Made in Standard Dimension Ratios (SDR),  
3155 SCH 40 and SCH 80, F480-14 (2014), referred to as “ASTM F480,” available at  
3156 <https://webstore.ansi.org/Standards/ASTM/ASTMF48014>;

3157  
3158 (xlvii) ASTM International Standard F645, Standard Guide for Selection, Design,  
3159 and Installation of Thermoplastic Water- Pressure Piping Systems, ASTM F645-18b, (2018),  
3160 referred to as “ASTM F645,” available at  
3161 <https://webstore.ansi.org/Standards/ASTM/ASTMF64518b>;

3162  
3163 (xlviii) ASTM International Standard F877, Standard Specification for  
3164 Crosslinked Polyethylene (PEX) Hot- and Cold-Water Distribution Systems, ASTM F877-20,  
3165 (2020), referred to as “ASTM F877,” available at  
3166 <https://webstore.ansi.org/Standards/ASTM/ASTMF87720>;

3167  
3168 (xlix) ASTM International Standard F2389, Standard Specification for Pressure-  
3169 rated Polypropylene (PP) Piping Systems, ASTM F2389-21, (2021), referred to as “ASTM  
3170 F2389,” available at <https://webstore.ansi.org/Standards/ASTM/ASTMF238921>;

3171  
3172 (l) ASTM International Standard F2806, Standard Specification for  
3173 Acrylonitrile-Butadiene-Styrene (ABS) Plastic Pipe (Metric SDR-PR), ASTM F2806-20, (2020),  
3174 referred to as “ASTM F2806,” available at  
3175 <https://webstore.ansi.org/Standards/ASTM/ASTMF280620>;

3176  
3177 (li) ASTM International Standard F2855, Standard Specification for  
3178 Chlorinated Poly(Vinyl Chloride)/Aluminum/Chlorinated Poly(Vinyl Chloride) (CPVC-AL-  
3179 CPVC) Composite Pressure Tubing ASTM F2855-19, (2019), referred to as “ASTM F2855,”  
3180 available at <https://webstore.ansi.org/Standards/ASTM/ASTMF285519>;

3181  
3182 (lii) ASTM International Standard F2969, Standard Specification for  
3183 Acrylonitrile-Butadiene-Styrene (ABS) IPS Dimensioned Pressure Pipe ASTM F2969-12(2020),  
3184 (2020), referred to as “ASTM F2969,” available at  
3185 <https://webstore.ansi.org/Standards/ASTM/ASTMF2969122020>;

3186

- 3187 (liii) Standard Methods for the Examination of Water and Wastewater,  
 3188 published by American Public Health Association, American Water Works Association, and  
 3189 Water Environment Federation, 23rd Edition (2018), referred to as “Standard Methods for the  
 3190 Examination of Water and Wastewater 2018,” available at  
 3191 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/65266295>;  
 3192
- 3193 (liv) Code of Federal Regulations 40 CFR Part 141, in effect as of July 1, 2011,  
 3194 available at: <http://www.ecfr.gov>;  
 3195
- 3196 (lv) Code of Federal Regulations 40 CFR 143.3, in effect as of July 1, 2021;  
 3197 available at: <http://www.ecfr.gov>;  
 3198
- 3199 (lvi) Code of Federal Regulations 40 CFR 173.3(e), in effect as of November 7,  
 3200 2018, available at: <http://www.ecfr.gov>;  
 3201
- 3202 (lvii) United States Department of Agriculture, Natural Resources Conservation  
 3203 Service, Part 631 National Engineering Handbook, Chapter 32 Well Design and Spring  
 3204 Development, Part 631.3201(b)(iii), in effect as of January 2010, referred to as “USDA NRCS  
 3205 Part 631 National Engineering Handbook,” available at  
 3206 <https://directives.sc.egov.usda.gov/OpenNonWebContent.aspx?content=26985.wba>;  
 3207
- 3208 (lviii) Recommended Standards for Water Works, published by Great Lakes  
 3209 Upper Mississippi River Board of State and Provincial Public Health and Environmental  
 3210 Managers, (2018), referred to as “2018 TSS,” available at  
 3211 [https://www.mngovpublications.com/catalog/Default.asp?CatalogID=21656&Provider\\_ID=1241](https://www.mngovpublications.com/catalog/Default.asp?CatalogID=21656&Provider_ID=1241868)  
 3212 [868](https://www.mngovpublications.com/catalog/Default.asp?CatalogID=21656&Provider_ID=1241868);  
 3213
- 3214 (lix) United States Environmental Protection Agency, Long Term 2 Enhanced  
 3215 Surface Water Treatment Rule Toolbox Guidance Manual, 2010, referred to as “Toolbox  
 3216 Guidance Manual,” available at <https://nepis.epa.gov/Exe/ZyPDF.cgi?Dockey=P1009JLI.txt>;  
 3217
- 3218 (lx) United States Environmental Protection Agency, Ultraviolet Disinfection  
 3219 Guidance Manual For The Final Long Term 2 Enhanced Surface Water Treatment Rule, 2006,  
 3220 referred to as “Ultraviolet Disinfection Guidance Manual for the Final LT2ESWTR,” available at  
 3221 <https://nepis.epa.gov/Exe/ZyPDF.cgi?Dockey=600006T3.txt>; and  
 3222
- 3223 (lxi) United States Environmental Protection Agency, Membrane Filtration  
 3224 Guidance Manual, 2005, referred to as “US EPA Membrane Filtration Guidance  
 3225 Manual,” available at  
 3226 <https://nepis.epa.gov/Exe/ZyNET.exe/P1008S15.TXT?ZyActionD=ZyDocument&Client=EPA&Index=2006+Thru+2010&Docs=&Query=&Time=&EndTime=&SearchMethod=1&TocRestrict=n&Toc=&TocEntry=&QField=&QFieldYear=&QFieldMonth=&QFieldDay=&IntQFieldOp=0&ExtQFieldOp=0&XmlQuery=&File=D%3A%5Czyfiles%5CIndex%20Data%5C06thru10%5CTxt%5C00000021%5CP1008S15.txt&User=ANONYMOUS&Password=anonymous&SortMethod=h%7C-&MaximumDocuments=1&FuzzyDegree=0&ImageQuality=r75g8/r75g8/x150y150g16/i425&D>  
 3232

3233 isplay=hpfr&DefSeekPage=x&SearchBack=ZyActionL&Back=ZyActionS&BackDesc=Results  
3234 %20page&MaximumPages=1&ZyEntry=1&SeekPage=x&ZyPURL.

3235

3236 (b) For these codes, standards, rules, and regulations incorporated by reference:

3237

3238 (i) The Environmental Quality Council has determined that incorporation of  
3239 the full text in these rules would be cumbersome or inefficient given the length or nature of the  
3240 rules.

3241

3242 (ii) This Chapter does not incorporate later amendments or editions of  
3243 incorporated codes, standards, rules, and regulations.

3244

3245 (iii) All incorporated codes, standards, rules, and regulations are available for  
3246 public inspection at the Department's Cheyenne office. Contact information for the Cheyenne  
3247 office may be obtained at <http://deq.wyoming.gov> or from (307) 777-7937.

CHAPTER 12

Design and Construction Standards for Public Water Supplies

**Section 1. Authority.**

These standards are promulgated pursuant to ~~W.S. 35-11-101 through 35-11-1207~~ the Wyoming Environmental Quality Act, ~~Specifically, W.S. § 35-11-302 requires the administrator to establish standards for the issuance of permits for construction, installation, or modification of any public water supply.~~

**Section 2. ~~Purpose.~~ Applicability.**

~~The purpose of these standards is to:~~

~~(a) — Ensure that the design and construction of public water supplies meet the purpose of the Environmental Quality Act.~~

~~(b) — Prevent, reduce and eliminate pollution and enhance the waters of the State of Wyoming by ensuring that the design and construction of public water supplies are capable of the required treatment and distribution providing continued operation to protect the health, safety and welfare of the users and operators.~~

~~These standards pertain only to permits required pursuant to Chapter 3, Wyoming Water Quality Rules and Regulations.~~

(a) This Chapter contains the minimum standards for the design and construction of public water supplies that are required to obtain a permit under Wyoming Statute (W.S.) § 35-11-301(a)(iii) and Water Quality Rules Chapter 3.

(i) All applicants for a Water Quality Rules Chapter 3 permit to construct, install, modify, or operate a public water supply facility shall comply with all minimum standards of this Chapter.

(ii) No permit to construct, install, modify, or operate a public water supply facility shall be issued to a facility that does not comply with the minimum standards of this Chapter.

(iii) All public water supply facilities shall be constructed, installed, and operated in accordance with permits issued pursuant to this Chapter.

(b) The construction, installation, or modification of any component of a public water supply facility requires a permit to construct.

**Section 3. ~~Intent~~ Timing of Compliance with These Regulations.**

46 ~~The design and construction standards included in these regulations are directed toward~~  
47 ~~conventional public water systems. These standards impose limiting values of design for which a~~  
48 ~~construction, installation, or modification permit application and plans and specifications can be~~  
49 ~~evaluated by the division.~~

50  
51 ~~The terms “shall” and “must” are used when practice is sufficiently standardized to permit~~  
52 ~~specific delineation of requirements or when safeguarding public health or protection of water~~  
53 ~~quality justifies such definite action. Other terms, such as “should”, “recommend”, and~~  
54 ~~“preferred” indicate desirable procedures or methods which allow deviations provided the~~  
55 ~~purpose of these regulations can be accomplished.~~

56  
57 ~~The applicant shall use the date referenced copy of other standards referred to in these~~  
58 ~~regulations. Where no date is listed for the referenced standards, the standards used shall be~~  
59 ~~those in effect when these regulations become effective.~~

60  
61 Any facility covered by an individual or general permit issued pursuant to Water Quality  
62 Rules, Chapter 3, prior to the effective date of this Chapter shall remain covered under that  
63 permit. New construction or modification of existing permitted facilities must obtain  
64 authorization under a new permit, in accordance with Water Quality Rules Chapter 3, Section  
65 4(d) or Section 5(e), subject to the requirements of this Chapter.

66  
67 **Section 4. ~~Definitions~~ Incorporation By Reference of Recommended Standards**  
68 **for Water Works 2018 Edition.**

69  
70 ~~(moved to Section 5) The following definitions supplement those contained in W.S. 35-~~  
71 ~~11-103 of the Wyoming Environmental Quality Act.~~

72  
73 ~~(moved to Section 5(a))(a) —“Auxiliary source of supply” means any water supply on or~~  
74 ~~available to the water user’s system other than an approved public water supply acceptable to the~~  
75 ~~water supplier.~~

76  
77 ~~These auxiliary waters may include water from another supplier’s public potable water supply or~~  
78 ~~any natural source(s), such as a well, spring, river, stream, harbor, and so forth; used waters; or~~  
79 ~~industrial fluids. These waters may be contaminated or polluted, they may be objectionable or~~  
80 ~~they may be from a water source which the water supplier is uncertain of sanitary control.~~

81  
82 ~~(moved to Section 5(b))(b) —“Average daily demand” means the total annual water use~~  
83 ~~divided by the number of days the system was in operation.~~

84  
85 ~~(moved to Section 4(e))(b) —“Backflow” means the undesirable reversal of flow of~~  
86 ~~water or mixtures of water and other liquids, gases, or other substances into the distribution~~  
87 ~~system of the public water supply from any other source or sources.~~

88  
89 ~~(moved to Section 5(d))(c) —“Backflow incident” means any identified backflow to a~~  
90 ~~public water supply distribution system or to the potable water piping within the water user’s~~

91 ~~system benefitting from a water service connection to the public water supply distribution~~  
92 ~~system.~~

93  
94 ~~(moved to Section 5(e))(d) —“Back pressure” means a form of backflow caused when~~  
95 ~~the pressure of the water users’ system is greater than that of the water supply system. This could~~  
96 ~~be caused by a pump, elevated tank, elevated piping, boiler, pressurized process, pressurized~~  
97 ~~irrigation system, air pressure or any other cause of pressure.~~

98  
99 ~~(moved to Section 5(f))(e) —“Back siphonage” means a form of backflow caused by~~  
100 ~~negative or reduced pressure in the water supply system. This situation can be caused by loss of~~  
101 ~~pressure due to high water demands, a line break, excessive fire fighting flows, etc.~~

102  
103 ~~(f) —“Containment” means the practice of installing approved backflow prevention~~  
104 ~~devices at the water service connection of the water user in order to protect the public water~~  
105 ~~supply from any backflow from the water users system.~~

106  
107 ~~(moved to Section 5(h))(g) —“Contamination” means an impairment of a public water~~  
108 ~~supply by the introduction or admission of any foreign substance which degrades the quality of~~  
109 ~~the potable water or creates a health hazard.~~

110  
111 ~~(moved to Section 5(i))(h) —“Cross connection” means any actual or potential~~  
112 ~~connection between a potable water supply and any other source or system through which it is~~  
113 ~~possible to introduce contamination into the system.~~

114  
115 ~~(moved to Section 5(j))(i) —“Degree of hazard” means either a high or low hazard~~  
116 ~~situation where a substance may be introduced into a public water supply through a cross~~  
117 ~~connection. The degree of hazard or threat to public health is determined by a hazard~~  
118 ~~classification.~~

119  
120 ~~(moved to Section 5(k))(j) —“Domestic services” means services using potable water for~~  
121 ~~ordinary living processes and not for commercial or industrial uses, fire protection systems with~~  
122 ~~antifreeze or other chemicals, heating systems, etc. Examples may include residences, churches,~~  
123 ~~office buildings, schools, etc.~~

124  
125 ~~(moved to Section 5(l))(k) —“Dual check” means a device conforming to ASSE~~  
126 ~~Standard #1024 consisting of two independently acting check valves. Dual check valves are~~  
127 ~~allowed only for residential water service connections that have a low hazard potential with back~~  
128 ~~pressure or backsiphonage under continuous pressure.~~

129  
130 ~~(moved to Section 5(m))(l) —“Groundwater source” includes all water obtained from~~  
131 ~~dug, drilled, bored, jetted or driven wells; springs which are developed so that the water does not~~  
132 ~~flow on the ground and protected to preclude the entrance of surface contamination; and~~  
133 ~~collection wells.~~

134

135 ~~(moved to Section 5(n))(m) —“Hazard classification” means a determination by a hazard~~  
136 ~~classification surveyor as to high hazard or low hazard and the potential cause of backflow as~~  
137 ~~either back pressure or back siphonage.~~

138  
139 ~~(moved to Section 5(o))(n) —“Hazard classification survey” means inspection of a~~  
140 ~~premises to identify the potable water systems, the location of any potential cross connections to~~  
141 ~~the potable water systems, the hazard of the potential backflow, the physical identification of any~~  
142 ~~backflow devices or methods present and the inspection status of any backflow devices or~~  
143 ~~methods. The hazard classification survey results must be recorded and certified by a qualified~~  
144 ~~hazard classification surveyor.~~

145  
146 ~~(moved to Section 5(p))(o) —“Hazard classification surveyor” means an individual~~  
147 ~~certified by the USC Foundation for Cross Connection Control and Hydraulic Research as~~  
148 ~~Cross Connection Control Specialist, the American Association of Sanitary Engineers (ASSE) as~~  
149 ~~a Cross Connection Control Surveyor, or by another state certification program approved by the~~  
150 ~~administrator, or by a water distribution system operator also certified as a backflow device~~  
151 ~~tester employed by the public water supplier for the service where the survey is being conducted.~~

152  
153 ~~(moved to Section 5(q))(p) —“High hazard” means a situation created when any~~  
154 ~~substance which is or may be introduced into a public water supply poses a threat to public~~  
155 ~~health through poisoning, the spread of disease or pathogenic organisms, or any other public~~  
156 ~~health concern.~~

157  
158 ~~(moved to Section 5(r))(q) —“Isolated” when referring to cross connections means the~~  
159 ~~proper approved backflow prevention devices have been installed at each point of cross~~  
160 ~~connection within the water user's system. This requires the installation of an approved backflow~~  
161 ~~protection device at each source of possible contamination. This type of control has the~~  
162 ~~advantage of protecting health within the water user's system as well as protecting the public~~  
163 ~~water supply.~~

164  
165 ~~(moved to Section 5(s))(r) —“Low hazard” means a situation created when any~~  
166 ~~substance which is or may be introduced into a public water supply does not pose a threat to~~  
167 ~~public health but which does adversely affect the aesthetic quality of the potable water.~~

168  
169 ~~(moved to Section 5(t))(s) —“Maximum daily demand” means the demand for water~~  
170 ~~exerted on the system over a period of 24 consecutive hours, for the period during which such~~  
171 ~~demand is greatest.~~

172  
173 ~~(moved to Section 5(u))(t) —“Maximum hour demand” means the highest single hour~~  
174 ~~demand exerted on the system. This may or may not occur on the maximum day.~~

175  
176 ~~(moved to Section 5(w))(u) —“Mineralized water” means any water containing more than~~  
177 ~~500 mg/L total dissolved solids.~~

178  
179 ~~(v) —“Offstream reservoir” means a facility into which water is pumped during periods~~  
180 ~~of good quality and high stream flow for future release to treatment facilities.~~



181  
182 ~~(moved to Section 5(aa))(w) “Surface water source” includes all tributary streams and~~  
183 ~~drainage basins, natural lakes and artificial reservoirs or impoundments upstream from the point~~  
184 ~~of the water supply intake.~~

185  
186 ~~(moved to Section 5(cc))(x) “Water service connection” means any water line or pipe~~  
187 ~~connected to a distribution supply main or pipe for the purpose of conveying water to a water~~  
188 ~~user’s system.~~

189  
190 ~~(moved to Section 5(dd))(y) “Water supplier” means any entity that owns or operates a~~  
191 ~~public water supply, whether public or private.~~

192  
193 ~~(moved to Section 5(ee))(z) “Water user” means any entity, whether public or private,~~  
194 ~~with a water service connection to a public water supply. The water user is also identified as a~~  
195 ~~customer of a public water supply.~~

196  
197 ~~(moved to Section 5(ff))(aa) “Water user’s system” means that portion of the user’s~~  
198 ~~water system between the water service connection and the point of use. This system includes all~~  
199 ~~pipes, conduits, tanks, fixtures, and appurtenances used to convey, store or utilize water provided~~  
200 ~~by the public water supply.~~

201  
202 (a) This Chapter incorporates sections of the Recommended Standards for Water  
203 Works, A Report of the Water Supply Committee of the Great Lakes--Upper Mississippi River  
204 Board of State and Provincial Public Health and Environmental Managers, 2018 Edition, referred  
205 to as “2018 TSS,” as noted in Section 8(a), Section 9(a), Section 10(a), Section 11(a), Section  
206 12(a), Section 13(a), Section 14(a), Section 15(a), Section 16(a), Section 17(a), and Section  
207 19(a)(lviii) of this Chapter.

208  
209 (b) The State term “Administrator” shall replace the term “reviewing authority” used  
210 in the Recommended Standards for Water Works 2018 Edition.

211  
212 (c) The State term “shall” shall replace the term “should” used in the Recommended  
213 Standards for Water Works 2018 Edition.

214  
215 **Section 5. ~~Facilities and Systems not Specifically Covered by these Standards~~**  
216 **Definitions.**

217  
218 ~~(moved to Section 6(a)) This section is provided to encourage new technology and~~  
219 ~~equipment and provide a process for evaluating and permitting designs which deviate from these~~  
220 ~~regulations. The proposed construction of facilities and processes not in compliance with these~~  
221 ~~regulations will be permitted provided that the facility, when constructed, can operate meeting~~  
222 ~~the purpose of these regulations.~~

223  
224 ~~(moved to Section 6(b))(a) — Each application for a permit to construct a facility under~~  
225 ~~this section shall be evaluated on a case-by-case basis using the best available technology. The~~  
226 ~~following information should be included with the application:~~

227  
228 ~~(moved to Section 6(b)(i)(A))(i) — Data obtained from a full scale, comparable~~  
229 ~~installation which demonstrates the acceptability of the design; and/or~~

230  
231 ~~(moved to Section 6(b)(i)(B))(ii) — Data obtained from a pilot plant operated~~  
232 ~~under the design condition for a sufficient length of time to demonstrate the acceptability of the~~  
233 ~~design; and/or~~

234  
235 ~~(moved to Section 6(b)(i)(C))(iii) — Data obtained from a theoretical evaluation~~  
236 ~~of the design which demonstrates a reasonable probability of the facility meeting the design~~  
237 ~~objectives; and~~

238  
239 ~~(moved to Section 6(b)(ii))(iv) — An evaluation of the flexibility of making~~  
240 ~~corrective changes to the constructed facility in the event it does not function as planned.~~

241  
242 ~~(moved to Section 6(c))(b) — If an applicant wishes to construct a pilot plant to provide~~  
243 ~~the data necessary to show the design will meet the purpose of the act, a permit to construct must~~  
244 ~~be obtained.~~

245  
246 ~~(formerly Section 4)(a)~~ The following definitions supplement those contained in W.S. §  
247 35-11-103 of the Wyoming Environmental Quality Act.

248  
249 ~~(formerly Section 4(a))(b)~~ “Auxiliary source of supply” means any water supply on or  
250 available to the water user’s system other than an approved public water supply acceptable to the  
251 water supplier. These auxiliary waters may include water from another supplier’s public potable  
252 water supply or any natural source(s), such as a well, spring, river, stream, harbor, and so forth;  
253 used waters; or industrial fluids. These waters may be contaminated or polluted, they may be  
254 objectionable or they may be from a water source ~~which~~ that the water supplier is uncertain of  
255 sanitary control.

256  
257 ~~(formerly Section 4(b))(c)~~ “Average daily demand” means the total annual water use  
258 divided by the number of days the system was in operation.

259  
260 ~~(formerly Section 4(b))(d)~~ “Backflow” means the undesirable reversal of flow of  
261 water or mixtures of water and other liquids, gases, or other substances into the distribution  
262 system of the public water supply from any other source or sources.

263  
264 ~~(formerly Section 4(e))(e)~~ “Backflow incident” means any identified backflow to a  
265 public water supply distribution system or to the potable water piping within the water user’s  
266 system benefitting from a water service connection to the public water supply distribution  
267 system.

268  
269 ~~(formerly Section 4(d))(f)~~ “Back-pressure” means a form of backflow caused when  
270 the pressure of the water users’s system is greater than that of the water supply system. ~~This~~  
271 ~~could be~~ whether caused by a pump, elevated tank, elevated piping, boiler, pressurized process,  
272 pressurized irrigation system, or air pressure ~~or any other cause of pressure.~~

273  
274 ~~(formerly Section 4(e))(g)~~ “Back-siphonage” means a form of backflow caused by  
275 negative or reduced pressure in the water supply system. ~~This situation can be~~ whether caused by  
276 loss of pressure due to high water demands, a line break, or excessive ~~fire fighting~~ firefighting  
277 flows, ~~etc.~~

278  
279 ~~(formerly Section 4(f))~~ ~~“Containment” means the practice of installing approved~~  
280 ~~backflow prevention devices at the water service connection of the water user in order to protect~~  
281 ~~the public water supply from any backflow from the water users system.~~

282  
283 (h) “Calculated Dose” means the reduction equivalent dose (RED) calculated using  
284 the dose-monitoring equation that was developed through validation testing.

285  
286 ~~(formerly Section 4(g))(i)~~ “Contamination” means an impairment of a public water  
287 supply by the introduction or admission of any foreign substance ~~which~~ that degrades the quality  
288 of the potable water or creates a health hazard.

289  
290 ~~(formerly Section 4(h))(j)~~ “Cross-connection” means any actual or potential  
291 connection between a potable water supply and any other source or system through which it is  
292 possible to introduce contamination into the system.

293  
294 ~~(formerly Section 4(i))(k)~~ “Degree of hazard” means either a high or low hazard  
295 situation where a substance may be introduced into a public water supply through a cross-  
296 connection. The degree of hazard or threat to public health is determined by a hazard  
297 classification.

298  
299 ~~(formerly Section 4(j))(l)~~ “Domestic services” means services using potable water for  
300 ordinary living processes ~~and not for commercial or industrial uses, fire protection systems with~~  
301 ~~antifreeze or other chemicals, heating systems, etc. Examples may include residences, churches,~~  
302 ~~office buildings, schools, etc.~~

303  
304 ~~(formerly Section 4(k))(m)~~ “Dual check” means a device conforming to American  
305 Association of Sanitary Engineers (ASSE) Standard #1024 consisting of two independently  
306 acting check valves. ~~Dual check valves are allowed only for residential water service connections~~  
307 ~~that have a low hazard potential with back pressure or backsiphonage under continuous pressure.~~

308  
309 ~~(formerly Section 4(l))(n)~~ “Groundwater source” includes all water obtained from  
310 dug, drilled, bored, jetted or driven wells; springs ~~which~~ that are developed so that the water does  
311 not flow on the ground and that are protected to preclude the entrance of surface contamination;  
312 and collection wells.

313  
314 ~~(formerly Section 4(m))(o)~~ “Hazard classification” means a determination by a  
315 ~~h~~Hazard ~~e~~Classification ~~s~~Surveyor as to high hazard or low hazard and the potential cause of  
316 backflow as either back-pressure or back-siphonage.

317

318 ~~(formerly Section 4(n))(p)~~ “Hazard eClassification sSurvey” means inspection of a  
319 premises to identify the potable water systems, the location of any potential cross connections to  
320 the potable water systems, the hazard of the potential backflow, the physical identification of any  
321 backflow devices or methods present, and the inspection status of any backflow devices or  
322 methods. ~~The hazard classification survey results must be~~ recorded and certified by a qualified  
323 hHazard eClassification sSurveyor.  
324

325 ~~(formerly Section 4(o))(q)~~ “Hazard eClassification sSurveyor” means an individual  
326 certified by the USC- Foundation for Cross-Connection Control and Hydraulic Research as  
327 Cross Connection Control Specialist, ~~(USC-FCCCHR), the American Association of Sanitary~~  
328 ~~Engineers (ASSE)~~ as a Cross-Connection Control Surveyor, or ~~by~~ another state certification  
329 program submitted with the permit application and approved by the aAdministrator, or ~~by an~~  
330 individual who is a water distribution system operator also certified as a backflow device tester  
331 employed by the public water supplier for the service where the survey is being conducted.  
332

333 ~~(formerly Section 4(p))(r)~~ “High hazard” means a situation created when any  
334 substance ~~which~~ that is or may be introduced into a public water supply poses a threat to public  
335 health through poisoning, the spread of disease or pathogenic organisms, or any other public  
336 health concern.  
337

338 ~~(formerly Section 4(q))(s)~~ “Isolated” when referring to cross connections means the  
339 properly approved backflow prevention devices have been installed at each point of cross-  
340 connection within the water user's system. ~~This requires the installation of an approved backflow~~  
341 ~~protection device at each source of possible contamination. This type of control has the~~  
342 ~~advantage of protecting health within the water user's system as well as protecting the public~~  
343 ~~water supply.~~  
344

345 ~~(formerly Section 4(r))(t)~~ “Low hazard” means a situation created when any  
346 substance ~~which~~ that is or may be introduced into a public water supply does not pose a threat to  
347 public health but ~~which~~ that does adversely affect the aesthetic quality of the potable water.  
348

349 ~~(formerly Section 4(s))(u)~~ “Maximum daily demand” means the demand for water  
350 exerted on the system over a period of 24 consecutive hours, for the period during which such  
351 demand is greatest.  
352

353 ~~(formerly Section 4(t))(v)~~ “Maximum hourly demand” means the highest single-hour  
354 demand exerted on the system. This may or may not occur on the maximum day.  
355

356 (w) “Mechanical sludge equipment” means the equipment used to physically remove  
357 solids from a water treatment process. This may include mechanical drives that use scrapers or  
358 differential water levels to collect the sludge.  
359

360 ~~(formerly Section 4(u))(x)~~ “Mineralized water” means any water containing more than  
361 500 mg/L total dissolved solids.  
362

363 (y) “Minor field change” means any in-field adjustment due to previously unknown  
364 physical constraints of the project site that do not affect the project’s scope. Minor field changes  
365 still allow full compliance with the requirements of this Chapter and are shown on the submitted,  
366 post-construction as-built plan set for the Division in red.

367  
368 (zz) “Primary disinfection” means disinfection that kills or inactivates bacteria,  
369 viruses, and other potentially harmful organisms in drinking water.

370  
371 (aa) “Reduction Equivalent Dose” means the ultraviolet (UV) dose derived by entering  
372 the log inactivation measured during full-scale reactor testing into the UV dose-response curve  
373 that was derived through collimated beam testing. RED values are always specific to the  
374 challenge microorganism used during experimental testing and the validation test conditions for  
375 full-scale reactor testing.

376  
377 (bb) “Required Dose” means the UV dose in units of mJ/cm<sup>2</sup> req needed to achieve  
378 the target log inactivation for the target pathogen.

379  
380 (cc) “Secondary disinfection” means disinfection that provides longer lasting water  
381 treatment as the water moves through pipes to consumers.

382  
383 (dd) “Stabilized drawdown” means a water level that has not fluctuated by more than  
384 plus or minus 0.5 foot for each 100 feet of water in the well over at least a six-hour period of  
385 constant pumping flow rate. The water column is measured from pre-test static water level to the  
386 top of the deepest water bearing fracture that contributes at least 10 percent of total well yield,  
387 and plotted measurements that have not shown a trend of decreasing water level.

388  
389 ~~(formerly Section 4(w))~~(ee) “Surface water source” includes all tributary streams and  
390 drainage basins, natural lakes, and artificial reservoirs or impoundments upstream from the point  
391 of the water supply intake.

392  
393 (ff) “Validated Dose” means the UV dose in units of mJ/cm<sup>2</sup> delivered by the UV  
394 reactor as determined through validation testing that is compared to the required dose to  
395 determine log inactivation credit.

396  
397 ~~(formerly Section 4(x))~~(gg) “Water service connection” means any water line or pipe  
398 connected to a distribution supply main or pipe for the purpose of conveying water to a water  
399 user’s system.

400  
401 ~~(formerly Section 4(y))~~(hh) “Water supplier” means any entity that owns or operates a  
402 public water supply, whether public or private.

403  
404 ~~(formerly Section 4(z))~~(ii) “Water user” means any entity, whether public or private,  
405 with a water service connection to a public water supply. ~~The water user is also identified as a~~  
406 and includes customers of a public water supply~~ier.~~

407

408 ~~(formerly Section 4(aa))(jj)~~ “Water user’s system” means that portion of the user’s  
409 water system between the water service connection and the point of use. This system includes all  
410 pipes, conduits, tanks, fixtures, and appurtenances used to convey, store, or ~~utilize~~ use water  
411 provided by the public water supply.

412  
413 **Section 6. ~~Engineering Design Report~~ Facilities and Systems not Specifically**  
414 **Covered by these Standards.**

415  
416 ~~(moved to Section 9(b))(a) — Scope and purpose. An engineering design report shall be~~  
417 ~~submitted with each application. The purpose of the report shall be to describe and provide~~  
418 ~~technical justification for all aspects of the proposed construction, modifications and/or~~  
419 ~~installations. The report should address existing conditions (if any), known or suspected~~  
420 ~~problems, proposed actions, and the reasoning used to arrive at those proposed actions. There is~~  
421 ~~no minimum or maximum size for the report, provided it meets the purpose of this section.~~

422  
423 ~~(moved to Section 9(c))(b) — Water distribution (water works) systems. The engineering~~  
424 ~~design report for all new water distribution system extensions shall include:~~

425  
426 ~~(moved to Section 9(c)(ii))(i) A description of the service area including sealed~~  
427 ~~vicinity plan map(s) of the project with regard to adjacent and proposed development, elevations,~~  
428 ~~and topographic features.~~

429  
430 ~~(moved to Section 9(c)(iii))(ii) — Current and projected system water demand~~  
431 ~~for average day, maximum day, maximum hour, needed fire flows and per capita maximum daily~~  
432 ~~flows.~~

433  
434 ~~(moved to Section 9(c)(iv))(iii) — Information on fire protection and fire flow~~  
435 ~~capabilities of the proposed system.~~

436  
437 ~~(iv) — Description of high service pumping systems and finished water storage~~  
438 ~~facilities.~~

439  
440 ~~(moved to Section 9(d))(c) — Treatment facilities. The engineering design report shall~~  
441 ~~include:~~

442  
443 ~~(moved to Section 9(d)(ii))(i) A description of the facility site and location,~~  
444 ~~including a sealed site plan, and:~~

445  
446 ~~(moved to Section 9(d)(ii)(A))(A) — Present and projected facility~~  
447 ~~property boundaries.~~

448  
449 ~~(moved to Section 9(d)(ii)(B))(B) — Flood protection indicating predicted~~  
450 ~~elevation of 25- and 100-year flood stages. The facility shall be protected from damage and be~~  
451 ~~capable of being operated during the 100-year flood or maximum flood of record, whichever is~~  
452 ~~greater. Flooding resulting from ice jams shall be considered.~~

453

454 ~~(moved to Section 9(d)(ii)(C))(C) — Present and proposed access.~~

455  
456 ~~(moved to Section 9(d)(ii)(D))(D) — Distances from current habitation,~~  
457 ~~the closest major treated water transmission line, the closest treated water storage facility, and~~  
458 ~~the water source.~~

459  
460 ~~(moved to Section 9(d)(ii)(E))(E) — Fencing and/or security.~~

461  
462 ~~(moved to Section 9(d)(ii)(F))(F) — Topographic features and contours~~  
463 ~~with indicated datum.~~

464  
465 ~~(moved to Section 9(d)(ii)(G))(G) — Soil and subsurface geological~~  
466 ~~characteristics. Provide a soils investigation report of the proposed site suitable for structural~~  
467 ~~design of the proposed facilities.~~

468  
469 ~~(moved to Section 9(d)(iii))(ii) — A detailed description of the service area for~~  
470 ~~the project including a scaled plan showing land use and boundaries.~~

471  
472 ~~(moved to Section 9(d)(iv))(iii) — A detailed description of the recycle flows~~  
473 ~~and procedures for reclamation of recycle streams.~~

474  
475 ~~(moved to Section 9(d)(v))(iv) — A detailed description of disposal techniques~~  
476 ~~for settled solids, including a description of the ultimate disposal of sludge.~~

477  
478 ~~(v) — Sources of water supply shall be described to include:~~

479  
480 ~~(moved to Section 9(f))(A) — Groundwater sources.~~

481  
482 ~~(moved to Section 9(f)(ii))(I) — Geology of aquifer and overlying~~  
483 ~~strata.~~

484  
485 ~~(II) — Summary of source exploration data, including test well~~  
486 ~~depth and method of construction; test pumping rates and duration; and water levels and specific~~  
487 ~~yield.~~

488  
489 ~~(moved to Section 9(f)(iii)) — Water quality, including biological, radiological and chemical~~  
490 ~~quality data sufficient to determine necessary treatment processes and compliance with all~~  
491 ~~drinking water standards as determined by the administrator. The same water quality data for all~~  
492 ~~secondary sources shall also be provided.~~

493  
494 ~~(III) — Sources of possible contamination around well and in any~~  
495 ~~known recharge areas, including location of any waste sites, industrial facilities and wastewater~~  
496 ~~disposal areas.~~

497  
498 ~~(B) — Surface water sources.~~

499

- 500 ~~(moved to Section 9(e)(ii))(I) Safe annual yield, the quantity of~~  
501 ~~water available from the source during the average and driest years of record.~~  
502
- 503 ~~(moved to Section 9(e)(ii)(A))(II) Hydrological data, stream~~  
504 ~~flows and diversion records.~~  
505
- 506 ~~(moved to Section 9(e)(iii)(III) Representative water quality~~  
507 ~~data, including bacteriological, radiological, chemical and physical data. These data shall be~~  
508 ~~sufficient to determine the necessary process and the ability to meet water quality standards.~~  
509
- 510 ~~(IV) Description of the watershed noting sources of potential~~  
511 ~~contamination.~~  
512
- 513 ~~(V) Description of any anticipated changes in water quality.~~  
514
- 515 ~~(moved to Section 9(e)(ii)(B))(VI) Description of any diversion~~  
516 ~~dams, impoundments or reservoirs and appurtenances.~~  
517
- 518 ~~(vi) Plant design conditions, including:~~  
519
- 520 ~~(A) Historical and design population.~~  
521
- 522 ~~(B) Existing and projected maximum daily demand flows and demand~~  
523 ~~variations.~~  
524
- 525 ~~(C) Complete description of existing facilities.~~  
526
- 527 ~~(D) Where applicable, a complete description of proposed treatment~~  
528 ~~process including:~~  
529
- 530 ~~(I) Unit process design criteria addressing flash mixing,~~  
531 ~~flocculation and settling basin size and equipment description; retention times; unit loadings and~~  
532 ~~overflow rates; filter area and proposed filtration rate; backwash rate and volume requirements;~~  
533 ~~chemical feeder capacities and ranges; and disinfection feeder capacities and ranges.~~  
534
- 535 ~~(II) Chemical requirements, including dosages and feed rates.~~  
536 ~~(III) Chemical delivery, handling, and storage systems.~~  
537
- 538 ~~(IV) Waste generation including types and volumes.~~  
539
- 540 ~~(V) Waste stream recycling, including holding basin capacities,~~  
541 ~~pump sizes and recycle rates.~~  
542
- 543 ~~(VI) Methods of ultimate waste disposal.~~  
544
- 545 ~~(VII) Low service pumping facilities.~~



546  
547                   ~~(E) — Description of on-site restrooms and sanitary sewer facilities.~~  
548  
549                   ~~(vii) — Summary of automatic operation and control systems, including basic~~  
550 ~~operation, manual override operation, and maintenance requirements.~~  
551  
552                   ~~(viii) — Description of the on-site laboratory facilities and a summary of those~~  
553 ~~tests to be conducted on-site. If no on-site laboratory is provided, a description of plant control~~  
554 ~~and water quality testing requirements, and where the testing will be conducted shall be included.~~  
555 ~~Description of cross-control measures to be provided at chemical feed tanks, filters, washdown~~  
556 ~~taps, direct connection to sewer or other relevant protection.~~  
557  
558                   ~~(moved to Section 9(b)(iv))(d) — Hazard classification. The engineering design report~~  
559 ~~shall include a hazard classification or specify the default classification identified in Section 14~~  
560 ~~(i) (i) (B) which shall be applicable to the project. A hazard classification shall include the~~  
561 ~~following:~~  
562  
563                   ~~(i) — A determination of the degree of hazard of all water service connections to~~  
564 ~~be connected to the proposed project.~~  
565  
566                   ~~(ii) — A determination of the potential cause of backflow for all water service~~  
567 ~~connections.~~  
568  
569                   ~~(formerly Section 5) This section is provided to encourage new technology and~~  
570 ~~equipment and provide a process for evaluating and permitting designs which deviate from these~~  
571 ~~regulations. The proposed construction of facilities and processes not in compliance with these~~  
572 ~~regulations will be permitted provided that the facility, when constructed, can operate meeting~~  
573 ~~the purpose of these regulations.~~  
574  
575                   ~~(formerly Section 5)(a)~~           Each application for a permit to construct a facility under  
576 this section shall be evaluated on a case-by-case basis using the best available technology. ~~The~~  
577 ~~following information should be included with the application:~~ The Administrator may approve  
578 applications demonstrating the constructed facility can meet the purpose of the Wyoming  
579 Environmental Quality Act and this Chapter.  
580  
581                   (b) The following information shall be included with the application for a permit to  
582 construct, install, modify, or operate a public water supply facility not specifically covered by  
583 these standards:  
584  
585                   ~~(formerly Section 5(a)(i))(i)~~ (i)   Data obtained from ~~a full-scale, comparable~~  
586 ~~installation which demonstrates the acceptability of the design; and/or:~~  
587  
588                   (A) a full scale, comparable installation ~~which~~ that demonstrates the  
589 acceptability of the design; ~~and/or~~  
590

591 ~~(formerly Section 5(a)(ii))(B) Data obtained from a~~ pilot plant operated  
592 under the design condition for a sufficient length of time to demonstrate the acceptability of the  
593 design; ~~and/or~~

594  
595 ~~(formerly Section 5(a)(iii))(C) \_\_\_\_\_ Data obtained from a~~ theoretical  
596 evaluation of the design ~~which~~ demonstrates a reasonable probability ~~of that~~ the facility ~~will~~  
597 ~~meeting~~ the design objectives; ~~and.~~

598  
599 ~~(formerly Section 5(a)(iv))(ii) An evaluation of the flexibility of making corrective~~  
600 changes to the constructed facility in the event it does not function as planned.

601  
602 ~~(formerly Section 5(b))(c) If an applicant wishes to construct a pilot plant to provide~~  
603 the data necessary to ~~show the design will~~ meet the ~~purpose requirements~~ of ~~the act~~ this Section,  
604 the applicant must obtain a permit to construct ~~must be obtained~~.

605  
606 **Section 7. ~~Plans and Specifications Content~~ Permits, Permit Application, and**  
607 **Recordkeeping Requirements.**

608  
609 ~~(moved to Section 8(b))(a) — All plans for water works and treatment facilities shall have~~  
610 ~~a suitable title showing the following:~~

611  
612 ~~(moved to Section 8(b))(i) — Name of owner and location of project.~~

613  
614 ~~(ii) — North arrow and drawing scale.~~

615  
616 ~~(iii) — Name, Wyoming registration number, and seal or signature of the~~  
617 ~~engineer.~~

618  
619 ~~(b) — All plans shall contain a site plan of the proposed project with topography and~~  
620 ~~boundaries of the project. Datum used shall be indicated.~~

621  
622 ~~(moved to Section 8(c))(c) — Water lines. Plans for transmission and distribution lines~~  
623 ~~shall include:~~

624  
625 ~~(moved to Section 8(c)(i)(i) — A detailed plan view at a legible scale of each reach~~  
626 ~~of the water line showing all existing and proposed streets, adjacent structures, physical features,~~  
627 ~~and existing locations of utilities. The location and size of all water lines, valves, access~~  
628 ~~manholes, air vacuum release stations, thrust blocking, and other appurtenances shall be~~  
629 ~~indicated. Pertinent elevations shall be indicated on all appurtenances.~~

630  
631 ~~(moved to Section 8(c)(ii))(ii) Profiles of all water lines shall be shown on the~~  
632 ~~same sheet as the plan view at legible horizontal and vertical scales, with a profile of existing and~~  
633 ~~finished surfaces, pipe size and material, valve size, material and type. The location of all special~~  
634 ~~features such as access manholes, concrete encasements, casing pipes, blowoff valves, and~~  
635 ~~airvacuum relief valves, etc., shall be shown.~~

636

637 ~~(moved to Section 8(e)(iii))(iii) — Special detail drawings scaled and~~  
638 ~~dimensioned to show the following:~~

639  
640 ~~(moved to Section 8(e)(iii)(A))(A) — The bottom of the stream, the~~  
641 ~~elevation of the high and low water levels, and other topographical features at all locations~~  
642 ~~where the water line is near or crosses streams or lakes.~~

643  
644 ~~(moved to Section 8(e)(iii)(B))(B) — Cross-section drawing of the pipe~~  
645 ~~bedding.~~

646  
647 ~~(moved to Section 8(e)(iii)(C))(C) — Additional features not otherwise~~  
648 ~~covered by specifications.~~

649  
650 ~~(moved to Section 8(e)(iv)(iv) — Location of any sewer lines within 30 feet (9~~  
651 ~~m) horizontally. Sewers that cross water lines shall be shown on the profile drawings.~~

652  
653 ~~(moved to Section 8(d))(d) — Storage tanks, pumping stations and treatment facilities.~~  
654 ~~Plans shall be submitted showing the relation of the proposed project to the remainder of the~~  
655 ~~system. Layouts and detail plans shall show the following:~~

656  
657 ~~(moved to Section 8(d)(i))(i) — Site location and layout including topographic and~~  
658 ~~physical features, proposed arrangement of pumping or treatment units, existing facilities,~~  
659 ~~existing and proposed piping and valving arrangements, access drive, power supply, fencing,~~  
660 ~~embankments, clearwells, waste and sludge ponds, etc.~~

661  
662 ~~(moved to Section 8(d)(ii))(ii) — Schematic flow diagram(s) and hydraulic~~  
663 ~~profile(s) for facility treated water, and flow diagram for sludge and wastewater flows.~~

664  
665 ~~(moved to Section 8(d)(iv))(iii) — Plan(s) and section view(s) of each~~  
666 ~~treatment facility process unit with specific construction details, features and pertinent~~  
667 ~~elevations. Details of each unit should include, but are not limited to: inlet and outlet devices,~~  
668 ~~baffles, valves, arrangement of automatic control devices, mixers, motors, chemical feeders,~~  
669 ~~sludge scrapers, sludge disposal, or other mechanical devices.~~

670  
671 ~~(moved to Section 8(e))(e) — Wells. Plan and profile drawings of well construction shall~~  
672 ~~be submitted showing diameter and depth of drill holes, casing and liner diameters and depths,~~  
673 ~~grouting depths, elevation and designation of geological formations, water levels, and other~~  
674 ~~details to describe the proposed well completely.~~

675  
676 ~~(moved to Section 8(f))(f) — Specifications. Technical specifications shall accompany~~  
677 ~~the plans for new water lines, pump stations, treatment facilities, wells, or~~  
678 ~~additions/modifications to existing systems or facilities. Where plans are for extensions to water~~  
679 ~~distribution systems, the specifications may be omitted, provided it is stated that the work is to be~~  
680 ~~constructed under specifications authorized by the Water Quality Division. Specifications on file~~  
681 ~~must conform to this standard. The specifications accompanying construction drawings shall~~  
682 ~~include:~~

- 683  
684 ~~(moved to Section 8(f)(i))(i) Identification of construction materials.~~  
685  
686 ~~(moved to Section 8(f)(iii))(ii) The type, size, strength, operating~~  
687 ~~characteristics, rating or requirements for all mechanical and electrical equipment, including~~  
688 ~~machinery, valves, piping, electrical apparatus, wiring and meters; laboratory fixtures and~~  
689 ~~equipment; operating tools; special appurtenances; and chemicals, when applicable.~~  
690  
691 ~~(moved to Section 8(f)(iv))(iii) Construction and installation procedure for~~  
692 ~~materials and equipment.~~  
693  
694 ~~(moved to Section 8(f)(v))(iv) Requirements and tests of materials and~~  
695 ~~equipment to meet design standards.~~  
696  
697 ~~(moved to Section 8(f)(vi))(v) Performance tests for operation of~~  
698 ~~completed works and component units.~~  
699  
700 ~~(moved to Section 8(f)(vii))(vi) Specialized requirements for tests, analyses,~~  
701 ~~disinfection techniques, and other special needs.~~  
702  
703 ~~(vii) Requirements for well construction and testing. The collection of the~~  
704 ~~following must be recorded and reported to the Wyoming Department of Environmental Quality,~~  
705 ~~Water Quality Division.~~  
706  
707 ~~(A) Geological data.~~  
708  
709 ~~(B) Well construction data. Well construction data shall include screen~~  
710 ~~locations, size of screen openings, screen intervals, accurate records of drill hole diameters and~~  
711 ~~depths, assembled order, size and length of casing and liners, casing wall thickness, grouting~~  
712 ~~depths, formations penetrated, water levels, and location of any blast charges.~~  
713  
714 ~~(C) Well test data. Well test data shall include test pump capacity-~~  
715 ~~head characteristics; static water level; depth of test pump setting; time of starting and ending~~  
716 ~~each test cycle; pumping rate; pumping water level; drawdown; and water recovery rate and~~  
717 ~~levels.~~  
718  
719 ~~(moved to Section 8(f)(viii))(g) Technical specifications shall require that all water~~  
720 ~~service connections will be provided with backflow prevention devices in accordance with the~~  
721 ~~requirements of Section 14 (i) of these regulations.~~  
722  
723 (a) Applications for a permit to construct, install, modify, or operate a public water  
724 supply shall comply with the requirements of Water Quality Rules Chapter 3, Section 6.  
725  
726 (b) The application shall include the following components:  
727

- 728                    (i) An engineering design report that meets the requirements of Section 9 of  
729 this Chapter;  
730
- 731                    (ii) A construction plan that meets the applicable requirements of Sections 8,  
732 10, 11, 12, 13, 14, 15, 16, and 17 of this Chapter;  
733
- 734                    (iii) An operation and maintenance plan that meets the requirements of Section  
735 18 of this Chapter; and  
736
- 737                    (iv) Any additional information required by the Administrator.  
738
- 739                    (c) The application and components required by this Chapter shall be submitted to the  
740 Division in a format required by the Administrator.  
741
- 742                    (d) The application shall include certification under penalty of perjury that the  
743 applicant has secured and will maintain permission for Department personnel and their invitees  
744 to access the facility, including permission to:  
745
- 746                    (i) Access the land where the facility is located;  
747
- 748                    (ii) Collect resource data as defined by W.S. § 6-3-414(e)(iv); and  
749
- 750                    (iii) Enter and cross all properties necessary to access the facility if the facility  
751 cannot be directly accessed from a public road.  
752
- 753                    (e) Sections of permit applications that represent engineering work shall be sealed,  
754 signed, and dated by a licensed professional engineer as required by W.S. § 33-29-601.  
755
- 756                    (f) Sections of permit applications that represent geologic work shall be sealed,  
757 signed, and dated by a licensed professional geologist as required by W.S. § 33-41-115.  
758
- 759                    (g) The Administrator may allow an alternative two-step permitting and application  
760 procedure for wells and water storage tank project applicants that meet the following  
761 requirements:  
762
- 763                    (ii) For applications that include wells, the Department will issue one permit  
764 with the following phased authorizations:  
765
- 766                    (A) The issued permit will authorize the well to be constructed,  
767 developed, and tested;  
768
- 769                    (B) Applicants shall then submit well test data and water quality data  
770 for Administrator review; and  
771

772 (C) Upon the Administrator’s approval of the well test data and water  
773 quality data, the Director shall modify the issued permit to authorize connection of the  
774 distribution system to the well.

775  
776 (iii) Applicants for water storage tanks may follow an alternative procedure  
777 when the final plans and specifications for the tank cannot be submitted with the initial permit  
778 application due to project bidding constraints. In these instances, the Department will issue a  
779 permit through the following phased authorizations:

780  
781 (A) The issued permit will authorize the project to initiate the bidding  
782 process. Applicants shall ensure the project bidding documentation includes a requirement that  
783 the final water storage tank design complies with the requirements of this Chapter.

784  
785 (B) Applicants shall then submit final documentation and  
786 specifications for the water storage tank that demonstrate the design is consistent with the  
787 requirements of this Chapter. Upon the Administrator’s approval of the final tank documentation  
788 specifications, the Director shall modify the issued permit to authorize the construction of the  
789 water storage tank and foundation.

790  
791 (iv) Applicants that use phased authorization procedures in this paragraph (g)  
792 shall request a pre-application meeting with the applicable Division district engineer prior to  
793 submission of the permit application package to ensure efficient coordination of the submittals of  
794 all reports, plans, and specifications, and Division review timelines.

795 **Section 8. ~~General Design Considerations~~ Plans and Specifications.**

796  
797  
798 ~~(moved to Section 10(b))(a)—Design basis. The capacity of the water treatment or water~~  
799 ~~production system shall be designed for the maximum daily demand at the design year. Where~~  
800 ~~water use records are not available to establish water use, the equivalent per capita water use~~  
801 ~~shall be at least 125 gpd (475 liters per day) and 340 gpd (1,285 liters per day) to size facilities~~  
802 ~~for average and maximum daily water demand, respectively.~~

803  
804 ~~(b)—Siting requirements.~~

805  
806 ~~(moved to Section 10(d)(ii))(i)—Location. Treatment facilities shall be~~  
807 ~~located such that no sources of pollution may affect the quality of the water supply or treatment~~  
808 ~~system. The facilities shall not be located within 500 feet of landfills, garbage dumps, or~~  
809 ~~wastewater treatment systems.~~

810  
811 ~~(moved to Section 10(d)(iii))(ii)—Flood protection. All treatment process~~  
812 ~~structures, mechanical equipment, and electrical equipment shall be protected from the~~  
813 ~~maximum flood of record or the 100-year flood, whichever is greater. The treatment facilities~~  
814 ~~shall remain fully operational and accessible during the 100-year flood.~~

815

816 ~~(moved to Section 10(e))(c)—Level of treatment. Treatment shall be provided to~~  
817 ~~produce a potable water that is bacteriologically, chemically, radiologically, and physically safe~~  
818 ~~as determined by the administrator.~~

819 ~~(i)—Surface supplies. Treatment shall include:~~

820 ~~(A)—Chemical addition/coagulation, flocculation, sedimentation,~~  
821 ~~filtration and disinfection; or~~

822 ~~(B)—Where the raw water maximum turbidity is less than 50 TU and is~~  
823 ~~not attributable to clay and maximum color is less than 30 TU, treatment facilities may include~~  
824 ~~slow sand filtration and disinfection; or~~

825 ~~(C)—Where the maximum monthly average raw water turbidity is less~~  
826 ~~than 25 TU, the color is less than 30 TU and fecal coliform organisms are less than 100 mpn/100~~  
827 ~~ml, treatment facilities may be diatomaceous earth filters and disinfection.~~

828 ~~(ii)—Groundwater supplies. Groundwater supply facilities shall provide~~  
829 ~~disinfection equipment and connections, as a minimum.~~

830 ~~(d)—Hydraulic and treatment reliability.~~

831 ~~(moved to Section 10(f))(i)—Multiple units. Treatment facilities with 100,000~~  
832 ~~gallons per day (gpd) (378.5 m<sup>3</sup>/day) capacity and over shall provide duplicate units, as a~~  
833 ~~minimum, for chemical feed, flocculation, sedimentation, filtration and disinfection. (moved to~~  
834 ~~Section 10(g))Treatment facilities under 100,000 gpd (378.5 m<sup>3</sup>/day) capacity shall provide~~  
835 ~~duplicate units as described above or may provide finished water system storage equal to twice~~  
836 ~~the maximum daily demand.~~

837 ~~(moved to Section 10(h))(ii)—Multiple equipment. All treatment facility pumping~~  
838 ~~shall provide the maximum daily flow with the largest single unit not in service. Finished water~~  
839 ~~pumping in combination with finished water storage that floats on the distribution systems shall~~  
840 ~~provide the maximum hour flow with the single largest unit not in service. When fire protection~~  
841 ~~is provided, pumping and finished water storage that floats on the system shall provide the fire~~  
842 ~~demand plus the maximum daily demand, or the maximum hour demand, whichever is greater.~~

843 ~~(moved to Section 10(i))(iii)—Alternative power source. Where the finished water~~  
844 ~~storage volume that floats on the distribution system is not capable of supplying the maximum~~  
845 ~~daily demand, an alternative power shall be provided for the finished water pumps. The~~  
846 ~~combined finished water storage volume and pumping capacity supplied by alternative power~~  
847 ~~shall be at least adequate to provide the maximum daily demand. Acceptable alternative power~~  
848 ~~sources include an engine generator, engine drive pumps, or a second independent electrical~~  
849 ~~supply.~~

860 ~~(moved to Section 10(j))(e) — Housing. Process equipment, including filters and~~  
861 ~~appurtenances, disinfection, chemical feed and storage, electrical and controls, and pipe galleries~~  
862 ~~shall be housed.~~

863  
864 ~~(f) — Electrical.~~

865  
866 ~~(moved to Section 10(s))(i) — Equipment location. Service transformers and other~~  
867 ~~critical electrical equipment shall be located above the 100-year flood and above grade.~~  
868 ~~Transformers shall be located so that they are remote or protected by substantial barriers from~~  
869 ~~traffic. Motor controls shall be located in superstructures and in rooms that do not contain~~  
870 ~~corrosive atmospheres.~~

871  
872 ~~(ii) — Code requirements. Electrical design shall comply with the National~~  
873 ~~Electrical Code as enacted and amended by the Wyoming Department of Fire Prevention and~~  
874 ~~Electrical Safety. Areas in which the occurrence of explosive concentrations of hazardous~~  
875 ~~gases, flammable fluids, or explosive dusts can occur shall be designed for hazardous locations~~  
876 ~~in accordance with the National Electrical Code Class 1, Groups C and D, Division 1 locations.~~

877  
878 ~~(g) — Structural.~~

879  
880 ~~(moved to Section 8(n))(i) — Construction materials. Construction materials~~  
881 ~~shall be selected, apportioned, and/or protected to provide water tightness, corrosion protection,~~  
882 ~~and resistance to weather variations.~~

883  
884 ~~(moved to Section 8(o))(ii) — Coatings. Coatings used to protect structures,~~  
885 ~~equipment, and piping shall be suitable for atmospheres containing moisture and low~~  
886 ~~concentrations of chlorine. Surfaces exposed in chemical areas shall be protected from chemical~~  
887 ~~attack. Paints shall not contain lead, mercury, or other toxic metals or chemicals.~~

888  
889 ~~(moved to Section 8(e))(iii) — Geological conditions. Structural design shall~~  
890 ~~consider the seismic zone, groundwater, and soil support. Soils investigations shall be made, or~~  
891 ~~adequate previous soils investigations shall be available to develop structural design.~~

892  
893 ~~(h) — Safety. The Wyoming Occupational Health and Safety (OHS) Rules and~~  
894 ~~Regulations shall be complied with. The following items shall also be provided:~~

895  
896 ~~(i) — Instruction manuals. Instruction manuals shall be provided for all~~  
897 ~~mechanical and electrical equipment describing operation, maintenance, and safety.~~

898  
899 ~~(ii) — Handrails. In addition to all Wyoming OHS requirements, barriers~~  
900 ~~around treatment basins shall be provided.~~

901  
902 ~~(iii) — Warning signs. Warning signs for pipes or hose bibs containing~~  
903 ~~nontreated water, electrical hazards, mechanical hazards, chemical hazards, or other unsafe~~  
904 ~~features shall be provided. Warning signs shall be permanently attached to the structure or~~  
905 ~~appropriate equipment.~~



906  
907 ~~(iv) — Equipment guards. Shields to protect operators from rotating or moving~~  
908 ~~machinery shall be provided.~~

909  
910 ~~(v) — Lighting. Provisions shall be made to light walkways, paths, and other~~  
911 ~~accessways around basins, in buildings and on the site. All areas shall be lit in a manner that the~~  
912 ~~failure of one lighting fixture will not cause an area to be dark, or the loss of power will not~~  
913 ~~cause a room or enclosed area to be dark.~~

914  
915 ~~(vi) — Climate conditions. Design of facilities such as exposed stairs, walkways,~~  
916 ~~and sidewalks shall include nonskid surfaces.~~

917  
918 ~~(i) — Instrumentation.~~

919  
920 ~~(moved to Section 10(t))(i) — Metering. The treatment facility shall have a flow~~  
921 ~~measuring device provided for raw water influent and clear well effluent. The accuracy of the~~  
922 ~~device shall be at least plus or minus two percent of span.~~

923  
924 ~~(moved to Section 10(t)(ii))(ii) — Type. All flow meters shall provide~~  
925 ~~totalized flow. For plants with a maximum daily flow of 50,000 gpd (189 m<sup>3</sup>/d) or more, the~~  
926 ~~meter shall also include recording of instantaneous flow rate.~~

927  
928 ~~(moved to Section 10(t)(i))(iii) — Controls. Automatic controls shall be~~  
929 ~~designed to permit manual override.~~

930  
931 ~~(moved to Section 13(c))(iv) — Alarms. High effluent turbidity and chlorine leaks~~  
932 ~~(when chlorine gas is used) shall be alarmed at an attended location.~~

933  
934 ~~(j) — Sample taps. Sample taps shall be provided so that water samples can be obtained~~  
935 ~~from each water source and from appropriate locations in each unit operation of treatment. Taps~~  
936 ~~shall be consistent with sampling needs and shall not be of the petcock type. Taps used for~~  
937 ~~obtaining samples for bacteriological analysis shall be of the smooth-nosed type without interior~~  
938 ~~or exterior threads, shall not be of the mixing type, and shall not have a screen, aerator, or other~~  
939 ~~such appurtenance.~~

940  
941 ~~(moved to Section 10(r))(k) — Ventilation. All enclosed spaces shall be provided with~~  
942 ~~forced ventilation, except pumping station wetwells or clearwells. In areas where there are open~~  
943 ~~treatment units exposed to the room, ventilation shall be provided to limit relative humidity to~~  
944 ~~less than 85 percent but not less than 6 air changes per hour. In electrical and equipment rooms,~~  
945 ~~ventilation shall be provided to limit the temperature rise in the room to less than 15° F (8° C)~~  
946 ~~above ambient, but not less than 6 air changes per hour. Rooms housing chlorine storage and/or~~  
947 ~~feeders shall have provisions for exhausting the room contents in 2 minutes and continuous~~  
948 ~~ventilation to provide not less than~~  
949 ~~12 air changes per hour.~~

950

951 ~~(l) — Dewatering of treatment units. All treatment units, channels, basins, clearwells~~  
952 ~~and wetwells shall be provided with drains or sumps that facilitate draining the unit for access~~  
953 ~~and maintenance. Drainage shall be to the process waste system, filter washwater system or~~  
954 ~~sanitary sewer. (moved to Section 10(l)) Basin slabs shall be designed to successfully resist the~~  
955 ~~hydrostatic uplift pressure or an area dewatering system shall be provided. Considerations must~~  
956 ~~be given in structural design to long span breakage in basins designed to resist uplift.~~

957  
958 ~~(moved to Section 10(k))(m) Cold weather protection. All equipment not required to be~~  
959 ~~in or on open basins (such as clarifier drives and flocculator) shall be housed in heated, lighted,~~  
960 ~~and ventilated structures. (moved to Section 10(m)) Structure entrances shall be above grade.~~  
961 ~~(moved to Section 10(l)) Piping shall be buried below frost level, placed in heated structures, or~~  
962 ~~provided with heat and insulated.~~

963  
964 ~~(n) — Chemical storage. All chemical storage shall be housed or buried. Areas~~  
965 ~~designated for storage of specific chemicals shall be separated from areas designated for other~~  
966 ~~reactive chemicals. Liquid storage containers shall be isolated from other portions of the~~  
967 ~~structure by a curb that will contain ruptured tank contents. Concrete floors, walls, and curbs in~~  
968 ~~chemical storage and feed areas shall be coated to protect the concrete from aggressive~~  
969 ~~chemicals. Floors in polymer feed and storage areas shall be provided with nonslip surfaces.~~  
970 ~~Rooms for chlorine storage and feed equipment shall be gastight and be provided with entry~~  
971 ~~from outdoors. All toxic chemical storage areas shall be provided with lighting and ventilation~~  
972 ~~switched from outside the room near the door. All toxic chemical storage areas shall be provided~~  
973 ~~with windows either in the door or near the door to permit viewing the room from outside.~~  
974 ~~Explosive chemicals shall be stored to protect operations personnel and equipment from injury or~~  
975 ~~damage.~~

976  
977 ~~(o) — Facility water supply. The facility water supply service line and the plant finished~~  
978 ~~water sample tap shall be supplied from a source of finished water at a point where all chemicals~~  
979 ~~have been thoroughly mixed, and the required disinfectant contact time has been achieved.~~  
980 ~~There shall be no cross connections between the facility water supply service line and any~~  
981 ~~piping, troughs, tanks, or other treatment units containing wastewater, treatment chemicals, raw~~  
982 ~~or partially treated water. The potable plant water supply line shall have provisions to prevent~~  
983 ~~backflow.~~

984  
985 ~~(moved to Section 10(b)(ii))(p) — Design capacities. The plant capacity shall include~~  
986 ~~maximum daily water demand, filter backwash quantities, and industrial water use. In the~~  
987 ~~absence of data, filter backwash quantity shall be five percent of the maximum daily demand.~~

988  
989 ~~(moved to Section 10(v))(q) — Monitoring equipment. Water treatment plants having a~~  
990 ~~capacity of 0.5 mgd (1892.6 m<sup>3</sup>/d) or more shall be provided with continuous finished water~~  
991 ~~turbidimeters (including recorders).~~

992  
993 ~~(r) — Labels. All process piping shall be labeled to identify materials being conveyed.~~  
994

995 (a) 2018 TSS, part 1.2-1.2.2(r), plans; 1.3-1.3(e), specifications; 1.4-1.4(m), design  
996 criteria; 1.5, revisions to approved plans; and 1.6, additional information required; are herein  
997 incorporated by reference.

998  
999 ~~(formerly Section 7(a))(b)~~ All plans for waterworks and treatment facilities shall ~~have~~  
1000 ~~a suitable title showing the following also include~~ the name of the real estate owner, ~~(formerly~~  
1001 ~~Section 7(a)(i)) Name of the~~ owner of the project, and the location of the project.

1002  
1003 ~~(formerly Section 7(e))(c) Water lines.~~ Plans for transmission and distribution lines  
1004 shall include:

1005  
1006 (i) The information required in paragraph (a) of this Section;

1007  
1008 ~~(formerly Section 7(e)(i))(ii)~~ A detailed plan view at a legible scale of each reach  
1009 of the water line showing all existing and proposed streets, adjacent structures, physical features,  
1010 and existing locations of utilities. ~~The location and size of all water lines, valves, access~~  
1011 ~~manholes, air vacuum release stations, thrust blocking, and other appurtenances shall be~~  
1012 ~~indicated. Pertinent elevations shall be indicated on all appurtenances. that indicates:~~

1013  
1014 ~~(formerly Section 7(e)(i))(A)~~ The location and size of all water lines,  
1015 valves, access manholes, air-vacuum release stations, thrust blocking, and other appurtenances  
1016 ~~shall be indicated.; and~~

1017  
1018 ~~(formerly Section 7(e)(i))(B)~~ Pertinent elevations ~~shall be indicated on all~~  
1019 ~~appurtenances.~~

1020  
1021 ~~(formerly Section 7(e)(i))(ii)~~ Profiles of all water lines ~~shall be that are~~ shown on  
1022 the same sheet as the plan view at legible horizontal and vertical scales; and that show ~~with a~~  
1023 ~~profile of existing and finished surfaces, pipe size and material, valve size, material and type.~~  
1024 ~~The location of all special features such as access manholes, concrete encasements, casing pipes,~~  
1025 ~~blowoff valves, and air vacuum relief valves, etc., shall be shown.;~~

1026  
1027 ~~(formerly Section 7(e)(i))(A)~~ pProfiles of:

1028  
1029 ~~(formerly Section 7(e)(i))(I)~~ eExisting and finished surfaces.;

1030  
1031 ~~(formerly Section 7(e)(i))(II)~~ pPipe size and material.;

1032  
1033 ~~(formerly Section 7(e)(i))(III)~~ vValve size, material and  
1034 type.

1035  
1036 ~~(formerly Section 7(e)(i))(B)~~ The location of all special features such as  
1037 access manholes, concrete encasements, casing pipes, blowoff valves, and air vacuum relief  
1038 valves, ~~etc., shall be shown.~~

1040 ~~(formerly Section 7(e)(iii))~~(iv) Special detail drawings scaled and  
1041 dimensioned to show the following:

1042  
1043 ~~(formerly Section 7(e)(iii)(A))~~(A) The bottom of the stream, the  
1044 elevation of the high- and low water levels, and other topographical features ~~at all locations~~  
1045 ~~where the water line is near or crosses streams or lakes,~~ at points where the water line:

1046  
1047 (I) Is located within 10 feet of streams or lakes; or

1048  
1049 (II) Crosses streams or lakes.

1050  
1051 ~~(formerly Section 7(e)(iii)(B))~~(B) A ~~C~~cross-section drawing of the pipe  
1052 bedding; and

1053  
1054 ~~(formerly Section 7(e)(iii)(C))~~(C) Additional features of the pipe or its  
1055 installation that are not otherwise covered by specifications.

1056  
1057 ~~(formerly Section 7(e)(iv))~~(iv) The ~~L~~location of any sewer lines within 30  
1058 feet ~~(9-m)~~ horizontally of water lines. Sewers that cross water lines shall be shown on the profile  
1059 drawings.

1060  
1061 ~~(formerly Section 7(d))~~(d) Plans for ~~S~~storage tanks, pumping stations, and water  
1062 treatment facilities. ~~Plans shall be submitted showing the relation of the proposed project to the~~  
1063 remainder of the system. Layouts and detail plans shall ~~show the following~~ include:

1064  
1065 (i) The information required in paragraph (a) of this Section;

1066  
1067 (ii) The seal and signature of the Wyoming Professional Engineer providing  
1068 the design;

1069  
1070 ~~(formerly Section 7(d)(i))~~(iii) The ~~S~~site location and layout including: ~~topographic~~  
1071 ~~and physical features, proposed arrangement of pumping or treatment units, existing facilities,~~  
1072 ~~existing and proposed piping and valving arrangements, access drive, power supply, fencing,~~  
1073 ~~embankments, clearwells, waste and sludge ponds, etc.~~

1074  
1075 ~~(formerly Section 7(d)(i))~~(A) ~~t~~Topographic and physical features,  
1076 including embankments;

1077  
1078 ~~(formerly Section 7(d)(i))~~(B) The proposed arrangement of pumping or  
1079 treatment units; ;

1080  
1081 ~~(formerly Section 7(d)(i))~~(C) ~~e~~Existing facilities; ;

1082  
1083 ~~(formerly Section 7(d)(i))~~(D) ~~e~~Existing and proposed piping and valving  
1084 arrangements; ;

1085

1086 ~~(formerly Section 7(d)(i))(E) access drive,~~ The route to access the facility;

1087  
1088 ~~(formerly Section 7(d)(i))(F) The power supply;~~

1089  
1090 ~~(formerly Section 7(d)(i))(G) Fencing;~~ and

1091  
1092 ~~(formerly Section 7(d)(i))(H) The proposed location of embankments,~~  
1093 clearwells, waste ponds, and sludge ponds, ~~etc.~~

1094  
1095 ~~(formerly Section 7(d)(ii))(iv) Schematic flow diagram(s) and hydraulic profile(s)~~  
1096 ~~for facility treated water, and flow diagram for sludge and wastewater flows;~~

1097  
1098 ~~(formerly Section 7(d)(ii))(v) A flow diagram for sludge and wastewater flows;~~  
1099 and

1100  
1101 ~~(formerly Section 7(d)(iii))(vi)~~ Plan(s) and section view(s) of each  
1102 treatment facility process unit with specific construction details, features, and pertinent  
1103 elevations. ~~Details of each unit should include, including~~ but are not limited to the following:  
1104 ~~inlet and outlet devices, baffles, valves, arrangement of automatic control devices, mixers,~~  
1105 ~~motors, chemical feeders, sludge scrapers, sludge disposal, or other mechanical devices.~~

1106  
1107 ~~(formerly Section 7(d)(iii))(A)~~ i Inlet and outlet devices;

1108  
1109 ~~(formerly Section 7(d)(iii))(B)~~ b Baffles;

1110  
1111 ~~(formerly Section 7(d)(iii))(C)~~ v Valves;

1112  
1113 ~~(formerly Section 7(d)(iii))(D)~~ a Arrangement of automatic control  
1114 devices;

1115  
1116 ~~(formerly Section 7(d)(iii))(E)~~ m Mixers;

1117  
1118 ~~(formerly Section 7(d)(iii))(F)~~ m Motors;

1119  
1120 ~~(formerly Section 7(d)(iii))(G)~~ e Chemical feeders;

1121  
1122 ~~(formerly Section 7(d)(iii))(H)~~ s Sludge scrapers;

1123  
1124 ~~(formerly Section 7(d)(iii))(I)~~ s Sludge disposal; or

1125  
1126 ~~(formerly Section 7(d)(iii))(J)~~ o Other mechanical devices.

1127  
1128 ~~(formerly Section 7(e))(e)~~ Wells. Plans and profile drawings of for well construction  
1129 shall be submitted include: showing diameter and depth of drill holes, casing and liner diameters  
1130 and depths, grouting depths, elevation and designation of geological formations, water levels,  
1131 and other details to describe the proposed well completely.

- 1132
- 1133 (i) The information required in paragraph (a) of this Section;
- 1134
- 1135 (ii) Assembled order, size, and length of casing and liners;
- 1136
- 1137 ~~(formerly Section 9(b)(ii)(B))(iii) Plumbness and alignment requirements.~~
- 1138 ~~Every well shall be tested for plumbness and alignment in accordance with AWWA A-100. The~~
- 1139 ~~well test method and allowable tolerance shall be stated in the specifications.;~~
- 1140
- 1141 ~~(formerly Section 9(b)(iii)(B)(V)(1.))(iv) The l~~Locations of all caisson
- 1142 construction joints and porthole assemblies ~~shall be indicated~~ on drawings, if a radial water
- 1143 collector is proposed.; ~~The caisson wall shall be reinforced to withstand the forces to which it~~
- 1144 ~~will be subjected. The top of the caisson shall be covered with a watertight floor. The pump~~
- 1145 ~~discharge piping shall not be placed through the caisson walls.~~
- 1146
- 1147 ~~(formerly Section 7(e))(v) From the ground surface to the total depth of the~~
- 1148 drilled borehole, the elevation and designation of geological formations, water levels, formations
- 1149 penetrated, and other details to describe the proposed well completely.;
- 1150
- 1151 ~~(formerly Section 7(f)(vii)(B))(vi) Well construction data. Well construction~~
- 1152 ~~data shall include s~~Screen locations, size of screen openings, and screen intervals.;
- 1153 ~~accurate records of drill hole diameters and depths, assembled order, size and length of casing and liners,~~
- 1154 ~~casing wall thickness, grouting depths, formations penetrated, water levels, and location of any~~
- 1155 ~~blast charges~~
- 1156
- 1157 ~~(formerly Section 7(f)(vii)(B))(vii) The location of any blast charges., if~~
- 1158 available; and
- 1159
- 1160 ~~(formerly Section 7(f)(vii)(e))(viii) (C) — Well test data. Existing W~~well test
- 1161 ~~data shall include including: test pump capacity head characteristics; static water level; depth of~~
- 1162 ~~test pump setting; time of starting and ending each test cycle; pumping rate; pumping water~~
- 1163 ~~level; drawdown; and water recovery rate and levels.~~
- 1164
- 1165 ~~(formerly Section 7(f)(vii)(C)(A) T~~test pump capacity-head
- 1166 characteristics;
- 1167
- 1168 ~~(formerly Section 7(f)(vii)(C)(B) s~~Static water level;
- 1169
- 1170 ~~(formerly Section 7(f)(vii)(C)(C) d~~Depth of test pump setting;
- 1171
- 1172 ~~(formerly Section 7(f)(vii)(C)(D) †~~Time of starting and ending each
- 1173 test cycle;
- 1174
- 1175 ~~(formerly Section 7(f)(vii)(C)(E) p~~Pumping rate;
- 1176
- 1177 ~~(formerly Section 7(f)(vii)(C)(F) p~~Pumping water level;

1178  
1179 ~~(formerly Section 7(f)(vii)(C)(G))~~ dDrawdown; and  
1180  
1181 ~~(formerly Section 7(f)(vii)(C)(H))~~ wWater recovery rate and levels.  
1182  
1183 ~~(formerly Section 7(f))~~(f) Specifications. Technical specifications shall accompany  
1184 the pPlans for ~~new~~ water lines, pump stations, treatment facilities, wells, storage, or  
1185 additions/modifications to existing systems or facilities. ~~Where plans are for extensions to water~~  
1186 ~~distribution systems, the specifications may be omitted, provided it is stated that the work is to be~~  
1187 ~~constructed under specifications authorized by the Water Quality Division. Specifications on file~~  
1188 ~~must conform to this standard. The specifications accompanying construction drawings shall~~  
1189 shall be accompanied by technical specifications that include:  
1190  
1191 (i) The information required in paragraph (a) of this Section;  
1192  
1193 ~~(formerly Section 7(f)(i))~~(ii) Identification of construction materials. ~~;~~  
1194  
1195 ~~(formerly Section 7(f)(ii))~~(iii) When applicable, Tthe type, size, strength,  
1196 operating characteristics, rating or requirements for all mechanical and electrical equipment,  
1197 including machinery, valves, piping, electrical apparatus, wiring, and meters; laboratory fixtures  
1198 and equipment; operating tools; special appurtenances; and chemicals, ~~when applicable.;~~  
1199  
1200 ~~(formerly Section 7(f)(iii))~~(iv) Construction and installation procedure for  
1201 materials and equipment. ~~;~~  
1202  
1203 ~~(formerly Section 7(f)(iv))~~(v) Requirements and tests of materials and equipment  
1204 to meet design standards. ~~;~~  
1205  
1206 ~~(formerly Section 7(f)(v))~~(vi) Performance tests for the operation of completed  
1207 works and component units. ~~;~~  
1208  
1209 ~~(formerly Section 7(f)(vi))~~(vii) Specialized requirements for tests, analyses,  
1210 disinfection techniques, and other special needs. ~~;~~  
1211  
1212 ~~(formerly Section 7(g))~~(viii) Technical specifications shall require A  
1213 demonstration that all water service connections will be provided with backflow prevention  
1214 devices in accordance with the requirements of Section ~~14 (i)~~ 16 (m) of ~~these regulations~~ this  
1215 Chapter; and  
1216  
1217 (ix) If technical specifications have been independently permitted by the  
1218 Department for statewide use, the title, date, and permit approval identification number in lieu of  
1219 providing technical specifications.  
1220

1221 **Section 9 Engineering Design Report.**

1222  
1223 ~~(a) — Surface water.~~

1224  
1225  
1226  
1227  
1228  
1229  
1230  
1231  
1232  
1233  
1234  
1235  
1236  
1237  
1238  
1239  
1240  
1241  
1242  
1243  
1244  
1245  
1246  
1247  
1248  
1249  
1250  
1251  
1252  
1253  
1254  
1255  
1256  
1257  
1258  
1259  
1260  
1261  
1262  
1263  
1264  
1265  
1266  
1267  
1268  
1269

~~(i) Structures.~~

~~(A) Design of reservoir or river intake structures.~~

~~(I) Facilities for withdrawal of water from more than one level shall be provided in impoundments if the maximum water depth at the intake is greater than 20 feet (6.1 m). All ports or intake gates shall be located above the bottom of the stream, lake, or impoundment. The lowest intake point shall be located at sufficient depth to be kept submerged at low water levels.~~

~~(II) Where water temperatures are 34° F (1° C) or less, the velocity of flow into the intake structure shall not exceed 0.5 feet per second (.152 m/s). Where intakes are located in shady reaches of a stream, facilities shall be available to diffuse air into the flow stream at a point in front of the intake pipe.~~

~~(III) Inspection manholes shall be located a maximum of every 1,000 feet (304.8 m) for pipe sizes 24 inches (0.61 m) and larger. Where pipelines operate by gravity and the hydraulic gradeline is below the ground surface, concrete manholes may be used. Where the pipeline is pressurized or the hydraulic gradeline is above ground, bolted and gasketed access ways shall be used.~~

~~(IV) Devices shall be provided to minimize entry of fish and debris from the intake structure.~~

~~(B) Offstream reservoir. Offstream reservoirs shall be constructed to assure that:~~

~~(I) Water quality is protected by controlling runoff into the reservoir.~~

~~(II) Dikes are structurally sound and protected against wave action and erosion.~~

~~(ii) Impoundments and reservoirs. The site of any impoundment or reservoir shall be cleared of all brush, trees, and other vegetation to the high water elevation.~~

~~(moved to Section 11(d))(iii) Raw water supply piping. No customer service connection shall be provided from the raw water transmission line to the treatment plant, unless there are provisions to treat the water to meet these standards, or the sole purpose of the service is for irrigation or agricultural water use.~~

~~(moved to Section 11(e))(b) Groundwater.~~

~~(moved to Section 11(e)(i))(i) Number and capacity. The total developed groundwater source, along with other water sources, shall provide a combined capacity that shall~~



1270 equal or exceed the design maximum daily demand. A minimum of 2 wells, or 1 well and  
1271 finished water storage equal to twice the maximum daily demand shall be provided. Where 2  
1272 wells are provided, the sources shall be capable of equaling or exceeding the design average  
1273 daily demand with the largest producing well out of service.

1274  
1275 (A) — General considerations.

1276  
1277 (I) — Every well shall be protected from and remain operational  
1278 during the 100-year flood or the largest flood of record, whichever is greater.

1279  
1280 (II) — All wells shall be disinfected after construction, repair, or  
1281 when work is done on the pump, before the well is placed in service. Disinfection procedures  
1282 shall be those specified in AWWA A 100 for disinfection of wells.

1283  
1284 (moved to Section 11(e)(ii)(B))(B) — Relation to sources of pollution.  
1285 Every well shall be located further from any of the sources of pollution listed below. The  
1286 isolation distances listed below apply when domestic wastewater is the only wastewater present.

1287  
1288 (moved to Section 11(e)(ii)(A))(I) — If the domestic sewage flow  
1289 is less than 2,000 gallons per day (7,560 L/day), the following minimum isolation distance shall  
1290 be maintained:

1291  
1292 Moved to Section 11(e)(ii)(A)

<u>Source of Domestic Wastewater</u>	<u>Minimum Distance to Well</u>
Sewer	50 feet (15.2 m)
Septic tank	50 feet (15.2 m)
Disposal field	100 feet (30.5 m)
Seepage pit	100 feet (30.5 m)
Cesspool	100 feet (30.5 m)

1293  
1294 Moved to Section 11(e)(ii)(B))(II)

1295 (II) — If the domestic sewage flow is greater than 2,000 gpd (7,560 L/day) but less than 10,000  
1296 gpd (37,800 L/day), the following minimum isolation distances shall be maintained:

<u>Source of Domestic Wastewater</u>	<u>Minimum Distance to Well</u>
Sewer	50 feet (15.2 m)
Septic tank	50 feet (15.2 m)
Disposal field	200 feet (61 m)
Seepage pit	200 feet (61 m)
Cesspool	200 feet (61 m)

1298  
1299  
1300  
1301  
1302  
1303  
1304  
1305  
1306  
1307  
1308  
1309  
1310  
1311  
1312  
1313  
1314  
1315  
1316  
1317  
1318  
1319  
1320  
1321  
1322  
1323  
1324  
1325  
1326  
1327  
1328  
1329  
1330  
1331  
1332  
1333  
1334  
1335  
1336  
1337  
1338  
1339  
1340  
1341  
1342  
1343  
1344

~~Moved to Section 11(e)(ii)(C))(III)—For systems larger than 10,000 gallons per day (37,800 L/day), the isolation distance shall be determined by a hydrogeological study, in accordance with the requirements of Section 15 of Chapter 3 Water Quality Rules and Regulations, but shall not be less than those listed above.~~

~~(IV)—For wastewaters other than domestic wastewater, the isolation distance required shall be determined by a hydrogeological study, in accordance with the requirements of Section 15 of Chapter 3 Water Quality Rules and Regulations.~~

~~Moved to Section 11(e)(iii)(C)—Relation to buildings.~~

~~Moved to Section 11(e)(iii)(A))(I)—When a well is adjacent to the building, the well shall be located so that the centerline, extended vertically, will clear any projection from the building by not less than 3 feet (0.91 m), and will clear any power line by not less than 10 feet (3.05 m).~~

~~Moved to Section 11(e)(iii)(B))(II)—When a well is to be located inside a building, the top of the casing and any other well opening shall not terminate in the basement of the building, or in any pit or space that is below natural ground surface unless the well is completed with a properly protected submersible pump. Wells located in a structure must be accessible to pull the casing or the pump. The structure shall have overhead access.~~

~~Moved to Section 11(e)(iii)(C))(D)—Relation to property lines. Every well shall be located at least 10 feet (3.05 m) from any property line.~~

~~Moved to Section 11(e)(iv))(ii)—Testing and records.~~

~~Moved to Section 11(e)(iv)(A))(A)—Yield and drawdown tests. Yield and drawdown tests shall be performed on every production well after construction or subsequent treatment and prior to placement of the permanent pump. The test methods shall be clearly indicated in the specifications. The test pump capacity, at maximum anticipated drawdown, shall be at least 1.5 times the design rate anticipated. The test shall provide for continuous pumping for at least 24 hours or until stabilized drawdown has continued for at least 6 hours when test pumped at 1.5 times the design pumping rate.~~

~~(moved to Section 11(e)(iv)(B))(B)—Plumbness and alignment requirements. Every well shall be tested for plumbness and alignment in accordance with AWWA A-100. The test method and allowable tolerance shall be stated in the specifications.~~

~~(iii)—Well construction.~~

~~(moved to Section 11(e)(vi))(A)—Protection during construction. During any well construction or modification, the well and surrounding area must be adequately protected to prevent any groundwater contamination. Surface water must be diverted away from the construction area.~~

~~(moved to Section 11(e)(vii))(B) — Well types and construction~~

~~methods.~~

~~moved to Section 11(e)(vii)(A)(I) — Dug wells. Dug wells shall be used only where geological conditions preclude the possibility of developing an acceptable drilled well.~~

~~(1.) — Every dug well, other than the buried slab type, shall be constructed with a surface curbing of concrete, brick, tile or metal, extending from the aquifer to above the ground surface. Concrete grout, at least 6 inches (0.15 m) thick, shall be placed between the excavated hole and the curbing for a minimum depth of 10 feet (3.05 m) below original or final ground elevation, whichever is lower, or to the bottom of the hole, if it is less than 10 feet (3.05 m).~~

~~(2.) — The well lining in the producing zone shall readily admit water, and shall be structurally sound to withstand external pressures.~~

~~(3.) — The well cover or platform shall be reinforced concrete with a minimum thickness of 4 inches (10 cm). The top of the platform shall be sloped to drain to all sides. The platform shall rest on and overlap the well curbing by at least 2 inches (5 cm), or it may be cast with the curbing or the concrete grout. Adequately sized pipe sleeve(s) shall be cast in place in the platform to accommodate the type of pump, pump piping or wiring proposed for the well. Pump discharge piping shall not be placed through the well casing or wall.~~

~~(4.) — A buried slab type of construction may be used if the dug well is greater than 10 feet (3.05 m) deep. The well lining shall be terminated a minimum of 10 feet (3.05 m) below the original or final ground elevation, whichever is lower. A steel reinforced concrete slab or platform, at least 4 inches (10 cm) thick, shall rest on and overlap the lining. A standard unperforated well casing shall extend from the concrete slab to at least 12 inches (30 cm) above the original or final ground surface, whichever is higher. This casing shall be firmly imbedded in the slab or connected to a pipe cast in the slab to ensure that the connection is watertight. The excavation above the slab shall be backfilled with a bentonite slurry or clean earth thoroughly tamped to minimize settling.~~

~~(II) — Drilled, driven, jetted, or bored wells.~~

~~(1.) — A drilled well may be constructed through an existing dug well provided that an unperforated casing extends to at least 12 inches (30 cm) above the original ground or final surface, whichever is higher. A seal of concrete, at least 2 feet (0.61 m) thick, shall be placed in the bottom of the dug well to prevent the direct movement of water from the dug well into the drilled well. The original dug well shall be adequately protected from contamination as described above.~~

~~(moved to Section 11(e)(vii)(B))(2.) Every drilled, driven, jetted, or bored well shall have an unperforated casing that extends from a minimum of 12 inches~~

1391 ~~(30 cm) above ground surface to at least 10 feet (3.05 m) below ground surface. In~~  
1392 ~~unconsolidated formations, this casing shall extend to the water table or below. In consolidated~~  
1393 ~~formations, the casing may be terminated in rock or watertight clay above the water table.~~  
1394

1395 (III) ~~— Sand or gravel wells. If clay or hard pan is encountered~~  
1396 ~~above the waterbearing formation, the permanent casing and grout shall extend through such~~  
1397 ~~materials. If a sand or gravel aquifer is overlaid only by permeable soils, the permanent casing~~  
1398 ~~and grout shall extend to at least 20 feet (6.1 m) below original or final ground elevation,~~  
1399 ~~whichever is lower. If a temporary outer casing is used, it shall be completely withdrawn as~~  
1400 ~~grout is applied.~~  
1401

1402 (IV) ~~— Gravel pack wells. The diameter of an oversized drill hole~~  
1403 ~~designed for the placement of an artificial gravel pack shall allow a thickness of gravel or sand~~  
1404 ~~outside the casing sufficient to block the movement of natural materials into the well. The size~~  
1405 ~~of the openings in the casing or screen shall be based on the size of the gravel or sand used in the~~  
1406 ~~gravel pack.~~  
1407

1408 (1.) ~~— Gravel pack shall be well rounded particles, 95~~  
1409 ~~percent siliceous material, that are smooth and uniform, free of foreign material, properly sized,~~  
1410 ~~washed, and then disinfected immediately prior to or during placement. Gravel pack shall be~~  
1411 ~~placed in one uniformly continuous operation.~~  
1412

1413 (2.) ~~— After completion, the well shall be overpumped,~~  
1414 ~~surged, or otherwise developed to ensure free entry of water without sediment. A gravel packed~~  
1415 ~~well shall be sealed in one of two ways to prevent pollution to the groundwater supply:~~  
1416

1417 ~~(moved to Section 11(e)(vii)(C)(I))(2.) — If a permanent surface casing is not~~  
1418 ~~installed, the annular opening between the casing and the drill hole shall be sealed in the top 10~~  
1419 ~~feet (3.05 m) with concrete or cement grout.~~  
1420

1421 ~~(moved to Section 11(e)(vii)(C)(II))(2.) — If a permanent surface casing is installed, it~~  
1422 ~~shall extend to a depth of at least 10 feet (3.05 m). The annular opening between this outer~~  
1423 ~~casing and the inner casing shall be covered with a metal or cement seal.~~  
1424

1425 (3.) ~~— Gravel refill pipes, when used, shall be Schedule 40~~  
1426 ~~steel pipe incorporated within the pump foundation and terminated with screwed or welded caps~~  
1427 ~~at least 12 inches (30 cm) above the pump house floor or concrete apron. Gravel refill pipes~~  
1428 ~~located in the grouted annular opening shall be surrounded by a minimum of 1-1/2 inches (3.8~~  
1429 ~~cm) of grout. Protection from leakage of grout into the gravel pack or screen shall be provided.~~  
1430

1431 (V) ~~— Radial water collector.~~  
1432

1433 ~~(moved to Section 8(e)(iv))(1.) — Locations of all~~  
1434 ~~caisson construction joints and porthole assemblies shall be indicated on drawings. The caisson~~  
1435 ~~wall shall be reinforced to withstand the forces to which it will be subjected. The top of the~~

1436 caisson shall be covered with a watertight floor. The pump discharge piping shall not be placed  
1437 through the caisson walls.

1438  
1439 (2.)—Provisions shall be made to assure that radial  
1440 collectors are essentially horizontal.

1441  
1442 (3.)—All openings in the floor shall be curbed and  
1443 protected from entrance of foreign material.

1444  
1445 (VI)—Infiltration lines. Where an infiltration line is used, the  
1446 source shall be considered a surface source requiring treatment defined in Section 8(c) (i) unless,  
1447 (1) the water system owner is in complete control of the surrounding property for a distance of  
1448 500 feet around the periphery of the infiltration system; (2) the area is fenced to exclude trespass;  
1449 and (3) the infiltration collection lines are a minimum of 40 inches below the ground surface at  
1450 all points within the infiltration collection system.

1451  
1452 (VII)—Limestone or sandstone wells. In consolidated formations,  
1453 casing shall be driven a minimum of 5 feet into firm bedrock and cemented into place.

1454  
1455 (VIII)—Artesian wells.

1456  
1457 (moved to Section 11(e)(vii)(D))(1.)—When artesian water  
1458 is encountered in a well, unperforated casing shall extend into the confining layer overlying the  
1459 artesian zone. This casing shall be adequately sealed with cement grout into the confining zone  
1460 to prevent both surface and subsurface leakage from the artesian zone. The method of  
1461 construction shall be such that during the placing of the grout and the time required for it to set,  
1462 no water shall flow through or around the annular space outside the casing, and no water  
1463 pressure sufficient to disturb the grout prior to final set shall occur. After the grout has set  
1464 completely, drilling operations may be continued into the artesian zone. If leakage occurs  
1465 around the well casing or adjacent to the well, the well shall be recompleted with any seals,  
1466 packers or casing necessary to eliminate the leakage completely.

1467  
1468 (2.)—If water flows at the surface, the well shall be  
1469 equipped with valved pipe connections, watertight pump connections, or receiving reservoirs set  
1470 at an altitude so that flow can be stopped completely. There shall be no direct connection  
1471 between any discharge pipe and a sewer or other source of pollution.

1472  
1473 (moved to Section 11(e)(vii)(E)(I)(IX))—Wells that penetrate  
1474 more than one aquifer.

1475  
1476 (moved to Section 11(e)(vii)(E)(I)(1.))—Where a well  
1477 penetrates more than one aquifer or water bearing strata, every aquifer and/or strata shall be  
1478 sealed off to prevent migration of water from one aquifer or strata to another. Strata shall be  
1479 sealed off by placing impervious material opposite the strata and opposite the confining  
1480 formation(s). The seal shall extend above and below the strata no less than 10 feet. The sealing  
1481 material shall fill the annular space in the interval to be sealed, and the surrounding void spaces

1482 ~~which might absorb the sealing material. The sealing material shall be placed from the bottom to~~  
1483 ~~the top of the interval to be sealed.~~

1484  
1485 ~~(2.)—Sealing material shall consist of neat cement, cement~~  
1486 ~~grout, or bentonite clay.~~

1487  
1488 ~~(moved to Section 11(e)(vii)(E)(X)—Wells that encounter~~  
1489 ~~mineralized or polluted water.~~

1490  
1491 ~~(moved to Section 11(e)(vii)(E)(1.)—Any time during the~~  
1492 ~~construction of a well that mineralized water or water known to be polluted is encountered, the~~  
1493 ~~aquifer or aquifers containing such inferior quality water shall be adequately cased or sealed off~~  
1494 ~~so that water shall not enter the well, nor will it move up or down the annular space outside the~~  
1495 ~~well casing. If necessary, special seals or packers shall be installed to prevent movement of~~  
1496 ~~inferior quality water. Mineralized water may be used if it can be properly treated to meet all~~  
1497 ~~drinking water quality standards as determined by the administrator. When mineralized water is~~  
1498 ~~encountered, it shall not be mixed with any other waters from different aquifers within the well.~~  
1499 ~~If a well is penetrating multiple aquifers, mineralized water shall be excluded from the well if~~  
1500 ~~water is taken from other non-mineralized aquifers.~~

1501  
1502 ~~(moved to Section 11(e)(vii)(C)(2.)—In gravel packed~~  
1503 ~~wells, aquifers containing inferior quality water shall be sealed by pressure grouting, or with~~  
1504 ~~special packers or seals, to prevent such water from moving vertically in gravel packed portions~~  
1505 ~~of the well.~~

1506  
1507 ~~(XI)—Conversion of existing oil or gas wells, or exploration test~~  
1508 ~~holes, into water wells.~~

1509  
1510 ~~(moved to Section 11(e)(vii)(F)(1.)—Existing oil and gas~~  
1511 ~~wells, seismic test holes, or mineral exploration holes may be converted for use as water wells~~  
1512 ~~provided that the wells can be completed to conform to the minimum construction standards~~  
1513 ~~cited in this chapter. This does not relieve the applicant from obtaining appropriate permits.~~

1514  
1515 ~~(2.)—Information on the geologic conditions encountered~~  
1516 ~~in the well at the time of the original drilling shall be used to determine what special construction~~  
1517 ~~standards shall be met in order to eliminate all movement of pollutants into the well or along the~~  
1518 ~~annular space surrounding the casing. If no original geologic information is available, an electric~~  
1519 ~~or other geophysical log is required to supplement known information.~~

1520  
1521 ~~(C)—Construction materials.~~

1522  
1523 ~~(I)—Casing. The casing shall provide structural stability to~~  
1524 ~~prevent casing collapse during installation as well as drill hole wall integrity when installed, be~~  
1525 ~~of required size to convey liquid at a specified injection/recovery rate and pressure, and be of~~  
1526 ~~required size to allow for sampling.~~

1527

1528 ~~(1.)—Temporary steel casing—Temporary steel casing~~  
1529 ~~used for construction shall be capable of withstanding the structural load imposed during its~~  
1530 ~~installation and removal.~~

1531  
1532 ~~(2.)—Permanent steel casing—Permanent steel casing~~  
1533 ~~pipe shall be new pipe meeting AWWA Standard A-100 specifications for water well~~  
1534 ~~construction. The casing shall have full circumferential welds or threaded coupling joints to~~  
1535 ~~assure a watertight construction.~~

1536  
1537 ~~a.——Standard and line pipe. This material shall~~  
1538 ~~meet one of the following specifications:~~

1539  
1540 ~~API Std. 5L, "Specifications for Line Pipe."~~

1541  
1542 ~~API Std. 5LX, "Specifications for High Test~~  
1543 ~~Line Pipe."~~

1544  
1545 ~~ASTM A53 "Standard Specification for Pipe~~  
1546 ~~Steel, Black and Hot Dipped, Zinc Coated Welded and Seamless."~~

1547  
1548 ~~ASTM A120 "Standard Specifications for~~  
1549 ~~Pipe, Steel, Black and Hot Dipped Zinc Coated (Galvanized) Welded and Seamless, for~~  
1550 ~~Ordinary Uses."~~

1551  
1552 ~~ASTM A134 "Standards Specifications for~~  
1553 ~~Electric Fusion (arc) Welded Steel Plate Pipe (sizes NPS 16 inches and over)."~~

1554  
1555 ~~ASTM A135 "Standard Specifications for~~  
1556 ~~Electric Resistance Welded Steel Pipe." ASTM A139 "Standard Specification for Electric~~  
1557 ~~Fusion (arc) Welded Steel Pipe (Sizes 4" and over)."~~

1558  
1559 ~~ASTM A211 "Standard Specifications for~~  
1560 ~~Spiral Welded Steel or Iron Pipe." AWWA C200 "AWWA Standard for Steel Water Pipe 6~~  
1561 ~~inches and Larger."~~

1562  
1563 ~~b.——Structural steel. This material shall meet one of the~~  
1564 ~~following specifications:~~

1565  
1566 ~~ASTM A36 "Standard Specification for Structural~~  
1567 ~~Steel."~~

1568  
1569 ~~ASTM A242 "Standard Specifications for High~~  
1570 ~~Strength Low Alloy Structural Steel." ASTM A283 "Standard Specification for Low and~~  
1571 ~~Intermediate Tensile Strength Carbon Steel Plates, Shapes and Bars of Structural Quality."~~

1572

1573 ~~ASTM A441 "Tentative Specifications for High-~~  
1574 ~~Strength Low Alloy Structural Manganese Vanadium Steel."~~

1575  
1576 ~~ASTM A570 "Standard Specification for Hot-~~  
1577 ~~Rolled Carbon Steel Sheet and Strip, Structural Quality."~~

1578  
1579 ~~e. — High strength carbon steel sheets or "well casing~~  
1580 ~~steel". Each sheet of material shall contain mill markings which will identify the manufacturer~~  
1581 ~~and specify that the material is well casing steel which complies with the chemical and physical~~  
1582 ~~properties published by the manufacturer.~~

1583  
1584 ~~d. — Stainless steel casing shall meet the~~  
1585 ~~provisions of ASTM A409 "Standard Specification for Welded Large Diameter Austenitic Steel~~  
1586 ~~Pipe for Corrosive or High Temperature Service".~~

1587  
1588 ~~3. — Nonferrous casing materials. Nonferrous or plastic~~  
1589 ~~material may be used as a well casing. It must be resistant to the corrosiveness of the water and~~  
1590 ~~to the stresses to which it will be subjected during installation, grouting, and operation. The~~  
1591 ~~material shall be nontoxic. All joints shall be durable and watertight.~~

1592  
1593 ~~a. — Thermoplastics. This material shall meet the~~  
1594 ~~requirements of ASTM F 480 "Standard Specification for Thermoplastic Water Well Casing~~  
1595 ~~Pipe and Couplings made in Standard Dimension Ratios (SDR)".~~

1596  
1597 ~~b. — Thermosets. This material shall meet the~~  
1598 ~~requirements of the following specifications:~~

1599  
1600 ~~b. — ASTM D2996 "Standard Specification for~~  
1601 ~~Filament Wound Reinforced Thermosetting Resin Pipe."~~

1602  
1603 ~~b. — ASTM D2997 "Standard Specification for~~  
1604 ~~Centrifugally Cast Reinforced Thermosetting Resin Pipe."~~

1605  
1606 ~~b. ASTM D3517 "Standard Specification for~~  
1607 ~~Reinforced Plastic Mortar Pressure Pipe." AWWA C950 "AWWA Standards for Glass—Fiber—~~  
1608 ~~Reinforced Thermosetting—Resin Pressure Pipe."~~

1609  
1610 ~~e. — Concrete pipe used for casing should conform to~~  
1611 ~~one of the following specifications:~~

1612  
1613 ~~e. — ASTM C14 "Standard Specifications for~~  
1614 ~~Concrete Sewer, Storm Drain, and Culvert Pipe."~~

1615  
1616 ~~e. — ASTM C76 "Standard Specification for~~  
1617 ~~Reinforced Concrete Culvert, Storm Drain, and Sewer Pipe."~~



1619 e. ~~AWWA C300 "AWWA Standards for~~  
1620 ~~Reinforced Concrete Pressure Pipe, Steel Cylinder Type, for Water and Other Liquids."~~

1621  
1622 e. ~~AWWA C301 "AWWA Standards for~~  
1623 ~~Prestressed Concrete Pressure Pipe, Steel Cylinder~~  
1624 ~~Type, for Water and Other Liquids."~~

1625  
1626 4. ~~Casing diameter. The casing diameter (inside diameter)~~  
1627 ~~shall be a minimum of one size larger than the largest dimension/diameter of the pump or~~  
1628 ~~pumping structure. If a reduction in casing diameter is made, there shall be adequate overlap of~~  
1629 ~~the casing to prevent misalignment and to prevent the movement of unstable sediment into the~~  
1630 ~~well. To prevent the migration of mineralized, polluted, or otherwise inferior quality water, lead~~  
1631 ~~or neoprene packers shall be installed to seal the annular space between casings.~~

1632  
1633 (II) ~~Packers. Packers shall be material that will not impart taste, odor,~~  
1634 ~~toxic substance, or bacterial contamination to the well water.~~

1635  
1636 (III) ~~Screens.~~

1637  
1638 (1.) ~~Screens shall be constructed of materials resistant to~~  
1639 ~~damage by chemical action of groundwater or cleaning operations, and have size of openings~~  
1640 ~~based on sieve analysis of formation and/or gravel pack materials. The screen shall have~~  
1641 ~~sufficient diameter to provide adequate specific capacity and low aperture entrance velocity. The~~  
1642 ~~entrance velocity shall not exceed 0.1 feet per second (3 cm/sec).~~

1643  
1644 (2.) ~~The screen shall be installed so that the pumping water~~  
1645 ~~level remains above the screen under all operating conditions, and shall be provided with a~~  
1646 ~~bottom plate or washdown bottom fitting of the same material as the screen.~~

1647  
1648 (3.) ~~For a nonhomogeneous aquifer having a uniformity~~  
1649 ~~coefficient less than 3.0 and an effective grain size less than 0.01 inches, an artificial filter or~~  
1650 ~~screen shall be used.~~

1651  
1652 (IV) ~~Grout and grouting requirements. All permanent well casing,~~  
1653 ~~except driven Schedule 40 steel casing, shall be surrounded by a minimum of 2 inches (5.1 cm)~~  
1654 ~~of grout. All temporary construction casings shall be removed. Where removal is not possible~~  
1655 ~~or practical, the casing shall be withdrawn at least 5 feet to ensure grout contact with the native~~  
1656 ~~formation.~~

1657  
1658 (1.) ~~Neat cement grout. Cement conforming to ASTM Standard~~  
1659 ~~C150 and water, with not more than 6 gallons (13.62 L) of water per sack of cement, must be~~  
1660 ~~used for 2 inch (5.1 cm) openings. Additives used to increase fluidity must meet ASTM C494.~~

1661  
1662 (2.) ~~Concrete grout. Equal parts of cement conforming to~~  
1663 ~~ASTM Standard C150 and sand, with not more than 6 gallons (13.62 L) of water per sack of~~  
1664 ~~cement, may be used for openings larger than 2 inches (5.1 cm). Where an annular opening~~

1665 ~~larger than 4 inches (10 cm) is available, gravel not larger than 1/2 inch (1.27 cm) in size may be~~  
1666 ~~added.~~

1667  
1668 (3.)—~~Clay seal.~~—~~Where an annular opening greater than 6~~  
1669 ~~inches (15.2 cm) is available a clay seal of clean local clay mixed with at least 10 percent~~  
1670 ~~swelling bentonite may be used.~~

1671  
1672 (4.)—~~Application.~~—~~Prior to grouting through creviced or~~  
1673 ~~fractured formations, bentonite or similar materials may be added to the annular opening in the~~  
1674 ~~manner indicated for grouting. After cement grouting is applied, work on the well shall be~~  
1675 ~~discontinued until the cement or concrete grout has properly set.~~

1676  
1677 ~~Sufficient annular opening shall be provided to permit a minimum of 2 inches (5.1 cm) of~~  
1678 ~~grout around permanent casings, including couplings.~~

1679  
1680 ~~When the annular opening is 4 or more inches (10 cm) and less than 100 feet (30.5 m) in~~  
1681 ~~depth and concrete grout is used, the grout may be placed by gravity through a grout pipe~~  
1682 ~~installed to the bottom of the annular opening in one continuous operation until the annular~~  
1683 ~~opening is filled.~~

1684  
1685 ~~When the annular opening exceeds 6 inches (15.2 cm), and less than 100 feet (30.5 m) in~~  
1686 ~~depth and a clay seal is used, it may be placed by gravity.~~

1687  
1688 (5.)—~~Guides.~~—~~The casing must be provided with sufficient guides~~  
1689 ~~welded to the casing to permit unobstructed flow and uniform thickness of grout.~~

1690  
1691 (V)—~~Upper terminal well construction.~~

1692  
1693 (1.)—~~Permanent casing for all groundwater sources shall project~~  
1694 ~~at least 12 inches (30.5 cm) above the pumphouse floor or concrete apron surface and at least 18~~  
1695 ~~inches (0.46 m) above final ground surface. The concrete floor or apron shall slope away from~~  
1696 ~~the casing at a slope of 1 inch per foot (8.33 cm/m).~~

1697  
1698 (2.)—~~Where a well house is constructed, the floor surface shall~~  
1699 ~~be at least 6 inches (15.2 cm) above the final ground elevation and shall slope away from the~~  
1700 ~~casing at a slope of 1/2 inch per foot (4.16 cm/m).~~

1701  
1702 (3.)—~~Sites subject to flooding shall be provided with an earthen~~  
1703 ~~berm surrounding the casing and terminating at an elevation at least 2 feet (0.61 m) above the~~  
1704 ~~highest known flood elevation, or other suitable protection shall be provided.~~

1705  
1706 (4.)—~~The top of the well casing at sites subject to flooding shall~~  
1707 ~~terminate at least 3 feet (0.91 m) above the 100-year flood level or the highest known flood~~  
1708 ~~elevation, whichever is higher.~~

1709

1710 ~~(5.)—The casing and/or well house shall be protected from~~  
1711 ~~entrance by animals.~~

1712  
1713 ~~(VI)—Development.~~

1714  
1715 ~~(1.)—Every well shall be developed to remove the native silts~~  
1716 ~~and clays, drilling mud or finer fraction of the gravel pack. Development shall continue until the~~  
1717 ~~maximum specific capacity is obtained from the completed well.~~

1718  
1719 ~~(2.)—Where chemical conditioning is required, the specifications~~  
1720 ~~shall include provisions for blasting and cleaning. Special attention shall be given to assure that~~  
1721 ~~the grouting and casing are not damaged by the blasting.~~

1722  
1723 ~~(VII)—Capping requirements. A welded metal plate or a threaded cap~~  
1724 ~~shall be used for capping a well. A properly fitted, firmly driven, solid wooden plug may be~~  
1725 ~~used for capping a well until pumping equipment is installed. At all times during the progress of~~  
1726 ~~work, the contractor shall provide protection to prevent tampering with the well or entrance of~~  
1727 ~~surface water or foreign materials.~~

1728  
1729 ~~(D)—Well pumps, discharge piping and appurtenances.~~

1730  
1731 ~~(I)—Line shaft pumps. Wells equipped with line shaft pumps shall~~  
1732 ~~have the casing firmly connected to the pump structure or have the casing inserted into a recess~~  
1733 ~~extending at least 1/2 inch into the pump base, have the pump foundation and base designed to~~  
1734 ~~prevent water from coming into contact with the joint, and avoid the use of oil lubrication at~~  
1735 ~~pump settings less than 400 feet (122 m).~~

1736  
1737 ~~(moved to Section 11(e)(xii))(II)—Submersible pumps. Where a~~  
1738 ~~submersible pump is used, the top of the casing shall be effectively sealed against the entrance of~~  
1739 ~~water under all conditions of vibration or movement of conductors or cables. The electrical~~  
1740 ~~cable shall be firmly attached to the rise pipe at 20 foot (6.1 m) intervals or less, and the pump~~  
1741 ~~shall be located at a point above the top of the well screen.~~

1742  
1743 ~~(III)—Discharge piping.~~

1744  
1745 ~~(1.)—The discharge piping shall have control valves and~~  
1746 ~~appurtenances located above the wellhouse floor. The piping shall be protected against the~~  
1747 ~~entrance of contamination and be equipped with a check valve, a shutoff valve, a pressure gauge,~~  
1748 ~~a means of measuring flow, and a smooth-nosed sampling tap located at a point where positive~~  
1749 ~~pressure is maintained. Where a submersible pump is used, a check valve shall be located in the~~  
1750 ~~casing in addition to the check valve located above ground to prevent negative pressures on the~~  
1751 ~~discharge piping.~~

1752  
1753 ~~(2.)—For pipes equipped with an air release vacuum relief valve,~~  
1754 ~~the valve shall be located upstream from the check valve, with exhaust/relief piping terminating~~  
1755 ~~in a downturned position at least 18 inches (0.46 m) above the floor and covered with a 24 mesh~~

1756 ~~corrosion-resistant screen. The discharge piping shall be valved to permit test pumping and~~  
1757 ~~control of each well.~~

1758  
1759 (3.) ~~All exposed piping, valves and appurtenances shall be~~  
1760 ~~protected against physical damage and freezing.~~

1761  
1762 (4.) ~~The piping shall be properly anchored to prevent~~  
1763 ~~movement, and shall be protected against surge or water hammer.~~

1764  
1765 (5.) ~~The discharge piping shall be provided with a means of~~  
1766 ~~pumping to waste, but shall not be directly connected to a sewer.~~

1767  
1768 ~~(moved to Section 11(e)(xxiv))(IV) Pitless well units. A pitless adaptor~~  
1769 ~~or well house shall be used where needed to protect the water system from freezing. moved to~~  
1770 ~~Section 11(e)(xxiv) A frost pit may be used only in conjunction with a properly protected pitless~~  
1771 ~~adaptor.~~

1772  
1773 (1.) ~~All pitless units shall be shop fabricated from the point of~~  
1774 ~~connection with the well casing to the unit cap or cover. They shall be threaded or welded to the~~  
1775 ~~well casing, and be of watertight construction throughout. The materials and weight shall be at~~  
1776 ~~least equivalent and compatible to the casing.~~

1777  
1778 (2.) ~~Pitless units shall have field connection to the lateral~~  
1779 ~~discharge from the pitless unit of threaded, flanged or mechanical joint connection, and the top~~  
1780 ~~of the pitless unit shall terminate at least 18 inches (0.46 m) above final ground elevation or 3~~  
1781 ~~feet above the 100-year flood level or the highest known flood elevation, whichever is higher.~~

1782  
1783 (3.) ~~Provisions shall be made to disinfect the well. The unit~~  
1784 ~~shall have facilities to measure water levels in the well; a cover at the upper terminal of the well~~  
1785 ~~that will prevent the entrance of contamination; a contamination proof entrance connection for~~  
1786 ~~electrical cable; an inside diameter as great as that of the well casing, up to and including casing~~  
1787 ~~diameters of 12 inches (30.5 cm), to facilitate work and repair on the well, pump, or well screen;~~  
1788 ~~and at least one check valve within the well casing.~~

1789  
1790 (V) ~~Casing vent. Provisions shall be made for venting the well casing~~  
1791 ~~to atmosphere. The vent shall terminate in a downturned position, at or above the top of the~~  
1792 ~~casing or pitless unit in a minimum 1 1/2 inch (3.8 cm) diameter opening covered with a 24~~  
1793 ~~mesh corrosion-resistant screen. The pipe connecting the casing to the vent shall be of adequate~~  
1794 ~~size to provide rapid venting of the casing.~~

1795  
1796 ~~(moved to Section 11(e)(xv))(vi) Water level management. Every~~  
1797 ~~well greater than 4 inches (10 cm) in diameter shall be equipped with an access port that will~~  
1798 ~~allow for the measurement of the depth to the water surface; or in the case of a flowing artesian~~  
1799 ~~well, with a pressure gauge that will indicate pressure. An air line used for level measurement~~  
1800 ~~shall be provided on all wells greater than 4 inches (10 cm) in diameter. Installation of water~~

1801 ~~level-measuring equipment shall be made using corrosion-resistant materials attached firmly to~~  
1802 ~~the drop pipe or pump column and in such a manner as to prevent entrance of foreign materials.~~

1803  
1804 ~~(moved to Section 11(e)(xvi))(VII) Discharge measuring device. Every~~  
1805 ~~well shall be piped so that a device capable of measuring the total well discharge can be placed~~  
1806 ~~in operation at the well for well testing. Every well field (or when only one well is present,~~  
1807 ~~every well) shall have a device capable of measuring the total discharge.~~

1808  
1809 ~~(VIII) Observation wells. Observation wells shall be constructed in~~  
1810 ~~accordance with the requirements for permanent wells if they are to remain in service after~~  
1811 ~~completion of a water supply well. They shall be protected at the upper terminal to preclude~~  
1812 ~~entrance of foreign materials.~~

1813  
1814 ~~moved to Section 11(e)(xvi))(IX) Well abandonment. Test wells and~~  
1815 ~~groundwater sources which are not in use shall be sealed in accordance with requirements of~~  
1816 ~~Chapter 26, Water Quality Rules and Regulations.~~

1817  
1818 ~~(moved to Section 11(e)(xvi))(IX) Wells shall be sealed by filling with neat cement grout.~~  
1819 ~~The filling materials shall be applied to the well hole through a pipe, tremie, or bailer.~~

1820  
1821 (a) 2018 TSS, parts 1.1.1-1.1.1(d), engineers report, general information; 1.1.2-  
1822 1.1.2(c), engineers report, extent of water works system; 1.1.4-1.1.4(c), engineers report, soil,  
1823 groundwater conditions, and foundation problems; 1.1.5-1.1.5(f), engineers report, water use  
1824 data; 1.1.6-1.1.6(b), engineers report, flow requirements; 1.1.7.1-1.1.7.1(f), engineers report,  
1825 surface water sources; 1.1.7.2-1.1.7.2(g), engineers report, groundwater; 1.1.8, engineers report,  
1826 proposed treatment processes; 1.1.9, engineers report, sewerage system available; 1.1.10,  
1827 engineers report, waste disposal; 1.1.15-1.1.15(d), engineers report, pumping facilities; 1.1.16-  
1828 1.1.16(c), engineers report, storage facilities; and 1.1.17-1.1.17(d), engineers report, security,  
1829 contingency planning, and emergency preparedness; are herein incorporated by reference.

1830  
1831 ~~(formerly Section 6(a))(b) Scope and purpose. An engineering design report shall be~~  
1832 ~~submitted with each application. The purpose of the report shall be to describe and provide~~  
1833 ~~technical justification for all aspects of the proposed construction, modifications and/or~~  
1834 ~~installations. The report should address existing conditions (if any), known or suspected~~  
1835 ~~problems, proposed actions, and the reasoning used to arrive at those proposed actions. There is~~  
1836 ~~no minimum or maximum size for the report, provided it meets the purpose of this section. and~~  
1837 ~~shall include the following required elements:~~

1838  
1839 (i) The information required in paragraph (a) of this Section;

1840  
1841 (ii) A description by narrative, analyses, and calculations of the project  
1842 purpose and intent in order to support the project plans and specifications;

1843  
1844 (iii) A description of known or suspected problems, needs, or requirements,  
1845 and the reasoning used to arrive at the proposed solution;

1847 (iv) An identification of problems and solutions related to but not limited to  
1848 the following:

1849  
1850 (A) Water quantity and quality;

1851  
1852 (B) Compliance with the Safe Drinking Water Act, 42 U.S.C. §300f et  
1853 seq.; and

1854  
1855 (C) Operational requirements, redundancy, maintenance, and  
1856 reliability.

1857  
1858 ~~(formerly 6(d))(v) Hazard classification. The engineering design report shall~~  
1859 ~~include a~~ A determination of the degree of hazard of all known or anticipated water service  
1860 connections to be connected to the proposed project. A hazard classification shall be identified  
1861 for each connection and recommended mitigation measures shall be described for each hazard.

1862 ~~\_\_\_\_\_ hazard classification or specify the default classification identified in Section 14 (i) (i)~~  
1863 ~~(B) which shall be applicable to the project. A hazard classification shall include the following:~~

1864  
1865 ~~(moved to Section 9(b)(iv))(i) A determination of the degree of hazard of all water~~  
1866 ~~service connections to be connected to the proposed project.~~

1867  
1868 ~~(moved to Section 9(b)(iv))(ii) \_\_\_\_\_ A determination of the potential cause of~~  
1869 ~~backflow for all water service connections.~~

1870  
1871 ~~(formerly Section 6(b))(c) Water distribution (water works) systems.~~ The engineering  
1872 design report for all new water distribution system extensions shall include the following  
1873 required elements:

1874  
1875 (i) The information required in paragraph (a) of this Section;

1876  
1877 ~~(formerly Section 6(b)(i))(ii)~~ (ii) A description of the service area including scaled  
1878 vicinity plan map(s) of the project with regard to adjacent and proposed development, elevations,  
1879 and topographic features;

1880  
1881 ~~(formerly Section 6(b)(ii))(iii)~~ (iii) Current and projected system water demand  
1882 for average day; use data and flow requirements to include maximum day-, maximum hour  
1883 hourly demand; needed fire flows and per capita maximum daily flows; and

1884  
1885 ~~(formerly Section 6(b)(iii))(iv)~~ (iv) Information on fire protection and fire flow  
1886 capabilities of the proposed system.

1887  
1888 ~~(formerly Section 6(b)(iv))~~ Description of high service pumping systems and  
1889 finished water storage facilities.

1890  
1891 ~~(formerly Section 6(e))(d)~~ (d) Treatment facilities. The engineering design report for all  
1892 treatment facilities shall include the following required elements:

1893  
1894 (i) The information required in paragraph (a) of this Section;  
1895  
1896 ~~(formerly Section 6(e)(i))~~(ii) A description of the facility site and location,  
1897 including a scaled site plan, and:  
1898  
1899 ~~(formerly Section 6(e)(i)(A))~~(A) Present and projected facility  
1900 property boundaries;  
1901  
1902 ~~(formerly Section 6(e)(i)(B))~~(B) Flood protection indicating predicted  
1903 elevation of 25- and 100-year flood stages. ~~The facility shall be protected from damage and be~~  
1904 ~~capable of being operated during the 100-year flood or maximum flood of record, whichever is~~  
1905 ~~greater. Flooding resulting from ice jams shall be considered.~~  
1906  
1907 ~~(formerly Section 6(e)(i)(C))~~(C) Present and proposed access. ~~for the~~  
1908 purpose of operation, maintenance, and compliance inspection;  
1909  
1910 ~~(formerly Section 6(e)(i)(D))~~(D) Distances from: ~~current habitation,~~  
1911 ~~the closest major treated water transmission line, the closest treated water storage facility, and~~  
1912 ~~the water source.~~  
1913  
1914 ~~(formerly Section 6(e)(i)(D))~~(I) ~~e~~Current habitation;  
1915  
1916 ~~(formerly Section 6(e)(i)(D))~~(II) ~~†~~The closest major treated  
1917 water transmission line;  
1918  
1919 ~~(formerly Section 6(e)(i)(D))~~(III) ~~†~~The closest treated water  
1920 storage facility; and  
1921  
1922 ~~(formerly Section 6(e)(i)(D))~~(IV) ~~†~~The water source.  
1923  
1924 ~~(formerly Section 6(e)(i)(E))~~(E) Fencing and ~~or~~ security;  
1925  
1926 ~~(formerly Section 6(e)(i)(F))~~(F) Topographic features and contours  
1927 with indicated datum; and  
1928  
1929 ~~(formerly Section 6(e)(i)(G))~~(G) Soil and subsurface geological  
1930 characteristics; including ~~Provide~~ a soils investigation report of the proposed site suitable for  
1931 structural design of the proposed facilities.  
1932  
1933 ~~(formerly Section 6(e)(ii))~~(iii) A ~~detailed~~ description of the service area, ~~for the~~  
1934 ~~project~~ including a scaled vicinity plan ~~showing land use and boundaries~~ map(s) of the project  
1935 with regard to adjacent and proposed development, elevations, and topographic features .  
1936  
1937 ~~(formerly Section 6(e)(iii))~~(iv) A detailed description of the recycle flows  
1938 and procedures for reclamation of recycle streams; and

1939  
1940 ~~(formerly Section 6(e)(iv))(v)~~ A detailed description of disposal techniques for  
1941 settled solids, including a description of the ultimate disposal of sludge.

1942  
1943 ~~(formerly Section 6(e)(v)(B))(e)~~ Engineering design reports for new Ssurface water  
1944 sources shall include the following required elements:

1945  
1946 (i) The information required in paragraph (a) of this Section;

1947  
1948 ~~(formerly Section 6(e)(v)(B)(I))(ii)~~ Safe annual yield, A description of the quantity of water  
1949 quantity available ~~from the source~~ during ~~the~~ average and driest years of record; that contains  
1950 details of:

1951  
1952 ~~(formerly Section 6(e)(v)(B)(H))(A)~~ Hydrological data, stream flows and  
1953 Any diversion records; and

1954  
1955 ~~(formerly Section 6(e)(v)(B)(VI))(B)~~ Description of any diversion dams,  
1956 impoundments or reservoirs ~~and appurtenances~~ that may impact design considerations or long-  
1957 term water availability.

1958  
1959 ~~(formerly Section 6(e)(v)(B)(III))(iii)~~ A tabulation of Representative water quality  
1960 data; that describes the including bacteriological biological, radiological, and chemical and  
1961 physical data. water quality These data shall be sufficient to determine the necessary treatment  
1962 processes and the ability to meet water quality standards. that:

1963  
1964 (A) For surface water source testing, include at least one sampling  
1965 event during spring runoff and at least one sampling event during late summer or early fall low  
1966 flow; and

1967  
1968 (B) Includes data that are sufficient for the Division to determine that  
1969 the processes safely and reliably comply with water quality standards required by 40 CFR Part  
1970 141.

1971  
1972 ~~(formerly Section 6(e)(v)(A))(f)~~ Engineering design reports for new Ggroundwater  
1973 sources shall include:

1974  
1975 (i) The information required in paragraph (a) of this Section;

1976  
1977 ~~(formerly Section 6(e)(v)(A)(I))(ii)~~ A description of the Ggeology of the  
1978 aquifer(s) and overlying strata;

1979  
1980 ~~(formerly Section 6(e)(v)(A)(II))(iii)~~ Tabulated Wwater quality; testing data  
1981 including for biological, radiological and chemical water quality data sufficient to determine  
1982 necessary treatment processes ~~and compliance with all drinking water standards as determined~~  
1983 ~~by the administrator. The same water quality data for all secondary sources shall also be~~



1984 ~~provided~~ and sufficient for the Administrator to determine that the processes safely and reliably  
1985 meet water quality standards required by 40 CFR Part 141;

1986  
1987 (iv) If known, a summary of the likely drilling and completion challenges that  
1988 will be faced, including a description of the engineering design, management, monitoring, and  
1989 drilling and completion practices that will be used to successfully construct the well in  
1990 accordance with this Chapter; and

1991  
1992 (v) For wells that will be drilled through multiple aquifers, applicants shall  
1993 request a pre-application meeting with the applicable Division district engineer to discuss:

1994  
1995 (A) The boring advancement, well sealing, well development, and  
1996 methods used to determine the adequacy of the well seal; and

1997  
1998 (B) The methods that will be used to overcome lost circulation, bore  
1999 instability, and deviations from vertical alignment.

2000  
2001 (g) Engineering design reports for conversion of an existing well into a public water  
2002 supply well shall include the following required elements:

2003  
2004 (i) The information required in paragraph (a) of this Section;

2005  
2006 (ii) The information required in paragraph (f) of this Section;

2007  
2008 (iii) The submission of the State Engineer's Office (SEO) Statement of  
2009 Completion and Description of Well; and

2010  
2011 (iv) A video log of the well inspection accompanied by a written description of  
2012 the location, shape, and estimated size of any holes, breaches, corroded areas in the casing, if  
2013 any, that includes:

2014  
2015 (A) If any damage to the casing is found, a description of how  
2016 defective areas will be repaired and if there is a need for additional well bond logging; or

2017  
2018 (B) If well bond logging is not recommended, a description of the  
2019 technical justification and an alternative means of certifying the adequacy of the well seal to  
2020 protect the water source.

2021  
2022 (h) Engineering design reports for new water treatment facilities shall include the  
2023 following required elements:

2024  
2025 (i) The information required in paragraph (a) of this Section;

2026  
2027 (ii) A description of all water treatment chemical requirements, including  
2028 dosage and feed rates, delivery, handling, and storage;

2029

2030 (iii) A description of automatic operation and control systems, including basic  
2031 operation, manual override operation, and maintenance requirements; and  
2032

2033 (iv) A description of the on-site laboratory facilities and a summary of those  
2034 tests to be conducted on-site. If no on-site laboratory is provided, a description of plant control  
2035 and water quality testing requirements, and where the testing will be conducted shall be included.  
2036

2037 (i) Engineering design reports for water treatment facility modifications shall  
2038 describe:  
2039

2040 (i) The information required in paragraph (a) of this Section;  
2041

2042 (ii) The purpose of the facility modification;  
2043

2044 (iii) All proposed new equipment, tankage, and chemical treatment processes,  
2045 including a description of the modification's effect on treatment system reliability, water  
2046 quantity and quality; and  
2047

2048 (iv) A listing of the new equipment design criteria and the associated  
2049 chemicals.  
2050

2051 (j) Engineering design reports for water main upsizing or looping projects shall  
2052 describe the purpose of the water main upsizing or looping project and shall include the  
2053 following required elements:  
2054

2055 (i) The information required in paragraph (a) of this Section;  
2056

2057 (ii) Hydraulic analysis that demonstrates how peak hour, average day,  
2058 maximum day, and maximum day plus fire flows, if fire flows are available, will be improved by  
2059 upsizing; and  
2060

2061 (iii) A table that summarizes the hydraulic model results.  
2062

2063 (k) Engineering design reports for water main removal and replacements shall  
2064 describe the purpose of the replacement and identify the existing main size, material type, and  
2065 condition, and shall include the following required elements:  
2066

2067 (i) The information required in paragraph (a) of this Section;  
2068

2069 (ii) For any main replacement(s), the replacement main size, material type,  
2070 and dimension ratio;  
2071

2072 (iii) For projects that consist of main replacements in multiple discrete  
2073 locations, an aerial image that shows all replacement pipeline segments, including new valves,  
2074 with called-out pipe diameters and lengths;  
2075

2076 (iv) A description of the protective measures that will be taken at locations  
2077 where the new water main will cross a sewer or storm sewer when standard horizontal and  
2078 vertical separations cannot be met; and

2079 (v) For projects where asbestos cement may be encountered, a discussion of  
2080 the disposal, or abandonment method to be used.

2081 (l) Engineering design reports for new water mains shall describe the purpose of the  
2082 new water main and shall include the information required in paragraph (a) of this Section. If the  
2083 water main will provide service to a new development the engineering design report shall include  
2084 the following required elements:

2085 (i) The modeling result from a hydraulic analysis that demonstrates that the  
2086 design will meet the requirements of Section 16(d)(i-ii) of this Chapter;

2087 (ii) A demonstration that the hydraulic model was calibrated based on existing  
2088 fire hydrant test flow data, when available, or based on modeling; and

2089 (iii) Identification of any impacts the new fire flow demand will have on  
2090 finished storage and pumping systems over the required fire flow duration.

2091 **Section 10. ~~Treatment~~ Design Requirements for Preliminary Treatment and**  
2092 **Redundancy.**

2093 ~~(moved to Section 12(b))(a) Design capacity. The capacity of the water treatment or~~  
2094 ~~water production system shall be designed for the maximum daily demand at the design year.~~

2095 ~~(moved to Section 12(c))(b) Presedimentation. Raw waters which have episodes~~  
2096 ~~of turbidity in excess of 1,000 TU for a period of one week or longer shall be presettled.~~

2097 ~~(moved to Section 12(d)(i))(i) Detention time. Basins without mechanical sludge~~  
2098 ~~collection equipment shall have a minimum detention time of three days. Basins with mechanical~~  
2099 ~~sludge collection equipment shall have a minimum detention time of three hours.~~

2100 ~~(ii) Inlet. Inlet flow shall be evenly dispersed along the inlet of the basin.~~

2101 ~~(moved to Section 12(b)(iv))(iii) Drains. Basins shall have a minimum of one~~  
2102 ~~8-inch (20 cm) drain line to completely dewater the facility.~~

2103 ~~(moved to Section 12(b)(iii))(iv) Bottom slope. Basins shall have a bottom~~  
2104 ~~slope to drain of 1/4 inch per foot (20 mm/m) without mechanical sludge collection equipment~~  
2105 ~~and 2 inches per foot (16 cm/m) with mechanical sludge collection equipment.~~

2106 ~~(v) Bypass. Basin bypass provisions shall be included in the process piping.~~

2121 ~~(moved to Section 12(e))(c) — Rapid mix. Rapid dispersal of chemicals throughout the~~  
2122 ~~water shall be accomplished by mechanical mixers, jet mixers, static mixers, or hydraulic jump.~~

2123  
2124 ~~(moved to Section 12(e)(i))(i) Mixing intensity. For mechanical mixers, the~~  
2125 ~~minimum  $Gt$  (velocity gradient (sec<sup>-1</sup>) x t (sec)) provided at maximum daily flow shall be~~  
2126 ~~27,000.~~

2127  
2128 ~~(moved to Section 12(e)(ii))(ii) — Mixing time. The detention time in a flash~~  
2129 ~~mixing chamber shall not exceed 30 seconds at maximum daily flow conditions.~~

2130  
2131 ~~(moved to Section 12(e)(iii))(iii) — Drain. The basin shall have a drain.~~

2132  
2133 ~~(moved to Section 12(f))(d) — Flocculation. The low velocity agitation of chemically~~  
2134 ~~treated water shall be accomplished by mechanical flocculators.~~

2135  
2136 ~~(moved to Section 12(f)(ii))(i) — Detention time. A minimum of 10 minutes~~  
2137 ~~detention time shall be provided.~~

2138  
2139 ~~(moved to Section 12(f)(iv))(ii) — Mixing intensity. The velocity gradient ( $G$~~   
2140 ~~value) imposed shall be adjustable by providing variable speed drives or shall be designed to be~~  
2141 ~~30 sec<sup>-1</sup> if a single basin is provided, 20 sec<sup>-1</sup> in the final basin of a two stage system, and 10~~  
2142 ~~sec<sup>-1</sup> in the final basin of a three stage system. For a single speed drive system, the tip speed of~~  
2143 ~~the mixer shall not exceed 3 feet per second (0.91 m/sec). Variable speed drives shall provide tip~~  
2144 ~~speeds of 0.5 to 3.0 feet per second (0.15-0.91 m/sec).~~

2145  
2146 ~~(moved to Section 12(f)(iii))(iii) — Drains. Flocculation basins shall have a~~  
2147 ~~minimum of one drain line to dewater the facility.~~

2148  
2149 ~~(moved to Section 12(f)(vi))(iv) — Piping. The velocity of flocculated water~~  
2150 ~~through pipes or conduits to settling basins shall not be less than 0.5 or greater than 1.5 feet per~~  
2151 ~~second (0.15-0.46 m/sec).~~

2152  
2153 ~~(moved to Section 12(g))(e) — Sedimentation basins.~~

2154  
2155 ~~(moved to Section 12(g)(i))(i) Diameter. The maximum diameter in circular basins~~  
2156 ~~shall be 80 feet.~~

2157  
2158 ~~(moved to Section 12(g)(v))(ii) — Overflow rate. The basin overflow rate shall~~  
2159 ~~not exceed 1,000 gpd/ft<sup>2</sup> (41 m<sup>3</sup>/m<sup>2</sup>d) at design conditions.~~

2160  
2161 ~~(iii) — Weir loading rate. Weir loading rates shall not exceed 20,000 gpd/ft (2480~~  
2162 ~~m<sup>3</sup>md) of length. The weir length shall be computed as the length of the centerline of the~~  
2163 ~~launder. Where the weir is located at 3/4 the radius, the weir may be loaded at 36,000 gpd/ft~~  
2164 ~~(4464 m<sup>3</sup>/m-d).~~

2166 ~~(moved to Section 12(g)(ii))(iv) — Side water depth. The minimum basin side~~  
2167 ~~water depth shall be 8 feet (2.43 m) if mechanical sludge collection equipment is provided or~~  
2168 ~~basins or basin sludge hopper segments are less than 100 square feet (9.3 m<sup>2</sup>) in surface area and~~  
2169 ~~15 feet (4.6 m) if basins are manually cleaned. Mechanical sludge collection equipment includes~~  
2170 ~~mechanically driven drives that use scrapers or differential water level to collect the sludge.~~

2171  
2172 ~~(moved to Section 12(g)(iii))(v) — Freeboard. The outer walls of settling basins~~  
2173 ~~shall extend at least 12 inches (30.5 cm) above the surrounding ground and provide at least 12~~  
2174 ~~inches (30.5 cm) of freeboard to the water surface. Where basin walls are less than 4 feet (1.22~~  
2175 ~~m) above the surrounding ground, a fence or other debris barrier shall be provided on the wall.~~

2176  
2177 ~~(vi) — Inlet devices. Inlets shall be designed to distribute the water equally and at~~  
2178 ~~uniform velocities. Open ports, submerged ports, and similar entrance arrangements are required.~~  
2179 ~~A baffle should be constructed across the basin close to the inlet end and should project several~~  
2180 ~~feet below the water surface to dissipate inlet velocities and provide uniform flows across the~~  
2181 ~~basin.~~

2182  
2183 ~~(vii) — Velocity. The velocity through settling basins shall not exceed 0.5 feet per~~  
2184 ~~minute (0.15 m/min). The basins must be designed to minimize short-circuiting.~~

2185  
2186 ~~(moved to Section 12(g)(vi))(viii) — Sludge collection. If settleable organics are~~  
2187 ~~present in the water or if there is a history of organically related taste and odor problems,~~  
2188 ~~mechanical sludge collection shall be provided.~~

2189  
2190 ~~(moved to Section 12(g)(vii))(ix) — Sludge removal. Sludge removal design~~  
2191 ~~shall provide that sludge pipes shall be not less than 6 inches (15.2 cm) in diameter and arranged~~  
2192 ~~to facilitate cleaning. Valves on the sludge line shall be located outside the tank.~~

2193  
2194 ~~(x) — Flushing lines. Flushing lines or hydrants shall be provided near the~~  
2195 ~~basins.~~

2196  
2197 ~~(moved to Section 12(e)(iv))(xi) — Drainage. Basin bottoms shall slope toward~~  
2198 ~~the drain at not less than 1 inch per foot (8 cm/m) where mechanical sludge collection equipment~~  
2199 ~~is provided and 1/4 inch per foot (2 cm/m) where no mechanical sludge collection equipment is~~  
2200 ~~provided.~~

2201  
2202 ~~(moved to Section 12(h))(f) — Softening sedimentation — clarification. Conventional~~  
2203 ~~sedimentation — clarification as described above shall be provided in softening operations, except~~  
2204 ~~for softening a groundwater supply of constant quality. Where a groundwater supply is softened,~~  
2205 ~~the requirements may be modified as follows:~~

2206  
2207 ~~(moved to Section 12(h)(i))(i) Overflow rate. The basin overflow rate at the design~~  
2208 ~~flow shall not exceed 2,100 gpd/ft<sup>2</sup> (86 m<sup>3</sup>/m<sup>2</sup>·d).~~

2210 ~~(moved to Section 12(h)(ii))(ii) — Sludge. Mechanical sludge removal shall be~~  
2211 ~~provided and shall be designed to handle a load of 40 lbs/foot (60 kg/m) of collector-scraper arm~~  
2212 ~~length.~~

2213  
2214 ~~(iii) — Other design considerations shall be the same as conventional~~  
2215 ~~sedimentation—clarification.~~

2216  
2217 ~~(moved to Section 12(l))(g) — Solids contact units. These treatment units are acceptable~~  
2218 ~~for combined softening and clarification of well water where water quality characteristics are not~~  
2219 ~~variable and flow rates are uniform. The units shall be designed to meet the criteria detailed~~  
2220 ~~previously.~~

2221  
2222 ~~(moved to Section 12(l)(i))(i) Such units may be considered for use as clarifiers~~  
2223 ~~without softening when they are designed to meet the criteria detailed in the conventional~~  
2224 ~~sedimentation—clarification.~~

2225  
2226 ~~(moved to Section 12(l)(ii))(ii) — These units may also be used for other~~  
2227 ~~treatment purposes, such as rapid mixing, flocculation, etc., when the individual components of~~  
2228 ~~the solids contact units are designed in accordance with the design criteria for that individual~~  
2229 ~~treatment process as described above.~~

2230  
2231 ~~(moved to Section 12(j))(h) — Settling tube clarifiers. Shallow depth sedimentation~~  
2232 ~~devices or tube clarifier systems of the essentially horizontal or steeply inclined types may be~~  
2233 ~~used when designed as follows:~~

2234  
2235 ~~(moved to Section 12(j)(iii))(i) — Sludge removal. Sludge shall be removed~~  
2236 ~~using 45 or steeper hoppers bottoms, or mechanical devices that move the sludge to hoppers, or~~  
2237 ~~devices that remove settled sludge from the basin floor using differential hydraulic level.~~

2238  
2239 ~~(moved to Section 12(j)(iv))(ii) — Tube cleaning. A method of tube cleaning~~  
2240 ~~shall be provided. This may include a provision for obtaining a rapid reduction in clarifier water~~  
2241 ~~surface elevation, a water jet spray system, or an air scour system. Where cleaning is automatic,~~  
2242 ~~controls shall be provided to cease clarifier operation during tube cleaning and a 20-minute rest~~  
2243 ~~period.~~

2244  
2245 ~~(moved to Section 12(j)(ii))(iii) — Tube placement. Tops of tubes shall be more~~  
2246 ~~than 12 inches (0.3 m) from the underside of the launder and more than 18 inches (0.46 m) from~~  
2247 ~~the water surface.~~

2248  
2249 ~~(moved to Section 12(j)(i))(iv) — Loading rates. The maximum overflow rate~~  
2250 ~~shall be less than 2.0 gpm/sq ft (62.7 m<sup>3</sup>/m<sup>2</sup>-d) based on the surface area of the basin covered by~~  
2251 ~~the tubes.~~

2252  
2253 ~~(moved to Section 12(j)(ii))(v) — Effluent launderers. The spacing between~~  
2254 ~~effluent launderers shall not exceed three times the distance from the water surface to the top of~~  
2255 ~~the tube modules.~~

2256  
2257  
2258  
2259  
2260  
2261  
2262  
2263  
2264  
2265  
2266  
2267  
2268  
2269  
2270  
2271  
2272  
2273  
2274  
2275  
2276  
2277  
2278  
2279  
2280  
2281  
2282  
2283  
2284  
2285  
2286  
2287  
2288  
2289  
2290  
2291  
2292  
2293  
2294  
2295  
2296  
2297  
2298  
2299  
2300

~~(moved to Section 12(k))(i)—Filtration.~~

~~(moved to Section 12(k)(i))(i) Pressure granular media filters. Vertical or horizontal pressure filters shall not be used for filtration of surface waters. Pressure filters may be used for groundwater filtration, including iron and manganese removal.~~

~~(ii)—Gravity filters.~~

~~(moved to Section 12(k)(i)(A))(A)—Slow rate sand filters. These types of filters may be used when maximum raw water turbidity is less than 50 TUs and the turbidity present is not attributable to colloidal clay. Maximum color shall not exceed 30 units.~~

~~(I)—Loading rates. The allowable loading rates at maximum daily demands shall not exceed 0.1 gpm/ft<sup>2</sup> (5.9 m<sup>3</sup>/m<sup>2</sup>.d) unless satisfactory pilot testing is completed prior to design which shows a higher rate is appropriate.~~

~~(II)—Number of filters. At least two units shall be provided. Where only two units are provided, each shall be capable of meeting the plant design capacity at the maximum filtration rate. Where more than two filter units are provided, the filters shall be capable of meeting the plant design at the maximum filtration rate with one filter removed from service.~~

~~(III)—Underdrains. Each filter unit shall be equipped with a main drain and an adequate number of lateral underdrains to collect the filtered water. The underdrains shall be so spaced that the maximum velocity of the water flow in the lateral underdrain will not exceed 0.75 feet per second (0.22 m/sec). The maximum spacing of the laterals shall not exceed 12 feet (3.7 m).~~

~~(IV)—Filter material. Filter sand shall be placed on graded gravel layers for a minimum sand depth of 30 inches (0.76 m). The effective size shall be between 0.15 mm and 0.35 mm. The uniformity coefficient shall not exceed 2.0. The sand shall be clean and free from foreign matter. The supporting gravel shall conform to the size and depth distribution provided for rapid rate gravity filters.~~

~~(V)—Depth of water on filter beds. Design shall provide a depth of at least 3 feet (0.91 m) of water over the sand. Influent water shall enter the water surface at a velocity of less than 2 feet per second (0.61 m/sec). An overflow shall be provided at the maximum water surface elevation.~~

~~(VI)—Appurtenances. Each filter shall be equipped with loss of head gauge; an orifice, Venturi meter, or other suitable metering device installed on each filter to control the rate of filtration; and an effluent pipe designed to maintain the water level above the top of the filter sand.~~

2301 ~~(VII) Covers. When covers are provided for temperature or~~  
2302 ~~sunlight control, they shall be designed to allow adequate headroom above the top of the sand~~  
2303 ~~and adequate access ports or manholes.~~

2304  
2305 ~~(B) Rapid rate filters.~~

2306  
2307 ~~(I) Loading rates. The maximum allowable loading rates at~~  
2308 ~~maximum daily demands shall not exceed 3 gpm/ft<sup>2</sup> (177 m<sup>3</sup>/m<sup>2</sup>-d) for single media filters or 5~~  
2309 ~~gpm/ft<sup>2</sup> (295 m<sup>3</sup>/m<sup>2</sup>-d) for dual or mixed media filters. Each filter shall have a rate limiting~~  
2310 ~~device to prevent the filter from exceeding the maximum rate.~~

2311  
2312 ~~(II) Filter compartment design. The filter media compartment~~  
2313 ~~shall be constructed of durable material not subject to corrosion or decay and structurally capable~~  
2314 ~~of supporting the loads to which it will be subjected.~~

2315  
2316 ~~(1.) There shall be an atmospheric break between~~  
2317 ~~filtered and non-filtered water, accomplished by double wall construction.~~

2318  
2319 ~~(2.) The compartment walls shall be vertical and shall~~  
2320 ~~not protrude into the filter media.~~

2321  
2322 ~~(3.) There shall be a minimum of 2½ feet (0.76 m) of~~  
2323 ~~headroom above the top of the filter compartment walls.~~

2324  
2325 ~~(4.) Neither floor nor roof drainage shall enter the filter.~~  
2326 ~~If the top of the filter compartment is at floor level, a minimum 4 inch curb shall be constructed~~  
2327 ~~around the box.~~

2328  
2329 ~~(5.) Walkways or observation platforms shall be~~  
2330 ~~provided for each filter compartment. Walk ways around the filter shall be a minimum of 24~~  
2331 ~~inches wide.~~

2332  
2333 ~~(6.) Effluent line shall be trapped or submerged below~~  
2334 ~~the low water level in the clearwell to prevent air from entering the filter bottom. The velocity in~~  
2335 ~~the filter influent line shall not exceed 4 feet per second (1.2 m/sec). An overflow from the~~  
2336 ~~influent of the filter compartment shall be provided.~~

2337  
2338 ~~(7.) The distance between the operating water level in~~  
2339 ~~the filter and the high water level in the clearwell or effluent trap shall be 10 feet (3.05 m)~~  
2340 ~~minimum. The minimum operating water level over the media shall be 3 feet (0.91 m), and the~~  
2341 ~~minimum depth of the filter box shall be 8 1/2 feet (2.6 m).~~

2342  
2343 ~~(III) Washwater troughs. (moved to Section 12(k)(ii)(A)) Washwater~~  
2344 ~~troughs shall be constructed to provide for not more than 6 feet (1.8 m) clear distance between~~  
2345 ~~troughs. The troughs shall not cover more than 25 percent of filter area.~~

2346



2347 ~~(moved to Section 12(k)(ii)(B))(1.)—Minimum clearance~~  
2348 ~~between the bottom of trough and top of unexpanded media shall be 12 inches (30.5 cm).~~

2349  
2350 ~~(moved to Section 12(k)(ii)(C))(2.)—Minimum distance~~  
2351 ~~between the weir of the trough and the unexpanded media shall be 30 inches (0.76 m).~~

2352  
2353 ~~(moved to Section 12(k)(ii)(E))(3.)—The trough and~~  
2354 ~~washwater waste line shall be sized to carry a filter backwash rate of 20 gpm/ft<sup>2</sup> (1181 m<sup>3</sup>/m<sup>2</sup>-d)~~  
2355 ~~plus a surface wash rate of 2.0 gpm/ft<sup>2</sup> (118 m<sup>3</sup>/m<sup>2</sup>-d).~~

2356  
2357 ~~(IV)—Backwash system.~~

2358  
2359 ~~(moved to Section 12(k)(ii)(F))(1.)—The backwash system shall~~  
2360 ~~be sized to provide a minimum backwash flow rate of 20 gpm/ft<sup>2</sup> (1181 m<sup>3</sup>/m<sup>2</sup>-d). Washwater~~  
2361 ~~storage shall be designed to provide two 20 minute washes in rapid succession. Where multiple~~  
2362 ~~units are not required and only one filter compartment is present, backwash storage capabilities~~  
2363 ~~may be reduced to provide one 20 minute backwash. Where pumps are used to provide backwash~~  
2364 ~~to the filter or to supply water to a washwater tank, the washwater pumps shall be in duplicate.~~

2365  
2366 ~~(moved to Section 12(k)(ii)(H))(2.)—The backwash and~~  
2367 ~~surface wash washwater supply shall be filtered and disinfected.~~

2368  
2369 ~~(moved to Section 12(k)(ii)(I))(3.)—Washwater rate shall~~  
2370 ~~be controlled by a separate valve, manual or automatic, on the main washwater line. Washwater~~  
2371 ~~flow rates shall be metered and indicated.~~

2372  
2373 ~~(moved to Section 12(k)(ii)(J))(4.)—Air assisted backwash~~  
2374 ~~systems may be used when the design precludes disturbing the gravel support.~~

2375  
2376 ~~(moved to Section 12(k)(ii)(K))(5.)—A surface wash~~  
2377 ~~system shall be provided. The system shall be capable of supplying 0.5 gpm/ft<sup>2</sup> (29.5 m<sup>3</sup>/m<sup>2</sup>-d)~~  
2378 ~~for system with rotating arms and 2.0 gpm/ft<sup>2</sup> (118 m<sup>3</sup>/m<sup>2</sup>-d) with fixed nozzles, at a minimum~~  
2379 ~~pressure of 50 psi (344 kPa). The surface wash shall use filtered and disinfected water or air and~~  
2380 ~~filtered disinfected water. The supply system shall be provided with adequate backflow~~  
2381 ~~prevention.~~

2382  
2383 ~~(V)—Filter materials. For rapid rate filters, coarse to fine beds of~~  
2384 ~~mixed or dual media or fine to coarse single media beds may be used.~~

2385  
2386 ~~1.—Types of filter media:~~

2387 ~~a.—Anthracite. Clean crushed anthracite, or a~~  
2388 ~~combination of anthracite and other media shall have an effective size of 0.45 mm–0.55 mm~~  
2389 ~~with uniformity coefficient not greater than 1.65 when used alone, or an effective size of 0.8 mm~~  
2390 ~~–1.2 mm with a uniformity coefficient not greater than 1.65 when used as a cap. The anthracite~~  
2391 ~~shall meet the requirements of AWWA B100.~~

2393  
2394  
2395  
2396  
2397  
2398  
2399  
2400  
2401  
2402  
2403  
2404  
2405  
2406  
2407  
2408  
2409  
2410  
2411  
2412  
2413  
2414  
2415  
2416  
2417  
2418  
2419  
2420  
2421  
2422  
2423  
2424  
2425  
2426  
2427  
2428  
2429  
2430  
2431  
2432  
2433  
2434  
2435  
2436  
2437  
2438

~~b.——Sand. Sand shall have an effective size of 0.45 mm to 0.55 mm, a uniformity coefficient of not greater than 1.65, and shall meet the requirements of AWWA B100.~~

~~(c.)——Granular activated carbon (GAC). Granular activated carbon media may be used in place of anthracite. There must be means for periodic treatment of granular activated carbon filter material for control of bacterial and other growths. Provisions must be made for replacement or regeneration if GAC is used for filtration.~~

~~(d.)——Torpedo sand or garnet. A layer of torpedo sand or garnet shall be used as a supporting media for filter sand.~~

~~2.——Sand for single media beds. The media shall be clean silica sand having a depth of not less than 24 inches (0.61 m), an effective size of from 0.45 mm to 0.55 mm, and a uniformity coefficient not greater than 1.65. A 3 inch (7.6 cm) layer of torpedo sand or other high density material shall be used as a supporting media for the filter sand. The material shall have an effective size of 0.8 mm to 2.0 mm, and a uniformity coefficient not greater than 1.7.~~

~~(moved to Section 12(k)(iii)) 3.——Anthracite for single media beds. Clean crushed anthracite or a combination of sand and anthracite may be used. Such media shall have an effective size from 0.45 mm to 0.55 mm, and a uniformity coefficient not greater than 1.65.~~

~~(moved to Section 12(k)(iii)(A)) 4.Gravel. When used as a supporting media, gravel shall consist of coarse aggregate in which a high proportion of the particles are rounded and tend toward a generally spherical or equidimensional shape. (moved to It shall possess sufficient strength and hardness to resist degradation during handling and use, be substantially free of harmful materials, and exceed the minimum density requirement. The gravel shall meet the requirements of AWWA B100.~~

~~(moved to Section 12(k)(ix)) 5.Multi-media. Filter beds of this type shall contain a depth of fine media made up of anthracite coal, specific gravity 1.5; silica sand, specific gravity 2.6; and garnet sand or ilemite, specific gravity 4.2—4.5.~~

~~(moved to Section 12(k)(ix)(A)) a.——Bed depths and distribution of the media shall be determined by the water quality, but shall not be less than 10 inches (0.25 m) of fine sand and 24 inches (0.61 m) of coal. The relative size of the particles shall be such that hydraulic grading of the material during backwash will result in a filter bed with pore space graded progressively from coarse to fine in the direction of filtration (down).~~

~~(moved to Section 12(k)(ix)(B)) b.——The multi-media shall be supported on two layers of special high density gravel placed above the~~

2439 ~~conventional silica gravel supporting bed. The special gravel shall have a specific gravity not~~  
2440 ~~less than 4.2. The bottom layer shall consist of particles passing No. 5 and retained on No. 12~~  
2441 ~~U.S. mesh sieves and shall be 1-1/2 inches (3.8 cm) thick. The top layer shall consist of particles~~  
2442 ~~passing No. 12 and retained on No. 20 U.S. mesh sieves, and shall be 1-1/2 inches (3.8 cm)~~  
2443 ~~thick.~~

2444  
2445 ~~(moved to Section 12(i)(iv)) 6. — Dual media. Coal sand filters~~  
2446 ~~shall consist of a coarse coal layer above a layer of fine sand. The media shall consist of not less~~  
2447 ~~than 8 inches (20 cm) of sand and 15 inches (0.38 m) of coal on a torpedo sand or garnet layer~~  
2448 ~~support of not less than 3 inches (7.8 cm) on the gravel support.~~

2449  
2450 ~~(moved to Section 12(k)(v))(VI) — Filter bottoms. Acceptable~~  
2451 ~~filter bottoms and strainer systems shall be limited to pipe, perforated pipe laterals, tile block and~~  
2452 ~~perforated tile block. Perforated plate bottoms or plastic nozzles shall not be used.~~

2453  
2454 ~~(moved to Section 12(k)(vi))(VII) — Appurtenances. Every filter~~  
2455 ~~shall have influent and effluent sampling taps; indicating loss of head gauge; indicating effluent~~  
2456 ~~turbidimeter; a waste drain for draining the filter compartment to waste; and a filter rate flow~~  
2457 ~~meter. Every filter shall provide polymer feed facilities including polymer mixing and storage~~  
2458 ~~tank and at least one feed pump for each filter compartment. On plants having a capacity in~~  
2459 ~~excess of 0.5 MGD, recorders shall be provided on the turbidimeters.~~

2460  
2461 ~~(moved to Section 12(k)(vii))(VIII) Filter rate control. Filter rate~~  
2462 ~~control shall be such that the filter is not surged. Filter rate of flow shall not change at a rate~~  
2463 ~~greater than 0.3 gpm/ft<sup>2</sup> (17.7 m<sup>3</sup>/m<sup>2</sup>-d) per minute. Filters that stop and restart during a cycle~~  
2464 ~~shall have a filter to waste system installed. Declining flow rate filters shall not be used unless~~  
2465 ~~the flow rate for each filter is controlled to rates less than allowed in 10 (i)(ii)(B) and there are~~  
2466 ~~four or more individual filters.~~

2467  
2468 ~~(moved to Section 12(k)(viii))(IX) — A filter to waste cycle shall~~  
2469 ~~be provided after the filter backwash operation. The filter to waste cycle shall be at least 10~~  
2470 ~~minutes.~~

2471  
2472 ~~(moved to Section 12(k)(x))(j) — Diatomaceous earth filtration. These types~~  
2473 ~~of filters may be used as the filtration process to remove turbidity from surface waters where~~  
2474 ~~turbidities entering the filters do not exceed 25 TU and where total raw water coliforms do not~~  
2475 ~~exceed 100 organisms/100 ml. These filters may be used where the raw water quality exceeds the~~  
2476 ~~above limits when flocculation and sedimentation are used preceding the filters. Diatomaceous~~  
2477 ~~earth filters may also be used for removal of iron from groundwaters.~~

2478  
2479 ~~(moved to Section 12(k)(x)(B))(i) — Types of filters. Pressure or vacuum~~  
2480 ~~diatomaceous earth filtration units will be considered for approval.~~

2481  
2482 ~~(moved to Section 12(k)(ix)(C))(ii) — Precoat. A precoating system shall be~~  
2483 ~~provided.~~

2484

2485 (A) ~~—A uniform precoat shall be applied hydraulically to each septum by~~  
2486 ~~introducing a precoat slurry to the filter influent line and employing a filter to waste or~~  
2487 ~~recirculation system.~~

2488  
2489 (B) ~~—Feed capabilities. Diatomaceous earth in the amount of 0.20 lb/ft<sup>2</sup>~~  
2490 ~~(1 Kg/m<sup>2</sup>) minimum of filter area shall be used with recirculation. When precoating is~~  
2491 ~~accomplished with a filter to waste system, 0.3 lbs/ft<sup>2</sup> (1.5 Kg/m<sup>2</sup>) minimum shall be provided.~~

2492  
2493 (iii) ~~—Body feed. A body feed system to apply diatomaceous earth slurry~~  
2494 ~~continuously during the filter run shall be provided. Continuous mixing of the body feed slurry~~  
2495 ~~tank during the filter cycle shall be provided.~~

2496  
2497 (iv) ~~—Filtration.~~

2498  
2499 (A) ~~—Rate of filtration. The maximum rate of filtration shall not exceed~~  
2500 ~~1.5 gpm/ft<sup>2</sup> (88.6 m<sup>3</sup>/m<sup>2</sup>-d) of septum area. The filtration rate shall be controlled by a positive~~  
2501 ~~means.~~

2502  
2503 (B) ~~—Head loss. The head loss shall not exceed 30 psi (206 kPa) for~~  
2504 ~~pressure diatomaceous earth filters, or a vacuum of 15 inches of mercury (50.8 kPa) for vacuum~~  
2505 ~~system.~~

2506  
2507 (C) ~~—Recirculation. A recirculation or holding pump shall be provided to~~  
2508 ~~maintain differential pressure across the filter when the unit is not in operation in order to~~  
2509 ~~prevent the filter cake from dropping off the filter elements. A minimum recirculation rate of 0.1~~  
2510 ~~gallons per minute per square foot (5.9 m<sup>3</sup>/m<sup>2</sup>-d) of filter area shall be provided. The filter~~  
2511 ~~control system shall prevent automatic restart after power failure.~~

2512  
2513 (D) ~~—Septum or filter element. The filter elements shall be structurally~~  
2514 ~~capable of withstanding maximum pressure and velocity variations during filtration and cleaning~~  
2515 ~~cycles, and shall be spaced so that not less than 2 inches (5.1 cm) are provided between elements~~  
2516 ~~or between any element and a wall.~~

2517  
2518 (E) ~~—Inlet design. The filter influent shall be designed to prevent scour~~  
2519 ~~of the diatomaceous earth from the filter element.~~

2520  
2521 (v) ~~—Appurtenances. Every filter shall provide sampling taps for raw and~~  
2522 ~~filtered water; loss of head or differential pressure gauge; rate of flow indicator, with totalizer;~~  
2523 ~~and a throttling valve used to reduce rates during adverse raw water conditions.~~

2524  
2525 (vi) ~~—Monitoring. A continuous monitoring turbidimeter is required on the filter~~  
2526 ~~effluent from each filter unit for plants treating surface water.~~

2527  
2528 (moved to Section 12(1))(k) ~~—Disinfection. Chlorine, chlorine dioxide, ozone or other~~  
2529 ~~disinfectant as approved by the administrator may be used for disinfection. Where the primary~~  
2530 ~~disinfectant is ozone, chlorination equipment shall be provided to enable maintaining a residual~~

2531 ~~disinfectant throughout the distribution system. Automatic proportioning of disinfectant feed to~~  
2532 ~~flow rate is required where the plant flow control is automatic.~~

2533  
2534 ~~(moved to Section 12(1)(i))(i) Chlorination equipment.~~

2535  
2536 ~~(moved to Section 12(1)(i)(A)(A) Type. Solution feed gas chlorinators~~  
2537 ~~or hypochlorite feeders of the positive displacement type shall be provided.~~

2538  
2539 ~~(B) Capacity. The chlorinator capacity shall be such that a minimum 5~~  
2540 ~~mg/L disinfection dose can be added on the maximum day. The equipment shall be of such~~  
2541 ~~design that it will operate accurately over the desired feeding range.~~

2542  
2543 ~~(moved to Section 12(1)(i)(E))(C) Standby equipment. Standby~~  
2544 ~~equipment of sufficient capacity shall be available to replace the largest chlorinator unit, except~~  
2545 ~~for a well water system providing no treatment other than disinfection.~~

2546  
2547 ~~(D) Automatic switchover. Automatic switch-over of chlorine~~  
2548 ~~cylinders shall be provided.~~

2549  
2550 ~~(moved to Section 12(1)(i)(B))(E) Diffuser. The chlorine solution~~  
2551 ~~injection/diffuser shall provide a rapid and thorough mix with all the water being treated. If the~~  
2552 ~~application point is to a pipeline discharging to a clearwell, the chlorine shall be added to the~~  
2553 ~~center of the pipe at least 10 pipe diameters upstream of the discharge into the clearwell.~~

2554  
2555 ~~(moved to Section 12(1)(i)(D)(I))(F) Injector/Eductor. For gas feed~~  
2556 ~~chlorinators, the injector/eductor shall be selected based on solution water pressure, injector~~  
2557 ~~waterflow rate, feed point backpressure, and chlorine solution line length and size. The~~  
2558 ~~maximum feed point backpressure shall not exceed 110 psi (759 kPa). Where backpressure~~  
2559 ~~exceeds 110 psi (750 kPa), a chlorine solution pump shall be used. Gauges shall be provided for~~  
2560 ~~chlorine solution pressure, feed water pressure and chlorine gas pressure, or vacuum.~~

2561  
2562 ~~(moved to Section 12(1)(ii))(ii) Points of application and contact time.~~

2563  
2564 ~~(A) At plants treating surface water, provisions shall be made for~~  
2565 ~~applying disinfectant to the raw water, filter influent, and filtered water.~~

2566  
2567 ~~(B) For plants treating groundwater, provisions shall be made for~~  
2568 ~~applying disinfectant to a point in the finished water supply line prior to any commercial,~~  
2569 ~~industrial, or municipal user. Agricultural users may remove water from the supply line prior to~~  
2570 ~~disinfectant application point.~~

2571  
2572 ~~(C) Where free chlorine residual is provided, 1/2 hour contact time~~  
2573 ~~shall be provided for groundwaters and 2 hours for surface waters. Where combined residual~~  
2574 ~~chlorination is provided, 2 hours contact time for groundwater and 3 hours contact for surface~~  
2575 ~~water shall be provided.~~

2576

2577 ~~(D)——When chlorine is applied to a groundwater source for the purpose~~  
2578 ~~of maintaining a residual, no contact time is required.~~

2579  
2580 ~~(iii)——Testing equipment. Chlorine residual test equipment recognized in the~~  
2581 ~~15th Edition of Standard Methods for the Examination of Water and Wastewater shall be~~  
2582 ~~provided and shall be capable of measuring residuals to the nearest 0.1 mg/L in the range below~~  
2583 ~~0.5 mg/L, to the nearest 0.3 mg/L between 0.5 mg/L and 1.0 mg/L and to the nearest 0.5 mg/L~~  
2584 ~~between 1.0 mg/L and 2.0 mg/L.~~

2585  
2586 ~~(iv)——Chlorinator piping.~~

2587  
2588 ~~(A)——Cross-connection protection. The chlorinator water supply piping~~  
2589 ~~shall be designed to prevent contamination of the treated water supply. At all facilities treating~~  
2590 ~~surface water, pre- and post-chlorination systems shall be independent to prevent possible~~  
2591 ~~siphoning of partially treated water into the clearwell. The water supply to each eductor shall~~  
2592 ~~have a separate shutoff valve. No master shutoff will be allowed. Chlorine solution feed water~~  
2593 ~~shall be finished water.~~

2594  
2595 ~~(B)——Pipe material. The pipes carrying liquid or gaseous chlorine shall~~  
2596 ~~be Schedule 80 black steel pipe with forged steel fittings. Bushings shall not be used. Vacuum~~  
2597 ~~piping for gaseous chlorine may be polyethylene tubing. Gas piping between the chlorine~~  
2598 ~~pressure reducing valve of the chlorinator and the ejector shall be PVC or polyethylene. Piping~~  
2599 ~~for aqueous solutions of chlorine beyond the ejector shall be PVC, fiberglass or steel pipe lined~~  
2600 ~~with PVC or saran.~~

2601  
2602 ~~(v)——Maximum withdrawal. The maximum withdrawal rate of gaseous chlorine~~  
2603 ~~shall be limited to 40 lbs/day (18.1 kg/day) for 100 or 150 lb (45.4 or 68.0 kg) cylinders and 400~~  
2604 ~~lbs/day (181 kg/day) for 2,000 lb (907 kg) cylinders, unless chlorine evaporators are employed.~~

2605  
2606 ~~(vi)——Ozonation equipment.~~

2607  
2608 ~~(A)——Capacity. The ozonator capacity shall be such that an applied dose~~  
2609 ~~of at least 10 mg/L can be attained at the maximum daily flows. The equipment shall be of such~~  
2610 ~~design that it will operate 5 percent over the desired feeding range.~~

2611  
2612 ~~(B)——Piping. Injection equipment and piping in contact with ozonated air~~  
2613 ~~and air-water emulsions shall be of stainless steel, teflon or other material resistant to ozone.~~  
2614 ~~Valves carrying ozonized air shall be made of metal coated with ozone-resistant materials.~~

2615  
2616 ~~(C)——Application. Ozone may be applied to the water directly as a gas or~~  
2617 ~~by an injector system similar to a chlorine injector system. In gas applications, depth of~~  
2618 ~~submergence of the diffusers shall be a minimum of 10 feet (3.05 m). Diffusion shall be fine~~  
2619 ~~bubble or mixed.~~

2620  
2621 ~~(D)——Contact time and point of application. Ozone shall be applied at a~~  
2622 ~~point which will provide contact time not less than 30 minutes. At plants treating surface water,~~

2623 ~~provisions should be made for applying a disinfectant to the raw water, filter influent, filtered~~  
2624 ~~water and final contact basin. At plants treating groundwater, provisions should be made for~~  
2625 ~~applying ozone to the clear well inlet.~~

2626  
2627 ~~(E)——Testing equipment. Testing equipment shall enable measurement~~  
2628 ~~of residuals to the nearest 0.1 mg/L in the range below 0.5 mg/L and to the nearest 0.2 mg/L~~  
2629 ~~above 0.5 mg/L.~~

2630  
2631 ~~(F)——Ozone destruct. An ozone destruct device shall be provided to~~  
2632 ~~destruct all ozone contractor off gases.~~

2633  
2634 ~~(G)——The use of ozone for disinfection will be allowed only if a chlorine~~  
2635 ~~or combined chlorine residual is provided in the distribution system.~~

2636  
2637 ~~(I)——Softening.~~

2638  
2639 ~~(i)——Lime or lime soda process. Design standards for rapid mix, flocculation~~  
2640 ~~and sedimentation are the same as for conventional treatment previously outlined. Lime or lime~~  
2641 ~~soda softened effluent shall be filtered.~~

2642  
2643 ~~(A)——Hydraulics. When split treatment is used, the bypass line shall be~~  
2644 ~~sized to carry total plant flow, and a means of measuring and splitting the flow shall be provided.~~

2645  
2646 ~~(B)——Chemical feed point. Lime and recycled sludge shall be fed~~  
2647 ~~directly into the rapid mix basin.~~

2648  
2649 ~~(C)——Stabilization. Provisions shall be made to chemically stabilize~~  
2650 ~~waters softened by the lime or lime soda process.~~

2651  
2652 ~~(D)——Sludge collection. Mechanical sludge removal equipment shall be~~  
2653 ~~provided in the sedimentation basin. Sludge recycling to the rapid mix shall be provided.~~

2654  
2655 ~~(E)——Disinfection. The use of excess lime shall not be considered a~~  
2656 ~~substitute for disinfection. Disinfection, as previously outlined, shall be provided.~~

2657  
2658 ~~(ii)——Cation exchange process.~~

2659  
2660 ~~(A)——Pretreatment requirements. Pretreatment is required when the~~  
2661 ~~content of iron, manganese, or a combination of the two, is 1 mg/L or more. Water with 5 units~~  
2662 ~~or more turbidity shall not be applied directly to the cation exchange softener.~~

2663  
2664 ~~(B)——Design. The units may be of pressure or gravity type, of either an~~  
2665 ~~upflow or downflow design. Automatic regeneration based on volume of water softened shall be~~  
2666 ~~used. A manual override shall be provided on all automatic controls.~~

2667

2668 ~~(C) Exchange capacity. The design capacity for hardness removal shall~~  
2669 ~~not exceed 20,000 grains per cubic foot (45,880 g/L) when resin is regenerated with 0.3 pounds~~  
2670 ~~(.14 kg) of salt per kilograin (2.29 g/L) of hardness removed.~~

2671  
2672 ~~(D) Depth of resin. The depth of the exchange resin shall not be less~~  
2673 ~~than 2 feet (0.6 m).~~

2674  
2675 ~~(E) Flow rates. The flow applied to the softening unit shall not~~  
2676 ~~exceed 7 gpm/ft<sup>2</sup> (413 m<sup>3</sup>/m<sup>2</sup>-d) of bed area. The minimum backwash rate shall be 6 gpm/ft<sup>2</sup>~~  
2677 ~~(354 m<sup>3</sup>/m<sup>2</sup>-d) of bed area or shall provide a minimum of 150 percent bed expansion at winter~~  
2678 ~~water temperatures. A positive means of controlling flow must be present.~~

2679  
2680 ~~(F) Underdrains and supporting gravel. The bottoms, strainer systems~~  
2681 ~~and support for the exchange resin shall conform to criteria provided for rapid rate gravity filters.~~

2682  
2683 ~~(G) Brine distribution. Facilities shall be included for even distribution~~  
2684 ~~of the brine over the entire surface of both upflow and downflow units.~~

2685  
2686 ~~(H) Cross-connection control. Backwash, rinse and air relief discharge~~  
2687 ~~pipes shall be installed in such a manner as to prevent any possibility of back siphonage.~~

2688  
2689 ~~(I) Bypass piping and equipment. A by-pass shall be provided around~~  
2690 ~~softening units to produce a blended water of desirable hardness. Totalizing meters must be~~  
2691 ~~installed on the bypass line and on each softener unit. An automatic proportioning or regulating~~  
2692 ~~device and shutoff valve shall be provided on the bypass line.~~

2693  
2694 ~~(J) Additional limitations.~~

2695  
2696 ~~(I) Silica gel resins shall not be used for waters having a pH~~  
2697 ~~above 8.4 or containing less than 6 mg/L silica and shall not be used when iron is present.~~

2698  
2699 ~~(II) When the applied water contains a chlorine residual, the~~  
2700 ~~cation-exchange resin shall be a type that is not damaged by residual chlorine.~~

2701  
2702 ~~(III) Phenolic resin shall not be used.~~

2703  
2704 ~~(K) Brine and salt storage tanks.~~

2705  
2706 ~~(I) Salt dissolving or brine tanks and wet salt storage tanks~~  
2707 ~~shall be covered and constructed of corrosion-resistant materials.~~

2708  
2709 ~~(II) The makeup water inlet shall be protected from back~~  
2710 ~~siphonage. Water for filling the tank shall be distributed over the entire surface by pipes above~~  
2711 ~~the maximum brine level in the tank. The tanks shall be provided with an automatic declining~~  
2712 ~~level control system on the makeup water line.~~

2713



2714 ~~(III) — Wet salt storage basins shall be equipped with manholes or~~  
2715 ~~hatchways for access and for direct dumping of salt from truck or railcar. Openings shall be~~  
2716 ~~provided with raised curbs and watertight covers having overlapping edges similar to those~~  
2717 ~~required for finished water reservoirs.~~

2718  
2719 ~~(IV) — Overflows, if provided, must be turned down, have a proper~~  
2720 ~~free fall discharge and be protected with corrosion resistant screens or self closing flap valves.~~

2721  
2722 ~~(V) — Two wet salt storage tanks or compartments designed to~~  
2723 ~~operate independently shall be provided.~~

2724  
2725 ~~(VI) — The salt shall be supported on graduated layers of gravel~~  
2726 ~~under which is a suitable means of collecting the brine.~~

2727  
2728 ~~(L) — Salt and brine storage capacity. Total salt storage capacity shall~~  
2729 ~~provide for at least 30 days of operation.~~

2730  
2731 ~~(M) — Brine pump or eductor. An eductor may be used to transfer brine~~  
2732 ~~from the brine tank to the softeners. If a pump is used, a brine measuring tank or means of~~  
2733 ~~metering shall be provided to obtain proper dilution.~~

2734  
2735 ~~(N) — Stabilization. Facilities for stabilizing corrosion control shall be~~  
2736 ~~provided.~~

2737  
2738 ~~(O) — Construction materials. Pipes and contact materials shall be~~  
2739 ~~resistant to the aggressiveness of salt. Plastic and red brass are acceptable piping materials. Steel~~  
2740 ~~and concrete shall be coated with a non leaching protective coating which is compatible with salt~~  
2741 ~~and brine.~~

2742  
2743 ~~(P) — Housing. Bagged salt and dry bulk salt storage shall be enclosed~~  
2744 ~~and separated from other operating areas in order to prevent damage to equipment.~~

2745  
2746 ~~(m) — Aeration. Aeration may be used to help remove tastes and odors due to dissolved~~  
2747 ~~gases from decomposing organic matter; to reduce or remove objectionable amounts of carbon~~  
2748 ~~dioxide, hydrogen sulfide, etc.; to introduce oxygen to assist in iron and/or manganese removal;~~  
2749 ~~and to strip volatile organic compounds for controlling the formation of trihalomethanes by~~  
2750 ~~removing the trihalomethane precursors.~~

2751  
2752 ~~(i) — Natural draft aeration — tray type. The design shall provide perforations in~~  
2753 ~~the distribution pan to provide uniform distribution of water over the top tray. The discharge~~  
2754 ~~shall be through a series of three or more trays. Tray material shall be resistant to aggressiveness~~  
2755 ~~of the water and dissolved gases. The loading rate shall not exceed five gpm/ft<sup>2</sup> (203 L/m<sup>2</sup>) of~~  
2756 ~~total tray area.~~

2757  
2758 ~~(ii) — Forced or induced draft aeration. Devices shall:~~  
2759

2760                               (A) ~~—Be constructed and located so that air introduced into the column~~  
2761 ~~shall be free from obnoxious fumes, dust, and dirt. All sections of the aerator shall be easily~~  
2762 ~~reached or removed for maintenance.~~

2763  
2764                               (B) ~~—Provide distribution of water uniformly over the top tray and~~  
2765 ~~discharge through a series of five or more trays.~~

2766  
2767                               (C) ~~—Be constructed so that the water outlet is adequately sealed to~~  
2768 ~~prevent unwarranted loss of air. Material shall be resistant to the aggressiveness of the water and~~  
2769 ~~dissolved gases. Loading shall be provided at a rate not to exceed five gpm/ft<sup>2</sup> (203 L/m<sup>2</sup>) of~~  
2770 ~~total tray area.~~

2771  
2772                               (iii) ~~—Pressure aeration. Pressure aeration may be used for oxidation purposes~~  
2773 ~~only; it is not acceptable for removing dissolved gases.~~

2774  
2775                               (iv) ~~—Protection of aerators. All aerators except those discharging to lime~~  
2776 ~~softening or clarification plants shall be protected from contamination by birds and insects by~~  
2777 ~~using louvers and 24 mesh screen.~~

2778  
2779                               (v) ~~—Disinfection. Disinfection must be provided as a final treatment to all~~  
2780 ~~waters receiving aeration treatment.~~

2781  
2782                               (vi) ~~—Bypass. A bypass shall be provided around all aeration units.~~

2783  
2784                               (vii) ~~—Volatile organics removal. Volatile organic compounds may be stripped~~  
2785 ~~by packed tower or diffused aeration methods.~~

2786  
2787                               (n) ~~—Iron and manganese control. Iron and manganese control, as used here, refers~~  
2788 ~~solely to treatment processes designed specifically for this purpose.~~

2789  
2790                               (i) ~~—Removal by oxidation, detention, and filtration.~~

2791  
2792                               (A) ~~—Oxidation. Oxidation may be accomplished by aeration or by~~  
2793 ~~chemical oxidation using chlorine, potassium permanganate, ozone, hydrogen peroxide, or~~  
2794 ~~chlorine dioxide.~~

2795  
2796                               (B) ~~—Detention following aeration. A minimum detention time of 20~~  
2797 ~~minutes shall be provided following aeration. The detention basin shall be designed as a holding~~  
2798 ~~tank with sufficient baffling to prevent short-circuiting. Sedimentation basins shall be provided~~  
2799 ~~when treating water with iron and/or manganese above 2 mg/L, or where chemical coagulation is~~  
2800 ~~used to reduce the load on the filters. Provisions for sludge removal shall be made.~~

2801  
2802                               (C) ~~—Filtration. Gravity or pressure filters shall be provided. Where~~  
2803 ~~pressure filters are used, the following criteria supplements that found in Section 10(i).~~

2804

2805 ~~(I) Rate of filtration. The rate shall not exceed 3 gpm/ft<sup>2</sup> (176~~  
2806 ~~m<sup>3</sup>/m<sup>2</sup>-d) of filter area.~~

2807  
2808 ~~(H) Design criteria. The filters shall have a minimum side wall~~  
2809 ~~shell height of 5 feet, and an air release valve on the highest point of each filter. Each filter shall~~  
2810 ~~have a means to observe the wastewater during backwashing and also a manhole to facilitate~~  
2811 ~~inspection and repairs.~~

2812  
2813 ~~(ii) Removal by the lime-soda softening process. These processes shall~~  
2814 ~~conform to the lime-soda process in Section 10(i).~~

2815  
2816 ~~(iii) Removal by manganese greensand filtration. Provide feed capability of~~  
2817 ~~potassium permanganate to the influent of a manganese greensand filter.~~

2818  
2819 ~~(A) An anthracite media cap of at least 6 inches (0.15 m) shall be~~  
2820 ~~provided over manganese green sand.~~

2821  
2822 ~~(B) The filtration rate shall not exceed 4 gpm/ft<sup>2</sup> (236 m<sup>3</sup>/m<sup>2</sup>-d).~~

2823  
2824 ~~(C) Provide a minimum backwash capability of 12 gpm/ft<sup>2</sup> (708~~  
2825 ~~m<sup>3</sup>/m<sup>2</sup>-d), with a rate control device.~~

2826  
2827 ~~(D) Air washing or surface washing is required.~~

2828  
2829 ~~(iv) Removal by ion exchange. This process of iron and manganese removal~~  
2830 ~~shall not be used for water containing more than 0.3 mg/L of iron, manganese or combination of~~  
2831 ~~the two. This process is not acceptable where either the raw water or washwater contains~~  
2832 ~~dissolved oxygen.~~

2833  
2834 ~~(v) Sequestration by polyphosphates. This process shall not be used when~~  
2835 ~~iron, manganese or a combination of the two as exceeds 1.0 mg/L. The total phosphate applied~~  
2836 ~~shall not exceed 10 mg/L as PO<sub>4</sub>. Where phosphate treatment is used, facilities shall be provided~~  
2837 ~~for maintaining a 0.5 mg/L free or combined chlorine residual at remote points in the distribution~~  
2838 ~~system.~~

2839  
2840 ~~(A) The stock phosphate solution tank shall be covered. Facilities shall~~  
2841 ~~be provided for disinfecting the solution tank. The facilities shall be capable of providing a~~  
2842 ~~minimum of 10 mg/L free chlorine residual.~~

2843  
2844 ~~(B) Polyphosphates shall not be applied ahead of iron and manganese~~  
2845 ~~removal treatment. The point of application shall be prior to any aeration, oxidation or~~  
2846 ~~disinfection if no iron or manganese removal treatment is provided.~~

2847  
2848 ~~(vi) Sequestration by sodium silicates. Sodium silicate sequestration of iron~~  
2849 ~~and manganese shall be used for groundwater supplies prior to air contact. Rapid oxidation of the~~  
2850 ~~metal ions by chlorine, chlorine dioxide, ozone, hydrogen peroxide, or other strong oxidant must~~

2851 ~~accompany or closely precede the sodium silicate addition. Injection of sodium silicate shall not~~  
2852 ~~occur at a point more than 15 seconds after oxidation feed point. Feed and dilution equipment~~  
2853 ~~shall be sized on the basis of feed solutions stronger than 5 percent silica as SiO<sub>2</sub>. Sodium silicate~~  
2854 ~~addition may be used only on water containing up to 2 mg/L of iron, manganese or a~~  
2855 ~~combination of the two. Sodium silicate addition shall not be used on waters where 20 mg/L or~~  
2856 ~~more SiO<sub>2</sub> is required or where the amount of added and naturally occurring silicate will exceed~~  
2857 ~~60 mg/L as SiO<sub>2</sub>.~~

2858  
2859 ~~(A) Facilities shall be provided for maintaining a chlorine residual of~~  
2860 ~~0.5 mg/L throughout the distribution system.~~

2861  
2862 ~~(B) Sodium silicate shall not be applied ahead of iron or manganese~~  
2863 ~~removal treatment.~~

2864  
2865 ~~(vii) Testing equipment. Testing equipment shall be provided for all iron and~~  
2866 ~~manganese control plants.~~

2867  
2868 ~~(A) The equipment should have the capacity to measure the iron~~  
2869 ~~content to a minimum of 0.1 mg/L and the manganese content to a minimum of 0.05 mg/L.~~

2870  
2871 ~~(B) Where polyphosphate sequestration is practiced, phosphate testing~~  
2872 ~~equipment shall be provided.~~

2873  
2874 ~~(moved to Section 12(n))(o) Fluoridation and defluoridation.~~

2875  
2876 ~~(moved to Section 12(n)(i))(i) Fluoride compound storage. Storage tanks shall be~~  
2877 ~~covered; all storage shall be inside a building. Storage tanks for hydrofluosilic acid shall be~~  
2878 ~~vented to the atmosphere at a point outside the building.~~

2879  
2880 ~~(moved to Section 12(n)(ii))(ii) Chemical feed equipment. Fluoride feed~~  
2881 ~~equipment shall meet the following requirements.~~

2882  
2883 ~~(moved to Section 12(n)(ii)(A))(A) Scales or loss of weight recorders~~  
2884 ~~shall be provided for dry chemical feeds. Feeders shall be accurate to within five percent of any~~  
2885 ~~desired feed rate.~~

2886  
2887 ~~(moved to Section 12(n)(ii)(B))(B) The point of application of~~  
2888 ~~hydrofluosilic acid, if into a horizontal pipe, shall be in the lower half of the pipe. Fluoride~~  
2889 ~~compound shall not be added before lime soda softening or ion exchange softening.~~

2890  
2891 ~~(moved to Section 12(n)(ii)(D))(C) A fluoride solution shall be applied~~  
2892 ~~by a positive displacement pump having a stroke rate not less than 20 nor more than 95 strokes~~  
2893 ~~per minute. Fluoride solutions shall not be injected to a point of negative pressure.~~

2894

2895 ~~(moved to Section 12(n)(ii)(F))(D)—All fluoride feed lines and dilution~~  
2896 ~~water lines shall be isolated from potable water supplies by either an air gap above the solution~~  
2897 ~~tank or a reduced pressure principal backflow preventor.~~

2898  
2899 ~~(moved to Section 12(n)(ii)(G))(E)—Water used for sodium fluoride~~  
2900 ~~dissolution shall have a hardness not exceeding 50 mg/L. Softening shall be provided for the~~  
2901 ~~solution water where hardness exceeds 45 mg/L.~~

2902  
2903 ~~(moved to Section 12(n)(ii)(H))(F)—Flow meters for treated flow rate and~~  
2904 ~~fluoride solution water shall be provided.~~

2905  
2906 ~~(iii)—Protective equipment. Protective equipment, including air purifying~~  
2907 ~~respirators approved by the National Institute of Occupational Safety and Health and emergency~~  
2908 ~~showers, shall be provided for operators handling fluoride compounds.~~

2909  
2910 ~~(iv)—Dust control.~~

2911  
2912 ~~(moved to Section 12(n)(iii))(A)—Provisions shall be made to allow the~~  
2913 ~~transfer of dry fluoride compounds from shipping containers to storage bins or hoppers in such a~~  
2914 ~~way as to minimize the quantity of fluoride dust which may enter the room in which the~~  
2915 ~~equipment is installed. The enclosure shall be provided with an exhaust fan and dust filter which~~  
2916 ~~places the hopper under a negative pressure. Air exhausted from fluoride handling equipment~~  
2917 ~~shall discharge through a dust filter to the outside atmosphere of the building. The discharge~~  
2918 ~~shall not be located near a building fresh air intake.~~

2919  
2920 ~~(moved to Section 12(n)(iii)(C))(B)—A floor drain shall be provided.~~

2921  
2922 ~~(v)—Testing equipment. Equipment shall be provided for measuring the~~  
2923 ~~quantity of fluoride in the water.~~

2924  
2925 ~~(vi)—Defluoridation. Where fluoride removal is required the following methods~~  
2926 ~~are acceptable:~~

2927  
2928 ~~(moved to Section 12(n)(iv)(A))(A)—Activated alumina may be employed~~  
2929 ~~in open gravity filter tanks or pressure filter tanks. The minimum media depth shall be 5 feet.~~  
2930 ~~The units shall not be loaded at a rate exceeding 4 gallons per minute per square foot (236~~  
2931 ~~m<sup>3</sup>/m<sup>2</sup>-d). The activated alumina media shall be in mesh sizes ranging from 28 to 48.~~  
2932 ~~Regeneration facilities shall be provided to regenerate the media. These shall include both weak~~  
2933 ~~caustic and weak acid systems.~~

2934  
2935 ~~(moved to Section 12(n)(iv)(F))(B)—Bone char filtration or lime softening~~  
2936 ~~with magnesium addition.~~

2937  
2938 ~~(p)—Stabilization. Stabilized water is a water that does not tend to corrode the pipe~~  
2939 ~~nor deposit large quantities of scale.~~

2941 ~~(i) Carbon dioxide addition.~~

2942  
2943 ~~(A) Recarbonation basin design shall provide a minimum total~~  
2944 ~~detention time of 20 minutes. Two compartments consisting of a mixing compartment having a~~  
2945 ~~detention time of at least three minutes and a reaction compartment are required. Each~~  
2946 ~~compartment shall have a minimum depth of 8 feet (2.4 m).~~

2947  
2948 ~~(B) Plants generating carbon dioxide from combustion shall have top~~  
2949 ~~recarbonation tanks in order to dissipate carbon monoxide gas. Care shall be taken to prevent the~~  
2950 ~~basin off-gases from entering any treatment plant structure.~~

2951  
2952 ~~(C) The recarbonation basin shall be sloped to a drain.~~

2953  
2954 ~~(ii) Acid addition. Facilities shall be provided for feeding both acid and~~  
2955 ~~alkalinity, such as sodium carbonate, lime or sodium bicarbonate.~~

2956  
2957 ~~(iii) Polyphosphates. The feeding of polyphosphates is applicable for~~  
2958 ~~sequestering calcium in lime softened water, corrosion control, and in conjunction with alkali~~  
2959 ~~feed following ion exchange softening. Chlorination equipment and feed points shall be available~~  
2960 ~~to chlorinate the phosphate solution tank to maintain a 10 mg/L free chlorine residual and to~~  
2961 ~~maintain a 0.5 mg/L residual in the distribution system.~~

2962  
2963 ~~(moved to 12 (n)(vii))(iv) Alkali feed. Unstable water created by ion exchange~~  
2964 ~~softening shall be stabilized by an alkali feed. An alkali feeder shall be provided for all ion~~  
2965 ~~exchange water softening plants.~~

2966  
2967 ~~(moved to 12 (n)(viii))(v) Control. Laboratory equipment shall be provided~~  
2968 ~~for determining the effectiveness of stabilization treatment. This shall include testing equipment~~  
2969 ~~for hardness, calcium, alkalinity, pH and magnesium, as a minimum.~~

2970  
2971 ~~(moved to Section 12(o))(q) Taste and odor control. Provision shall be made for the~~  
2972 ~~control of taste and odor at all surface water treatment plants.~~

2973  
2974 ~~(i) Flexibility. Plants treating water that is known to have taste and odor~~  
2975 ~~problems shall be provided with equipment that makes at least two of the control processes~~  
2976 ~~available.~~

2977  
2978 ~~(ii) Chlorination. When chlorination is used for the removal of some~~  
2979 ~~objectionable odors, two hours of contact time must be provided to complete the chemical~~  
2980 ~~reactions involved.~~

2981  
2982 ~~(iii) Chlorine dioxide. Chlorine dioxide can be used in the treatment of any~~  
2983 ~~taste and odor that is treatable by an oxidizing compound. Provisions shall be made for proper~~  
2984 ~~storing and handling of the sodium chlorite to eliminate any danger of explosion.~~

2985

2986 ~~(iv) Powdered activated carbon. Provisions shall allow the addition of carbon~~  
2987 ~~to the presedimentation basin influent, rapid mix basin, and clarifier effluent. Carbon feed~~  
2988 ~~equipment shall be capable of feeding from 0 to 40 mg/L at plant design flows.~~  
2989

2990 ~~(iv) A provision shall be made for adequate dust control. Powdered activated~~  
2991 ~~carbon shall be handled as a potentially combustible material. It shall be stored and used in a~~  
2992 ~~building or compartment as nearly fireproof as possible. Carbon feeder rooms shall be designed~~  
2993 ~~for hazardous locations, National Electric Code, Class 1, Groups C and D, Division 1.~~  
2994

2995 ~~(moved to Section 12(o)(i))(v) Granular activated carbon adsorption units.~~  
2996 ~~Open or closed carbon contacting may be used for taste and odor control by adsorption of~~  
2997 ~~organics. The loading rate shall not exceed 10 gpm/ft<sup>2</sup> (236 m<sup>3</sup>/m<sup>2</sup>-d). The minimum empty bed~~  
2998 ~~contact time shall be 20 minutes. Provisions shall be made for moving carbon to and from the~~  
2999 ~~contactors.~~  
3000

3001 ~~(vi) Potassium permanganate. The application point shall be in the raw water~~  
3002 ~~or ahead of the clarifier influent. Facilities shall be capable of feeding not less than 10 mg/L of~~  
3003 ~~permanganate.~~  
3004

3005 ~~(moved to Section 12(o)(iii))(vii) Ozone. Thirty minutes of contact time must~~  
3006 ~~be provided to complete the chemical reactions involved. The facilities shall be capable of an~~  
3007 ~~applied ozone feed rate of 15 mg/L minimum.~~  
3008

3009 ~~(moved to Section 12(p))(r) Microscreening. A microscreen will be allowed as a~~  
3010 ~~mechanical supplement to treatment. The microscreening shall be capable of removing~~  
3011 ~~suspended matter from the water by straining. It may be used to reduce nuisance organisms and~~  
3012 ~~organic loadings. It shall not be~~  
3013 ~~used in place of filtration or coagulation.~~  
3014

3015 ~~(moved to Section 12(p)(iii))(i) Screens shall be of a corrosion resistant~~  
3016 ~~material, plastic or stainless steel.~~  
3017

3018 ~~(moved to Section 12(p)(iv))(ii) Bypass piping shall be provided around the~~  
3019 ~~unit.~~  
3020

3021 ~~(moved to Section 12(p)(v))(iii) Protection against back siphonage shall be~~  
3022 ~~provided when potable water is used for washing the screen.~~  
3023

3024 ~~(moved to Section 12(p)(vi))(iv) Washwaters shall be wasted and not~~  
3025 ~~recycled to the microscreen.~~  
3026

3027 ~~(s) Organics removal by granular carbon adsorption.~~  
3028

3029 ~~(moved to Section 12(o)(i)(C))(i) Adsorption of organics on granular activated~~  
3030 ~~carbon. Water to be treated may be contacted with granular activated carbon. The pH of the~~

3031 ~~water shall be less than 9.0. The turbidity of the applied water shall be less than 2 TU when~~  
3032 ~~packed beds are used.~~

3033  
3034 ~~(ii) — Contact time. The carbon beds or columns shall provide a minimum of 20~~  
3035 ~~minutes of empty bed contact time at design flow. Surface loading rates shall not exceed 10~~  
3036 ~~gpm/ft<sup>2</sup> (590 m<sup>3</sup>/m<sup>2</sup>-d).~~

3037  
3038 ~~(iii) — Carbon bed or column design.~~

3039  
3040 ~~(moved to Section 12(o)(i)(E))(A) — If an upflow countercurrent~~  
3041 ~~contactors is used, it may be either packed or expanded. A single unit is acceptable. If a~~  
3042 ~~downflow contactor is used, two or more beds in parallel are required.~~

3043  
3044 ~~(moved to Section 12(o)(i)(F))(B) — Contactors may be designed as open~~  
3045 ~~gravity units, or pressure beds. They may be constructed of concrete, steel, or fiberglass~~  
3046 ~~reinforced plastic. Steel vessels shall be protected against corrosion by coaltar epoxy coating,~~  
3047 ~~rubber or glass lining, or other means.~~

3048  
3049 ~~(moved to Section 12(o)(i)(I))(C) — All carbon beds or columns shall be~~  
3050 ~~equipped with provisions for flow reversal and bed expansion. Combination downflow filter~~  
3051 ~~contactors shall have backwashing facilities to provide up to 50 percent bed expansion and shall~~  
3052 ~~meet the same backwash criteria as rapid filters.~~

3053  
3054 ~~(D) — Inlet and outlet screens shall be 304 or 316 stainless steel or other~~  
3055 ~~suitable materials.~~

3056  
3057 ~~(E) — Carbon beds and columns shall have a means for removing spent~~  
3058 ~~carbon and introducing makeup or regenerated carbon.~~

3059  
3060 ~~(F) — Pressure contactors shall be equipped with air vacuum release~~  
3061 ~~valves fitted with a stainless steel screen, slot size 0.036 mm (0.14 inches), to prevent plugging~~  
3062 ~~with carbon.~~

3063  
3064 ~~(t) — Radionuclides. Where radionuclide removal is practiced, the waste shall be~~  
3065 ~~evaluated for its classification as a hazardous or low level radioactive waste and disposed of as~~  
3066 ~~required by the Nuclear Regulatory Commission or other appropriate authority.~~

3067  
3068 ~~(u) — Waste handling and disposal. Disposal of any waste sludge or liquid shall meet all~~  
3069 ~~the requirements of Chapter 11 of the Water Quality Rules and Regulations where applicable.~~

3070  
3071 ~~(moved to Section 12(t)(i)(i)) — Sanitary and laboratory wastes. The sanitary~~  
3072 ~~and laboratory wastes from water treatment plants, pumping stations, etc., shall not be recycled~~  
3073 ~~to any part of the water plant. Waste from these facilities must be discharged directly to a~~  
3074 ~~sanitary sewer system when feasible, or to an on-site waste treatment facility permitted by the~~  
3075 ~~Wyoming Department of Environmental Quality.~~

3076



3077 ~~(moved to Section 12(t)(ii))(ii) — Brine waste. The waste from ion-exchange~~  
3078 ~~plants, demineralization plants, etc., may not be recycled to the plant. Where discharging to a~~  
3079 ~~sanitary sewer, a holding tank shall be provided to prevent the overloading of the sewer and/or~~  
3080 ~~interference with the waste treatment processes. The effect of brine discharge to sewage lagoons~~  
3081 ~~may depend on the rate of evaporation from the lagoons. Where disposal to an off-site waste~~  
3082 ~~treatment system is proposed, it must be demonstrated that the sewer and the facility have the~~  
3083 ~~required capacity and dilution capability. The impact on any treatment system discharge shall be~~  
3084 ~~evaluated.~~

3085  
3086 ~~(moved to Section 12(t)(iii))(iii) — Lime softening sludge. Acceptable methods~~  
3087 ~~of treatment and disposal are as follows:~~

3088  
3089 ~~(moved to Section 12(t)(iii)(A))(A) — Sludge lagoons. Lagoons shall be~~  
3090 ~~designed on the basis of providing a surface area of 0.7 acres (.28 ha) per million gallons per day~~  
3091 ~~(3785 m<sup>3</sup>/day) (average day) per 100 mg/L of hardness removed, based on a usable lagoon depth~~  
3092 ~~of 5 feet (1.5 m). At least 2 lagoons shall be provided. An acceptable means of final sludge~~  
3093 ~~disposal must be provided. Provisions must be made for convenient cleaning of the lagoons.~~

3094  
3095 ~~(moved to Section 12(t)(iii)(A))(A) — The design of lagoons shall provide~~  
3096 ~~for location above the 100-year flood or adequately protected from the 100-year flood. There~~  
3097 ~~shall be means of diverting surface water runoff so that it does not flow into the lagoons.~~  
3098 ~~Minimum free board of 3 feet (0.66 m) shall be present. An adjustable decanting device for~~  
3099 ~~recycling the overflow shall be present. There shall be an accessible effluent sampling point.~~

3100  
3101 ~~(moved to Section 12(t)(iii)(B))(B) — Land application of liquid lime~~  
3102 ~~sludge shall comply with Part E of Chapter 11 of the Water Quality Rules and Regulations.~~

3103  
3104 ~~(moved to Section 12(t)(iii)(C))(C) — Disposal at a suitable landfill~~  
3105 ~~shall be authorized by the Solid Waste Management Program of the Department of~~  
3106 ~~Environmental Quality.~~

3107  
3108 ~~(moved to Section 12(t)(iii)(D))(D) — Mechanical dewatering of sludge~~  
3109 ~~may be employed.~~

3110  
3111 ~~(moved to Section 12(t)(iii)(E))(E) — Recalcination of sludge may be~~  
3112 ~~employed.~~

3113  
3114 ~~(moved to Section 12(t)(iii)(F))(F) — Lime sludge drying beds shall not be~~  
3115 ~~used.~~

3116  
3117 ~~(moved to Section 12(t)(iv))(iv) — Alum sludge.~~

3118  
3119 ~~(moved to Section 12(t)(iv)(A))(A) — Lagooning may be used as a storage~~  
3120 ~~and interim disposal method for alum sludge. The volume of alum sludge storage lagoons shall~~  
3121 ~~be at least 100,000 gallons (378.5 m<sup>3</sup>) per 1,000,000 gpd (3,785 m<sup>3</sup>/d) of treatment plant~~  
3122 ~~capacity.~~

3123  
3124 ~~(moved to Section 12(t)(iv)(B))(B)—Discharge of alum sludge to sanitary~~  
3125 ~~sewers may be used only when the sewage system has the capability to adequately handle the~~  
3126 ~~flow and sludge.~~

3127  
3128 ~~(moved to Section 12(t)(iv)(C))(C)—Mechanical dewatering of sludge~~  
3129 ~~may be employed.~~

3130  
3131 ~~(moved to Section 12(t)(iv)(D))(D)—Alum sludge drying beds may be~~  
3132 ~~used.~~

3133  
3134 ~~(moved to Section 12(t)(iv)(E))(E)—Alum sludge may be acid treated and~~  
3135 ~~recovered.~~

3136  
3137 ~~(moved to Section 12(t)(iv)(F))(F)—Disposal at a suitable landfill shall be~~  
3138 ~~authorized by the Solid Waste Management Program of the Department of Environmental~~  
3139 ~~Quality.~~

3140  
3141 ~~(v)—Iron and manganese waste. Waste filter washwater from iron and~~  
3142 ~~manganese removal plants may be disposed by filtration, by lagooning, or by discharge to the~~  
3143 ~~sewer system.~~

3144  
3145 ~~(A)—Sand filters. Sand filters should have a total filter area of not less~~  
3146 ~~than 100 square feet (9.29 m<sup>2</sup>) in a minimum of 2 compartments. The filter shall have sufficient~~  
3147 ~~surface area and capacity to contain, in a volume of 2 feet (0.61 m) above the level of the sand,~~  
3148 ~~the entire volume of washwater produced by washing the production filters.~~

3149  
3150 ~~(I)—The filter shall not be subject to flooding by surface runoff~~  
3151 ~~or flood waters. Finished grade elevation shall be such as to facilitate maintenance, cleaning and~~  
3152 ~~removal of surface sand as required.~~

3153  
3154 ~~(II)—The filter media shall consist of a minimum of 12 inches~~  
3155 ~~(30.4 cm) of sand, 3 inches (7.6 cm) of supporting small gravel or torpedo sand, and 9 inches~~  
3156 ~~(0.22 m) of gravel in graded layers. All sand and gravel shall be washed to remove fines. Filter~~  
3157 ~~sand shall have an effective size of 0.3 to 0.5 mm and a uniformity coefficient not to exceed 3.5.~~

3158  
3159 ~~(III)—The filter shall be provided with an underdrain collection~~  
3160 ~~system, and provision shall be made for an accessible sample point.~~

3161  
3162 ~~(IV)—Overflow devices from these filters shall not be permitted.~~

3163  
3164 ~~(V)—Where freezing may occur, provisions shall be made for~~  
3165 ~~covering the filters during the winter months.~~

3166

3167 ~~(VI) Iron and manganese waste filters shall provide an~~  
3168 ~~atmosphere air break between adjacent compartments that contain finished water and unfiltered~~  
3169 ~~water.~~

3170  
3171 ~~(B) Washwater recovery lagoons. Filter backwash wastewater may be~~  
3172 ~~recovered by washwater recovery lagoons. Decanted filter backwash wastewater from the~~  
3173 ~~lagoons shall be recycled to the head of the plant. Lagoons shall provide 250,000 gallons of~~  
3174 ~~storage (946 m<sup>3</sup>) for each 1,000,000 gallons per day (3,785 m<sup>3</sup>/day) of treatment capacity.~~  
3175 ~~Lagoons shall have a minimum usable depth of 3 feet (0.91 m), a length 4 times the width, and a~~  
3176 ~~width of at least 3 times the water depth.~~

3177  
3178 (a) 2018 TSS, parts 2.9-2.9(c), monitoring equipment; 2.10, sample taps; 2.11,  
3179 facility water supply; and 2.14, piping color code; are herein incorporated by reference.

3180  
3181 ~~(formerly Section 8(a))(b) Design basis.~~ The proposed design shall demonstrate that  
3182 the capacity of the water treatment or water production system ~~shall be~~ is designed for the  
3183 maximum daily demand at the design year based on historical usage records. ~~Where water use~~  
3184 ~~records are not available to establish water use, the equivalent per capita water use shall be at~~  
3185 ~~least 125 gpd (475 liters per day) and 340 gpd (1,285 liters per day) to size facilities for average~~  
3186 ~~and maximum daily water demand, respectively.~~

3187  
3188 ~~(formerly Section 8(a))(i)~~ Where water use records are not available to  
3189 establish water use, the design shall include an equivalent per capita water use ~~shall be~~ of at least  
3190 125 gallons per day (gpd) (475 liters per day) for average daily water demand and 340 gpd  
3191 ~~(1,285 liters per day) to size facilities for average and maximum daily water demand,~~  
3192 ~~respectively.~~

3193  
3194 ~~(formerly Section 8(p))(ii) Design capacities.~~ The plant capacity design shall  
3195 ~~include maximum daily water demand, filter backwash quantities, and industrial water use. In~~  
3196 ~~the absence of data, filter backwash quantity shall be five percent of the maximum daily demand.~~  
3197 demonstrate consideration of:

3198  
3199 ~~(formerly Section 8(p))(A)~~ Mmaximum daily water demand;

3200  
3201 ~~(formerly Section 8(p))(B)~~ Agricultural water use;

3202  
3203 ~~(formerly Section 8(p))(C)~~ and Industrial water use; and

3204  
3205 ~~(formerly Section 8(p))(D)~~ Filter backwash quantities. In the absence  
3206 of data, filter backwash quantity shall be five percent of the maximum daily demand.

3207  
3208 ~~(formerly Section 8(g)(iii))(c) Geological conditions.~~ The Structural design shall  
3209 demonstrate consideration of the seismic zone, groundwater, and soil support. ~~Soils~~  
3210 ~~investigations shall be made, or adequate previous soils investigations shall be available to~~  
3211 ~~develop structural design.~~

3213 ~~(formerly Section 8(g)(iii))~~(i) The seismic zone;

3214

3215 ~~(formerly Section 8(g)(iii))~~(ii) Groundwater; and

3216

3217 ~~(formerly Section 8(g)(iii))~~(iii) Soil support: that demonstrates:

3218

3219 ~~(formerly Section 8(g)(iii))~~(A) The applicant has conducted Ssoils

3220 investigations ~~shall be made,~~ or has included documentation of adequate previous soils

3221 investigations ~~shall be available~~used to develop the structural design;

3222

3223 ~~(formerly Section 8(l))~~(B) Basin slabs ~~shall be~~ have been designed to

3224 successfully resist the hydrostatic uplift pressure or include an area dewatering system ~~or an area~~

3225 ~~dewatering system shall be provided;~~ and

3226

3227 ~~(formerly Section 8(l))~~(C) Considerations ~~must be given in structural~~

3228 ~~design to~~ of long-span breakage in basins designed to resist uplift.

3229

3230 ~~(formerly Section 8(b)(i))~~(d) Location. Proposed ~~T~~treatment facilities locations shall ~~be~~

3231 ~~located such~~ demonstrate that:

3232

3233 ~~(formerly Section 8(b)(i))~~(i) No sources of pollution ~~may~~ will affect the quality

3234 of the water supply or treatment system;

3235

3236 ~~(formerly Section 8(b)(i))~~(ii) The ~~facilities~~ facility shall not be located location is

3237 not within 500 feet of landfills, garbage dumps, or wastewater treatment systems; and

3238

3239 ~~(formerly Section 8(b)(i))~~(iii) ~~Flood protection.~~ All treatment process

3240 structures, mechanical equipment, and electrical equipment ~~shall~~ will be protected, accessible,

3241 and remain fully operational during ~~from~~ the maximum flood of record or the 100-year flood,

3242 whichever is greater. ~~The treatment facilities shall remain fully operational and accessible during~~

3243 ~~the 100-year flood.~~

3244

3245 ~~(formerly Section 8(e))~~(e) Level of treatment. Proposed ~~T~~treatment shall ~~be provided~~

3246 ~~to demonstrate that the facility will~~ produce potable water that is bacteriologically, chemically,

3247 radiologically, and physically safe, ~~as determined by the administrator as required by 40 CFR~~

3248 Part 141.

3249

3250 ~~(formerly Section 8(d)(i))~~(f) ~~Multiple units.~~ Designs for proposed ~~T~~treatment facilities

3251 with 100,000 ~~gallons per day (gpd) (378.5 m<sup>3</sup>/day)~~ capacity and over shall ~~provide~~ include

3252 duplicate units, as a minimum, for chemical feed, flocculation, clarification, sedimentation,

3253 filtration, and disinfection.

3254

3255 ~~(formerly Section 8(d)(i))~~(g) Designs for proposed ~~T~~treatment facilities under 100,000

3256 gpd ~~(378.5 m<sup>3</sup>/day)~~ capacity shall ~~provide~~ include:

3257

3258 ~~(formerly Section 8(d)(i))~~(i) Duplicate units as described ~~above~~ in paragraph (f)  
3259 of this Section; or ~~may provide~~

3260  
3261 ~~(formerly Section 8(d)(i))~~(ii) ~~f~~Finished water system storage equal to twice the  
3262 maximum daily demand-; and

3263  
3264 (iii) Demonstration of consideration of plant design flexibility to account for  
3265 future changes in source water quality, unexpected need to modify process piping, service area  
3266 expansion, changing treatment technologies, and equipment life cycles and upgrades.

3267  
3268 ~~(formerly Section 8(d)(ii))~~(h) ~~Multiple equipment.~~All treatment facility pumping shall  
3269 provide the maximum daily demand flow with the largest single-unit not in service. Finished  
3270 water pumping in combination with finished water storage that floats on the distribution systems  
3271 shall provide the maximum hourly demand with the largest single-unit not in service. ~~When For~~  
3272 designs that include fire protection ~~is provided~~, pumping, and finished water storage that floats  
3273 on the system shall provide the fire demand plus the maximum daily demand, or the maximum  
3274 hourly demand, whichever is greater.

3275  
3276 ~~(formerly Section 8(d)(iii))~~(i) ~~Alternative power source.~~Where the finished water storage  
3277 volume that floats on the distribution system is not capable of supplying the maximum daily  
3278 demand, an the proposed design shall include alternative power ~~shall be provided~~ for the finished  
3279 water pumps- ~~The combined finished water storage volume and pumping capacity supplied by~~  
3280 ~~alternative power shall be at least adequate to provide the maximum daily demand. Acceptable~~  
3281 ~~alternative power sources include an engine generator, engine drive pumps, or a second~~  
3282 ~~independent electrical supply. that demonstrates:~~

3283  
3284 ~~(formerly Section 8(d)(iii))~~(i) The combined finished water storage volume and  
3285 pumping capacity supplied by alternative power ~~shall~~ will be at least adequate to provide the  
3286 maximum daily demand-; and

3287  
3288 ~~(formerly Section 8(d)(iii))~~(ii) ~~Acceptable~~ The alternative power sources  
3289 will include ~~an~~ engine generators, engine drive pumps, or a second independent electrical supply  
3290 that will provide sufficient power to run the system.

3291  
3292 ~~(formerly Section 8(e))~~(j) ~~Housing.~~ Process equipment, filters and appurtenances,  
3293 disinfection, chemical feed and storage, electrical and controls, and pipe galleries shall be ~~housed~~  
3294 located in suitable structures.

3295  
3296 ~~(formerly Section 8(m))~~(k) All equipment not required to be in or on open basins,  
3297 ~~(such as clarifier drives and flocculators),~~ shall be located in heated, lighted, and ventilated  
3298 structures. ~~Structure entrances shall be above grade. Piping shall be buried below frost level,~~  
3299 ~~placed in heated structures, or provided with heat and insulated.~~

3300  
3301 ~~(formerly Section 8(m))~~(l) Piping shall be buried below frost level, placed in heated  
3302 structures, or provided with heat and insulated.

3303

3304 ~~(formerly Section 8(m))~~(m) Structure entrances shall be above grade.

3305

3306 ~~(formerly Section 8(g)(i))~~(n) ~~Construction materials. Selected c~~Construction materials  
3307 shall ~~be selected, apportioned, and/or protected to~~ provide water tightness, corrosion protection,  
3308 and resistance to weather variations.

3309

3310 ~~(formerly Section 8(g)(ii))~~(o) ~~Coatings. NSF/ANSI/CAN 61-2020/NSF/ANSI/CAN 600-~~  
3311 2021 certified Coatings used to protect structures, equipment, and piping shall be suitable for  
3312 atmospheres containing moisture and low concentrations of chlorine. ~~Surfaces exposed in~~  
3313 ~~chemical areas shall be protected from chemical attack. Paints shall not contain lead, mercury, or~~  
3314 ~~other toxic metals or chemicals.~~

3315

3316

3317 ~~(formerly Section 8(g)(ii))~~(p) Surfaces exposed in chemical areas shall be protected from  
3318 chemical attack.

3319

3320 ~~(formerly Section 8(g)(ii))~~(q) Paints shall not contain lead, mercury, or other toxic metals  
3321 or chemicals.

3322

3323 ~~(formerly Section 8(k))~~(r) ~~Ventilation.~~ All enclosed spaces shall be provided with  
3324 forced ventilation, except pumping station wetwells or clearwells. ~~In areas where there are open~~  
3325 ~~treatment units exposed to the room, ventilation shall be provided to limit relative humidity to~~  
3326 ~~less than 85 percent but not less than 6 air changes per hour. In electrical and equipment rooms,~~  
3327 ~~ventilation shall be provided to limit the temperature rise in the room to less than 15° F (8° C)~~  
3328 ~~above ambient, but not less than 6 air changes per hour. Rooms housing chlorine storage and/or~~  
3329 ~~feeders shall have provisions for exhausting the room contents in 2 minutes and continuous~~  
3330 ~~ventilation to provide not less than 12 air changes per hour. that meet the following~~  
3331 requirements:

3332

3333 ~~(formerly Section 8(k))~~(i) In areas where there are open treatment units  
3334 exposed to the room, ventilation shall be provided to limit relative humidity to less than 85  
3335 percent but not less than six air changes per hour.; and

3336

3337 ~~(formerly Section 8(k))~~(ii) ~~In electrical and equipment rooms, V~~entilation in  
3338 electrical and equipment rooms shall ~~be provided to~~ limit the temperature rise in the room to less  
3339 than 15 °F (8° C) degrees Fahrenheit above ambient, ~~but not less than with at least~~ six air  
3340 changes per hour. ~~Rooms housing chlorine storage and/or feeders shall have provisions for~~  
3341 ~~exhausting the room contents in 2 minutes and continuous ventilation to provide not less than 12~~  
3342 ~~air changes per hour.~~

3343

3344 ~~(formerly Section 8(f)(i))~~(s) ~~Equipment location.~~ Service transformers and other critical  
3345 electrical equipment shall be located above the 100-year flood and above grade. Transformers  
3346 shall be located so that they are remote or protected by substantial barriers from traffic. Motor  
3347 controls shall be located in superstructures and in rooms that do not contain corrosive  
3348 atmospheres.

3349

3350 ~~(formerly Section 8(i)(i))(t) Metering.~~ All The treatment facility facilities shall have a  
3351 flow measuring device provided for raw water influent and clear well effluent and ~~(formerly~~  
3352 ~~Section 8(i)(i)) All flow meters each shall provide totalized flow.~~ The accuracy of the device  
3353 shall be at least plus or minus two percent of span. and shall meet the following requirements:

3354  
3355 ~~(formerly Section 8(i)(iii))(i) Controls.~~ Automatic controls shall be designed to  
3356 permit manual override. ; and

3357  
3358 ~~(formerly Section 8(i)(ii))(ii) Type.~~ All flow meters shall provide totalized flow.  
3359 ~~For plants with a maximum daily flow of 50,000 gpd (189 m<sup>3</sup>/d) or more, t~~The meter shall also  
3360 record the instantaneous flow rate.

3361  
3362 ~~(formerly Section 8(q))(u) Monitoring equipment.~~ Water treatment plants with a  
3363 capacity of ~~0.5 mgd (1892.6 m<sup>3</sup>/d)~~ 500,000 gpd or more shall be provided with continuous  
3364 finished water turbidimeters (including recorders) that demonstrate compliance with the  
3365 Guidance Manual for Compliance with the Surface Water Treatment Rules, Turbidity  
3366 Provisions.

3367  
3368 **Section 11. Chemical Application Source Development.**

3369  
3370 ~~(a) — General.~~

3371  
3372 ~~(i) — Chemical application. Chemicals shall be applied by such means as to~~  
3373 ~~prevent backflow or back siphonage between multiple points of feed through common~~  
3374 ~~manifolds.~~

3375  
3376 ~~(ii) — General equipment design. General equipment design shall be such that:~~

3377  
3378 ~~(A) — Feeders will be able to supply the necessary amounts of chemical~~  
3379 ~~throughout the feed range at all times.~~

3380  
3381 ~~(B) — Chemical contact materials and surfaces are resistant to the~~  
3382 ~~aggressiveness of the chemical solution.~~

3383  
3384 ~~(C) — Corrosive chemicals are introduced in such a manner as to~~  
3385 ~~minimize potential for corrosion.~~

3386  
3387 ~~(D) — Chemicals that are incompatible are not stored or handled together.~~

3388  
3389 ~~(E) — All chemicals are conducted from the feeder to the point of~~  
3390 ~~application in separate conduits.~~

3391  
3392 ~~(F) — Chemical feeders and pumps operate at no lower than 20 percent~~  
3393 ~~of the feed range.~~

3395 ~~(G) — Slurry type chemicals, especially lime, are fed by gravity where~~  
3396 ~~practical.~~

3397  
3398 ~~(moved to Section 13(b))(b) — Facility design.~~

3399  
3400 ~~(moved to Section 13(b)(i))(i) — Number of feeders. A separate feeder shall~~  
3401 ~~be provided for each chemical applied.~~

3402  
3403 ~~(ii) — Control. Feeders may be manually or automatically controlled. Automatic~~  
3404 ~~controls shall be designed to allow override by manual controls. Where plant flow rates are not~~  
3405 ~~manually controlled, chemical feed rates shall be automatically proportioned to flow.~~

3406  
3407 ~~Calibration cylinders shall be provided for each chemical system, enabling exact~~  
3408 ~~measurement of chemical feed dose.~~

3409  
3410 ~~(iii) — Dry chemical feeders. Dry chemical feeders shall measure chemicals~~  
3411 ~~volumetrically or gravimetrically; they shall be provided with a solution water system and mixer~~  
3412 ~~in the solution tank and; shall completely enclose chemicals to prevent emission of dust to the~~  
3413 ~~operating room.~~

3414  
3415 ~~(iv) — Positive displacement pumps. Positive displacement pumps shall be sized~~  
3416 ~~for the maximum pressure at the point of injection. A backpressure valve shall be provided in~~  
3417 ~~instances where chemicals can flow by gravity through the pump and pump check valves.~~

3418  
3419 ~~(v) — Liquid chemical feeders — siphon control. Liquid chemical feeders shall be~~  
3420 ~~such that chemical solutions cannot be siphoned into the water supply.~~

3421  
3422 ~~(vi) — Cross-connection control. Cross-connection control must be provided to~~  
3423 ~~assure that the service water lines discharging to solution tanks shall be protected from backflow~~  
3424 ~~and that liquid chemical solutions cannot be siphoned through solution feeders into the water~~  
3425 ~~supply. No direct connection shall exist between any sewer and a drain or overflow from the~~  
3426 ~~feeder, solution chamber or tank. All drains shall terminate at least 6 inches (0.15 m) or 2 pipe~~  
3427 ~~diameters, whichever is greater, above the overflow rim of a receiving sump, conduit or waste~~  
3428 ~~receptacle.~~

3429  
3430 ~~(vii) — In-plant water supply. The in-plant water supply shall be of sufficient~~  
3431 ~~quantity and pressure to meet the chemical system needs. A minimum capability of 15 gpm at 50~~  
3432 ~~psi is required.~~

3433  
3434 ~~There shall be a new means of controlling and measuring the water when used for~~  
3435 ~~preparing specific solution concentrations by dilution, i.e., rotometer and control valve. The~~  
3436 ~~water shall be properly treated for hardness when hardness affects the chemical solution.~~

3437  
3438 ~~(viii) — Storage of chemicals.~~



3440 (A) ~~Storage space or tank volume shall be provided for at least 30 days~~  
3441 ~~of chemical supply. The storage shall provide protection from intermixing of 2 different~~  
3442 ~~chemicals.~~

3443  
3444 (B) ~~Storage tanks and pipelines for liquid chemicals shall be specific to~~  
3445 ~~the chemical and not for alternates.~~

3446  
3447 (C) ~~Liquid chemical storage tanks must have a liquid level indicator,~~  
3448 ~~an overflow and a receiving basin or drain capable of receiving accidental spills or over-flows,~~  
3449 ~~and be located in a contained area sized to store the total contents of a ruptured tank.~~

3450  
3451 (moved to Section 13(b)(ii))(D) ~~All chemical storage tanks shall be~~  
3452 ~~constructed of materials which are resistant to the chemical which they store. The tank shall not~~  
3453 ~~lose its structural integrity through chemical action or be subject to corrosion.~~

3454  
3455 (ix) ~~Solution and slurry tanks.~~

3456  
3457 (A) ~~Feed and dilution systems shall be designed to maintain uniform~~  
3458 ~~strength of solution in solution tanks. A mixer shall be provided to mix the tank contents when~~  
3459 ~~batching solutions. Continuous agitation shall be provided to maintain slurries in suspension. A~~  
3460 ~~means shall be provided to measure the solution level in the tank. Chemical solution tanks shall~~  
3461 ~~have a cover. Large tanks with access openings shall have such openings curbed and fitted with~~  
3462 ~~overhanging covers.~~

3463  
3464 (B) ~~Subsurface locations for solution tanks shall be free from sources~~  
3465 ~~of possible contamination, and assure positive drainage for groundwaters, accumulated water,~~  
3466 ~~chemical spills and overflows.~~

3467  
3468 (C) ~~Overflow pipes, when provided, shall be turned downward, with~~  
3469 ~~the end screened. They shall have a free fall discharge and be located where noticeable.~~

3470  
3471 (D) ~~Acid storage tanks must be vented to the outside atmosphere, but~~  
3472 ~~not through vents shared with any other material.~~

3473  
3474 (E) ~~Each tank shall be provided with a valved drain, protected against~~  
3475 ~~backflow by an air gap of 6 inches (0.15 m) or 2 pipe diameters, whichever is greater.~~

3476  
3477 (x) ~~Day tanks.~~

3478  
3479 (A) ~~Day tanks shall be provided where bulk storage of liquid chemical~~  
3480 ~~is provided and a dilute solution is to be fed, or where chemicals are manually batched. Day~~  
3481 ~~tanks shall meet the requirements of solution tanks. Tanks shall be properly labeled to designate~~  
3482 ~~the chemical contained.~~

3483  
3484 (B) ~~Hand pumps may be used to transfer chemicals from a carboy or~~  
3485 ~~drum. A tip rack may be used to permit withdrawal into a bucket from a spigot. Where motor-~~

3486 ~~driven transfer pumps are provided, a liquid level limit switch and an overflow from the day tank~~  
3487 ~~shall be provided.~~

3488  
3489 ~~(C) — Continuous agitation shall be provided to maintain chemical~~  
3490 ~~slurries in suspension. A mixer shall be provided to mix the initial dilution.~~

3491  
3492 ~~(xi) — Feed lines:~~

3493  
3494 ~~(A) — Shall be of durable material, resistant to the chemical handled.~~

3495  
3496 ~~(B) — Shall be readily accessible for maintenance when located within~~  
3497 ~~structures.~~

3498  
3499 ~~(C) — Shall be protected against freezing.~~

3500  
3501 ~~(D) — Shall be readily cleanable by using plugged crosses for 90° bends.~~

3502  
3503 ~~(E) — Shall slope upward from the chemical source to the feeder when~~  
3504 ~~conveying gases.~~

3505  
3506 ~~(F) — Shall be designed consistent with scale forming or solids-~~  
3507 ~~depositing properties of the water, chemical, solution, or mixtures conveyed.~~

3508  
3509 ~~(G) — Shall be color coded.~~

3510  
3511 ~~(H) — Shall have a connection for a flushing line.~~

3512  
3513 ~~(xii) — Handling.~~

3514  
3515 ~~(A) — Carts, elevators and other appropriate means shall be provided for~~  
3516 ~~lifting chemical containers.~~

3517  
3518 ~~(B) — Provisions shall be made for the transfer of dry chemicals from~~  
3519 ~~shipping containers to storage bins or hoppers to minimize the quantity of dust which may enter~~  
3520 ~~the room in which the equipment is installed. Provisions shall also be made for disposing of~~  
3521 ~~empty bags, drums or barrels which will minimize exposure to dusts. Control may be provided~~  
3522 ~~by using:~~

3523  
3524 ~~(I) — Vacuum/pneumatic equipment or closed conveyor systems.~~

3525  
3526 ~~(II) — Facilities for emptying shipping containers in special~~  
3527 ~~enclosures.~~

3528  
3529 ~~(III) — Exhaust fans and dust filters which put the hoppers or bins~~  
3530 ~~under negative pressure.~~

3531

3532 ~~(C) Provision shall be made for measuring quantities of chemicals used~~  
3533 ~~to prepare feed solutions.~~

3534  
3535 ~~(xiii) Housing. Floor surfaces shall be smooth and impervious, slip-resistant and~~  
3536 ~~well drained with 2.5 percent minimum slope. Vents from feeders, storage facilities and~~  
3537 ~~equipment exhaust shall discharge to the outside atmosphere above grade and remote from air~~  
3538 ~~intakes.~~

3539  
3540 ~~(e) Specific chemicals.~~

3541  
3542 ~~(i) Chlorine gas.~~

3543  
3544 ~~(A) Respiratory protection equipment. Respiratory protection~~  
3545 ~~equipment, meeting the requirements of the National Institute of Occupational Safety and Health~~  
3546 ~~(NIOSH), shall be available where chlorine gas is handled, and shall be stored at a convenient~~  
3547 ~~location, but not inside any room where chlorine is used or stored. The units shall use~~  
3548 ~~compressed air, have at least a 30-minute capacity, and be compatible with or exactly the same as~~  
3549 ~~units used by the fire department responsible for the plant.~~

3550  
3551 ~~(B) Chlorine leak detection. Where ton containers are used, or where~~  
3552 ~~plants store more than 1000 lbs (454 kg) of chlorine, continuous electronic chlorine leak~~  
3553 ~~detection equipment shall be provided.~~

3554  
3555 ~~(C) Repair kits. Repair kits approved by the Chlorine Institute shall be~~  
3556 ~~provided for plants employing chlorine gas chlorination. The chlorine repair kits shall be~~  
3557 ~~available for each size container stored at the facility.~~

3558  
3559 ~~(D) Feed and storage areas. Chlorine gas feed and storage shall be~~  
3560 ~~enclosed and separated from other operating areas. The chlorine room shall be provided with a~~  
3561 ~~shatter-resistant window installed in an interior wall. The room shall be constructed in such a~~  
3562 ~~manner that all openings between the chlorine room and the remainder of the plant are sealed.~~  
3563 ~~The doors shall be equipped with panic hardware, assuring ready means of exit and opening~~  
3564 ~~outward only to the building exterior.~~

3565  
3566 ~~(E) Ventilation. Where chlorine gas is used, the room shall~~  
3567 ~~have an exhaust ventilating system with a capacity which provides one complete air change~~  
3568 ~~every two minutes. The ventilating system shall take suction within 18 inches (0.46 m) of the~~  
3569 ~~floor, as far as practical from the door and air inlet, with the point of discharge so located as not~~  
3570 ~~to contaminate air intakes to any rooms or structures.~~

3571  
3572 ~~Air intakes shall be through louvers near the ceiling. Louvers for chlorine room~~  
3573 ~~air intake and exhaust shall facilitate airtight closure.~~

3574  
3575 ~~Separate switches for the fan and lights shall be located outside of the chlorine~~  
3576 ~~room and at the inspection window. Outside switches shall be protected from vandalism. A~~

3577 ~~signal light indicating fan operation shall be provided at each entrance when the fan can be~~  
3578 ~~controlled from more than one point.~~

3579  
3580 ~~Vents from feeders and storage shall discharge to the outside atmosphere, above~~  
3581 ~~grade. The room location shall be on the prevailing downwind side of the building away from~~  
3582 ~~entrances, windows, louvers, walkways, etc.~~

3583  
3584 ~~Floor drains shall discharge to the outside of the building and shall not be~~  
3585 ~~connected to other internal or external drainage systems.~~

3586  
3587 ~~(F) — Cylinders. Full and empty cylinders of chlorine gas shall be~~  
3588 ~~isolated from operating areas, restrained in position to prevent upset, stored in rooms separate~~  
3589 ~~from ammonia storage, and stored in areas not in direct sunlight or exposed to excessive heat.~~

3590  
3591 ~~(G) — Heating. Chlorinator rooms shall be heated to 60° F (15.6° C) and~~  
3592 ~~be protected from excessive heat. Cylinders and gas lines shall be protected from temperatures~~  
3593 ~~above that of the feed equipment.~~

3594  
3595 ~~(H) — Feed lines. Pressurized chlorine feed lines shall not carry chlorine~~  
3596 ~~gas beyond the chlorinator room.~~

3597  
3598 ~~(ii) — Acids and caustics.~~

3599  
3600 ~~(A) — Acids and caustics shall be kept in closed corrosion-resistant~~  
3601 ~~shipping containers or in covered bulk storage units.~~

3602  
3603 ~~(B) — Acids and caustics shall be pumped in undiluted form from~~  
3604 ~~original containers or bulk storage units through suitable pipe or hose to the point of treatment or~~  
3605 ~~to a covered day tank.~~

3606  
3607 ~~(C) — An emergency deluge shower and eye wash shall be provided~~  
3608 ~~where corrosive chemicals are stored or used.~~

3609  
3610 ~~(iii) — Sodium chlorite. Provisions shall be made for proper storage and handling~~  
3611 ~~of sodium chlorite to eliminate any danger of explosion. No hydrocarbons or organics shall be~~  
3612 ~~stored with sodium chlorite.~~

3613  
3614 (a) 2018 TSS, parts 3.1.4.1-3.1.4.1(i), surface water, structures, design of intake  
3615 structures; 3.1.4.3-3.1.4.3(f) surface water, structures, offstream raw water storage reservoir;  
3616 3.1.6-3.1.6.3, surface water, impoundments and reservoirs; 3.2.3.2, groundwater, location,  
3617 continued sanitary protection; 3.2.4-3.2.4.14(b)(4), groundwater, general well construction;  
3618 3.2.5-3.2.5.4, groundwater, testing and records; 3.2.6.1-3.2.6.1(c), groundwater, aquifer types  
3619 and construction methods--special conditions, sand or gravel wells; 3.2.6.2-3.2.6.2(b)(7),  
3620 groundwater, aquifer types and construction methods--special conditions, gravel pack material;  
3621 3.2.6.4-3.2.6.4(d), groundwater, aquifer types and construction methods--special conditions,  
3622 infiltration lines; 3.2.6.5-3.2.6.5(b), groundwater, aquifer types and construction methods--

3623 special conditions, limestone or sandstone wells; 3.2.7.3-3.2.7.3(c)(3), groundwater, well pumps,  
3624 discharge piping and appurtenances, discharge piping; 3.2.7.4-3.2.7.4(d), groundwater, well  
3625 pumps, discharge piping and appurtenances, pitless well units; 3.2.7.6, groundwater, well pumps,  
3626 discharge piping and appurtenances, casing vent; 3.2.7.7-3.2.7.7(b), groundwater, well pumps,  
3627 discharge piping and appurtenances, water level measurement; 3.2.7.8-3.2.7.8(b), groundwater,  
3628 well pumps, discharge piping and appurtenances, observation wells; are herein incorporated by  
3629 reference.

3630

3631 (b) Surface water intake structures that operate in the winter shall be capable of  
3632 minimizing the formation of ice on the intake.

3633

3634 (c) Transmission lines and interconnecting process piping shall be capable of  
3635 withstanding the forces and conditions they will be subject to and comply with the following  
3636 specifications for water service, as applicable:

3637

3638 (i) AWWA C200;

3639

3640 (ii) AWWA C207;

3641

3642 (iii) AWWA C208;

3643

3644 (iv) AWWA C220;

3645

3646 (v) AWWA C228;

3647

3648 (vi) AWWA C300;

3649

3650 (vii) AWWA C301;

3651

3652 (viii) AWWA C302;

3653

3654 (ix) AWWA C303;

3655

3656 (x) AWWA C304;

3657

3658 (xi) AWWA C900;

3659

3660 (xii) AWWA C901;

3661

3662 (xiii) AWWA C903;

3663

3664 (xiv) AWWA C904;

3665

3666 (xv) AWWA C906;

3667

3668 (xvi) AWWA C907;

- 3669  
3670 [\(xvii\) AWWA C909;](#)  
3671  
3672 [\(xviii\) AWWA C950;](#)  
3673  
3674 [\(xix\) ASTM A53;](#)  
3675  
3676 [\(xx\) ASTM A134;](#)  
3677  
3678 [\(xxi\) ASTM A135;](#)  
3679  
3680 [\(xxii\) ASTM A139;](#)  
3681  
3682 [\(xxiii\) ASTM D2846;](#)  
3683  
3684 [\(xxiv\) ASTM F480;](#)  
3685  
3686 [\(xxv\) ASTM F645;](#)  
3687  
3688 [\(xxvi\) ASTM F877;](#)  
3689  
3690 [\(xxvii\) ASTM F23891;](#)  
3691  
3692 [\(xxviii\)ASTM F2806;](#)  
3693  
3694 [\(xxix\) ASTM F2855;](#)  
3695  
3696 [\(xxx\) ASTM F2969;](#)  
3697  
3698 [\(xxxi\) API 5L;](#)  
3699  
3700 [\(A\) Grade B;](#)  
3701  
3702 [\(B\) Grade X42;](#)  
3703  
3704 [\(C\) Grade X46;](#)  
3705  
3706 [\(D\) Grade X52;](#)  
3707  
3708 [\(E\) Grade X56;](#)  
3709  
3710 [\(F\) Grade X60;](#)  
3711  
3712 [\(G\) Grade X65;](#)  
3713  
3714 [\(H\) Grade X70; or](#)

3715  
3716  
3717  
3718  
3719  
3720  
3721  
3722  
3723  
3724  
3725  
3726  
3727  
3728  
3729  
3730  
3731  
3732  
3733  
3734  
3735  
3736  
3737  
3738  
3739  
3740  
3741  
3742  
3743  
3744  
3745  
3746  
3747  
3748  
3749  
3750  
3751  
3752  
3753  
3754  
3755  
3756  
3757  
3758  
3759

(I) Grade X80.

~~(formerly Section 9(a)(iii))(d) Raw water supply piping. No Designs shall~~  
not include any customer service connection ~~shall be provided~~ from the raw water transmission  
line to the treatment plant, unless there are provisions to treat the water to meet ~~these standards~~  
the requirements of this Chapter, or the sole purpose of the service is for irrigation or agricultural  
water use. For irrigation agricultural services, applicants shall conduct a hazard classification and  
implement appropriate backflow prevention.

~~(formerly Section 9(b))(e) Designs that include Ggroundwater source development~~  
shall comply with the following requirements:

~~(formerly Section 9(b)(i))(i) Number and capacity. The total developed~~  
~~groundwater source, along with other water sources, shall provide a combined capacity that shall~~  
~~equal or exceed the design maximum daily demand. Proposed designs shall include Aa~~  
~~minimum of: 2 wells, or 1 well and finished water storage equal to twice the maximum daily~~  
~~demand shall be provided. Where 2 wells are provided, the sources shall be capable of equaling~~  
~~or exceeding the design average daily demand with the largest producing well out of service.~~

~~(formerly Section 9(b)(i))(A) 2 wells, or 1 well and finished water storage~~  
~~equal to twice the maximum daily demand shall be provided. Where 2 Two wells are provided,~~  
~~the sources shall be that are each~~ capable of ~~equaling or exceeding the design supplying the~~  
average daily demand with the largest producing well out of service: ;

~~(formerly Section 9(b)(i))(B) 2 wells, or 1 One well and finished water~~  
~~storage that together equal to twice the maximum daily demand shall be provided. Where 2 wells~~  
~~are provided, the sources shall be capable of equaling or exceeding the design average daily~~  
~~demand with the largest producing well out of service. ; or~~

(C) For public water supplies that are not community water systems or  
nontransient noncommunity water systems, as determined by the Administrator, one well that is  
capable of supplying the maximum daily demand.

~~(formerly Section 9(b)(i)(B))(ii) Relation to sources of pollution. Every well~~  
~~shall be located further from any of the sources of pollution listed below. The Wells shall~~  
maintain the following minimum isolation distances ~~listed below apply when domestic~~  
~~wastewater is the only wastewater present.;~~

~~(formerly Section 9(b)(i)(B)(I))(A) If domestic wastewater is the only~~  
~~wastewater present and the design domestic sewage flow is less than 2,000 gallons per day gpd~~  
~~(7,560 L/day), the following minimum isolation distance shall be maintained:~~

~~(formerly Section 9(b)(i)(A)(II)(A) Table 1. Isolation Distances for Domestic Sewage Flows~~  
Less than 2,000 gpd

<i>Source of Domestic Wastewater</i>	<i>Minimum Distance to Well</i>
--------------------------------------	---------------------------------

Sewer	50 feet
Septic tank	50 feet
Disposal field	100 feet (30.5 m)
Seepage pit	100 feet (30.5 m)
Cesspool	100 feet (30.5 m)
<u>Storm and Sanitary Sewer Collection Systems</u>	<u>50 feet</u>
<u>Septic tank</u>	<u>100 feet</u>
<u>Absorption system</u>	<u>200 feet</u>

3760  
3761 ~~(formerly Section 9(b)(i)(B)(H))(B)~~ If domestic wastewater is the only  
3762 wastewater present and the design domestic sewage flow is greater than 2,000 gpd ~~(7,560 L/day)~~  
3763 but less than 10,000 gpd ~~(37,800 L/day)~~, the following minimum isolation distances shall be  
3764 maintained:

3765  
3766 Table 2. Isolation Distances for Domestic Sewage Flows Greater than 2,000 gpd

<u>Source of Domestic Wastewater</u>	<u>Minimum Distance to Well</u>
Sewer	50 feet
Septic tank	50 feet
Disposal field	200 feet
Seepage pit	200 feet
Cesspool	200 feet
<u>Storm and Sanitary Sewer Collection Systems</u>	<u>50 feet</u>
<u>Septic tank</u>	<u>100 feet</u>
<u>Absorption system</u>	<u>500 feet</u>

3767  
3768 ~~(formerly Section 9(b)(i)(B)(H))(C)~~ For systems larger If domestic  
3769 wastewater is the only wastewater present and the design domestic sewage flow is greater than  
3770 10,000 gallons per day ~~(37,800 L/day)~~; or non-domestic wastewater is present the required  
3771 isolation distance shall be determined by a ~~hydrogeological~~ subsurface study, in accordance with  
3772 the requirements of ~~Section 15 of Chapter 3 Water Quality Rules and Regulations~~ Water Quality  
3773 Rules Chapter 3, Section 17(b), but shall not be less than those ~~listed above~~ required in Tables 1  
3774 and 2 of this Section.

3775  
3776 ~~(formerly Section 9(b)(i)(C))(iii)~~ Relation to Wells shall maintain the  
3777 following minimum isolation distances from buildings and property lines:-  
3778



3779 ~~(formerly Section 9(b)(i)(C)(I))(A)~~ When a well is adjacent to the  
3780 outside of a building, the well shall be located so that the ~~centerline~~ the surface casing has a  
3781 clearance radius of a minimum of 10 feet horizontally and extended vertically, will clear any  
3782 projection from the building ~~by not less than 3 feet (0.91 m), and will clear any power line by not~~  
3783 less than 10 feet (3.05 m);

3784  
3785 ~~(formerly Section 9(b)(i)(C)(II))(B)~~ When a well is ~~to be~~ located  
3786 inside a building; ~~the top of the casing and any other well opening shall not terminate in the~~  
3787 ~~basement of the building, or in any pit or space that is below natural ground surface unless the~~  
3788 ~~well is completed with a properly protected submersible pump. Wells located in a structure~~  
3789 ~~must be accessible to pull the casing or the pump. The structure shall have overhead access.~~

3790  
3791 ~~(formerly Section 9(b)(i)(C)(II))(I)~~ ~~†~~The top of the casing  
3792 and any other well opening shall not terminate in the basement of the building, or in any pit or  
3793 space that is below natural ground surface unless the well is completed with a properly protected  
3794 submersible pump or provided with provisions for drainage to the ground surface that is not  
3795 subject to flooding by surface water;

3796  
3797 ~~(formerly Section 9(b)(i)(C)(II))(II)~~ Wells located in a  
3798 structure shall be accessible to pull the casing, pipe, or pump; and

3799  
3800 ~~(formerly Section 9(b)(i)(C)(II))(III)~~ The structure shall  
3801 have overhead access.

3802  
3803 ~~(formerly Section 9(b)(i)(D))(C)~~ ~~Relation to property lines. Every~~  
3804 ~~w~~Wells shall be located at least ~~10~~ 50 feet ~~(3.05 m)~~ from any property line.

3805  
3806 ~~(formerly Section 9(b)(ii)(iv))~~ ~~Applicants for wells shall complete~~ ~~†~~testing and  
3807 maintain records as follows:

3808  
3809 ~~(formerly Section 9(b)(ii)(A))(A)~~ ~~Yield and drawdown tests.~~ Yield  
3810 and drawdown tests shall be performed on every production well after construction or  
3811 subsequent treatment and prior to placement of the permanent pump. The test methods shall be  
3812 clearly indicated in the specifications. The test pump capacity, at maximum anticipated  
3813 drawdown, shall be at least 1.5 times the design rate anticipated. The ~~test well~~ shall ~~provide for~~  
3814 ~~continuous pumping~~ be test pumped at the desired yield (design capacity) of the well for at least  
3815 24 consecutive hours ~~or until after~~ stabilized drawdown. ~~has continued~~ Alternatively, the well  
3816 may be pumped at a rate of 150 percent of the desired yield for at least ~~6~~ six continuous hours  
3817 after stabilized drawdown. ~~when test pumped at 1.5 times the design pumping rate.~~

3818  
3819 ~~(formerly Section 9(b)(ii)(B))(B)~~ ~~Plumbness and alignment~~  
3820 ~~requirements.~~ Every well shall be tested for plumbness and alignment in accordance with  
3821 AWWA A-100 A100. ~~The test method and allowable tolerance shall be stated in the~~  
3822 ~~specifications.~~

3823

3824 (v) In addition to meeting the requirements of Section 8 of this Chapter, plans for  
3825 wells developed through acidizing activities shall also include the following elements:

3826  
3827 (A) Information on the geology of the area that contains descriptions  
3828 of:

3829  
3830 (I) Known or potential faults, fractures, springs, karst features  
3831 (such as sinkholes and other similar features) within a one-mile radius of the proposed well; and

3832  
3833 (II) Faults and fractures that may extend from the acidized zone  
3834 into overlying and underlying geologic formations and a description of any measures that will be  
3835 taken to ensure that the acidized solution does not migrate into any of those geologic formations.

3836  
3837 (B) For wells developed within a radius of one mile of existing wells,  
3838 applicants shall submit plans that analyze the risk and mitigation measures to be taken to prevent  
3839 impacts to those wells and the risk and mitigation measures for any potential effects to each  
3840 existing well;

3841  
3842 (C) Existing information on the location of other wells (such as water  
3843 supply, oil and gas, mineral development wells) within a one-mile radius of the proposed well,  
3844 including any wells that intercept the acidized zone, and for wells that intercept the acidized  
3845 zone;

3846  
3847 (I) An analysis of whether or not those wells that intercept the  
3848 acidized zone have been properly plugged and abandoned;

3849  
3850 (II) An analysis of whether or not those wells have been  
3851 properly cased and cemented; and

3852  
3853 (III) A description of what measures will be or have been taken  
3854 to prevent the acidized solution from migrating vertically in the annular space or casing of the  
3855 existing wells into overlying or underlying geologic formations.

3856  
3857 (D) A description of the borehole drilling phase and what measures  
3858 will be taken to minimize the introduction of lost circulation materials into aquifers when  
3859 encountering under-pressured geologic formations or other factors that may lead to a loss of  
3860 circulation;

3861  
3862 (E) A description of the acid injection process and the measures that  
3863 will be taken to ensure that injection pressures do not create fractures in the overlying and  
3864 underlying geologic formations and through which the acidized solution may migrate;

3865  
3866 (F) A description of the volume and content of the acid and any other  
3867 chemical compounds to be used during acidizing activities, including the management of the acid  
3868 and chemical compounds prior to acidizing and final disposition of any acid, water, or chemical  
3869 mixtures recovered from the well after acidizing activities are completed;

3870  
3871 (G) A description of the measures that will be or have been taken to  
3872 ensure that the recovery of the acidized solution is of sufficient duration and volume to eliminate  
3873 the potential for acidic impacts to other wells completed within the injection zone; and

3874  
3875 (H) A description of the methods to be performed to establish the  
3876 placement and integrity of the annular seal and casing prior to acidization of the well.

3877  
3878 ~~(formerly Section 9(b)(iii)(A))(vi) Protection during construction.~~ During any  
3879 well construction or modification, the well and surrounding area ~~must~~ shall be adequately  
3880 protected to prevent any groundwater contamination. Surface water ~~must~~ shall be diverted away  
3881 from the construction area.

3882  
3883 ~~(formerly Section 9(b)(iii)(B))(vii) All Wells types and shall comply with the~~  
3884 following construction methods standards.;

3885  
3886 ~~(formerly Section 9(b)(iii)(I))(A) Dug wells.~~ Dug wells shall be ~~used~~  
3887 ~~only where geological conditions preclude the possibility of developing an acceptable drilled~~  
3888 ~~well constructed according to the State Engineer's standards.;~~  
3889

3890 ~~(formerly Section 9(b)(iii)(II)(2.))(B) Every d~~Drilled, driven, jetted, or bored wells  
3891 shall have an unperforated casing that extends from a minimum of 12 inches ~~(30 cm)~~  
3892 ~~ground~~ the concrete surface and 18 inches above natural ground surface ~~to at least 10 feet (3.05~~  
3893 ~~m) below ground surface. In unconsolidated formations, this casing shall extend to the water~~  
3894 ~~table or below. In consolidated formations, the casing may be terminated in rock or watertight~~  
3895 ~~clay above the water table. and the design shall demonstrate compliance with Water Quality~~  
3896 Rules, Chapter 26, Section 8;

3897  
3898 ~~(formerly Section 9(b)(iii)(B)(X)(2.))(C)~~ In gravel-packed wells or  
3899 artificial filter-packed wells, aquifers containing inferior quality water shall be sealed by pressure  
3900 grouting, or with special packers or seals, to prevent such water from moving vertically in  
3901 gravel-packed portions of the well. Gravel-packed wells shall meet the following sealing  
3902 requirements:

3903  
3904 ~~(formerly Section 9(b)(iii)(IV)(2.))(I)~~ If a permanent surface  
3905 casing is not installed, the annular opening between the casing and the drill hole shall be sealed  
3906 in the top 10 feet ~~(3.05 m)~~ with concrete or cement grout. or

3907  
3908 ~~(formerly Section 9(b)(iii)(IV)(2.))(II)~~ If a permanent surface  
3909 casing is installed, it shall extend to a depth of at least 10 feet ~~(3.05 m)~~. The annular opening  
3910 between this outer casing and the inner casing shall be covered with a metal or cement seal.

3911  
3912 ~~(formerly Section 9(b)(iii)(IV)(1.))(D)~~ When ~~artesian~~  
3913 naturally flowing water is encountered in a well, unperforated casing shall extend into the  
3914 confining layer overlying the ~~artesian~~ water-bearing zone. This casing shall be adequately sealed  
3915 with cement grout into the confining zone and shall extend at least 10 feet into the target aquifer

3916 to prevent both surface and subsurface leakage from the ~~artesian~~ water-bearing zone. The  
3917 method of construction shall be such that during the placing of the grout and the time required  
3918 for it to set, no water shall flow through or around the annular space outside the casing, and no  
3919 water pressure sufficient to disturb the grout prior to final set shall occur. ~~After the grout has set~~  
3920 ~~completely, d~~Drilling operations ~~may~~ shall not be continued into the ~~artesian~~ water-bearing zone  
3921 until the grout has set completely. If leakage occurs around the well casing or adjacent to the  
3922 well, the well shall be recompleted with any seals, packers or casing necessary to eliminate the  
3923 leakage completely.

3924  
3925 (I) Flowing wells shall be constructed to control the flow of  
3926 water from the well. The well grouting shall be engineered to prevent the movement of water  
3927 along the well casing and to prevent the migration of pressurized water into upper aquifers. A  
3928 flow control device shall be installed into the wellhead to control the flow of water from the well.  
3929 The well discharge or overflow line installations must connect to the well casing at least 12  
3930 inches above ground and be valved. The size of the air gap between the overflow line from the  
3931 well to drainage structure shall be twice the diameter of the well overflow pipe. Overflow water  
3932 must be drained and diverted to prevent ponding around the well casing.

3933  
3934 (II) There shall be no direct connection between any discharge  
3935 pipe and a sewer or other source of pollution.

3936  
3937 ~~(formerly Section 9(b)(iii)(B)(X)(1.))(E)~~ Any time during the  
3938 ~~construction of a well that~~ If mineralized water or water known to be polluted is encountered  
3939 during the construction of a well, the aquifer or aquifers containing such inferior quality water  
3940 shall be adequately cased or sealed off ~~so that to prevent~~ water shall not from entering the well,  
3941 ~~nor will it move~~ and to prevent water from moving up or down the annular space; ~~outside the~~  
3942 ~~well casing. If necessary, special seals or packers shall be installed to prevent movement of~~  
3943 ~~inferior quality water. Mineralized water may be used if it can be properly treated to meet all~~  
3944 ~~drinking water quality standards as determined by the administrator. When mineralized water is~~  
3945 ~~encountered, it shall not be mixed with any other waters from different aquifers within the well.~~

3946  
3947 ~~(formerly Section 9(b)(iii)(B)(X)(1.))(I)~~ If a well is penetrating  
3948 ~~multiple aquifers, mineralized water shall be excluded from the well if water is taken from other~~  
3949 ~~non-mineralized aquifers. If a~~ For wells is that penetrating penetrate multiple aquifers,  
3950 mineralized water shall be excluded from the well if water is taken from other, non-mineralized  
3951 aquifers.

3952  
3953 (II) Applicants that propose to use mMineralized water ~~may be~~  
3954 ~~used as a public water supply shall demonstrate if it can be properly~~ that any necessary  
3955 ~~treatment to meet all will comply with the~~ drinking water quality standards ~~as determined by~~  
3956 ~~the administrator~~ required by 40 CFR Part 141.

3957  
3958 ~~(formerly Section 9(b)(iii)(B)(XI)(1.))(F)~~ Existing oil ~~and or~~ gas wells,  
3959 ~~seismic test holes, private water wells, or mineral~~ exploration ~~test holes that can be completed to~~  
3960 ~~conform to all minimum construction standards required by this Chapter~~ may be converted for  
3961 use as a public water supply wells, ~~provided that the wells can be completed to conform to the~~

3962 ~~minimum construction standards cited in this chapter. This does not relieve the applicant from~~  
3963 ~~obtaining appropriate permits. The permit application shall identify all actions to be completed to~~  
3964 ~~achieve compliance with this Chapter.~~

3965  
3966 (viii) The minimum grout thickness for public water supply wells shall be  
3967 determined in accordance with AWWA Standard A100, part 4.7.8.3.

3968  
3969 (ix) Well seals shall meet the following requirements:

3970  
3971 (A) The annular space shall be sealed to protect against contamination  
3972 or pollution by the entrance of surface or shallow subsurface waters; and

3973  
3974 (B) Annular seals shall be installed to provide protection for the casing  
3975 against corrosion, to ensure the structural integrity of the casing, and to stabilize the upper  
3976 formation.

3977  
3978 (x) Upper terminal well designs that include a concrete floor shall  
3979 demonstrate a slope of one inch per foot away from the casing at .

3980  
3981 (xi) Well pumps shall be located at a point above the top of the well screen.

3982  
3983 ~~(formerly Section 9(b)(iii)(D)(II))~~ (xii) Submersible pumps. Where a  
3984 submersible pump is used, the top of the casing shall be effectively sealed against the entrance of  
3985 water under all conditions of vibration or movement of conductors or cables. The electrical  
3986 cable shall be firmly attached to the rise pipe at 20 foot (6.1 m) intervals or less, and the pump  
3987 shall be located at a point above the top of the well screen. An accessible check valve that is not  
3988 located in the pump column shall be installed in the discharge line of each well between the  
3989 pump and the shut-off valve. Additional check valves shall be located in the pump column as  
3990 necessary to prevent negative pressures on the discharge piping.

3991  
3992 ~~(formerly Section 9(b)(iii)(C)(IV))~~ (xiii) Pitless well units. A pitless adaptor  
3993 or well house shall be used where needed to protect the water system from freezing.

3994  
3995 ~~(formerly Section 9(b)(iii)(C)(IV))~~ (xiv) A frost pit may be used only in  
3996 conjunction with a properly protected pitless adaptor.

3997  
3998 ~~(formerly Section 9(b)(iii)(C)(vi))~~ (xv) Water level management. Every  
3999 wWells with diameters that are greater than 4 four inches (10 cm) in diameter shall be equipped  
4000 with an access port that will allow for the measurement of the depth to the water surface; or in  
4001 the case of a flowing artesian well, with a pressure gauge that will indicate pressure. A an air line  
4002 used for water level measurements or, shall be provided on all wells greater than 4 inches (10  
4003 cm) in diameter. Installation of water level measuring equipment shall be made using corrosion-  
4004 resistant materials attached firmly to the drop pipe or pump column and in such a manner as to  
4005 prevent entrance of foreign materials. in the case of a flowing artesian well, with a pressure gauge  
4006 that will indicate pressure.

4008 ~~(formerly Section 9(b)(iii)(C)(VII))(xvi)~~ Discharge measuring device. Every  
4009 well shall be piped so that a device capable of measuring the total well discharge can be placed  
4010 in operation at the well for well testing. Every well field (or when only one well is present,  
4011 every well) shall have a device capable of measuring the total discharge. An instantaneous and  
4012 totalizing flow meter equipped with nonvolatile memory shall be installed on the discharge line  
4013 of each well in accordance with the manufacturer's specifications. Meters installed on systems  
4014 with variable frequency drives shall be capable of accurately reading the full range of flow rates.  
4015

4016 ~~(formerly Section 9(b)(iii)(D)(IX))(xvii)~~ Well abandonment. Test wells and  
4017 groundwater sources ~~which that are not in use shall be~~ sealed for plugging and abandonment in  
4018 accordance with requirements of Water Quality Rules Chapter 26, ~~Water Quality Rules and~~  
4019 ~~Regulations. Section 11 (formerly 9(b)(iii)(D)(IX))Wells~~ shall be sealed by filling with neat  
4020 cement grout. The filling materials shall be applied to the well hole through a pipe, or tremie, ~~or~~  
4021 ~~bailer.~~  
4022

4023 (xviii) Designs for groundwater sources that are subject to 40 CFR  
4024 141.402(a)(1)(i) and either 40 CFR 141.402(a)(1)(ii) or 40 CFR 141.402(a)(1)(iii) shall  
4025 demonstrate compliance with 40 CFR 141.402(e).  
4026

4027 (f) Facilities that include spring development shall meet the following requirements:  
4028

4029 (i) Spring collection systems shall be constructed to collect spring water  
4030 while preventing contamination of the source from the ground surface or other contaminant  
4031 sources.  
4032

4033 (ii) Seepage springs shall have a trench for the collection site that extends at  
4034 least six inches into the impervious layer, but not entirely through the impervious layer.  
4035 Concentrated springs shall be developed down to bedrock.  
4036

4037 (iii) A bed of clean and disinfected rock that extends the width of the spring  
4038 from which water is being collected shall be installed at the collection site.  
4039

4040 (iv) The collection site shall:

4041 (A) Be covered with 60 mil plastic sheeting or an equivalent puncture-  
4042 proof and water-proof barrier; and  
4043

4044 (B) Be protected from damage during back-fill and re-grading of the  
4045 site to the original surface elevation with protective fabric or sand.  
4046

4047 (v) Collecting walls shall be:

4048 (A) Constructed immediately downstream of the collection site; and  
4049

4050 (B) Made of concrete, or other material that meets the requirements of  
4051 Section 15(b)(ii) of this Chapter;  
4052  
4053

4054  
4055           (vi) The spring water collection pipe shall be installed in accordance with the  
4056 USDA NRCS Part 631 National Engineering Handbook, Chapter 32, part 631.3201(b)(iii) for  
4057 delivery pipes and shall meet the following requirements:

4058  
4059                   (A) The size of the collection pipe shall be sufficient to convey the  
4060 flow of the spring; and

4061  
4062                   (B) Pipe material and appurtenances shall comply with allowable well  
4063 construction material for water distribution in accordance with the standards listed in paragraph  
4064 (c) of this Section.

4065  
4066           (vii) Appropriate bedding and cover material shall protect the spring collection  
4067 system from damage and freezing.

4068  
4069           (viii) The Administrator shall determine the spring protection area, based on the  
4070 information submitted in the engineering design report required by Section 8 of this Chapter,  
4071 which shall be no less than the isolation distances in (e)(ii) of this Section. The Administrator  
4072 may require additional setback distances if the engineering design report demonstrates the  
4073 additional distance is required to prevent contamination of the source from the ground surface or  
4074 other contaminant sources.

4075  
4076           (ix) All potential sources of contamination shall be removed from the spring  
4077 protection area.

4078  
4079           (x) The spring collection site shall include fencing or other protective features  
4080 that are constructed and secured to exclude large animals and unauthorized persons from  
4081 entering the protection area.

4082  
4083                   (A) Fencing shall be designed to withstand animals and snow loading.  
4084 Other protective systems may be proposed.

4085  
4086                   (B) Fencing shall include an entry point to allow access by authorized  
4087 persons for inspection and maintenance activities.

4088  
4089           (xi) The spring collection site shall include a diversion ditch that is constructed  
4090 on the upstream side of the spring collection site to route surface water flows away from the  
4091 collection area. The diversion ditch shall be located a minimum of 10 feet away from the  
4092 collection wall.

4093  
4094           (xii) The spring collection site shall be equipped to disinfect water prior to  
4095 distribution and shall include sampling ports before and after the disinfection application point.  
4096 The equipment shall be maintained and available to operate for its intended use.

4097

4098 (xiii) Spring box designs shall comply Section 15(a), (b), (f-j), and (l) of this  
4099 Chapter. Combined spring box and finished water storage designs shall comply with Section 15  
4100 of this Chapter.

4101  
4102 (xiv) All designs for the spring collector box and collecting walls shall be  
4103 performed by a Wyoming registered professional engineer. The plans or contractor furnished  
4104 information shall be signed and sealed by a Wyoming registered professional engineer.

4105  
4106 **Section 12. Pumping Facilities Treatment.**

4107  
4108 ~~(moved to Section 14(g)(iv))(a) — Total dynamic head. The total dynamic head rating~~  
4109 ~~of pumping units shall be based on pipe friction, pressure losses from piping entrances, exits,~~  
4110 ~~appurtenances (bends, valves, etc.), and static head at the design flow.~~

4111  
4112 ~~(b) — Location.~~

4113  
4114 ~~(i) — The pumping station shall be elevated or protected to a minimum of 3 feet~~  
4115 ~~above the 100-year flood elevation, or 3 feet above the highest recorded flood elevation,~~  
4116 ~~whichever is higher.~~

4117  
4118 ~~(ii) — The station shall be accessible to operating personnel at all times, and~~  
4119 ~~during all weather.~~

4120  
4121 ~~(iii) — The site around the station shall be graded to lead surface drainage away~~  
4122 ~~from the station.~~

4123  
4124 ~~(iv) — The station shall have security installed to prevent vandalism and entrance~~  
4125 ~~by unauthorized persons or animals.~~

4126  
4127 ~~(e) — Pumping stations — raw and finished water.~~

4128  
4129 ~~(i) — They shall have outward-opening doors.~~

4130  
4131 ~~(ii) — They shall have a floor elevation or a main level entry of at least 6 inches~~  
4132 ~~above finished grade. All floors shall slope at least 2-1/2 inches in every 10 feet to a suitable~~  
4133 ~~drain. Pumps shall have an outlet for drainage from pump glands without discharging onto the~~  
4134 ~~floor.~~

4135  
4136 ~~(iii) — They shall have any underground structures waterproofed.~~

4137  
4138 ~~(d) — Wetwells. Finished water wetwells shall be covered. All vents shall be turned~~  
4139 ~~down and screened. Finished water wetwells shall be located above the groundwater table and~~  
4140 ~~the top of the walls from the wetwell shall be at least 18 inches above finished grade.~~

4141  
4142 ~~(e) — Equipment servicing. Pump stations shall be provided with craneways, hoist~~  
4143 ~~beams, eyebolts, or other facilities for servicing or removing pumps, motors or other heavy~~



4144 equipment. They shall be rated for not less than 50 percent more than the weight of the heaviest  
4145 single item to be lifted. Openings in floors and roofs shall be provided as needed for removal of  
4146 heavy or bulky equipment.

4147  
4148 ~~(moved to Section 14(b))(f) — Stairways and ladders. Stairways or ladders shall be~~  
4149 ~~provided between all floors, and in pits or compartments which must be entered. They shall have~~  
4150 ~~handrails on both sides, and treads of non-slip material. The Wyoming Occupational Health and~~  
4151 ~~Safety Rules and Regulations shall be complied with.~~

4152  
4153 ~~(moved to Section 14(e))(g) — Heating. Provisions shall be made for heating to maintain a~~  
4154 ~~minimum temperature of 40° F (4° C) if not typically occupied and 50° F (10° C) if occupied.~~

4155  
4156 ~~(moved to Section 14(d))(h) — Ventilation. All accessible pumping station areas shall be~~  
4157 ~~ventilated. Ventilation may be continuous or intermittent. If intermittent, ventilation in areas~~  
4158 ~~normally visited by operating personnel shall be started automatically at not greater than 30~~  
4159 ~~minute intervals. Permanently installed drywell ventilation shall provide at least 6 air changes~~  
4160 ~~per hour if continuous, and 12 air changes per hour if intermittent. Intermittent ventilating~~  
4161 ~~equipment shall ensure starting upon entry of operating personnel. Wetwells shall be designed to~~  
4162 ~~permit the use of portable blowers that will exhaust the space and continue to supply fresh air~~  
4163 ~~during access periods.~~

4164  
4165 ~~(moved to Section 14(e))(i) — Dehumidification. In below ground pumping stations, a~~  
4166 ~~means for dehumidification shall be provided. The facilities shall be sized to maintain the~~  
4167 ~~dewpoint at least 2 below the coldest anticipated temperature of water to be conveyed in the~~  
4168 ~~pipes.~~

4169  
4170 ~~(j) — Lighting. Lighting levels shall be sufficient to permit safe operation and~~  
4171 ~~maintenance of all equipment within the pumping stations, but not less than 30 foot candles. All~~  
4172 ~~areas shall be lit in such a manner that the failure of 1 lighting fixture or lamp will not cause the~~  
4173 ~~area to be completely dark.~~

4174  
4175 ~~(moved to Section 14(f))(k) — Sanitary and other conveniences. All pumping stations that~~  
4176 ~~are manned for four or more hours per day shall be provided with potable water, lavatory and~~  
4177 ~~toilet facilities. Wastes shall be discharged to the sanitary sewer or to an on-site waste treatment~~  
4178 ~~system.~~

4179  
4180 ~~(moved to Section 14(g))(l) — Pumps. At least two pumping units shall be provided. With~~  
4181 ~~the largest pump out of service, the remaining pump or pumps shall be capable of providing the~~  
4182 ~~maximum pumping rate of the system.~~

4183  
4184 ~~(moved to Section 14(g)(ii))(m) — Suction lift. Pumps shall be selected so that the net~~  
4185 ~~positive suction head required at maximum flow (NPSHR) is less than the net positive suction~~  
4186 ~~head available (NPSHA) minus 4 feet (1.2 m) based on the hydraulic conditions and altitude of~~  
4187 ~~the pumping station. If this condition is not met, then priming shall be provided.~~

4188

4189 ~~Priming water must not be of lesser sanitary quality than that of the water being pumped.~~  
4190 ~~Vacuum priming may be used.~~

4191  
4192 ~~When an air operated ejector is used, the screened intake shall draw clean air from a point~~  
4193 ~~at least 10 feet above the ground or other source of possible contamination.~~

4194  
4195 ~~(moved to Section 14(g)(iii))(n) — Surge control. Piping systems shall be designed to~~  
4196 ~~withstand the maximum possible surge (water hammer) from the pumping station, or adequate~~  
4197 ~~surge control provided to protect the piping. Pressure relief valves are not acceptable surge~~  
4198 ~~control.~~

4199  
4200 ~~(moved to Section 14(h))(o) — Booster pumps.~~

4201  
4202 ~~(moved to Section 14(h)(i))(i) Booster pumps shall not produce a pressure less~~  
4203 ~~than 5 psi in suction lines. Where the suction line has service connections, booster pump intake~~  
4204 ~~pressure shall be at least 35 psi (138 kPa) when the pump is in normal operation and shall be~~  
4205 ~~provided with a low pressure cutoff switch if the suction line pressure is a minimum of 20 psi (69~~  
4206 ~~kPa).~~

4207  
4208 ~~(moved to Section 14(h)(iii))(ii) — Automatic or remote control devices shall~~  
4209 ~~have a range between the start and cutoff pressure which will prevent cycling of more than 1~~  
4210 ~~start every 15 minutes.~~

4211  
4212 ~~(moved to Section 14(h)(iv))(iii) — In line booster pumps shall be accessible for~~  
4213 ~~servicing and repairs. The access opening and vault shall be large enough to remove the pump.~~

4214  
4215 ~~(moved to Section 14(h)(v))(iv) — Individual home booster pumps shall not be~~  
4216 ~~allowed for any individual service from the public water supply main.~~

4217  
4218 ~~(moved to Section 14(h)(vi))(p) — Automatic and remote controlled stations.~~  
4219 ~~Conditions that may affect continuous delivery of water shall be alarmed at an attended location.~~

4220  
4221 ~~(q) — Appurtenances.~~

4222  
4223 ~~(i) — Valves.~~

4224  
4225 ~~(A) — All pumps except submersibles shall have a suction and discharge~~  
4226 ~~valve to permit satisfactory operation, maintenance and repair of the equipment. Submersible~~  
4227 ~~pumps shall have a check valve and discharge valve to permit satisfactory operation,~~  
4228 ~~maintenance and repair of the equipment.~~

4229  
4230 ~~(B) — If foot valves are necessary, they shall have a net valve area of at~~  
4231 ~~least 2 1/2 times the area of the suction pipe and they shall be screened.~~

4233 ~~(moved the Section 14(i)(i))(C) — Each pump shall have an individual~~  
4234 ~~suction line or the lines shall be so manifolded that they will ensure similar hydraulic and~~  
4235 ~~operating conditions.~~

4236  
4237 ~~(D) — Check. All pumps shall be provided with a check valve located~~  
4238 ~~between the pump and the discharge shutoff valve, except where arranged so that backflow is not~~  
4239 ~~possible under normal operating conditions.~~

4240  
4241 ~~(moved to Section 14(i)(i))(E) — Air release. Air release valves shall~~  
4242 ~~be provided where the pipe crown is dropped in elevation.~~

4243  
4244 ~~(ii) — Gauges. Each pump shall have a standard pressure gauge on its discharge~~  
4245 ~~line. Each pump shall have a compound gauge on its suction line, except wet pit type pumps.~~

4246  
4247 ~~(iii) — Water seals. Water seals shall not be supplied with water of a lesser~~  
4248 ~~sanitary quality than that of the water being pumped. Where pumps are sealed with potable water~~  
4249 ~~and are pumping water of lesser sanitary quality, the seal shall be supplied from a break tank~~  
4250 ~~open to atmospheric pressure. The tank shall have an air gap of at least 6 inches (0.15 m) or 2~~  
4251 ~~pipe diameters, whichever is greater, between the feeder line and the spill line of the tank.~~

4252  
4253 ~~(iv) — Controls. Pumps, their prime movers and accessories, shall be controlled~~  
4254 ~~in such a manner that they will operate at rated capacity without overload. Provision shall be~~  
4255 ~~made to prevent energizing the motor in the event of a backspin cycle. Electrical controls shall~~  
4256 ~~be located above grade.~~

4257  
4258 (a) 2018 TSS, parts 4.2.1(b), presedimentation, inlets; 4.2.1(c), presedimentation,  
4259 bypass; 4.2.2, coagulation; 4.2.2(a), coagulation, mixing; 4.2.2(b), coagulation, equipment;  
4260 4.2.2(c), coagulation, location; 4.2.4(b), sedimentation, inlet devices; 4.2.4(c), sedimentation,  
4261 velocity; 4.2.4(d)-4.2.4(d)(4), sedimentation, outlet devices; 4.3.1.1, rapid rate gravity filters,  
4262 pretreatment; 4.3.1.4-4.3.1.4(o), rapid rate gravity filters, structural details and hydraulics;  
4263 4.3.1.6(a), filter material, total depth; 4.3.1.6(b), filter material, uniformity coefficient; 4.3.1.6(c),  
4264 filter material, minimum; 4.3.1.6(d)(1)-4.3.1.6(d)(1)(f), filter material, types of filter media,  
4265 anthracite; 4.3.1.6(d)(2)-4.3.1.6(d)(2)(d), filter material, types of filter media, sand filter;  
4266 4.3.1.6(d)(4)-4.3.1.6(d)(4)(d), filter material, types of filter media, granular activated carbon  
4267 (GAC); 4.3.1.6(e)(1)-4.3.1.6(e)(1)(b), filter material, support media, topedo sand; 4.3.3.6-  
4268 4.3.3.6(b), diatomaceous earth filtration, pre-coat; 4.3.3.7-4.3.3.7(c), diatomaceous earth  
4269 filtration, body feed; 4.3.3.8-4.3.3.8(e), diatomaceous earth filtration, filtration; 4.3.3.10(a)(1),  
4270 diatomaceous earth filtration, appurtenances, sampling taps; 4.3.3.10(a)(2), diatomaceous earth  
4271 filtration, appurtenances, loss of head; 4.3.3.10(a)(3), diatomaceous earth filtration,  
4272 appurtenances, rate of flow indicator; 4.3.3.10(a)(4), diatomaceous earth filtration,  
4273 appurtenances, throttling valve; 4.3.4.2, slow sand filters, number; 4.3.4.4, slow sand filters, rates  
4274 of filtration; 4.3.4.5, slow sand filters, underdrains; 4.3.4.6-4.3.4.6(e), slow sand filters, filter  
4275 material; 4.3.4.7, slow sand filters, filter gravel; 4.3.4.8, slow sand filters, depth of water on filter  
4276 beds; 4.3.4.9(b) and (e), slow sand filters, control appurtenances; 4.3.4.9(f), slow sand filters,  
4277 control appurtenances; 4.4.1(a), disinfection, contact time, CT, and point(s) of application;  
4278 4.4.1(b), disinfection, contact time, CT, and point(s) of application; 4.4.3(a)-(d), disinfection,

4279 testing equipment; 4.4.4.3, chlorine, automatic switch-over; 4.4.4.7, chlorine, cross-connection  
4280 protection; 4.4.4.8, chlorine, pipe material; 4.4.5, chloramines; 4.4.6.1, ozone, design  
4281 considerations; 4.4.6.2, ozone, feed gas preparation; 4.4.6.3, ozone, ozone generator; 4.4.6.4,  
4282 ozone, ozone contactors; 4.4.6.5, ozone, ozone destruction unit; 4.4.6.6, ozone, piping materials;  
4283 4.4.6.7, ozone, joints and connections; 4.4.6.8, ozone, instrumentation; 4.4.6.9, ozone, alarms;  
4284 4.4.6.11, ozone, construction considerations; 4.5.1, softening, lime or lime-soda process; 4.5.1.1,  
4285 softening, lime or lime-soda process, hydraulics; 4.5.1.3, softening, lime or lime-soda process,  
4286 chemical feed point; 4.5.1.4, softening, lime or lime-soda process, rapid mix; 4.5.1.5, softening,  
4287 lime or lime-soda process, stabilization; 4.5.1.6-4.5.1.6(b), softening, lime or lime-soda process,  
4288 sludge collection; 4.5.1.7, softening, lime or lime-soda process, sludge disposal; 4.5.1.8,  
4289 softening, lime or lime-soda process, disinfection; 4.5.1.9, softening, lime or lime-soda process,  
4290 plant start-up; 4.5.2.1, cation exchange process, pre-treatment requirements; 4.5.2.2, cation  
4291 exchange process, design; 4.5.2.3, cation exchange process, design; 4.5.2.4, cation exchange  
4292 process, depth of resin; 4.5.2.5, cation exchange process, flow rates; 4.5.2.7, cation exchange  
4293 process, underdrains and supporting gravel; 4.5.2.8, cation exchange process, brine distribution;  
4294 4.5.2.9, cation exchange process, cross-connection control; 4.5.2.10, cation exchange process,  
4295 bypass piping and equipment; 4.5.2.11, cation exchange process, additional limitations;  
4296 4.5.2.13(a)-4.5.2.13(f), cation exchange process, brine and salt storage tanks; 4.5.2.14, cation  
4297 exchange process, salt and brine storage capacity; 4.5.2.15, cation exchange process, brine pump  
4298 or eductor; 4.5.2.18, cation exchange process, construction materials; 4.5.2.19, cation exchange  
4299 process, housing; 4.5.3, water quality test equipment; 4.6, anion exchange treatment; 4.6.1, anion  
4300 exchange treatment, pre-treatment requirements; 4.6.2-4.6.2(b), anion exchange treatment,  
4301 design; 4.6.3, anion exchange treatment, exchange capacity; 4.6.4, anion exchange treatment,  
4302 number of units; 4.6.5, anion exchange treatment, type of resin; 4.6.6, anion exchange treatment,  
4303 flow rates; 4.6.7, anion exchange treatment, free board; 4.6.8-4.6.8(b), anion exchange treatment,  
4304 miscellaneous appurtenances; 4.6.9, anion exchange treatment, cross-connection control; 4.6.10,  
4305 anion exchange treatment, construction materials; 4.6.11, anion exchange treatment, housing;  
4306 4.6.12, anion exchange treatment, pre-conditioning of the resin; 4.6.13, anion exchange  
4307 treatment, waste disposal; 4.6.14, anion exchange treatment, water quality test equipment; 4.7,  
4308 aeration; 4.7.1-4.7.1(i), aeration, natural draft aeration; 4.7.2-4.7.2(l), aeration, forced or induced  
4309 draft aeration; 4.7.3-4.7.3(e), aeration, spray aeration; 4.7.4-4.7.4(b), aeration, pressure  
4310 aeration; 4.7.5, aeration, packed tower aeration; 4.7.5.1-4.7.5.1(f), aeration, packed tower  
4311 aeration, process design; 4.7.5.2-4.7.5.2(b), aeration, packed tower aeration, materials of  
4312 construction; 4.7.5.3-4.7.5.3(l), aeration, packed tower aeration, water flow system; 4.7.5.4-  
4313 4.7.5.4(f), aeration, packed tower aeration, air flow system; 4.7.5.5-4.7.5.5(m), aeration, packed  
4314 tower aeration, other features that shall be provided; 4.7.5.6-4.7.5.6(b), aeration, packed tower  
4315 aeration, environmental factors; 4.7.6, aeration, other methods of aeration; 4.7.7, aeration,  
4316 protection of aerators; 4.7.8, aeration, disinfection; 4.7.9, aeration, bypass; 4.7.10, aeration,  
4317 corrosion control; 4.7.11, aeration, quality control; 4.8, iron and manganese control; 4.8.1, iron  
4318 and manganese control, removal by oxidation, detention and filtration, oxidation; 4.8.1.2, iron  
4319 and manganese control, removal by oxidation, detention and filtration, detention; 4.8.1.3, iron  
4320 and manganese control, removal by oxidation, detention and filtration, filtration; 4.8.2, iron and  
4321 manganese control, removal by the lime-soda softening process; 4.8.3-4.8.3(f), iron and  
4322 manganese control, removal by manganese coated media filtration; 4.8.4, iron and manganese  
4323 control, removal by ion exchange; 4.8.6-4.8.6(d), iron and manganese control, sequestration by  
4324 polyphosphates; 4.8.7-4.8.7(e), iron and manganese control, sequestration by sodium silicates;

4325 4.8.8, iron and manganese control, sampling taps; 4.9.3-4.9.3(e), stabilization and corrosion  
4326 control, carbon dioxide addition; 4.9.5(c)-4.9.5(c)(9), stabilization and corrosion control,  
4327 phosphates, design; 4.9.6, stabilization and corrosion control, pH/alkalinity adjustment; 4.9.6.1,  
4328 stabilization and corrosion control, pH/alkalinity adjustment; 4.9.6.1(a), stabilization and  
4329 corrosion control, pH/alkalinity adjustment, chemicals; 4.9.6.1(a)(1.), stabilization and corrosion  
4330 control, pH/alkalinity adjustment, chemicals, caustic soda; 4.9.6.1(a)(2.), stabilization and  
4331 corrosion control, pH/alkalinity adjustment, chemicals, soda ash; 4.9.6.1(a)(3.), stabilization and  
4332 corrosion control, pH/alkalinity adjustment, chemicals, lime; 4.9.6.1(a)(4.), stabilization and  
4333 corrosion control, pH/alkalinity adjustment, chemicals, sodium bicarbonate; 4.9.6.1(b)-  
4334 4.9.6.1(b)(4.), stabilization and corrosion control, pH/alkalinity adjustment, simultaneous  
4335 compliance; 4.9.6.1(c)-4.9.6.1(c)(4.), stabilization and corrosion control, pH/alkalinity  
4336 adjustment, alkalinity/pH adjustment systems; 4.10, taste and odor control; 4.10.1, taste and odor  
4337 control, flexibility; 4.10.2, taste and odor control, chlorination; 4.10.3, taste and odor control,  
4338 chlorine dioxide; 4.10.4-4.10.4(f), taste and odor control, powdered activated carbon; 4.10.8,  
4339 taste and odor control, potassium permanganate; 4.11, membrane technologies for public water  
4340 supplies; 4.11.1-4.11.1(c), membrane technologies for public water supplies, pilot  
4341 study/preliminary investigations; 4.11.2, membrane technologies for public water supplies,  
4342 general design considerations; 4.11.2(a), membrane technologies for public water supplies,  
4343 general design considerations, pretreatment; 4.11.2(b), membrane technologies for public water  
4344 supplies, general design considerations, materials; 4.11.2(c), membrane technologies for public  
4345 water supplies, general design considerations, useful life of membranes; 4.11.2(d), membrane  
4346 technologies for public water supplies, general design considerations, membrane integrity and  
4347 finished water monitoring; 4.11.2(e), membrane technologies for public water supplies, general  
4348 design considerations, bypass water; 4.11.2(f)-4.11.2(f)(6.), membrane technologies for public  
4349 water supplies, general design considerations, membrane cleaning; 4.11.2(g), membrane  
4350 technologies for public water supplies, general design considerations, controls; 4.11.2(h)-  
4351 4.11.2(h)(13.), membrane technologies for public water supplies, general design considerations,  
4352 alarms; 4.11.2(i), membrane technologies for public water supplies, general design  
4353 considerations, compressed air; 4.11.2(j), membrane technologies for public water supplies,  
4354 general design considerations, operation frequency; 4.11.2(k), membrane technologies for public  
4355 water supplies, general design considerations, cross connection control; 4.11.2(l)-4.11.2(l)(4.),  
4356 membrane technologies for public water supplies, general design considerations, redundancy of  
4357 critical components; 4.11.3-4.11.3(h), membrane technologies for public water supplies, systems  
4358 treating surface water or GWUDI; 5.4.7-5.4.7(f), specific chemicals, fluoride; 5.4.8, specific  
4359 chemicals, activated carbon; 9.3, precipitative softening sludge; 9.3(a)-9.3(a)(2.), precipitative  
4360 softening sludge, lagoons; 9.4.1-9.4.1(h), alum sludge, lagoons; 9.5, red water waste; 9.5.1-  
4361 9.5.1(k), red water waste, sand filters; 9.5.2-9.5.2(g), red water waste, lagoons; 9.5.3, red water  
4362 waste, discharge to community sanitary sewer; are herein incorporated by reference.

4363  
4364 ~~(formerly Section 10(a))(b)~~ **Design capacity.** The capacity of the water treatment or  
4365 water production system shall be designed for the maximum daily demand at the design year.

4366  
4367 ~~(formerly Section 10(b))(c)~~ Presedimentation: shall be required for Rraw waters  
4368 which that have episodes of turbidity in excess of 1,000 ~~TU~~ Nephelometric turbidity units (NTU)  
4369 for a period of one week or longer ~~shall be presettled~~.

4370

- 4371 (d) Basins shall meet the following requirements:  
4372  
4373 ~~(formerly Section 10(b)(i))(i)~~ (i) ~~Detention time.~~ Basins without mechanical  
4374 sludge collection equipment shall have a minimum detention time of three days; ~~Basins with~~  
4375 ~~mechanical sludge collection equipment shall have a minimum detention time of three hours.~~  
4376  
4377 ~~(formerly Section 10(b)(i))(ii)~~ (ii) Basins with mechanical sludge collection  
4378 equipment shall have a minimum detention time of three hours; ~~;~~  
4379  
4380 ~~(formerly Section 10(b)(iv))(iii)~~ (iii) ~~Bottom slope.~~ Basins shall have a bottom  
4381 slope to drain of ¼ inch per foot ~~(20 mm/m)~~ without mechanical sludge collection equipment and  
4382 2 two inches per foot ~~(16 cm/m)~~ with mechanical sludge collection equipment; ~~;~~ and  
4383  
4384 ~~(formerly Section 10(b)(iii))(iv)~~ (iv) ~~Drains.~~ Basins shall have a minimum of one, ~~;~~  
4385 ~~8-inch (20 cm)~~ eight-inch drain line to completely dewater the facility.  
4386  
4387 ~~(formerly Section 10(e))(e)~~ (e) ~~Rapid mix.~~ Rapid dispersal of chemicals throughout the  
4388 water shall be accomplished by mechanical mixers, jet mixers, static mixers, or hydraulic jump;  
4389 and shall meet the following requirements:  
4390  
4391 ~~(formerly Section 10(e)(i))(i)~~ (i) ~~Mixing intensity.~~ For mechanical mixers, the  
4392 minimum Gt (velocity gradient (sec-1) x t (sec)) provided at maximum daily flow shall be  
4393 27,000; ~~;~~  
4394  
4395 ~~(formerly Section 10(e)(ii))(ii)~~ (ii) ~~Mixing time.~~ The detention time in a flash  
4396 mixing chamber shall not exceed 30 seconds at maximum daily flow conditions; ~~;~~ and  
4397  
4398 ~~(formerly Section 10(e)(iii))(iii)~~ (iii) ~~Drain.~~ The basin shall have a drain.  
4399  
4400 ~~(formerly Section 10(d))(f)~~ (f) Flocculation shall comply with the following  
4401 requirements; ~~The low velocity agitation of chemically treated water shall be accomplished by~~  
4402 ~~mechanical flocculators.~~  
4403  
4404 ~~(formerly Section 10(d))(i)~~ (i) Mechanical flocculators shall be used for ~~The low~~-velocity  
4405 agitation of chemically treated water ~~shall be accomplished by mechanical flocculators.~~  
4406  
4407 ~~(formerly Section 10(d)(i))(ii)~~ (ii) ~~Detention time.~~ ~~A~~ The minimum detention  
4408 time of 10 minutes ~~detention time~~ shall be provided.  
4409  
4410 ~~(formerly Section 10(d)(iii))(iii)~~ (iii) ~~Drains.~~ ~~Flocculation~~ Basins shall have a  
4411 minimum of one drain line to dewater the facility.  
4412  
4413 ~~(formerly Section 10(d)(ii))(iv)~~ (iv) ~~Mixing intensity.~~ The velocity gradient (G  
4414 value) ~~imposed~~ shall be adjustable ~~by providing~~ through the use of variable speed drives, ~~or shall~~  
4415 ~~be designed to~~ The velocity gradient for single basin systems shall be 30 sec-1, ~~if a single basin~~  
4416 ~~is provided~~, 20 sec-1 in the final basin of a two stage system, and 10 sec-1 in the final basin of a

4417 three stage system. ~~For a single speed drive system, the tip speed of the mixer shall not exceed 3~~  
4418 ~~feet per second (0.91 m/sec). Variable speed drives shall provide tip speeds of 0.5 to 3.0 feet per~~  
4419 ~~second (0.15-0.91 m/sec).~~

4420  
4421 ~~(formerly Section 10(d)(ii))(v)~~ For a single speed drive system, ~~t~~The tip  
4422 speed for a single speed drive system of the mixer shall not exceed 3 feet per second ~~(0.91~~  
4423 ~~m/sec) (ft/sec)~~. Variable speed drives shall provide tip speeds ~~of~~ between 0.5 ~~to~~ and 3.0 ~~feet per~~  
4424 ~~second (0.15-0.91 m/sec) ft/sec~~.

4425  
4426 ~~(formerly Section 10(d)(iv))(vi)~~ Piping. The velocity of flocculated water  
4427 through pipes or conduits to settling basins shall not be less than 0.5 ft/sec or greater than 1.5 ~~feet~~  
4428 ~~per second (0.15-0.46 m/sec) ft/sec~~.

4429  
4430 ~~(formerly Section 10(e))(g)~~ Sedimentation basins shall comply with the following  
4431 requirements:

4432  
4433 ~~(formerly Section 10(e)(i))(i)~~ Diameter. The maximum diameter in circular basins  
4434 shall be 80 feet.

4435  
4436 ~~(formerly Section 10(e)(iv))(ii)~~ Side water depth. The minimum basin side  
4437 water depth shall be 8 eight feet ~~(2.43 m)~~ if mechanical sludge collection equipment is provided  
4438 or ~~basins or~~ basin sludge hopper segments are less than 100 square feet ~~(9.3 m)~~ in surface area  
4439 and 15 feet ~~(4.6 m)~~ if basins are manually cleaned. ~~Mechanical sludge collection equipment~~  
4440 ~~includes mechanically driven drives that use scrapers or differential water level to collect the~~  
4441 ~~sludge.~~

4442  
4443 ~~(formerly Section 10(e)(v))(iii)~~ Freeboard. The outer walls of the settling  
4444 basins shall extend at least 12 inches ~~(30.5 cm)~~ above the surrounding ground and provide at  
4445 least 12 inches ~~(30.5 cm)~~ of freeboard to the water surface. Where the basin walls are less than 4  
4446 four feet ~~(1.22 m)~~ above the surrounding ground, a fence or other debris barrier shall be provided  
4447 on the wall.

4448  
4449 ~~(formerly Section 10(e)(xi))(iv)~~ Drainage. Basin bottoms shall slope toward  
4450 the drain at not less than 1 one inch per foot ~~(8 cm/m)~~ where mechanical sludge collection  
4451 equipment is provided and ¼ inch per foot ~~(2 cm/m)~~ where no mechanical sludge collection  
4452 equipment is provided.

4453  
4454 ~~(formerly Section 10(e)(ii))(v)~~ Overflow rate. The basin overflow rate shall  
4455 not exceed 1,000 gpd/ft<sup>2</sup> ~~(41 m<sup>3</sup>/m<sup>2</sup>d)~~ at design conditions.

4456  
4457 ~~(formerly Section 10(e)(viii))(vi)~~ Sludge collection. Mechanical sludge  
4458 collection shall be provided ~~if~~ settleable organics are present in the water or if ~~there is a history~~  
4459 ~~of organically related taste and odor problems, mechanical sludge collection shall be provided~~  
4460 the source water exceeds secondary maximum contaminant levels identified at 40 CFR 143.3.

4461

4462 ~~(formerly Section 10(e)(ix))(vii)~~ Sludge removal. ~~Sludge removal design~~  
4463 ~~shall provide that sludge pipes~~ for removing sludge shall ~~be~~ not be less than ~~6 six~~ inches ~~(15.2~~  
4464 ~~cm)~~ in diameter and arranged to facilitate cleaning. Valves on ~~the~~ sludge lines shall be located  
4465 outside the tank.

4466  
4467 ~~(formerly Section 10(f))(h)~~ Facilities with ~~S~~softening sedimentation – or clarification.  
4468 ~~Conventional sedimentation—clarification as described above shall be provided in softening~~  
4469 ~~operations, except for softening~~ softened a groundwater supply sources of constant quality.  
4470 ~~Where a groundwater supply is softened, the requirements may be modified as follows~~ shall  
4471 meet the following requirements:

4472  
4473 ~~(formerly Section 10(f)(i))(i)~~ Overflow rate. The basin overflow rate ~~at the design~~  
4474 ~~flow~~ shall not exceed ~~2,100~~ 21,000 gpd/ft<sup>2</sup> ~~(86 m<sup>3</sup>/m<sup>2</sup>-d)~~ at the design flow; and

4475  
4476 ~~(formerly Section 10(f)(ii))(ii)~~ Sludge. Mechanical sludge removal shall be  
4477 provided and shall be designed to handle a load of 40 lbs/~~foot~~ ft ~~(60 kg/m)~~ of collector ~~scraper~~  
4478 scraper arm length.

4479  
4480 ~~(formerly Section 10(g))(i)~~ Solids contact units. ~~These treatment~~ Solids contact units  
4481 are acceptable for combined softening and clarification of well water where water quality  
4482 characteristics are not variable and the flow rates are uniform and consistent. ~~The Solids contact~~  
4483 ~~units shall be designed to meet the criteria detailed previously~~ meet the requirements of  
4484 paragraphs (c) and (e) of this Section, and may be considered under the following circumstances:

4485  
4486 ~~(formerly Section 10(g)(i))(i)~~ Such Solids contact units may be considered for use  
4487 as clarifiers without softening when they are designed ~~to meet the criteria detailed in the~~ as  
4488 ~~conventional sedimentation—clarification—units; and~~

4489  
4490 ~~(formerly Section 10(g)(ii))(ii)~~ These Solids contact units may ~~also~~ be used  
4491 for other treatment ~~purposes; processes~~ such as rapid mixing; or flocculation; ~~etc.~~, when the  
4492 individual components of the ~~solids contact~~ units are designed ~~in accordance with the design~~  
4493 ~~criteria~~ for that individual specific treatment process ~~as described above~~.

4494  
4495 ~~(formerly Section 10(h))(j)~~ Settling tube clarifiers. ~~Shallow depth sedimentation~~  
4496 ~~devices or tube clarifier systems of the essentially horizontal or steeply inclined types~~ Tube  
4497 clarifiers that are horizontal or steeply inclined may be used when designed as follows:

4498  
4499 ~~(formerly Section 10(h)(iv))(i)~~ Loading rates. The maximum ~~overflow~~ rate  
4500 shall be less than 2.0 ~~gpm/sq ft (62.7 m<sup>3</sup>/m<sup>2</sup>-d)~~ gpm/ft<sup>2</sup> based on the surface area of the basin  
4501 covered by the tubes;:

4502  
4503 ~~(formerly Section 10(h)(iii))(ii)~~ Tube placement. ~~The T~~tops of the tubes  
4504 shall be more than 12 inches ~~(0.3 m)~~ from the underside of the launder and more than 18 inches  
4505 ~~(0.46 m)~~ from the water surface; and ~~(formerly Section 10(h)(v)) T~~the spacing between of the  
4506 effluent launders shall not ~~exceed~~ be more than three times the distance from the water surface to  
4507 the top of the tube modules;:



4508  
4509 ~~(formerly Section 10(h)(i))(iii)~~ (iii) ~~Sludge removal.~~ Sludge shall be removed  
4510 using 45-~~degree~~ or steeper hoppers bottoms, ~~or~~ mechanical devices that move the sludge to  
4511 hoppers, or devices that remove settled sludge from the basin floor using differential hydraulic  
4512 level-; and

4513  
4514 ~~(formerly Section 10(h)(i))(iv)~~ (iv) ~~Tube cleaning.~~ A method of tube cleaning  
4515 shall be provided. ~~This that~~ may include a provisions for ~~obtaining~~ a rapid reduction in clarifier  
4516 water surface elevation, a water jet spray system, or an air scour system. ~~Where~~ If cleaning is  
4517 automatic, controls shall ~~be provided to~~ cease clarifier operation during tube cleaning and a 20-  
4518 minute rest period.

4519  
4520 ~~(formerly Section 10(i))(k)~~ (k) Filtration-systems shall comply with the following  
4521 requirements:

4522  
4523 ~~(formerly Section 10(i)(i))(i)~~ (i) ~~Pressure granular media filters.~~ Vertical or  
4524 horizontal pressure filters shall not be used for on ~~filtration of~~ surface waters. Pressure filters  
4525 may be used for groundwater filtration, including iron and manganese removal.

4526  
4527 ~~(formerly Section 10(i)(ii)(A))(A)~~ (A) Slow rate sand filters. ~~These types of~~  
4528 ~~filters~~ may be used when maximum ~~raw water~~ turbidity is less than 50 NTUs and the turbidity  
4529 present is not ~~attributable to~~ caused by colloidal clay-; and ~~Maximum color shall not exceed 30~~  
4530 ~~units.~~

4531  
4532 ~~(formerly Section 10(i)(ii)(A))(B)~~ (B) Maximum color shall not exceed 30  
4533 units.

4534  
4535 ~~(formerly Section 10(i)(ii)(B)(III))(ii)~~ (ii) Washwater troughs shall comply  
4536 with the following requirements. ~~Washwater troughs shall be constructed to provide for not more~~  
4537 ~~than 6 feet (1.8 m) clear distance between troughs. The troughs shall not cover more than 25~~  
4538 ~~percent of filter area.;~~

4539  
4540 ~~(formerly Section 10(i)(ii)(B)(III))(A)~~ (A) The Washwater troughs shall  
4541 not cover more than 25 percent of the filter area-;

4542  
4543 ~~(formerly Section 10(i)(ii)(B)(III)(1.))~~ (B) The Mminimum clearance  
4544 distance between the bottom of the trough and the top of the unexpanded media shall be 12  
4545 inches ~~(30.5 cm);~~

4546  
4547 ~~(formerly Section 10(i)(ii)(B)(III)(2.))~~ (C) The Mminimum distance  
4548 between the weir of the trough and the unexpanded media shall be 30 inches ~~(0.76 m);~~

4549  
4550 ~~(formerly Section 10(i)(ii)(B)(III))(D)~~ (D) ~~Washwater troughs shall be~~  
4551 ~~constructed to provide for not~~ There shall be no more than 6 six feet ~~(1.8 m)~~ clear distance  
4552 between troughs-;

4553

4554 ~~(formerly Section 10(i)(ii)(B)(III)(3)(E)~~ The trough and ~~washwater~~  
4555 ~~waste wastewater~~ line shall be sized ~~to carry~~ for a filter backwash rate of 20 gpm/ft<sup>2</sup> ~~(1181~~  
4556 ~~m<sup>3</sup>/m<sup>2</sup>-d)~~ plus a surface wash rate of 2.0 gpm/ft<sup>2</sup> ~~(118 m<sup>3</sup>/m<sup>2</sup>-d);~~  
4557

4558 ~~(formerly Section 10(i)(ii)(B)(IV)(1.))~~(F) The backwash system  
4559 shall be sized to provide a minimum backwash ~~flow rate~~ flowrate of 20 gpm/ft<sup>2</sup> ~~(1181 m<sup>3</sup>/m<sup>2</sup>-d)~~.  
4560 ~~Washwater storage shall be designed to provide two 20 minute washes in rapid succession.~~  
4561 ~~Where multiple units are not required and only one filter compartment is present, backwash~~  
4562 ~~storage capabilities may be reduced to provide one 20 minute backwash. Where pumps are used~~  
4563 ~~to provide backwash to the filter or to supply water to a washwater tank, the washwater pumps~~  
4564 ~~shall be in duplicate, or a rate necessary to provide a 50 percent expansion of the filter bed;~~  
4565

4566 ~~(formerly Section 10(i)(ii)(B)(IV)(1.))~~(G) The system and Washwater  
4567 wash water storage shall be designed to provide two, 20-minute washes in rapid succession ~~and~~  
4568 shall meet the following requirements:  
4569

4570 ~~(formerly Section 10(i)(ii)(B)(IV)(1.))~~(I) Where multiple units  
4571 are not required and only one filter compartment is present, backwash storage capabilities may  
4572 be reduced to provide one 20 minute backwash. If only one filter is provided, the backwash  
4573 system needs to provide only one 20-minute backwash; and  
4574

4575 ~~(formerly Section 10(i)(ii)(B)(IV)(1.))~~(II) Where If pumps are  
4576 used to provide convey backwash water to the filter(s) or to supply water to a the washwater  
4577 wash water tank, ~~the washwater~~ two equivalent pumps shall be ~~in duplicate~~ provided.  
4578

4579 ~~(formerly Section 10(i)(ii)(B)(IV)(2.))~~(H) The backwash and surface  
4580 ~~wash-washwater supply~~ Washwater shall be filtered and disinfected;:  
4581

4582 ~~(formerly Section 10(i)(ii)(B)(IV)(3.))~~(I) The Washwater wastewater  
4583 rate shall be controlled ~~by a separate valve, manual or automatic,~~ on the main ~~washwater~~ wash  
4584 water line. ~~Washwater~~ and the flow rate flowrate shall be metered and indicated;:  
4585

4586 ~~(formerly Section 10(i)(ii)(B)(IV)(4.))~~(J) Air-assisted backwash  
4587 systems may be used when the design precludes disturbing the gravel support ~~and the the~~  
4588 minimum flowrate for air-assisted backwash shall be 12 gpm/ft<sup>2</sup>;  
4589

4590 ~~(formerly Section 10(i)(ii)(B)(IV)(5.))~~(K) A surface wash system shall  
4591 be provided ~~and shall meet the following requirements: The system shall be capable of~~  
4592 ~~supplying 0.5 gpm/ft<sup>2</sup> (29.5 m<sup>3</sup>/m<sup>2</sup>-d) for system with rotating arms and 2.0 gpm/ft<sup>2</sup> (118~~  
4593 ~~m<sup>3</sup>/m<sup>2</sup>-d) with fixed nozzles, at a minimum pressure of fifty (50) psi (344 kPa). The surface~~  
4594 ~~wash shall use filtered and disinfected water or air and filtered disinfected water The supply~~  
4595 ~~system shall be provided with adequate backflow prevention.~~  
4596

4597 ~~(formerly Section 10(i)(ii)(B)(IV)(5.))~~(I) The system shall be  
4598 capable of supplying 0.5 gpm/ft<sup>2</sup> ~~(29.5 m<sup>3</sup>/m<sup>2</sup>-d)~~ for a system with rotating arms and 2.0 gpm/ft<sup>2</sup>  
4599 ~~(118 m<sup>3</sup>/m<sup>2</sup>-d)~~ with for fixed nozzles, at a minimum pressure of fifty (50) psi ~~(344 kPa); and~~

4600  
4601 ~~(formerly Section 10(i)(ii)(B)(IV)(5.))~~(II) The surface wash  
4602 ~~shall use filtered and disinfected water or air and filtered disinfected water~~ can be air-assisted.  
4603 ~~The supply system shall be provided with adequate backflow prevention.~~

4604  
4605  
4606 ~~(formerly Section 10(i)(ii)(B)(IV)(5.))~~(L) The Both backwash and  
4607 surface wash supply systems shall be provided with adequate backflow prevention.;

4608  
4609 ~~(formerly Section 10(i)(ii)(B)(V)(3.))~~(iii) ~~Anthracite for s~~Single media beds:  
4610 shall use either ~~C~~clean crushed anthracite or a ~~combination of sand and anthracite~~ may be used  
4611 mixture, Such the media shall have an effective size ~~from of~~ 0.45 mm to ~~0.55 mm,~~ and a  
4612 uniformity coefficient not greater than 1.65, and shall meet the following requirements:

4613  
4614 ~~(formerly Section 10(i)(ii)(B)(V)(4.))~~(A) Gravel. When gravel is used  
4615 as a supporting media, ~~gravel it~~ shall consist of coarse aggregate in which ~~a high proportion of~~  
4616 ~~the particles are~~ most of it is rounded round and ~~tend toward a generally spherical or~~  
4617 equidimensional of similar size and shape. ~~It shall possess sufficient strength and hardness to~~  
4618 ~~resist degradation during handling and use, be substantially free of harmful materials, and exceed~~  
4619 ~~the minimum density requirement. The gravel shall meet the requirements of AWWA B100.~~

4620  
4621 ~~(formerly Section 10(i)(ii)(B)(V)(4.))~~(B) ~~It~~Gravel as supporting media  
4622 shall ~~possess~~have sufficient strength and hardness to resist degradation during handling and use,  
4623 ~~be substantially free of harmful materials, and exceed the minimum density requirements.;~~ and

4624  
4625 ~~(formerly Section 10(i)(ii)(B)(V)(4.))~~(C) The gravel shall ~~meet also~~  
4626 comply with the requirements of AWWA B100 specifications.

4627  
4628 ~~(formerly Section 10(i)(ii)(B)(V)(6.))~~(iv) Dual media: ~~C~~coal sand  
4629 filters shall consist of a coarse layer of coal ~~layer~~ not less than 15 inches deep above a layer of  
4630 fine sand not less than eight inches deep on a torpedo sand or garnet layer of support not less  
4631 than three inches on gravel support. ~~The media shall consist of not less than 8 inches (20 cm) of~~  
4632 ~~sand and 15 inches (0.38 m) of coal on a torpedo sand or garnet layer support of not less than 3~~  
4633 ~~inches (7.8 cm) on the gravel support.~~

4634  
4635 ~~(formerly Section 10(i)(ii)(B)(VI))~~(v) Filter bottoms: ~~Acceptable filter~~  
4636 ~~bottoms~~ and strainer systems shall be limited to pipe, perforated pipe laterals, tile block, and  
4637 perforated tile block. Perforated plate bottoms or plastic nozzles shall not be used.

4638  
4639 ~~(formerly Section 10(i)(ii)(B)(VII))~~(vi) Appurtenances: Every filter shall  
4640 have: ~~influent and effluent sampling taps; indicating loss of head gauge; indicating effluent~~  
4641 ~~turbidimeter; a waste drain for draining the filter compartment to waste; and a filter rate flow~~  
4642 ~~meter. Every filter shall provide polymer feed facilities including polymer mixing and storage~~  
4643 ~~tank and at least one feed pump for each filter compartment. On plants having a capacity in~~  
4644 ~~excess of 0.5 MGD, recorders shall be provided on the turbidimeters.~~

4645

4646 ~~(formerly Section 10(i)(ii)(B)(VII))(A)~~ iInfluent and effluent  
4647 ~~sampling~~ taps;  
4648  
4649 ~~(formerly Section 10(i)(ii)(B)(VII))(B)~~ A ~~indicating loss of~~ head loss  
4650 gauge;  
4651  
4652 ~~(formerly Section 10(i)(ii)(B)(VII))(C)~~ An indicating effluent  
4653 turbidimeter;  
4654  
4655 ~~(formerly Section 10(i)(ii)(B)(VII))(D)~~ a ~~A~~ waste drain for draining  
4656 the filter ~~compartment~~ component to waste; ~~and~~  
4657  
4658 ~~(formerly Section 10(i)(ii)(B)(VII))(E)~~ a ~~A~~ filter rate ~~flow meter~~  
4659 flow meter;  
4660  
4661 ~~(formerly Section 10(i)(ii)(B)(VII))(F)~~ Every filter shall provide  
4662 ~~p~~Polymer feed facilities including polymer mixing, ~~and~~ storage tank and at least one feed pump  
4663 for each filter compartment-; and  
4664  
4665 ~~(formerly Section 10(i)(ii)(B)(VII))(G)~~ On plants having a capacity  
4666 ~~in excess of 0.5 MGD, r~~Recorders ~~shall be provided~~ on the turbidimeters if the facility has a  
4667 capacity in excess of 0.5 MGD.  
4668  
4669 ~~(formerly Section 10(i)(ii)(B)(VIII))(vii)~~ Filter rate control. Filter rate control  
4670 shall be such that the filter is not surged. The fFilter rate of flow shall not change ~~at a rate greater~~  
4671 more than 0.3 gpm/ft<sup>2</sup> ~~(17.7 m<sup>3</sup>/m<sup>2</sup>-d)~~ per minute. A Filters that stops and restarts during a  
4672 cycle shall have a filter-to-waste system installed. Declining flow rate filters shall not be used  
4673 unless the flow rate for each filter is controlled to a rates less than allowed in ~~10(i)(ii)(B)~~  
4674 paragraph (j)(iii) of this Section and there are four ~~or~~ more individual filters.  
4675  
4676 ~~(formerly Section 10(i)(ii)(B)(IX))(viii)~~ A filter to waste cycle shall be  
4677 provided after the filter backwash operation. The filter to waste cycle shall be at least 10 minutes.  
4678  
4679 ~~(formerly Section 10(i)(ii)(B)(V)(5.))(ix)~~ Multi-media: Filter beds ~~of this type~~  
4680 shall contain a depth of fine media made up of anthracite ~~coal (specific gravity 1.5), specific~~  
4681 ~~gravity 1.5;~~ silica sand (specific gravity 2.6), ~~specific gravity 2.6;~~ and garnet sand or ilemite  
4682 (specific gravity 4.2-4.5), ~~specific gravity 4.2—4.5. (formerly Section 10(i)(ii)(B)(V)(5.)(a.))~~ The  
4683 bBed depths and distribution ~~of the media~~ shall be determined by the water quality;and shall  
4684 meet the following requirements:  
4685  
4686 ~~(formerly Section 10(i)(ii)(B)(V)(5.)(a.))(A)~~ Bed depths and  
4687 ~~distribution shall be determined by the water quality but~~ There shall not be less than 10 inches  
4688 ~~(0.25 m) of fine sand and 24 inches (0.61 m) of coal anthracite;~~ The relative size of the particles  
4689 shall be such that hydraulic grading of the material during backwash will result in a filter bed  
4690 with pore space graded progressively from coarse to fine in the direction of filtration (down)-.  
4691

4692 ~~(formerly Section 10(i)(ii)(B)(V)(5.)(a.))~~(B) The relative size of  
4693 the ~~particles media~~ shall be such that the hydraulic grading of the material during backwash will  
4694 result in a ~~filter bed with~~ pore space ~~graded that~~ progressively goes from coarse to fine in the  
4695 direction of ~~filtration (down) flow~~;

4696  
4697 ~~(formerly Section 10(i)(ii)(B)(V)(5.)(b.))~~ (C) The multi-media shall  
4698 be supported on two layers of special high-density gravel placed above the conventional silica  
4699 gravel supporting bed; ~~The special gravel shall have a specific gravity not less than 4.2. The~~  
4700 ~~bottom layer shall consist of particles passing No. 5 and retained on No. 12 U.S. mesh sieves~~  
4701 ~~and shall be 1 ½ inches (3.8 cm) thick. The top layer shall consist of particles passing No. 12 and~~  
4702 ~~retained on No. 20 U.S. mesh sieves, and shall be 1 ½ inches (3.8 cm) thick.~~

4703  
4704 ~~(formerly Section 10(i)(ii)(B)(V)(5.)(b.))~~ (D) The special gravel  
4705 shall have a specific gravity not less than 4.2;

4706  
4707 ~~(formerly Section 10(i)(ii)(B)(V)(5.)(b.))~~ (E) The bottom layer  
4708 shall consist of particles passing ~~No. U.S. Standard 5 mesh sieves~~ and retained ~~on~~ in No. U.S.  
4709 Standard 12 U.S. mesh sieves and shall be 1 ½ inches ~~(3.8 cm)~~ thick; and

4710  
4711 ~~(formerly Section 10(i)(ii)(B)(V)(5.)(b.))~~ (F) The top layer shall  
4712 consist of particles passing ~~No. U.S. Standard 12 mesh sieves~~ and retained on U.S. Standard No.  
4713 20 U.S. mesh sieves; and shall be 1 ½ inches ~~(3.8 cm)~~ thick.

4714  
4715 ~~(formerly Section 10(j))~~(x) Diatomaceous earth filtration shall comply with the  
4716 following requirements; ~~These types of filters may be used as the filtration process to remove~~  
4717 ~~turbidity from surface waters where turbidities entering the filters do not exceed 25 TU and~~  
4718 ~~where total raw water coliforms do not exceed 100 organisms/100 ml. These filters may be used~~  
4719 ~~where the raw water quality exceeds the above limits when flocculation and sedimentation are~~  
4720 ~~used preceding the filters. Diatomaceous earth filters may also be used for removal of iron from~~  
4721 ~~groundwaters.~~

4722  
4723 ~~(formerly Section 10(j))~~(A) ~~These types of Diatomaceous earth filters~~  
4724 may be used under the following circumstances:

4725  
4726 ~~(formerly Section 10(j))~~(I) ~~filters may be used as the filtration~~  
4727 ~~process t~~To remove turbidity from surface waters where turbidities entering the filters do not  
4728 exceed 25 NTU and where total raw water coliforms do not exceed 100 organisms/100 mL;

4729  
4730 ~~(formerly Section 10(j))~~(II) ~~These filters may be used w~~Where  
4731 the raw water quality exceeds the ~~above~~ previously mentioned limits when flocculation and  
4732 sedimentation are used preceding the filters; and

4733  
4734 ~~(formerly Section 10(j))~~(III) ~~Diatomaceous earth filters may also~~  
4735 ~~be used for removal of~~ To remove iron from groundwaters.

4736

4737 ~~(formerly Section 10(j)(i))(B) Types of filters. The proposed diatomaceous~~  
4738 ~~earth filtration units shall include Ppressure or vacuum diatomaceous earth filtration units will be~~  
4739 ~~considered for approval.~~ type units; and

4740  
4741 ~~(formerly Section 10(j)(ii))(C) Precoat.~~ A precoating system shall  
4742 be provided.

4743  
4744 (D) The proposed diatomaceous earth filtration shall include a  
4745 continuous monitoring turbidimeter with recorder on each filter effluent for plants treating  
4746 surface water.

4747  
4748 (l) All designs that propose supplies of surface water, groundwater under the direct  
4749 influence of surface water, and groundwater that does not meet 40 CFR Part 141 or where other  
4750 treatment is provided, shall include disinfection via one of the following methods:

4751  
4752 (i) Chlorine;

4753  
4754 (ii) Chloramines, recommended only for secondary disinfection;

4755  
4756 (iii) Chlorine dioxide;

4757  
4758 (iv) Ozone;

4759  
4760 (v) Ultraviolet light; or

4761  
4762 (vi) Other disinfecting agents that demonstrate reliable application equipment  
4763 is available and that include testing procedures for a residual that is recognized in Standard  
4764 Methods for the Examination of Water and Wastewater 2018.

4765  
4766 (m) All designs that require disinfection shall demonstrate that:

4767  
4768 (i) The system will maintain a detectable residual throughout the distribution  
4769 system; and

4770  
4771 (ii) The applicant has considered the formation of disinfection byproducts  
4772 when selecting the disinfection.

4773  
4774 ~~(formerly Section 10(k))(n) Disinfection equipment shall comply with the following~~  
4775 ~~requirements: Chlorine, chlorine dioxide, ozone or other disinfectant as approved by the~~  
4776 ~~administrator may be used for disinfection. Where the primary disinfectant is ozone, chlorination~~  
4777 ~~equipment shall be provided to enable maintaining a residual disinfectant throughout the~~  
4778 ~~distribution system. Automatic proportioning of disinfectant feed to flow rate is required where~~  
4779 ~~the plant flow control is automatic.~~

4780  
4781 ~~(formerly Section 10(k)(i))(i) Chlorination equipment shall comply with~~  
4782 ~~NSF/ANSI/CAN 61-2020/NSF/ANSI/CAN 600-2021 and the following requirements:-~~

4783  
4784 ~~(formerly Section 10(k)(i)(A))(A)~~ Type. Solution feed gas chlorinators  
4785 ~~or hypochlorite feeders of the positive displacement type~~ Positive displacement pumps shall be  
4786 provided for solution feed gas chlorinators or hypochlorite feeders;

4787  
4788 ~~(formerly Section 10(k)(i)(E))(B)~~ Diffuser. The chlorine solution  
4789 ~~injection injector/diffuser shall provide a rapid and thorough mix with all the water being treated.~~  
4790 ~~If the application point is to a pipeline discharging to a clearwell, the chlorine shall be added to~~  
4791 ~~the center of the pipe at least 10 pipe diameters upstream of the discharge into the clearwell.;~~

4792  
4793 ~~(formerly Section 10(k)(i)(E))(C)~~ \_\_\_\_\_ If the application point is to a  
4794 pipeline discharging to a clearwell, the chlorine shall be added to the center of the pipe at least  
4795 10 pipe diameters upstream of the discharge into the clearwell.;

4796  
4797 (D) \_\_\_\_\_ Gas chlorinators shall comply with the following requirements:

4798  
4799 ~~(formerly Section 10(k)(i)(F))(I)~~ Injector/Eductor. For gas feed  
4800 ~~chlorinators, t~~The injector/eductor eductor shall be selected based on solution ~~water~~ pressure,  
4801 injector ~~waterflow rate~~ water flowrate, feed point backpressure, and chlorine solution line length  
4802 and size. ~~The maximum feed point backpressure shall not exceed 110 psi (759 kPa). Where~~  
4803 ~~backpressure exceeds 110 psi (750 kPa), a chlorine solution pump shall be used. Gauges shall be~~  
4804 ~~provided for chlorine solution pressure, feed water pressure and chlorine gas pressure, or~~  
4805 ~~vacuum.~~

4806  
4807 ~~(formerly Section 10(k)(i)(F))(II)~~ \_\_\_\_\_ The maximum feed point  
4808 backpressure shall not exceed 110 psi ~~(759 kPa).~~ unless ~~Where backpressure exceeds 110 psi~~  
4809 ~~(750 kPa), a chlorine solution pump shall be is used.;~~ and

4810  
4811 ~~(formerly Section 10(k)(i)(F))(III)~~ \_\_\_\_\_ Gauges shall be provided for  
4812 chlorine solution pressure, feed water pressure and chlorine gas pressure, or vacuum.

4813  
4814 ~~(formerly Section 10(k)(i)(C))(E)~~ Standby equipment. Standby  
4815 equipment of sufficient capacity shall be available to replace the largest chlorinator unit. ~~;~~ except  
4816 ~~for a w~~Well water systems providing no treatment other than disinfection are exempt from the  
4817 requirements of this paragraph (E) and are not required to provide standby chlorination  
4818 equipment.

4819  
4820 ~~(formerly Section 10(k)(ii))(ii)~~ \_\_\_\_\_ Points of application and contact time shall  
4821 comply with the following requirements.;

4822

4823 (A) Filtration types shall comply with the contact time and minimum chlorine  
4824 residuals required in Table 3 of this Section after the appropriate baffling factor has been applied  
4825 to the reactor. Contact times assume a baffling factor of 0.1 unless documentation justifying the  
4826 use of a higher baffling factor is provided. Contact time requirements are based on worst-case  
4827 operating conditions of water temperature of 32.9 degrees Fahrenheit and pH of 9.  
4828  
4829

Table 3. Required Contact Time and Residual by Filtration Type

<u>Filtration Type</u>	<u>Required Contact Time (minutes), 0.4 mg/L minimum chlorine residual</u>	<u>Required Contact Time (minutes), 1.0 mg/L minimum chlorine residual</u>
<u>Conventional Filtration</u>	<u>162.5</u>	<u>73</u>
<u>Direct Filtration, Bag or Cartridge Filtration, Slow Sand Filtration, Diatomaceous Earth Filtration</u>	<u>325</u>	<u>146</u>
<u>Membrane Filtration (MF or UF)</u>	<u>30</u>	<u>12</u>

4830  
4831  
4832 (B) When chlorine is applied to a groundwater source to maintain a  
4833 residual, no contact time is required.  
4834

4835 (o) Systems that propose disinfection via ultraviolet light shall comply with the  
4836 following requirements:  
4837

4838 (i) Proposed designs for ultraviolet light shall include the following  
4839 information in the ultraviolet reactor influent water quality analysis:  
4840

4841 (A) Influent temperature (degrees Fahrenheit);  
4842

4843 (B) UV transmittance (UVT) at a reported wavelength of 254 nm and a  
4844 pathlength of 1 cm;  
4845

4846 (C) A description of the UVT range over a 12-month period;  
4847

4848 (D) Total hardness (mg/L as CaCO<sub>3</sub>);  
4849

4850 (E) pH;  
4851

4852 (F) Alkalinity (mg/L as CaCO<sub>3</sub>);  
4853

4854 (G) Total iron (mg/L) influent < 0.3mg/L;  
4855

4856 (H) Calcium (mg/L); and  
4857



- 4858 (I) Total manganese (mg/L) influent <0.03 mg/L
- 4859
- 4860 (ii) Proposed designs for ultraviolet disinfection systems shall include the
- 4861 following information:
- 4862
- 4863 (A) The maximum, average, and minimum flowrates;
- 4864
- 4865 (B) A matrix that identifies paired flow and ultraviolet treatment values;
- 4866
- 4867 (C) A description of the organisms targeted for inactivation;
- 4868
- 4869 (D) Log inactivation requirements;
- 4870
- 4871 (E) Operating approach (UV intensity vs. calculated dose);
- 4872
- 4873 (F) Maximum and minimum operating pressures;
- 4874
- 4875 (G) Maximum pressure at the UV reactor;
- 4876
- 4877 (H) UV system redundancy;
- 4878
- 4879 (I) Lamp cleaning strategy;
- 4880
- 4881 (J) Mercury trap for broken UV lamps;
- 4882
- 4883 (K) Maximum headloss through the UV reactor;
- 4884
- 4885 (L) A demonstration that the UV reactor(s) shall be hydrostatically
- 4886 tested to 1.5 times the rated operating pressure;
- 4887
- 4888 (M) A demonstration that the UV reactor(s) shall be designed to ensure
- 4889 that plant personnel can change lamps and the UV intensity meter without draining the reactor;
- 4890 and
- 4891
- 4892 (N) A demonstration that the units shall meet NSF/ANSI/CAN
- 4893 Standard 61.
- 4894
- 4895 (iii) Ultraviolet treatment systems shall be designed to comply with the
- 4896 Ultraviolet Disinfection Guidance Manual for the Final LT2ESWTR and the following dose
- 4897 requirements:
- 4898
- 4899 (A) The UV disinfection system shall deliver a validated dose that
- 4900 meets or exceeds the required dose at the end of lamp life, with fouled sleeves.
- 4901
- 4902 (B) The minimum required validated dose used for system design shall
- 4903 incorporate a Combined Age and Fouling Factor (CAF), calculated as:

4904  
4905  
4906  
4907  
4908  
4909  
4910  
4911  
4912  
4913  
4914  
4915  
4916  
4917  
4918  
4919  
4920  
4921  
4922  
4923  
4924  
4925  
4926  
4927  
4928  
4929  
4930  
4931  
4932  
4933  
4934  
4935  
4936  
4937  
4938  
4939  
4940  
4941  
4942  
4943  
4944  
4945  
4946  
4947  
4948  
4949

CAF = EOLL x FF.

EOLL is the ratio of the lamp output at the end of life relative to the new lamp output

FF is the fouling factor.

(C) The EOLL shall be 75 percent of the new lamp output.

(D) The FF shall be:

(I) 0.5 for UV systems with no sleeve wiping system;

(II) 0.75 for UV systems with mechanical wiping only; or

(III) 0.95 for UV systems with a combined online chemical and mechanical cleaning.

(E) The validated dose that meets or exceeds the required dose shall be delivered under maximum flow and design (UVT) condition, when the larger UV unit is out of service.

(iv) Ultraviolet disinfection shall comply with the following validation requirements:

(A) The applicant shall submit the manufacturer's bioassay validation report for the proposed UV reactor with the permit application;

(B) The bioassay testing and results shall demonstrate validation by an independent third party in full compliance with the Ultraviolet Disinfection Guidance Manual for the Final LT2ESWTR;

(C) The owner and engineer shall submit a certification to the Administrator if validation requirements are adjusted and identify each of the equipment and system modifications required to ensure that the appropriate dosage is provided for the inactivation requirements;

(D) Bioassay testing shall evaluate reactor performance over the range of:

(I) Flowrates (maximum, average, and minimum);

(II) UVT from 70 percent to 98 percent (measured at 254 nm, 1 cm path length); and

4950 (III) RED at maximum flowrate and design UVT conditions.

4951  
4952 (E) The bioassay testing shall incorporate the range of design and  
4953 operating conditions described in paragraph (o)(i) of this Section for UV Light;

4954  
4955 (F) Extrapolations to flowrates, UV transmittance values, or UV doses  
4956 outside the range actually tested, are not permitted; and

4957  
4958 (G) Bioassay testing shall also verify that the head loss generated by  
4959 the proposed reactor is less than or equal to the specified limits.

4960  
4961 (v) Ultraviolet disinfection hydraulics shall comply with the following  
4962 requirements:

4963  
4964 (A) The inlet and outlet piping configuration to the UV reactor shall  
4965 result in a UV dose delivery that is equal to or greater than the dose delivered when the UV  
4966 reactor was validated;

4967  
4968 (B) If the UV reactor validation is performed off-site, the applicant  
4969 shall refer to the validation report to determine the validated inlet and outlet conditions that apply  
4970 to the site-specific requirements; and

4971  
4972 (C) Ultraviolet hydraulic piping shall comply with at least one of the  
4973 following requirements:

4974  
4975 (I) The piping configuration shall consist of a minimum of 10  
4976 pipe diameters of straight pipe upstream and five pipe diameters of straight pipe downstream of  
4977 the UV reactors, with additional pipe diameters above the minimum if required by the  
4978 manufacturer's guidelines for electromagnetic or other flowmeter installation;

4979  
4980 (II) The inlet and outlet piping configurations shall be identical  
4981 to those constructed for the UV reactor validation; or

4982  
4983 (III) If on-site validation or custom off-site validation is  
4984 planned, the inlet and outlet piping hydraulics must be designed according to the manufacturer's  
4985 recommendations and to accommodate any site-specific constraints.

4986  
4987 (vi) Ultraviolet control and measurement instrumentation for each reactor shall  
4988 comply with the following requirements:

4989  
4990 (A) Each reactor shall be capable of measuring UV intensity and lamp  
4991 status (on/off);

4992  
4993 (B) For systems that use the calculated dose monitoring strategy, each  
4994 reactor shall be capable of measuring or calculating the UV transmittance;

4995

4996 (C) Piping for each UV reactor shall be sized and configured in  
4997 accordance with the validated operating conditions and maintain equal head loss through each  
4998 reactor over the range of validated flowrates. Each UV reactor shall not be by-passed;  
4999

5000 (D) Each UV reactor train shall have a dedicated flow meter to confirm  
5001 the validated operating conditions;  
5002

5003 (E) UV lamps in the UV reactor shall be submerged at all times during  
5004 operation;  
5005

5006 (F) The specific configuration of the UV reactor(s) within a facility  
5007 will dictate the use of air release, air/vacuum, or combination air valves to prevent air pockets  
5008 and negative pressure conditions and the design shall verify that the UV manufacturer was  
5009 consulted to determine any equipment-specific air release and pressure control valve  
5010 requirements;  
5011

5012 (G) Each UV reactor shall have the piping configured so that it can be  
5013 isolated and removed from service while the other UV reactor(s) remain in service; and  
5014

5015 (H) A booster pump shall be used if the head loss constraints indicate  
5016 that a pump is necessary. The UV reactor shall be sized accordingly.  
5017

5018 (vii) The applicant shall describe the dose monitoring strategy and the  
5019 operational approach for the UV reactor that complies with the approaches described in  
5020 Ultraviolet Disinfection Guidance Manual for the Final LT2ESWTR, part 3.5.2.  
5021

5022 (viii) The cleaning system for each UV reactor shall comply with the following  
5023 requirements:  
5024

5025 (A) Each UV reactor shall be equipped with an automatic online  
5026 mechanical lamp sleeve cleaning system and may include optional chemical cleaning;  
5027

5028 (B) The UV sensor shall include mechanical cleaning capabilities with  
5029 an automatically initiated and controlled cleaning cycle; and  
5030

5031 (C) The UV reactor(s) shall be fully operational and shall provide  
5032 validated dose requirements during system cleaning.  
5033

5034 (ix) The minimum spare parts kept at a facility shall include the following:  
5035

5036 (A) 20 percent of the UV Lamps;  
5037

5038 (B) Five percent of the lamp sleeves; and  
5039

5040 (C) One UV intensity sensor.  
5041

5042 ~~(formerly Section 10(o))(p)~~ Facilities that propose disinfection via Fluoridation and  
5043 defluoridation shall comply with the following requirements:

5044  
5045 ~~(formerly Section 10(o)(i))(i)~~ Fluoride compound storage designs shall  
5046 demonstrate that: ~~Storage tanks shall be covered; all storage shall be inside a building. Storage~~  
5047 ~~tanks for hydrofluosilie acid shall be vented to the atmosphere at a point outside the building.~~

5048  
5049 ~~(formerly Section 10(o)(i))(A)~~ Fluoride Sstorage tanks shall be  
5050 covered;

5051  
5052 ~~(formerly Section 10(o)(i))(B)~~ Aall other storage shall be inside a  
5053 building; and

5054  
5055 ~~(formerly Section 10(o)(i))(C)~~ Storage tanks for of hydrofluosilie  
5056 hydrofluorosilicic acid shall be vented to the atmosphere at a point outside the building.

5057  
5058 ~~(formerly Section 10(o)(i))(ii)~~ Chemical feed equipment. Fluoride feed  
5059 equipment shall meet the following requirements:

5060  
5061 ~~(formerly Section 10(o)(ii)(A))(A)~~ There shall be Sscales or ~~loss of~~  
5062 weight loss recorders ~~shall be provided~~ for dry chemical feeds and the Ffeeders shall be accurate  
5063 to within five percent of any desired feed rate;

5064  
5065 ~~(formerly Section 10(o)(ii)(B))(B)~~ The point of application of  
5066 hydrofluosilie hydrofluorosilicic acid, if into a horizontal pipe, shall be in the lower half of the  
5067 pipe;

5068  
5069 ~~(formerly Section 10(o)(ii)(B))(C)~~ Fluoride compounds shall not be added  
5070 before lime soda ~~softening~~ or ion exchange softening;

5071  
5072 ~~(formerly Section 10(o)(ii)(C))(D)~~ A fluoride solution shall be applied  
5073 by a positive displacement pump having a stroke rate not less than 20 nor more than 95 strokes  
5074 per minute. Fluoride solutions shall not be injected to a point of negative pressure;

5075  
5076 ~~(formerly Section 10(o)(ii)(C))(E)~~ Fluoride The solutions shall not be  
5077 injected ~~to~~ into a point of negative pressure;

5078  
5079 ~~(formerly Section 10(o)(ii)(D))(F)~~ All fluoride feed lines and dilution  
5080 water lines shall be isolated from the potable water supplies by either an air gap above the  
5081 solution tank or a reduced pressure principal backflow ~~preventor~~ preventer;

5082  
5083 ~~(formerly Section 10(o)(ii)(E))(G)~~ Water used for sodium fluoride  
5084 fluoride dissolution solution shall have a hardness not exceeding ~~50 mg/L~~ 45 mg/L; and  
5085 Softening shall be provided for the solution water where hardness exceeds 45 mg/L.

5086

5087 ~~(formerly Section 10(o)(ii)(F))~~(H) Flow meters for treated water flow  
5088 rate and fluoride solution water shall be provided.

5089  
5090 ~~(formerly Section 10(o)(iv)(A))~~(iii) Provisions shall be made to allow the  
5091 transfer of dry fluoride compounds from shipping containers to storage bins or hoppers ~~in such a~~  
5092 ~~way as to~~ that minimize the quantity of fluoride dust ~~which that~~ may enter the room ~~in which~~  
5093 where the equipment is installed. and shall meet the following requirements: The enclosure shall  
5094 be provided with an exhaust fan and dust filter which places the hopper under a negative  
5095 pressure. Air exhausted from fluoride handling equipment shall discharge through a dust filter to  
5096 the outside atmosphere of the building. The discharge shall not be fresh air intake.

5097  
5098 ~~(formerly Section 10(o)(iv)(A))~~(A) ~~The enclosure~~The transfer system  
5099 shall be ~~provided~~equipped with an exhaust fan and dust filter ~~which that~~ places the hopper or  
5100 storage bin under negative pressure.;

5101  
5102 ~~(formerly Section 10(o)(iv)(A))~~(B) Air exhausted from fluoride handling  
5103 equipment shall discharge through a dust filter to the atmosphere outside the building. ~~The~~  
5104 discharge and shall not ~~be located near a building~~ discharge within 50 feet of a fresh air intake  
5105 for the building.; and

5106  
5107 ~~(formerly Section 10(o)(iv)(B))~~(C) A floor drain shall be provided for  
5108 cleaning equipment and maintenance.

5109  
5110 (iv) The following methods are acceptable for fluoride removal:

5111  
5112 ~~(formerly Section 10(o)(vi)(A))~~(A) Activated alumina may be ~~employed~~  
5113 used in open gravity filters ~~tanks~~ or pressure filter tanks. ~~The minimum media depth shall be 5~~  
5114 feet. The units shall not be loaded at a rate exceeding 4 gallons per minute per square foot (236  
5115 m<sup>3</sup>/m<sup>2</sup>-d). The activated alumina media shall be in mesh sizes ranging from 28 to 48.  
5116 ~~Regeneration facilities shall be provided to regenerate the media. These shall include both weak~~  
5117 ~~caustic and weak acid systems.~~

5118  
5119 ~~(formerly Section 10(o)(vi)(A))~~(B) The minimum media depth shall be 5  
5120 five feet.;

5121  
5122 ~~(formerly Section 10(o)(vi)(A))~~(C) The ~~units shall not be loaded~~ loading  
5123 at a rate exceeding shall not exceed 4 gallons per minute per square foot gpm/ft<sup>2</sup> (236 m<sup>3</sup>/m<sup>2</sup>-d).;

5124  
5125 ~~(formerly Section 10(o)(vi)(A))~~(D) The mesh size for the activated  
5126 alumina media shall be in mesh sizes ranging from between #28 to and #48.;

5127  
5128 ~~(formerly Section 10(o)(vi)(A))~~(E) Media Regeneration facilities shall  
5129 be provided ~~to regenerate the media. These~~ and shall include both weak caustic and weak acid  
5130 systems.; and

5131

5132 ~~(formerly Section 10(o)(vi)(B))(F)~~ Bone char filtration or lime softening  
5133 with magnesium addition may be used.

5134  
5135 (v) Water that is unstable due either to natural causes or to subsequent  
5136 treatment shall be stabilized.

5137  
5138 (vi) Facilities shall have the capability of feeding both acid and alkalinity.

5139  
5140 ~~(formerly Section 10(q)(iv))(vii)——Alkali feed.~~ Unstable water created by ion  
5141 exchange softening shall be stabilized by an alkali feed. ~~An alkali feeder shall be provided for all~~  
5142 ~~ion-exchange water softening plants.~~

5143  
5144 ~~(formerly Section 10(q)(v))(viii) Control.~~ Laboratory equipment shall be  
5145 provided ~~for to determining~~ determine the effectiveness of stabilization treatment. This shall  
5146 include testing equipment for hardness, calcium, alkalinity, pH<sub>2</sub> and magnesium; at as-a  
5147 minimum.

5148  
5149 ~~(formerly Section 10(q))(q) Taste and odor control equipment.~~ ~~Provision shall be made~~  
5150 ~~for the control of taste and odor at all surface water treatment plants.~~ shall comply with the  
5151 following requirements:

5152  
5153 ~~(formerly Section 10(q)(v))(i) Granular activated carbon adsorption units.~~  
5154 Open or closed, granular activated carbon ~~contacting~~ adsorption units may be used to absorb  
5155 organics for taste and odor control. ~~by adsorption of organics subject to the following~~  
5156 requirements.: ~~The loading rate shall not exceed 10 gpm/ft<sup>2</sup> (236 m<sup>3</sup>/m<sup>2</sup>-d). The minimum~~  
5157 ~~empty bed contact time shall be 20 minutes. Provisions shall be made for moving carbon to and~~  
5158 ~~from the contactors.~~

5159  
5160 ~~(formerly Section 10(q)(v))(A)~~ The loading rate shall not exceed 10  
5161 gpm/ft<sup>2</sup> ~~(236 m<sup>3</sup>/m<sup>2</sup>-d).~~;

5162  
5163 ~~(formerly Section 10(q)(v))(B)~~ The minimum empty bed contact  
5164 time shall be 20 minutes.;

5165  
5166 ~~(formerly Section 10(s)(i))(C) Adsorption of organics on granular~~  
5167 ~~activated carbon. Water to be treated may be contacted with granular activated carbon.~~ The pH  
5168 of the water shall be less than 9.0 with a turbidity of less than 2 NTU when using packed beds.:  
5169 ~~The turbidity of the applied water shall be less than 2 TU when packed beds are used.~~

5170  
5171 ~~(formerly Section 10(q)(v))(D)~~ There shall be Provisions ~~shall be~~  
5172 ~~made~~ for moving the carbon to and from the contactors.;

5173  
5174 ~~(formerly Section 10(s)(iii)(A))(E) If an upflow countercurrent~~  
5175 ~~contactors is used, it may be either packed or expanded. A single unit is acceptable. If a~~  
5176 ~~downflow contactor is used, two or more beds in parallel are required.~~ Contactors may be

5177 upflow or downflow design. A single unit is acceptable for countercurrent upflow designs.  
5178 Downflow designs shall have two or more parallel units;

5179  
5180 ~~(formerly Section 10(s)(iii)(B))(F)~~ Contactors may shall be designed as  
5181 open gravity ~~units~~; or pressure beds.; ~~They may be constructed of concrete, steel, or fiberglass~~  
5182 ~~reinforced plastic. Steel vessels shall be protected against corrosion by coaltar epoxy coating,~~  
5183 ~~rubber or glass lining, or other means.~~

5184  
5185 (G) Pressure contactors shall have an air-vacuum relief valve fitted  
5186 with a stainless-steel screen to prevent plugging;

5187  
5188 ~~(formerly Section 10(s)(iii)(B))(H)~~ They may be constructed The  
5189 contactor materials of construction shall be concrete, steel, or fiberglass reinforced plastic; and  
5190 shall meet the following requirements:

5191  
5192 ~~(formerly Section 10(s)(iii)(B))(I)~~ Steel vessels shall be  
5193 protected against corrosion by coaltar epoxy coating, rubber or glass lining, or other means.; and

5194  
5195 ~~(formerly Section 10(s)(iii)(B))(II)~~ Inlet and outlet screens shall  
5196 be made of stainless steel or other suitable materials.

5197  
5198 ~~(formerly Section 10(s)(iii)(C))(I)~~ All carbon beds or columns There  
5199 shall be equipped with provisions for flow reversal and bed expansion; ~~that meet the following~~  
5200 requirements: Combination downflow filter contactors shall have backwashing facilities to  
5201 provide up to 50 percent bed expansion and shall meet the same backwash criteria as rapid  
5202 filters.

5203 ~~(formerly Section 10(s)(iii)(C))(I)~~ Combination downflow filter  
5204 contactors shall have bBackwashing facilities to shall provide up to 50 percent bed expansion;  
5205 and

5206  
5207 ~~(formerly Section 10(s)(iii)(C))(II)~~ Backwashing facilities shall  
5208 meet the ~~same~~ backwash criteria as rapid filters.

5209  
5210 ~~(formerly Section 10(q)(vii))(ii)~~ Ozone. If ozone is used for taste and odor  
5211 control, there shall be at least Thirty 10 minutes of contact time ~~must be provided~~ to complete ~~the~~  
5212 all chemical reactions ~~involved. and T~~ the facilities shall be capable of an minimum applied feed  
5213 rate of ozone feed rate of shall be 15 1 mg/L ~~minimum.~~; or the design shall identify a contact  
5214 time and feed rate that demonstrate the application of ozone will not cause an exceedance of the  
5215 maximum contaminant levels identified at 40 CFR 143.3.

5216  
5217 (r) Designs that include the addition of phosphates for stabilization and corrosion  
5218 control shall demonstrate the evaluation of reactions with aluminum and impacts on wastewater  
5219 treatment plants to overcome the secondary impacts of phosphates that may potentially limit  
5220 their use.

5221



5222 (s) Designs that propose anion-exchange treatment shall include a pH/alkalinity feed  
5223 system unless otherwise approved by the Administrator.

5224  
5225 ~~(formerly Section 10(r))(t) Microscreening-~~ Microscreens shall comply with the  
5226 following requirements: ~~A microscreen will be allowed as a mechanical supplement to treatment.~~  
5227 ~~The microscreening shall be capable of removing suspended matter from the water by straining.~~  
5228 ~~It may be used to reduce nuisance organisms and organic loadings. It shall not be used in place~~  
5229 ~~of filtration or coagulation.~~

5230  
5231 ~~(formerly Section 10(r))(i)~~ A microscreen ~~will~~ shall be allowed as a ~~mechanical~~  
5232 supplement to treatment ~~but it shall not be used in place of filtration or coagulation~~;

5233  
5234 ~~(formerly Section 10(r))(ii)~~ The ~~microscreening~~ screen shall be capable of  
5235 removing suspended matter from the water by straining;

5236  
5237 ~~(formerly Section 10(r)(i))(iii)~~ Screens shall be ~~made~~ of a corrosion-  
5238 resistant material, ~~plastic or stainless steel~~;

5239  
5240 ~~(formerly Section 10(r)(ii))(iv)~~ Bypass piping ~~around the unit~~ shall be  
5241 provided ~~around the unit~~;

5242  
5243 ~~(formerly Section 10(r)(iii))(v)~~ There shall be ~~p~~Protection against back  
5244 siphonage ~~shall be provided~~ when potable water is used for washing the screen; and

5245  
5246 ~~(formerly Section 10(r)(iv))(vi)~~ ~~Washwaters~~ Wash water shall be wasted and  
5247 not recycled to the microscreen.

5248  
5249 (u) Membrane technologies shall comply with the following requirements:

5250  
5251 (i) Proposed membrane treatment processes shall comply with the  
5252 requirements of Section 6 of this Chapter. Protocols for pilot plant testing shall incorporate  
5253 guidance or procedures from the US EPA Membrane Filtration Guidance Manual, Chapter 6.

5254  
5255 (ii) All proposed membrane filters shall demonstrate third-party validation for  
5256 the removal of Giardia or Cryptosporidium. Removal efficiency shall be determined through  
5257 challenge testing as outlined in the US EPA Membrane Filtration Guidance Manual and one of  
5258 the following:

5259  
5260 (A) Membranes that are used as final compliance filters of a multiple  
5261 treatment barrier approach shall meet the requirements of 40 CFR Part 141; or

5262  
5263 (B) All surface water or groundwater under direct influence (GWUDI)  
5264 systems using membrane technology shall demonstrate minimum disinfection that meets 4.0-Log  
5265 virus inactivation.

5267 (v) Facilities that propose bag and cartridge filters shall comply with the procedures  
5268 identified in Section 6 of this Chapter and the following requirements:

5269  
5270 (i) Filter performance will be based on Cryptosporidium oocyst removal;

5271  
5272 (ii) The filter shall demonstrate at least a 3-log removal of particle size 1  
5273 micron and above with an associated log reduction credit of 2-logs for Giardia and  
5274 Cryptosporidium;

5275  
5276 (iii) Removal efficiency shall be determined through challenge testing as  
5277 outlined in Toolbox Guidance Manual, Chapter 8 and NSF/ANSI 419-2018;

5278  
5279 (iv) The performance demonstration shall be specific to the corresponding  
5280 housing and type or model of filter. Any other combination of housing and filter that could be  
5281 used for treatment shall also demonstrate filter efficiency;

5282  
5283 (v) Applicants shall include documentation that the proposed bag or cartridge  
5284 filter has received third-party validation for the removal of Giardia and Cryptosporidium;

5285  
5286 (vi) Filter and housing specifications shall include a description of the  
5287 materials of construction, surface area per filter, and the minimum and maximum operating  
5288 pressure, and the specifications shall meet the requirements of NSF/ANSI 419-2018 and the  
5289 Toolbox Guidance Manual, Chapter 8;

5290  
5291 (vii) System components such as housing, bags, cartridges, gaskets, and O-  
5292 rings shall comply with NSF/ANSI/CAN 61 for leaching of contaminants;

5293  
5294 (viii) A means for monitoring the performance of the filter shall be provided and  
5295 shall include at a minimum flow meters and valves, pressure gauges, and sample taps;

5296  
5297 (ix) The proposed design shall specify chemical compatibility limitations;

5298  
5299 (x) A minimum of two filter housings shall be provided;

5300  
5301 (xi) Bag or cartridge filters that are used as final compliance filters of a  
5302 multiple treatment barrier approach shall meet the requirements of 40 CFR Part 141; and

5303  
5304 (xii) All surface water or GWUDI systems using bag or cartridge filter  
5305 technology shall provide at minimum disinfection that meets 4.0-log virus inactivation and 1.0-  
5306 log Giardia inactivation or shall demonstrate that combined filtration and disinfection will  
5307 provide 3-log removal.

5308  
5309 (w) Pre-engineered water treatment plants shall comply with the following  
5310 requirements:

5312 (i) Pre-engineered water treatment plants shall be permitted on a case-by-case  
5313 basis for specific process applications and flow rates. Multiple units may be installed in parallel  
5314 to accommodate flow rates.

5315  
5316 (ii) Pre-engineered water treatment plant equipment shall be designed in  
5317 accordance with NSF/ANSI/CAN 61 and NSF/ANSI/CAN 372;

5318  
5319 (iv) Pre-engineered water treatment plants shall comply with the procedures in  
5320 Section 6 of this Chapter to obtain data that demonstrates the treatment effectiveness of the  
5321 treatment for the source water and the proposed application; and

5322  
5323 (v) Each component and process of the pre-engineered water treatment plant  
5324 shall demonstrate compliance with the applicable design criteria of the respective treatment  
5325 processes of this Chapter.

5326  
5327 (x) Wastes shall be handled and disposed of as follows:

5328  
5329 ~~(formerly Section 10(u)(i))~~(i) Sanitary and laboratory wastes. The sanitary  
5330 and laboratory wastes from water treatment plants, pumping stations, ~~ete.~~or well systems, shall  
5331 not be recycled to any part of the water plant. ~~Waste from these facilities must and shall be~~  
5332 discharged directly to into a sanitary sewer system when feasible, ~~or to an on-site waste~~  
5333 ~~treatment facility permitted by the Wyoming Department of Environmental Quality.~~ or a  
5334 permitted on-site disposal system;

5335  
5336 ~~(formerly Section 10(u)(ii))~~(ii) Brine waste. ~~The waste~~ from ion exchange  
5337 plants, demineralization plants, ~~ete., and other similar facilities~~ may not be recycled to the water  
5338 plant. ~~and shall meet the following requirements:~~ Where discharging to a sanitary sewer, a  
5339 holding tank shall be provided to prevent the overloading of the sewer and interference with the  
5340 waste treatment process. Where disposal to an off-site waste treatment system is proposed, the  
5341 sewer and treatment facility shall have the required capacity and dilution capability.

5342  
5343 ~~(formerly Section 10(u)(ii))~~(A) Where discharging to a sanitary sewer, a  
5344 holding tank shall be provided to prevent the overloading of the sewer and/or interference with  
5345 the waste treatment processes; and ~~The effect of brine discharge to sewage lagoons may depend~~  
5346 ~~on the rate of evaporation from the lagoons.~~

5347  
5348 ~~(formerly Section 10(u)(ii))~~(B) Where disposal to an off-site waste  
5349 treatment system is proposed, it must be demonstrated that the sewer and the treatment facility  
5350 shall have the required capacity and dilution capability. ~~The impact on any treatment system~~  
5351 ~~discharge shall be evaluated.~~

5352  
5353 ~~(formerly Section 10(u)(iii))~~(iii) ~~Lime softening sludge.~~ Acceptable methods  
5354 of-treatment and disposal of lime softening sludge are ~~as follows:~~

5355  
5356 (A) Sludge lagoons, provided that the design of sludge lagoons  
5357 includes:

5358  
5359 ~~(formerly Section 10(u)(iii)(A))(I)~~ for The location of the lagoon  
5360 shall be protected from above the 100-year flood ~~or adequately protected from the 100-year~~  
5361 ~~flood.~~

5362  
5363 ~~(formerly Section 10(u)(iii)(A))(II)~~ There shall be A means of  
5364 diverting surface water runoff so that it does not flow into the lagoons;

5365  
5366 ~~(formerly Section 10(u)(iii)(A))(III)~~ Minimum free board The  
5367 freeboard shall be a minimum of 3 three feet ~~(0.66 m) shall be present.;~~

5368  
5369 ~~(formerly Section 10(u)(iii)(A))(IV)~~ An adjustable decanting  
5370 device for recycling the overflow ~~shall be present.;~~ and

5371  
5372 ~~(formerly Section 10(u)(iii)(A))(V)~~ There shall be aAn accessible  
5373 effluent sampling point.

5374  
5375 ~~(formerly Section 10(u)(iii)(B))(B)~~ Land application of liquid lime  
5376 softening sludge; shall comply with Part E of that demonstrates compliance with Water Quality  
5377 Rules Chapter 11, Part E of the Water Quality Rules and Regulations.

5378  
5379 ~~(formerly Section 10(u)(iii)(C))(C)~~ Disposal at a suitable landfill; shall  
5380 be authorized by the Solid Waste Management Program of the Department of Environmental  
5381 Quality.

5382  
5383 ~~(formerly Section 10(u)(iii)(D))(D)~~ Mechanical dewatering of sludge  
5384 may be employed-used.;

5385  
5386 ~~(formerly Section 10(u)(iii)(E))(E)~~ Recalcination of sludge may be  
5387 employed-used.; and

5388  
5389 ~~(formerly Section 10(u)(iii)(F))(F)~~ Lime sludge drying beds shall not be  
5390 used allowed.

5391  
5392 ~~(formerly Section 10(u)(iv))(iv)~~ Acceptable methods of treatment and  
5393 disposal of Alum sludge-are as follows:

5394  
5395 ~~(formerly Section 10(u)(iv)(A))(A)~~ Lagooning Lagoons may be used as  
5396 a storage and interim disposal method for alum sludge. Lagoons used for storage shall have a  
5397 The volume of alum sludge storage lagoons shall be at least 100,000 gallons (378.5 m<sup>3</sup>) per for  
5398 every 1,000,000 gpd (3,785 m<sup>3</sup>/d) of facility water treatment plant treating capacity.

5399  
5400 ~~(formerly Section 10(u)(iv)(B))(B)~~ Discharge of alum sludge to sanitary  
5401 sewers may be used only when the sewage system has the capability to adequately handle the  
5402 flow and sludge. Alum sludge may be discharged to the sanitary sewer only when the system is  
5403 capable of handling the waste and with the approval of the owner of the sewer system.

5404  
5405 ~~(formerly Section 10(u)(iv)(C))(C)~~ Mechanical dewatering ~~of sludge~~  
5406 may be ~~employed~~ used.

5407  
5408 ~~(formerly Section 10(u)(iv)(D))(D)~~ Alum sludge drying beds may be used.

5409  
5410 ~~(formerly Section 10(u)(iv)(E))(E)~~ Alum sludge may be acid treated and  
5411 recovered.

5412  
5413 ~~(formerly Section 10(u)(iv)(F))(F)~~ Disposal at a suitable landfill ~~shall be~~  
5414 ~~authorized by the Solid Waste Management Program of the Department of Environmental~~  
5415 ~~Quality.~~

5416  
5417 (v) Designs that propose disposal of waste filter wash water from iron and manganese  
5418 removal plants that include sand filters shall demonstrate the inclusion of a separate structure,  
5419 unless otherwise approved by the Administrator.

5420  
5421 **Section 13. ~~Finished Water Storage~~ Chemical Application.**

5422  
5423 ~~(moved to Section 15(b))(a) — General. Steel finished water storage structures shall be~~  
5424 ~~provided using the requirements of the AWWA D100 or AWWA D103. All tank design and~~  
5425 ~~foundation design shall be performed by a registered professional engineer and the plans or~~  
5426 ~~contractor furnished information shall so designate the registered engineer providing the design.~~  
5427 ~~Materials other than steel may be used for water storage tanks.~~

5428  
5429 ~~(i) — Sizing. Storage facilities shall have the capacity to meet domestic~~  
5430 ~~demands, and where required, fire protection storage.~~

5431  
5432 ~~(A) — Water systems serving less than 50,000 gallons (189 m<sup>3</sup>) on the~~  
5433 ~~design average daily demand shall provide clearwell and system storage capacity equal to the~~  
5434 ~~average daily demand.~~

5435  
5436 ~~(B) — Water systems serving from 50,000 to 500,000 gallons (189-1,892~~  
5437 ~~m<sup>3</sup>) on the design average daily demand shall provide clearwell and system storage capacity~~  
5438 ~~equal to the average daily demand plus fire storage, based on recommendations established by~~  
5439 ~~the State Fire Marshall or local fire agency.~~

5440  
5441 ~~(C) — Water systems serving in excess of 500,000 gallons (1,892 m<sup>3</sup>) on~~  
5442 ~~the design average daily demand shall provide clearwell and system storage capacity equal to 25~~  
5443 ~~percent of the design maximum daily demand, plus added fire storage based on~~  
5444 ~~recommendations established by the State Fire Marshall or local fire agency.~~

5445  
5446 ~~(moved to Section 15(c)(iv))(D) — Storage need not be provided in a~~  
5447 ~~well supply system where a minimum of two wells are provided and the maximum hour demand~~  
5448 ~~or fire demand, whichever is greater, can be supplied with the largest well out of service.~~  
5449

5450 (ii) ~~Location of ground level reservoirs.~~

5451

5452 (A) ~~The bottom of reservoirs and standpipes shall be above or~~  
5453 ~~protected from the 100-year flood or highest flood of record, whichever is greater.~~

5454

5455 (B) ~~When the bottom is below normal ground surface, it shall be~~  
5456 ~~placed above the groundwater table. Sewers, drains, standing water, and similar sources of~~  
5457 ~~possible contamination must be kept at least 50 feet (15.2 m) from the reservoir. Watermain pipe,~~  
5458 ~~pressure tested in place to 50 psi (345 kPa) without leakage, may be used for gravity sewers at~~  
5459 ~~distances greater than 20 feet (6.1 m) and less than 50 feet (15.2 m).~~

5460

5461 (C) ~~The top of the reservoir walls shall not be less than 18 inches (0.46~~  
5462 ~~m) above normal ground surface. Clearwells constructed under filters are exempted from this~~  
5463 ~~requirement when the total design gives the same protection.~~

5464

5465 (iii) ~~Protection. All finished water storage structures shall have suitable~~  
5466 ~~watertight roofs which exclude birds, animals, insects, and excessive dust.~~

5467

5468 (iv) ~~Protection from trespassers. Security type fencing, locks on access~~  
5469 ~~manholes, and other precautions shall be provided to prevent trespassing, vandalism, and~~  
5470 ~~sabotage at above ground storage facilities. Below ground level storage facilities may be exempt~~  
5471 ~~from the fencing requirements.~~

5472

5473 (v) ~~Drains. No drain on a water storage structure may have a direct connection~~  
5474 ~~to a sewer or storm drain. Water storage structures drained to sewer or storm drains shall be~~  
5475 ~~drained through piping which allows an air gap such that the drain pipe is at least three pipe~~  
5476 ~~diameters above the ground level at the drain point to the sanitary or storm drain.~~

5477

5478 (vi) ~~Overflow. All water storage structures shall be provided with an overflow~~  
5479 ~~which is brought down to an elevation between 12 and 24 inches (0.3-0.61 m) above the ground~~  
5480 ~~surface, and discharges over a drainage inlet structure or a splash plate. No overflow may be~~  
5481 ~~connected directly to a sewer or a storm drain. All overflow pipes shall be located so that any~~  
5482 ~~discharge is visible.~~

5483

5484 (A) ~~When an internal overflow pipe is used on elevated tanks, it shall~~  
5485 ~~be located in the access tube. For vertical drops on other types of storage facilities, the overflow~~  
5486 ~~pipe shall be located on the outside of the structure.~~

5487

5488 (moved to Section 15(f)(iv))(B) ~~The overflow of a ground level~~  
5489 ~~structure shall open downward and be screened with noncorrodible screen installed within the~~  
5490 ~~pipe at a location least susceptible to damage by vandalism.~~

5491

5492 (C) ~~The overflow pipe shall be of sufficient diameter to permit wasting~~  
5493 ~~of water in excess of the filling rate.~~

5494

5495 ~~(vii) — Access. Finished water storage structures shall be designed with access to~~  
5496 ~~the interior for cleaning and maintenance. Manholes above the waterline shall be framed at least~~  
5497 ~~4 inches (0.1 m) above the surface of the roof at the opening; on ground level structures,~~  
5498 ~~manholes should be elevated a minimum of 24 inches (0.61 m) above the top. The manholes~~  
5499 ~~shall be fitted with a solid watertight cover which overlaps the framed opening and extends down~~  
5500 ~~around the frame at least 2 inches (5 cm). The cover shall be hinged at 1 side and shall have a~~  
5501 ~~locking device. The man hold shall have a minimum inside opening diameter of 24 inches.~~

5502  
5503 ~~(moved to Section 15(i))(viii) Vents. Finished water storage structures shall be~~  
5504 ~~vented. Overflows shall not be considered as vents. Open construction between the sidewall and~~  
5505 ~~roof is not permissible. Vents shall prevent the entrance of surface water and rainwater, and shall~~  
5506 ~~exclude birds and animals.~~

5507  
5508 ~~(moved to Section 15(i)(i))(A) — For elevated tanks and standpipes, 24~~  
5509 ~~mesh noncorrodible screen may be used.~~

5510  
5511 ~~(B) — For ground level structures, the vents shall terminate in an inverted~~  
5512 ~~U construction with the opening a minimum of 24 inches (0.61 m) above the roof and covered~~  
5513 ~~with 24 mesh noncorrodible screen installed within the pipe at a location least susceptible to~~  
5514 ~~vandalism.~~

5515  
5516 ~~(ix) — Roof and sidewall. The roof and sidewalls of all structures shall be~~  
5517 ~~watertight with no openings except properly constructed vents, manholes, overflows, risers,~~  
5518 ~~drains, pump mountings, control ports, or piping for inflow and outflow.~~

5519  
5520 ~~(x) — Painting and/or cathodic protection. Protection shall be given to metal~~  
5521 ~~surfaces by paints or other protective coatings, by cathodic protective devices, or by both.~~  
5522 ~~Materials and procedures shall conform to AWWA Standard D102. Paint systems, after proper~~  
5523 ~~curing, shall not transfer any substance to the water which will be toxic or cause tastes or odors.~~  
5524 ~~Paints containing lead or mercury shall not be used. All paints and other protective coatings shall~~  
5525 ~~be compatible.~~

5526  
5527 ~~(xi) — Disinfection. Finished water storage structures shall be specified to be~~  
5528 ~~disinfected in accordance with AWWA Standard D105. Sampling shall be specified.~~

5529  
5530 ~~(b) — Plant storage.~~

5531  
5532 ~~(i) — Washwater tanks. Washwater tanks shall be sized, in conjunction with~~  
5533 ~~available pump units and finished water storage, to provide the backwash water required by~~  
5534 ~~Section 10 (i). The storage and pumping shall be sized so that a minimum of two filters may be~~  
5535 ~~backwashed in rapid succession.~~

5536  
5537 ~~(moved to Section 15(m)(i))(ii) — Clearwell. Clearwell storage shall be sized,~~  
5538 ~~in conjunction with distribution system storage, to relieve the filters from having to follow~~  
5539 ~~fluctuations in water use. Where water is pumped from clearwater storage to the system, an~~  
5540 ~~overflow shall be provided.~~

5541  
5542 ~~(iii) — Adjacent compartments. Finished water must be separated from~~  
5543 ~~unfinished water in adjacent compartments by double walls.~~

5544  
5545 ~~(moved to Section 15(m)(iii))(iv) — Basins and wetwells. Receiving basins and~~  
5546 ~~pump wetwells for finished water shall be designed as finished water storage structures.~~

5547  
5548 ~~(e) — Hydropneumatic tanks. Hydropneumatic (pressure) tanks may be used as the only~~  
5549 ~~storage facility when the system serves less than 50 homes. When servicing more than 50 homes,~~  
5550 ~~ground or elevated storage designed in accordance with Section 13(a) should be provided.~~  
5551 ~~Pressure tank storage is not to be considered for fire protection purposes. Pressure tanks shall~~  
5552 ~~meet ASME code requirements or local laws and regulations for the construction and installation~~  
5553 ~~of unfired pressure vessels.~~

5554  
5555 ~~(i) — Location. The tank shall be located above normal ground surface and be~~  
5556 ~~completely housed.~~

5557  
5558 ~~(ii) — Sizing. The capacity of the wells and pumps in a hydropneumatic system~~  
5559 ~~shall be at least 10 times the average daily consumption rate. The gross volume of the~~  
5560 ~~hydropneumatic tank, in gallons, shall be at least 10 times the capacity of the largest pump, rated~~  
5561 ~~in gallons per minute. For example, a 250 gpm (1,364 m<sup>3</sup>/d) pump should have a 2,500 gallon~~  
5562 ~~(9.46 m<sup>3</sup>) pressure tank.~~

5563  
5564 ~~(iii) — Piping. The tank shall be plumbed with bypass piping.~~

5565  
5566 ~~(iv) — Appurtenances. Each tank shall have an access manhole, a drain, and~~  
5567 ~~control equipment consisting of pressure gauge, water tight glass, automatic or manual air~~  
5568 ~~blowoff, means for adding air, and pressure operated startstop controls for the pumps.~~

5569  
5570 (a) 2018 TSS, parts 5.0.2(f), chemical application, general, chemical application;  
5571 5.0.3-5.0.3(h), chemical application, general, general equipment design; 5.1.2-5.1.2(e)(4.),  
5572 chemical application, feed equipment, control; 5.1.3-5.1.3(c), chemical application, feed  
5573 equipment, dry chemical feeders; 5.1.4-5.1.4(d), chemical application, feed equipment, positive  
5574 displacement solution feed pumps; 5.1.5-5.1.5(d), chemical application, feed equipment, liquid  
5575 chemical feeders-siphon control; 5.1.6-5.1.6(d), chemical application, feed equipment, cross-  
5576 connection control; 5.1.8-5.1.8(e), chemical application, feed equipment, in-plant water supply;  
5577 5.1.9(a)(1-3), (b), and (d), chemical application, feed equipment, storage of chemicals; 5.1.10-  
5578 5.1.10(j), chemical application, feed equipment, bulk liquid storage tanks; 5.1.11-5.1.11(h),  
5579 chemical application, feed equipment, day tanks; 5.1.12-5.1.12(e), chemical application, feed  
5580 equipment, feed lines; 5.1.13-5.1.3(d); chemical application, feed equipment, handling; 5.1.14-  
5581 5.1.14(b), chemical application, feed equipment, housing; 5.3.2, operator safety, respiratory  
5582 protection equipment; 5.3.3, operator safety, chlorine gas leak detection; 5.4.1(d)(1-5) and (7-  
5583 10), (f), and (h), specific chemicals, chlorine gas; 5.4.1(f) and (h), 5.4.2-5.4.2(b), specific  
5584 chemicals, acids and caustics; 5.4.3-5.4.3(c)(5.), specific chemicals, sodium chlorite; 5.4.4-  
5585 5.4.4(b)(5.), specific chemicals, sodium hypochlorite; are herein incorporated by reference.  
5586



5587 ~~(formerly Section 11(b))~~(b) Chemical application Ffacility designs shall comply with  
5588 the following requirements:;

5589  
5590 ~~(formerly Section 11(b)(i))~~(i) Number of feeders: A separate feeder shall be  
5591 provided used for each chemical applied; and

5592  
5593 ~~(formerly Section 11(b)(viii)(D))~~(ii) All eChemical storage tanks shall be  
5594 constructed of materials ~~which that~~ are resistant to the chemicals which they store ~~stored~~. The  
5595 ~~t~~Tanks shall ~~not lose its~~ maintain structural integrity ~~through chemical action or be subject to~~  
5596 ~~corrosion~~ while in use.

5597  
5598 ~~(formerly Section 8(i)(iv))~~(c) Alarms: Chemical application facilities shall include an alarm for  
5599 Hhigh effluent turbidity, low chlorine residual, and chlorine leaks ~~(when chlorine gas is used)~~  
5600 ~~shall be alarmed at an attended location.~~ The alarm shall be located at an attended location.

5601  
5602 **Section 14. ~~Distribution Systems~~ Pumping Facilities.**

5603  
5604 (a) ~~Materials.~~

5605  
5606 ~~(moved to Section 16(b))(i)~~ ~~Types of commercial pipe approved for water~~  
5607 ~~systems include:~~

5608  
5609 ~~(moved to Section 16(b)(i))(A)~~ ~~PVC water pipe: ASTM D2241, less~~  
5610 ~~than 4" diameter (10 cm); AWWA C900: 4" (10 cm) and larger diameter.~~

5611  
5612 ~~(B)~~ ~~Asbestos cement pressure pipe: AWWA C400.~~

5613  
5614 ~~(moved to Section 16(b)(ii))(C)~~ ~~Ductile iron pipe: AWWA C151.~~

5615  
5616 ~~(moved to Section 16(b)(iii))(D)~~ ~~Glass fiber reinforced~~  
5617 ~~thermosetting resin pressure pipe: AWWA C950.~~

5618  
5619 ~~(moved to Section 16(b)(iv))(E)~~ ~~Polyethelyene: AWWA C901.~~

5620  
5621 ~~(F)~~ ~~Polybutelyene: AWWA C902.~~

5622  
5623 ~~(ii)~~ ~~Used materials. Watermains and valves which have been used previously~~  
5624 ~~for conveying potable water may be reused provided they are in good working order and can~~  
5625 ~~meet these standards. No other used materials may be employed.~~

5626  
5627 ~~(moved to Section 16(c)(iii))~~ ~~Joints. Packing and jointing materials used in the~~  
5628 ~~joints of pipe shall be flexible and durable. Flanged piping shall not be used for buried service~~  
5629 ~~except for connections to valves; push-on or mechanical joints shall be used.~~

5630  
5631 ~~(iv)~~ ~~Service connections. Service connections shall mean and include any~~  
5632 ~~water line or pipe connected to a distribution supply main or pipe for the purpose of conveying~~

5633 ~~water to a building or dwelling. All service connections shall be constructed in conformance with~~  
5634 ~~the Uniform Plumbing Code.~~

5635  
5636 ~~(moved to Section 16(d))(b) — Watermain design.~~

5637  
5638 ~~(i) — Pressure. All watermains, including those not designed to provide fire~~  
5639 ~~protection, shall be sized after a hydraulic analysis based on flow demands and pressure~~  
5640 ~~requirements. The system shall be designed to maintain a minimum pressure of 20 psi (138 kPa)~~  
5641 ~~at ground level at all points in the distribution system under all conditions of flow. The normal~~  
5642 ~~working pressure in the distribution system shall be not less than 35 psi (276 kPa).~~

5643  
5644 ~~(ii) — Diameter. The minimum size of a watermain for providing fire protection~~  
5645 ~~and serving fire hydrants shall be 6 inches (0.15 m) diameter when service is provided from 2~~  
5646 ~~directions, or where the maximum length of 6 inches pipe serving the hydrant from 1 direction~~  
5647 ~~does not exceed 250 feet, or 8 inches (0.2 m) where service is provided from 1 direction only.~~  
5648 ~~Larger size mains shall be provided as necessary to allow the withdrawal of the required fire~~  
5649 ~~flow while maintaining the minimum residual pressure of 20 psi (138 kPa).~~

5650  
5651 ~~(moved to Section 16(d)(i))(iii) — Fire protection. When fire protection is to be~~  
5652 ~~provided, system design shall be such that fire flows can be served.~~

5653  
5654 ~~(iv) — Small mains. Any main smaller than 6 inches (0.15 m) shall be justified by~~  
5655 ~~hydraulic analysis and future water use.~~

5656  
5657 ~~(v) — Hydrants. Only watermains designed to carry fire flows shall have fire~~  
5658 ~~hydrants connected to them.~~

5659  
5660 ~~(vi) — Deadends. Deadends shall be minimized by looping.~~

5661  
5662 ~~(vii) — Flushing. Where deadend mains occur they shall be provided with a~~  
5663 ~~flushing hydrant or blowoff for flushing purposes. Flushing devices shall be sized to provide~~  
5664 ~~flows which will give a velocity of 2.5 feet per second minimum in the watermain being flushed.~~  
5665 ~~No flushing device shall be directly connected to any sewer.~~

5666  
5667 ~~(e) — Valves. Valves shall be provided on watermains so that inconvenience and~~  
5668 ~~sanitary hazards will be minimized during repairs. Valves shall be located at not more than 500~~  
5669 ~~foot (152 m) intervals in commercial districts and at not more than 1 block or 800 foot (244 m)~~  
5670 ~~intervals in other districts.~~

5671  
5672 ~~(d) — Hydrants.~~

5673  
5674 ~~(moved to Section 16(f)(i))(i) Hydrant leads. The hydrant lead shall be a~~  
5675 ~~minimum of 6 inches (0.15 m) in diameter. Valves shall be installed in all hydrant leads.~~

5676  
5677 ~~(moved to Section 16(e)(iii))(ii) — Protection from freezing. Provisions shall be~~  
5678 ~~made to protect fire hydrant leads and barrels from freezing. The use of hydrant weep holes is~~

5679 ~~not allowed when groundwater levels are above the gravel drain area. In these cases it will be~~  
5680 ~~necessary to pump the hydrant dry or use other means of dewatering.~~

5681  
5682 ~~(moved to Section 16(f)(v))(iii)——Drainage. Hydrant drains shall not be~~  
5683 ~~connected to or located within 10 feet (3.05 m) of sanitary sewers or storm drains.~~

5684  
5685 ~~(e)——Air relief valves; Valve, meter and blowoff chambers.~~

5686  
5687 ~~(i)——Air relief valves. In all transmission lines and in distribution lines 16~~  
5688 ~~inches and larger at high points (where the water pipe crown elevation falls below the pipe invert~~  
5689 ~~elevation), provisions shall be made for air relief. Fire hydrants or active service taps may be~~  
5690 ~~substituted for air relief valves on 6 and 8 inch lines. Manholes or chambers for automatic air~~  
5691 ~~relief valves shall be designed to prevent submerging the valve with groundwater or surface~~  
5692 ~~water.~~

5693  
5694 ~~(ii)——Chamber drainage. Chambers, pits or man holes containing valves,~~  
5695 ~~blowoffs, meters, or other such appurtenances to a distribution system, shall not be connected~~  
5696 ~~directly to any storm drain or sanitary sewer, nor shall blowoffs or air relief valves be connected~~  
5697 ~~directly to any sewer. Such chambers or pits shall be drained to the surface of the ground where~~  
5698 ~~they are not subject to flooding by surface water or to absorption pits underground. Where~~  
5699 ~~drainage cannot be provided, a sump for a permanent or portable pump shall be provided.~~

5700  
5701 ~~(moved to Section 16(h))(f)——Excavation, bedding, installation, backfill.~~

5702  
5703 ~~(moved to Section 16(h)(i))(i)Excavation. The trench bottom shall be excavated~~  
5704 ~~for the pipe bell. All rock shall be removed within 6 inches (15.2 cm) of the pipe. The trench~~  
5705 ~~shall be dewatered for all work.~~

5706  
5707 ~~(moved to Section 16(h))(ii)——Bedding. Bedding shall be designed in accordance~~  
5708 ~~with ASTM C12 types A, B, C for rigid pipe and ASTM D2321 types I, II, III for flexible~~  
5709 ~~pipe.~~

5710  
5711 ~~(iii)——Installation. The pipe shall be joined to assure a watertight fitting. Ductile~~  
5712 ~~iron pipe shall be installed in accordance with AWWA 600 and PVC piping shall be installed in~~  
5713 ~~accordance with AWWA manual M23.~~

5714  
5715 ~~(moved to Section 16(k))(iv)——Backfill. Backfill shall be performed without~~  
5716 ~~disturbing pipe alignment. Backfill shall not contain debris, frozen material, unstable material, or~~  
5717 ~~large clods. Stones greater than 3 inches (7.6 cm) in diameter shall not be placed within 2 feet~~  
5718 ~~(0.6 m) of pipe. Compaction shall be to a density equal to or greater than the surrounding soil.~~

5719  
5720 ~~(v)——Cover. All watermains shall be located to protect them from freezing and~~  
5721 ~~frost heave.~~

5722  
5723 ~~(vi)——Blocking. All tees, bends, plugs, and hydrants shall be provided with~~  
5724 ~~reaction blocking, tie rods, or joints designed to prevent movement.~~

5725  
5726           (vii) — ~~Pressure and leakage testing. All types of installed pipe shall be specified~~  
5727 ~~to be pressure tested and leakage tested in accordance with AWWA Standard C600.~~

5728  
5729           (viii) — ~~Disinfection. All new, cleaned, repaired, or reused watermains shall be~~  
5730 ~~specified to be disinfected in accordance with AWWA Standard C601. Specifications shall~~  
5731 ~~include detailed procedures for the adequate flushing, disinfection, and microbiological testing of~~  
5732 ~~all watermains.~~

5733  
5734           ~~(moved to Section 16(l))(g) — Separation of watermains, sanitary sewers and storm~~  
5735 ~~sewers.~~

5736  
5737           (i) — ~~Horizontal and vertical separation from sewer lines. Minimum horizontal~~  
5738 ~~separation shall be 10 feet (3 m) where the invert of the watermain is less than 1.5 feet (0.46 m)~~  
5739 ~~above the crown of the sewer line. Minimum vertical separation shall be 1.5 feet (0.46 m) at~~  
5740 ~~crossings. Joints in sewers at crossings shall be located at least 10 feet (3 m) from water mains.~~  
5741 ~~The upper line of a crossing shall be specially supported. Where vertical and/or horizontal~~  
5742 ~~clearances cannot be maintained, the sewer or water line shall be placed in a separate conduit~~  
5743 ~~pipe.~~

5744  
5745           ~~(formerly Section 14)(g)(ii) — Sewer manholes. No water pipe shall pass through~~  
5746 ~~or come in contact with any part of a sewer manhole.~~

5747  
5748           (h) — ~~Surface water crossings.~~

5749  
5750           (i) — ~~Above water crossings. The pipe shall be adequately supported and~~  
5751 ~~anchored, protected from damage and freezing, and accessible for repair or replacement.~~

5752  
5753           (ii) — ~~Underwater crossings. A minimum cover of 2 feet (0.61 m) shall be~~  
5754 ~~provided over the pipe. When crossing water courses which are greater than 15 feet (4.6 m) in~~  
5755 ~~width, the following shall be provided:~~

5756  
5757                   (A) — ~~The pipe shall be of special construction, having flexible watertight~~  
5758 ~~joints.~~

5759  
5760                   (B) — ~~Valves shall be provided at both ends of water crossings so that the~~  
5761 ~~section can be isolated for testing or repair; the valves shall be easily accessible and not subject~~  
5762 ~~to flooding; and the valve closest to the supply source shall be located in a manhole.~~

5763  
5764           ~~(moved to Section 16(l))(i) — Cross connections.~~

5765  
5766           ~~(moved to Section 16(l))(i)(i) Cross connections. There shall be no water service~~  
5767 ~~connection installed or maintained between a public water supply and any water user whereby~~  
5768 ~~unsafe water or contamination may backflow into the public water supply.~~

5769

5770 ~~(moved to Section 16(1)(i)(A))(A) — Applicability. In order to protect all~~  
5771 ~~public water supplies from the possibility of the introduction of contamination due to cross~~  
5772 ~~connections, the water supplier shall require backflow prevention devices for each water service~~  
5773 ~~connection in accordance with Table 1 which appears at the end of this section, with the~~  
5774 ~~exception of (B)(I) residential water service connections and (B)(II) domestic non-residential~~  
5775 ~~water service connections. The water supplier shall take appropriate actions which may include~~  
5776 ~~immediate disconnection for any water user that fails to maintain a properly installed backflow~~  
5777 ~~prevention device or comply with other measures as identified in Section 14 (i) of these~~  
5778 ~~regulations.~~

5779  
5780 ~~(moved to Section 16(1)(i)(A)(III))(I) Any high hazard non-~~  
5781 ~~residential connection to any public water supply shall be protected by the appropriate backflow~~  
5782 ~~prevention device.~~

5783  
5784 ~~(II) — Any service connection made to facilities constructed under~~  
5785 ~~a permit to construct issued after adoption of this regulation, Section 14 (i), shall be in full~~  
5786 ~~compliance with this section. This requirement applies to all service connections made or~~  
5787 ~~initially activated after the adoption of this regulation.~~

5788  
5789 ~~(moved to Section 16(1)(i)(A)(IV))(III) — Water suppliers shall~~  
5790 ~~establish record keeping and management procedures to ensure that requirements of this~~  
5791 ~~regulation for installation and maintenance of backflow prevention devices are being met.~~

5792  
5793 ~~(moved to Section 16(1)(i)(B))(B) — The method of backflow control,~~  
5794 ~~selected from Table 1, shall be determined based upon the degree of hazard of the cross~~  
5795 ~~connection and the cause of the potential backflow. Hazards shall be classified as high hazard or~~  
5796 ~~low hazard. The potential cause of the backflow shall be identified as being back siphonage or~~  
5797 ~~back pressure.~~

5798  
5799 ~~(moved to Section 16(1)(i)(B)(I))(I) — Residential water service~~  
5800 ~~connections shall be considered to be low hazard back siphonage connections, unless determined~~  
5801 ~~otherwise by a hazard classification.~~

5802  
5803 ~~(moved to Section 16(1)(i)(B)(II))(II) Domestic non-residential~~  
5804 ~~water service connections shall be considered to be low hazard back pressure connections, unless~~  
5805 ~~determined otherwise by a hazard classification conducted by the water supplier. Examples~~  
5806 ~~include schools without laboratories, churches, office buildings, warehouses, motels, etc.~~

5807  
5808 ~~(moved to Section 16(1)(i)(B)(III))(III) — Any water user's~~  
5809 ~~system with an auxiliary source of supply shall be considered to be a high hazard, back pressure~~  
5810 ~~cross connection. A reduced pressure principle backflow device shall be installed at the water~~  
5811 ~~service connection to any water user's system with an auxiliary source of supply.~~

5812  
5813 ~~(moved to Section 16(1)(i)(B)(V))(IV) — All water loading~~  
5814 ~~stations shall be considered high hazard connections. A device, assembly, or method consistent~~  
5815 ~~with Table 1 shall be provided.~~

5816  
5817 ~~(moved to Section 16(1)(i)(B)(VI))(V) — Non-domestic~~  
5818 ~~commercial or industrial water service connections shall be considered to be high-hazard back-~~  
5819 ~~pressure connections, unless determined otherwise by a hazard classification. Examples include~~  
5820 ~~restaurants, refineries, chemical mixing facilities, sewage treatment plants, mortuaries,~~  
5821 ~~laboratories, laundries, dry cleaners, irrigation systems, facilities producing or utilizing~~  
5822 ~~hazardous substances, etc. For some of these service connections, a hazard classification may~~  
5823 ~~result in a determination of a back-siphonage or low-hazard classification. The backflow~~  
5824 ~~prevention device required shall be appropriate to the hazard classification. Where potential high~~  
5825 ~~hazards exist within the non-residential water user's system, even though such high hazards may~~  
5826 ~~be isolated at the point of use, an approved backflow prevention device shall be installed and~~  
5827 ~~maintained at the water service connection.~~

5828  
5829 ~~(moved to Section 16(1)(i)(C))(C) — Determination of the hazard~~  
5830 ~~classification of a water service connection is the responsibility of the water supplier. The water~~  
5831 ~~supplier may require the water user to furnish a hazard classification survey to be used to~~  
5832 ~~determine the hazard classification.~~

5833  
5834 ~~(moved to 5(o))(D) — Hazard classifications shall be conducted by hazard~~  
5835 ~~classification surveyors that are certified by the USC Foundation for Cross-Connection Control~~  
5836 ~~and Hydraulic Research, the American Association of Sanitary Engineers (ASSE), or by another~~  
5837 ~~state certification program approved by the administrator, or by a water distribution system~~  
5838 ~~operator also certified as a backflow device tester employed by the public water supplier for the~~  
5839 ~~service where the survey is being conducted.~~

5840  
5841 ~~(moved to Section 16(1)(i)(E))(E) — All backflow prevention devices~~  
5842 ~~must be in-line serviceable (repairable), in-line testable except for devices meeting ASSE~~  
5843 ~~Standard #1024, and installed in accordance with manufacturer instructions and applicable~~  
5844 ~~plumbing codes.~~

5845  
5846 ~~(moved to Section 16(1)(i)(F))(F) — All backflow prevention devices~~  
5847 ~~must have a certification by an approved third-party certification agency. Approved certification~~  
5848 ~~agencies are:~~

5849  
5850 ~~(moved to Section 16(1)(i)(F)(I))(I) — American Society of Sanitary~~  
5851 ~~Engineers (ASSE),~~

5852  
5853 ~~(moved to Section 16(1)(i)(F)(II))(II) — International Association of~~  
5854 ~~Plumbing/Mechanical officials (IAPMO), and~~

5855  
5856 ~~(moved to Section 16(1)(i)(F)(III))(III) — Foundation for Cross-~~  
5857 ~~Connection Control and Hydraulic Research, University Of Southern California~~  
5858 ~~(USC\_FCCCHR).~~

5859

5860 ~~(moved to Section 16(1)(i)(G))(G) — Backflow prevention devices at~~  
 5861 ~~water service connections shall be inspected and certified by a certified backflow assembly tester~~  
 5862 ~~at the time of installation. Certification of the assembly tester shall be by one of the following:~~

5863  
 5864 ~~(moved to Section 16(1)(i)(G)(I))(I) — The American Society~~  
 5865 ~~Sanitary Engineers (ASSE);~~

5866  
 5867 ~~(moved to Section 16(1)(i)(G)(II))(II) American Backflow~~  
 5868 ~~Prevention Association (ABPA);~~

5869  
 5870 ~~(III) — A state certification program approved by the~~  
 5871 ~~administrator.~~

5872  
 5873 ~~(moved to Section 16(1)(i)(H))(H) — Backflow prevention devices~~  
 5874 ~~installed at high hazard non-residential cross connections shall be inspected and tested on an~~  
 5875 ~~annual basis by a certified backflow assembly tester.~~

5876  
 5877 ~~(moved to Section 16(1)(i)(I))(I) — The administrator may conduct~~  
 5878 ~~inspections of backflow prevention devices. If any device is found to be defective or functioning~~  
 5879 ~~improperly, it must be immediately repaired or replaced. Failure to make necessary repairs to a~~  
 5880 ~~backflow prevention device will be cause for the water service connection to be terminated.~~

5881  
 5882 ~~(moved to Section 16(1)(i)(J))(J) — All public water suppliers shall~~  
 5883 ~~report any high hazard backflow incident within seven (7) days to the Wyoming Department of~~  
 5884 ~~Environmental Quality, Water Quality Division. The backflow incident shall be reported on a~~  
 5885 ~~form provided by the administrator.~~

5886  
 5887 ~~(moved to Section 16(1)(ii))(ii) — Recycling water. Neither steam condensate~~  
 5888 ~~nor cooling water from engine jackets or other heat exchange devices shall be returned to the~~  
 5889 ~~public water supply after it has passed through the water service connection.~~

5890  
 5891 ~~(moved to Section 16(1)(ii) TABLE 1~~  
 5892 ~~Backflow Prevention Devices, Assemblies and Methods~~

5893

Device, Assembly or Method	Degree of Hazard				Notes
	Low Hazard		High Hazard		
	Back- Siphonage	Back- Pressure	Back- Siphonage	Back- Pressure	
Airgap	X		X		See Note 1
Atmospheric Vacuum Breaker	X		X		Not allowed under continuous pressure
Spill-proof Pressure-type Vacuum	X		X		

Double Check Valve Backflow Preventer	X	X			
Pressure Vacuum Breaker	X		X		
Reduced Pressure Principle Backflow	X	X	X	X	See Note 2
Dual Check	X				Restricted to residential services

5894  
5895  
5896  
5897  
5898  
5899  
5900  
5901  
5902  
5903  
5904  
5905  
5906  
5907  
5908  
5909  
5910  
5911  
5912  
5913  
5914  
5915  
5916  
5917  
5918  
5919  
5920  
5921  
5922  
5923  
5924

~~———— Note 1 Minimum Airgap for Water Distribution. For spouts with an effective opening diameter of one-half inch or less, the minimum airgap when the discharge is not affected by side walls shall be one inch. The minimum airgap when the discharge is affected by sidewalls shall be one and one-half inches. For effective openings greater than one-half inch, the minimum airgap shall be two times the effective opening diameter when the discharge is not affected by side walls. The minimum airgap when the discharge is affected by sidewalls shall be three times the effective opening diameter.~~

~~———— Note 2 Extreme Hazards. In the case of any water user’s system where, in the opinion of the water supplier or the administrator, an undue health threat is posed because of the presence of extremely toxic substances or potential back pressures in excess of the design working pressure of the device, the water supplier may require an air gap at the water service connection to protect the public water system.~~

(a) 2018 TSS, parts 6.1-6.1.1(e), location; 6.2, 6.2(b-e), pumping stations; 6.2.1-6.2.1(d), pumping stations, suction well; 6.2.2, 6.2.2(a-b), pumping stations, equipment servicing; 6.3.2, pumps, pump priming; 6.6.1, appurtenances, valves; 6.6.3-6.6.3(d), appurtenances, gauges and meters; 6.6.4-6.6.4(b), appurtenances, water seals; 6.6.5, appurtenances, controls; 6.6.6, appurtenances, standby power; are herein incorporated by reference.

~~(formerly Section 12(f))(b) Stairways and ladders. Stairways or ladders shall be provided between all floors, and in pits or compartments which that must be entered. They shall have handrails on both sides, and treads of non-slip material. The Wyoming Occupational Health and Safety Rules and Regulations shall be complied with.~~

~~(formerly Section 12(g))(c) Heating. Provisions Pumping facilities shall be made for heating heated to maintain a minimum temperature of 40° F degrees Fahrenheit (4° C) if not typically unoccupied and 50° F degrees Fahrenheit (10° C) if normally occupied.~~



5925 ~~(formerly Section 12(h))(d)~~ Pumping station Vventilation: designs shall demonstrate  
5926 that: All accessible pumping station areas shall be ventilated. Ventilation may be continuous or  
5927 intermittent. If intermittent, ventilation in areas normally visited by operating personnel shall be  
5928 started automatically at not greater than 30 minute intervals. Permanently installed drywell  
5929 ventilation shall provide at least 6 air changes per hour if continuous, and 12 air changes per hour  
5930 if intermittent. Intermittent ventilating equipment shall ensure starting upon entry of operating  
5931 personnel. Wetwells shall be designed to permit the use of portable blowers that will exhaust the  
5932 space and continue to supply fresh air during access periods.

5933  
5934 ~~(formerly Section 12(h))(i)~~ All accessible areas of the pumping station that are  
5935 accessible areas shall be ventilated.

5936  
5937 ~~(formerly Section 12(h))(ii)~~ Ventilation may be continuous or intermittent.

5938  
5939 ~~(formerly Section 12(h))(iii)~~ Permanently installed dDrywell ventilation shall  
5940 provide: at least 6 air changes per hour if continuous, and 12 air changes per hour if intermittent.

5941  
5942 ~~(formerly Section 12(h))(A)~~ aAt least ~~6~~ six air changes per hour if  
5943 continuous; and ~~12 air changes per hour if intermittent.~~

5944  
5945 ~~(formerly Section 12(h))(B)~~ At least 30 air changes per hour if  
5946 intermittent; with an automatic start upon operator entry into the area. ventilation in areas  
5947 normally visited by operating personnel shall be started automatically at not greater than 30  
5948 minute intervals. Intermittent ventilating equipment shall ensure starting upon entry of operating  
5949 personnel.

5950  
5951 ~~(formerly Section 12(h))(iv)~~ Wetwells ventilation shall provide 12 continuous air  
5952 changes per hour or 60 intermittent air changes per hour and be designed to permit the use of  
5953 portable blowers that will exhaust the space and ~~continue to~~ supply fresh air during the access  
5954 periods.

5955  
5956 ~~(formerly Section 12(i))(c)~~ Dehumidification: equipment shall be provided in below  
5957 ground pumping stations; a means for dehumidification shall be provided. The facilities  
5958 equipment shall be sized to maintain ~~the a~~ dewpoint at least ~~2~~ two degrees Fahrenheit below the  
5959 coldest anticipated temperature of the water to be conveyed in the pipes.

5960  
5961 ~~(formerly Section 12(k))(f)~~ Sanitary and other conveniences. All pumping  
5962 stations that are manned ~~for~~ four or more hours per day shall be provided with potable water,  
5963 lavatory, and toilet facilities. The Wwastes shall be discharged to the sanitary sewer or ~~to~~ an on-  
5964 site waste treatment system.

5965  
5966 (g) Pumps: design shall comply with the following requirements: At least two  
5967 pumping units shall be provided. With the largest pump out of service, the remaining pump or  
5968 pumps shall be capable of providing the maximum pumping rate of the system.

5970 ~~(formerly Section 12(l))(i)~~ (i) At least two ~~pumping units~~ pumps shall be  
5971 provided. With the largest pump out of service, the remaining pump or pumps shall be capable of  
5972 providing the maximum pumping ~~rate~~ capacity of the system.

5973  
5974 ~~(formerly Section 12(m))(ii)~~ (ii) ~~Suction lift.~~ Pumps shall be selected ~~so~~ such that the  
5975 net positive suction head required ~~at maximum flow~~ (NPSHR) is less than the net positive  
5976 suction head available (NPSHA) minus four (4) feet (1.2 m) based on ~~the~~ hydraulic conditions  
5977 and the altitude of the ~~pumping station~~ installation. If this condition ~~is not met~~ cannot be  
5978 satisfied, ~~then a means of~~ priming shall be provided.

5979  
5980 ~~(iii)(formerly Section 12(n))~~ (iii) ~~Surge control. Piping systems~~ A surge analysis shall  
5981 be ~~designed to withstand the maximum possible surge (water hammer) from the pumping station,~~  
5982 ~~or adequate surge control~~ provided to demonstrate if surge protection devices will be needed to  
5983 protect the piping. Pressure relief valves are not acceptable as surge control.

5984  
5985 ~~(formerly Section 12(a))(iv)~~ (iv) ~~Total dynamic head.~~ The calculated total dynamic  
5986 head ~~rating of~~ for pumping units shall be based on pipe friction, pressure losses from piping pipe  
5987 entrances, exits, appurtenances (~~bends, valves, etc.~~ such as valves and bends), and static head at  
5988 the design flow.

5989  
5990 (v) The station shall have a flow rate indicator and totalizing meter, and a  
5991 method of recording the total water pumped.

5992  
5993 ~~(formerly Section 12(o))(h)~~ (h) Booster pumps shall comply with the following  
5994 requirements:

5995  
5996 ~~(formerly Section 12(o)(i))(i)~~ (i) Booster pumps shall not produce ~~a pressure~~ less  
5997 than 5 psi in suction lines. ~~Where~~ If the suction line has service connections, ~~booster pump intake~~  
5998 the pressure shall be at least 35 psi (~~138 kPa~~) ~~when the pump is in~~ during normal operation and  
5999 shall ~~be provided with~~ have a low-pressure cutoff switch ~~if the suction line pressure is a~~  
6000 minimum of to maintain at least 20 psi (~~69 kPa~~).

6001  
6002 (ii) For booster pumps used for fire suppression, no person shall install or  
6003 maintain a water service connection to any premises where a fire pump has been installed on the  
6004 service line to or within such premises unless the pump is equipped with one of the following:

6005  
6006 (A) A low suction throttling valve or pilot-operated valve installed in  
6007 the discharge piping that maintains positive pressure in the suction piping while monitoring  
6008 pressure in the suction piping through a sensing line. The valve shall throttle the discharge of the  
6009 pump when necessary so that suction pressure will not be reduced below 20 psi gauge when the  
6010 pump is operating; or

6011  
6012 (B) A variable-speed suction limiting control that is used to maintain a  
6013 minimum positive suction pressure at the pump inlet by reducing the pump driver speed while  
6014 monitoring pressure in the suction piping through a sensing line. The limiting control shall be set  
6015 so that the suction pressure will not be reduced below 20 psi gauge while the pump is operating.

6016  
6017 ~~(formerly Section 12(o)(ii))(iii)~~ Automatic or remote controlled led devices  
6018 pumps shall have a range between the start and cutoff pressure ~~which that~~ will prevent the pump  
6019 from cycling ~~of~~ more than ± one start every 15 minutes.

6020  
6021 ~~(formerly Section 12(o)(iii))(iv)~~ In-line booster pumps shall be accessible for  
6022 ~~servicing and repairs~~ maintenance. ~~The~~ There shall be access openings, as needed, ~~and vault~~  
6023 ~~shall be large enough to~~ to allow the remove removal of the pump.

6024  
6025 ~~(formerly Section 12(o))(v)~~ Individual home booster pumps shall not be allowed  
6026 for any individual service from the public water supply main.

6027  
6028 ~~(formerly Section 12(p))(vi)~~ ~~Automatic and remote controlled stations.~~  
6029 ~~Conditions that may affect continuous delivery of water shall be alarmed at an attended location.~~  
6030 Un-manned or remotely controlled pump stations shall have an alarm at an operator attended  
6031 location for any conditions that may affect the continuous delivery of water.

6032  
6033 (i) Pumping facility valves shall comply with the following requirements:

6034  
6035 ~~(formerly Section 12(q)(i))(E)(i)~~ Air release. Air release valves shall be  
6036 provided where the pipe crown is dropped in elevation. The discharge pipe from the valve shall  
6037 have a minimum of an 8-inch air gap and shall be covered with a #24 mesh non-corrodible  
6038 screen.

6039  
6040 ~~(formerly Section 12(q)(i))(C)(ii)~~ Each pump shall either have an individual  
6041 suction line or the suction lines shall be ~~so~~ manifolded such that they ~~will ensure~~ demonstrate  
6042 similar hydraulic and operating conditions.

6043  
6044 **Section 15. Laboratory Requirements Finished Water Storage.**

6045  
6046 ~~(moved to Section 17(b))(a) — Test procedures. Test procedures for analysis of monitoring~~  
6047 ~~samples shall conform to the 15th Edition of Standard Methods for the Examination of Water~~  
6048 ~~and Wastewater.~~

6049  
6050 ~~(moved to Section 17(c))(b) — Testing requirements. All treatment plants shall have the~~  
6051 ~~capability to perform or contract for the self-monitoring analytical work required by the Safe~~  
6052 ~~Drinking Water Act and/or state regulation. All plants shall, in addition, be capable of~~  
6053 ~~performing or contracting the analytical work required to assure good management and control~~  
6054 ~~of plant operation and performance.~~

6055  
6056 ~~(moved to Section 17(d))(c) — Minimum requirements.~~

6057  
6058 ~~(moved to Section 17(d)(i))(i) Location and space. The laboratory shall be located~~  
6059 ~~away from vibrating machinery or equipment which might have adverse effects on the~~  
6060 ~~performance of laboratory instruments or the analyst and shall be designed to prevent adverse~~  
6061 ~~effects from vibration.~~

6062  
6063 (i) ~~Where a full time chemist is proposed to work in the laboratory, a minimum of~~  
6064 ~~400 square feet (37.2 m<sup>2</sup>) of floor space shall be provided in the laboratory. If more than two~~  
6065 ~~persons will be working in the laboratory, 100 square feet (9.3 m<sup>2</sup>) of additional space shall be~~  
6066 ~~provided for each additional person.~~

6067  
6068 (moved to Section 17(d)(ii))(ii) ~~Materials. Walls shall have an easily~~  
6069 ~~cleaned, durable and impervious surface. Two exit doors or openings shall be located to permit a~~  
6070 ~~straight exit from the laboratory; one exit shall be directly to the outside of the building. Panic~~  
6071 ~~hardware shall be used. Interior doors shall have glass windows.~~

6072  
6073 (moved to Section 17(d)(iii))(iii) ~~Cabinets and bench tops. Cabinet and~~  
6074 ~~storage space shall be provided for dust free storage of instruments and glassware.~~

6075  
6076 (moved to Section 17(d)(iii))(iii) ~~Bench top height shall be 30 inches (0.91 m). Tops~~  
6077 ~~should be field joined into a continuous surface with acid, alkali, and solvent resistant cements.~~

6078  
6079 (moved to Section 17(d)(iv))(iv) ~~Hoods. Fume hoods shall be provided where~~  
6080 ~~reflux or heating of toxic or hazardous materials is required. A hood shall not be situated near a~~  
6081 ~~doorway, unless a secondary means of exit is provided. All switches, electrical outlets, and utility~~  
6082 ~~and baffle adjustment handles shall be located outside the hood. Light fixtures shall be~~  
6083 ~~explosion proof. Twenty four hour continuous exhaust capability shall be provided. Exhaust fans~~  
6084 ~~shall be explosion proof.~~

6085  
6086 (moved to Section 17(d)(v))(v) ~~Sinks. The laboratory shall have a minimum~~  
6087 ~~of 2 sinks per 400 ft<sup>2</sup> (37.2 m<sup>2</sup>) (not including cup sinks). Sinks shall be double well with~~  
6088 ~~drainboards and shall be made of epoxy resin or plastic. All water fixtures shall be provided with~~  
6089 ~~reduced pressure zone backflow preventers. Traps constructed of glass, plastic, or lead and~~  
6090 ~~accessible for cleaning shall be provided.~~

6091  
6092 (vi) ~~Ventilation and lighting. Laboratories shall be separately heated and~~  
6093 ~~cooled, with external air supply for 100 percent makeup volume. Separate exhaust ventilation~~  
6094 ~~shall be provided. Ventilation outlet locations shall be remote from ventilation inlets.~~

6095  
6096 (vi) ~~Lighting shall provide 100 foot candles at the bench top.~~

6097  
6098 (vii) ~~Gas. If gas is required in the laboratory, natural gas shall be supplied.~~

6099  
6100 (moved to Section 17(d)(vi))(viii) ~~Water still. Distilled water shall conform to~~  
6101 ~~the quality specified by Standard Methods for the Examination of Water and Wastewater, 15th~~  
6102 ~~Edition.~~

6103  
6104 (ix) ~~Emergency shower and eye wash. All laboratories shall be equipped with~~  
6105 ~~an emergency eye wash and shower that is located within the laboratory.~~

6107 ~~(moved to Section 17(e))(d) — Portable testing equipment. Portable testing equipment~~  
6108 ~~shall be provided where necessary for operational control testing.~~

6109  
6110 (a) 2018 TSS, parts 7.0.1-7.0.1(c), sizing; 7.0.2-7.0.2(b), location of finished water  
6111 storage structures; 7.0.3, protection from contamination; 7.0.4, security; 7.0.5, drains; 7.0.6, stored  
6112 water age; 7.0.9-7.0.9(e), vents; 7.0.10-7.0.10(f), roof and sidewall; 7.0.17-7.0.17(c), painting  
6113 and/or cathodic protection; 7.0.18-7.0.18(c), disinfection; 7.1.1, treatment plant storage, filter  
6114 washwater tanks; 7.2-7.2.4, hydropneumatic tank systems; are herein incorporated by reference.

6115  
6116 ~~(formerly Section 13(a))(b) General. Steel finished water storage structures shall be~~  
6117 ~~provided using the requirements of the AWWA D100 or AWWA D103. All tank design and~~  
6118 ~~foundation design shall be performed by a registered professional engineer and the plans or~~  
6119 ~~contractor furnished information shall so designate the registered engineer providing the design.~~  
6120 ~~Materials other than steel may be used for water storage tanks.~~ Finished water storage structures  
6121 shall comply with the following requirements:

6122  
6123 ~~(formerly Section 13(a))(i) Steel finished water storage structures shall be~~  
6124 ~~provided using the requirements of the AWWA D100 or AWWA D103.~~ Water storage structures  
6125 shall comply with the following standards for storage tanks, standpipes, ground storage  
6126 reservoirs that are described in AWWA M42, clearwells, and elevated storage:

6127  
6128 (A) AWWA D100;

6129  
6130 (B) AWWA D102;

6131  
6132 (C) AWWA D103;

6133  
6134 (D) AWWA D104;

6135  
6136 (E) AWWA D106;

6137  
6138 (F) AWWA D107;

6139  
6140 (G) AWWA D108;

6141  
6142 (H) AWWA D110;

6143  
6144 (I) AWWA D115;

6145  
6146 (J) AWWA D120; and

6147  
6148 (K) AWWA D121;

6149  
6150 ~~(formerly Section 13(a))(ii) All tank design and foundation design shall be~~  
6151 ~~performed by a Wyoming registered professional engineer. and t~~ The plans or contractor-

6152 furnished information shall ~~so designate the registered engineer providing the design~~ be signed  
6153 and sealed by a Wyoming registered professional engineer.

6154  
6155 (iii) All new or modified water storage tanks shall have the inlet and outlet  
6156 connections separated from each other as much as is practical.

6157  
6158 (c) Storage facility designs shall demonstrate:

6159  
6160 (ii) The average daily demand will require a daily fill of 20 percent of the total  
6161 storage volume for surface water sources and 10 percent for groundwater sources.

6162  
6163 (iii) For designs that demonstrate the storage tank has a small daily demand  
6164 and a high fire water storage requirement, or the storage tank water age an average is greater than  
6165 two days, the design shall demonstrate that a a volume equal to at least 20 percent of the tank  
6166 volume will be delivered to the storage tank each time pumping is initiated.

6167  
6168 ~~(formerly Section 13(a)(i)(D))(iv) Storage need not be provided in a well~~  
6169 ~~supply system where~~ For designs with well systems that provide a minimum of two wells ~~are~~  
6170 ~~provided and that can supply either~~ the maximum hourly demand or the fire demand, whichever  
6171 is greater, can be supplied with the largest well out of service storage is not required. These  
6172 systems shall demonstrate that they will provide alternative power for the finished water pumps.

6173  
6174 (d) Storage structure design shall eliminate short-circuiting.

6175  
6176 (e) The minimum inlet velocity shall be 10ft/sec unless demonstration of employed  
6177 mixing system or lower inlet velocity addresses disinfection by-product formation, stratification,  
6178 stagnation, freezing, and other water age issues.

6179  
6180 (f) Overflow and drain lines shall:

6181  
6182 (i) Be protected with a mechanical device such as:

6183  
6184 (A) A sealed flapper valve or duckbill valve; or

6185  
6186 (B) A #24 mesh non-corrodible screen.

6187  
6188 (ii) For overflow lines that are protected with a mechanical device, include  
6189 installation of a #4 mesh non-corrodible screen or finer to prevent the entrance of birds or  
6190 rodents;

6191  
6192 (iii) For overflow lines that are protected with #24 mesh non-corrodible screen,  
6193 demonstrate prevention of screen clogging that would lead to structural storage tank damage;

6194  
6195 ~~(formerly Section 13(a)(vi)(B))(iv) Include installation of the screen within T~~  
6196 the overflow line of a ground level structure shall open downward and be screened with

6197 ~~noncorrodible screen installed within the pipe~~ at a location that is not least susceptible to ~~damage~~  
6198 by vandalism and that allows for the overflow line to be operational during an overflow event;

6199  
6200 (v) Provide access to the screen with the smallest openings for replacement;  
6201 and

6202  
6203 (vi) Demonstrate that the screen with the smallest openings will be the  
6204 outermost screen.

6205  
6206 (g) Overflow designs shall demonstrate the provisions that will be included to prevent  
6207 mechanical devices from freezing shut.

6208  
6209 (h) Overflow lines shall not be considered as vents.

6210  
6211 ~~(formerly Section 13(a)(viii))(i) Vents. Finished water storage structures shall be~~  
6212 ~~vented. Overflows shall not be considered as vents. Open construction between the sidewall and~~  
6213 ~~roof is not permissible. Vents shall prevent the entrance of~~ be designed to protect the tank from  
6214 contaminants including but not limited to surface water, and rainwater, stormwater runoff,  
6215 insects, rodents, and shall exclude birds and animals.

6216  
6217 ~~(formerly Section 13(a)(viii)(A))(i) For elevated tanks and standpipes, All~~  
6218 openings shall be protected with #24 mesh noncorrodible non-corrodible screen may be used or a  
6219 combination of #24 mesh and coarser mesh non-corrodible screen.

6220  
6221 (ii) The design shall demonstrate consideration of site conditions, freezing,  
6222 frosting, and provide justification including precautions for snow depth.

6223  
6224 (A) The design shall demonstrate consideration of frost free or frost  
6225 proof vents; and

6226  
6227 (B) The design shall demonstrate consideration of a pressure/vacuum,  
6228 frost-proof release vents that will need to protect openings with #24 mesh non-corrodible screen.

6229  
6230 (j) Down-turned vent openings shall be at least 24 inches above the nearest  
6231 horizontal surface.

6232  
6233 (k) Elevated tanks shall be designed to remove snow via tank geometry to prevent  
6234 snow build-up clogging vents.

6235  
6236 (l) Vent designs shall include calculations that verify the required volume of flow is  
6237 achievable through the proposed vent pipe and screen combination.

6238  
6239 (m) Finished water plant water storage shall comply with the following requirements:

6240  
6241 ~~(formerly Section 13(b)(ii))(i) Clearwell. Clearwell storage shall be sized,~~  
6242 in conjunction with distribution system storage, to relieve the filters from of having to follow

6243 fluctuations in water use. Where water is pumped from ~~clearwater~~ clearwell storage to the  
6244 system, an overflow shall be provided.

6245  
6246 (ii) If unfinished water is stored in compartments adjacent to finished water,  
6247 the unfinished and finished water shall be separated by double walls.  
6248

6249 ~~(formerly Section 13(b))(iv)(iii) Basins and wetwells.~~ Receiving basins and  
6250  ~~pump wetwells for finished water~~ shall be designed as finished water storage structures and shall  
6251 comply with the requirements of this Section.  
6252

6253 **Section 16. ~~Operation and Maintenance Manuals~~ Distribution Systems.**  
6254

6255 ~~(moved to Section 18(a))(a) Where required. Plant operation and maintenance manuals~~  
6256 ~~are required for each new or modified treatment or pumping facility. The manuals shall provide~~  
6257 ~~the following information as a minimum:~~  
6258

6259 ~~(moved to Section 18(a)(i))(i) Introduction.~~

6260  
6261 ~~(moved to Section 18(a)(ii))(ii) Description of facilities and unit processes~~  
6262 ~~within the plant from influent structures through effluent structures.~~

6263  
6264 ~~(moved to Section 18(a)(iii))(iii) Plant control system.~~

6265  
6266 ~~(moved to Section 18(a)(iv))(iv) Utilities and systems.~~

6267  
6268 ~~(moved to Section 18(a)(v))(v) Emergency operation and response.~~

6269  
6270 ~~(moved to Section 18(a)(vi))(vi) Permit requirements and other regulatory~~  
6271 ~~requirements.~~

6272  
6273 ~~(moved to Section 18(a)(vii))(vii) Staffing needs.~~

6274  
6275 ~~(moved to Section 18(a)(ix))(viii) Index to manufacturer's manuals.~~

6276  
6277 ~~(moved to Section 18(b))(b) When required. Acceptance of the final operation and~~  
6278 ~~maintenance manuals is required prior to plant startup.~~

6279  
6280 ~~(c) Description of facilities. The description of facilities and unit processes shall~~  
6281 ~~include the size, capacity, model number (where applicable) and intended loading rate.~~

6282  
6283 ~~(moved to Section 18(c)(i) Each unit. The manual shall describe each unit,~~  
6284 ~~including the function, the controls, the lubrication and maintenance schedule. The manual shall~~  
6285 ~~also include start-up operations; routine operations; abnormal operations; emergency or power~~  
6286 ~~outage operations; bypass procedures; and safety.~~  
6287



6288                   (ii) ~~Flow diagrams. The manual shall provide flow diagrams of the entire~~  
6289 ~~process, as well as individual unit processes. The flow diagrams shall show the flow options~~  
6290 ~~under the various operational conditions listed above.~~

6291  
6292                   (d) ~~Operating parameters. The O & M manual shall provide the design criteria for~~  
6293 ~~each unit process. The data shall include the number, type, capacity, sizes, etc., and other~~  
6294 ~~information, as applicable.~~

6295  
6296                   (moved to Section 18(c)(iii)(e)) ~~Troubleshooting guide. Each equipment~~  
6297 ~~maintenance manual shall include a section on troubleshooting. These manuals are to be indexed~~  
6298 ~~in the plant O & M manual. The troubleshooting guide shall include typical operation problems~~  
6299 ~~and solutions. The guide shall include a telephone number for factory troubleshooting assistance.~~

6300  
6301                   (f) ~~Emergency procedures. The plant O & M manual shall detail emergency~~  
6302 ~~operations procedures for possible foreseeable emergencies, including power outage, equipment~~  
6303 ~~failure, development of unsafe conditions, and other emergency conditions. The details shall~~  
6304 ~~include valve positions, flow control settings, and other information to ensure continued~~  
6305 ~~operation of the facility at maximum possible efficiency.~~

6306  
6307                   The manual shall also detail emergency notification procedures to be followed to protect  
6308 ~~health and safety under various emergency conditions.~~

6309  
6310                   (g) ~~Safety. The manual shall provide general information on safety in and around the~~  
6311 ~~plant and its components. Each unit process discussion shall include applicable safety procedures~~  
6312 ~~and precautions. For unit processes or operations having extreme hazards (such as chlorine,~~  
6313 ~~closed tanks, etc.), the discussion shall detail appropriate protection, rescue procedures, and~~  
6314 ~~necessary safety equipment.~~

6315  
6316                   (moved to Section 18(c)(iv)(h)) ~~Maintenance manuals. Maintenance manuals shall~~  
6317 ~~be required for each piece of equipment. These manuals must meet the requirements of the~~  
6318 ~~engineer and contractor for installation and startup of equipment. The information included in the~~  
6319 ~~manufacturer's manuals shall not be included in the O & M manual.~~

6320  
6321                   The manual shall have a neatly typewritten table of contents for each volume arranged in  
6322 ~~a systematic order. The general contents shall include product data; drawings; written text as~~  
6323 ~~required to supplement product data for the particular installation; and a copy of each warranty,~~  
6324 ~~bond and service contract issued.~~

6325  
6326                   The manuals for equipment and systems shall include a description of unit and  
6327 ~~component parts; operating procedures; maintenance procedures and schedules; service and~~  
6328 ~~lubrication schedule; sequence of control operation; a parts list; and a recommended spare parts~~  
6329 ~~list.~~

6330  
6331                   (a) 2018 TSS, parts 8.2-8.2.4(b), system design; 8.3, valves; 8.4-8.4.4(d), hydrants;  
6332 8.5-8.5.2(c), air relief valves; 8.6, valve, meter, and blow-off chambers; 8.7.3, installation of  
6333 water mains, cover; 8.7.4, installation of water mains, blocking; 8.7.6, installation of water

6334 mains, pressure and leakage testing; 8.7.7, installation of water mains, disinfection; 8.7.8,  
6335 installation of water mains, external corrosion; 8.7.9, installation of water mains, separation from  
6336 other utilities; 8.8.2-8.8.2(b), separation distances from contamination sources, parallel  
6337 installation; 8.8.3-8.8.3(b), separation distances from contamination sources, crossings; 8.8.6,  
6338 separation distances from contamination sources, sewer manholes, inlets, and structures; 8.9.1,  
6339 surface water crossings, above-water crossings; 8.9.2-8.9.2(c); surface water crossings, under  
6340 water crossings; 8.11.1, water services and plumbing, plumbing; 8.12, service meters; are herein  
6341 incorporated by reference.

6342  
6343 ~~(formerly Section 14(a)(i))(b) Types~~ Distribution systems shall be constructed of  
6344 commercial pipe approved for water systems include that conform to the following standards:

6345  
6346 ~~(formerly Section 14(a)(i)(A))(i)~~ PVC water pipe: ASTM D2241, less  
6347 than 4" diameter (10 cm); AWWA C900: 4" (10 cm) and larger diameter.

6348  
6349 ~~(formerly Section 14(a)(i)(A))(A)~~ ASTM D2241, Less than 4" four  
6350 inches diameter (10 cm), ASTM D 2241; or

6351  
6352 ~~(formerly Section 14(a)(i)(A))(B)~~ AWWA C900: 4" (10 cm) Four  
6353 inches and larger diameter, AWWA C900.

6354  
6355 ~~(formerly Section 14(a)(i)(C))(ii)~~ Ductile iron pipe; AWWA C151;

6356  
6357 ~~(formerly Section 14(a)(i)(D))(iii)~~ Glass fiber reinforced thermosetting resin  
6358 pressure pipe: Fiberglass pressure pipe, AWWA C950; or

6359  
6360 ~~(formerly Section 14(a)(i)(E))(iv)~~ Polyethylene Polyethylene pipe:

6361  
6362 (A) ¾ inch through three inches diameter, AWWA C901;

6363  
6364 (B) Four inches through 65 inches diameter, AWWA C906; or

6365  
6366 (v) Other material submitted with the permit application and approved by the  
6367 Administrator.

6368  
6369 ~~(formerly Section 14(a)(iii))(c)~~ Joints. Packing and jointing materials used in the  
6370 joints of pipe shall be flexible and durable. Flanged piping shall not be used allowed for buried  
6371 service except for connections to valves; push-on or mechanical joints shall be used pipe except  
6372 for connection to valves.

6373  
6374 (d) New water mains shall be sized after the hydraulic analysis required by Section  
6375 9(l)(i) of this Chapter and the design shall demonstrate that:

6376  
6377 ~~((formerly 14(b)(ii))(i)~~ Pressure. All watermains, including those not  
6378 designed to provide fire protection, shall be sized after a hydraulic analysis based on flow  
6379 demands and pressure requirements. The system shall be designed to maintain a minimum

6380 ~~pressure of 20 psi (138 kPa) at ground level at all points in the distribution system under all~~  
6381 ~~conditions of flow. The normal working pressure in the distribution system shall be not less than~~  
6382 ~~35 psi (276 kPa). At maximum day demand plus current State of Wyoming-required fire flow, or~~  
6383 ~~the fire flow of an authority having jurisdiction, the pressure in the municipal distribution system~~  
6384 ~~will not fall below 20 pounds per square inch (psi); and~~

6385  
6386 ~~((formerly 14(b)(ii))(ii))~~ (ii) The normal system working pressure shall be  
6387 greater than 35 psi.

6388  
6389 ~~(formerly Section 14(b)(iii))(e)~~ (e) ~~Fire protection.~~ When fire protection is ~~to be~~  
6390 provided, ~~the system design water main system~~ shall be ~~such that~~ designed to also serve fire  
6391 flows ~~can be served.~~

6392  
6393 ~~(formerly Section 14(d))(f)~~ (f) Hydrants: ~~shall:~~

6394  
6395 ~~(formerly Section 14(d)(i))(i)~~ (i) Hydrant leads. ~~The~~ Have hydrant leads shall be a  
6396 that are a minimum of 6 six inches (~~0.15 m~~) in diameter. ~~Valves shall be installed in all hydrant~~  
6397 ~~leads.~~

6398  
6399 ~~(formerly Section 14(d)(i))(ii)~~ (ii) ~~Have~~ vValves shall be installed in all  
6400 hydrant leads.;

6401  
6402 ~~(formerly Section 14(d)(ii))(iii)~~ (iii) ~~Be~~ Protection-protected from freezing: at  
6403 hydrant leads and barrels. ~~Provisions shall be made to protect fire hydrant leads and barrels from~~  
6404 ~~freezing. The use of hydrant weep holes is not allowed when groundwater levels are above the~~  
6405 ~~gravel drain area. In these cases it will be necessary to pump the hydrant dry or use other means~~  
6406 ~~of dewatering.~~

6407  
6408 ~~(formerly Section 14(d)(ii))(iv)~~ (iv) ~~The use of hydrant weep holes is not~~  
6409 ~~allowed when groundwater levels are above the gravel drain area. In these cases it will be~~  
6410 ~~necessary to pump the hydrant dry or use other means of dewatering.~~ Where groundwater levels  
6411 are above the gravel drain area, hydrants shall be pumped dry or otherwise dewatered and  
6412 hydrant weep holes shall not be used; and

6413  
6414 ~~(formerly Section 14(d)(iii))(v)~~ (v) ~~Drainage.~~ Hydrant ~~Have~~ drains shall ~~not be~~  
6415 that are not connected to or located within 10 feet (~~3.05 m~~) of a sanitary sewers or storm drains.

6416  
6417 ~~(formerly Section 14(e)(i))(g)~~ (g) Fire hydrants or active service taps may be  
6418 substituted for air relief ~~valves on~~ in 6- and 8-inch lines.

6419  
6420 ~~(formerly Section 14(f))(h)~~ (h) ~~Excavation, bedding, installation, backfill.~~ Where  
6421 excavation is performed for distribution systems:

6422  
6423 ~~(formerly Section 14(f)(i))(i)~~ (i) ~~Excavation.~~ The trench bottom shall be excavated  
6424 for the pipe bell ~~bell of the pipe;~~ All rock shall be removed within 6 inches (15.2 cm) of the pipe.  
6425 ~~The trench shall be dewatered for all work.~~

6426  
6427 ~~(formerly Section 14)(f)(i)(ii)~~ All rock shall be removed within 6 six inches ~~(15.2~~  
6428 ~~cm)~~ of the pipe.;

6429  
6430 ~~(formerly Section 14)(f)(i)(iii)~~ \_\_\_\_\_ The trench shall be dewatered for all work.;

6431  
6432 ~~(formerly Section 14)(f)(ii)(i)~~ Bedding-Distribution system B bedding for rigid pipe shall  
6433 be designed in accordance with ASTM C12 ~~-types Classes A, B, or C-for rigid pipe\_ and~~  
6434 Flexible pipe bedding shall be designed in accordance with ASTM D2321 ~~-types Class I, II, or~~  
6435 III -for flexible pipe.;

6436  
6437 (j) Distribution system pipe shall be joined to ensure a watertight fitting and installed  
6438 in accordance with the following standards, as applicable:

6439  
6440 (i) For ductile iron pipe, AWWA C600;

6441  
6442 (ii) For PVC pipe, AWWA M23; and

6443  
6444 (iii) For HDPE pipe, AWWA M55.

6445  
6446 ~~(formerly Section 14)(f)(iv)(k)~~ \_\_\_\_\_ Backfill. Backfill for distribution systems shall:  
6447 ~~be performed without disturbing pipe alignment. Backfill shall not contain debris, frozen~~  
6448 ~~material, unstable material, or large clods. Stones greater than 3 inches (7.6 cm) in diameter shall~~  
6449 ~~not be placed within 2 feet (0.6 m) of pipe. Compaction shall be to a density equal to or greater~~  
6450 ~~than the surrounding soil.~~

6451  
6452 ~~(formerly Section 14)(f)(iv)(i)~~ \_\_\_\_\_ Bbe performed without disturbing pipe  
6453 alignment.;

6454  
6455 ~~(formerly Section 14)(f)(iv)(ii)~~ \_\_\_\_\_ Backfill shall nNot contain debris, frozen  
6456 material, unstable material, or large clods.;

6457  
6458 ~~(formerly Section 14)(f)(iv)(iii)~~ \_\_\_\_\_ Not contain rocks or Sstones that are greater  
6459 than 3 three inches ~~(7.6 cm)~~ in diameter ~~shall not be placed~~ within 2 two feet ~~(0.6 m)~~ of pipe.;

6460 and  
6461  
6462 ~~(formerly Section 14)(f)(iv)(iv)~~ \_\_\_\_\_ Compaction shall be Be compacted to a  
6463 density equal to or greater than the surrounding soil.

6464  
6465 ~~(formerly Section 14)(g)(l)~~ \_\_\_\_\_ Distribution systems shall meet the following requirements  
6466 for Sseparation of ~~watermains, water mains from~~ sanitary ~~sewers~~ and storm sewers.;

6467  
6468 (i) Where the minimum vertical or horizontal separation distances required  
6469 by incorporation by reference of 2018 TSS parts 8.8.2 and 8.8.3 of paragraph (a) of this Section  
6470 cannot be met, the sewer or water line shall be placed in a separate conduit pipe or meet the  
6471 flow-fill requirements of paragraphs (ii) and (iii) of this Paragraph (l);

6472  
6473  
6474  
6475  
6476  
6477  
6478  
6479  
6480  
6481  
6482  
6483  
6484  
6485  
6486  
6487  
6488  
6489  
6490  
6491  
6492  
6493  
6494  
6495  
6496  
6497  
6498  
6499  
6500  
6501  
6502  
6503  
6504  
6505  
6506  
6507  
6508  
6509  
6510  
6511  
6512  
6513  
6514  
6515  
6516  
6517

(ii) Flow-fill for pipelines shall comply with the following:

(A) Cement-treated fill, non-shrink backfill, low-density concrete backfill, or structural backfill may be used as flow-fill when the material has a 28-day compressive strength of 30-60 psi;

(B) The pipe to be encased shall be laid on a four to six-inch of bed of washed gravel that has been widened, with the walls of the trench benched away from the center-line of the trench, so the pipe is uniformly supported over the length or supported on blocks no further than 10 feet apart;

(C) The flow-fill and washed gravel or blocks shall rest on an undisturbed trench bottom;

(D) The pipe shall not move laterally or float during placement of the flow-fill and the line and grade of the pipe shall be maintained; and

(E) The flow-fill shall extend from trench sidewall to trench sidewall and extend at least two inches above the top of the pipe.

(vii) Flow-fill for pipe crossings shall comply with the following:

(A) To the extent possible, there shall be no joints or taps within nine feet of the crossing;

(B) The flow-fill shall extend from undisturbed earth at the bottom of the lower pipe to at least two inches above the top of the upper pipe;

(C) The block of flow-fill shall be wide enough to ensure the structural integrity of the installation; and

(D) Pipes that cross one another shall be separated by a minimum of two inches when encased in flow-fill.

~~(formerly Section 14(i))(m)~~ Cross-connections shall comply with the following requirements:

~~(formerly Section 14(i)(i))(i) Cross-connections:~~ There shall be no water service connection installed or maintained between a public water supply and any water user whereby unsafe water or contamination may backflow into the public water supply.

~~(formerly Section 14(i)(i)(A))(A) Applicability. In order to~~ protect all public water supplies from the possibility of the introduction of contamination due to cross - connections, the water supplier shall: require backflow prevention devices for each water service connection in accordance with Table 1 which appears at the end of this section , with the

6518 ~~exception of (B)(I) residential water service connections and (B)(II) domestic non-residential~~  
6519 ~~water service connections. The water supplier shall take appropriate actions which may include~~  
6520 ~~immediate disconnection for any water user that fails to maintain a properly installed backflow~~  
6521 ~~prevention device or comply with other measures as identified in Section 14 (i) of these~~  
6522 ~~regulations.~~

6523  
6524 ~~(formerly Section 14(i)(i)(A))(I)~~ (I) ~~Require~~ Require backflow prevention  
6525 devices for each water service connection in accordance with ~~Table 1 which appears at the end of~~  
6526 ~~this section~~ Table 4 of this Section, with the exception of (B)(I) residential water service  
6527 connections and (B)(II) domestic non-residential water service connections.;

6528  
6529 ~~(formerly Section 14(i)(i)(A))(II)~~ (II) ~~The water supplier shall~~  
6530 ~~Take~~ Take appropriate actions ~~which~~ that may include;

6531  
6532 ~~(formerly Section 14(i)(i)(A))1.~~ 1. ~~i~~ Immediate  
6533 disconnection for any water user that fails to maintain a properly installed backflow prevention  
6534 device; or

6535  
6536 ~~(formerly Section 14(i)(i)(A))2.~~ 2. ~~e~~ Compliance with  
6537 other measures as identified in ~~Section 14 (i) of these regulations~~ this Section;

6538  
6539 ~~(formerly Section 14(i)(i)(A)(I))(III)~~ (III) Any high hazard non-  
6540 residential connection to any public water supply shall be protected by the ~~appropriate~~ backflow  
6541 prevention device required by Table 4.

6542  
6543 ~~(formerly Section 14(i)(i)(A)(III))(IV)~~ (IV) Water suppliers shall  
6544 establish record keeping and management procedures to ensure that requirements of this  
6545 regulation for installation and maintenance of backflow prevention devices are being met.

6546  
6547 ~~(formerly Section 14(i)(i)(B))(B)~~ (B) The method of backflow control,  
6548 selected from Table ~~14~~, shall be determined based upon the degree of hazard of the cross-  
6549 connection and the cause of the potential backflow. Hazards shall be classified as high hazard or  
6550 low hazard. The potential cause of the backflow shall be identified as being back-siphonage or  
6551 back-pressure.

6552  
6553 ~~(formerly Section 14(i)(i)(B)(I))(I)~~ (I) Residential water service  
6554 connections shall be considered to be low hazard back-siphonage connections; unless determined  
6555 otherwise by a ~~h~~ Hazard ~~e~~ Classification.

6556  
6557 ~~(formerly Section 14(i)(i)(B)(II))(II)~~ (II) Domestic non-residential  
6558 water service connections (such as schools without laboratories, churches, office buildings,  
6559 warehouses, and motels) shall be considered to be low hazard back-pressure connections; unless  
6560 determined otherwise by a ~~h~~ Hazard ~~e~~ Classification conducted by the water supplier. ~~Examples~~  
6561 ~~include schools without laboratories, churches, office buildings, warehouses, motels, etc.~~

6562

6563 ~~(formerly Section 14(i)(i)(B)(III))~~(III) Any water user's  
6564 system with an auxiliary source of supply shall be considered to be a high hazard, back-pressure  
6565 cross-connection. A reduced pressure principle backflow device shall be installed at the water  
6566 service connection to any water user's system with an auxiliary source of supply.

6567  
6568 ~~(formerly Section 14(i)(i)(B)(IV))~~(IV) All water loading  
6569 stations shall be considered high hazard connections. A device, assembly, or method consistent  
6570 with Table 14 shall be provided.

6571  
6572 ~~(formerly Section 14(i)(i)(B)(V))~~(V) Non-domestic  
6573 commercial or industrial water service connections (such as restaurants, refineries, chemical  
6574 mixing facilities, sewage treatment plants, mortuaries, laboratories, laundries, dry cleaners,  
6575 irrigation systems, and facilities producing or using hazardous substances) shall be considered to  
6576 be high hazard back-pressure connections, unless determined otherwise by a hHazard  
6577 eClassification. ~~Examples include restaurants, refineries, chemical mixing facilities, sewage~~  
6578 ~~treatment plants, mortuaries, laboratories, laundries, dry cleaners, irrigation systems, facilities~~  
6579 ~~producing or utilizing hazardous substances, etc.~~ For some of these service connections, a  
6580 hHazard eClassification may result in a determination of a back-siphonage or low hazard  
6581 classification. The backflow prevention device required shall be appropriate to the degree of  
6582 hazard established by the hHazard eClassification. Where potential high hazards exist within the  
6583 non-residential water user's system, even though such high hazards may be isolated at the point  
6584 of use, an approved backflow prevention device shall be installed and maintained at the water  
6585 service connection.

6586  
6587 ~~(formerly Section 14(i)(i)(C))~~(C) Determination of the hazard  
6588 classification of a water service connection is the responsibility of the water supplier. The water  
6589 supplier may require the water user to furnish a hHazard eClassification sSurvey to be used to  
6590 determine the hHazard eClassification.

6591  
6592 (D) Hazard Classification Surveys that have been conducted by  
6593 Hazardous Classification Surveyors that have been certified by another state certification  
6594 program shall include the following information for Administrator approval:

6595  
6596 (I) Documentation that indicates the Hazard Classification  
6597 Surveyor has received certification from the regulatory agency that issued the current  
6598 certification that states the name of the Hazard Classification Surveyor, the status of their  
6599 certification, the date originally issued, the expiration date, and the classification for which the  
6600 Hazard Classification Surveyor is certified; and

6601  
6602 (II) Any disciplinary action imposed against the applicant; if  
6603 any.

6604  
6605 ~~(formerly Section 14(i)(i)(E))~~(E) All backflow prevention devices  
6606 ~~must shall~~ be in-line serviceable (repairable), in-line testable except for devices meeting ASSE  
6607 ~~Standard #1024~~, and installed in accordance with manufacturer instructions and applicable  
6608 plumbing codes.

6609  
6610 ~~(formerly Section 14(i)(i)(F))~~(F) All backflow prevention devices  
6611 must have a certification by an approved third party certification agency. Approved certification  
6612 agencies are:  
6613 ~~(formerly Section 14(i)(i)(F)(I))~~(I) American Society of Sanitary  
6614 Engineers (ASSE),  
6615  
6616 ~~(formerly Section 14(i)(i)(F)(II))~~(II) International Association of  
6617 Plumbing/Mechanical officials (IAPMO); and  
6618  
6619 ~~(formerly Section 14(i)(i)(F)(III))~~(III) Foundation for Cross-  
6620 Connection Control and Hydraulic Research, University Of Southern California (USC-  
6621 FCCCHR).

6622  
6623 ~~(formerly Section 14(i)(i)(G))~~(G) Backflow prevention devices at  
6624 water service connections shall be inspected and certified by a certified backflow assembly tester  
6625 at the time of installation. Certification of the assembly tester shall be by one of the following:  
6626  
6627 ~~(formerly Section 14(i)(i)(G)(I))~~(I) The American Society of  
6628 Sanitary Engineers (ASSE); or  
6629  
6630 ~~(formerly Section 14(i)(i)(G)(II))~~(II) American Backflow  
6631 Prevention Association (ABPA);

6632  
6633 ~~(formerly Section 14(i)(i)(H))~~(H) Backflow prevention devices  
6634 installed at high hazard non- residential cross connections shall be inspected and tested on an  
6635 annual basis by a certified backflow assembly tester.

6636  
6637 ~~(formerly Section 14(i)(i)(I))~~(I) ~~The administrator may conduct~~  
6638 ~~inspections of backflow prevention devices.~~ If any device is found to be defective or functioning  
6639 improperly, it must shall be immediately repaired or replaced. Failure to make necessary repairs  
6640 to a backflow prevention device will be cause for the water service connection to be terminated.

6641  
6642 ~~(formerly Section 14(i)(i)(J))~~(J) All public water suppliers shall  
6643 report any high hazard backflow incident within seven ~~(7)~~ days to the ~~Wyoming Department of~~  
6644 ~~Environmental Quality, Water Quality~~ Division. The backflow incident shall be reported on a  
6645 form provided by the ~~a~~AAdministrator.

6646  
6647 ~~(formerly Section 14(i)(ii)(ii))~~ ~~Recycling water.~~ Neither steam condensate  
6648 nor cooling water from engine jackets or other heat exchange devices shall be returned to the  
6649 public water supply after it has passed through the water service connection.

6650  
6651 ~~TABLE 1~~ Table 4. Backflow Prevention Devices, Assemblies and Methods

	Degree of Hazard		Notes
	Low Hazard	High Hazard	



Device, Assembly or Method	Back-Siphonage	Back-Pressure	Back-Siphonage	Back-Pressure	
Airgap	X	<u>X</u>	X	<u>X</u>	See Note 1 and Note 2
Atmospheric Vacuum Breaker	X		X		Not allowed under continuous pressure
Spill-proof Pressure-type Vacuum	X		X		
Double Check Valve Backflow Preventer	X	X			
Pressure Vacuum Breaker	X		X		
Reduced Pressure Principle Backflow	X	X	X	X	See Note 2
Dual Check	X				Restricted to residential services

6652  
6653 ~~(formerly Section 14, Table 1)~~ Note 1: Minimum Airgap for Water Distribution. For  
6654 spouts with an effective opening diameter of ~~one-half~~ 1/2 inch or less, the minimum airgap when  
6655 the discharge is not affected by side walls shall be one inch. The minimum airgap when the  
6656 discharge is affected by sidewalls shall be ~~one and one-half~~ 1 1/2 inches. For effective openings  
6657 greater than ~~one-half~~ 1/2 inch, the minimum airgap shall be two times the effective opening  
6658 diameter when the discharge is not affected by sidewalls. The minimum airgap when the  
6659 discharge is affected by sidewalls shall be three times the effective opening diameter.

6660  
6661 ~~(formerly Section 14, Table 1)~~ Note 2: Extreme Hazards. In the case of any water user's  
6662 system where, in the opinion of the water supplier or the Administrator, an undue health threat is  
6663 posed because of the presence of extremely toxic substances or potential back pressures in excess  
6664 of the design working pressure of the device, the water supplier may require an airgap at the  
6665 water service connection to protect the public water system.

6667 **Section 17. Laboratory Requirements.**

6668  
6669 (a) 2018 TSS, parts 2.8.1-2.8.1(h), testing equipment, is herein incorporated by  
6670 reference.

6671

6672 ~~(formerly Section 15)(a)(b)~~ Test procedures. Test procedures for analysis of monitoring  
6673 samples shall conform to the ~~15th Edition of Standard Methods for the Examination of Water~~  
6674 ~~and Wastewater~~ Standard Methods for the Examination of Water and Wastewater.  
6675

6676 ~~(formerly Section 15)(b)(c)~~ Testing requirements. All treatment plants shall have the  
6677 capability to perform or contract for the self-monitoring analytical work required by the Safe  
6678 Drinking Water Act, ~~and/or state regulation~~ 42 U.S.C. §300f et seq. All plants shall, in addition,  
6679 be capable of performing or contracting the analytical work required to assure good management  
6680 and control of plant operation and performance.  
6681

6682 ~~(formerly Section 15)(e)(d)~~ All laboratories used for the tests, analysis, and monitoring  
6683 required by this Section shall meet the following ~~Minimum~~ requirements.:  
6684

6685 ~~(formerly Section 15)(e)(i)(i)~~ Location and space. The laboratory shall be located  
6686 away from vibrating machinery or equipment ~~which that~~ might have adverse effects on the  
6687 performance of laboratory instruments or the analyst and shall be designed to prevent adverse  
6688 effects from vibration.  
6689

6690 ~~(formerly Section 15)(e)(ii)(ii)~~ Materials. Walls shall have an easily  
6691 cleaned, durable and impervious surface. ~~Two exit doors or openings shall be located to permit a~~  
6692 ~~straight exit from the laboratory; one exit shall be directly to the outside of the building. Panic~~  
6693 ~~hardware shall be used. Interior doors shall have glass windows.~~  
6694

6695 ~~(formerly Section 15)(e)(iii)(iii)~~ Cabinets and bench tops. Cabinet and  
6696 storage space shall be provided for dust-free storage of instruments and glassware. ~~(formerly~~  
6697 ~~Section 15)(e)(iii)~~ Bench top Benchtop height shall be 30 inches ~~(0.91 m).~~ Tops Benchtops  
6698 ~~should~~ shall be field joined into a continuous surface with acid, alkali, and solvent-resistant  
6699 cements.  
6700

6701 ~~(formerly Section 15)(e)(iv)(iv)~~ Hoods. Fume hoods shall be provided where  
6702 reflux or heating of toxic or hazardous materials is required. A hood shall not be situated near a  
6703 doorway, unless a secondary means of exit is provided. All fume hood switches, electrical  
6704 outlets, and utility and baffle adjustment handles shall be located outside the hood. Light fixtures  
6705 shall be explosion-proof. ~~Twenty-four hour~~ 24-hour continuous exhaust capability shall be  
6706 provided. Exhaust fans shall be explosion-proof.  
6707

6708 ~~(formerly Section 15)(e)(v)(v)~~ Sinks. The laboratory shall have a minimum  
6709 of 2 two sinks per 400 ~~ft<sup>2</sup> (37.2 m<sup>2</sup>)~~ square feet (not including cup sinks). Sinks shall be double  
6710 well with drainboards and shall be made of epoxy resin or plastic. All water fixtures shall ~~be~~  
6711 ~~provided with~~ have reduced pressure zone backflow preventers. Traps shall be constructed of  
6712 glass, plastic, or lead and be accessible for cleaning ~~shall be provided.~~  
6713

6714 ~~(formerly Section 15)(e)(viii)(vi)~~ Water still. Distilled water shall conform to  
6715 the quality specified by ~~Standard Methods for the Examination of Water and Wastewater, 15th~~  
6716 ~~Edition~~ Standard Methods for the Examination of Water and Wastewater 2018.  
6717

6718 ~~(formerly Section 15)(d)(e)~~ Portable testing equipment. Portable testing equipment  
6719 shall be provided where necessary for operational control testing.

6720  
6721 **Section 18. Operation and Maintenance Manuals.**

6722  
6723 ~~(formerly Section 16(a))(a)~~ Where required. Plant operation and maintenance manuals  
6724 ~~are required for each new or modified treatment or pumping facility.~~ Each new or modified  
6725 treatment or pumping facility shall have an operation and maintenance manual (O & M Manual)  
6726 located at the facility. The manuals shall provide the following information as a minimum:

6727  
6728 ~~(formerly Section 16(a)(i))(i)~~ Introduction;

6729  
6730 ~~(formerly Section 16(a)(ii))(ii)~~ Description of facilities and unit processes  
6731 within the plant from influent structures through effluent structures;

6732  
6733 (A) The size, capacity, model number (where applicable), and intended  
6734 loading rate of facilities and unit processes;

6735  
6736 (B) A description of each unit, including the function, the controls, the  
6737 lubrication, and maintenance schedule;

6738  
6739 (C) A description of start-up operations, routine operations, abnormal  
6740 operations, emergency or power outage operations, bypass procedures, and safety;

6741  
6742 (D) Flow diagrams of the entire process, as well as individual unit  
6743 processes that show the flow options under the various operational conditions listed in paragraph  
6744 (a)(ii) of this Section; and.

6745  
6746 (E) The design criteria for each unit process, including the number,  
6747 type, capacity, sizes, and other relevant information.

6748  
6749 ~~(formerly Section 16(a)(iii))(iii)~~ Plant control system;

6750  
6751 ~~(formerly Section 16(a)(iv))(iv)~~ Utilities and systems;

6752  
6753 ~~(formerly Section 16(a)(v))(v)~~ Emergency ~~operation and response~~  
6754 procedures, including:

6755  
6756 (A) Details of emergency operations procedures for possible  
6757 foreseeable emergencies, such as power outage, equipment failure, development of unsafe  
6758 conditions, and other emergency conditions;

6759  
6760 (B) Emergency operations valve positions, flow control settings, and  
6761 other information to ensure continued operation of the facility at maximum possible efficiency  
6762 during emergencies; and

6764 (C) Emergency notification procedures to be followed to protect health  
6765 and safety under various emergency conditions.

6766  
6767 ~~(formerly Section 16)(a)(vi)(vi)~~ Permit requirements and other regulatory  
6768 requirements;

6769  
6770 ~~(formerly Section 16)(a)(vii)(vii)~~ Staffing needs;

6771  
6772 ~~(formerly Section 16)(a)(viii)(viii)~~ Index to of manufacturer's manuals;

6773  
6774 (ix) Index of equipment maintenance manuals; and

6775  
6776 (x) General information on safety in and around the plant and its components,  
6777 including the following safety information:

6778  
6779 (A) Each unit process discussion shall include applicable safety  
6780 procedures and precautions; and

6781  
6782 (B) For unit processes or operations having extreme hazards (such as  
6783 chlorine and closed tanks), the discussion shall detail appropriate protection, rescue procedures,  
6784 and necessary safety equipment.

6785  
6786 ~~(formerly Section 16)(b)(b) When required. Acceptance of the final operation and~~  
6787 ~~maintenance manuals~~ Administrator approval of the final O & M Manual is required prior to  
6788 plant startup.

6789  
6790 ~~(formerly Section 16)(c)(i)(c) Each unit. The Public water supply facilities shall~~  
6791 ~~have an equipment maintenance manual located at the facility for each piece of equipment. Each~~  
6792 ~~equipment maintenance manual shall; describe each unit, including the function, the controls, the~~  
6793 ~~lubrication and maintenance schedule. The manual shall also include start-up operations; routine~~  
6794 ~~operations; abnormal operations; emergency or power outage operations; bypass procedures; and~~  
6795 ~~safety.~~

6796  
6797 (i) Have a typewritten table of contents for each volume arranged in a  
6798 systematic order;

6799  
6800 (ii) Include the following general contents:

6801  
6802 (A) Product data;

6803  
6804 (B) Drawings;

6805  
6806 (C) Written text as required to supplement product data for the  
6807 particular installation;

6808  
6809 (D) Copies of each warranty, bond, and service contract issued;

- 6810  
6811 (E) Descriptions of unit and component parts;  
6812  
6813 (F) Operating procedures;  
6814  
6815 (G) Maintenance procedures and schedules;  
6816  
6817 (H) Service and lubrication schedule;  
6818  
6819 (I) Sequence of control operation;  
6820  
6821 (J) Parts list; and  
6822  
6823 (K) Recommended spare parts list.  
6824

6825 ~~(formerly Section 16(e))(iii) Troubleshooting guide. Each equipment~~  
6826 ~~maintenance manual shall include a section on troubleshooting; that shall include: These~~  
6827 ~~manuals are to be indexed in the plant O & M manual. The troubleshooting guide shall include~~  
6828 ~~typical operation problems and solutions. The guide shall include a telephone number for factory~~  
6829 ~~troubleshooting assistance.~~

6830  
6831 ~~(formerly Section 16(e))(A) Typical operation problems and solutions;~~  
6832 and

6833  
6834 ~~(formerly Section 16(e))(B) aA telephone number for factory~~  
6835 ~~troubleshooting assistance; and~~

6836  
6837 ~~(formerly Section 16)(h))(iv) Maintenance manuals. Maintenance manuals shall~~  
6838 ~~be required for each piece of equipment. These manuals must meet the requirements of the~~  
6839 ~~engineer and contractor for installation and startup of equipment. The information included in the~~  
6840 ~~manufacturer's manuals shall not be included in the O & M manual.~~

6841  
6842 **Section 19. Incorporation by Reference.**

6843  
6844 (a) The following codes, standards, rules, and regulations referenced in this Chapter  
6845 are incorporated by reference:

6846  
6847 (i) American National Standards Institute/National Sanitation Foundation  
6848 Standard 53, Drinking Water Treatment Units - Health Effects (2019), referred to as "NSF/ANSI  
6849 53," available at <https://webstore.ansi.org/Standards/NSF/NSFANSI532020>;

6850  
6851 (ii) American National Standards Institute/National Sanitation Foundation  
6852 Standard 55, Ultraviolet Microbiological Water Treatment Systems (2020), referred to as  
6853 "NSF/ANSI 55," available at <https://webstore.ansi.org/Standards/NSF/NSFANSI552021>;  
6854

- 6855 (iii) American National Standards Institute/National Sanitation Foundation  
6856 Standard 61, Drinking Water System Components - Health Effects NSF/ANSI/CAN 61-  
6857 2020/NSF/ANSI/CAN 600-2021, referred to as “NSF/ANSI/CAN 61-2020/NSF/ANSI/CAN  
6858 600-2021,” available at <https://webstore.ansi.org/Standards/NSF/NSFANSI612021600>;  
6859
- 6860 (iv) American National Standards Institute/National Sanitation Foundation  
6861 Standard 372, Drinking Water System Components-Lead Content 372-20, referred to as  
6862 “NSF/ANSI/CAN 372-20,” available at  
6863 <https://webstore.ansi.org/Standards/NSF/NSFANSI3722020>;  
6864
- 6865 (v) American National Standards Institute/National Sanitation Foundation  
6866 Standard 419, Public Drinking Water Equipment Performance – Filtration, referred to as  
6867 “NSF/ANSI 419-2018,” available at  
6868 <https://webstore.ansi.org/Standards/NSF/NSFANSI4192018>;  
6869
- 6870 (vi) American Petroleum Institute Specification 5L, Line Pipe, Forty-Sixth  
6871 Edition (2019), referred to as “API 5L,” available at  
6872 [https://www.techstreet.com/api/standards/api-spec-5l?gateway\\_code=api&product\\_id=2010552](https://www.techstreet.com/api/standards/api-spec-5l?gateway_code=api&product_id=2010552);  
6873
- 6874 (vii) American Water Works Association Standard A100, Water Wells, A100-  
6875 20, referred to as “AWWA A100-20,” available at  
6876 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/83080725>;  
6877
- 6878 (viii) American Water Works Association Standard C200, Steel Water Pipe, 6  
6879 In. (150 mm) and Larger, C200-17 (2017), referred to as “AWWA C200,” available at  
6880 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/63106282>;  
6881
- 6882 (ix) American Water Works Association Standard C300, Reinforced Concrete  
6883 Pressure Pipe, Steel-Cylinder Type, C300-11 (2011), referred to as “AWWA C300,” available at  
6884 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/59483818>;  
6885
- 6886 (x) American Water Works Association Standard C301, Prestressed Concrete  
6887 Pressure Pipe, Steel-Cylinder Type, C301-14 (2014), referred to as “AWWA C301,” available at  
6888 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/81647229>;  
6889
- 6890 (xi) American Water Works Association Standard C600, Installation of  
6891 Ductile-Iron Mains and Their Appurtenances, C600-10 (2010), referred to as “AWWA C600,”  
6892 available at <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/25724>;  
6893
- 6894 (xii) American Water Works Association Standard C601, AWWA Standard for  
6895 Disinfecting Water Mains, C601-81 (1981), referred to as “AWWA C601,” available at  
6896 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/18646>;  
6897
- 6898 (xiii) American Water Works Association Standard C652, Disinfection of Water  
6899 Storage Facilities, C652 (2011), referred to as “AWWA C652,” available at  
6900 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/81912774>;

- 6901  
6902                   (xiv) American Water Works Association Standard C900, Polyvinyl Chloride  
6903 (PVC) Pressure Pipe and Fabricated Fittings, 4 In. Through 12 In. (100 mm through 300 mm),  
6904 for Water Transmission and Distribution, C900-07 (2007), referred to as “AWWA C900,”  
6905 available at <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/18943>;  
6906
- 6907                   (xv) American Water Works Association Standard C901, Polyethylene (PE)  
6908 Pressure Pipe and Tubing, 3/4 in. (19 mm) through 3 in. (76 mm), for Water Service, C901- 20  
6909 (2020), referred to as “AWWA C901,” available at  
6910 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/86488411>;  
6911
- 6912                   (xvi) American Water Works Association Standard C906, Polyethylene (PE)  
6913 Pressure Pipe and Fittings, 4 in. through 65 In. (100 mm Through 1,650 mm), for Waterworks,  
6914 C906-21 (2021), referred to as “AWWA C906,” available at  
6915 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/105341623>;  
6916
- 6917                   (xvii) American Water Works Association Standard C950, Fiberglass Pressure  
6918 Pipe, C950-13 (2013), referred to as “AWWA C950,” available at  
6919 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/34040472>;  
6920
- 6921                   (xviii) American Water Works Association Standard D100, Welded Carbon Steel  
6922 Tanks for Water Storage, D100-11 (2011), referred to as “AWWA D100-11,” available at  
6923 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/28162>;  
6924
- 6925                   (xvix) American Water Works Association Standard D102, Coating Steel Water-  
6926 Storage Tanks, D102-17 (2017), referred to as “AWWA D102-21,” available at  
6927 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/92298590>;  
6928
- 6929                   (xx) American Water Works Association Standard D103, Factory-Coated  
6930 Bolted Carbon Steel Tanks for Water Storage, D103-19, referred to as “AWWA D103-19,”  
6931 available at [https://engage.awwa.org/PersonifyEbusiness/Store/Product-](https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/80453600)  
6932 [Details/productId/80453600](https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/80453600);  
6933
- 6934                   (xxi) American Water Works Association Standard D104-17, Automatically  
6935 Controlled, Impressed-Current Cathodic Protection for the Interior of Steel Water Storage,  
6936 referred to as “AWWA D104-17,” available at  
6937 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/65522513>;  
6938
- 6939                   (xxii) American Water Works Association Standard D106-20, Sacrificial anode  
6940 Cathodic Protection Systems for the Interior Submerged Surfaces of Steel Water Storage Tanks,  
6941 referred to as “AWWA D106-20,” available at  
6942 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/84700967>;  
6943
- 6944                   (xxiii) American Water Works Association Standard D107-16, Composite  
6945 Elevated Tanks for Water Storage, referred to as “AWWA D107-16,” available at  
6946 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/54635993>;

6947  
6948 (xxiv) American Water Works Association Standard D108-19, Aluminum Dome  
6949 Roofs for Water Storage Facilities, referred to as “AWWA D108-19,” available at  
6950 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/80933896>;  
6951  
6952 (xxv) American Water Works Association Standard D110-13 (R18), Wire- and  
6953 Strand-Wound, Circular, Prestressed Concrete Water Tanks, referred to as “AWWA D110-13  
6954 (R18),” available at [https://engage.awwa.org/PersonifyEbusiness/Store/Product-](https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/72304450)  
6955 [Details/productId/72304450](https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/72304450);  
6956  
6957 (xxvi) American Water Works Association Standard D115-20, Tendon-  
6958 Prestressed Concrete Water Tanks, referred to as “AWWA D115-20,” available at  
6959 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/83072907>;  
6960  
6961 (xxvii) American Water Works Association Standard D120-19, Thermosetting  
6962 Fiberglass-Reinforced Plastic Tanks, referred to as “AWWA D120-19,” available at  
6963 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/79004100>;  
6964  
6965 (xxviii) American Water Works Association Standard D121-12, Bolted  
6966 Aboveground Thermosetting Fiberglass Reinforced Plastic Panel-Type Tanks for Water Storage,  
6967 referred to as “AWWA D121-12,” available at  
6968 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/29429>;  
6969  
6970 (xxix) American Water Works Association Standard M23-20, PVC Pipe –  
6971 Design and Installation, Third Edition, M23, referred to as “AWWA M23-20,” available at  
6972 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/81145714>;  
6973  
6974 (xxx) American Water Works Association Standard M55-20, PE Pipe-Design  
6975 and Installation, Second Edition, M55, referred to as “M55-20,” available at  
6976 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/84701177>;  
6977  
6978 (xxxii) American Water Works Association Manual M42, Steel Water Storage  
6979 Tanks, 2013, referred to as “AWWA M42,” available at  
6980 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/36253113>;  
6981  
6982 (xxxiii) American National Standards Institute ASSE Standard 1024, Dual Check  
6983 Backflow Preventers, ASSE 1024-17 (2017), referred to as “ASSE 1024,” available at  
6984 <https://webstore.ansi.org/Standards/ASSE-Sanitary/ASSEStandard10242017>;  
6985  
6986 (xxxiiii) ASTM International Standard A53, Standard Specification for Pipe, Steel,  
6987 Black and Hot-Dipped, Zinc-Coated, Welded and Seamless, A53M-18 (2018), referred to as  
6988 “ASTM A53, available at [https://www.astm.org/a0053\\_a0053m-18.html](https://www.astm.org/a0053_a0053m-18.html);  
6989  
6990 (xxxiv) ASTM International Standard A134, Standard Specification for Pipe,  
6991 Steel, Electric-Fusion (Arc)-Welded (Sizes NPS 16 and Over), A134M-18 (2018), referred to as  
6992 “ASTM A134,” available at <https://webstore.ansi.org/standards/astm/astma134a134m18>;



6993  
6994 (xxxv) ASTM International Standard A135, Standard Specification for Electric-  
6995 Resistance-Welded Steel Pipe, A135M-19 (2019), referred to as “ASTM A135,” available at  
6996 <https://webstore.ansi.org/standards/astm/astma135a135m19>;  
6997  
6998 (xxxvi) ASTM International Standard ASTM A139 / A139M – 16, Standard  
6999 Specification for Electric-Fusion (Arc)-Welded Steel Pipe (NPS 4 and Over), (2016), referred to  
7000 as “ASTM A139,” available at [https://www.astm.org/a0139\\_a0139m-16.html](https://www.astm.org/a0139_a0139m-16.html);  
7001  
7002 (xxxvii) ASTM International Standard A409, Standard Specification for  
7003 Welded Large Diameter Austenitic Steel Pipe for Corrosive or High-Temperature Service,  
7004 A409M-15 (2015), referred to as “ASTM A409,” available at  
7005 <https://webstore.ansi.org/Standards/ASTM/ASTMA409A409M15>;  
7006  
7007 (xxxviii) ASTM International Standard C12, Standard Practice for Installing  
7008 Vitrified Clay Pipe Lines, C12-17 (2017), referred to as “ASTM C12,” available at  
7009 <https://webstore.ansi.org/standards/astm/astmc1217>;  
7010  
7011 (xxxix) ASTM International Standard C14, Standard Specification for  
7012 Nonreinforced Concrete Sewer, Storm Drain, and Culvert Pipe, C14-15a (2015), referred to as  
7013 “ASTM C14,” available at  
7014 [https://webstore.ansi.org/standards/astm/astmc1415a?gclid=Cj0KCOiA95aRBhCsARIsAC2xvfx](https://webstore.ansi.org/standards/astm/astmc1415a?gclid=Cj0KCOiA95aRBhCsARIsAC2xvfxIaQ66MqCuC40LMUwG0WMe0kbvHUvuxW6F3Nc7jy92bGyVdNFHiaoaAo-uEALw_wcB)  
7015 [IaQ66MqCuC40LMUwG0WMe0kbvHUvuxW6F3Nc7jy92bGyVdNFHiaoaAo-uEALw\\_wcB](https://webstore.ansi.org/standards/astm/astmc1415a?gclid=Cj0KCOiA95aRBhCsARIsAC2xvfxIaQ66MqCuC40LMUwG0WMe0kbvHUvuxW6F3Nc7jy92bGyVdNFHiaoaAo-uEALw_wcB);  
7016  
7017 (xl) ASTM International Standard C76, Standard Specification for Reinforced  
7018 Concrete Culvert, Storm Drain, and Sewer Pipe, C76-19a (2019), referred to as “ASTM C76,”  
7019 available at <https://webstore.ansi.org/Standards/ASTM/ASTMC7619a>;  
7020  
7021 (xli) ASTM International Standard D2321, Standard Practice for Underground  
7022 Installation of Thermoplastic Pipe for Sewers and Other Gravity-Flow Applications, D2321-18  
7023 (2018), referred to as “ASTM D2321,” available at  
7024 <https://webstore.ansi.org/Standards/ASTM/ASTMD232118>;  
7025  
7026 (xlii) ASTM International Standard D2846, Standard Specification for  
7027 Chlorinated Poly(Vinyl Chloride) (CPVC) Plastic Hot- and Cold-Water Distribution Systems,  
7028 ASTM D2846/D2846M-19A (2019), referred to as “ASTM D2846,” available at  
7029 <https://webstore.ansi.org/Standards/ASTM/ASTMD2846D2846M19a>;  
7030  
7031 (xliii) ASTM International Standard D2996, Standard Specification for  
7032 Filament-Wound “Fiberglass” (Glass-Fiber-Reinforced Thermosetting-Resin) Pipe, D2996-17  
7033 (2017), referred to as “ASTM D2996,” available at  
7034 <https://webstore.ansi.org/Standards/ASTM/ASTMD299617>;  
7035  
7036 (xliv) ASTM International Standard D2997, Standard Specification for  
7037 Centrifugally Cast “Fiberglass” (Glass-Fiber-Reinforced Thermosetting-Resin) Pipe, D2997-15

7038 (2015), referred to as “ASTM D2997,” available at  
7039 <https://webstore.ansi.org/Standards/ASTM/ASTMD299715>;  
7040  
7041 (xlv) ASTM International Standard D3517, Standard Specification for  
7042 “Fiberglass” (Glass-Fiber-Reinforced Thermosetting-Resin) Pressure Pipe, D3517-19 (2019),  
7043 referred to as “ASTM D3517,” available at  
7044 <https://webstore.ansi.org/Search/Find?in=1&st=ASTM+D3517-19>;  
7045  
7046 (xlvi) ASTM International Standard F480, Standard Specification for  
7047 Thermoplastic Well Casing Pipe and Couplings Made in Standard Dimension Ratios (SDR),  
7048 SCH 40 and SCH 80, F480-14 (2014), referred to as “ASTM F480,” available at  
7049 <https://webstore.ansi.org/Standards/ASTM/ASTMF48014>;  
7050  
7051 (xlvii) ASTM International Standard F645, Standard Guide for Selection, Design,  
7052 and Installation of Thermoplastic Water- Pressure Piping Systems, ASTM F645-18b, (2018),  
7053 referred to as “ASTM F645,” available at  
7054 <https://webstore.ansi.org/Standards/ASTM/ASTMF64518b>;  
7055  
7056 (xlviii) ASTM International Standard F877, Standard Specification for  
7057 Crosslinked Polyethylene (PEX) Hot- and Cold-Water Distribution Systems, ASTM F877-20,  
7058 (2020), referred to as “ASTM F877,” available at  
7059 <https://webstore.ansi.org/Standards/ASTM/ASTMF87720>;  
7060  
7061 (xlix) ASTM International Standard F2389, Standard Specification for Pressure-  
7062 rated Polypropylene (PP) Piping Systems, ASTM F2389-21, (2021), referred to as “ASTM  
7063 F2389,” available at <https://webstore.ansi.org/Standards/ASTM/ASTMF238921>;  
7064  
7065 (l) ASTM International Standard F2806, Standard Specification for  
7066 Acrylonitrile-Butadiene-Styrene (ABS) Plastic Pipe (Metric SDR-PR), ASTM F2806-20, (2020),  
7067 referred to as “ASTM F2806,” available at  
7068 <https://webstore.ansi.org/Standards/ASTM/ASTMF280620>;  
7069  
7070 (li) ASTM International Standard F2855, Standard Specification for  
7071 Chlorinated Poly(Vinyl Chloride)/Aluminum/Chlorinated Poly(Vinyl Chloride) (CPVC-AL-  
7072 CPVC) Composite Pressure Tubing ASTM F2855-19, (2019), referred to as “ASTM F2855,”  
7073 available at <https://webstore.ansi.org/Standards/ASTM/ASTMF285519>;  
7074  
7075 (lii) ASTM International Standard F2969, Standard Specification for  
7076 Acrylonitrile-Butadiene-Styrene (ABS) IPS Dimensioned Pressure Pipe ASTM F2969-12(2020),  
7077 (2020), referred to as “ASTM F2969,” available at  
7078 <https://webstore.ansi.org/Standards/ASTM/ASTMF2969122020>;  
7079  
7080 (liii) Standard Methods for the Examination of Water and Wastewater,  
7081 published by American Public Health Association, American Water Works Association, and  
7082 Water Environment Federation, 23rd Edition (2018), referred to as “Standard Methods for the

7083 Examination of Water and Wastewater 2018, available at  
7084 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/65266295>;  
7085  
7086 (liv) Code of Federal Regulations 40 CFR Part 141, in effect as of July 1, 2011,  
7087 available at: <http://www.ecfr.gov>;  
7088  
7089 (lv) Code of Federal Regulations 40 CFR 143.3, in effect as of July 1, 2021;  
7090 available at: <http://www.ecfr.gov>;  
7091  
7092 (lvi) Code of Federal Regulations 40 CFR 173.3(e), in effect as of November 7,  
7093 2018, available at: <http://www.ecfr.gov>;  
7094  
7095 (lvii) United States Department of Agriculture, Natural Resources Conservation  
7096 Service, Part 631 National Engineering Handbook, Chapter 32 Well Design and Spring  
7097 Development, Part 631.3201(b)(iii), in effect as of January 2010, referred to as “USDA NRCS  
7098 Part 631 National Engineering Handbook,” available at  
7099 <https://directives.sc.egov.usda.gov/OpenNonWebContent.aspx?content=26985.wba>;  
7100  
7101 (lviii) Recommended Standards for Water Works, published by Great Lakes  
7102 Upper Mississippi River Board of State and Provincial Public Health and Environmental  
7103 Managers, (2018), referred to as “2018 TSS,” available at  
7104 [https://www.mngovpublications.com/catalog/Default.asp?CatalogID=21656&Provider\\_ID=1241](https://www.mngovpublications.com/catalog/Default.asp?CatalogID=21656&Provider_ID=1241868)  
7105 [868](https://www.mngovpublications.com/catalog/Default.asp?CatalogID=21656&Provider_ID=1241868);  
7106  
7107 (lix) United States Environmental Protection Agency, Long Term 2 Enhanced  
7108 Surface Water Treatment Rule Toolbox Guidance Manual, 2010, referred to as “Toolbox  
7109 Guidance Manual,” available at <https://nepis.epa.gov/Exe/ZyPDF.cgi?Dockey=P1009JLI.txt>;  
7110  
7111 (lx) United States Environmental Protection Agency, Ultraviolet Disinfection  
7112 Guidance Manual For The Final Long Term 2 Enhanced Surface Water Treatment Rule, 2006,  
7113 referred to as “Ultraviolet Disinfection Guidance Manual for the Final LT2ESWTR,” available at  
7114 <https://nepis.epa.gov/Exe/ZyPDF.cgi?Dockey=600006T3.txt>; and  
7115  
7116 (lxi) United States Environmental Protection Agency, Membrane Filtration  
7117 Guidance Manual, 2005, referred to as “US EPA Membrane Filtration Guidance  
7118 Manual,” available at  
7119 [https://nepis.epa.gov/Exe/ZyNET.exe/P1008S15.TXT?ZyActionD=ZyDocument&Client=EPA&](https://nepis.epa.gov/Exe/ZyNET.exe/P1008S15.TXT?ZyActionD=ZyDocument&Client=EPA&Index=2006+Thru+2010&Docs=&Query=&Time=&EndTime=&SearchMethod=1&TocRestrict=n&Toc=&TocEntry=&QField=&QFieldYear=&QFieldMonth=&QFieldDay=&IntQFieldOp=0&ExtQFieldOp=0&XmlQuery=&File=D%3A%5Czyfiles%5CIndex%20Data%5C06thru10%5CTxt%5C00000021%5CP1008S15.txt&User=ANONYMOUS&Password=anonymous&SortMethod=h%7C-&MaximumDocuments=1&FuzzyDegree=0&ImageQuality=r75g8/r75g8/x150y150g16/i425&Display=hpfr&DefSeekPage=x&SearchBack=ZyActionL&Back=ZyActionS&BackDesc=Results%20page&MaximumPages=1&ZyEntry=1&SeekPage=x&ZyPURL)  
7120 [Index=2006+Thru+2010&Docs=&Query=&Time=&EndTime=&SearchMethod=1&TocRestrict](https://nepis.epa.gov/Exe/ZyNET.exe/P1008S15.TXT?ZyActionD=ZyDocument&Client=EPA&Index=2006+Thru+2010&Docs=&Query=&Time=&EndTime=&SearchMethod=1&TocRestrict=n&Toc=&TocEntry=&QField=&QFieldYear=&QFieldMonth=&QFieldDay=&IntQFieldOp=0&ExtQFieldOp=0&XmlQuery=&File=D%3A%5Czyfiles%5CIndex%20Data%5C06thru10%5CTxt%5C00000021%5CP1008S15.txt&User=ANONYMOUS&Password=anonymous&SortMethod=h%7C-&MaximumDocuments=1&FuzzyDegree=0&ImageQuality=r75g8/r75g8/x150y150g16/i425&Display=hpfr&DefSeekPage=x&SearchBack=ZyActionL&Back=ZyActionS&BackDesc=Results%20page&MaximumPages=1&ZyEntry=1&SeekPage=x&ZyPURL)  
7121 [=n&Toc=&TocEntry=&QField=&QFieldYear=&QFieldMonth=&QFieldDay=&IntQFieldOp=0](https://nepis.epa.gov/Exe/ZyNET.exe/P1008S15.TXT?ZyActionD=ZyDocument&Client=EPA&Index=2006+Thru+2010&Docs=&Query=&Time=&EndTime=&SearchMethod=1&TocRestrict=n&Toc=&TocEntry=&QField=&QFieldYear=&QFieldMonth=&QFieldDay=&IntQFieldOp=0&ExtQFieldOp=0&XmlQuery=&File=D%3A%5Czyfiles%5CIndex%20Data%5C06thru10%5CTxt%5C00000021%5CP1008S15.txt&User=ANONYMOUS&Password=anonymous&SortMethod=h%7C-&MaximumDocuments=1&FuzzyDegree=0&ImageQuality=r75g8/r75g8/x150y150g16/i425&Display=hpfr&DefSeekPage=x&SearchBack=ZyActionL&Back=ZyActionS&BackDesc=Results%20page&MaximumPages=1&ZyEntry=1&SeekPage=x&ZyPURL)  
7122 [&ExtQFieldOp=0&XmlQuery=&File=D%3A%5Czyfiles%5CIndex%20Data%5C06thru10%5C](https://nepis.epa.gov/Exe/ZyNET.exe/P1008S15.TXT?ZyActionD=ZyDocument&Client=EPA&Index=2006+Thru+2010&Docs=&Query=&Time=&EndTime=&SearchMethod=1&TocRestrict=n&Toc=&TocEntry=&QField=&QFieldYear=&QFieldMonth=&QFieldDay=&IntQFieldOp=0&ExtQFieldOp=0&XmlQuery=&File=D%3A%5Czyfiles%5CIndex%20Data%5C06thru10%5CTxt%5C00000021%5CP1008S15.txt&User=ANONYMOUS&Password=anonymous&SortMethod=h%7C-&MaximumDocuments=1&FuzzyDegree=0&ImageQuality=r75g8/r75g8/x150y150g16/i425&Display=hpfr&DefSeekPage=x&SearchBack=ZyActionL&Back=ZyActionS&BackDesc=Results%20page&MaximumPages=1&ZyEntry=1&SeekPage=x&ZyPURL)  
7123 [Ttxt%5C00000021%5CP1008S15.txt&User=ANONYMOUS&Password=anonymous&SortMeth](https://nepis.epa.gov/Exe/ZyNET.exe/P1008S15.TXT?ZyActionD=ZyDocument&Client=EPA&Index=2006+Thru+2010&Docs=&Query=&Time=&EndTime=&SearchMethod=1&TocRestrict=n&Toc=&TocEntry=&QField=&QFieldYear=&QFieldMonth=&QFieldDay=&IntQFieldOp=0&ExtQFieldOp=0&XmlQuery=&File=D%3A%5Czyfiles%5CIndex%20Data%5C06thru10%5CTxt%5C00000021%5CP1008S15.txt&User=ANONYMOUS&Password=anonymous&SortMethod=h%7C-&MaximumDocuments=1&FuzzyDegree=0&ImageQuality=r75g8/r75g8/x150y150g16/i425&Display=hpfr&DefSeekPage=x&SearchBack=ZyActionL&Back=ZyActionS&BackDesc=Results%20page&MaximumPages=1&ZyEntry=1&SeekPage=x&ZyPURL)  
7124 [od=h%7C-](https://nepis.epa.gov/Exe/ZyNET.exe/P1008S15.TXT?ZyActionD=ZyDocument&Client=EPA&Index=2006+Thru+2010&Docs=&Query=&Time=&EndTime=&SearchMethod=1&TocRestrict=n&Toc=&TocEntry=&QField=&QFieldYear=&QFieldMonth=&QFieldDay=&IntQFieldOp=0&ExtQFieldOp=0&XmlQuery=&File=D%3A%5Czyfiles%5CIndex%20Data%5C06thru10%5CTxt%5C00000021%5CP1008S15.txt&User=ANONYMOUS&Password=anonymous&SortMethod=h%7C-&MaximumDocuments=1&FuzzyDegree=0&ImageQuality=r75g8/r75g8/x150y150g16/i425&Display=hpfr&DefSeekPage=x&SearchBack=ZyActionL&Back=ZyActionS&BackDesc=Results%20page&MaximumPages=1&ZyEntry=1&SeekPage=x&ZyPURL)  
7125 [od=h%7C-](https://nepis.epa.gov/Exe/ZyNET.exe/P1008S15.TXT?ZyActionD=ZyDocument&Client=EPA&Index=2006+Thru+2010&Docs=&Query=&Time=&EndTime=&SearchMethod=1&TocRestrict=n&Toc=&TocEntry=&QField=&QFieldYear=&QFieldMonth=&QFieldDay=&IntQFieldOp=0&ExtQFieldOp=0&XmlQuery=&File=D%3A%5Czyfiles%5CIndex%20Data%5C06thru10%5CTxt%5C00000021%5CP1008S15.txt&User=ANONYMOUS&Password=anonymous&SortMethod=h%7C-&MaximumDocuments=1&FuzzyDegree=0&ImageQuality=r75g8/r75g8/x150y150g16/i425&Display=hpfr&DefSeekPage=x&SearchBack=ZyActionL&Back=ZyActionS&BackDesc=Results%20page&MaximumPages=1&ZyEntry=1&SeekPage=x&ZyPURL)  
7126 [od=h%7C-](https://nepis.epa.gov/Exe/ZyNET.exe/P1008S15.TXT?ZyActionD=ZyDocument&Client=EPA&Index=2006+Thru+2010&Docs=&Query=&Time=&EndTime=&SearchMethod=1&TocRestrict=n&Toc=&TocEntry=&QField=&QFieldYear=&QFieldMonth=&QFieldDay=&IntQFieldOp=0&ExtQFieldOp=0&XmlQuery=&File=D%3A%5Czyfiles%5CIndex%20Data%5C06thru10%5CTxt%5C00000021%5CP1008S15.txt&User=ANONYMOUS&Password=anonymous&SortMethod=h%7C-&MaximumDocuments=1&FuzzyDegree=0&ImageQuality=r75g8/r75g8/x150y150g16/i425&Display=hpfr&DefSeekPage=x&SearchBack=ZyActionL&Back=ZyActionS&BackDesc=Results%20page&MaximumPages=1&ZyEntry=1&SeekPage=x&ZyPURL)  
7127 [od=h%7C-](https://nepis.epa.gov/Exe/ZyNET.exe/P1008S15.TXT?ZyActionD=ZyDocument&Client=EPA&Index=2006+Thru+2010&Docs=&Query=&Time=&EndTime=&SearchMethod=1&TocRestrict=n&Toc=&TocEntry=&QField=&QFieldYear=&QFieldMonth=&QFieldDay=&IntQFieldOp=0&ExtQFieldOp=0&XmlQuery=&File=D%3A%5Czyfiles%5CIndex%20Data%5C06thru10%5CTxt%5C00000021%5CP1008S15.txt&User=ANONYMOUS&Password=anonymous&SortMethod=h%7C-&MaximumDocuments=1&FuzzyDegree=0&ImageQuality=r75g8/r75g8/x150y150g16/i425&Display=hpfr&DefSeekPage=x&SearchBack=ZyActionL&Back=ZyActionS&BackDesc=Results%20page&MaximumPages=1&ZyEntry=1&SeekPage=x&ZyPURL)  
7128 [od=h%7C-](https://nepis.epa.gov/Exe/ZyNET.exe/P1008S15.TXT?ZyActionD=ZyDocument&Client=EPA&Index=2006+Thru+2010&Docs=&Query=&Time=&EndTime=&SearchMethod=1&TocRestrict=n&Toc=&TocEntry=&QField=&QFieldYear=&QFieldMonth=&QFieldDay=&IntQFieldOp=0&ExtQFieldOp=0&XmlQuery=&File=D%3A%5Czyfiles%5CIndex%20Data%5C06thru10%5CTxt%5C00000021%5CP1008S15.txt&User=ANONYMOUS&Password=anonymous&SortMethod=h%7C-&MaximumDocuments=1&FuzzyDegree=0&ImageQuality=r75g8/r75g8/x150y150g16/i425&Display=hpfr&DefSeekPage=x&SearchBack=ZyActionL&Back=ZyActionS&BackDesc=Results%20page&MaximumPages=1&ZyEntry=1&SeekPage=x&ZyPURL)

7129 (b) For these codes, standards, rules, and regulations incorporated by reference:

7130

7131 (i) The Environmental Quality Council has determined that incorporation of  
7132 the full text in these rules would be cumbersome or inefficient given the length or nature of the  
7133 rules.

7134

7135 (ii) This Chapter does not incorporate later amendments or editions of  
7136 incorporated codes, standards, rules, and regulations.

7137

7138 (iii) All incorporated codes, standards, rules, and regulations are available for  
7139 public inspection at the Department's Cheyenne office. Contact information for the Cheyenne  
7140 office may be obtained at <http://deq.wyoming.gov> or from (307) 777-7937.

**BEFORE THE  
ENVIRONMENTAL QUALITY COUNCIL  
STATE OF WYOMING**

<b>IN THE MATTER OF REVISIONS TO</b>	)	
<b>WATER QUALITY RULES AND</b>	)	<b>STATEMENT OF</b>
<b>REGULATIONS: CHAPTER 12, DESIGN</b>	)	<b>PRINCIPAL REASONS</b>
<b>AND CONSTRUCTION STANDARDS FOR</b>	)	<b>FOR ADOPTION</b>
<b>PUBLIC WATER SUPPLIES</b>	)	

**INTRODUCTION**

The Environmental Quality Council, pursuant to the authority vested in it by Wyoming Statute (W.S.) § 35-11-112 (a)(i), has adopted revisions to Wyoming Water Quality Rules: Chapter 12, Design and Construction Standards for Public Water Supplies.

The Department of Environmental Quality, Water Quality Division reduced inefficiencies within Chapter 12 by incorporating specific sections of the Recommended Standards for Water Works, 2018 Edition, by reference, in accordance with W.S. § 16-3-103(h).

The adopted revisions include new paragraphs that require public water supplies that propose acidization to submit plans that describe existing wells in the proposed area, mitigation plans, local geology, and placement and integrity of the annular seal and casing of the well so that the Water Quality Division may ensure the acidization activities do not negatively impact underground sources of drinking water that are in the vicinity of the proposed activities.

The adopted revisions also include the addition of requirements for treatment technologies, including ultraviolet and membrane technologies, that have become widely used since the chapter was originally promulgated in 1985.

Finally, the adopted revisions include the correction of outdated references, formatting, numbering, and grammar errors; the removal of metric units that are redundant to English units; the removal of introductory statements that are redundant to passages that follow the removed statements; the removal of requirements that are not within the statutory authority of the Water Quality Division; the reorganization of sections to group passages with other similar passages; the reorganization of passages to clarify requirements; and the addition of a new section that identifies the information incorporated by reference, in accordance with W.S. § 16-3-103(h).

The Council finds that these regulations are reasonable and necessary to accomplish the policy and purpose of the Act, as stated in W. S. § 35-11-102, and that they have been promulgated in accordance with rulemaking provisions of the Wyoming Administrative Procedure Act.

Dated this \_\_\_\_\_ day of \_\_\_\_\_, 2022.


\_\_\_\_\_  
Hearing Examiner – *Printed Name*  
Wyoming Environmental Quality Council

\_\_\_\_\_  
Hearing Examiner – **Signed Name**  
Wyoming Environmental Quality Council



# Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Mark Gordon, Governor

Todd Parfitt, Director

**TO:** Honorable Mark Gordon, Governor

**FROM:** Todd Parfitt, Director  
Department of Environmental Quality

**SUBJECT:** Proposed Rules for Wyoming Department of Environmental Quality, Water Quality, Chapter 12

**DATE:** August 15, 2022

**PRIORITY:** HIGH—Deadline for response is **August 29, 2022**

**SUMMARY:** The Department is proposing to amend Chapter 12, Design and Construction Standards for Public Water Supplies by adding new requirements for public water supplies that propose well acidization, updating water treatment technologies passages, and incorporating by reference the Recommended Standards for Water Works, 2018 Edition. Specific information on the changes can be found in the Statement of Principal Reasons and the accompanying supporting documentation.

**AGENCY CONTACT NAME:** Keenan Hendon

**AGENCY CONTACT PHONE:** (307) 777-7075

**AGENCY CONTACT EMAIL:** keenan.hendon2@wyo.gov

**Governor's Response Options (to be completed by Governor's Office):**

Agency may proceed.

Delay public comment and set up meeting with

*Carl Weertling* 8/19/22

Signature: Governor's Counsel



## Notice of Intent to Adopt Rules

A copy of the proposed rules may be obtained at <https://rules.wyo.gov>

Revised June 2020

<b><u>1. General Information</u></b>			
a. Agency/Board Name*			
b. Agency/Board Address		c. City	d. Zip Code
e. Name of Agency Liaison		f. Agency Liaison Telephone Number	
g. Agency Liaison Email Address			
h. Date of Public Notice		i. Comment Period End Date	
j. Public Comment URL or Email Address:			
k. Program			
Amended Program Name (if applicable):			
* <input type="checkbox"/> By checking this box, the agency is indicating it is exempt from certain sections of the Administrative Procedure Act including public comment period requirements. Please contact the agency for details regarding these rules.			
<b><u>2. Legislative Enactment</u></b> For purposes of this Section 2, "new" only applies to regular non-emergency rules promulgated in response to a Wyoming legislative enactment not previously addressed in whole or in part by prior rulemaking and does not include rules adopted in response to a federal mandate.			
a. Are these non-emergency regular rules new as per the above description and the definition of "new" in Chapter 1 of the Rules on Rules?			
<input type="checkbox"/> No. <input type="checkbox"/> Yes. If the rules are new, please provide the Legislative Chapter Numbers and Years Enacted (e.g. 2015 Session Laws Chapter 154):			
<b><u>3. Rule Type and Information</u></b> For purposes of this Section 3, "New" means an emergency or regular rule that has never been previously created.			
a. Provide the Chapter Number, Title and Proposed Action for Each Chapter. Please use the "Additional Rule Information" form to identify additional rule chapters.			
Chapter Number:	Chapter Name:	<input type="checkbox"/> New <input type="checkbox"/> Amended <input type="checkbox"/> Repealed	
Amended Chapter Name (if applicable):			
Chapter Number:	Chapter Name:	<input type="checkbox"/> New <input type="checkbox"/> Amended <input type="checkbox"/> Repealed	
Amended Chapter Name (if applicable):			
Chapter Number:	Chapter Name:	<input type="checkbox"/> New <input type="checkbox"/> Amended <input type="checkbox"/> Repealed	
Amended Chapter Name (if applicable):			
Chapter Number:	Chapter Name:	<input type="checkbox"/> New <input type="checkbox"/> Amended <input type="checkbox"/> Repealed	
Amended Chapter Name (if applicable):			
Chapter Number:	Chapter Name:	<input type="checkbox"/> New <input type="checkbox"/> Amended <input type="checkbox"/> Repealed	
Amended Chapter Name (if applicable):			

**4. Public Comments and Hearing Information**

a. A public hearing on the proposed rules has been scheduled.  No.  Yes. Please complete the boxes below.

Date:	Time:	City:	Location:
-------	-------	-------	-----------

b. What is the manner in which interested persons may present their views on the rulemaking action?

By submitting written comments to the Agency at the physical and/or email address listed in Section 1 above.

At the following URL: \_\_\_\_\_

A public hearing will be held if requested by 25 persons, a government subdivision, or by an association having not less than 25 members. Requests for a public hearing may be submitted:

To the Agency at the physical and/or email address listed in Section 1 above.

At the following URL: \_\_\_\_\_

c. Any person may urge the Agency not to adopt the rules and request the Agency to state its reasons for overruling the consideration urged against adoption. Requests for an agency response must be made prior to, or within thirty (30) days after adoption, of the rule, addressed to the Agency and Agency Liaison listed in Section 1 above.

**5. Federal Law Requirements**

a. These rules are created/amended/repealed to comply with federal law or regulatory requirements.  No.  Yes. Please complete the boxes below.

Applicable Federal Law or Regulation Citation:
--

Indicate one (1):

The proposed rules meet, but do not exceed, minimum federal requirements.

The proposed rules exceed minimum federal requirements.

Any person wishing to object to the accuracy of any information provided by the Agency under this item should submit their objections prior to final adoption to:

To the Agency at the physical and/or email address listed in Section 1 above.

At the following URL: \_\_\_\_\_

**6. State Statutory Requirements**

a. Indicate one (1):

The proposed rule change *MEETS* minimum substantive statutory requirements.

The proposed rule change *EXCEEDS* minimum substantive statutory requirements. Please attach a statement explaining the reason that the rules exceed the requirements.

b.  The Agency has completed a takings assessment as required by W.S. 9-5-304. A copy of the assessment used to evaluate the proposed rules may be obtained:

By contacting the Agency at the physical and/or email address listed in Section 1 above.

At the following URL: \_\_\_\_\_



**7. Additional APA Provisions**

a. Complete all that apply in regards to uniform rules:

These rules are not impacted by the uniform rules identified in the Administrative Procedure Act, W.S. 16-3-103(j).

The following chapters do not differ from the uniform rules identified in the Administrative Procedure Act, W.S. 16-3-103(j):

\_\_\_\_\_ (Provide chapter numbers)

These chapters differ from the uniform rules identified in the Administrative Procedure Act, W.S. 16-3-103(j) (see Statement of Principal Reasons).

\_\_\_\_\_ (Provide chapter numbers)

b. Checklist

The Statement of Principal Reasons is attached to this Notice and, in compliance with *Tri-State Generation and Transmission Association, Inc. v. Environmental Quality Council*, 590 P.2d 1324 (Wyo. 1979), includes a brief statement of the substance or terms of the rule and the basis and purpose of the rule.

If applicable: In consultation with the Attorney General's Office, the Agency's Attorney General representative concurs that strike and underscore is not required as the proposed amendments are pervasive (Chapter 3, *Types of Rules Filings*, Section 1, Proposed Rules, of the Rules on Rules).

**8. Authorization**

a. I certify that the foregoing information is correct.

<i>Printed Name of Authorized Individual</i>	
<i>Title of Authorized Individual</i>	
<i>Date of Authorization</i>	

### TAKINGS CHECKLIST

	<b>CRITERIA</b>	<b>YES</b>	<b>NO</b>
1.	Does the action affect private property? (If no, no further inquiry is necessary.)		
2.	Is the action mandated by State or federal law? (If yes, go to question 3. If no, go to question 4.)		
3.	Does the proposed action advance a statutory purpose?		
4.	Does the action result in permanent occupation of private property?		
5.	Does the action require the property owner to dedicate property or grant an easement?		
6.	Does the regulatory action interfere with the owner's investment-backed expectations?		
7.	Does the character of the government action balance the public interest and private burdens?		
8.	Does the action deprive the owner of all economically viable uses of the property?		
9.	Does the action have a significant impact on the landowner's economic interest?		
10.	Does the action deny the owner a fundamental attribute of ownership?		
11.	Does the action serve the same purpose that would be served by directly prohibiting use of the land?		
12.	Could the problem which has necessitated the action be addressed in a less restrictive manner?		

*If these questions are answered yes, legal counsel should be consulted, for it is possible the proposed action will be a taking.*

## **Water Quality Rules and Regulations Chapter 12 Takings Checklist Analysis for Proposed Revisions**


1. *Does the action affect private property?* Yes. The proposed revisions to Chapter 12 may indirectly impact private property in that the revisions may impact the conditions placed on public water supplies that are privately owned.
2. *Is the action mandated by State or federal law?* No. The action is not mandated. The action is intended to ensure that public water supply well acidization activities are properly conducted and do not negatively impact underground sources of drinking water that are in the vicinity of the proposed activities, in cases of public water systems that intend to acidize new wells during well completions. The action is intended to update existing regulations pertaining to public water systems.
4. *Does the action result in permanent occupation of private property?* No. The proposed revisions do not require the design or construction of public water systems.
5. *Does the action require the property owner to dedicate property or grant an easement?* No. The chapter does not dictate the specific placement of public water systems on private property nor does it require easements.
6. *Does the regulatory action interfere with the owner's investment-backed expectations?* No. The design and construction standards that applicants must comply with in order to obtain a permit are not prohibitive.
7. *Does the character of the government action balance the public interest and private burdens?* Yes. The purpose of Wyoming Statute § 35-11-302 as declared by the Wyoming legislature is "to prescribe standards for the issuance of permits for construction, installation, modification or operation of any public water supply and sewerage system, subdivision water supply, treatment works, disposal system or other facility, capable of causing or contributing to pollution.
8. *Does the action deprive the owner of all economically viable uses of the property?* No. The revisions do not prescribe any proposed uses of the property.
9. *Does the action have a significant impact on the landowner's economic interest?* No. The revisions do not reduce or eliminate reasonable profitable uses of the property nor do they contribute to a severe reduction in property value.
10. *Does the action deny the owner a fundamental attribute of ownership?* No. The revisions do not deny property owners of the right to possess, exclude others, or dispose of all or a portion of their property.
11. *Does the action serve the same purpose that would be served by directly prohibiting use of the land?* No. Directly prohibiting use of the land would be much more restrictive than the proposed revisions.
12. *Could the problem which has necessitated the action be addressed in a less restrictive manner?* No. Less restrictive provisions could potentially endanger human health, the environment, or private property rights.



Mark Gordon, Governor

# Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Todd Parfitt, Director

## MEMORANDUM

**TO:** Nicole Budine, Wyoming Assistant Attorney General

**FROM:** Jennifer Zygmunt, Water Quality Division Administrator

**DATE:** July 25, 2022

**PRIORITY:** HIGH – Deadline for response is **August 8, 2022**

**SUBJECT:** Request for review of proposed rules for statutory authority

The Department of Environmental Quality (DEQ), Water Quality Division (WQD) is seeking a statutory authority review of proposed revisions to Water Quality Rules Chapter 12, Design and Construction Standards for Public Water Supplies. WQD is proposing to incorporate specific sections of the Recommended Standards for Water Works, 2018 Edition by reference; add new paragraphs that require public water supplies that propose acidization to submit plans that describe existing wells in the proposed area, mitigation plans, local geology, and placement and integrity of the annular seal and casing of the well so that the Department of Environmental Quality, Water Quality Division may ensure the acidization activities do not negatively impact underground sources of drinking water that are in the vicinity of the proposed activities; add requirements for treatment technologies, including ultraviolet and membrane technologies; correct outdated references, formatting, numbering, and grammar errors; remove requirements that are not within the statutory authority of the Water Quality Division; reorganize passages to clarify requirements; and add a new section that identifies the information incorporated by reference, in accordance with W.S. § 16-3-103(h).

WQD took public comment on the proposed rules between November 5, 2021 and February 14, 2022. WQD presented the proposed revisions to Chapter 12 to the Water and Waste Advisory Board (WWAB) at meetings held on December 21, 2021, March 15, 2022, and May 3, 2022. On May 3, 2022 the WWAB voted 2-2 on a motion to move the proposed rule forward to the Environmental Quality Council (EQC). DEQ Director Parfitt has advised WQD to proceed with plans to present the revisions to the EQC at their November 15, 2022 hearing.

WQD has reviewed the requirements of W.S. 35-11-302(a)(iii) and (vi) of the Act and has determined this rulemaking to be in procedural compliance with the statute. WQD has reviewed and responded to the Takings Checklist provided by the Attorney General's Office. WQD requests a response as noted below regarding the review of the proposed rules for statutory authority. Once WQD receives your response, we will proceed as appropriate.

200 West 17th Street, Cheyenne, WY 82002 · <http://deq.wyoming.gov> · Fax (307) 635-1784

ADMIN/OUTREACH (307) 777-7937	ABANDONED MINES (307) 777-6145	AIR QUALITY (307) 777-7391	INDUSTRIAL SITING (307) 777-7369	LAND QUALITY (307) 777-7756	SOLID & HAZ. WASTE (307) 777-7752	WATER QUALITY (307) 777-7781
----------------------------------	-----------------------------------	-------------------------------	-------------------------------------	--------------------------------	--------------------------------------	---------------------------------

Per the Attorney General's Rules Handbook, you will find enclosed:

- A copy of the draft memo to Governor Gordon
- A copy of the draft Statement of Principal Reasons for Adoption
- A copy of Chapter 12 in strike and underline format
- A copy of Chapter 12 in clean format
- A response to the Attorney General's Takings Checklist.

If you have any questions or need additional information regarding the proposed rules please contact me or Keenan Hendon of my staff.

**Attorney General's Response Options:**

X


Proposed Rules are within the Division's statutory authority, may seek permission to proceed from the Governor's Office.

\_\_\_\_\_

Proposed rules exceed statutory authority, delay proceeding with rulemaking



Signature: Nicole Budine




Date

JZ/gjt



# Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.




Mark Gordon, Governor



Todd Parfitt, Director

**TO:** Honorable Mark Gordon, Governor

**FROM:** Todd Parfitt, Director   
Department of Environmental Quality

**SUBJECT:** Supplemental Information Related to Proposed Rules for Wyoming Department of Environmental Quality, Water Quality, Chapter 12

**DATE:** August 15, 2022

**PRIORITY:** **HIGH**—Deadline for response is **August 29, 2022**

**AGENCY CONTACT NAME:** Keenan Hendon

**AGENCY CONTACT PHONE:** (307) 777-7075

**AGENCY CONTACT EMAIL:** keenan.hendon2@wyo.gov

**SUPPLEMENTAL INFORMATION:** As noted in the request for approval to proceed with rulemaking, the Department is proposing to amend Chapter 12, Design and Construction Standards for Public Water Supplies. The following supplemental information summarizes the Water Quality Division's (WQD) determination that consultation and advice of the Water and Waste Advisory Board (WWAB) under Wyoming Statutes (W.S.) § 35-11-114(b) has been satisfied in order to proceed with the associated request for approval to begin formal rulemaking.

The WQD presented revisions to Chapter 12 to the WWAB three times, at meetings held on December 21, 2021, March 15, 2022, and May 3, 2022. At the May 3, 2022 meeting, the WWAB voted 2-2 on a motion to move the proposed rule forward to the Environmental Quality Council (EQC).

The two board members opposed to the motion expressed concern that the proposed revisions contained incorrect and unclear references. In response, the WQD has carefully considered these concerns and has conducted an additional review of the proposed rule to ensure the use of correct references and to clarify incorporation by reference language. The WQD will include these non-substantive revisions in the rulemaking materials submitted to the Environmental Quality Council.

The two board members opposed to the motion also felt another public comment opportunity associated with the WWAB's review was warranted. The WQD has considered this advice but does not agree that an additional public comment period would add value at this time because of the substantive public outreach already conducted: the WQD held an informal public outreach comment period in October 2020; the proposed rule was available for public comment for a total of 130 days in association with the WWAB meetings; the WQD responded in writing to all comments received during the public comment opportunity and contacted each commenter individually to ensure comments were understood and

200 West 17th Street, Cheyenne, WY 82002 · <http://deq.wyoming.gov> · Fax (307) 635-1784

ADMIN/OUTREACH (307) 777-7937	ABANDONED MINES (307) 777-6145	AIR QUALITY (307) 777-7391	INDUSTRIAL SITING (307) 777-7369	LAND QUALITY (307) 777-7756	SOLID & HAZ. WASTE (307) 777-7752	WATER QUALITY (307) 777-7781
----------------------------------	-----------------------------------	-------------------------------	-------------------------------------	--------------------------------	--------------------------------------	---------------------------------

addressed; and the WQD hosted a webinar to provide an overview of the proposed rule and answer questions from the public. Only one member of the public provided comments during the March 2022 meeting, and, during that meeting, the WWAB advised the WQD that another public comment period would not be necessary if the WWAB had an additional meeting to review the rule.

Upon receipt of the Governor's Office approval to proceed with formal rulemaking, the WQD will provide a 45-day public comment opportunity prior to the EQC hearing, in accordance with W.S. § 16-3-103(a)(i). Additionally, the WQD will provide the EQC with all WWAB comments to ensure EQC members are informed of the concerns raised by members of the WWAB.

The WWAB has consulted and advised the WQD Administrator on the entirety of the proposed rule and that advice has been thoroughly considered and incorporated as appropriate by the WQD Administrator. It is the WQD's determination that the WWAB has satisfied its statutory requirement to advise the Administrator on the proposed rule, per W.S. § 35-11-114(b).

Finally, it is important to update the chapter in a timely manner to ensure public water systems are constructed and modified in accordance with current standards, specifications, and treatment technologies. With the state poised to potentially receive over \$413 million for drinking water infrastructure projects over the next five years under the Bipartisan Infrastructure Law, it is particularly important to ensure we are operating under up-to-date standards and specifications to support defensible and consistent decision-making to protect public health and to give the regulated community current information to support long-term planning and avoid compliance issues.

JZ/KH/GJT

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

WYOMING WATER AND WASTE ADVISORY BOARD

-----  
RE: Water Quality Rules, Chapter 12  
-----

TRANSCRIPT OF WWAB HEARING PROCEEDINGS

Pursuant to notice duly given to all parties in interest, this matter came on for hearing on the 21st day of December, 2021, at the hour of 10:31 a.m., at the Capitol Extension Room 4, Herschler Building, 122 West 25th Street, Cheyenne, Wyoming before the Wyoming Water and Waste Advisory Board. Mr. Alan Kirkbride, Chairman, presiding, with Mr. James Cochran in attendance, and Mr. Brian Deurloo, Ms. Lorie Cahn, and Brian Dickson also in attendance virtually.

Ms. Nicole Budine, Attorney for the Board, present virtually; Ms. Jennifer Zygmunt, Water Quality Administrator; Mr. Bill Tillman, SRF Principal Engineer; Mr. Keenan Hendon, Water and Waste Water Section Manager; and Ms. Gina Thompson, Water Quality Division, were also in attendance, as well as various members of the public.



1 PROCEEDINGS

2 (Hearing proceedings commenced  
3 10:31 a.m., December 21, 2021.)

4 CHAIRMAN KIRKBRIDE: I think we're present  
5 and accounted for. I don't see anybody else clamoring at  
6 the door here, so why don't we start.

7 Would you like to --

8 MS. ZYGMUNT: Thank you, Mr. Chairman,  
9 Members of the Board. We are pleased to be here today to  
10 present our revised Chapter 12 to you, the Wyoming Water  
11 Quality Rules.

12 My name is Jennifer Zygmunt. I'm the  
13 Administrator of the Water Quality Division appointed in  
14 August. And with me today I have Bill Tillman, who is our  
15 SRF Principal Engineer. Bill works primarily in the SRF  
16 program, but also extensively with rules and also  
17 enforcement actions.

18 I will note that Bill is retiring on  
19 December 29th. He's been with us a long time, so we will  
20 miss him. I know he's worked with the Board on many rule  
21 packages. I just wanted to pass that news on and let you  
22 know how much we appreciate Bill and all of his efforts  
23 over the years.

24 And I'm also pleased to introduce Keenan Hendon  
25 to the Board. Keenan is our new Water and Wastewater

1 Section Manager. He joined us in August, I believe.

2 MR. HENDON: August.

3 MS. ZYGMUNT: He took over for Rich Cripe,  
4 who left the DEQ in May. So we're very pleased to have  
5 Keenan on board. He brings a lot of great experience from  
6 other state agencies, including Water Development and State  
7 Lands.

8 So I'll start with a brief overview of why we're  
9 here today, the purpose of the rule, the revisions that  
10 we've made, and then I'll turn it over to Bill and Keenan  
11 to walk through the rule revisions in detail and also  
12 through the public comments we received on this rule.

13 Chapter 12 establishes a design and construction  
14 standards for public water supplies. Entities that wish to  
15 construct, install or modify public water supply need to  
16 meet these standards when they're applying for a permit to  
17 construct under Chapter 3 of our rules.

18 And as a quick reminder, Wyoming doesn't have  
19 primacy for many of the drinking water regulatory programs  
20 under the Safe Drinking Water Act. EPA Region 8 directly  
21 implements the Public Water System Supervision Program in  
22 Wyoming, which includes things such as developing  
23 regulations for drinking water protection, managing  
24 compliance with those regulations and conducting sanitary  
25 surveys. But we, Wyoming DEQ, issues the permits to

1 construct these facilities, so it's important that we work  
2 with EPA on these standards to make sure that communities  
3 can remain in compliance with both EPA's regulatory  
4 programs and our regulatory programs. So there are areas  
5 of overlap, and you'll hear some of those later today in  
6 our presentation and some of the public comments.

7           So why are we revising Chapter 12 now? First, it  
8 hasn't been updated in quite some time. We first  
9 promulgated this rule in 1984. It was updated in 2003,  
10 2006 and 2012. But those are very minor revisions and only  
11 tackle either cross-reference updates or specific  
12 subsections. So, in essence, it's about 4 years -- 40  
13 years since Chapter 12 has had a complete reevaluation.

14           As you can imagine, in 40 years technology has  
15 changed, and it's important to incorporate the modern  
16 technologies for drinking water treatment into our rules to  
17 make sure that communities have up-to-date options for  
18 drinking water protection in the state. In particular,  
19 you'll see updates related to ultraviolet treatment and  
20 membrane technology.

21           Third, we're going to talk about incorporation by  
22 reference. And I appreciate some of the comments that we  
23 heard in the previous Division's presentation this morning.  
24 But we have done quite a bit of incorporation by reference  
25 into this chapter, and that did start under Governor Mead's

1 initiative in 2013 to streamline our rules. So we've  
2 incorporated the 10 States Standards into the rule. It's  
3 also known as the Recommended Standards for Waterworks.  
4 10 States Standards is the short name, which we -- which  
5 you'll hear a lot.

6 We do understand that there are pros and cons to  
7 incorporation by reference, and we'll look forward to some  
8 discussions and questions on that. We'll be happy to  
9 provide some more perspective.

10 You know, even though that initiative came out  
11 under Governor Mead's administration, I do feel that  
12 streamlining and efficiency's important under any  
13 administration, so it is my goal as administrator to make  
14 as good of a product as we can for the regulatory  
15 community. And I do feel incorporation by reference is the  
16 way to go. However, it's my responsibility to recommend  
17 these rules to our director after consultation with the  
18 advisory board. So we will take feedback on that aspect of  
19 the rule. And, again, we do recognize that there are pros  
20 and cons to going that route.

21 We have been able to reduce this rule by about 10  
22 pages from the previous version due to the incorporation by  
23 reference. I will note that if we put in the standards --  
24 this is a copy of the 10 States Standards. It's 144 pages.  
25 So if we incorporated the language back in, we would see

1 significant increases to this rule. So something to  
2 consider.

3 Fourth, another major revision to Chapter 12 is  
4 that we've added requirements for public water supplies  
5 that are proposing acidization to submit detailed  
6 information about wells in the area and geologic conditions  
7 in the area to make sure that those acidization activities  
8 aren't affecting underground sources of drinking water.

9 And this came about due to special -- a special  
10 investigation in the state a few years ago. And while  
11 acidization didn't end up being the cause of the water  
12 quality concerns, it did point out some areas where we  
13 could strengthen our rules to make sure groundwater was  
14 being protected.

15 And then, finally, this rule has undergone our  
16 Attorney General edits for streamlining, consistency and  
17 clarity per their directive to review all our rules. I  
18 know that you're now becoming familiar with seeing those  
19 edits and that they can be quite overwhelming when you're  
20 looking at them in a strike and underline version.

21 I think Gina has done a great job trying to  
22 digest what the actual changes are, even pointing out where  
23 we're just moving information versus where we've actually  
24 added language or removed language. So, again, we know  
25 that can be a lot to understand and track changes, and we'd

1 be happy to answer questions today to help understand what  
2 were Attorney General edits and what were removal of  
3 language or addition of language.

4           And I do feel, even though they're challenging,  
5 the Attorney General edits are leading to better rules  
6 products for our Division, so we've enjoyed working with  
7 the Attorney Generals to make those edits.

8           So we do recognize these are extensive updates to  
9 this chapter. Again, it's been 40 years -- almost 40 years  
10 since we've given this chapter a comprehensive look. It  
11 has been a significant undertaking for staff. We have been  
12 working on this rule about five to six years.

13           Staff turnover within the Division has also been  
14 a challenge. So I would just like to thank the staff who  
15 have worked on this chapter over the years to get it to  
16 this point where we're ready to present it to you today.

17           I'll also note that we originally brought this  
18 rule to you in 2019. At that time we had only proposed  
19 revisions for well acidization. The Board proposed -- or  
20 advised us to move forward to the EQC at that time.

21 Between the Advisory Board meeting and the EQC meeting, we  
22 have further edits through our Attorney General's Office.  
23 And understandably that caused quite a bit of concern with  
24 our stakeholders, so at that time we opted to withdraw the  
25 rulemaking and start over and have incorporated the broader

1 revisions we are bringing before you today.

2           So we know this is an important rule to the  
3 state. Many entities are very interested in that rule --  
4 our public water systems, municipalities, private  
5 engineering firms, the Wyoming Association of Rural Water  
6 Systems, also known as WARWS, and other stakeholders. We  
7 did informal outreach for this chapter in October of 2020,  
8 and worked with WARWS and one private engineering firm to  
9 incorporate feedback at that time, and we appreciate their  
10 comments.

11           As you saw in your handouts, we had ample public  
12 comments on this chapter, again which reflects a high  
13 interest from the regulated community and other  
14 stakeholders in these standards. We received over a  
15 hundred comments from eight different entities. Most of  
16 those were received during the 30-day public notice period  
17 that started on November 5th. We did also receive two  
18 comment letters yesterday on Monday and staff did a great  
19 job working very hard yesterday to respond to those  
20 comments. So what we're presenting to you today are  
21 responses to all hundred-plus comments that we received on  
22 this rule.

23           The comments addressed some important aspects  
24 that we'll hear you about today. Again, I do look forward  
25 to more conversation on incorporation by reference and some

1 other specific topics that are important subjects to  
2 discuss when we talk about design and construction  
3 standards for public water supplies.

4 So with that, unless anybody has any questions  
5 for me, I'll turn it over to Bill.

6 Yes, Mr. Chairman.

7 CHAIRMAN KIRKBRIDE: Yes, I have a question  
8 about the 10 States Standards. What are those 10 states?  
9 Are they regional? Are they -- and then what -- are they a  
10 division of the EPA, or do they have -- what authority do  
11 they make decisions? And do we -- does Wyoming have input  
12 somewhat on these?

13 MS. ZYGMUNT: Yes, thank you, Mr. Chairman.  
14 That's a good question. I'm actually going to defer that  
15 to Bill or to Keenan to talk about what the 10 States  
16 Standards are.

17 CHAIRMAN KIRKBRIDE: Okay. That's all I  
18 had. Anybody else got some general, for Ms. Zygmunt,  
19 questions? Okay.

20 BOARD MEMBER DEURLOO: Mr. Chairman, I do  
21 have one question, if you don't mind.

22 CHAIRMAN KIRKBRIDE: Yes. Go ahead, Brian.

23 BOARD MEMBER DEURLOO: Thank you.

24 Hi, Jennifer. Thank you for that overview. Just  
25 a question for -- what sort of input do -- does your



1 staff -- or the people that have to implement these rules  
2 for Chapter 12, what district people, or even in Cheyenne,  
3 set up members of the DEQ, what sort of input process do  
4 you have as you roll this out to your staff statewide? And  
5 what kind of timing do you give them and -- if you can kind  
6 of just go through that process and how you get your staff  
7 involved, please.

8 MS. ZYGMUNT: Yes. Mr. Chairman. Board  
9 Member Deurloo, thank you for the question. It's a good  
10 one. Again, this has been a long-term effort for the  
11 Division. Again, we've been working on this five to six  
12 years. It's gone through ample internal review with our  
13 staff, including Bill and other district engineers in the  
14 Cheyenne office and across the state.

15 As I mentioned, we did do informal outreach in  
16 October 2020, where we sent the scope of revisions that we  
17 were thinking about to interested parties, including all of  
18 our public water systems, Wyoming Association of Rural  
19 Water Systems, and asked for feedback at that time. Again,  
20 at that time, we can received comments from WARWS and one  
21 private engineering firm.

22 And so while I think folks have been aware that  
23 we've been working on Chapter 12, I think this past 30-day  
24 public comment period, again that started on November 5th,  
25 is really the major public comment opportunity that folks

1 have had to look at the final draft rule and provide  
2 comments.

3           After -- or during the public notice period, we  
4 did reach out to WARWS and had a targeted conversation with  
5 them about some of the revisions that we made and  
6 addressing certain subjects. And then also we had a  
7 targeted conversation with EPA to gain some of their  
8 feedback and go over some of the revisions that we had  
9 made.

10           So, again, we have been doing outreach at the  
11 beginning of the rule, and now during the public comment  
12 period for the rule. And if the Board advises us to move  
13 forward to the EQC during this meeting, there would be  
14 another public comment opportunity prior to the EQC  
15 meeting.

16           Does that answer the question, Board Member  
17 Deurloo?

18           BOARD MEMBER DEURLOO: Yes. Thank you,  
19 Ms. Zygmunt. I appreciate that.

20           So do you -- yeah, you said that in your  
21 introduction. Thanks for repeating some of that  
22 information.

23           Do you feel that it's -- people saw this like --  
24 and they saw the 2020 -- people had a -- a -- had time to  
25 look at 20- -- or 2019 and 2020. Do you feel that from

1 this last month of public comment that people are waking up  
2 or getting a lot more comments saying this is real and it's  
3 getting close to the end? I don't know. I'm just kind of  
4 looking for your feelings for why are we having so many  
5 comments in this last 30 days where we hardly had any input  
6 in the last two years? If you can speak to that a bit.

7 MS. ZYGMUNT: Yes. Mr. Chairman. Board  
8 Member Deurloo, it's a good question. I don't know that I  
9 have a good answer to that.

10 However, Mr. Chairman, if I can turn it over to  
11 Mr. Tillman, I think he has some more input that may help  
12 answer the question.

13 MR. TILLMAN: This is Bill Tillman, again,  
14 SRF Principal Engineer, as well as rules and enforcement.

15 And over the past couple years I think part of  
16 the reason why we probably didn't get comments is that we  
17 were still working on the draft internally.

18 And speaking to some of your questions, Board  
19 Member Deurloo. Through the draft process, we -- as we  
20 were drafting it, we spent time at each of the district  
21 offices in different sections talking about the contents,  
22 things they liked, didn't like, things that they weren't  
23 getting, as far as when we were receiving applications for  
24 particular projects, things that were missing.

25 So throughout the drafting process of all the

1 different sections, we interacted with each of the staff  
2 members in their district offices and individually fielded  
3 comments from them regarding, you know, changes that we  
4 were making. So I guess throughout the last five or six  
5 years, we've kind of hashed this out internally, you know,  
6 over and over again.

7           Now, the fact that we received quite a few  
8 comments over the last 30 days, particularly the last few  
9 days, in addition to those, I think that just speaks to  
10 people's concerns, people's interests. I don't think that  
11 the two years previous had any bearing on that, because  
12 they didn't have any product to look at. It wasn't  
13 available to them. We were still, I guess, working on it  
14 internally. So that speaks to their lack of comments over  
15 the last few years. But I believe that the comments we did  
16 receive were fairly spread out. Some of them were more on  
17 format and content. I believe that the EPA was -- in  
18 particular, they had more comments on individual  
19 technologies and specifics within the treatment sections.  
20 But overall, I believe the comments were fairly spread out  
21 across the board as far as different interests, the people  
22 exposed, I guess, their concerns with what we were doing.

23           Hopefully that answers your question, Board  
24 Member Deurloo.

25                           BOARD MEMBER DEURLOO: Thank you,

1 Mr. Tillman. I appreciate that.

2 Mr. Chairman, I have no further questions at this  
3 time.

4 CHAIRMAN KIRKBRIDE: Anyone else?

5 All right. Ma'am, you may proceed.

6 MS. ZYGMUNT: Thank you, Mr. Chairman.

7 Would you like us to follow up on your question about the  
8 10 States Standards first before we go into the rules?

9 CHAIRMAN KIRKBRIDE: Yeah. If you want to.

10 MR. HENDON: Absolutely. Keenan Hendon,  
11 Wyoming -- or Wyoming DEQ, the Water/Wastewater Section  
12 Manager.

13 So the Great Lakes-Upper Mississippi River Board  
14 of State and Provincial Public Health and Environmental  
15 Managers, that's -- that is the entity or the group, the  
16 board, that works together to provide the recommended  
17 standards for waterworks. And they're comprised -- they  
18 started off in 1950. Excuse me.

19 BOARD MEMBER CAHN: Excuse me.

20 MR. HENDON: Yes.

21 BOARD MEMBER CAHN: For some reason you're  
22 breaking up. So maybe if you could speak closer to the  
23 microphone, that might help.

24 MR. HENDON: Is this a little bit better?

25 BOARD MEMBER CAHN: Fantastic.

1 MR. HENDON: All right. Perfect.

2 So the Great Lakes-Upper Mississippi River Board  
3 of State and Provincial Health and Environmental Managers  
4 started off in 1950. Excuse me. They had met subsequently  
5 over the years. Most recently they've prepared this 2018  
6 standard. And the states that participate and entities  
7 that participate are Illinois, Indiana, Iowa, Michigan,  
8 Minnesota, Missouri, New York, Ohio, Ontario, Pennsylvania  
9 and Wisconsin. So a number of states that are similar in  
10 region and weather and acclimation. Also a number of  
11 states incorporated by reference, so they incorporate the  
12 same rules as presented for their water systems and for  
13 their designs of the well.

14 CHAIRMAN KIRKBRIDE: So we like these  
15 standards because we like them, right? Because they're  
16 suitable?

17 MR. TILLMAN: Chairman Kirkbride, it's not  
18 so much that they're suitable. But, I guess, in the  
19 engineering industry, specifically I believe in civil  
20 engineering, this has been kind of the Bible, if you will,  
21 for designing water treatment systems for municipalities or  
22 special districts. It's kind of -- like I said, it's an  
23 unwritten document that engineers go by. That's why we  
24 typically call it the 10 States Standards and everybody  
25 knows what that document is.

1           And so that's why -- unfortunately, when our  
2 rules were first promulgated, the consultant that, I guess,  
3 put these rules together essentially took the 10 States  
4 Standards almost verbatim for large swaths of our rule.  
5 And since that was the case, that was kind of our impetus  
6 for our incorporation by reference. Because as I went  
7 through it, I would find pages, paragraphs, that were  
8 identical, and I mean word for word what they were saying.  
9 So it just made sense for us to make that incorporation by  
10 reference, one, because it was standards that we use, and  
11 also to meet the requirement that the governor gave us at  
12 that time to reduce our rules. But as you see, our -- the  
13 number didn't reduce all that much. But then, again, there  
14 was quite a few new technologies and things that we had to  
15 add to the chapter that were not spoken to before. So it  
16 was kind of a balance, if you will, of subtraction and  
17 addition that came to the total number that we're at right  
18 now.

19                           CHAIRMAN KIRKBRIDE: Thank you.

20           Okay. Anything else on that?

21           All right. Proceed.

22                           MS. ZYGMUNT: Thank you, Mr. Chairman.

23 I'll turn it over to Bill now to walk us through the rule  
24 and the revisions that we made.

25                           MR. TILLMAN: Chairman Kirkbride. I'd like

1 to begin with, as our administrator, Ms. Zygmunt, alluded  
2 to, that the Attorney General, they made quite a few  
3 changes as far as to layout, orientation, format, and those  
4 sorts of things. I'm not going to speak to those for each  
5 and every section. It's pervasive throughout the chapter.

6           Additionally, there was grammar and punctuation  
7 changes. A lot of rearranging. If you look at the strike  
8 and underline version, it makes my head spin. I imagine it  
9 did yours as well. It seems like there was a lot going on,  
10 but there was a lot that was removed, a lot of things that  
11 were -- places were changed as far as where they were for,  
12 I guess, readability and for just cohesiveness, as far as  
13 we had some things spread out in different sections that  
14 really should have been put together, and we tried to  
15 accomplish that through part of the rewrite.

16           In addition, in the incorporation by reference,  
17 the fact that we had large parts of the chapter that were  
18 incorporated by reference, we tried to do that at the  
19 beginning of each section, those parts that were  
20 incorporated. So in some sections it's not as much, in  
21 other sections, as in Section 12, the treatment section, is  
22 quite an extensive list of what is incorporated by  
23 reference. But we tried to do that up front in each  
24 section, and everything that followed that is an exception  
25 to those things that were incorporated. So that's kind of



1 format that we followed.

2 I understand that for some folks that may create  
3 some -- a bit of a headache because they've got to kind of  
4 go back and forth. But speaking as a professional  
5 engineer, I spent 20 years in refining before I came to the  
6 regulatory side, and I can say that I don't believe I had  
7 any design -- and I mean any design -- that I used one book  
8 exclusively that I could use to finish a design. I've used  
9 several books, several references, looking at materials,  
10 different techniques, maybe even different components. So  
11 that part of the design incorporating by reference and  
12 using multiple documents to me is nothing new and something  
13 that is expected as an engineer. Your boss just wants an  
14 answer. He doesn't really care how many things you have to  
15 look at to get him that answer, he just wants an answer.

16 So I understand that as -- from -- from the  
17 public saying that it would be nice to have it all in one  
18 spot, but from an engineering perspective, it's never been  
19 in one spot. So that's my perspective on that.

20 Moving forward, though, I'd like to go through  
21 each section and give you just kind of general summary.  
22 I'm not going to go in detail. If you have questions about  
23 each section or in a section, please bring those up as  
24 we're going along. But I'd like to begin, if you would  
25 allow me.

1                   CHAIRMAN KIRKBRIDE: Please do.

2                   MR. HENDON: Say, Bill.

3                   MR. TILLMAN: Yes.

4                   MR. HENDON: If I could, I'd just like to  
5 also state that the 10 States Standards is available online  
6 for purchase. It's \$13 in cost. So it is available. It's  
7 out there. We're also looking at options to prepare and  
8 provide that online, if we can, through our website. And  
9 we're also going to make sure it's available through our  
10 satellite offices as well for review and for our design  
11 engineers throughout the state to come in and take a look,  
12 if they need to.

13                   CHAIRMAN KIRKBRIDE: All right.

14                   MR. TILLMAN: Beginning with Section 1,  
15 which is our Authority. There were minor changes to that,  
16 and just restated our statutory authority to promulgate  
17 rules.

18                   In Section 2, Applicability, again, this is minor  
19 changes where we added words to clarify the applicability  
20 of the rules that are presented in our chapter.

21                   Section 3 is compliance with our new standards.  
22 And that's where we had some comments. Some people were  
23 concerned that the new changes to the chapter that they had  
24 to go through their facility and radically change what they  
25 already had or what had been approved prior to that. But

1 in the new section, existing facilities are going to be  
2 covered under previous -- or the existing Chapter 12  
3 design. Any new construction or modification to existing  
4 facilities would then be required to follow the new  
5 conditions in the new chapter.

6 In Sections 4, 5 and 6, where we discuss the  
7 incorporation by reference, the definitions that were used,  
8 some taken out, and also other technologies. There's  
9 nothing new in those sections. Those were brought over  
10 from the previous Chapter 12. Of course the incorporation  
11 by reference, how we're doing that, is discussed in detail.

12 The other technologies section is, again,  
13 something that was in the previous Chapter 12, and it just  
14 allows for anything that's developed recently or we're not  
15 aware of or maybe some unique niche treatment possibility,  
16 that people can bring that forward in application and bring  
17 us basically information, pilot plant data, maybe full-  
18 scale data that supports that the new technology is  
19 applicable for a particular treatment issue that they're  
20 dealing with. But we still have that as an alternative for  
21 folks to present new ideas to us that we're not aware of  
22 for application for treatment facilities.

23 In Section 7, under Permits, Applications, and  
24 Recordkeeping, again, this -- we added a part there that  
25 was not previously in the Chapter 12. It's in our Chapter

1 3, as far as how we accept applications for permits. But  
2 we're no longer requiring that application be submitted in  
3 triplicate hard copy. We had that same language where they  
4 submitted in a form acceptable to our Administrator, but  
5 basically that gives our district engineers the flexibility  
6 to request only one electronic copy and maybe one hard  
7 copy, again, hopefully making it easier for our applicants  
8 to submit information, and also for us to deal with that  
9 information.

10 Applicants also need to -- we had a section where  
11 we put it in the rule that they have to give us secure  
12 access to the facility through easements or public road  
13 access. Again, this was something that was in the document  
14 permit that was issued that spoke to the fact that we need  
15 to have access to do inspections and other sorts of things  
16 to carry out our regulatory duties, but now we put it in  
17 the rules so that they also understand it in the chapter as  
18 well as in the paperwork they receive that we will need to  
19 have access to the site.

20 We also included in the chapter -- that was also  
21 Chapter 3 but not in Chapter 12 -- the requirement that  
22 most of the documents that we receive in an engineering  
23 application or engineering report needs to be signed and  
24 sealed by a registered professional engineer or registered  
25 professional geologist, depending on the discipline area

1 that was discussed in the application or the project.

2           Also, in this section we discuss -- or we codify  
3 what was previously a procedural way we handled things,  
4 namely in water wells and storage tanks. In water wells  
5 that were permitted, that was essentially what we call a  
6 two-step process, where we issue a permit for them to drill  
7 the well, construct it and get data from it. And once we  
8 got that data, then we would evaluate the data, the water  
9 quality, and then issue another permit to allow them to  
10 actually hook that to the distribution system. So, again,  
11 that was kind of a two-step process that was understood.

12           One that was not so well understood was when we  
13 had water storage tanks that were funded through the Water  
14 Development Office, it was kind of -- kind of a mishmash of  
15 how we got through that, because Water Development needed  
16 to bid the project prior to actually all the engineering  
17 being done. But as a part of that bid, they needed to  
18 receive a permit from us saying that we would allow the  
19 storage facility to be constructed. And so you kind of see  
20 we didn't have all the information, so we were reluctant to  
21 give them that permit, but they needed that permit in order  
22 to get the bids out. So we amended that. We put it in  
23 rule to where we understand that when they initially apply  
24 for a water storage tank permit, especially one that's  
25 funded by Water Development, we know that we're not going

1 to have all the information specifically, the foundation  
2 information or the geologic information that supports that,  
3 we're not going to have initially. So we'll give them a  
4 permit to go out to bid that talks about some more or less  
5 the general aspects of the tank. But within those bid  
6 documents, we require that they acknowledge that they would  
7 come back to us and that the remaining parts of the tank  
8 construction and design would be per Chapter 12 and be  
9 approved by us and they will receive a second permit to  
10 complete construction of that tank.

11 And that was, again, something that was not  
12 necessarily codified in rule, but it was a procedural --  
13 that was kind of understood when people came to us, and we  
14 thought it was important that that in particular was put in  
15 the rules so people understood that when you're having a  
16 tank funded by Water Development, that it was going to be a  
17 two-step process, and that, you know, it's going to take  
18 some time, but it was understood by both parties the  
19 process that was -- it was going to take.

20 CHAIRMAN KIRKBRIDE: Okay.

21 MR. TILLMAN: In Section 8 and Section 9,  
22 we discuss -- in Section 8 is Plans and Specifications and  
23 Section 9 is the engineering report. And in both of those  
24 sections nothing significant changed there, although we did  
25 add a little specificity as to the different types of

1 application that we get, be it from projects that involve  
2 distribution systems in particular or a section of a  
3 distribution system, as opposed to major changes to a  
4 treatment works operation.

5           But what we did there was basically specify what  
6 we would want in the engineering report, as well as in the  
7 plans and specs for the individual types of projects that  
8 we would get so that the applicant would know kind of the  
9 information that we needed to have, because sometimes,  
10 again, we weren't necessarily getting the specific  
11 information we needed for a particular type of project, and  
12 it was not spelled out in the previous chapter exactly what  
13 we were expecting to receive. So we tried to clarify that.

14           In Section 10, we added a requirement there.  
15 It's in the minimum design and construction standards. I  
16 believe before it was called just general design  
17 considerations. But we wanted to add and have the design  
18 engineer, when they were proposing either new treatment  
19 works or modification to treatment works, that we added a  
20 degree or considered a degree of flexibility in the plant  
21 design from anywhere from changes in that water quality to  
22 the need to possibly increase the treatment capacity if a  
23 service area increased or even adding new treatment  
24 technology. We wanted to make sure that the design and how  
25 it was constructed made it easier to make those

1 modifications if they were required. And it was something  
2 that we wanted to make sure that, again, the design  
3 engineer considered at the outset of that application and  
4 that project modification.

5 CHAIRMAN KIRKBRIDE: I have a question.

6 MR. TILLMAN: Yes, sir.

7 CHAIRMAN KIRKBRIDE: Backing up just a  
8 little on applying for permits. It seems to me like it's  
9 so many entities, individuals, and otherwise, apply for  
10 permits from governmental agencies. It seems like to me  
11 people feel they have encountered an unreasonable delay. I  
12 don't know if delay, but it just takes a long time to get  
13 the permit back. And I just wonder, what's your experience  
14 with this?

15 MR. TILLMAN: Chairman Kirkbride, I  
16 understand, and I've heard that same feedback from certain  
17 individuals, that they feel like it's taken more time than  
18 they felt necessary to receive a permit. Some of that has  
19 to do with our staffing issues that we've had over the last  
20 three or four years. We've just now, I believe, in the  
21 last three or four months come up to a full staff, where I  
22 believe the last four or five years previous to that we  
23 were short at least two to three engineers. So, you know,  
24 from the district engineers that had assistance, they  
25 didn't have that assistance. So, again, you have one



1 man -- one person handling all those applications.

2           In addition to that, many times we don't get all  
3 the information necessary to review the application and to  
4 issue that permit. And it's incumbent upon the applicant  
5 to give us that information. And sometimes it's not the  
6 applicant, it's the engineering company or people working  
7 for the engineering company that don't necessarily -- it's  
8 not on the top of their list to get us information that  
9 we're missing. They felt like they gave us everything they  
10 thought they needed to give us, but we didn't receive it.  
11 So there's some back and forth with that as well as far as  
12 receiving the proper information.

13           Additionally, and one they don't like to hear, is  
14 that statutorily we do have 60 days to complete a permit,  
15 to issue a permit. And many times consultants, engineers  
16 will think that theirs is fairly simple and they submit it  
17 to us, and then we get a call literally within a couple of  
18 days of receiving the application asking us if we started  
19 working on it yet, or if we could move that up a little bit  
20 in the list. And absolutely we cannot do that. We work on  
21 them and review them as they come in. Unfortunately, if  
22 there's 15 ahead of you, you're number 16 and we can't  
23 start working on that until we kind of plow through rest of  
24 them.

25           And so there's a combination of things that

1 contribute to that perceived delay. Again, part of it is,  
2 again, lack of staff at one point. But, again, many times  
3 it's information that we're requesting going back and  
4 forth, you know, trying to get that information to make  
5 sure it's complete so we can do that review.

6 CHAIRMAN KIRKBRIDE: All right. And then  
7 I'm not the only one that complains to you guys, but that's  
8 just a general statement.

9 Is there -- are they -- is the demand for -- I  
10 assume it's mostly modifications in the state here; is that  
11 right?

12 MR. TILLMAN: Primarily. You don't get a  
13 lot of brand-new treatment works that are being  
14 constructed. You get many modifications to existing  
15 treatment works. There's some emergent contaminants that  
16 are coming up, peat moss, peat humus, some of those types  
17 of things.

18 So, yeah, you're correct, Chairman Kirkbride,  
19 that most of them are modifications, you know, to an  
20 existing system.

21 CHAIRMAN KIRKBRIDE: And the workload is --  
22 is fairly heavy?

23 MR. TILLMAN: It's increasing. There are  
24 certain districts that get a significant more applications  
25 than others, particularly this district, the southwest

1 district and the northeast district, which is -- northeast  
2 is Casper, kind of run up to Sheridan and then go to the  
3 border there.

4           The Sheridan-Gillette area is doing a lot of  
5 work. In addition to down here, we're getting not only  
6 subdivisions, but a lot of modifications to existing  
7 system. Maybe not so much in the southwest district, but I  
8 believe that the northwest is all starting to pick up as  
9 far as the number of applications they're getting for other  
10 entities, kind of mobile home parks, trailer parks, things  
11 like that. So there are some that have more activity than  
12 others, so that kind of contributes to some of the delays  
13 that they might be seeing.

14           CHAIRMAN KIRKBRIDE: Uh-huh.

15           MR. HENDON: Yes, Chairman Kirkbride, if I  
16 can also add to that. A number of our districts are seeing  
17 increased subdivision applications. And so that is a  
18 number of folks moving into our state, which is good, but  
19 it's creating an increased workload for all of us, so...

20           CHAIRMAN KIRKBRIDE: Uh-huh. Thank you.

21           BOARD MEMBER CAHN: Chairman Kirkbride.

22           CHAIRMAN KIRKBRIDE: Yes.

23           BOARD MEMBER CAHN: Bill, I wanted to ask  
24 you. You mentioned that you guys weren't getting what you  
25 needed for Sections 8 and 9. Can you give an example --

1 and why you had to make these changes to the rule. Can you  
2 give us some examples of what you felt were deficiencies  
3 and submittals that the rule is addressing?

4 MR. TILLMAN: The rule really -- excuse me,  
5 Board Member Cahn. I don't think that we've added  
6 significantly to, I guess, the detail, but I would say  
7 that, you know, for instance, they would give us a plan and  
8 profile and then not give us existing utilities that were  
9 in the ground. And so you can't make an evaluation as to  
10 whether or not they're going to have issues with crossing,  
11 with distance separation, or anything like that.

12 We also don't receive information strictly on --  
13 from a design standpoint, from the design engineer  
14 sometimes on particulars about technologies that they are  
15 proposing. I can't give you specifics right now, but,  
16 again, those are things that we're looking forward to make  
17 our evaluation. And, again, we have to go back to them to  
18 receive that information. And right now, I'd say over the  
19 last couple of years -- and it's going to get worse -- the  
20 consultants that we're dealing with are exceptionally busy.  
21 With the infrastructure money that's coming out and people  
22 trying to get projects on the board, we're -- we're getting  
23 not necessarily delayed from them on purpose, but I think  
24 their -- their being busy to the extent that when we ask  
25 questions, they don't get back to us right away, and we

1 wait until we get that information, because, again, we're  
2 receiving other applicants. We try to move on and come  
3 back to it as we receive that information.

4           And this goes to not only just treatment works.  
5 I believe it also extends -- I've seen it on septic systems  
6 as well to where folks feel like they've given us  
7 information that we've asked for distance separations,  
8 photos, contact with the installers, and we just don't get  
9 that. They felt like they had given us everything. And so  
10 we wait until we get that to where we have enough  
11 information to where we can issue that permit with  
12 confidence that we don't have any environmental issue or  
13 construction problems with what's being proposed.

14           I don't know if that answers your question, Board  
15 Member Cahn.

16           BOARD MEMBER CAHN: Thank you.

17           CHAIRMAN KIRKBRIDE: Okay. Go ahead.

18           MR. TILLMAN: Moving on to Section 11.

19           CHAIRMAN KIRKBRIDE: Would you give us --  
20 where is 11, more or less?

21           MS. THOMPSON: You're going to start --

22           CHAIRMAN KIRKBRIDE: What page?

23           MS. THOMPSON: It starts on page 32 -- or  
24 line 3284 --

25           CHAIRMAN KIRKBRIDE: There we go.

1                   MS. THOMPSON: -- page 12-73 of that green  
2 version. And paragraph (a) is going to start on line 3530,  
3 page 12-79.

4                   CHAIRMAN KIRKBRIDE: Okay. Thank you. Go  
5 ahead.

6                   MR. TILLMAN: Sorry, Chairman Kirkbride.  
7 Part of my summary, I didn't get specific on where I was  
8 starting.

9                   CHAIRMAN KIRKBRIDE: Happens to us all a  
10 little bit.

11                  MR. TILLMAN: My apologies.

12                  Again, Section 11, which is Source Development,  
13 we added some of the isolation distances that we had  
14 changed in the Chapter 25, which had to do with septic  
15 systems. We added those in the chapter.

16                  We included some additional standards for  
17 incorporation by reference for piping materials. We also  
18 added, as our -- Administrator Zygmunt has previously  
19 talked about, those requirements for water wells that are  
20 going to be stimulated by acid and acidization. We added  
21 requirements for that.

22                  In addition, we did not have previously any  
23 design consideration for spring development, and that's  
24 something that many of our communities have springs as a  
25 source of their drinking water, and they're good, viable --

1 good water quality, and so we needed to have some  
2 conditions for that, and we've added that to the section as  
3 well.

4 In Section 12, on Treatment, again, I think that  
5 was to me kind of the meat of the matter. We added  
6 additional technologies regarding UV light disinfection  
7 membranes, specifically as it speaks to reverse osmosis  
8 membranes, RO membranes.

9 We added technology as far as bag and cartridge  
10 filtration. And, in addition, we added conditions for  
11 pre-engineered skid-mounted units at treatment plants for,  
12 you know, folks that have a smaller application, that that  
13 would be something that would be applicable to their  
14 problem.

15 Additionally, we added a table for contact time  
16 for chlorine residuals for specific types of filtration.  
17 And we added that with the help of EPA Region 8.

18 In Section 13, we have really no substantive  
19 changes there. That was the Clinical Application, that  
20 people do within water treatment. Nothing really to note  
21 there, any changes.

22 In Section 14, regarding Pumping Facilities, we  
23 added requirements for booster pumps that are going to be  
24 added or going to be proposed for firefighting -- fire  
25 suppression that wasn't previously there.

1           In Section 15, we discuss Finished Water Storage.  
2   And this is where I believe our unique position with the  
3   EPA in regards to the Safe Drinking Water Act and primacy  
4   is a problem at times, mainly because, as Zygmunt --  
5   Administrator Zygmunt mentioned, we issue the construction  
6   requirements for treatment plants. The EPA Region 8 does  
7   the monitoring, and -- I guess monitoring for those plants.  
8   And they do their sanitary surveys for the installations.

9           And that's where we kind of hit a disconnect, if  
10   you will, because we, from a construction standpoint, look  
11   at things differently, maybe, than they do from a  
12   monitoring standpoint. And so we run into problems quite  
13   often with 24 mesh screens. 24 mesh is a -- the higher the  
14   number, the tighter the opening. So it's tighter than a  
15   bug screen on your house, probably.

16           And EPA -- and this is my opinion -- they're  
17   looking at 24 mesh from the standpoint of biological  
18   contamination. We look at it from an engineering  
19   perspective, from, you know, how is it applicable and how  
20   does it work? And we kind of have a disconnect there.

21           24 mesh is prescribed for overflows and for vents  
22   on water storage tanks. And there can be issues with that.  
23   In overflows, 24 mesh can cause problems with being able to  
24   discharge enough water in an overflow situation.  
25   Additionally, 24 mesh, when you come to vents on the top of



1 tanks, being that that mesh is fairly tight, it can have a  
2 tendency to get frost, moisture, freeze over and cause some  
3 issues as far as operations there.

4           Within the section we've offered, I guess,  
5 alternatives to the strict use of 24 mesh. That was vetted  
6 by Region 8 EPA. If you noted, they had no comments in  
7 regards to that section in our alternatives to 24 mesh, so  
8 on overflow situations, rather than strictly putting 24  
9 mesh on the end of an overflow pipe, we offer mechanical  
10 device, duckbill or flapper valve, backed by a 4 mesh  
11 screen, which has a much larger opening, but doesn't tend  
12 to obstruct the flow that a 24 mesh would. And, again,  
13 we've had acceptance and concurrence from Region 8 with  
14 those alternatives, so we feel good that not only do we  
15 offer what they're looking for in their sanitary survey  
16 strictly from a 24 mesh being on the end of a piece of  
17 pipe, but we also give the entity an alternative to some of  
18 the issues that may be raised by adding -- simply adding 24  
19 mesh to a piece of pipe from an operational standpoint.  
20 And we feel like, again, the fact the EPA did not comment  
21 on that, that they're in support of our recommendations and  
22 conditions.

23           CHAIRMAN KIRKBRIDE: Well, 4 mesh sounds  
24 like it was very different from a 24.

25           MR. TILLMAN: Yeah.

1                   CHAIRMAN KIRKBRIDE: Will a baby mouse  
2 float through a 4?

3                   MR. TILLMAN: 4 mesh won't allow a baby  
4 mouse to float through. You will get bit by a mosquito.  
5 But, again, what it's backed by, again, that mechanical --  
6 that duckbill, if you will -- is a rubber device that  
7 basically -- it closes pretty darn tight. But if something  
8 were to try to squeeze through that, then we would provide  
9 that screen as a backup in the flange that supports that to  
10 try to mitigate any entrants from that perspective. So  
11 it's the best we can do -- or we feel to offer protection  
12 as well as not impede its intended use.

13                   In Section 16, on Distribution Systems, again, we  
14 added additional standards for materials and distribution  
15 pipe. Additionally, we added a condition to allow the use  
16 of flow-fill when we cannot achieve --

17                   BOARD MEMBER DEURLOO: Mr. Chairman, I'm  
18 sorry. This is Brian Deurloo. I have to -- if I can just  
19 come back to that 24 mesh just for a moment, if you don't  
20 mind. So -- Mr. Chairman, do you mind if I ask a question?

21                   CHAIRMAN KIRKBRIDE: No. Please go ahead,  
22 Brian.

23                   BOARD MEMBER DEURLOO: Thank you.

24                   Mr. Tillman -- is Tillman or Tiller? Sorry.

25                   MR. TILLMAN: Tillman.

1                   BOARD MEMBER DEURLOO: Tillman. Hi,  
2 Mr. Tillman.

3                   So with this mesh size, are -- I've not actually  
4 seen a picture of one of these. I deal with meshes a lot  
5 with water filtration, so forth like that. But it seems to  
6 me -- I've heard that there are cases within Wyoming where  
7 that kind of mesh has caused problems, and, actually,  
8 potentially quite costly damage to some water treatment  
9 plants. I think maybe down in the southeast corner of the  
10 state. I'm not positive about that.

11                   But would size 16 mesh be okay? It's slightly  
12 larger, allows a little more debris to go through. Because  
13 24 mesh is on the outlet; is that correct? You're talking  
14 about 24 mesh at the outlet to prevent things from coming  
15 in?

16                   MR. TILLMAN: That is correct. And what  
17 you're alluding to is -- is very near and dear. That one  
18 happened in the town of Pine Bluffs. There was some other  
19 circumstances that caused the problem -- I guess the  
20 situation that caused the overflow incident. But, yes,  
21 they had a problem where they had 24 mesh. They were  
22 instructed to put 24 mesh over the end of their overflow  
23 pipe retroactively from the design. So understanding that  
24 the design pipe was sized for a particular flow, and when  
25 you put 24 mesh, a tight mesh screen, on the end of it, now

1 you've impeded the ability of that pipe to flow the  
2 required amount of water.

3           And what happened was they accidentally filled  
4 the wrong tank when they thought they were filling a new  
5 tank. And subsequently they were watching it, thinking it  
6 was filling up. And it filled up, overflowed, could not  
7 release the amount of water that it needed to, and  
8 subsequently broke the roof of that concrete tank, lifted  
9 it up. When the operator realized that he wasn't seeing  
10 flow out, the overflow that he should, he remembered what  
11 he had put over that end. He immediately loosened that. I  
12 believe that screen shot roughly 20, 30 yards out to the  
13 yard, relieved a bunch of water. And then he heard the  
14 thud of the roof as it settled back down on the tank.

15           So, yes, it was quite extensive damage. And it  
16 was, in my opinion -- you might find others that will  
17 disagree -- that was directly related to adding the 24 mesh  
18 screen on the end of the overflow pipe without doing enough  
19 engineering to understand what implications you were  
20 imposing on yourself from an operational standpoint.

21           Would 16 mesh be better? Yes, it would. But  
22 then understand that when the EPA performs their sanitary  
23 survey, their surveyor's not an engineer. He's looking at  
24 the requirements. He says 24 mesh. If he doesn't see  
25 24 mesh, he dings it as not being in compliance. So that's

1 why we opted for what we put in our -- what we're proposing  
2 in the chapter, so that, you know, we have an alternative  
3 to the 24. And, again, it's not something that the EPA is  
4 advertising, but they're in support of our alternatives.

5           And if you were to put 16 mesh, again, that would  
6 be better, but you run the risk of being in noncompliance  
7 of the sanitary survey.

8           MS. ZYGMUNT: And Mr. Chairman and board  
9 Deurloo, if I can add to that. So we do absolutely  
10 recognize the concerns with 24 mesh, particularly when it  
11 may be used on a retrofitted system. So it is something  
12 that we will be keeping an eye on from an engineering  
13 perspective very closely to make sure that there are the  
14 appropriate designs to prevent the situation like what  
15 happened in town -- in the town of Pine Bluffs from  
16 happening again in the state.

17           So it is on our radar. We will be keeping a  
18 close eye on it. But as Bill just described, it is  
19 important that we don't put our communities in a spot where  
20 they're out of compliance with either us or the EPA. And  
21 we do feel that this is a viable solution to give our  
22 communities options while ensuring that they have the  
23 proper engineering designs to, again, prevent a situation  
24 like the town of Pine Bluffs.

25           BOARD MEMBER DEURLOO: Okay. Thank you.

1           Are we -- if -- we've already recognized there's  
2 an issue with -- with the 5,900 lines we've gone through at  
3 blazing speed, it's kind of funny we're sitting here  
4 discussing 24 mesh or 16 mesh, but that's what we've chosen  
5 to do.

6           So the -- are we pushing back on those standards?  
7 We in Wyoming have found that that is an issue. If  
8 somebody puts 24 mesh at the end of an outlet pipe or  
9 overflow lines, some debris is caught, that has caused  
10 massive damage for a municipality, they may have a  
11 difficult time paying for it. What steps are we taking --  
12 I know that's a little bit maybe outside the bounds of the  
13 discussion today, but I'd like to know what steps are we  
14 taking to push back to say, hey, this isn't working for us.  
15 We got to -- how does the DEQ -- how does the DEQ do that  
16 in regards to the EPA?

17           MS. ZYGMUNT: Mr. Chairman. Board Member  
18 Deurloo, it's a good question. And this will be an ongoing  
19 discussion we'll have with EPA to make sure we're working  
20 with them. And, you know, at the end of the day we do need  
21 to be working with EPA because of the overlap between our  
22 two programs.

23           So recognizing the differences, again, I think  
24 there are viable options, given the options that  
25 Mr. Tillman described and situations where 24 mesh can work

1 provided, you know, a solid engineering design is done on  
2 the system to make sure that there's a proper airflow and  
3 other factors to consider.

4 I will point out that other western states of  
5 very cold climates such as Wyoming use 24 mesh screen, and  
6 we're not seeing issues consistently with 24 mesh. So it  
7 can work, provided that the proper engineering design  
8 accompanies use of 24 mesh.

9 I had indicated to EPA that if we run into a  
10 situation where they're requiring 24 mesh as part of a  
11 sanitary survey, and we don't feel it can work from  
12 engineering design, we will address those on a case-by-case  
13 basis and have that conversation with our EPA Region 8  
14 counterparts.

15 BOARD MEMBER DEURLOO: Thank you,  
16 Ms. Zygmunt.

17 Thank you, Chairman.

18 CHAIRMAN KIRKBRIDE: Uh-huh. Okay. Go  
19 ahead.

20 MR. TILLMAN: Again, moving on to Section  
21 16, Distribution Systems. I believe I mentioned that we've  
22 added additional standards for materials for distribution  
23 pipe. Also, we added a section where our conditions for  
24 flow-fill when we can't achieve pipe separation distances  
25 that we need, specifically between usually water and sewer

1 pipe, require that they have a conduit and then fill that  
2 with kind of a slurry concrete just so we can mitigate  
3 possibility of cross-contamination if we happen to get some  
4 leaking -- leaking joints or connections within those  
5 pipes.

6           Additionally, we added a condition for accepting  
7 hazard classifications for by -- by people that are  
8 certified in another state. Many times that hazard  
9 classification, that that person is certified to make that  
10 evaluation, and we just allowed for acceptance of people  
11 that are certified in other states.

12           In Section 17, as far as Laboratory Equipment,  
13 again, there's no substantive changes there in that  
14 section.

15           And Section 18, regarding Operation and  
16 Maintenance, we've added provisions to the O&M manual that  
17 we require. Specifically we added a description of  
18 facility and all of its processes. We want details of the  
19 emergency operations of the facility. And also we'd like  
20 additional information or more information than we  
21 currently get about the safety systems within a facility  
22 and all its components. And that's for the people  
23 occupying and operating that facility so that they  
24 understand how they're supposed to operate in emergency  
25 situations and all the safety parameters that are designed



1 into their facility.

2           And with that, I've quickly summarized what we've  
3 done in Chapter 12. Like I said, the majority of what we  
4 did, I believe, was through the reorganization that was  
5 authored and helped by the Attorney General, in addition to  
6 the incorporation by reference eliminated and moved quite a  
7 bit of materials. So that was the bulk of what was done.

8           But also we did add what we feel are needed  
9 changes, conditions that were added to the chapter to  
10 hopefully get a better product when we were processing or  
11 reviewing applications for modifications to treatment  
12 plants and distribution systems.

13                   CHAIRMAN KIRKBRIDE: All right.

14           MS. ZYGMUNT: So, Mr. Chairman, we do know  
15 this was a high-level overview. I think Bill did a great  
16 job going through the sections to give you a sense of what  
17 we changed. We would be happy to go through the sections  
18 in detail, if you'd like, or just open it up to high-level  
19 questions that you'd like to discuss, again, recognizing  
20 this is the first time we've presented this extensive  
21 revision to the Board.

22                   CHAIRMAN KIRKBRIDE: All right. Questions  
23 or comments for the Board at this time? Thoughts?

24           BOARD MEMBER CAHN: This is Lorie. I'll  
25 have a lot of questions that are real specific, so I think

1 the -- I'm not sure how DEQ wants to proceed. If they want  
2 to go through the specifics and then take public comment  
3 and then Board discussion, or how -- how -- how -- how DEQ  
4 plans on addressing the specifics.

5 MS. ZYGMUNT: Mr. Chairman. Board Member  
6 Cahn, we are open to how the Board would like to proceed.  
7 We'd be happy to go section by section and take specific  
8 comments, if that's your pleasure.

9 CHAIRMAN KIRKBRIDE: Well, if we're working  
10 toward ultimately approving, I suppose we need to go and  
11 deal with the comments we have.

12 Lorie, perhaps you want to -- I mean, do we need  
13 to go section by section or can we go to -- well, can we go  
14 to your comments? Well, maybe -- maybe I guess that can  
15 be -- we can go section by section, I guess.

16 Would that be -- is that all right? Would that  
17 suit you, Lorie?

18 BOARD MEMBER CAHN: Well, there's a lot of  
19 people on -- listening in that are from the public. So  
20 maybe we could take public comments and then go through --  
21 and then do the specifics with DEQ. Just because there's a  
22 lot of people online, I'm sure they're busy and can go to  
23 them first. That would be just a suggestion.

24 BOARD MEMBER DEURLOO: Chairman Kirkbride,  
25 I would second that. I don't know if I can second that.

1 But what Board Member Cahn is speaking about, it may be --  
2 is that she's a thorough individual when it comes to  
3 changes, and it may be good to have public comment first,  
4 would be my recommendation.

5 CHAIRMAN KIRKBRIDE: I would think that's  
6 fine.

7 That's fine, Gina? Either way?

8 All right. Well, if that's okay with you guys,  
9 let's do -- we're going to open it up to public comment  
10 now.

11 MS. THOMPSON: Okay. So we do not have any  
12 members of the public in the room with us, but we have  
13 quite a few of you online. So what I'd like to invite you  
14 to do is if you're interested in speaking on the record  
15 today, go ahead and use your reactions button and raise  
16 your hand, and we will just work through the list and call  
17 on you to provide your comment.

18 Just a reminder, when it's your turn, please  
19 introduce yourself, speak clearly, make sure you introduce  
20 the organization you represent, and -- yeah, go ahead. If  
21 there's any of you interested -- I don't see anyone raising  
22 their hand -- but go ahead and do that at this time.

23 CHAIRMAN KIRKBRIDE: Do they end up at the  
24 top of the list there?

25 MS. THOMPSON: It looks like we have a

1 Lenz. So if you want to go ahead and introduce yourself.

2 MR. LENZ: Hello. Yes. This is Brian  
3 Lenz, Town Engineer for Jackson. Thanks for having the  
4 meeting and working on these regulation updates.

5 I had been going through it, and I had one --  
6 probably have a few questions -- but where you incorporate  
7 the 10 States Standards by reference, I could not easily  
8 find those -- the 2018 version of those standards on a  
9 Google search. And so I guess I would -- from utilizing it  
10 on a permitting side for our projects, but also others,  
11 it's like the more specific what those standard -- the  
12 title of the standards, the version of the standards, who  
13 wrote the standards, and where you can get the specific  
14 standards that you're incorporating would be helpful.

15 And I did see there was -- I don't have the  
16 reference right now which line, but there was a reference  
17 to them further down in the document after they were  
18 adopted that was different than the language used in the  
19 adoption. And -- sorry, I don't have more to comment on it  
20 than that, but I think that's an important -- something  
21 that's important to be clear and make sure that when people  
22 are -- when consultants and the public are using a  
23 document, that they are referencing the correct document.  
24 Thank you.

25 MR. HENDON: Hello, Brian. Keenan Hendon

1 here. I think that's something that we can definitely look  
2 into and provide a section for clarity for all of our  
3 entities to have a quick reference to find these standards  
4 and move forward in a quickly and concise matter. So I  
5 think it's something we can look into further.

6 CHAIRMAN KIRKBRIDE: Well, Mr. Hendon, you  
7 did have a -- you said there was a -- it was really fairly  
8 accessible to get those; is that correct?

9 MR. HENDON: It is accessible, perhaps,  
10 depending on how you're doing a Google search. If you're  
11 doing a Google search for the 10 States Standards, you may  
12 not come up with the -- I guess, perhaps you might -- might  
13 not land on the right location to access it.

14 MS. THOMPSON: Additionally, Mr. Kirkbride,  
15 we have the complete publication information listed in  
16 Section 19. However, Section 19 has grown quite lengthy.  
17 And it is the end of the chapter. One of the comments we  
18 received yesterday requested that we maybe put that  
19 information earlier in the chapter. That's something that  
20 we will be following up with our Attorney General's Office,  
21 to make sure that if we do that, that we do it in a way  
22 that doesn't make more work on their end to defend our  
23 rule. But we think we might be able to provide that  
24 publication information earlier so that people aren't  
25 struggling to find the document. Because Mr. Hendon is

1 correct, if you search 10 States Standards, not going to  
2 find it as easily as if you searched the complete title.  
3 And it actually is routed through the State of Minnesota.  
4 They are kind of the stewards of the rule.

5 MR. HENDON: So perhaps it's something we  
6 can just address on the front end of the documents to make  
7 it easy and concise for our entities and applicants to find  
8 the information directly and in a timely manner.

9 CHAIRMAN KIRKBRIDE: Mr. Lenz, does this  
10 address your -- or have we addressed your concern?

11 MR. LENZ: Yeah, I think that that would  
12 address it. I haven't had a chance to look at Section 19.  
13 I did try -- I tried searching the title that it was listed  
14 as where it was incorporated, and I think it's Broward --  
15 Broward, Minnesota or -- broward.org that I can get the  
16 2012 version, but I did not see the 2018 version that was  
17 listed in the document.

18 And I'm not a millennial, but I'm -- I do pretty  
19 well with Google, so -- but, yeah, it was just -- it was  
20 not straightforward, just based on that if you searched for  
21 the document right where it was adopted, that language.

22 CHAIRMAN KIRKBRIDE: Well, okay.

23 BOARD MEMBER CAHN: Chairman Kirkbride.

24 CHAIRMAN KIRKBRIDE: Yes.

25 BOARD MEMBER CAHN: Yeah, this is Lorie.

1           I would just like to say that I think Brian's  
2 comment brings up kind of a big picture issue for me, and  
3 that is that it's the first time the public's really had a  
4 chance to look at these, all these changes. And, you know,  
5 Brian is an implementing engineer -- county engineer for --  
6 or, excuse me, Jackson engineer, for the town. And so he's  
7 not the only person we're hearing from had a problem  
8 finding these standards.

9           And so my point is that the 30-day public comment  
10 period, I don't think -- may not have been enough time for  
11 people to review it, all these changes, if they couldn't  
12 even get -- it's mostly incorporation by reference, and  
13 then people haven't been able to find the reference  
14 material. That, to me, just brings up an issue that I  
15 think we need more time on this. But I'll get to those  
16 comments later, but I just wanted to throw in my 2 cents.  
17 Thank you.

18           MS. ZYGMUNT: Mr. Chairman and Board Member  
19 Cahn, we certainly understand the concern, and we  
20 absolutely want to make sure there's ample public comment  
21 opportunity for this rule. So we welcome more discussion  
22 on that.

23           I do want to point out that we did post the 10  
24 States Standards on our website, along with the material  
25 for the advisory board meeting, including the draft rule.

1 We apologize to the constituents if they weren't able to  
2 locate it.

3 We are looking into copyright issues to see if we  
4 can permanently post the 201810 States Standards on our  
5 website. I don't think we have an answer on that, but,  
6 absolutely, if we can post that on our website, we will.  
7 Otherwise, as Mr. Hendon said, we will make it very clear  
8 where people can access the standards online.

9 CHAIRMAN KIRKBRIDE: All right. Sounds  
10 like a good effort is intended here.

11 Do we have another member of the public who would  
12 like to --

13 BOARD MEMBER DEURLOO: Chairman Kirkbride,  
14 can I make one more comment on that, please, if you don't  
15 mind?

16 CHAIRMAN KIRKBRIDE: Sure. Sure, you can.

17 BOARD MEMBER DEURLOO: So I heard earlier  
18 that this 10 States -- sorry. This is Chairman -- or not  
19 chairman -- Brian Deurloo.

20 I heard that you can get these online for \$13.95  
21 or something earlier. How many public -- how many  
22 regulated public water treatment plants are in the state of  
23 Wyoming, out of curiosity? Does anybody have a plus or  
24 minus number?

25 MR. TILLMAN: Roughly -- excuse me, Board



1 Member Deurloo. I believe there are roughly 400 and some  
2 odd water -- public water systems within the state.

3 BOARD MEMBER DEURLOO: Okay.

4 MR. TILLMAN: No. I take that. I take  
5 that back. It's 200-something community and noncommunity,  
6 nontransient -- I believe there's 400 transient. So I  
7 believe the number's closer to 700.

8 BOARD MEMBER DEURLOO: Uh-huh.

9 Have you ever -- thank you.

10 Have you ever distributed -- like when we have  
11 a -- an incorporated by reference, like what we're doing  
12 here with the 10 States Standards, have you ever provided  
13 like the pamphlets or the documents to the regulated  
14 entities that are government owned? Like, for example,  
15 have you ever sent out something like the pamphlet that  
16 we're talking about here to all the regulated entities so  
17 they can review it, because it will be part of the  
18 standards coming up, have it in paper form?

19 MR. TILLMAN: No, we haven't. And, Gina,  
20 correct me if I'm wrong, but I thought that there was an  
21 issue with being able to copy it and just distribute it for  
22 copyright rules. And I don't know if we have the authority  
23 to buy enough copies for all entities that were interested  
24 in -- and just off the record -- or, excuse me, as another  
25 aside, we've never had -- in our 30-day comment period,

1 we've never had anyone contact us regarding being able to  
2 get a copy of that or wondered where they could get a copy  
3 or anything of that nature.

4 MS. THOMPSON: So just to clarify. We had  
5 an individual out of Sheridan that asked where they could  
6 get a copy. And the organization that publishes the 10  
7 States made that digital copy available to us at no charge.  
8 But as far as making a printed copy available, we -- we --  
9 that is not our normal practice for any reference material.  
10 The Administrative Procedures Act kind of governs how we  
11 handle these incorporation by reference. And it requires  
12 that we keep a copy of the reference material and that we  
13 note where individuals who need a hard copy can get that  
14 information. And that information is contained in Section  
15 19.

16 So we're required to have one at least in the  
17 Cheyenne office, which is what we include in the chapter.  
18 And then DEQ is committed to providing a hard copy to all  
19 of our field offices. Additionally, we can clarify that  
20 Section 19 entry to make sure that the Web address is  
21 included for that material so that people can just click on  
22 it. I believe that that is an acceptable inclusion at the  
23 Secretary of State level when they review the rules. You  
24 know, that's a piece that they would look for is does  
25 that -- you know, did the format of our incorporation by

1 reference meet the standard.

2           So potentially, while we wouldn't purchase a hard  
3 copy and mail it to every public water supply, we would  
4 make sure that there was one available at the main office  
5 and the four field offices.

6           BOARD MEMBER DEURLOO: Thank you, Gina.

7           Yeah, I finally did find the reference on like  
8 third from -- fourth from the bottom or something like  
9 that. On line 2885 on the clean version is where you do  
10 that. So I'd probably, like you said earlier, move that up  
11 in the importance -- or the list under those things in  
12 Section 19. Thank you for that discussion.

13           Mr. Chairman, I have no more comments on that.

14           CHAIRMAN KIRKBRIDE: All right. If not, is  
15 there another member of the public who would like to --

16           BOARD MEMBER CAHN: Excuse me. I had one  
17 more thing on that.

18           CHAIRMAN KIRKBRIDE: Okay, Lorie. Sorry.

19           BOARD MEMBER CAHN: So I guess I just  
20 wanted to clarify what Mr. Hendon said. If somebody  
21 googles the standards and decides to order their \$13 copy,  
22 I just want to clarify they have to wait to get that copy  
23 in the mail. They're not just going to get an instant  
24 digital copy online; is that correct?

25           MS. THOMPSON: No, that is incorrect. So

1 the digital copy is \$13.95. That is an instant download, I  
2 believe. And then there's a hard copy that if someone  
3 wishes to receive a paper copy, they can purchase one  
4 through the same Web page. And it's 19.95 to cover the  
5 State of Minnesota's publishing costs. And I'm not  
6 entirely sure if there's shipping, but it is a difference  
7 in price to cover the publishing -- the cost of publishing  
8 a hard copy versus an electronic download.

9 BOARD MEMBER CAHN: Thank you, Gina, for  
10 clarifying that.

11 CHAIRMAN KIRKBRIDE: I'm sorry. I can't do  
12 chat very well. Is there somebody else with a hand raised?

13 MS. THOMPSON: Mr. Lenz, if you were -- if  
14 your comment has been addressed, if you could lower your  
15 hand.

16 And then we would like to recall that in the  
17 Chapter 18 presentation earlier, there was a gentleman from  
18 the Board of Public Utilities that noted that he would like  
19 to make a comment.

20 So, Mr. Bassett, if you were interested in making  
21 a comment, this would be the time to raise your hand so we  
22 could call on you.

23 MR. BASSETT: My comment has been  
24 addressed. Thank you.

25 MS. THOMPSON: Oh, okay.

1                   And so it looks like a Mr. -- it looks like  
2 Mr. Strong has a comment potentially.

3                   MR. STRONG: Yes. This is Frank Strong. I  
4 am the Engineering and Water Resource Division manager for  
5 the Cheyenne Board of Public Utilities. I just want to  
6 comment on glad to see these regulations are being updated.  
7 I know we provided quite a few comments for your  
8 consideration. We'd be happy to help you guys work through  
9 any of those to make it clear what we were getting at.  
10 Hopefully we can have a good product when we're done.  
11 Thank you.

12                   CHAIRMAN KIRKBRIDE: Are we going to go  
13 over public -- those comments?

14                   MR. TILLMAN: At your discretion, Chairman  
15 Kirkbride.

16                   CHAIRMAN KIRKBRIDE: Yeah, okay. Well, if  
17 we have more live comments, let's take them now.

18                   MS. THOMPSON: Mr. Chairman, I'm not seeing  
19 any other hands raised. So we're at the speak now or  
20 forever hold your peace or at least hold your peace until  
21 the next comment period. So if there are any other  
22 interested parties, please raise your hand, otherwise we'll  
23 return it to the Board's discussion.

24                   CHAIRMAN KIRKBRIDE: Okay.

25                   MS. THOMPSON: I'm just not seeing any,

1 sir.

2 CHAIRMAN KIRKBRIDE: And we'll try to keep  
3 our eyes peeled in case there's another hand that comes up  
4 on the chat.

5 BOARD MEMBER CAHN: Chairman Kirkbride.

6 CHAIRMAN KIRKBRIDE: Yes, Lorie.

7 BOARD MEMBER CAHN: I guess I'd like to  
8 suggest maybe now we start going through -- start going  
9 through section by section with responses to comments, to  
10 the public comments, EPA comments, and then Board  
11 discussion. And then I think at some point maybe members  
12 of the public, if something comes up, that they thought,  
13 oh, geez, I want to comment or something on that, maybe  
14 they can use the chat feature, raised hand, so we can see  
15 what their concerns might be. Thank you.

16 CHAIRMAN KIRKBRIDE: I think that's fine.  
17 If there's no -- no problem with that, let's -- we'll go --  
18 start chapter by chapter -- or I mean section by section.  
19 Yes.

20 MS. ZYGMUNT: Thank you, Mr. Chairman. So  
21 my understanding is you'd like us to go section by section  
22 and work in the comments we received on each section as  
23 well?

24 CHAIRMAN KIRKBRIDE: Yes. Yes.

25 MS. ZYGMUNT: All right.

1                   CHAIRMAN KIRKBRIDE: Also, it's 11:45.  
2 Let's kind of get an idea of what -- whether we going to  
3 need a lunch break. If we're going to go solidly until  
4 3:00, we probably need a lunch break. If we're going to --  
5 I don't know how to project it. This could take a while,  
6 though, so --

7                   BOARD MEMBER CAHN: Mr. Chairman.

8                   CHAIRMAN KIRKBRIDE: Yes.

9                   BOARD MEMBER CAHN: I would like to suggest  
10 that we take a lunch break now, and then we can continue in  
11 the afternoon sort of uninterrupted or whatever. So that  
12 would be my suggestion. So it's 11:45.

13                  CHAIRMAN KIRKBRIDE: Anybody have a problem  
14 with that? Okay. How much time do we need? What  
15 traditionally -- do we need an hour? 45 minutes? What?

16                  MS. THOMPSON: It is nearly noon, and we  
17 are in the Capitol Complex, and so all the other kiddos are  
18 going to be clearing out for lunch as well. So potentially  
19 an hour would give you enough time to -- for the folks in  
20 the room to grab some lunch. And these folks that are --  
21 you know, are joining us remotely from their offices or  
22 from home, that we give them a chance to go and gather  
23 lunch, if they need to, at the busy noon hour. So an hour  
24 I feel, would be appropriate, sir.

25                  CHAIRMAN KIRKBRIDE: Okay. All right.

1 Let's -- how about 12:50 we'll ring the gavel. How about  
2 that? Yes? All right. Good. Everybody? Okay. See you  
3 then.

4 (Meeting proceedings recessed  
5 11:46 a.m. to 12:51 p.m.)

6 CHAIRMAN KIRKBRIDE: We're going to resume  
7 the meeting of the Water and Waste Advisory Board. All the  
8 board members are on, as well as our presenters.

9 And welcome to any of the public who is joining  
10 us on Zoom or otherwise. We're glad to have you.

11 We're about to proceed now to go through Chapter  
12 12, as presented, kind of section by section, and take  
13 comments. We're also going to -- as we go along, we've had  
14 a number of comments from the public and deal with them --  
15 if they haven't been dealt with otherwise -- deal with  
16 responses to those questions.

17 And we wanted to make it available for the  
18 members of the public and to be able to -- if you have  
19 something that is timely, to interject, please raise your  
20 hand, and we'll try to note that and pick it up. I can't  
21 see really well from where I'm sitting. I've got a glare.  
22 And if we don't get your hand for a while, we'll try to get  
23 you. But the intent is that we kind of deal with each of  
24 these areas and try to deal with them as they come up.

25 Yes, Gina.



1                   MS. THOMPSON: Mr. Chairman, I will note  
2 that we did receive a written comment in the electronic  
3 portal while we were at lunch, and so at your leisure, sir,  
4 I can read -- it's two pages, but I can read it into the  
5 record, since you won't have access to it during the  
6 meeting for a printed-out version. I don't have print  
7 capabilities in the building.

8                   CHAIRMAN KIRKBRIDE: All right. Is it  
9 appropriate now?

10                  MS. THOMPSON: It looks like it covers  
11 multiple topics. There's a general statement, a statement  
12 on Section 12, Treatment, some comments on Pumping  
13 Facilities, and then some comments on Distribution Systems  
14 in Section 16.

15                  CHAIRMAN KIRKBRIDE: I suppose you should  
16 just go ahead with it now.

17                  MS. THOMPSON: Okay. I'll go ahead and  
18 read that in.

19                  So this comment is from Mr. Brian Sepe, and  
20 Mr. Sepe states generally due to the size and complexity,  
21 the format of the proposed rules is challenging to use.  
22 Consider adding a table of contents illustrating each  
23 section and the associated page numbers. Because many  
24 sections have major subsections, these could be labeled as  
25 subheading and included in the table of contents. The

1 partial inclusion of specific 10 States Standards by  
2 reference only may lead to issues when interpreting and  
3 enforcing the standards. The user must cross-reference  
4 back to specific sections of the TSS. In several instances  
5 only select portions of the TSS are referenced. Consider  
6 incorporating the full text, with permission, of each  
7 included sections of the TSS directly into the appropriate  
8 subsections of Chapter 12. The verbiage will need to be  
9 modified to merge with the contents of the proposed rule.  
10 As the rule is proposed now, that merging will need to be  
11 made by users and/or the reviewer, which may cause a  
12 confusion.

13 Water treatment process design is very specific  
14 to the waters being treated. The use of pilot or  
15 demonstration plants is essential to most all surface water  
16 treatment plants of sufficient size. The cost and time  
17 associated with successful pilot studies must yield  
18 benefits to the design permitting process. Consider  
19 bolstering Section 6 so that once a study has provided  
20 proven results those findings are the basis for compliance  
21 with potential conflicting requirements that may be more  
22 generally written.

23 Concerning Section 12, Treatment, for paragraph  
24 12(h), proprietary treatment systems often incorporate tube  
25 settlers. These systems may or may not require routine

1 cleaning beyond normal blowdowns, as tube cleaning may be  
2 only an annual occurrence. These types of systems would  
3 not comply with 12(h)(iv) as written.

4 On paragraph 12(m)(ii), is it missing or is there  
5 misnumbering?

6 On 12(m)(iii), the use of ozone may be driven by  
7 several factors, depending on the process or design goals.  
8 Taste and odor may be secondary or incident benefit. When  
9 used as a pre-oxidant, the dosage and contact time  
10 presented in (iii) is excessive and may be detrimental.

11 Concerning paragraph (r) and (s), Section 93.3(b)  
12 of the TSS has not been included by reference. Without the  
13 inclusion of 93.3(b), the proposed Chapter 12 rules do not  
14 address land application of dewatered sludge except for the  
15 liquid lime softening sludge in paragraph (r)(iv).

16 Alum sludge is specifically addressed in  
17 subsection (s), but sludge from ferric sulfate or ferric  
18 chloride is not. Consider including TSS Section 93.3(b).  
19 It is an appropriate method to be considered depending on  
20 site-specific conditions.

21 Concerning Section 14, Pumping Facilities.  
22 Paragraph (d)(iii), six air changes an hour is excessive in  
23 a pump station where sensitive electrical gear is in a  
24 segregated or isolated room. Consider allowing exceptions  
25 where applicable.

1           And in paragraph (g)(iii), pump and pipeline  
2 design must consider surge. Pressure relief valves may  
3 provide the appropriate level of protection for some  
4 designs. Categorically excluding relief valves should be  
5 reconsidered.

6           For Section 16, Distribution Systems. At  
7 paragraph (a), the proposed Chapter 12 does not include TSS  
8 8.5, which provided a method to address inflow prevention  
9 via AWWA C514. Consider inclusion of this section of the  
10 TSS.

11           And at paragraph (f), air relief and vacuum  
12 breakers are essential in most large transmission systems.  
13 It is not always practical to provide a segregated depth  
14 piping to the surface, such as within paved areas.  
15 Alternate designs to drain the vaults or add inflow  
16 preventers need to be considered.

17           And that concludes Mr. Sepe's comments, sir.

18           CHAIRMAN KIRKBRIDE: All right. Just  
19 briefly, do things -- are these things you've considered  
20 otherwise? Did you hear something that -- I mean, I assume  
21 you'll want to analyze all that, but --

22           MS. ZYGMUNT: Yes, Mr. Chairman. I think  
23 we might need some time to analyze those comments. Some of  
24 the issues, such as numbering, we can double-check to make  
25 sure we haven't misnumbered sections. In regards to the

1 technical comments, I think we would be challenged to  
2 respond to all those today, but I'll let Mr. Tillman and  
3 Mr. Hendon speak if they feel differently.

4 MR. TILLMAN: Chairman Kirkbride. Oh,  
5 sorry about that.

6 Chairman Kirkbride, yes, we probably need to look  
7 at those. I was listening as Gina was reading those off,  
8 and I believe that some of the other comments that we  
9 received are similar in nature that we may have addressed.

10 Just off the top of my head, the one on ozone, I  
11 think we changed the fee rate on ozone that another  
12 commenter thought the rate that we had previously had  
13 presented issues with DDPs and some other operational  
14 considerations that may occur in some facilities. So I  
15 think we've addressed that one.

16 And I think a couple others we may have addressed  
17 in other comments similar, but off the top of my head, I'd  
18 definitely want some time to look at that in detail before  
19 we reply to those.

20 CHAIRMAN KIRKBRIDE: Sure.

21 MR. HENDON: Mr. Chairman, I could concur  
22 with Bill and Jennifer's sentiments with taking time to go  
23 back and review those comments and provide an in-depth  
24 review from the necessary comments with regards to his  
25 concerns.

1                   CHAIRMAN KIRKBRIDE: Surely that's --  
2 Mr. Sepe isn't, by any chance, on the call, is he?

3                   MS. THOMPSON: I don't see him included on  
4 the participant list, sir.

5                   CHAIRMAN KIRKBRIDE: Okay. All right.  
6 Therefore, I think we can go and proceed with what our plan  
7 was.

8                   Bill, go ahead.

9                   MR. TILLMAN: Chairman Kirkbride, we'd like  
10 to address the comments, as Board Member Cahn suggested. I  
11 think the way we'd like to go about that is to go through  
12 at least the general comments that we received. And then I  
13 would like to, I guess, engage Ms. Cahn and ask her if  
14 there were specific parts of each section as we get to them  
15 that were of concern to her, or if there were comments that  
16 she noted that were of concern, rather than kind of reading  
17 through the list, because I think some of them tended to  
18 overlap. But if she could provide those areas she was  
19 concerned with and those specific comments, we can get to  
20 those and address those in this format. Think that would  
21 be acceptable?

22                   CHAIRMAN KIRKBRIDE: How about that, Lorie?  
23 What did you have -- how do you think it would be best to  
24 go about it?

25                   BOARD MEMBER CAHN: Well, I'm not sure the

1 members of the public that are -- made comments that are in  
2 here. Have they had access to the responses to the  
3 comments?

4 MS. THOMPSON: We posted -- we did post the  
5 responses to the comments to the website yesterday, but  
6 obviously not everyone may have read them. We can screen  
7 share as we go through.

8 MS. ZYGMUNT: And, Mr. Chairman, let me  
9 clarify. So most of the responses to comments we've had on  
10 the website for about a week, I believe, because there were  
11 two sets of responses to comments. And I'm going to look  
12 at Gina for help here.

13 MS. THOMPSON: I believe we sent the  
14 initial responses to the Board on Friday, and then we  
15 received additional comments on Monday. And we made sure  
16 everything was posted yesterday, which was Monday. So the  
17 public did not have the weekend to look at that responses  
18 to comments, I don't believe.

19 MS. ZYGMUNT: Yes. Thank you, Gina.

20 I retract my comment. Gina's correct. They were  
21 posted yesterday.

22 And, again, we do accept comments -- just to  
23 clarify for people who are not familiar with the process.  
24 So prior to the advisory board meeting we request comments  
25 by a certain time to allow us to provide responses in a

1 timely manner. Again, we received more comments than we  
2 were expecting. And then we do also allow comments right  
3 up to the advisory board meeting so we can receive comments  
4 at any point during that time. And I'd just like to  
5 acknowledge it can be a challenge to turn those around in a  
6 timely manner.

7 CHAIRMAN KIRKBRIDE: Sure.

8 BOARD MEMBER CAHN: I want to thank you  
9 guys for a quick -- the quick turnaround that you did. I  
10 was very impressed with how quickly you got the comments  
11 up. So I think people from the public who are listening in  
12 can go to the website and see how their comments were  
13 respond -- those that made comments or those that didn't  
14 but are interested can see what others have said and how  
15 responded.

16 And, Bill, to -- I want to clarify. It's not  
17 just me, necessarily, that's going to have comments. So I  
18 think we would -- what we typically do, we'll open it up to  
19 anybody on the Board that wants to comment on a section.  
20 And maybe to help speed things along, because I know we  
21 only have two hours left to get a lot of stuff covered, if  
22 you guys -- you and Keenan can focus on more important  
23 issues, technical issues, and maybe things that either were  
24 big issues that somebody brought to your attention that you  
25 agreed with and you're going to make the change or



1 something that they brought up but you didn't agree with  
2 and why you wouldn't be making the change I think would be  
3 helpful, so -- and maybe we want to start -- I don't know  
4 if we want to start with general comments or if we want to  
5 end with the general comments, but maybe -- maybe we start  
6 with them.

7 MS. ZYGMUNT: Yes. Mr. Chairman. I  
8 recommend we start with the general comments, and then we  
9 can just highlight each section again, note the major  
10 changes and associated comments with each section.

11 CHAIRMAN KIRKBRIDE: We'll accept that  
12 plan. Go ahead.

13 MR. TILLMAN: Okay. Chairman Kirkbride,  
14 I'd like to begin with just the general comments.  
15 Beginning with Cheyenne BOPU. Cheyenne BOPU asked do plant  
16 mods or upgrades require the entire plant to meet these  
17 requirements? How will new standards be applied to  
18 existing plant modifications and expansions?

19 I believe we addressed that in the chapter where  
20 we suggest that any existing facility is under the purview  
21 of the existing Chapter 12. It's not until they perform  
22 modifications or build something new that we would impose  
23 the new requirements of the chapter on that part being  
24 modified. And, obviously, with -- being that it's not a  
25 black and white integration of new parts to old parts, we

1 would obviously work with an entity to try to figure out  
2 what was the best place to make that break, that separation  
3 of new to old, and make sure that it's not an undue burden  
4 for the compliance with the new set of rules that we've  
5 imposed.

6 MR. HENDON: Mr. Chairman, I'd also just  
7 like to add that this comment was probably one of the more  
8 common comments that we got with regards to questions and  
9 the outreach to the community.

10 MR. TILLMAN: Let's see. Next Mr. Dayton  
11 Alsaker. Mr. Alsaker commented, and I quote, I previously  
12 provided some specific comments about the draft Chapter 12,  
13 but I'd like to provide a more general comment. Why is  
14 this being done? Wyoming's version of Chapter 12 has  
15 served the state and its water systems worked well for many  
16 years. Why now incorporate other standards? I don't see  
17 this as a benefit -- as benefitting Wyoming, its water  
18 system for those that work with the water systems, even on  
19 the regulatory side. I'd like to see us stay with the  
20 State's version of these standards that have served us  
21 well. Maybe some minor revising/updating is needed, but I  
22 don't see a benefit to basically rewriting them or doubling  
23 their length.

24 Also, the major federal ARPA and infrastructure  
25 funding coming our way in 2022, everyone involved will be

1 working overtime to keep up with the projects and spending  
2 these additional funds wisely to maximize the benefit to  
3 our water systems. Now does not appear to be the time to  
4 take on additional duties that can slow down more important  
5 tasks.

6           And our response to Mr. Alsaker, as Administrator  
7 Zygmunt mentioned earlier, these revisions to Chapter 12  
8 didn't just start recently. We started them several years  
9 ago. I believe 2014, 2015. And we've been working on them  
10 as staff and as time has allowed. It's taken us quite a  
11 bit of time to get to this point where we're at. Didn't  
12 foresee, I guess, the COVID and all the infrastructure and  
13 different things that have come along since then. And  
14 absolutely that's going to impact the municipalities as  
15 well as government agencies that deal with those  
16 municipalities, in addition to the funding that they're  
17 looking at. It's going to be a tremendous burden on  
18 everyone involved. But we don't feel that modifying these  
19 rules impacts that in any way -- in any way or form, and  
20 that those activities are kind of independent of our  
21 revising of this chapter.

22           And it's necessary to update this. As we've  
23 demonstrated, new technology, things that were procedural  
24 that were not codified that we had to talk people through,  
25 now we've tried to put into the rules so we can see them

1     beforehand.

2                     So we understand his concern and kind of  
3     frustration that when you get used to something, then it  
4     changes on you, that it's something to get used to. But we  
5     feel that the new version of Chapter 12 will be a better  
6     product for him to work with.

7                     Let's see. Another comment from Darwin Dick of  
8     Tetra Tech. Mr. Dick commented this subject matter is  
9     primarily related to the type of wells allowed by Chapter  
10    12.

11                    MR. HENDON: It's in the --

12                    MR. TILLMAN: Excuse me. I was making sure  
13    it was still in general comments. It seemed to be somewhat  
14    specific. But continuing on. Related to type of wells  
15    allowed by Chapter 12, and if dug wells should still be  
16    permitted. Chapter 12 makes reference to dug wells that  
17    should be constructed according to the State Engineer's  
18    Office. Chapter 12 also includes concrete pipe or well  
19    casing materials which is assumed to be for dug wells. Dug  
20    wells are older technology and would typically deliver  
21    groundwater under direct influence of surface water.  
22    Subsequently, how and where are procedures for classifying  
23    wells or groundwater wells or groundwater wells under  
24    direct influence of surface water? Are there microscopic  
25    particular analysis requirements covered that confirm

1 classification of shallower water wells? Also, are shallow  
2 horizontal infiltration galleries or in-bank filtration  
3 options available as options for well water intakes?  
4 Appropriate classification of wells will dictate the level  
5 of treatment required for results of MPAs.

6 Our response, we considered the comment. Dug  
7 wells would be individual wells that are proposed to be  
8 converted to a public well -- water well. These wells  
9 would need to meet all public water system construction  
10 requirements for Water Quality permitting review and would  
11 need to demonstrate to the agency that with primacy for  
12 drinking water, which is Environmental -- Environmental  
13 Protection Agency Region 8, that the well meets the EPA  
14 requirements, and that wells are not under the direct  
15 influence of surface water.

16 And, unfortunately, this is where we kind of  
17 overlap, because we do not have the authority to make that  
18 designation of the water source. Region 8 EPA does. So  
19 although we have regulations considering how to construct  
20 the well, how the well is analyzed in its classification is  
21 dictated by Region 8. So we have complementary  
22 responsibilities in that regard.

23 Those were all the general -- those were the only  
24 couple of general comments that we have.

25 MS. ZYGMUNT: One more. Mr. Hooten's.

1                   MR. TILLMAN: Oh, sorry. My mistake. One  
2 more. From Mr. Andy Hooten.

3                   Mr. Hooten commented rather than incorporating  
4 the 10 States Standards you want and excluding other at the  
5 beginning of the section, I would recommend placing the  
6 applicable 10 States Standards in the section where it  
7 makes sense. The proposed format was difficult to follow  
8 and did not provide clear intent.

9                   And we considered his comment, and we tested the  
10 suggested format earlier in our drafting process, and  
11 internally we found that to be more cumbersome than the way  
12 we ended up now with stating the parts of the 10 States  
13 Standards that are included at the beginning of the  
14 section. So we've kind of gone both gamuts, and we feel  
15 that where we're at now, putting the inclusion of the 10  
16 States Standards, those sections at the beginning of each  
17 section, is more appropriate and seemed to be a better read  
18 than the way we had it before.

19                   Okay. And that concludes the general comments.

20                   The next set of comments are in Section 4. I  
21 didn't know if any of the board members had any concerns in  
22 Sections 1, 2, 3 that we need to address.

23                   BOARD MEMBER CAHN: I think maybe we can  
24 have a Board discussion on general comments.

25                   MR. TILLMAN: Okay.

1                   BOARD MEMBER CAHN: And if -- Mr. Chair,  
2 may I start?

3                   CHAIRMAN KIRKBRIDE: You certainly may.

4                   BOARD MEMBER CAHN: Okay. I guess, you  
5 know, one of my concerns -- or things that I need to  
6 understand is what -- what happened or what -- I mean,  
7 obviously you're saying there's some new technologies that  
8 aren't being addressed because the standards are 40 years  
9 old. What's driving this -- you know, driving you to redo  
10 the standards besides that? What's the direction from the  
11 current governor in terms of, you know, reducing  
12 regulations or incorporation by reference? That sounds  
13 like that doesn't come from the governor's office, so I  
14 guess what's current -- I think we address that a little  
15 bit, but just kind of what's the current -- what's the word  
16 I'm looking for -- you know, path that the DEQ wants to  
17 take on this?

18                   Let me just -- and then, you know, just kind of a  
19 general concern that we have a huge number of political --  
20 of public comments being made on this, bigger than I've  
21 seen on anything for quite a while. And so I appreciate  
22 the fact that you need more time to go over what people are  
23 bringing up. But I'm a little concerned about, you know,  
24 how we got to -- and I don't know if there's an answer, but  
25 how do we get to a place where we have a lot of unhappiness

1 with this when we're close to -- you know, this far along.  
2 And so I have some concerns about kind of process and how  
3 we could maybe do -- what we can learn from this and how it  
4 can be done better, maybe, next time.

5           And then just kind of a general comment about the  
6 difficulty that people are -- who have to -- are the  
7 practitioners we're hearing from in the state that have to  
8 implement this, the difficulty of going back and forth  
9 between the incorporation by reference. And so I guess it  
10 just still brings up the question for me do we really have  
11 to do incorporation by referencing? What's -- if what  
12 we're really referencing is 150 pages long, or whatever,  
13 and would increase the regulation by that, why aren't we  
14 just taking those sections we want instead of incorporating  
15 by reference, putting them in, and then seeing how much --  
16 does it improve the readability.

17           And I understand from your response to comment  
18 you guys started on that path but then changed your mind to  
19 do incorporation by reference because it wasn't working. I  
20 think that's what I read.

21           I don't know. I guess I've given you enough  
22 things to -- I'll forget where I started. So maybe you can  
23 answer those, and then I'll continue my general comments.  
24 Sorry.

25           MS. ZYGMUNT: Yes. Mr. Chairman. Board



1 Member Cahn, yeah, there's a lot packed into that question,  
2 so let me see if I can take it part by part.

3 I'll start off, and then I'm sure Bill and Keenan  
4 will have things to add. I'll speak to the incorporation  
5 by reference. And, again, to answer your question, I  
6 cannot speak for any directives from the governor's office  
7 about rules at this time, but we did start down this  
8 process -- we started working on Chapter 12 when Governor  
9 Mead was in office with the streamlining initiative in  
10 effect.

11 Even after his administration ended -- again, as  
12 I stated earlier this morning, I do think it's in the  
13 interest of any agency to look for opportunities to  
14 streamline and increase efficiency when we can. And I do  
15 support incorporation by reference as a way to do that in  
16 regulatory documents.

17 Again, we recognize the pros and cons. And, you  
18 know, we did hear feedback that it is challenging to look  
19 through multiple references, but I also will repeat Bill's  
20 comment that that is a bit of a standard in the engineering  
21 field, that you commonly have multiple references that  
22 you're working from. So I don't think that we're departing  
23 from, you know, what the standard is in the field or what  
24 other agencies do.

25 I would like to continue down the incorporation

1 by reference, but, of course, we'll take the public  
2 feedback that we heard and feedback from the Board, and if  
3 it's the Board directive that we need to reconsider some  
4 feedback, that's something I'll discuss with Director  
5 Parfitt.

6 I will, excuse me, reemphasize, though, that if  
7 we added back all the 10 States Standards sections that we  
8 referenced, it would significantly increase the length of  
9 this rule. I think we're talking around a hundred pages  
10 would be added since we refer to it pretty extensively.

11 We did hear some challenging feedback about the  
12 incorporation by reference, but there's other people that  
13 feel it can work too. So I would just acknowledge both,  
14 that I do think incorporation by reference has challenges,  
15 but it can be a workable solution.

16 Let's see. Board Member Cahn, I'm trying to  
17 think of the other parts of your question there. And,  
18 again, the driver of this rule, yes, it is nearly 40 years  
19 old. Again, we need to have updated modern technology in  
20 those rules so that our communities have the appropriate  
21 standards to design these facilities, construct these  
22 facilities so that we are protecting public health by  
23 having quality drinking water.

24 Let me stop there and see if Bill or Keenan would  
25 like to add anything.

1                   MR. TILLMAN: No, I -- Board Member Cahn,  
2 just to echo sentiments of Administrator Zygmunt. I don't  
3 think that, you know -- it's six of one, half a dozen of  
4 the other whether or not you try to put all of what we've  
5 incorporated by reference from the 10 States Standards into  
6 our chapter. There are still other standards, as we refer  
7 to, AWWA, NSF, several others entities that we reference in  
8 the document as well. So we wouldn't just be incorporating  
9 the 10 States Standards and putting in their words. We  
10 would -- would also have to include everything else that  
11 we've incorporated.

12                   So I think, again it's six of one, half a dozen  
13 the other, whether or not you have one or two documents or  
14 you have a single one that's the size of an encyclopedia.  
15 I still think that you're going to reference other  
16 documents in order to make sure that that design's  
17 complete.

18                   So, again, I don't feel that that's a pervasive  
19 argument. I think we've had a couple of people say that.  
20 We've had also people say to the contrary that they can  
21 work with what we've got. There are other people that had  
22 no comment on the incorporation by reference. So it's a --  
23 I understand the personal nature that some people feel it's  
24 difficult to get through, but I think in general, as an  
25 industry, that is not -- I would not consider that to be

1     cumbersome.

2                     MS. ZYGMUNT:  And, Mr. Chairman, Board  
3     Member Cahn, I remember the second part of the question,  
4     and I'll speak more to the process and the public notice.  
5     And certainly understand the question and the concerns.  
6     And we were a bit surprised by the number of public  
7     comments on this as well.

8                     In terms of what we could do differently, I think  
9     in the future, for this rule and others that are similar to  
10    it, we would likely rethink our initial public outreach and  
11    consider having a draft document to start from at that  
12    point, which might give people, you know, more concrete  
13    target to start providing comments on.

14                    Again, we did do informal outreach in October of  
15    2020.  Only garnered two comments.  So perhaps during that  
16    informal outreach, when we have a better tentative draft,  
17    I'll say, might be a better way to better give people an  
18    idea of what we're proposing.  So we're very open to  
19    looking at that process and seeing how we can make  
20    improvements in the future, and, you know, complete  
21    outreach up front to, you know, reduce the public comments  
22    at this point.

23                    Again, it has been challenging to receive  
24    comments for this up to the point of the board meeting.  I  
25    think that is something else that we could consider in

1 coordination with Administrator Engels, if that is the best  
2 way to go about it. We want to make sure that people who  
3 are commenting have a clear idea of how we'll be able to  
4 respond to their comments and make sure that the board  
5 members have complete information by the time that we meet.

6           So those are just some of my initial thoughts.  
7 And we were open to looking at how to do our processes  
8 better. And, again, if it's the Board's direction that we  
9 need to take more time to look at the public comments and  
10 feedback from the Board, we certainly understand that  
11 perspective.

12           CHAIRMAN KIRKBRIDE: One of my thoughts is  
13 that I think most of us have had the experience of having a  
14 problem and calling somebody at some office for help, and  
15 they say, oh, no, you got to call Person B. You call  
16 Person B, and they say, oh, no, you got to call Person F.  
17 Well, when -- and it's very frustrating. And I think if  
18 you -- I would favor the incorporation by reference to  
19 simplify things. But you want to have it accurate. You  
20 want -- that needs to be user friendly too so that you go  
21 to the right place, it seems to me. And I think as long as  
22 you're careful in doing that, I would think that's a  
23 preferable way. That's personal opinion from a distance.

24           BOARD MEMBER CAHN: Yeah. I guess another  
25 part of my comments about the incorporation by reference,

1 if I may, Mr. Chair.

2 CHAIRMAN KIRKBRIDE: Yes.

3 BOARD MEMBER CAHN: You know, when I worked  
4 for the -- for most of my career I worked in Idaho. And  
5 Idaho has a regulation that -- I can't remember -- it might  
6 be 135 pages or so. Somewhere along what we're talking  
7 about this might become. But I remember it being very,  
8 very easy to use and having everything in one place. And I  
9 didn't find it cumbersome to use something, and it was --  
10 you could click on -- you know, when you looked at it  
11 online, you could click on a section from the beginning and  
12 it'd take you right to where -- you know, where you were  
13 going. So that's -- that's one of the things.

14 Another thing -- so I -- I would prefer that to  
15 incorporation by reference. And I think we're hearing, you  
16 know, a split where some members of the public like it and  
17 some members don't. But I think, you know, if the goal is  
18 to increase efficiency and streamline, I think we have to  
19 look at whose perspective is that from, because if it's  
20 from the perspective of DEQ, maybe it's streamlined or  
21 efficient to have incorporation by reference. But from  
22 user perspective, practicing engineers in the state, it's  
23 less efficient and less streamlined.

24 And I think -- so -- so I guess I'll just leave  
25 it at that, other than to say I think if -- if you were to

1 write out everything that you want instead of incorporating  
2 by reference, I think we could differentiate between things  
3 that are AWWA, or, you know, things that are always in  
4 regulations not all spelled out. We've always referred to  
5 things like that.

6           And, you know, whereas referring to the 10 States  
7 Standards, they're really not standards. The title of it  
8 is recommend -- something like recommend -- I'll have to  
9 pull it up again, but it's something like recommended  
10 practice. And so, you know, in my mind, it's one thing to  
11 incorporate EPA requirements when -- by reference, when  
12 everybody can pull those up, or -- yeah, so it's  
13 recommended standards for waterworks is the title.

14           So in my mind, there's some -- there's a bunch of  
15 questions. One is, you know, if we're doing something --  
16 like when we do RCRA or HMLA, you know, citing EPA makes  
17 sense, because everybody can look those up. And no matter  
18 which state you work at, the EPA rules aren't going to  
19 change. But anyways -- so one of my questions has to  
20 do with is this recommended standards from midwestern  
21 states -- and provinces, Ontario -- is that even  
22 appropriate for Wyoming, and should -- maybe we should be  
23 looking at states closer to us that are in the Rocky  
24 Mountains, you know, maybe some of the issues that people  
25 bringing up have to do with -- maybe they're not at issue

1 in the midwestern states.

2           So I guess I would recommend that DEQ look at the  
3 Idaho standards and see if maybe -- you know, that would be  
4 one suggestion, to see if maybe that looks user friendly to  
5 them. And the second is, I guess I would like to see --  
6 and obviously I'm just one person -- but I would want to  
7 see going back to a stakeholder group. And we certainly  
8 have a number of people now that have -- around the state,  
9 from all parts of the state, that are saying we're  
10 concerned about the usability of this, and we have some  
11 concerns about technical things, put together user group,  
12 stakeholder group that includes not just users but  
13 obviously the practitioners -- the people who are -- who are  
14 out in the field looking at these sites and helping people  
15 who are regulating, you know, like the district engineers  
16 that we have within Wyoming -- within DEQ, and having --  
17 going back kind of to the drawing board to -- to rethink  
18 this.

19           And, you know, perhaps maybe -- 10 States  
20 Standards -- I'm not sure why that was chosen. Maybe  
21 that's not the -- and that was chosen -- I mean, Bill -- I  
22 appreciate what you said, Bill. I think you said it was  
23 chosen like 40 years ago to -- to start with, and that's  
24 kind of what we're stuck with. Well, if we're redoing the  
25 regulations, maybe we're not stuck with it. Maybe, you



1 know, we should -- we should, you know, not use 10 States  
2 Standards. So I'm kind of -- I think there was enough  
3 concerns about it that maybe -- maybe that's not the  
4 appropriate -- and, as I said, it's recommended practice.

5           So I'm concerned about referencing --  
6 incorporating by reference things that are not a regulation  
7 by something like the EPA. And, you know, if it's a  
8 procedure that AWWA has, or whatever, those -- those are  
9 typically -- I don't think -- I don't think -- if you -- I  
10 don't think we have to say, if we do an incorporation by  
11 reference for AWWA, that, therefore, we have to do  
12 everything else incorporation by reference. Or if we spell  
13 out what we want, that we can't refer to an AWWA and  
14 incorporate that by reference. So I think there could be a  
15 mix and match of what makes sense and what makes it most  
16 user friendly.

17           And then -- and then another thing I'll say, you  
18 know, when Bill talks about engineers needing to refer to a  
19 bunch of different references. Well, yeah, we all do that  
20 when we're, you know, putting things together. But it's  
21 different, in my mind, when we're looking at a regulation.  
22 You know, what -- what do we have to -- what do we have to  
23 fit -- you know, what we're building, what does it have to  
24 fit? And in my mind it's easier to know where you're going  
25 if you know -- if you have it all in one spot, whereas how

1 do I get there? Yes, I'll refer to a whole bunch of  
2 different manuals and references to get there. So I'll  
3 just leave that on the table.

4 MS. ZYGMUNT: Mr. Chairman. Board Member  
5 Cahn, let me start with some initial thoughts on how to  
6 respond to those comments, which we certainly understand.  
7 And I think I might not go exactly in order here.

8 But first, you know, the 10 States Standards are  
9 robust. Again, they're used widely in the engineering  
10 field, so I have absolute confidence that we're referring  
11 to appropriate standards to incorporate into our  
12 regulations.

13 This is different than you've seen in our other  
14 rule packages, that this is not a primacy program. So  
15 there are not corresponding EPA regulations we would point  
16 to like we would for some of our Clean Water Act, Safe  
17 Drinking Water Act programs. So there's a difference there  
18 that we're -- it's not apples and apples to some of the  
19 other rules that you've seen where we are pointing back to  
20 EPA regulations.

21 You know, and, again, recognizing your concerns,  
22 Board Member Cahn, about public outreach. I feel -- you  
23 know, again, there were a lot of comments, but I don't feel  
24 like they're anything that we can't work through with the  
25 commenting entities. I'm not seeing any deal breakers.

1 And so, you know, given your request to take this back to  
2 square one with the stakeholder group, I'll consider that,  
3 but I don't feel like that would be an appropriate step at  
4 this time, given the work that has been done. And, again,  
5 I think we have received some very good comments, but after  
6 people have time to digest our responses, we can work with  
7 those commenting entities further, but I don't think we  
8 need to roll it back to square one of the stakeholder  
9 group.

10 I think that answers a few of your questions,  
11 Board Member Cahn. And let me turn it over to Bill for his  
12 thoughts.

13 MR. TILLMAN: I guess to echo the  
14 sentiments of Administrator Zygmunt, the 10 States  
15 Standards or recommended practices for waterworks is  
16 something that's used all across the country. It's not  
17 just the Great Lakes. It's used from California to New  
18 York, down to Florida, up to Washington. Just about  
19 everyone in the civil engineering field is familiar with  
20 those standards, and they use those exclusively.

21 As a matter of fact, I believe it's Montana  
22 paraphrases the 10 States Standards, and they say so right  
23 up front. The 10 States Standards are not -- you can, I  
24 guess, incorporated fully, but they basically paraphrased  
25 them.

1           North Dakota uses 10 States Standards  
2 exclusively. Colorado has also paraphrased the 10 States  
3 Standards. They just didn't mention that up front. So to  
4 shed any, I guess, concern about the 10 States Standards  
5 and their ability to design water treatment systems is a  
6 misnomer. They're used exclusively, extensively, and will  
7 be used in the future.

8           They're regulated by engineers, by boards. They  
9 review those regularly. Yes, they were initially part of  
10 our standards, our rules 40 years ago. They've been  
11 updated every five to six years since, hence the 2012  
12 standards, the 2018 standards. There will be other  
13 standards. So they're reviewed constantly by engineers, by  
14 entities for their appropriateness, for their content.

15           And I think there's a significant difference  
16 between engineering design standards that we're calling  
17 regulations and other types of regulations for Air -- Air,  
18 Solid and Hazardous Waste, things like that. So to mix  
19 those two together, I don't think that is appropriate as  
20 far as an analysis of how they look.

21           Secondly, and, again, I'll reiterate, you will  
22 never find all the things you need in a single document.  
23 Even if we have all the 10 States Standards written out in  
24 Chapter 12, someone's still going to pull out a pump  
25 manual, a materials manual, some other pamphlet, an

1 individual component manual to try to figure out does this  
2 work for me? Is this appropriate for this application?

3           So to try to -- I guess, to give the incentive  
4 that we can have everything in one spot and it can be done  
5 and be efficient in one spot, I don't think that's  
6 appropriate. I don't think that would be relative for an  
7 engineer or the regulated communities who are going to be  
8 doing the engineering, that's not what they would be --  
9 something they would look at.

10           BOARD MEMBER CAHN: I see that Brian has  
11 his hand up.

12           CHAIRMAN KIRKBRIDE: Mr. Deurloo.

13           MR. HENDON: I'm not sure his mic's on.

14           MS. THOMPSON: Brian, it looks like you're  
15 muted. Oops.

16           BOARD MEMBER DEURLOO: How now brown cow.

17           MS. THOMPSON: We can hear you. Oh, there  
18 you are. Okay. Yeah, this technology...

19           BOARD MEMBER DEURLOO: Okay. Very good.  
20 Yeah. Great. Well, I really appreciate -- thank you,  
21 Mr. Chairman.

22           I really appreciate what the DEQ is saying right  
23 there in the last comment by Mr. Tillman. And it finally  
24 hit me how much time is saved by referencing by  
25 incorporation, especially with the 10 States Standards,

1 which it seems appears they're updated every three to five  
2 years, recently. And I can see why it would be an  
3 advantage to do that, because it also saves us on the Board  
4 time every three to five years. If we reference those,  
5 rather than writing our own in that we thought was the end  
6 all and be all as a good reference for standards, I think  
7 it would save us all time if we did allow that. I mean,  
8 it's not like -- that way that we went ahead with reference  
9 by incorporation. So, yeah, you sold me on that.

10 As we were -- it's all really good comments on  
11 this. And I have to say it's good work. You guys have  
12 done a tremendous amount of work on Chapter 12. And water  
13 is a touchy subject, especially clean water, drinking  
14 water. It's going to become even more of a deal. Every  
15 day water's becoming more valuable, and we need to make  
16 sure that we have good standards for its protection.

17 I had to remind myself -- as you guys were  
18 talking, I walked and went to the wall map. And I just  
19 tried to discover and remind myself how many rivers from  
20 Wyoming go to the Mississippi River. We have the  
21 Yellowstone River, the Bighorn River, the Powder River, the  
22 Belle Fourche, the North Platte, which includes Crow Creek,  
23 all flow to the Missouri River Basin into the Mississippi  
24 Basin. So more than half the water probably leaving the  
25 state of Wyoming is feeding the Mississippi River in the

1 long run.

2           So we are actually a part of the upper river --  
3 or at least could be. And so my question to the staff --  
4 or for discussion is would it be -- have we considered  
5 joining the 10 States Standards, seeing how we're part of  
6 the Upper Mississippi? Or to Lorie's point -- I mean,  
7 wouldn't there be an advantage to joining that, that we can  
8 have a seat at the table, because as a board, each state  
9 gets one vote.

10           And, let's see -- or, you know, as Lorie was  
11 speaking about, is there a western states, because we also,  
12 you know, feed into the Colorado River. And then also feed  
13 into the Columbia River. There's major watersheds we feed  
14 in all over the place. So we're at a pretty pivotal point  
15 with our regulations, and people may look up to us if we do  
16 a good job on these.

17           So also I'd like to finally -- it is 1:38 right  
18 now, by my standards -- or by my clock. We are -- I'm  
19 happy to go to however late it takes with you guys, but  
20 we're going to have to figure out some way to kind of, you  
21 know, more hastily either answer these questions or address  
22 them or set up a second meeting or something like that.  
23 I'm saying it's still 1:30. We've got some time, but I  
24 wanted to bring this to everybody's attention. Thank you,  
25 Mr. Chairman, for the time.

1                   CHAIRMAN KIRKBRIDE: Thank you.

2                   MS. ZYGMUNT: Board Member Deurloo, yeah,  
3 thanks for the comments. I don't have enough historical  
4 knowledge to tell you if we have considered joining the  
5 10 States Standards or what would be involved there. We  
6 will absolutely look into it for you. It's a good  
7 question.

8                   And we're not currently aware of any other  
9 comparable western state manuals. And, again, that's a  
10 question that we can keep on our radar.

11                   I'm going to look at Bill and see if he has  
12 anything to correct me with there.

13                   MR. TILLMAN: No, I'm not aware of any  
14 other guidance manual for designing water treatment systems  
15 other than this recommended practice of 10 States  
16 Standards. That's what -- pretty much across the country.  
17 Even at national conventions with SRF, people are  
18 referencing that document as something that they look to  
19 for designing systems or for new treatment options, things  
20 like that. So I don't think there's another document  
21 similar to that in nature for designing water treatment  
22 systems or distribution systems for drinking water.

23                   BOARD MEMBER CAHN: Mr. Chair.

24                   CHAIRMAN KIRKBRIDE: Yes.

25                   BOARD MEMBER CAHN: I just wanted to



1 clarify something that Brian said. I just wanted to make  
2 sure everybody understands that -- or my understanding,  
3 just to make sure -- want to make sure I'm correct -- is  
4 that even if we adopt the 10 States Standards and they go  
5 through in three years or five years and they make an  
6 upgrade, they change it, we're locking in time the 2018  
7 standards if we approve -- if this regulation goes forward  
8 until such time as we go through another rulemaking. So  
9 even if they come up with a 2022 change, we're locked in at  
10 2018 until we go through rulemaking again, and then we can  
11 incorporate the most current of the TSS at that time.

12 Thank you.

13 MS. ZYGMUNT: Mr. Chairman. Board Member  
14 Cahn, that is correct. When we reference the 10 States  
15 Standards, we will be referencing the current manual, which  
16 is 2018. We would -- if that manual is updated in 2022, we  
17 would have to go through rulemaking again to reference the  
18 2022 standards. But at that point, the incorporation by  
19 reference makes the rules revisions easier by just changing  
20 the manual that we're referencing at that point.

21 MR. TILLMAN: Also, Chairman Kirkbride, if  
22 I remember correctly -- Gina, correct me if I'm wrong -- I  
23 believe that we were given direction from our Attorney  
24 General that we could not say future references or future  
25 editions of this document. We have to cite a specific

1 document that we're referring to when we're referring to  
2 any type of information that we're inferring from. So we  
3 cannot just say every future edition of the 10 States  
4 Standards we'll adopt. We have to wait until it comes out,  
5 see what they change, and then adopt certain aspects of it,  
6 just as we have done now. So, unfortunately, that's not  
7 legally one of the things we're allowed to do.

8 MS. THOMPSON: That's correct, Bill. It's  
9 actually spelled out in the Administrative Procedures Act.  
10 And we have to include a statement that includes the date  
11 that we are adopting. And then we also have to include a  
12 statement that says we are not adopting any future  
13 iterations. And that language is really specific. And any  
14 time you have a rule that's promulgated in any DEQ rule  
15 right now where we're doing incorporation by reference,  
16 you'll see that statement at some point in the chapter,  
17 because, otherwise, it's ambiguous and we don't want to be  
18 in violation of any part of the act, so...

19 CHAIRMAN KIRKBRIDE: Thanks for that  
20 clarification.

21 All right. Well, are we back to -- Lorie, do you  
22 have some things -- any more on Section 1, 2 and 3, or does  
23 any other board member?

24 BOARD MEMBER CAHN: I do not.

25 BOARD MEMBER DEURLOO: No, sir.

1                   CHAIRMAN KIRKBRIDE: All right. Why don't  
2 you guys go on.

3                   MR. TILLMAN: Chairman Kirkbride, the next  
4 comment was regarding Section 4(a) from Mr. Alsaker. I'll  
5 read his comment. Mr. Alsaker recommended removing the  
6 statement that '18 TSS applies unless noted, instead  
7 referencing the relevant TSS section for each WQD Chapter  
8 12 section. Mr. Alsaker asked are there any places where  
9 it's noted that sections of '18 TSS do not apply?

10                   Our comment, DEQ/WQD has considered comments.  
11 Section 4(a) states that chapters incorporating by  
12 reference all sections of the 2018 TSS, except Section 1.0,  
13 the first paragraph of each subsequent section of proposed  
14 revisions of Chapter 12 states that the 2018 TSS sections  
15 apply to the material within, and we will try to keep the  
16 passage as written.

17                   So we felt like we've done our best to tell which  
18 sections it applies to and where it's applicable, as  
19 opposed to not applicable, as he recommended. It just  
20 seemed to make more sense of what applies as opposed to  
21 what doesn't apply.

22                   Do we have any of comments from the Board as far  
23 as that section goes, Section 4?

24                   BOARD MEMBER CAHN: Mr. Chair, I do.

25                   CHAIRMAN KIRKBRIDE: All right. Lorie, go

1 ahead.

2 BOARD MEMBER CAHN: Yeah. So this is  
3 confusing the way this is written, because as I go through  
4 the 10 States Standards and I write out all the things you  
5 guys have referenced of the way you say, you know, this  
6 Section .1.1 and Section .1.3, and whatever, and you're  
7 skipping sections, to me that doesn't mean you're  
8 incorporating the whole thing. You're specifically  
9 incorporating sections that you call out.

10 So I agree with -- I agree with Mr. Alsaker's  
11 comment that this could be better worded. It would almost  
12 be this -- this chapter refers to sections of the  
13 recommended standards for water, and -- you know, and --  
14 because we're not incorporating the whole thing by  
15 reference. Otherwise why would we go through in each  
16 section and say this section, this section, this section,  
17 this section?

18 So I think maybe DEQ either misunderstood the  
19 comment or didn't really address it in the response.

20 MR. TILLMAN: Chairman Kirkbride. Board  
21 Member Cahn, I felt that we addressed it, because you can  
22 say either what's included or what's excluded. And either  
23 way, you're going to have someone that's going to read it  
24 and say why didn't you tell me about the parts -- the other  
25 parts. So we've opted for, I guess, on the positive, on

1 the affirmative, of what's included as opposed to what you  
2 can include. And absolutely we did not incorporate by  
3 reference the entire document, and that is on purpose,  
4 because there are lots of sections where we disagree with  
5 what they propose. And so, therefore, we have to  
6 incorporate by reference specific parts of the standard.  
7 And I guess it's -- you know, is your glass half full or  
8 half empty, depends on how you look at it, whether or not  
9 you include or exclude in that opening statement.

10 BOARD MEMBER CAHN: Bill, I think we're in  
11 violent agreement with each other about how we're doing it.  
12 I think it's how it's being explained. So I think, like  
13 when it says "unless otherwise noted," I don't think  
14 there's anywhere in here where we say we're not  
15 incorporating X, Y and Z. I think we're incorporating --  
16 we're saying we're incorporating A and not B and C and not  
17 D. So I think -- I think it's -- I think you and I are  
18 saying the same thing. It's just that I don't think this  
19 statement on line 203, 204 is saying what you're saying.  
20 That's what I'm trying to say.

21 MS. ZYGMUNT: Yes. Mr. Chairman. Board  
22 Member Cahn, I understand what you're asking. And I think  
23 it is just how we presented our response and response to  
24 comments document, but we are on the same page with Bill's  
25 explanation of how we're incorporating sections of the 10

1 States Standards. So we'll take a look at that language.

2 And we can also work with our Attorney Generals  
3 to rewrite 4(a) to meet the intent of the Administrative  
4 Procedures Act and make that a little bit clearer for you.

5 BOARD MEMBER CAHN: Thank you.

6 MR. TILLMAN: Continuing on --

7 CHAIRMAN KIRKBRIDE: Go ahead.

8 MR. TILLMAN: -- Chairman Kirkbride.

9 CHAIRMAN KIRKBRIDE: Yes, please.

10 MR. TILLMAN: We don't have any comments in  
11 Section 5.

12 The next section we have comments from the public  
13 is Section 6(b)(iii) through (iv). And the comment -- the  
14 Region 8 comment, this section appears to allow the use of  
15 alternative treatment --

16 THE REPORTER: You're going to have slow  
17 down, please. Slow down.

18 MR. HENDON: Not so fast.

19 MR. TILLMAN: This section appears to allow  
20 the use of alternative treatment technologies not directly  
21 covered under Chapter 12 regulations based on theoretical  
22 evaluation of the design that demonstrates a reasonable  
23 probability that the technology meets -- will meet the  
24 design objectives.

25 Says why this is of concern, it seems like a

1 fairly old standard for use of new or novel treatment  
2 technologies. These technologies could be used for  
3 microbial reduction credit under surface water treatment  
4 rules. Suggests for facilities producing finish water for  
5 consumption, that data for a full-scale comparable  
6 installation or pilot plant be required instead of only a  
7 theoretical evaluation.

8           Our response, we considered the comment. The  
9 passage in this section allows for systems that propose new  
10 and innovative technologies. District engineers evaluate  
11 these types of applications under this section for  
12 compliance with the chapter and for other water quality  
13 considerations. These applications go through a thorough  
14 review and approval process before we issue them. And so  
15 we understand that adding a pilot plant or operating  
16 facility that incorporates new technology for information  
17 for data to see how well it works is one thing, but that's  
18 not always possible or practical. And the way we wrote the  
19 section, it allows for folks to give us theoretical  
20 information based on other evaluations of new technology  
21 that gives us a sense of whether or not it can work or  
22 can't work. And to exclude that would limit -- limit the  
23 possibility of new innovative technology. So we feel that  
24 leaving it the way it is gives a wider acceptance of new  
25 treatment technologies that could be available to us.

1                   Any comments from the board members on that  
2 comment and passage?

3                   BOARD MEMBER CAHN: Mr. Chair.

4                   CHAIRMAN KIRKBRIDE: Yes.

5                   BOARD MEMBER CAHN: We blew past the  
6 definitions, and I had some comments on the definitions.  
7 So after we take this Section 6, maybe we can go back to  
8 the definitions.

9                   CHAIRMAN KIRKBRIDE: Was that in a  
10 different section, Lorie? Am I --

11                   BOARD MEMBER CAHN: Yes.

12                   CHAIRMAN KIRKBRIDE: Okay. Since we're on  
13 6, and -- we got anything on 6?

14                   Okay. Let's go back to 5, then.

15                   MR. TILLMAN: Chairman Kirkbride, we did  
16 not have any comments on the definition in Section 5, so  
17 that's why I did not comment.

18                   CHAIRMAN KIRKBRIDE: That's fine.

19                   MR. TILLMAN: But, Board Member Cahn, if  
20 you have comments or questions on the definitions, please  
21 proceed.

22                   BOARD MEMBER CAHN: Yeah. I have comments  
23 on Section 5.

24                   So on line 348 it says this may include  
25 mechanically driven drives, and it just seems like driven



1 drives is -- could probably be better worded to just  
2 include mechanical drives. So that's just a minor comment,  
3 but...

4 And then on line 359 to 361, I think they were  
5 talking about offstream reservoirs. And I think there was  
6 a public comment -- I guess there wasn't. I'm sorry.

7 Offstream reservoir is a term that's not used in  
8 the rest of the document, unless it's in the 10 States  
9 Standards. And then if it's in the 10 States Standards,  
10 this brings up kind of a procedural question. Do we have  
11 to have in our definitions everything that's in the 10  
12 States Standards for definitions?

13 MR. TILLMAN: Board Member Cahn, we tried  
14 to make sure any definition that we put in Section 5 is  
15 used in the chapter. Apparently we missed one. And if  
16 that is not used in the chapter at all, we will delete that  
17 one. We do not include definitions that are strictly in  
18 the 10 States Standards. That's not part of our direction  
19 from the AG as far as what we need to include from a  
20 definition standpoint.

21 BOARD MEMBER CAHN: Okay. And then I would  
22 just ask, since I didn't see it referred to at all in here,  
23 I wonder how -- I guess I have a question about how  
24 often -- how many of those are there in Wyoming, offstream  
25 reservoirs. Is it a setting that occurs or not? Do we

1 have lots of them or none of them or one?

2 MR. TILLMAN: Board Member Cahn, I cannot  
3 answer that question. I don't know. I did not -- I can't  
4 remember. I think this came -- this definition came in  
5 when we were in a discussion, I believe, on wells and some  
6 other things. I'm not sure we have any offstream  
7 reservoirs, at least in my world.

8 MS. ZYGMUNT: Mr. Chairman. Board Member  
9 Cahn, we can look into that question and get back to you.

10 BOARD MEMBER CAHN: Okay. And then I just  
11 have a -- just kind of a general English usage term -- or  
12 thing that would apply in other places potentially. On  
13 line 38, we talk about utilized water provided by the  
14 public water supply. And typically "utilize" refers to a  
15 use other than which that thing is designed for. So I  
16 think just to simplify language, you can just use the word  
17 "use." So just to watch for when you use utilize, and if  
18 it really means just use, use "use." So that's all I have  
19 on Section 5.

20 MS. ZYGMUNT: Board Member Cahn, can you  
21 clarify where that is? I do not see it immediately.

22 BOARD MEMBER CAHN: Yeah. It's on line  
23 381.

24 MS. ZYGMUNT: Oh, thank you.

25 BOARD MEMBER CAHN: And then I have

1 comments on Section 6.

2 MR. TILLMAN: Board Member Cahn, if you  
3 have your comments on Section 6, please continue.

4 CHAIRMAN KIRKBRIDE: Yeah. Yeah.

5 BOARD MEMBER CAHN: I'm having problems  
6 with my comments showing up. I think EPA had a comment in  
7 Section 6 on line 563, EPA comment 1.

8 MR. TILLMAN: Yes, Board Member Cahn. We  
9 addressed that. Basically they're -- they consider us  
10 allowing for a theoretical information regarding new  
11 technologies. They consider that a low bar, and why don't  
12 we have a pilot plan for that. And, again, my comment --  
13 or the DEQ's comment was basically sometimes that's not  
14 practical to have a pilot plan or a full-scale  
15 demonstration of new technologies. Sometimes theoretical  
16 information, theoretical data, is all that we have, and  
17 it's all that is practical at that time for what's being  
18 presented. So we -- we would like to keep the passage as  
19 written to allow for those -- that information to be  
20 conveyed to us.

21 BOARD MEMBER CAHN: Okay. Thank you.

22 I'm sorry. I forgot you mentioned that. I  
23 apologize.

24 MR. TILLMAN: Any other comments on Section  
25 6 or Section 5 from board members?

1 CHAIRMAN KIRKBRIDE: Hearing none, proceed.

2 MR. TILLMAN: Okay. The next section we  
3 received comment on was Section 7. The first comment is  
4 from Region 8. Region 8 commented, the proposed Chapter 12  
5 regulations do not require applicants to submit as  
6 constructed record drawings to Wyoming DEQ after a  
7 permitted project is constructed. It is acknowledged that  
8 statements of completion are described with each general  
9 individual permit issued. However, Chapter 12 should  
10 familiarize and require this as-built verification process.

11 Their suggestion, add a citation requiring all  
12 permitted construction projects to provide an engineer's  
13 certification to Wyoming DEQ and require that the  
14 registered professional engineer to provide documentation  
15 to Wyoming DEQ that the project was constructed according  
16 to the permit requirements.

17 Our response, we have considered the comment.  
18 Water Quality Rules Chapter 3 Section 11(b) identifies the  
19 permit application process for as-built drawings, and the  
20 section will remain as written.

21 It is already part of our procedure that the  
22 notice of completion that engineers -- that we requested  
23 engineers send back to us has a section where it -- you  
24 check the box that you constructed the project as -- as the  
25 submitted application information -- excuse me, as the

1 information that was submitted on the application, or there  
2 was modifications to that application based on things that  
3 were found, discovered as construction was going on. And,  
4 again, depending on the nature of those changes, if it was  
5 just a minor change, an elevation change that were a couple  
6 inches, maybe half a foot, we wouldn't consider that worthy  
7 of noting on a new drawing. But if they dug into the  
8 ground and found, oh, we have to completely change the  
9 alignment, where it goes, we now cross another pipe, those  
10 are types of things that are already in place that we  
11 receive as-built or new drawings of those changes after  
12 construction is noted.

13           Also, in our Chapter 3, that is not a part of  
14 Chapter 12, we also require if there are changes, they tell  
15 us about those things. We just did not feel that it was  
16 necessary to include that clarification in this chapter  
17 when this chapter was providing for design construction  
18 details as opposed to, you know, when you were constructing  
19 the project things you ran into. We thought those were  
20 adequately addressed in Chapter 3 and didn't need to be  
21 commented again in Chapter 12.

22           Any comments from the Board on that -- on that  
23 comment or response?

24                           CHAIRMAN KIRKBRIDE: I don't hear any.

25                           MR. TILLMAN: Moving on. We have another

1 comment in Section 7. Section 7(d). Mr. Darwin Dick noted  
2 that we have an incorrect numbering. We addressed that.

3 Section 7(e), we received a comment from Jason  
4 Palmer of the City of Green River. Mr. Palmer requested  
5 that this section include a requirement that the  
6 responsible charge operator review, formerly chief  
7 operator, commenting that operators ultimately have to make  
8 things work that are constructed and need a say in the  
9 design.

10 Our comment, we considered -- we have considered  
11 the comment, DEQ and Water Quality Division expects that's  
12 as part of the design engineer's due diligence, the review  
13 by the responsible charge operator or public works director  
14 will have been taken into consideration as part of the  
15 submitted design. DEQ and Water Quality Division will  
16 leave the requirement as written, but recommends that local  
17 governments include this collaboration of coordination of  
18 the design engineer in the contract forces and design.

19 Do we have any comments from the Board in regards  
20 to that comment or our response?

21 CHAIRMAN KIRKBRIDE: Sounds like we don't.

22 MR. TILLMAN: Hearing none, moving on.

23 That was all the comments we had in Section 7.

24 The next comments come in Section 8.

25 MR. HENDON: Are there any -- excuse me,

1 Mr. Chairman, are there are any further comments from the  
2 board with regard to Section 7?

3 CHAIRMAN KIRKBRIDE: I don't think so.

4 MR. HENDON: Okay. Sorry to interrupt,  
5 Bill.

6 MR. TILLMAN: In Section 8(c)(i), Darwin  
7 Dick from Tetra Tech, his comment, with respect to the  
8 requirement that are transmission and distribution lines  
9 project, plans, view include existing location of  
10 utilities. Mr. Dick recommended that Chapter 12 revision  
11 adopt ASCE Standard 38-02 Guideline for the collection and  
12 depiction of existing subsurface utility data.

13 We've considered that suggestion. And the intent  
14 was to ensure that the existence and location of all  
15 subsurface utilities are included on the project plan set.  
16 We didn't agree that it was necessary to add another layer  
17 of formatting requirements to that information as necessary  
18 for -- as an extra layer of formatting requirement. We  
19 think that basically the information that we're requesting  
20 is just location of existing utilities, as long as it's  
21 discernible and defined on the plan views that we get, that  
22 that's adequate. That we didn't think it was necessary to  
23 add another set of guidelines to convey that information.

24 Do we have any comments from the Board regarding  
25 that -- that comment from the public for our response?

1 BOARD MEMBER CAHN: I have, Mr. Chair.

2 CHAIRMAN KIRKBRIDE: Yes.

3 BOARD MEMBER CAHN: So I have to go back to  
4 the previous section. I have a lot of comments, and so  
5 it's hard for me to -- I'm trying to read them all and  
6 figure out what's really important and which ones can wait.

7 And it's -- when -- it starts really on line 728,  
8 when we're talking about an alternative two-step  
9 permitting. And I sort of have a bigger overall comment  
10 when we're looking at alternatives. I struggle with this a  
11 lot with the rules, and that is when should something be a  
12 policy and when should something be in the rule. So if you  
13 want flexibility for alternatives, which are in section  
14 (g), and their -- then it's line 746, there's alternative  
15 procedure. Line 758, there's an alternative procedure, et  
16 cetera. So a lot of the rest of the Section 7, I would  
17 probably say all of it, because it follows under that,  
18 would it be appropriate, as a policy or procedure -- you  
19 know, procedure, as opposed to being part of the rule?

20 MR. TILLMAN: Board Member Cahn, that's one  
21 of the things we were given direction from the Attorney  
22 General's Office. To make it enforceable it needs to be in  
23 the rule. Policy is not enforceable. So if we try to  
24 enforce policy, people could push back and say that it's  
25 not -- not a part of our regulations. That's why anything



1 that we're adamant about that, that we're going to try to  
2 enforce, that we're going to require that they do, we try  
3 to make that a part of the rule.

4           And the addition that we add to Section 7 is part  
5 of those what we call the two-step process for permitting  
6 water wells and for permitting water storage tanks that are  
7 funded by WDO. We just wanted -- we added that for  
8 clarity, because it was something that was a part of a  
9 discussion when people submitted applications that they  
10 weren't aware of, and then when they called us and we told  
11 them about that procedure, it was basically new news. It  
12 typically impacted their schedule of how they were trying  
13 to plan the project and execute the project.

14           So we felt that it was appropriate that those  
15 types of procedures be vet -- vetted, I guess, through the  
16 rule so the people were aware up front that when you have  
17 these types of projects, here's the procedure and here's  
18 the timeline that it goes by, so that they weren't caught  
19 off guard and it did not impact significantly their project  
20 as far as when they're trying to complete them.

21           So I guess, in our opinion, what we've added  
22 added clarity to what we were already doing, because it was  
23 not written or codified in any way. It was more or less if  
24 they didn't ask about it, they wouldn't have been aware of  
25 it. But now it's in our rule that anyone that's -- may

1 possibly be considering or they're getting asked to do  
2 something like that, they understand now the procedure and  
3 the time it takes to execute that rather than thinking they  
4 could submit it and go in one shot.

5 BOARD MEMBER CAHN: Okay. Thank you, Bill.  
6 I appreciate that.

7 MR. TILLMAN: Do we have any other comments  
8 from the Board on Section 7?

9 Moving on to another part of Section 8.

10 BOARD MEMBER CAHN: Please wait. Please  
11 give me some time to look through all my comments. I'm  
12 still trying to sort out which ones I can call Gina up  
13 afterwards and say here's an English -- you know,  
14 grammatical one. So I'm trying to sort through my  
15 comments. So just give me a chance to get through, please.

16 Yeah, I do have a question on line 10 -- 1047.  
17 And that's -- it's talking about a Wyoming registered  
18 engineer. And I -- my question is does it -- is it  
19 necessary that they're licensed in Wyoming, or can an  
20 engineer coming over from, you know, Fort Collins or  
21 something do it?

22 MR. TILLMAN: Board Member Cahn, yes, they  
23 have to be a registered Wyoming engineer. Typically if  
24 you're registered in one state, reciprocity is easily  
25 attained in another state, but we do require that they have

1 a Wyoming registered engineer.

2 BOARD MEMBER CAHN: Okay. I have another  
3 question on line 1079. It's talking about the formation.  
4 So it says "The elevation and designation of geological  
5 formations, water levels, formations penetrated, and other  
6 details to describe the proposed well completely." I'm not  
7 sure now -- now I'm not understanding my comment. I have  
8 how far below the penetration should they go in giving  
9 elevations? Perhaps formations can be deleted or specify  
10 how far below the penetrating formations they should  
11 describe. I'm not sure -- oh, I understand my comment.

12 So this is before, correct? This is the listing  
13 of plans. I'm just trying to refresh where we are, what  
14 section. With all the redline/strikeout, it's hard to --  
15 actually, that's another general comment I want to bring  
16 up, and that is by having these things with -- the way we  
17 do it in Wyoming was, you know, section and then (a) and  
18 then (i), and it's just gets so hard to know -- I mean,  
19 I've always had this problem. It's so hard to get to know  
20 where you are. Whereas when I looked back and refreshed my  
21 memory on what, say, Idaho did, having, you know, 1.1, 1.2,  
22 and you knew where you were, having a numeric thing. And  
23 it's kind of above everybody's pay grade, and that's not  
24 how we do it in Wyoming. But it sure makes it confusing.

25 And I guess my first question would be is there

1 any opportunity to change that to something that's more  
2 user friendly?

3 MS. ZYGMUNT: Mr. Chairman. Board Member  
4 Cahn, no, that is not at our discretion to change at this  
5 time.

6 Gina, would you like to add anything about the  
7 Secretary of State requirements?

8 MS. THOMPSON: Yes. So as the rules  
9 registrar for the state, the Secretary of State's Office  
10 sets the format and outline and other specific requirements  
11 for all state agencies. So while -- while we're -- you  
12 know, we periodically struggle with this numbering system  
13 in DEQ, all state agencies are subject to this. There are  
14 no exemptions. We don't get -- there's no variance  
15 process.

16 If our rule doesn't meet their strict outline  
17 requirements, we don't get a rule. So they have the  
18 ability to forbid our promulgation if we do alternate  
19 numbering. So at this time, you know, it's not something  
20 that we can push back on or ask about, because it doesn't  
21 just affect DEQ. It affects all the agencies. And it's --  
22 it just -- it's something that we're subject to.

23 BOARD MEMBER CAHN: Okay. Thanks. I  
24 was --

25 BOARD MEMBER DEURLOO: Mr. Chairman. And,

1 Lorie, first -- Mr. Chairman. I would have to agree. I  
2 think it's backwards, big A being the smallest, and I --  
3 what would it take to approach the Secretary of State? Who  
4 would offer the change in lettering and numbering so it  
5 makes it easier? Like what we're trying to do is make  
6 things easier for everybody. That's the whole goal is to  
7 simplify as much as possible and regulate the things that  
8 we need to.

9           How would one go about changing it to the more of  
10 a numeric -- numeric style, like, say, over a course of 10  
11 years? I know it's probably like changing from imperial to  
12 metric, which I am all in favor of, for the record. But  
13 I'm not going to go there right now. But how does one go  
14 around doing that, please?

15           MS. ZYGMUNT: Mr. Chairman. Board Member  
16 Deurloo, I don't know at this point. I would recommend  
17 contacting Secretary of State. I think the most that we  
18 can do would be to try to find a contact. I'm not familiar  
19 enough with their system to know if it's in regulations.  
20 So, again, my recommendation would be to contact the  
21 Secretary of State directly. But at this time, that's not  
22 a message that our Division would carry.

23           BOARD MEMBER DEURLOO: Okay. Thank you.

24           BOARD MEMBER CAHN: Mr. Chair.

25           CHAIRMAN KIRKBRIDE: Yes.

1                   BOARD MEMBER CAHN: So I do understand my  
2 comment on line 1078. I had to kind of back up to see  
3 where it was.

4                   So we're talking about plans and specifications.  
5 And they're saying -- this is requesting the -- saying we  
6 need to know the elevation and destination of geologic  
7 formations, water levels, formations penetrated, and other  
8 details to describe the proposed well completely. So it's  
9 a little bit vague in terms of how far below the  
10 penetration are you -- should they be going in giving  
11 elevations. And they haven't drilled the well yet. So,  
12 you know, how far below the proposed penetration do you  
13 want them to describe? I mean, we're not going all the way  
14 to China.

15                   MR. TILLMAN: Chairman Kirkbride. Board  
16 Member Cahn, I believe Kevin Frederick was involved with  
17 the UIC group in helping us draft that section. And I  
18 believe that he was referring to probably as far as that  
19 aquifer that they're proposing to use for drinking water,  
20 drill to that depth. So I'm thinking everything that they  
21 know down to the depth of that aquifer that they're looking  
22 to use for drinking water is my guess, is what he's  
23 intending for that elevation.

24                   BOARD MEMBER CAHN: Yeah. So my point is  
25 that this is very unclear. What -- you know, what's the

1 bar somebody meets -- because it's a proposed well, so it's  
2 not like this is a completion drawing for a completed well.  
3 And so elevation and designation of geological formations  
4 will -- how far down -- it's not giving anybody any  
5 inclination about how far below where they're planning on  
6 putting in the proposed wells should they go.

7 MR. HENDON: Chairman. Board Member Cahn.

8 BOARD MEMBER CAHN: It penetrated, that's  
9 like -- go ahead.

10 MR. HENDON: Chairman. Board Member Cahn,  
11 perhaps we can add in a simple definition or declaration  
12 that states how far below the end of their planned well and  
13 how far below that they need to explain the other  
14 formations presented with regards to well and plans and  
15 specs. So we can just have capstone statement with, I  
16 guess, a minimum standard below the --

17 THE REPORTER: Below the?

18 MR. HENDON: Below the end of their  
19 proposed well.

20 BOARD MEMBER CAHN: Or to the --

21 MR. HENDON: Or the casing. The casing.

22 BOARD MEMBER CAHN: -- that they're  
23 being -- that they're planning on getting water from, maybe  
24 it's the bottom of the formation from what they're getting  
25 water from. But maybe you want to know what there is below

1 that for an aquitard or anything.

2           So, anyways, I don't have the answer to this. I  
3 just think that it needs to be better specified.

4           MS. ZYGMUNT: Board Member Cahn, we'll  
5 consult with the groundwater section. And, as Keenan  
6 indicated, we'll add some clarification there.

7           BOARD MEMBER CAHN: Then I have a comment  
8 on line -- on the section that starts on line 1126. And it  
9 uses -- on line 1127, it uses the term "all," but then at  
10 the end on line 1129, it says "when applicable." And so I  
11 say is "when applicable" necessary when the list is "all"?  
12 If it's not part after all, it's not applicable. So I  
13 thought it was confusing having both the terms "all" and  
14 "when applicable."

15           I'll let you guys figure that out. I don't  
16 have --

17           MR. TILLMAN: Board Member Cahn, let us  
18 take a look at that. Let me read that real quickly before  
19 we formulate a response.

20           BOARD MEMBER DEURLOO: Lorie, what line  
21 number was that again, please?

22           BOARD MEMBER CAHN: It's lines 1126 through  
23 1129. And it basically reads the type, size, strength,  
24 operating characteristics, rating or requirements for all  
25 mechanical, electrical equipment, including machinery,



1 valves, piping, electrical apparatus, wiring and meters,  
2 laboratory fixtures and equipment, operating tools, special  
3 appurtenances and chemicals when applicable. So it's  
4 either -- it's all of those things and -- so or when  
5 applicable, so...

6 MS. THOMPSON: Mr. Chairman and Ms. Cahn.  
7 When I read that, all mechanical and electrical equipment,  
8 those -- I think that's a separate concept. So we want it  
9 for all mechanical and electrical equipment, including all  
10 those examples. And laboratory fixtures and equipment and  
11 operating tools and special appurtenances and chemicals --  
12 and chemicals, when applicable. So "when applicable" only  
13 applies to chemicals.

14 BOARD MEMBER CAHN: Okay. So I would  
15 then -- if that's true, then I would say "and, when  
16 applicable chemicals." And then it's clear that -- and  
17 then we have to have an "and" after -- oh, and we do have  
18 "and meters" -- wait. We'd have to have an "and" after  
19 tools and before special appurtenance.

20 MS. THOMPSON: And potentially, if I might  
21 suggest, that might be a good candidate to break that up a  
22 bit.

23 BOARD MEMBER CAHN: Yes.

24 MS. THOMPSON: Because that is a very long  
25 string, and I can see where that would be confusing.

1                   BOARD MEMBER CAHN: Yes. That's all I have  
2 on Section 8.

3                   MR. TILLMAN: All right. Okay. Chairman  
4 Kirkbride, moving on.

5                   CHAIRMAN KIRKBRIDE: Uh-huh.

6                   MR. TILLMAN: Next comment on Section 8  
7 from Darwin Dick was just considering a numbering error and  
8 adding something to a list. We corrected the numbering  
9 error and considered the suggestion, put the design  
10 engineer responsible for researching the information that  
11 is regulated by Wyoming Public Service Commission as a part  
12 of their due diligence. The proposed standard that he  
13 recommended was ASCE 3802 falls outside our regulatory  
14 authority and is better adopted by local governments.

15                   That was the last comment that we had on Section  
16 8. Do we have any other comments from the Board regarding  
17 Section 8 or any other concerns to that section?

18                   BOARD MEMBER CAHN: Yes, I do. Can you  
19 kind of explain to me what you anticipate an engineering  
20 design report to do? When is it prepared, and what --  
21 what's its purpose, and what do you envision is in that?

22                   MR. TILLMAN: The design report typically  
23 is to put into words what they're trying to achieve with  
24 the project, what the proposed -- what project is. The  
25 problem is trying to solve, how it proposes to solve that,

1 and any, I guess, variances or things that they want to  
2 consider or need to consider in application of that design  
3 for that problem. Different than plans and specs. Plans  
4 and specs are typically drawings and spec sheets. The  
5 engineering report is a verbal description of what they  
6 plan to do and any, I guess, other considerations they had  
7 to take into account to make the design workable and fit  
8 our rules and regulations. And, therefore, that's why,  
9 when we modified that, the engineer that we were working  
10 with at the time -- or a couple of engineers -- they noted  
11 that when they got necessarily engineering design reports,  
12 let's say on a treatment works, they weren't necessarily  
13 getting all the things they were expecting to be described  
14 or talked about. So in that section we tried to annotate  
15 exactly what we would expect from the different types of  
16 applications that we received, be it treatment works or  
17 distribution systems or things of that like. And there  
18 was -- whether it was new or existing, it mattered kind of  
19 what that was in the type of information we received.

20 So I guess that's the best way we can address  
21 that comment.

22 BOARD MEMBER CAHN: Okay. Let me -- let me  
23 go through and find my specific comments.

24 MR. TILLMAN: And, Board Member Cahn, there  
25 isn't really any standard template that we expect from

1    them, and that's why we kind of gave them an outline,  
2    because we weren't getting the information that we wanted  
3    or the description of what they were trying to do or why  
4    they chose -- I guess certain design parameters can also be  
5    described in that engineering report.

6                    So it's a verbal description that we look for to  
7    help us understand the who, when, where and why of a  
8    design.

9                    BOARD MEMBER CAHN:  So some of the stuff  
10   seems a little bit more prescriptive and detailed than  
11   you're kind of describing to me.  So I guess I would ask  
12   you to kind of look through this list as you do your  
13   reviews to see if some of this may be -- is either out of  
14   place or -- like, for instance, there's a description on --  
15   on line 1892, it starts out "A summary of the likely  
16   drilling and completion challenges that will be faced,  
17   including description of the engineering design,  
18   management, monitoring, and drilling and completion  
19   practices that will be used to successfully construct the  
20   well in accordance with this Chapter."  And I will say a  
21   lot of this stuff isn't really known ahead of time, so, you  
22   know, I'm not sure that some of the stuff really belongs in  
23   an engineering -- kind of a high-level conceptual report,  
24   or -- so...

25                    And then, again -- let's see.  "The methods that

1 will be used to overcome lost circulation, bore  
2 instability, and deviations from vertical" -- I mean, I  
3 think a lot of the stuff you aren't going to know until --  
4 I mean, you have might have some contingency plans of what  
5 you're thinking you're going to do, but I think a lot of  
6 this is just really premature. It's really more  
7 appropriate for -- at the back end, after you've put in  
8 your well, not while you're proposing your well.

9 MR. TILLMAN: Chairman Kirkbride and Board  
10 Member Cahn. That section in particular was -- arose from  
11 the issues that they came up with in Gillette Madison in  
12 that acidizing. And you're correct, there's some of that  
13 information you're not going to know. But on the other  
14 hand, we're requesting that they do their due diligence to  
15 try to find out that information, because that was probably  
16 some of the issues that we ran into, is that -- or that we  
17 do run into when people drill some wells. They'll claim  
18 they don't know anything about the geology, where they're  
19 going into. And sometimes they don't. But at the same  
20 time, if we're going to permit them to drill those wells,  
21 to the best of our ability we have to request that we get  
22 that information so that we can try to protect the  
23 environment and the aquifers and those existing wells to  
24 the best that we can. And it is very well understood that  
25 some of that information would not be known up front. But

1 at the same time, through other means, through other  
2 documents, through maybe other drilling logs in the area,  
3 maybe -- and I don't know how far apart that needs to be,  
4 because I know geology can change from an acre of land from  
5 one corner to the next, but we would ask that that person,  
6 the engineer, do their diligence, use all their channels,  
7 to try to figure out where that information might reside.  
8 And if they don't -- if they can't come up with that  
9 information, let us know to their ability what they do know  
10 and what they're planning so that, again, we can try to  
11 make a calculated decision and an agreed decision with the  
12 permittee that with all we know and what all we know of  
13 that area, we're in pretty good shape that we're not going  
14 to have any issues.

15           So, again, there is some -- there is some  
16 understanding that we may not get all that we're asking  
17 for, but we're still going to ask for that, and we're  
18 obligated to ask for that in trying to protect the  
19 environment.

20           BOARD MEMBER CAHN: Okay. It just -- it  
21 sort of seems like a lot of information based on one --  
22 maybe you can quickly summarize what happened in Gillette  
23 with that acidization problem. Just quickly.

24           MR. TILLMAN: I guess the best way I can  
25 summarize that is that they were trying to, you know,

1 stimulate a well through acidization. And I guess they had  
2 accompanying ranchers, other residents, that all the sudden  
3 saw the pH in their water in their well drop to -- I think  
4 it was below 2. It was around a 1 or something like that.  
5 To where animals wouldn't go near it. And they're kind of  
6 going what's going on here?

7           And so part of the investigation -- we didn't  
8 understand whether or not it was part of the stimulation of  
9 that well that got away from them, that they didn't know  
10 the geology, the formation, the cracks, fissures, and all  
11 those sorts of things that may have led to possible acid  
12 getting into a formation or into an aquifer that they  
13 weren't aware of. But as it turned out, it seemed that the  
14 geology, the natural components in the dirt, in the earth,  
15 lended itself towards an acidic liquid. And so it was  
16 something that was naturally occurring, but it just so  
17 happened to be at the same time that they were trying to  
18 stimulate a well in a nearby area. So it was kind of  
19 happenstance that they discovered that it was natural  
20 geology chemistry that was contributing to that low pH  
21 water different than injecting acid into the ground, trying  
22 to fracture or stimulate, you know, water production.

23           So, again, that was part of the drive to try to  
24 understand more of what's going on subsurface prior to  
25 someone drilling a well and drilling a hole and saying,

1 hey, I think we've got water, so that we have fully  
2 understood what we might run into. And, again, that's a  
3 might, and I think we're -- the public puts that on the  
4 Department that we do our diligence to the best that we can  
5 to understand what that might be in the future, because  
6 whether we're wrong or we're right, they're going to expect  
7 that we -- we permitted that well and we knew what we were  
8 doing when we did permit that well.

9 BOARD MEMBER CAHN: So it seems -- it  
10 sounds to me like we had a problem and we thought it was  
11 acidization. So because of that, we are bringing in all  
12 these new requirements. But then it turned out not to be  
13 that. So I'm a little bit -- it seems like a lot of  
14 prescriptive stuff for one example that didn't turn out to  
15 be what we thought it was.

16 MS. ZYGMUNT: Can I -- if I can interject.  
17 So Mr. Chairman. Board Member Cahn, Bill gave a good  
18 summary of the Gillette Madison project. And, yes, it did  
19 not turn out to be acidization of the well causing the  
20 water quality problems, but as we mentioned this morning,  
21 that investigation pointed to areas where we needed more  
22 information -- information to make sure that we are doing,  
23 as Bill said, a regulatory due diligence to protect  
24 groundwater.

25 We will take another look at this language, but



1 I'm feeling pretty confident that it's language that we  
2 need to address what we learned through the Gillette  
3 Madison project. So we understand your comment. We will  
4 consider that feedback. But I do just want to make it  
5 clear why we have included this language and why it is  
6 important to the State.

7 BOARD MEMBER CAHN: Okay. Thank you.

8 And then going on to line 1916. It says "If any  
9 damage to the casing" -- sorry, 1915. "If any damage to  
10 the casing is found, the applicant shall describe how  
11 defective areas will be repaired and if there is a need for  
12 additional well bond logging." And, I guess, is there an  
13 example where when well bond logging wouldn't be needed for  
14 damaged or defective casing?

15 MR. TILLMAN: Excuse me, Board Member Cahn,  
16 could you please repeat that?

17 BOARD MEMBER CAHN: Yeah. So on line 1915  
18 and 16, we're talking about if any damage of the casing is  
19 found, and said the applicant shall describe how defective  
20 areas will be repaired and if there is a need for  
21 additional well bond logging. And I'm thinking isn't  
22 there -- is there an example where you wouldn't need well  
23 bond logging for damaged or defective casing?

24 MR. TILLMAN: Board Member Cahn, I believe  
25 that not always when they drill a well is bond logging

1 required. In some instances where they know they've got  
2 problems or they had an issue with putting in that casing,  
3 I think that where bond logging can give them indication as  
4 to where that problem is, how -- how pervasive or how long  
5 or depthwise that problem exists, and gives them indication  
6 what they can do.

7 In some instances, bond logging is not -- is not  
8 necessary, is not even asked for. So I guess what we're  
9 trying to do there was in the event that they're putting in  
10 casing, they know they had issues, that bond logging can  
11 give them some information, some intel, as to what they  
12 need to do and how they can solve and rectify the problem  
13 that they've run into.

14 BOARD MEMBER CAHN: But you're saying it  
15 wouldn't always need to be well bond logging if there's  
16 damage to the casing or defective areas?

17 MR. TILLMAN: Not always, but, again, I  
18 would leave that -- I'm not a driller, and I would leave  
19 that to the drilling -- the drilling people, geologists, to  
20 determine whether or not that bond logging would give them  
21 that information, that additional information that they  
22 need to make a repair or to not -- or deem it's not severe  
23 enough to be repaired.

24 But that would be something I would defer to that  
25 specialist -- that geologist to make that determination.

1 BOARD MEMBER CAHN: Okay.

2 MS. ZYGMUNT: Mr. Chairman, if I could  
3 interrupt. So we are at 2:30. And Mr. Deurloo pointed out  
4 earlier that we will not likely get through all sections of  
5 the rule today. If it would be a good plan, we could  
6 finish the section that we're on now, Section 9, and then  
7 it might be the best use of time to then talk about what  
8 the Board would like us to do from this point forward.

9 CHAIRMAN KIRKBRIDE: I think that's fine.  
10 Go ahead.

11 BOARD MEMBER DEURLOO: Mr. Chairman, I'll  
12 make -- just as a -- I've been involved with lots of  
13 drilling, lots of coal-bed methane wells and core wells and  
14 oil wells and so forth. And that line 1915 seems -- Lorie,  
15 it seems fine to me. When there's -- when the original  
16 bond log finds a problem in the well, whether it be annulus  
17 cement or casing or whatever. There's an innumerable  
18 amount of tools you can send down wells to -- downhole to  
19 determine what the problem is. And so I think that's  
20 pretty -- I believe it's pretty well written to allow the  
21 experts to -- you know, they need to notify the DEQ that  
22 something's gone wrong, but there's additional bond logging  
23 if necessary to figure out what's wrong with it.

24 BOARD MEMBER CAHN: Okay. Thank you,  
25 Brian.

1                   MR. TILLMAN: Chairman Kirkbride, we're now  
2 into Section 9.

3                   BOARD MEMBER CAHN: Excuse me. I think --

4                   MR. TILLMAN: Go ahead.

5                   BOARD MEMBER CAHN: -- we had decided --  
6 oh, I see. We're just finishing Section 9. I'm sorry. Go  
7 ahead.

8                   MR. TILLMAN: Comments that we had on  
9 Section 9, the first one was from Cheyenne BOPU. Basically  
10 it was a number -- numbering error in 9(a). We will  
11 address that.

12                   In Section 9(b)(iv), from Mr. Dayton Alsaker.  
13 Mr. Alsaker commented a design engineer may not know about  
14 all the services that are connected to a new waterline. It  
15 seems this comes later by the system owner through their  
16 cross-connection control program by the person designated  
17 to conduct this evaluation.

18                   And we've considered this comment. Each new  
19 water service connection is required to be permitted. DEQ,  
20 Water Quality Division requires that the review at that  
21 time of the design for the overall type of hazard, and we  
22 will review future changes to assist them to permit  
23 conformance. DEQ anticipates that the design engineer will  
24 conduct their analysis to the best of their knowledge and  
25 future connections will need to be considered as new

1 details emerge.

2           So at the time that they, I guess, apply for  
3 their permit, all the information that they know regarding  
4 service connection needs to be evaluated for its having  
5 connection. And to the best of their extent, if they don't  
6 know, and they don't know what the services will be, when  
7 those services are applied for a permit, that at that time  
8 we will evaluate what those connections are and their  
9 hazard classification, and then assign them that  
10 classification at that time and move forward with the  
11 installation.

12           Any comments from the board members or -- on that  
13 comment or our response?

14           CHAIRMAN KIRKBRIDE: I don't hear any.

15           MR. TILLMAN: Objection. Moving on to the  
16 next comment in Section 9. Section 9(e)(ii)(A). Region 8  
17 EPA commented that this section requires water systems that  
18 are collecting water quality data for surface water sources  
19 to conduct two water quality sampling events; one during  
20 spring runoff and one during late summer or early fall low  
21 flow. There are concerns that this may not capture the  
22 expected seasonal variability of some water quality  
23 parameters. They suggest that we increase the sampling  
24 frequency for some water quality parameters that are  
25 expected to be highly variable.

1           Our response, Water Quality Division has  
2 considered this comment. Paragraph B, capital B, states  
3 this data shall be sufficient for the Division to determine  
4 that the process safely and reliably complies with the  
5 water quality standards required by 40 CFR Part 141. When  
6 combined with Part B, the sampling frequency is flexible so  
7 that DEQ, Water Quality Division, may require additional  
8 sampling as needed. And depending on what information we  
9 get, we can always ask for more. And so we would request  
10 this passage remain as written.

11           Do we have any comments from the board members  
12 regarding that comment or our response to that comment?

13           CHAIRMAN KIRKBRIDE: I don't hear any.

14           BOARD MEMBER CAHN: Um, have we gotten to  
15 Mr. -- which section are we in right now? I mean, we're  
16 Section 9. Which part are we in right now?

17           MR. TILLMAN: We're in Section 9. The  
18 comment was from Region 8, and the Section 9(e)(ii)(A).

19           BOARD MEMBER CAHN: Okay. I guess I'll  
20 want to go back to the previous comment by Dayton Alsaker.  
21 You have to excuse me. We have so many pieces of paper,  
22 and I'm trying to shuffle through all of them on my  
23 computer, and it's just really hard to keep track of where  
24 we are and what people said.

25           So his comment on 9(b)(iv).

1 MR. TILLMAN: Uh-huh.

2 BOARD MEMBER CAHN: He said -- Mr. Alsaker  
3 commented that a design engineer may not necessarily know  
4 about all the services that are to be connected to a new  
5 waterline. And I'm thinking that the comment -- the  
6 passage could actually be reworded, I think, to address his  
7 comment. I think it's the way it was worded.

8 And then I'll have to switch back to line 1781.  
9 Sorry. I have -- we have so many files for this, I can't  
10 even find --

11 BOARD MEMBER DEURLOO: Yeah, it's really  
12 difficult. I feel your pain, Lorie, because we're going  
13 off comments and then we're going off the document that was  
14 written for public comment and one that's corrected. It's  
15 all over the place, trying to figure out which number we're  
16 on.

17 BOARD MEMBER CAHN: Yes. So line 17 -- oh.  
18 Line -- I think it's at 1681. I've got to get there on  
19 another -- okay.

20 BOARD MEMBER DEURLOO: I'd like to make --  
21 Lorie, while you're looking, Mr. Chairman, if I may for a  
22 moment?

23 CHAIRMAN KIRKBRIDE: All right.

24 BOARD MEMBER DEURLOO: So, Mr. Chairman, if  
25 I'm understanding, because I'm like Lorie, kind of jumping

1 back and forth here. You're reading comments from the  
2 public that were based upon their referring to 9(b)(ix) or  
3 what have you, you know, we're trying to follow that down,  
4 and that's the lines. But then the most recent one that  
5 we're looking at is the last -- the second to last file on  
6 your website. It's -- it's the Chapter 12 strike and  
7 underline, yet you're referring to with the public comments  
8 on this -- not the -- sorry.

9 I'm looking at the -- sorry. Never mind. So,  
10 yeah, I do have a question here. When you're -- when --  
11 because I'm jumping back and forth. When the comments from  
12 like EPA come and they say we want to make a comment and on  
13 9(e), you guys have made -- as of December made updates to  
14 those incorporating some of the comments into the rules,  
15 right -- into the draft rules, right?

16 MS. ZYGMUNT: Mr. Chairman. Board Member  
17 Deurloo, that is correct. So the response to comments are  
18 just organized by section with a header to give you a sense  
19 of what passage in the rule. But the most recent strike  
20 and underline that Gina provided does include any edits we  
21 made to the rule itself based on the comments.

22 BOARD MEMBER DEURLOO: Got it. And where  
23 my train came off the rails was at 9(b), because it would  
24 have 9(a) to 9(t). And I think that is referring like this  
25 updated -- updated numerals? Is that right, or am I wrong



1 on that? Because on 9(b), the old ones, you go from 9(a)  
2 to 9(g), skip (b), (c), (d), (e), (f). And so are you  
3 referring to old numbering here when you say 9(b) or the  
4 new?

5 MS. ZYGMUNT: The new numbering would be my  
6 understanding, Board Member Deurloo.

7 BOARD MEMBER DEURLOO: Okay. Yeah.

8 MS. ZYGMUNT: We do recognize this is  
9 confusing. We get confused ourselves, and it is a big  
10 challenge. And I just have to give kudos to Gina, because  
11 she does a phenomenal job trying to track these changes and  
12 present them in a digestible way. So we recognize the  
13 challenge that we're throwing at you, particularly with  
14 this size of rule. We're open to feedback how we can  
15 present that information more clearly, but it is a big  
16 challenge. We get that.

17 BOARD MEMBER DEURLOO: Sorry. I'm not  
18 trying to complain about this. I'm trying to figure out  
19 different ways or if there's an easier way.

20 Thank you. I'll bet Lorie's got her thoughts  
21 together by now. Thank you.

22 BOARD MEMBER CAHN: Well, on that, Brian, I  
23 think in the response to comments, if it could give the  
24 line number that the comment -- you know, Section 9(b)(iv),  
25 if we got that that refers to 1781 to 1782 in the

1 redline/strikeout version, then that would help us jump to  
2 that part. But anyway, so what --

3 BOARD MEMBER DEURLOO: I agree.

4 BOARD MEMBER CAHN: I think Mr. Alsaker has  
5 a really good point here. He says -- so the language in  
6 the proposed language says "A determination of the degree  
7 of hazard of all water service connections" -- and this is  
8 line 1781 -- "to be connected to the proposed project. A  
9 hazard classification shall be identified for each  
10 connection and recommended mitigation measures shall be  
11 described for each hazard." And what he's saying is design  
12 engineer's not going to necessarily know about -- for a new  
13 waterline, the design engineer's not going to necessarily  
14 know all the services that are to be connected. So he says  
15 that -- you know, seems this comes later by the system  
16 owner through their cross-connection control program. So  
17 are we asking for stuff that it's not -- they might not  
18 even know, or -- or we asking for it in the wrong place? I  
19 mean, you know, does the cross-connection control permit --  
20 are we regulating it in two places, is kind of what I'm  
21 asking. But -- that's number one. And number two, his --  
22 I think his point is since this isn't going to be known,  
23 maybe -- I'm saying maybe DEQ could reword and take out the  
24 word "all" on 1781. So it's determination of the degree of  
25 hazard of water service connections to connect -- or

1 anticipated to be connected to the proposed pipe -- or  
2 known to be future connections or something. Because  
3 obviously there's lots of unknowns. And by using the word  
4 all, somebody could say, well, you never told us about  
5 this. And they can say but I didn't know about it at the  
6 time. So I think we need something to cover the event  
7 where a future use is not anticipated at the time. This  
8 is, again, an engineering design report. So this is this  
9 high-level, upfront document.

10           So, again, I think there's a lot of detail in  
11 here that seems to me to be too early on in the project.  
12 It -- we're at the planning stage, not the done and  
13 reporting stage. So I would just ask DEQ to kind of look  
14 through -- that's the stuff in here we talked about, maybe  
15 looking through and seeing if there's some stuff here that  
16 is really too detailed through this stage. And I think  
17 this is an example where maybe the word "all" might need to  
18 come out, as well as maybe some other things. So I'll  
19 leave it at that.

20           MR. TILLMAN: Board Member Cahn, when they  
21 submit an application, they don't submit application to  
22 install a waterline. They just say we want to stick a line  
23 in the ground. Typically with an application they're  
24 installing for a subdivision, for a business, for a  
25 service, for an apartment building. They know something

1 about what they're doing. They may not know the extension  
2 that we're going to go, you know, another couple hundred  
3 yards and add another subdivision. They may not know that  
4 at that time, but at the time they're usually putting in an  
5 application for water system, they have a fairly good idea  
6 what the initial use of that water system's going to be.

7           That's all we're asking. To the extent that they  
8 don't know what the extension might be, if they put a plug  
9 and valve at the end of the line saying we can extend that  
10 further if someone wants to incorporate that area or  
11 someone wants to buy, you know, that piece of land and do  
12 something else with it, and they don't know what that looks  
13 like, we understand that.

14           But we argue that when they put in a line for a  
15 subdivision, they know what residences are. They know  
16 where they're going to be plugged in. They know whether  
17 they're going to have a strip mall or if they're going to  
18 have apartment buildings. And all we're asking is that  
19 they evaluate those hazard classifications at that time.

20           And you're absolutely correct, sometimes they  
21 don't know. But that's what we're saying, when they do  
22 know and they go to apply for that permit to finish that  
23 construction, at the time when they do know, they give us  
24 that hazard classification based on the information that  
25 they're going to build.

1 MS. ZYGMUNT: And I think, Board Member  
2 Cahn, that the way we can potentially write that to support  
3 what Bill just said and address your concern would be all  
4 known or anticipated water service connections, and then as  
5 a response indicates we would work with them on future  
6 modifications. But as Bill said, we do need to know  
7 upfront everything they are anticipating at that time.

8 BOARD MEMBER CAHN: Jennifer, I --  
9 Jennifer, I appreciate that. I think adding that language  
10 "known or anticipated at the time" type language would  
11 really help.

12 MS. ZYGMUNT: Great.

13 MR. TILLMAN: Chairman Kirkbride, that  
14 concludes Section 9. So I think we're at a point where we  
15 need to, I guess, discuss our path forward.

16 CHAIRMAN KIRKBRIDE: Anybody else got  
17 anything on 9?

18 Okay. All right. Path forward, what do you  
19 think?

20 MS. ZYGMUNT: Mr. Chairman, we're certainly  
21 open to feedback. I think after what we've heard today,  
22 you know, I'm seeing a couple needs. First, people need  
23 time to digest the material that we've presented. We also  
24 need time to digest the comment that Mr. Sepe provided  
25 today via our Smart Comment Portal. So we will definitely

1 take a look at that and can update response to comments and  
2 draft documents.

3 I'm tentatively foreseeing the Board might like  
4 another public notice comment period on this rule.  
5 Obviously we would do that before bringing the rule back to  
6 the Board at the first quarter of 2022. So we're open to  
7 doing that again. I do not feel, again, that we need to go  
8 back to square one, start over with the stakeholder group.  
9 I think the comments have identified, excuse me, entities  
10 that we can do some targeted outreach with, look at their  
11 comments and their questions, provide responses, do a  
12 little bit more outreach that way to better prepare us to  
13 come back to you at your next board meeting with further  
14 revisions and/or additional responses to comments.

15 Those are my initial thoughts, but, again, I'm  
16 open to feedback on what the Board would like to see.

17 BOARD MEMBER DEURLOO: Mr. Chairman, this  
18 is Brian Deurloo. May I make a comment?

19 CHAIRMAN KIRKBRIDE: Please do.

20 BOARD MEMBER DEURLOO: Thank you.

21 As just a thought, I think we're just throwing  
22 some ideas on how to proceed. This is the first time that  
23 I have -- Chairman Kirkbride and I joined the Board at the  
24 same time --- I don't know how many years, three, four  
25 years ago now -- and it's the first time I've seen that we

1 haven't got all way through like a single rule and had to  
2 carry on to the next one.

3 I would be willing to meet sometime in January,  
4 even before the next quarter. Like we don't have to wait  
5 the full quarter to get to it, otherwise it might take us a  
6 year to get this passed.

7 I don't know -- we've already had a public  
8 comment on this draft of the rules. I don't know if I  
9 recommend another public comment on the whole thing when  
10 we've already covered one-third of it today. If it please  
11 the Board, and I'd open it up for comment, that we just  
12 continue with this discussion and -- between now and -- or  
13 sometime in January. Maybe Lorie can share some of her  
14 grammatical and other comments with Gina between now and  
15 then, we pick up right where they left off and then plan on  
16 completing it even before the first quarter board meeting,  
17 potentially. So I guess what I'm talking about is maybe a  
18 special session to continue discussion.

19 MS. THOMPSON: Those special meetings  
20 are -- they're allowed under the Rules of Practice and  
21 Procedure that govern rulemaking. And if you -- if you  
22 want, I can pull up that rule to see what the requirements  
23 are. I think -- I think that's one of your decision  
24 options. But if you -- if it pleases the Chairman, I can  
25 look up that rule and see what the requirements are for a

1 special meeting.

2 CHAIRMAN KIRKBRIDE: All right. What is  
3 the timeline that the Division needs? I mean, are you  
4 wanting to keep this moving?

5 MS. ZYGMUNT: We're absolutely willing to  
6 keep this moving. It will not take significant time to  
7 respond to Mr. Sepe's comment from this morning. Again,  
8 if we need to do targeted outreach with the individuals  
9 who have commented so far, I think having a meeting in  
10 January -- toward the end of January would give us time to  
11 do that.

12 CHAIRMAN KIRKBRIDE: Is any Board unwilling  
13 or think it's a better idea to wait?

14 BOARD MEMBER COCHRAN: Mr. Chairman.

15 CHAIRMAN KIRKBRIDE: Yes.

16 BOARD MEMBER COCHRAN: I might ask what is  
17 proposed for the first quarter meeting?

18 MS. ZYGMUNT: I might have to look at Gina,  
19 see what she has on her radar.

20 MS. THOMPSON: So my understanding, as of  
21 this week, our sister division has no topics ready for your  
22 next meeting. DEQ anticipates -- or we had anticipated  
23 bringing the new rule to you governing the fees for the  
24 electric sequestration projects and the special revenue  
25 account. That rule has not been through our preliminary



1 attorney review, and so that one would not be ready for an  
2 early January meeting. We had anticipated bringing that to  
3 you in March. That those -- that project is the only one  
4 that I'm aware of at this time.

5 MS. ZYGMUNT: Mr. Chairman -- and, Gina,  
6 thank you for the reminder. Yes, that would be Chapter 29.  
7 I'll give you a heads-up that is only five pages, though,  
8 so in terms of you doing a review of that rule, it should  
9 not be a significant lift, much different than Chapter 12.

10 So I think we're open. We can go either way. If  
11 the board feels it's important enough to keep this moving,  
12 meet toward the end of January, we'd be happy to do that.  
13 If we wanted to wrap both chapters into one meeting, the  
14 new Chapter 29, coming back to Chapter 12, we would be fine  
15 waiting until February, March as well.

16 BOARD MEMBER CAHN: So would we just -- let  
17 me ask just a couple questions. So, I mean, I see one  
18 option we just hold onto our comments that we have on the  
19 rest of the chapter and we leave the public comment period  
20 open, because I think, in my mind, given the problems that  
21 some people had expressed their frustration in finding the  
22 10 States Standards, we need to give more people time to  
23 comment on these. So we can leave them as is, and at our  
24 next meeting pick up and maybe cut off the public comment  
25 period so many days before our meeting so that you have a

1 chance to go over them and -- and then continue our  
2 discussion with the rest of the chapter. And then you go  
3 back and make changes, if necessary. Otherwise, maybe the  
4 Board just says, yeah, we're addressing these comments  
5 adequately at that meeting and go forward.

6           So I see one option would be to -- to continue  
7 the public comment period and continue -- basically  
8 continue this meeting until either January or the next time  
9 that we're going to have a quarterly meeting anyways. I'm  
10 afraid that if we do another alternative, which is you guys  
11 go back and revise it now and come back to us with a new  
12 one, all the comments -- it's going to make a lot of work  
13 for the Board, because all the comments that we've -- I  
14 have spent days and days and days.

15           I cannot -- I've never spent this much time on a  
16 new -- on the regulations and the comments as I have on  
17 this, and I don't want to lose what -- what work I've  
18 already done and have to redo it and figure out where does  
19 what I've got -- wrote before apply to new rules and  
20 everything else. So -- but I'm willing to do that if -- if  
21 you prefer to take it now and go back to the drawing board  
22 and then have a new public comment period with new rules,  
23 new revised rules. So I think we've got kind of two  
24 options, and I guess I'm looking for feedback on what DEQ  
25 thinks and what other board members think about that.

1 MS. ZYGMUNT: Mr. Chairman. Board Member  
2 Cahn, yeah, we clarify we certainly don't feel we need to  
3 go back to the drawing board. We feel we have a good  
4 product that's still obviously in development. We have a  
5 good initial round of feedback. We certainly don't want to  
6 create additional work for the Board. And we know how big  
7 of a lift this has been for us, so we can appreciate the  
8 time that it's taken you to go through this significant  
9 chapter as well.

10 So that said, I am going to, you know, have Gina  
11 double-check me here as I talk out loud. But if we wanted  
12 to extend the public comment period so that people have  
13 time to look at the 10 States Standards and during that  
14 time we'll make -- do some outreach to make sure people  
15 know where they can find the 10 States Standards and then  
16 have a clear cutoff date before the next Board meeting,  
17 that would be a workable solution for us as well. But  
18 compared to what we've done in the past board meetings,  
19 where the public notice goes up to the meeting, a clear  
20 cutoff date for those comments well in advance of the  
21 meeting will help assure that we can wrap up any comments  
22 and get a clear product to you before the meeting that you  
23 have time to review.

24 Gina, can you correct me on anything there?

25 MS. THOMPSON: Yeah, I would agree, that

1 would be consistent with how we've handled other similar  
2 extended comment periods. And, you know, I would reiterate  
3 if we do extend this, that closing it off well in advance  
4 of the Board, so that we can finalize any changes, give  
5 them to you in time for you to review them, we can  
6 certainly do that. With that extension of the comment  
7 period, we would -- we would follow our typical public  
8 process. We've done an ad before. So we'd probably do a  
9 newspaper ad, do our listserv, do our hand mails, and then  
10 make adjustments to your advisory board Web page resources  
11 so that there's isn't confusion on what we're asking people  
12 to look at. So...

13 BOARD MEMBER CAHN: I'd like to add  
14 something. And I think, you know, with us losing -- with  
15 you losing Bill -- and good luck to you, Bill, in your next  
16 endeavor -- I think we're losing a lot of institutional  
17 knowledge and expertise, and so I would like -- you know, I  
18 don't know who's replacing Bill or who's going to be  
19 working on this, but it would -- I think particularly,  
20 because we're losing Bill, I think it would be really  
21 important that whatever stakeholder group also has people  
22 within DEQ that have the experience base working with  
23 the -- I'd like the district engineers to be involved,  
24 so -- anyways, just want to ask that, you know, you guys  
25 work with your district engineers as well as the

1 stakeholders within the state.

2 MS. ZYGMUNT: Absolutely, Mr. Chairman,  
3 Board Member Cahn. Pretty much all the staff in the Water  
4 and Wastewater Section have been involved in this rule.  
5 Yes, we are very sad to lose Bill. We have not talked him  
6 out of retirement yet, and I don't think we will over the  
7 next week. So it is a challenge every time we lose that  
8 historical knowledge within the agency and the Division.

9 I have failed to introduce Anthony earlier.  
10 Anthony Rivers is in the room with us. He is one of our  
11 newest additions to the Water and Wastewater Section. And  
12 he's been working with Bill to help assimilate some of that  
13 historical knowledge on this rule and has been a big help  
14 on bringing this revised chapter to where it is now. So  
15 Anthony will be picking up some of the workload, but we  
16 will be working with all of our district engineers, because  
17 that historical knowledge is important. And, again, Board  
18 Member Cahn, we will outreach to entities that have reached  
19 out to us in comments.

20 BOARD MEMBER CAHN: Thank you.

21 MS. ZYGMUNT: And one other note,  
22 Mr. Chairman. You know, as appropriate, and we want to be  
23 cognizant of public meetings laws, but if there are times  
24 when we could facilitate one on outreach with board members  
25 to help answer questions, we'd be happy to look into that

1 too. We might need to consult with Gina and our Attorney  
2 Generals just to make sure we are following all appropriate  
3 procedures there. But if it would help to do some specific  
4 outreach with you guys one on one, we'd be happy to do  
5 that.

6 CHAIRMAN KIRKBRIDE: I believe we've come  
7 to some kind of consensus, unless somebody's got -- seemed  
8 like to me, Gina, you look for a time, huh? Explore a time  
9 for ways you had -- you had mentioned quite a few hoops you  
10 had to jump through.

11 MS. THOMPSON: Right. Go ahead,  
12 Mr. Deurloo.

13 BOARD MEMBER DEURLOO: Oh, thank you.  
14 Mr. Chairman. So I hear -- like the question is do public  
15 comment or not do public comment before the next meeting, I  
16 suppose, maybe is what I'm hearing. We could move the --  
17 we could move the first quarter advisory board meeting up  
18 to -- well, I don't know. It's just a matter of timing,  
19 and I'm wondering what the staff prefers, that we do extend  
20 the public comment period or we finish the review process  
21 here.

22 It seems to me -- I could be wrong, but it seems  
23 to me that we will -- if we go through this, it's one of  
24 the most important -- it's a very -- not most important,  
25 but very important rule. Will we be sending this to public

1 again after our next one? You know, so we've taken onboard  
2 the comments we already have. I'm not trying to make a  
3 motion for the next meeting or anything like that. I'm  
4 just kind of wondering, are we going to be sending this out  
5 for public comment again after our next meeting? I think  
6 that might dictate if we hold or extend public comment on  
7 this one. Am I right or off base there?

8 MS. ZYGMUNT: So, Mr. Chairman, Board  
9 Member Deurloo, I think I'll answer your question, but once  
10 the advisory board advises us to move forward with the  
11 rule, it will go to the Environmental Quality Council.  
12 There will always be a public notice before the  
13 Environmental Quality Council meeting. And I'm going to be  
14 looking toward Gina here as well, but we are required to  
15 have a public notice before each advisory board meeting as  
16 well. So there -- if -- regardless, before the next  
17 advisory board meeting, there will be another public  
18 comment opportunity for folks to comment on this rule. Did  
19 that answer your question or confuse?

20 BOARD MEMBER DEURLOO: That answered my  
21 question. Yes, it totally did. Thank you.

22 BOARD MEMBER CAHN: And I would like to  
23 propose that we just extend the public comment period that  
24 we're in right now, that ends at the end of this Board  
25 meeting. I think we just extend that. I've been on the

1 Board a long time. We've done that many times before. So  
2 we just -- I would propose we just extend this public  
3 comment period. And I don't know if we're having our  
4 meeting in March or January or whatever, but if there's  
5 other business to be done, then we can combine -- have one  
6 Board meeting in March that has other business, then maybe  
7 we would end the public comment -- you know, extend it now  
8 for another -- it's the holidays, so maybe we extend it for  
9 45 days, or something like that, because the holidays and  
10 now that people know where they can get a copy of the  
11 201810 State Standard. So that would be my proposal.

12 MS. ZYGMUNT: Mr. Chairman, I propose we  
13 try to have the next board meeting in early March, and at  
14 that meeting finish up Chapter 12, finish your discussion  
15 on Chapter 12, and that should also give us time to wrap up  
16 Chapter 29. Again, it's a five-page rule, it should be  
17 very straightforward. It should be similar to other rules  
18 that we've promulgated.

19 So I think that would be a reasonable agenda for  
20 one meeting. It would be more efficient for us if we could  
21 try to combine them into one meeting. So that is what I  
22 would propose, and I would support Board Member Cahn's  
23 proposition to extend the current public notice period for  
24 at least 45 days. If we had the Board meeting in early  
25 March, perhaps we could cut off the public notice period



1       sometime mid-February to give us time to wrap the comments  
2       and deliver products to you.

3                       BOARD MEMBER CAHN:   That sounds good to me.  
4       Thank you.

5                       CHAIRMAN KIRKBRIDE:   Do I hear a motion to  
6       that effect or any other?

7                       BOARD MEMBER CAHN:   I so move.

8                       BOARD MEMBER COCHRAN:   Second.   Jim  
9       Cochran.

10                      CHAIRMAN KIRKBRIDE:   Any discussion?  We'll  
11       vote.  All in favor say aye.

12                      COUNCIL MEMBER COCHRAN:   Aye.

13                      BOARD MEMBER DEURLOO:   Mr. Chairman, I'm  
14       sorry.  Didn't get my mute off.  So, again, I do have a  
15       discussion.  So to me, Lorie still moves, I'm just being  
16       clear.  So sounds like what we're looking at doing is  
17       extending the public comment period by 45 days, and we'll  
18       revisit Chapter 12 as it currently stands with additional  
19       response to comments to the public comments at our next --  
20       the first quarter advisory board meeting.  Is that what I  
21       heard?

22                      CHAIRMAN KIRKBRIDE:   I believe that's it.

23                      BOARD MEMBER CAHN:   I'll just clarify that  
24       I think we're looking at extending the public comment  
25       period to middle of February, so maybe not necessarily

1 talking about number of days, just extending it. We want  
2 to just end it significant enough time before our board  
3 meeting that DEQ has a chance to respond to whatever  
4 comments they receive by the time we have our meetings. So  
5 I would say mid-February would -- considering the holidays,  
6 rather than saying 45 days, it's just -- I like the idea of  
7 let's say we're cutting off the public comment period in  
8 mid-February, and then have our March meeting, deal with  
9 chapter 29, plus this, or whatever else business comes up  
10 at the time.

11 BOARD MEMBER DEURLOO: Okay. Thank you.

12 CHAIRMAN KIRKBRIDE: Clear?

13 BOARD MEMBER DEURLOO: That was my  
14 discussion, Mr. Chairman.

15 CHAIRMAN KIRKBRIDE: Any other discussion?  
16 Proceed to vote. All in favor say aye.

17 BOARD MEMBER COCHRAN: Aye.

18 BOARD MEMBER CAHN: Aye.

19 BOARD MEMBER DEURLOO: Aye.

20 CHAIRMAN KIRKBRIDE: All opposed.

21 All right. That passes. We'll do.

22 Any further business -- when will we be hearing,  
23 do you think?

24 MS. THOMPSON: That is a good question,  
25 Mr. Chairman. We had not discussed. I think that's the

1 last item on our agenda before you adjourn, which would be  
2 the discussion scheduling of the next meeting. And if you  
3 want to adjourn the public part and have the discussion  
4 without the transcriptionist typing, I'll run back and  
5 forth on our schedule, you're welcome to adjourn the public  
6 part so Kathy doesn't have to type it all.

7 CHAIRMAN KIRKBRIDE: Well, then, I declare  
8 the meeting adjourned.

9 (Hearing proceedings concluded  
10 3:07 p.m., December 21, 2021.)

11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

C E R T I F I C A T E

I, KATHY J. KENDRICK, a Registered Professional Reporter, do hereby certify that I reported by machine shorthand the foregoing proceedings contained herein, constituting a full, true and correct transcript.

Dated this 24th day of January, 2022.

  
KATHY J. KENDRICK  
Registered Professional Reporter



**Proposed Revisions to Water Quality Rules, Chapter 12, Design and Construction Standards for Public Water Systems**

**Analysis of Comments Received Prior to February 14, 2022 Notice Period End Date related to the December 21, 2021 and March 15, 2022 Water and Waste Advisory Board Meetings**



**March 2, 2022**

Prepared by:

Wyoming Department of Environmental Quality

Water Quality Division

Water and Wastewater Section

## Commenters:

Darwin Dyck, Tetra Tech  
Jason Palmer, City of Green River  
Dayton Alsaker  
EPA Region 8  
Cheyenne Board of Public Utilities (BOPU)  
Andy Hooten  
Jeffery Rosenlund  
Dave Engels, American Council of Engineering Companies of Wyoming  
Bryan Seppie, Joint Powers Water Board  
Wyoming Association of Rural Water Systems  
Craig Barsness, Shoshone Municipal Pipeline  
Ben Jordan, Weston Engineering  
Toni Stassinios  
Ty Ross, Nelson Engineering  
Frank Page, Morrison Maierle  
Brian Lenz, Town of Jackson

## Chapter 12 Comments and Responses

### General Comments

**American Council of Engineering Companies of Wyoming, Ben Jordan, Bryan Seppie, Cheyenne BOPU, Darwin Dyck, and Ty Ross:** The commenters identified typos and incorrect numbering throughout the chapter.

**Department Response:** WDEQ/WQD has corrected the passages as needed.

**Cheyenne BOPU and Jason Palmer:** Cheyenne BOPU asked when plant modifications require the entire plant to meet the proposed requirements and how will new standards be applied to existing plant modifications. Mr. Palmer requested a definition of “modification,” such as recoating.

**Department Response:** WDEQ/WQD considered the comment. Water Quality Rules Chapter 3, Section 9(a)(iii) identifies the requirements for modifications. WDEQ/WQD will issue a permit to modify the facility that requires the facility to meet the minimum design standards that are in effect when the permit to modify is issued that apply to the modification without altering any other minimum design standards that apply to the facility under its existing permit. WDEQ/WQD will work with permittees as needed to seek compliance with Chapter 12, while to the extent possible, minimizing the burden on permittees when bringing existing facilities into compliance.

**American Council of Engineering Companies of Wyoming, Bryan Seppie, Dayton Alsaker, Andy Hooten, Frank Page, and Brian Lenz:**

The commenters noted concern at using two sets of standards instead of just Chapter 12. The commenters were concerned that the incorporated 2018 TSS is difficult to find online. Some commenters questioned how WDEQ/WQD will resolve potential conflicts between Chapter 12 and the 2018 TSS. Some commenters recommended that WDEQ/WQD incorporate the material differently throughout the chapter, such as adding the pertinent 2018 TSS reference in the paragraph where it applies. Some commenters recommended that WDEQ/WQD use alternate formats and include a table of contents.

**Department Response:** WDEQ/WQD has included incorporations of the parts of the 2018 TSS that we determined are appropriate for systems in Wyoming and has included other requirements to address conditions as needed. After considering several options WDEQ/WQD determined the current proposed approach is the most effective given the various conditions that we needed to tailor from the 2018 TSS and the volume of overall material that is incorporated by reference, not only from the 2018 TSS but also from the American National Standards Institute, American Water Works Association, and the other entities noted in Section 19. After the rule is promulgated, WDEQ/WQD will update the guidance documents related to this Chapter to assist readers with navigation of the rule and the incorporated material.

WDEQ/WQD does not expect an overlap of language between what is incorporated by reference and what is explicitly stated in Chapter 12. If for some reason there is a conflict, the WDEQ/WQD reviewing engineer or Water and Wastewater Section Manager will resolve the conflict on a case-by-case basis, with input from the Administrator as needed.

WDEQ/WQD will have a copy of incorporated materials available for public inspection at WDEQ/WQD's Cheyenne office, as stated in Section 19(b)(iii), and anticipates making a public copy of the 2018 TSS available at our various field offices as well. WDEQ/WQD will post the digital document on WDEQ/WQD's website, similar to the posting we have provided for this rulemaking comment period. The incorporated version of the 2018 TSS is available online at:

[https://www.mngovpublications.com/catalog/Default.asp?CatalogID=21656&Provider\\_ID=1241868](https://www.mngovpublications.com/catalog/Default.asp?CatalogID=21656&Provider_ID=1241868)

for purchase in hard copy or as a digital download.

The overall format of the rule is set by the Secretary of State under the Rules on Rules for State Agencies. Tables of contents are not allowed in official rules that are signed into effect by the Governor.

WDEQ/WQD tested alternative incorporation by reference formats earlier in our drafting process and found that it made sections difficult to follow. The incorporation by reference format will remain as written.

**Frank Page:** Mr. Page commented, “ It is acknowledged that all formal rules and regulations are required to follow the Secretary of State - Rules on Rules. However, these antiquated rules were set up for manual typewriters and make reading, using and referencing the rules more complex, cumbersome and difficult than necessary. It is suggested that the rules on rules be reviewed and revise to make them easier to use.

**Department Response:** WDEQ/WQD has considered the comment. WDEQ/WQD is subject to the Secretary of State’s Rules on Rules for State Agencies and has no statutory authority to revise them.

**Frank Page:** Mr. Page commented, “In the past the Ten States Standards have been used and referred to by WYDEQ, university courses and consultants as a reference. The 2018 TSS is mentioned in the Notice as being incorporated by reference. If it is now going to be used as a regulatory document, then the regulated community should be fully advised of this action. The Public Notice does not adequately advise Wyoming system operators and consultants who will be affected by this change.”

**Department Response:** WDEQ/WQD has considered the comment. WDEQ/WQD has published and distributed notification of our intent to incorporate the Recommended Standards for Water Works for review and comment by the regulated community on November 30, 2020 and on November 5, 2021. The supporting documentation noted in the November 30, 2020 public notice as “additional information” explains that WDEQ/WQD intends to incorporate materials by reference and the November 5, 2021 notice explicitly states that WDEQ/WQD intends to incorporate the Recommended Standards for Water Works, 2018 Edition by reference. WDEQ/WQD proposes no edits to resolve this comment.

**Darwin Dyck, Tetra Tech:** Mr. Dyck wondered “if dug wells should still be permitted. Chapter 12 makes reference to dug wells that shall be constructed according to State Engineer's Office. Chapter 12 also includes concrete piping for well casing material which is assumed to be for dug wells. Dug wells are older technology and would typically deliver groundwater under direct influence of surface water. Subsequently, how and where are procedures for classifying wells as groundwater wells or groundwater wells under direct influence of surface water? Are there Microscopic Particulate Analysis (MPA) requirements covered that confirm classification of shallower water wells? Also, are shallow horizontal infiltration galleries or in-bank filtration options available as options for raw water intakes? Appropriate classification of wells will dictate level of treatment required per results of MPAs.”

**Department Response:** WDEQ/WQD has considered the comment. Dug wells would be individual wells that are proposed to be converted to a public water supply (PWS) well. These wells would need to meet all PWS construction requirements for WDEQ/WQD’s permitting review. Dug wells would need to demonstrate they are not under the direct influence of surface water through MPA sampling.



**American Council of Engineering Companies of Wyoming:** ACEC commented, “As somewhat of a general comment, most State-funded contracts require that engineering costs not exceed 20% of the construction costs. While we are more than happy to comply with any new, additional standards requirements, and that we are capable of complying with these requirements, the State should recognize that it becomes just that much more difficult to stay within the 20% requirement.”

**Department Response:** WDEQ/WQD has considered the comment. The comment pertains to engineering costs that are applied to government-funded projects and does not pertain to the proposed design standards in Chapter 12. Justification of engineering costs and activities are the responsibility of the public water supply, the engineering consultant, and the funding provider. WDEQ/WQD’s proposed standards are consistent with design standards that are widely used throughout the United States and Canada and disagrees that complying with the proposed standards will be economically unreasonable.

**American Council of Engineering Companies of Wyoming:** ACEC commented, “A lot of the changes to the regulations appear to make the language more clear and concise, this is appreciated.”

**Department Response:** WDEQ/WQD appreciates the support of our efforts to make the chapter clearer and more concise.

**Wyoming Association of Rural Water Systems:** WARWS commented, “We encourage the DEQ to add the source water protection language in the 10 State Standards such as 1.1.7.2h.”

**Department Response:** WDEQ/WQD considered the comment. At this time, WDEQ/WQD addresses source water protection planning on a voluntary basis. We look forward to continuing to work together with WARWS on voluntary development of source water protection plans.

**Toni Stassinis:** Ms. Stassinis commented that “there is dirt” in her water “if it sits for anytime. Dirt in my bath water. Tastes bad.”

**Department Response:** The comment is outside of the scope of the proposed rulemaking. However, WDEQ/WQD has advised the commenter to reach out to the City of Rock Springs or to our district engineer, depending on the source of her water.

## **Section 2**

### **2(a)(i) and (iii)**

**Ty Ross:** Mr. Ross noted that W.S. 35-11-301(a)(v) states that “no permit to operate shall be required...”

**Department Response:** WDEQ/WQD has considered the comment. W.S. 35-11-302(a)(iii) allows the Administrator to recommend rules governing “Standards for the issuance of permits for construction, installation, modification or operation of any public water supply and sewerage system.” Entities that have questions regarding whether a permit to construct is needed should contact WDEQ.wQD to discuss specific situations. The passages will remain as written.

## 2(b)

**Ty Ross:** Mr. Ross commented, “This is overly broad and appears to indicate that a PTC would be required for routine or emergency maintenance.”

**Department Response:** WDEQ/WQD has considered the comment. Generally, routine and emergency maintenance are not considered to be “construction, installation, or modification of any component of a public water supply facility.” Routine and emergency maintenance are required to be included in the Operation and Maintenance Manual, pursuant to Chapter 12 Section 18. The passage will remain as written.

## Section 3

**Ty Ross:** Mr. Ross commented, “This section is titled “Timing...”, but speaks nothing of it.”

**Department Response:** WDEQ/WQD has considered the comment. The section explains that facilities that were permitted in the time before the adoption of this version of Chapter 12 will still be covered under the issued permit—permittees will not be required to automatically reapply or retrofit their facility. It also explains that facilities that are newly constructed or modified will be required to comply with this version of Chapter 12 after it becomes effective. The section will remain as written.

## Section 4

### 4(a)

**Dayton Alsaker:** Mr. Alsaker recommended removing the statement that “18 TSS applies unless noted,” and instead referencing the relevant TSS section for each WQD Ch12 section. Mr. Alsaker asked “Are there any places where it is noted that sections of 18TSS do not apply?”

**Ty Ross:** Mr. Ross commented, “aka the 2018 Ten States Standards or ‘2018 TSS’”

**American Council of Engineering Companies of Wyoming:** ACEC recommended that the “2018 TSS” be defined before or on Line 966. ACEC also wondered if WDEQ/WQD will omit the year reference.

**Department Response:** WDEQ/WQD has revised the paragraph to “ This Chapter incorporates sections of the Recommended Standards for Water Works, A Report of the Water Supply Committee of the Great Lakes--Upper Mississippi River Board of State and Provincial Public Health and Environmental Managers, 2018 Edition, referred to as “2018 TSS,” as noted in Section 8(a), Section 9(a), Section 10(a), Section 11(a), Section 12(a), Section 13(a), Section 14(a), Section 15(a), Section 16(a), and Section 19(a)(liv) of this Chapter.”

The first paragraph of each subsequent section in the proposed revisions to Chapter 12 states which 2018 TSS sections apply to the material within.

Removing the year reference in 2018 TSS would be a violation of W.S. § 16-3-103(h)(ii). The reference format will remain as written.

## **Section 5**

**Frank Page:** Mr. Page commented, “Add – Ten States Standards (TSS). 2018 TSS is referenced throughout the text but the acronym “2018 TSS” is not defined until page 12-64.”

**Department Response:** WDEQ/WQD has considered the comment. WDEQ/WQD has revised the passage at Section 4(a) to more clearly describe the incorporated reference. Additionally, Section 19 also identifies publication information for the referenced material.

**Ty Ross:** Mr. Ross commented, “the Act.”

**Department Response:** WDEQ/WQD has revised Section 1 and has revised the only instance of the phrase “the Act” in the Chapter. The recommended edit is no longer applicable and the passage will remain as written.

### **5(u)**

**Ty Ross:** Mr. Ross requested the passage be edited to “mechanical drives.”

**Department Response:** WDEQ/WQD has revised the passage from “mechanically driven drives” to “mechanical drives.”

### **5(v)**

**Ben Jordan:** Mr. Jordan noted concern that the definition of mineralized water poses a conflict with development of both surface and groundwater sources for public water systems, as public water systems across the state for whom water with a total dissolved solids concentration of less than 500 mg/L is not available and treatment to reduce the total dissolved

solids concentration to below 500 mg/L would be an extreme financial burden without a significant improvement in quality. Mr. Jordan requested a change to Chapter of an alternate concentration for “mineralized” water, such as 1,000 mg/L.

**Department Response:** WDEQ/WQD considered the comment. The requirements for wells that encounter mineralized or polluted water have been in place since Chapter 12 was originally promulgated in 1985. The existing and proposed versions of the Chapter require that wells that encounter mineralized water shall be constructed to prevent the mineralized water from entering the well, moving up and down in the annular space outside the casing, or mixing with waters from different aquifers within the well. Neither the existing nor the proposed Chapter explicitly require treatment to levels below 500 mg/L but both do specifically require applicants that propose to use mineralized water as a public water supply to demonstrate compliance with drinking water standards. The proposed revision adjusts this language to specifically require compliance with the National Drinking Water Standards at 40 CFR Part 141. As the requirements pertain to well construction, require compliance with a national standard that the primacy agency EPA will also enforce, and as WDEQ/WQD has not been made aware of any extreme financial burdens to implement this requirement since 1985, the definition and associated passages will remain as written.

#### 5(z)

**Frank Page:** Mr. Page requested definitions for water service connections related domestic, commercial, and industrial.

**Department Response:** WDEQ/WQD needs additional information and will discuss this item with the commenter before providing a formal response.

#### Section 6

**Bryan Seppie:** Mr. Seppie requested that WDEQ/WQD revise Section 6, “so that once a study has provided proven results, those findings are the basis for compliance with the potential conflicting requirements that may be more ‘generally’ written.”

**Department Response:** WDEQ/WQD considered the comment. Many plant designs that would fall under this section contain proprietary information. Pilot plants that don’t meet the general requirements are evaluated on a case-by-case basis.

#### 6(b)(iii)-(iv)

**EPA Region 8:** Region 8 suggested for facilities producing finished water for consumption, that data for a full-scale, comparable installation or a pilot-be required, instead of only a theoretical evaluation.

**Department Response:** WDEQ/WQD has considered the comment. The passages in this section allow systems to propose new and innovative technologies. District engineers evaluate these types of applications under this section for compliance with the Chapter and for other water quality considerations. These types of applications go through a thorough review and approval process before issuance. The passages will remain as written.

## Section 7

**American Council of Engineering Companies of Wyoming:** ACEC requested that WDEQ/WQD include “WDEQ’s responsibility in record keeping requirements” and suggested that WDEQ/WQD add a “record keeping requirement that WDEQ maintain records required for permit approval in their system for future reference.”

**Department Response:** WDEQ/WQD applies retention schedules to its records, including records associated with issuing Chapter 3 permits to construct in accordance with Chapter 12. Retention schedules identify the time period for which records must be kept to ensure records are preserved until they have served their intended purpose. Retention schedules are prepared by the Wyoming State Archives in consultation with the WDEQ/WQD; final schedules are approved by the State Records Committee. Because of this process and the need to review and, if needed, update retention schedules periodically, it is not appropriate to include retention schedules within our rules. WDEQ/WQD staff are available to provide more information to interested parties about our retention schedules, and our efforts to improve digital records management to increase the ability to find and access records.

**EPA Region 8:** Region 8 noted that “the proposed Chapter 12 regulations do not require applicants to submit as-constructed record drawings to Wyoming DEQ after a permitted project is constructed...” and requested that WDEQ/WQD “add a citation requiring all permitted construction projects to provide an engineer’s certification to Wyoming DEQ and require the registered professional engineer to provide documentation to Wyoming DEQ that the project was constructed according to the permit requirements.”

**Department Response:** WDEQ/WQD has considered the comment. Water Quality Rules Chapter 3, Section 11(b) identifies the permit application process for as-built drawings. Chapter 12 will remain as written.

**Jason Palmer:** Mr. Palmer requested that this section include a requirement for the “responsible charge” operator’s review (formerly Chief Operator).

**Department Response:** WDEQ/WQD has considered the comment. WDEQ/WQD expects that, as part of the design engineer’s due diligence, the review by the responsible charge operator or public works director will be taken into consideration as part of the submitted design. WDEQ/WQD will leave the requirement as written but

recommends that local governments include this collaboration and coordination of the design engineer in the contract for system design.

### **7(g)**

**Ben Jordan:** Mr. Jordan noted, “Does this section of the draft regulations mean that a new well would be able to be connected to the public water system following submittal of the appropriate data?”

**Department Response:** WDEQ/WQD considered the comment. Section 7(g) through 7(g)(ii)(C) explains that well applications can be permitted as a two-step process. The well can be constructed, developed and tested during the first step. Upon submitting well test and water quality data, the Administrator can authorize the well connection to the system. WDEQ/WQD has revised this paragraph to more clearly describe the process.

### **7(g)(iii)**

**American Council of Engineering Companies of Wyoming:** ACEC commented, “...there could be a considerable amount of time necessary between when the construction contract is awarded to the general contractor and the time that construction could start, given the need for a second DEQ permit to construct being issued. Assuming that DEQ is allowed up to 60 days to review each application, this could substantially slow down the schedule for actual construction.”

**Department Response:** The two-step permitting process described in Section 7 is WDEQ/WQD’s codification of a current practice that we use for the permitting of tanks that are funded through the Wyoming Water Development Office (WDO). For these projects, the foundation and geologic information are not yet available when the applicant initially seeks a permit to construct so that they may go out to bid. The purpose of including this information in the rule is to inform design engineers and their clients of what they can expect from WDEQ/WQD for WDO-funded projects.

### **7(g)(iii)**

**Frank Page:** Mr. Page commented that “...The “Final” plans may not be specific for the actual tank and tank appurtances, as most Public Works projects are competitive bid projects with “Approved Equal” provisions...Is the intent to have the proposed contractor/fabricator supplied “Shop Drawings” be submitted for review, rather than the Bid Set submitted for review? It is suggested the narrative be clarified to include ‘Specific Manufacturer/Supplier Final Engineering Shop Drawings, Specifications, Calculations’ be submitted to WYDEQ and USEPA Region 8 for review and approval, prior to the design engineer’s approval of the shop drawings.”

Mr. Page also noted that “ coordination within WYDEQ, and between WYDEQ and USEPA – Region 8 could be improved...There is a disjoint between the permit process and the final constructed project. Many of the issues of concern that are noted in the Sanitary Sewer reports could be addressed, efficiently and more economically at the permit stage, before fabrication and construction. Retrofitting a storage facility after project completion is expensive and should be avoided if possible.” Mr. Page requested “a joint review of permit applications and inspections by both agencies at the same time, and joint inspections, prior to approval of the “Permit-to-Construct”; or “USEPA convey primacy and provide funding and support to WYDEQ to handle public water system regulatory role.”

**Department Response:** WDEQ/WQD has considered the comment. The proposed process is intended to allow flexibility for projects with bidding constraints and does not specifically pertain to our USEPA interaction. WDEQ/WQD is aware that final plans for tanks and wells are not always available until after the bidding process is complete, which is why we are proposing a process to allow a secondary submittal of these details for Administrator approval. At this time, WDEQ/WQD does not intend to request primacy and related funding for the drinking water program. WDEQ/WQD is committed to working with USEPA on a case-by-case basis and does not believe that revisions to Chapter 12 are warranted to address our partnership.

## Section 8

### 8(c)(i)

**Darwin Dyck, Tetra Tech:** With respect to the requirement that transmission and distribution lines project plan views include “existing locations of utilities”, Mr. Dyck recommended that this Ch.12 Revision adopt the ASCE Standard 38-02, Guideline for the Collection and Depiction of Existing Subsurface Utility Data.

**Department Response:** WDEQ/WQD has considered the comment. The intent of the passage is to ensure that the existence and locations of all subsurface utilities are included in a project plan set. WDEQ/WQD does not agree that it is necessary to add an extra layer of formatting requirements as long as the necessary information is discernable and defined within the plan views.

**Frank Page:** Mr. Page commented, “Providing elevations on ALL appurtenances, is a high standard, that would increase costs and clutter drawing. Elevations should be included for low, high and some intermediate points but are not necessary on all appurtenances. The design engineer and the WYDEQ reviewing engineer should have discretion on this requirement.”

**Department Response:** WDEQ/WQD has revised the passage to “Pertinent elevations shall be indicated on all appurtenances.”

### 8(c)(ii)

**American Council of Engineering Companies of Wyoming:** ACEC requested that WDEQ/WQD provide a definition of size when a profile is required and a more concise definition of what lines need to be profiled as opposed to “all water lines”.

**Department Response:** WDEQ/WQD has considered the comment. The information noted in the comment is typically necessary to build and complete projects. WDEQ/WQD typically requests information that is already available. WDEQ/WQD proposes to leave the passage as-is to maintain flexibility but welcomes discussion of this passage for specific projects if the concern arises.

### 8(e)(i)

**Darwin Dyck, Tetra Tech:** Mr. Dyck recommended adding to the list of requirements under paragraphs (e) and (f) “Identification of existing subsurface utilities [in accordance with Subsurface Utility Engineering standard ASCE 38-02, Standard Guideline for the Collection and Depiction of Existing Subsurface Utility Data].”

**Department Response:** WDEQ/WQD has considered the suggestion. The design engineer is responsible for researching this information, which is regulated by the Wyoming Public Service Commission as part of the due diligence of the design. The proposed standard ASCE 38-02 falls outside of the regulatory authority of WDEQ/WQD and is better suited to adoption by local governments. The requirement will remain as written.

### 8(e)-8(e)(xii)(H)

**Ben Jordan:** Mr. Jordan requested that, “This section should be revised and physical constraints of legible drawings be considered” since “Much of the requested information belongs in the engineering design report and in drawings or specifications.”

**Department Response:** WDEQ/WQD considered the comment. This is an existing requirement in WQR Chapter 12 Section 7, Plans and Specifications, that conforms to the Ten States Standards. In both the current version of and proposed revision to Chapter 12, there are two sections pertinent to the submission of project design deliverables: Plans and Specifications and Engineering Design Report. The proposed revision of Chapter 12, Section 8 for Plans and Specifications is written to explicitly state informational requirements for any technical documents that will be submitted. The proposed revision of Chapter 12, Section 9 for Engineering Design Report provides for the compositional requirements of the report itself as well as additional details on the requisite information. WDEQ/WQD acknowledges that there is some conceptual overlap and has revised paragraph 8(e) to remove “drawings” for clarity.



## Section 9

### 9(a)

**Ty Ross:** Mr. Ross commented, “(1.1.1.15) Wrong reference #, and why not just specify parts 1.1.15-1.1.17? The specific surface and ground water subsections are included generally under 1.1.7 – why call them out specifically?”

**Department Response:** WDEQ/WQD has considered the comment. WDEQ/WQD has corrected the reference to 1.1.15. WDEQ/WQD is not proposing to incorporate 1.1.7.2(h) so 1.1.7.1 and 1.1.7.2(a-g) will remain. WDEQ/WQD has revised the passage to “ 1.1.1-1.1.2, 1.1.4-1.1.6, 1.1.7.1-1.1.7.2(a-g), 1.1.8-1.1.10, 1.1.15-1.1.17, Engineer’s Report.”

### 9(b)(iv)

**Dayton Alsaker:** Mr. Alsaker commented that a design engineer may not necessarily know about all the services that are to be connected to a new water line, that “this comes later by the system owner through their cross-connection control program, by the person designated to conduct this evaluation.”

**Department Response:** WDEQ/WQD revised the passage to the following: “A determination of the degree of hazard of all known or anticipated water service connections to be connected to the proposed project. A hazard classification shall be identified for each connection and recommended mitigation measures shall be described for each hazard.”

### 9(e)(ii)(A)

**EPA Region 8:** Region 8 suggested “increasing the sample frequency for some water quality parameters that are expected to be highly variable (examples include turbidity, TOC / DOC, and UV transmittance).”

**Department Response:** WDEQ/WQD has considered the comment. Paragraph (B) states “the data shall be sufficient for the Division to determine that the processes safely and reliably comply with water quality standards required by 40 CFR Part 141.” When combined with paragraph (B), the sampling frequency is flexible so that WDEQ/WQD may require additional sampling as needed. The passage will remain as written.

### 9(f)(iii)

**Ben Jordan:** Mr. Jordan noted, “The term “aquifer” is not defined in Chapter 12; therefore, it is not clear when a pre-application meeting will be required.

**Department Response:** WDEQ/WQD considered the comment. WDEQ/WQD does not have the statutory authority to define “aquifer” for the purposes of withdrawing water. The right to extract water from the proposed wells is governed by the State Engineer’s Office and applicants are subject to W.S. 41-3-901, which identifies an aquifer as “any underground geological structure or formation having boundaries that may be ascertained or reasonably inferred, in which water stands, flows or percolates.” For the purposes of Chapter 12, applicants will be expected to provide documentation of information that is consistent with the documentation they submit to the State Engineer’s Office.

If an applicant is proposing to install a well for the purposes of drawing water for a public water supply, Chapter 12, Section 9(f)(iii) requires a pre-meeting when the application indicates the proposed well will be drilled through multiple aquifers. If the applicant is proposing to drill their proposed well through multiple “underground geological structures or formations having boundaries that may be ascertained or reasonably inferred, in which water stands, flows or percolates” then that applicant will need to request a pre-meeting with WDEQ/WQD so that we can discuss the proposed plan and ensure that the applicant understands all of the construction standards they will need to meet so their design and resulting water will comply with the Environmental Quality Act. WDEQ/WQD will not add a definition as requested.

#### 9(g)(ii)

**Ben Jordan:** Mr. Jordan noted, “Many downhole video cameras do not have sound recording capacity or the sound is not readily heard. Furthermore, when video logging a well, the videographer and observers often speculate what is being observed and speculations may be erroneous and corrected at a later point in time. Subsequent viewings of video logs in a controlled environment with suitable lighting often result in identification of features not seen in the field. Written descriptions are more accurate than real-time narrative and are adequate for describing the logs. The requirement for a recorded narrative should be removed.

**Department Response:** WDEQ/WQD considered the comment and recognizes that the term “narrated video” may cause confusion. WDEQ/WQD has changed the passage from “a recording of a narrated video” to read, “...a video log of the well inspection accompanied by a written description of the location...”.

#### 9(j)(A)

**Ty Ross:** Mr. Ross commented, “What if looping is proposed simply as a measure of redundancy?”

**Department Response:** WDEQ/WQD has considered the comment. Water main looping projects that are only intended as a measure of redundancy will still require an application to construct or modify. An engineering design report is required for all

applications for permits to construct or modify public water supplies. The section will remain as written.

**Ben Jordan:** Mr. Jordan noted, “Water main upsizing or looping may not be for fire flows. Suggest changing the text to state, “...and maximum day plus fire flows if required or provided will be improved...”

**Department Response:** WDEQ/WQD considered the comment. Section 9(a) of the proposed revision incorporates by reference 2018 TSS section 1.1.6 (a & b), Engineer’s Report - Flow Requirements, in which paragraph (b) states, “fire flows, when fire protection is provided, meeting the recommendations...” If fire flows will not be required or provided by the project, the district engineer may not require it as part of the hydraulic analysis. The passage will remain as written.

#### 9(k)

**Frank Page:** Mr. Page suggested that WDEQ “include criteria on what constitutes a repair versus a remove and replacement, include in definitions.”

**Department Response:** WDEQ/WQD has considered the comment. Water Quality Rules Chapter 3, Section 9(a)(iii) identifies the requirements for modifications. This passage and Section 5 will remain as written.

#### 9(l)

**Frank Page:** Mr. Page commented, “It is suggested to include criteria on what constitutes a new water main, include in definitions.”

**Department Response:** WDEQ/WQD needs additional information and will discuss this item with the commenter before providing a formal response.

#### 9(l) and 9(l)(ii)(A)

**Ben Jordan:** Mr. Jordan noted, “How can a hydraulic model be calibrated on fire hydrant test flow data if the system doesn’t exist? Should line 618 state that this section refers to extension of new mains for existing water systems? Or does there need to be a section (m) that discusses requirements for new public water system distribution systems where hydrant testing is not possible?”

**Department Response:** WDEQ/WQD considered the comment. WDEQ/WQD will revise the passage by adding to 9(l)(ii)(A), “...calibrated based on existing fire hydrant test flow data, when available, or based on modeling;”.

## Section 10

### 10(a)

**Cheyenne BOPU:** Cheyenne BOPU asked, “[When] piping color code does not match existing plant, do modifications/expansions need to meet this color code or existing color code?”

**Department Response:** WDEQ/WQD has considered the comment. 2018 TSS, 2.14 applies to piping color. WDEQ/WQD would expect that the proposed piping color meet the requirements in place at the time of the application for modification per Chapter 3, Section 9(a)(iii). Applicants that are unable to comply with the permitting requirements would need to discuss the options with WDEQ/WQD prior to being granted a permit.

### 10(b)(i)

**Ty Ross:** Mr. Ross commented, “Speak to whether the prescribed #s include some irrigation component, and/or whether irrigation should be considered separately.”

**Department Response:** WDEQ/WQD has considered the comment. The paragraph requires consideration of the maximum daily demand per capita, which includes consideration of lawn/yard irrigation. Consideration of agricultural irrigation is required under 10(b)(I)(B). The passage will remain as written.

### 10(o)

**Cheyenne BOPU:** Cheyenne BOPU recommended adding/adopting NSF61 reference to this section for “clarity and simplification.”

**Department Response:** WDEQ/WQD has considered the comment and has revised the paragraph as requested.

### 10(t)(ii)

**EPA Region 8:** Region 8 suggested “requiring all surface water treatment plants to conduct instantaneous flow monitoring, regardless of maximum daily design flow.”

**Department Response:** WDEQ/WQD has revised the passage to “~~For plants with a maximum daily flow of 50,000 gpd (189 m<sup>3</sup>/d) or more, t~~The meter shall also record the instantaneous flow rate.”

### 10(u)

**EPA Region 8:** Region 8 suggested: “also requiring systems to have a low chlorine residual alarm, where a continuous chlorine analyzer is required (2018 Ten States Standards Section 4.4.3 requires a continuous chlorine analyzer at facilities with a capacity of 0.5 MGD or greater, or that serve a population greater than 3,300, which is appropriate).”

**Department Response:** WDEQ/WQD has removed 2018 TSS 4.4.3 from Section 10(a) and has added 4.4.3(a,b,d) to Section 12(a). WDEQ/WQD has moved the passage from 10(u) to 13(c). At 13(c) WDEQ/WQD has revised the passage to “Chemical application facilities shall include an alarm for high effluent turbidity, low chlorine residual, and chlorine leaks when chlorine gas is used. The alarm shall be located at an attended location.”

**Cheyenne BOPU:** Cheyenne BOPU asked if the “attended location” requires 24/7 attendance?

**Department Response:** WDEQ/WQD has considered the comment. WDEQ/WQD anticipates that some systems include multiple operational shifts and others operate the facility remotely. Chapter 5, Section 15(a)(ii) requires initiation within one hour of “operational and technical actions upon notification” of an alarm. As long as the initiation of a resolution is possible remotely, WDEQ/WQD would not require 24/7 attendance.

## **Section 10(v)**

**EPA Region 8:** Region 8 suggested: “requiring a continuous combined filter effluent turbidimeter, either in lieu of or in addition to the finished water turbidimeter.”

**Department Response:** WDEQ/WQD has revised the passage to “Water treatment plants with a capacity of 500,000 gpd or more shall be provided with continuous finished water turbidimeters (including recorders) that demonstrate compliance with the Guidance Manual for Compliance with the Surface Water Treatment Rules, Turbidity Provisions.

## **Section 11**

**Wyoming Association of Rural Water Systems:** WARWS commented, “We have concerns about legacy private wells. These are wells that were permitted under the SEO Minimum Construction Standards, but do not meet the DEQ construction standards, or setback requirements, but become sources for public water systems as land uses change. There should be some sort of review process and strategy that allows the SEO, EPA and DEQ to communicate with the new PWS on what is expected to put the well into service as a PWS.”

**Department Response:** WDEQ/WQD considered the comment. Chapter 12, Section 11(e)(vii)(F) allows the conversion of private wells to public water supply wells

as long as the application demonstrates that the well will comply with all of the minimum construction standards in the chapter. Chapter 12, Section 9(g) identifies the information that WDEQ/WQD will require in the engineering design report so that we can determine whether the proposed well conversion will comply with Chapter 12. WDEQ/WQD will not permit converted wells that do not demonstrate compliance with the Chapter. As WDEQ/WQD already identifies the permit process for converted wells, the chapter will remain as written. However, WDEQ/WQD will consider this topic as an item to include in our guidance materials that will accompany Chapter 12 upon its promulgation, and we look forward to continuing to work with WARWS on this topic.

### 11(a)

**Cheyenne BOPU:** Cheyenne BOPU asked if the list of succeeding sections from the 2018 TSS, "...3.2.7, well pumps, discharge piping, and appurtenances; 3.2.7.3, discharge piping; 3.2.7.4, pitless well units; 3.2.7.6, casing vent requirements; 3.2.7.7, water level measurement; and 3.2.7.8, observation wells, are herein incorporated by reference," means that 2018 TSS sections "3.2.7.1, 3.2.7.2, and 3.2.7.5" do not apply?

**Department Response:** 2018 TSS sections 3.2.7.1, 3.2.7.2, and 3.2.7.5 are not in paragraph (a); therefore, they are not incorporated by reference.

**Ty Ross:** Mr. Ross commented, "This extensive cross reference will breed confusion."

**Department Response:** WDEQ/WQD has considered the comment. Paragraph (a) contains the incorporated material that is pertinent to source development. As this topic is complex, and WDEQ is not proposing to adopt all of 2018 TSS Part 3, it is necessary to individually identify the sections of the 2018 TSS that are incorporated. The passage will remain as written.

**Ben Jordan:** Mr. Jordan noted, "Comparison of sections of 2018 TSS with the proposed Chapter 12 regulations for determining conflicts is onerous and difficult. There are multiple conflicts in the requirements between the two documents that will be hard to resolve. There are also requirements of 2018 TSS that will not work for some well designs used in Wyoming and open hole well requirements are not addressed.

**Department Response:** WDEQ/WQD needs additional information and will discuss this item with the commenter before providing a formal response.

### 11(e)

**EPA Region 8:** Region 8 suggested that WDEQ/WQD "add language requiring all groundwater sources to provide a raw water sample tap that represents the water quality for the individual groundwater sources, which may include wells, springs or infiltration galleries."

**Department Response:** WDEQ/WQD has considered the comment. Section 10(a) incorporates 2018 TSS 2.10, which identifies requirements for sample taps. Additionally, at 11(e)(xxx) WDEQ/WQD proposes to revise Chapter 12 to the following language:

11(e)(xxx): Designs for groundwater sources that are subject to 40 CFR 141.402(a)(1)(i) and either 40 CFR 141.402(a)(1)(ii) or 40 CFR 141.402(a)(1)(iii) shall demonstrate compliance with 40 CFR 141.402(e).

Other states, such as Washington and New Jersey, do not explicitly require the sample tap via rules but tie it to the federal requirement guidance. WDEQ/WQD proposes to handle the requirement in a similar manner and will direct applicants to the upcoming Region 8 guidance that ties the federal requirement to the sample tap.

### **11(e)(i)**

**Ben Jordan:** Mr. Jordan noted, “2018 TSS Part 3.2.1.1 does not agree with the requirements of Lines 890 to 892.

**Department Response:** WDEQ/WQD has removed the reference to 3.2.1.1 in Section 11(a).

**Ben Jordan:** Mr. Jordan noted, “The requirements of this section, as compared to the current Chapter 12 regulations, will pose a challenge for small water systems i.e. rest areas, campgrounds, visitors centers, rural stores, that can be shut down if a well is out of service, especially with the removal of sections of Chapter 12 allowing hydropneumatic tanks. The economic impact of requiring two wells meeting maximum daily demand or installation of storage meeting twice the maximum daily demand will be significant. This will also potentially lead to issues meeting disinfection by-product requirements, water aging requirements, etc.

**Department Response:** WDEQ/WQD considered the comment. The proposed requirement is an existing requirement of the current Chapter 12. Hydropneumatic tanks are still allowed and are incorporated by reference in the 2018 TSS sections 7.2 through 7.2.4. The section will remain as written.

### **11(e)(ii)(A), Table 1**

**EPA Region 8:** Region 8 suggested that WDEQ/WQD “provide additional guidance either within the regulations or separately. Situations where additional distance may be prudent include where fractured rock, solution channels, or highly transmissive alluvial aquifers are present. Subsurface study, as in (e)(ii)(C), may be of value in these situations as well. Determination of aquifer properties may also help to evaluate their potential use as a water supply.”

**Department Response:** WDEQ/WQD has considered the comment. Applications with geologic concerns such as those noted in the comment are reviewed by

WDEQ/WQD's Groundwater Section in addition to the Water and Wastewater Section design review. The setback requirements in this section are consistent with requirements in Water Quality Rules Chapter 25. Through the permitting process and based on the authorities outlined in Water Quality Rules Chapters 3, 12, and 25, the Administrator has the discretion to require additional conditions, such as a subsurface study, on a case-by-case basis. WDEQ/WQD will not revise the passage and will rely on our existing processes.

**Ty Ross:** Mr. Ross recommended renaming Tables 1 and 2 to Table 11-1 and 11-2.

**Department Response:** WDEQ/WQD will keep the naming convention for tables that is consistent with other Water Quality Rules. The table titles will remain as written.

#### 11(e)(iii)

**Ben Jordan:** Mr. Jordan noted, "Power line clearance requirements or overhead equipment vary by voltage per OSHA requirements. Setting a 10-foot clearance requirement may not be suitably protective.

**Department Response:** WDEQ/WQD considered the comment and recognizes that there are numerous different minimum safety distances for operating or constructing near power lines between federal, state, and industry regulations. WDEQ/WQD has revised the section by removing electrical safety offsets because operators and personnel are still required to adhere to all federal, state, or jurisdiction authority safety guidelines.

#### 11(e)(iii)(B)

**Ben Jordan:** Mr. Jordan noted, "It is not clear what is meant by "casing" that will be pulled. Should this be pump column pipe?"

**Department Response:** WDEQ/WQD considered the comment. The passage begins by describing the subject as, "the top of the casing and any other well opening." Its intention is to require that the well is fully accessible within the structure for maintenance, repairs, or column pipe or pump removal. However, WDEQ/WQD will revise the passage to, "Wells located in a structure shall be accessible to pull the casing, pipe, or pump."

#### 11(e)(iv)

**Ben Jordan:** Mr. Jordan recommended rewording the passage to "Testing and records maintained for water wells shall be as follows:"

**Ty Ross:** Mr. Ross recommended revising the passage to "Systems employing wells..."



**Department Response:** WDEQ/WQD has revised the passage to “Applicants for wells shall complete testing and maintain records as follows.”

#### **11(e)(iv)(A)**

**Ben Jordan:** Mr. Jordan noted, “The term “stabilized drawdown” should be replaced with text that clarifies the intent. Water and Wastewater district engineers have different interpretations of the term and it should be consistent. Consideration should also be given to design based on the results of longer testing, such as 7 days. For instance, if a well is pumped at 100 gpm for seven days then that data is more meaningful than a well pumped at 150 gpm for one day for determining the design pumping rate.

**Department Response:** WDEQ/WQD needs additional information and will discuss this item with the commenter before providing a formal response.

#### **11(e)(vii)(B)**

**Ty Ross:** Mr. Ross recommended revising the passage to “wells that employ a concrete apron.”

**Ben Jordan:** Mr. Jordan noted, “ What is the reference to Chapter 26? A review of Chapter 26 found no clear relevance. Having to cross reference multiple chapters is onerous, prone to confusion, especially when chapters are updated, and can contribute to mistakes. Consider removing the reference and include any needed text from Chapter 26 into Chapter 12 to prevent issues.

**Department Response:** **Department Response:** WDEQ/WQD has considered the comment. WDEQ/WQD has confirmed that EPA no longer requires the concrete apron as part of the sanitary survey process. WDEQ/WQD has revised the passage to include the specific reference to Chapter 26, Section 8, which pertains to casing requirements. As the passages in Chapter 26, Section 8 cover several pages, WDEQ/WQD will not restate the information from Chapter 26.

WDEQ/WQD has revised the passage as follows, “~~d~~Drilled, driven, jetted, or bored wells shall have an unperforated casing that extends from a minimum of 12 inches above the concrete surface ~~for concrete~~ and 18 inches above natural ground surface. The design shall demonstrate compliance with Water Quality Rules, Chapter 26, Section 8.”

#### **11(e)(vii)(C)**

**Ben Jordan:** Mr. Jordan noted, “The term “gravel pack” should not be used. Gravel is rarely, if ever, appropriate for use in construction of public water supply wells and implies that it is acceptable. Filter pack is a more appropriate term.”

**Department Response:** WDEQ/WQD considered the comment and recognizes that the term “gravel pack” may seem outdated considering the usage of synthetic and non-gravel materials for filter packs. However, preliminary search of technical publications shows that the industry terms “filter pack” and “gravel pack” are used interchangeably (though the hyphenated term “gravel-pack” normally refers to the sand component of the engineered commercial filter pack). The 2018 Recommended Standards for Waterworks uses only the term “gravel pack” to refer to filter material that is placed in the annular space between the well screen and hole. The National Groundwater Association Manual of Water Well Construction Practices refers to “artificial filter packs” as being engineered, for formations that lack sufficient coarse-grained materials and appropriate grading, from selected materials of prescribed grain sizes based on formation material sample sieve analyses. US Geological Survey publications and well-performance studies also use both terms interchangeably and refer to gravel and sand as being primary materials for filter packs.

Filter materials can be gravel and sand or alternative materials such as resin-coated sand, garnet, glass beads, and aluminum oxides. Commercial artificial filter packs are commonly made of gravel and/or naturally occurring quartz sand gravel-pack.

In order to prevent confusion on this subject, WDEQ/WQD will revise the passage to “In gravel-packed or artificial filter-packed wells, aquifers containing inferior quality water shall be sealed by pressure grouting, or with special packers or seals, to prevent such water from moving vertically in gravel or filter-packed portions of the well. Gravel/filter-packed wells shall meet the following...”

#### **11(e)(vii)(C)(I)**

**Ben Jordan:** Mr. Jordan noted, “Installation of cement in the top 10 feet of the borehole where there is no surface casing is problematic with wells using pitless units. A large excavation is required for installation of the pitless unit, electric lines, and the discharge piping. Filling the resultant void will result in considerable costs that are unnecessary and also will cause problems in removing large amounts of concrete or grout if and when work is required on any of the infrastructure. The annular seal beneath the pitless unit should be relied upon for protection of the water source.

**Department Response:** WDEQ/WQD needs additional information and will discuss this item with the commenter before providing a formal response.

#### **11(e)(vii)(C)(II)**

**Ben Jordan:** Mr. Jordan noted, “What is the justification for using at least 10 feet of surface casing? The seal for the production casing should extend to just above the top of the

production zone for a screened well and into a confined open hole well. The surface casing is used to provide borehole stability during the well drilling and construction process, not to provide an annular seal. As with the comment above, if a pitless unit is installed, then the permanent surface casing will most likely be removed to a depth of 8 feet. Having 2 feet of surface casing left in place with cement between the casings is not something that needs to be regulated.

**Department Response:** WDEQ/WQD needs additional information and will discuss this item with the commenter before providing a formal response.

#### **11(e)(vii)(D)**

**Ben Jordan:** Mr. Jordan noted, “The requirement of extending the casing into the confining layer “overlying” the water-bearing zone and sealing with grout is problematic. In many geologic settings the confining layer overlying the production zone is comprised of shale which is not competent and if left open will result in sloughing and production of solids and turbid water. The requirement is also in conflict with the requirement of the State Engineer’s Office of setting the production casing at least 10 feet into the target aquifer and cementing the casing in place. Consideration should be given to rewrite this section to avoid issues.

**Department Response:** WDEQ/WQD needs additional information and will discuss this item with the commenter before providing a formal response.

#### **11(e)(viii)**

**Ben Jordan:** Mr. Jordan noted, “What is the purpose of the “required size to allow for sampling”? This language seems out of place.

**Department Response:** WDEQ/WQD considered the comment. The passage indicates that the casing size needs to allow for the equipment associated with sampling. The passage will remain as written.

#### **11(e)(ix)(A)**

**Ben Jordan:** Mr. Jordan noted, “Some packers, such as liner-hanger-packers that are used in both oil field and deeper water wells use seals that are mechanical metal-on-metal or mechanical that use seals that are not neoprene but are NSF 61 certified. Suggest that this section state that packers with neoprene or other NSF 61 certified materials shall be installed to.....

**Department Response:** WDEQ/WQD has edited the passage to the following: “Neoprene or other NSF 61 certified material packers shall be installed to seal the annular space between casings to prevent the migration of mineralized, polluted, or otherwise inferior quality water.”

### 11(e)(xii)

**Ty Ross:** Mr. Ross commented, “If employed.”

**Ben Jordan:** Mr. Jordan noted, “This requirement indicates that the well casing is to extend up a particular distance above a finished floor or concrete apron. The use of concrete aprons around wells is generally unnecessary and counterproductive. EPA no longer requires them for public water supply wells. Concrete aprons are not needed because the annular space seal must already be protective of the well and a properly contoured ground surface will direct surface water drainage away from the wellhead. Concrete aprons will move with frost conditions and quite often result in electrical conduit seal failure, even when using expansion fittings, exposing the well to significant risk of contamination. I have observed many well completions with failed conduits from frost action with dirt, insects, and even rodents in the wellhead. Concrete aprons provide preferred burrowing sites for rodents which then directs surface water flow back to the wellhead and thus compromises the well integrity. This section should require that the finished grade around the well slope at one inch per foot.

**Department Response:** WDEQ/WQD considered the comments. WDEQ/WQD has confirmed that EPA no longer requires the concrete apron as part of the sanitary survey process and has revised the passage as follows, “Upper terminal well designs that include a concrete floor or apron of an upper terminal well construction for a public water supply well shall demonstrate a slope of one inch per foot away from the casing at a slope of one inch per foot.”

### 11(e)(xiv)

**Ben Jordan:** Mr. Jordan noted, “A submersible pump can have a check valve in the pump column pipe but will not have a foot valve. A foot valve is installed at the bottom of the pipe column for a centrifugal pump on the ground surface.

**Department Response:** WDEQ/WQD considered the comment and removed the term “(foot valve)” from the passage.

### 11(e)(xvii)

**Ben Jordan:** Mr. Jordan noted, “It is agreed that each well needs to have an accurate flow meter to collect production data. The proposed rule suggests having a separate meter capable of measuring the total wellfield discharge, although a strict interpretation of the wording in the sentence indicates total wellfield production must be measured at each well. The range of production from a wellfield will have significant variations in flow conditions that may not be accurately recorded by a single large meter as appears to be intended in this section. A wellfield meter will be expensive and probably provide less accurate and conflicting results when

compared with individual well meters. A wellfield meter will cause most operators frustration, will not be read, and impose unnecessary costs on most public water systems.

**Department Response:** WDEQ/WQD considered the comment. Unless otherwise approved by the Department based on documentation provided by the design engineer, an instantaneous and totalizing flow meter equipped with nonvolatile memory shall be installed on the discharge line of each well in accordance with the manufacturer's specifications. Meters installed on systems with variable frequency drives shall be capable of accurately reading the full range of flow rates.

#### **11(f)**

**EPA Region 8:** Region 8 suggested that "WDEQ's regulations more clearly define sources for ground water development that are not wells, and require source monitoring prior to development to reduce the risk of developing GWUDI or contaminated water. Ideally, "spring" water daylights at ground surface through some artesian pressure produced by a cohesive confining layer such as "hard pans" (caliche, iron deposits), high plastic clays, or competent bedrock. It is important to be able to differentiate competent bedrock from highly fractured bedrock caused by weathering or by structural processes such as tectonic forces. The length, breadth and thickness of the confining layer needs to be determined and considered to ensure that the layer is physically able to protect the water source that will be developed. This will allow for the potential "clean capture" of the water, as the confining layer will protect the aquifer's vertical recharge ability. EPA also recommends that the recharge area should be identified."

**Department Response:** WDEQ/WQD has considered the comment. WDEQ/WQD looks forward to continuing to work with EPA on GWUDI concerns on a case-by-case basis as we do not believe that revisions to Chapter 12 are warranted to address this concern. Following WDEQ/EPA conversations on GWUDI concerns, WDEQ/WQD will consider revising Chapter 12 at a later date if needed.

#### **11(f)(i)**

**Ben Jordan:** Mr. Jordan noted, "Will this rule prohibit developing a spring that issues from a canyon wall, such as Periodic Spring? Or can the development excavate to where at least three feet of cover is provided? It is not clear if the intention of this section is to prohibit the development of groundwater where the spring vent occurs naturally at a depth of more than 3 feet below ground level or if 3 feet of cover is required.

**Department Response:** WDEQ/WQD needs additional information and will discuss this item with the commenter before providing a formal response.

#### **11(f)(ii)**

**Ben Jordan:** Mr. Jordan noted, “There is no (b)(iv) in Section 11 of Chapter 12.

**Department Response:** WDEQ/WQD has corrected the reference to paragraph (e)(ii).

#### 11(f)(iii)

**Ben Jordan:** Mr. Jordan noted, “What is the “spring protection area”? A definition of the term would clarify how far away sources of contamination must be removed.

**Department Response:** WDEQ/WQD considered the comment. The section has been updated to the following at f(ii): “The horizontal setback for spring development shall be no less than the setback distances in e(ii) of this Section. The Administrator may require additional setback distances to prevent contamination from the ground surface of other contamination. This area will be known as the spring protection area.”

#### 11(f)(i)(C)(II)

**Ty Ross:** Mr. Ross commented, “(minimum width) What does this mean? Wall thickness? No plastic spec?”

**Department Response:** WDEQ/WQD has revised the passage as follows: “Made of concrete, with a minimum width or wall thickness of six inches, ~~or plastic~~; and”

#### 11(f)(vi)

**EPA Region 8:** Region 8 commented: “The spring collection site shall be equipped to disinfect water prior to distribution and shall include sampling ports before and after the disinfection application point.” Region 8 suggested that WDEQ/WQD “clarify this sentence to make clear if operational disinfection will be required for spring sources.”

**Department Response:** WDEQ/WQD has considered the comment and has revised the paragraph to “The spring collection site shall be equipped to disinfect water prior to distribution and shall include sampling ports before and after the disinfection application point. The equipment shall be maintained and [available to operate](#) for its intended use.”

## Section 12

**Wyoming Association of Rural Water Systems:** WARWS commented, “We are very pleased to see the membrane section of the 10 State Standards adopted and fully support that section.”

**Department Response:** WDEQ/WQD appreciates WARWS’s support of this revision.

## 12(a)

**Ty Ross:** Mr. Ross commented, “Would it take less room to just add the text of each section?”

**Department Response:** WDEQ/WQD has considered the comment. Incorporating the text verbatim would add a significant number of pages to the chapter. As WDEQ/WQD has determined incorporation of the full text would be “inefficient given the length or nature of the rules,” the passage will remain as written.

## 12(b)(i), 12(j)(j)(a), 12(x)(A)(I), 12 (m))

**EPA Region 8 and Ben Jordan:** Region 8 and Ben Jordan suggested “using units of NTU for all turbidity references...” Region 8 also suggested lowering the maximum allowable feed water turbidity for both slow sand filters and diatomaceous earth filters to 10 NTU.”

**Department Response:** WDEQ/WQD has considered the comment and has revised the Chapter as recommended.

## 12(h)

**Bryan Seppie:** Mr. Seppie commented, “Proprietary treatment systems often incorporate tube settlers. These systems may or may not require routine cleaning beyond normal “blowdowns” - -- thus tube cleaning may only be an annual occurrence. These types of systems would not comply with 12. (h),(iv) as written.”

**Department Response:** WDEQ/WQD considered the comment. The passage requires that cleaning be provided but does not prescribe frequency. The passage will remain as written.

## 12(i)

**Cheyenne BOPU:** Cheyenne BOPU suggested adding “Media Filtration” instead of just “Filtration systems” to clarify that the following subsections do not apply to “membrane filters”.

**Department Response:** WDEQ/WQD has considered the comment. Membrane filters are specifically incorporated in Section 12(a). Each subparagraph under paragraph (i) identifies the applicability of the requirements. The passage will remain as written.

## 12(i)(ii)(F), 12(i)(ii)(J)

**Darwin Dyck, Tetra Tech:** Mr. Dyck requested confirmation of the allowable minimum backwash flowrate, specifically for air-assisted backwash - 12-15 gpm/sqft.

**Department Response:** WDEQ/WQD considered the comment and reviewed the 2018 TSS. Section 12(i)(ii)(F) will remain as written. However, WDEQ/WQD will revise Section 12(i)(ii)(J) to add the minimum flowrate for air-assisted backwash as follows: “The minimum flowrate for air-assisted backwash shall be 12 gpm/ft<sup>2</sup>.”

#### **12(i)(ii)(G)**

**Darwin Dyck, Tetra Tech:** Mr. Dyck suggested that the duration of the backwash waste cycle should be “flexible based on operator input and whether or not air assisted backwash is provided.”

**Department Response:** WDEQ/WQD will leave the section as written because it appropriately conveys the intent, which is that the backwash waste cycle is a facility design and construction requirement. Operator input should be solicited during the design process.

**Cheyenne BOPU:** Cheyenne BOPU commented: “Our existing plant cannot provide this much water in a backwash cycle. What kind of plant modification would require update to meet this criterion?”

**Department Response:** WDEQ/WQD considered the comment. Water Quality Rules Chapter 3, Section 9(a)(iii) identifies the requirements for modifications. WDEQ/WQD will issue a permit to modify the facility that requires the facility to meet the minimum design standards that are in effect when the permit to modify is issued that apply to the modification without altering any other minimum design standards that apply to the facility under its existing permit. WDEQ/WQD will work with permittees as needed to seek compliance with Chapter 12, while to the extent possible, minimizing the burden on permittees when bringing existing facilities into compliance.

#### **12(i)(ii)(H)**

**Cheyenne BOPU:** Cheyenne BOPU commented: “Our backwash water is not disinfected and barely chlorinated. Is this requiring backwash pumps to be located after sufficient contact time? Does this disinfection requirement prevent the use of biofiltration?”

**Department Response:** WDEQ/WQD has considered the comment. The requirement is an existing one that was previously located at Section 10(i)(ii)(B)(IV)(2.). This requirement is specific to filtered and disinfected water and does not affect the location of backwash pumps. The degree of disinfection is not specified and does not prevent the use of biofiltration.

#### **12(i)(ii)(K)**

**Cheyenne BOPU:** Cheyenne BOPU commented: “Our existing plant does not include



surface wash system. What kind of plant modification would require update to meet this criterion?

**Department Response:** WDEQ/WQD has considered the comment. The requirement is an existing one that was previously located at Section 10(i)(ii)(B)(IV)(5.)). Water Quality Rules Chapter 3, Section 9(a)(iii) identifies the requirements for modifications. WDEQ/WQD will issue a permit to modify the facility that requires the facility to meet the minimum design standards that are in effect when the permit to modify is issued that apply to the modification without altering any other minimum design standards that apply to the facility under its existing permit. WDEQ/WQD will work with permittees as needed to seek compliance with Chapter 12, while to the extent possible, minimizing the burden on permittees when bringing existing facilities into compliance.

#### **12(i)(ii)(L)**

**Darwin Dyck, Tetra Tech:** Mr. Dyck suggested that “Automated block and bleed valving system can be provided as an option for backflow prevention if air gap is not available between backwash / filter-to-waste discharge and HWL of the backwash waste storage / holding basin.”

**Department Response:** WDEQ/WQD notes that the design requirement is not intended to explicitly describe specific technologies but does require that applicants take adequate measures to prevent backflow. “Automated block and bleed valves” may be considered adequate technology as determined in the permitting review process. The section will remain as written.

#### **12(i)(vi)(F)**

**Cheyenne BOPU:** Cheyenne BOPU asked, “We have two pumps for 8 filters; does firm yield for plant capacity suffice here?”

**Department Response:** WDEQ/WQD has considered the comment. The requirement is an existing one that was previously located at Section 10(i)(ii)(B)(VII). Water Quality Rules Chapter 3, Section 9(a)(iii) identifies the requirements for modifications. WDEQ/WQD will issue a permit to modify the facility that requires the facility to meet the minimum design standards that are in effect when the permit to modify is issued that apply to the modification without altering any other minimum design standards that apply to the facility under its existing permit. WDEQ/WQD will work with permittees as needed to seek compliance with Chapter 12, while to the extent possible, minimizing the burden on permittees when bringing existing facilities into compliance.

#### **12(i)(viii)**

**Darwin Dyck, Tetra Tech:** Mr. Dyck commented: in reference to the 10-minute minimum for the filter to waste cycle, that the “Duration of filter-to-waste cycle should be flexible and be site specific. Monitoring and low turbidity can be confirmed to end filter-to-waste cycle to minimize waste.”

**Department Response:** WDEQ/WQD considered the comment. While close monitoring by the operator may result in a slightly shorter cycle and slightly less waste, WDEQ/WQD expects that changing the requirement would require additional revisions to the criteria under which an operator may consider the cycle complete. The change would also require additional design requirements for monitoring equipment, which would require their own design parameters and maintenance cycles. The section will remain as written

#### **12(i)(x)(C)**

**Ty Ross:** Mr. Ross commented, “Add a section addressing cartridge filtration.”

**Department Response:** WDEQ/WQD has considered the comment. Paragraph 12(p) outlines the requirements for bag and cartridge filters.

#### **12(j)(i)**

**Cheyenne BOPU:** Cheyenne BOPU suggested adding/adopting NSF61 here.

**Department Response:** WDEQ/WQD revised the passage as requested.

#### **12(j)(i)(B)**

**Darwin Dyck, Tetra Tech:** Mr. Dyck recommended, in reference to the addition of chlorine, that an “inline static mixer” be included as an option because “installation of inline static mixer does not require 10 pipe diameters” (upstream of the discharge).

**Department Response:** WDEQ/WQD has considered the comment and will leave the section as written. This requirement is method-specific regarding the application point of chlorine solution, i.e., “to a pipeline discharging to a clearwell”, and as such it would thereby necessitate application to “center of the pipe at least 10 pipe diameters upstream...” Alternative methods are not prohibited by this section and their effectiveness must be demonstrated to the WDEQ/WQD engineer reviewing the application.

#### **12(j)(ii)(A)**

**EPA Region 8:** Region 8 recommended that WDEQ/WQD “more clearly specify that the contact time requirements in Table 3 are after the baffling factor has been applied to the reactor, not

before. Also consider adding a requirement that all plants treating surface water and GWUDI have the capability to monitor the free chlorine residual using a handheld analyzer with a digital readout (or continuous analyzer, if required based on population served or design flow), water temperature, and pH at locations necessary to evaluate adequate CT and verify that adequate inactivation is being consistently achieved. The pH and temperature can be grab samples in most cases, but the system needs to have the appropriate monitoring equipment to be able to collect and analyze the samples.”

**Department Response:** WDEQ/WQD has considered the comment. Paragraph 12(j)(ii)(A) has been revised to the following: “Filtration types shall comply with the contact time and minimum chlorine residuals required in Table 3 of this Section after the appropriate baffling factor has been applied to the reactor. Contact times assume a baffling factor of 0.1 unless documentation justifying the use of a higher baffling factor is provided.”

WDEQ/WQD has reviewed Section 10(a) and Section 12(a) and has reorganized and edited the references to the 2018 TSS in these paragraphs for clarity. All of 2018 TSS 4.4.3 is now incorporated into Section 12, which addresses the request to require analyzers with digital readouts. Additionally, WDEQ/WQD has moved 2018 TSS 2.9 from Section 10(a) to Section 12(a) to address the request for a requirement for monitoring capability.

To address the concern regarding the use of “should” in the 2018 TSS, WDEQ/WQD has added a paragraph at Section 4(c) to indicate that the term “shall” replaces “should” where it is used in the 2018 TSS. “Shall” is the mandatory term that WDEQ/WQD uses throughout the Water Quality Rules.

## **12(k)**

**EPA Region 8:** Region 8 recommended that WDEQ/WQD specify “which UV requirements apply to all systems, and which are specific to systems using the UV treatment for microbial reduction credit under the Surface Water Treatment Rules or Ground Water Rule.”

**Department Response:** WDEQ/WQD has considered the comment. As WDEQ/WQD will not be evaluating whether systems that choose UV disinfection will qualify for the microbial treatment credits and the qualification will be determined by EPA based on the design engineer’s submittal, the passage will not be revised to differentiate between surface water or other systems. However, to clarify that these systems are not mandatory and that they are a choice for PWSs to make with the advice of their design engineer, we are proposing to revise the passage to “Systems that propose disinfection via ultraviolet light shall comply with the following requirements.”

## **12(k)(i) and 12(k)(i)(B)**

**EPA Region 8:** Region 8 recommended that WDEQ/WQD “include a reference to monitoring the UV Transmittance (UVT) at 254 nm and a 1 cm path length. Include a reference to capturing the range in UV transmittance of the influent water over a 12 month period, and consider requiring a buffer between the minimum validated UVT of the reactor, and the minimum observed UVT. This is particularly important in situations where a system has limited ability to treat the water to increase the UVT.”

**Department Response:** WDEQ/WQD has considered the comment. WDEQ/WQD will not incorporate EPA’s buffer suggestion at this time, as information was not provided to describe conditions for specific buffer values and the specific circumstances that WDEQ/WQD would need to evaluate in order to require the suggested buffer. WDEQ/WQD proposes to revise the passage as follows:

(B) UV Transmittance (UVT) ~~at~~ reported for a wavelength of 254 nm and a pathlength of 1-cm;

(C) A description of the UVT range over a 12-month period;

#### 12(k)(ii)(N)

**EPA Region 8:** Region 8 recommended that WDEQ/WQD remove “the reference to NSF Standard 55 from this section. Refer specifically to NSF Standard 55A for any references to this standard, and only reference it as an option for small UV units (equal to or less than 40 gpm production rate).”

**Department Response:** WDEQ/WQD has considered the comment and has removed the reference to NSF/ANSI Standard 55 as requested.

#### 12(k)(iii)(A)

**EPA Region 8:** Region 8 recommended that WDEQ/WQD provide “a definition for all UV dose terms cited in the regulation for clarity, definitions are included in the EPA UV Disinfection Guidance Manual. Suggest changing the reference to RED at line 1600 to “a validated dose that meets or exceeds the required dose” and line 1603 to “minimum required validated dose used for system design”. Suggest changing the reference to RED in line 1623 to “validated dose that meets or exceeds the required dose”.”

**Department Response:** WDEQ/WQD has considered the comment. WDEQ/WQD has added the terms “reduction equivalent dose,” “required dose,” “validated dose,” and “calculated dose” to Section 5. WDEQ/WQD proposes to revise passages at Section 12(k)(iii) as follows:

(iii) Ultraviolet treatment systems shall ~~be designed to comply~~ demonstrate compliance with UV Disinfection Guidance Manual for the Final LT2ESWTR and the

following dose requirements:

(A) The UV disinfection system shall deliver ~~the Reduced Equivalent Dose (RED)~~ a validated dose that meets or exceeds the required dose at the end of lamp life, with fouled sleeves.

(B) The ~~RED~~ minimum required validated dose used for system design shall incorporate a Combined Age and Fouling Factor (CAF), calculated as

(E) The ~~RED~~ validated dose that meets or exceeds the required dose shall be delivered under maximum flow and design (UVT) condition, with the larger UV unit out of service.

#### **12(k)(iv)(B)**

**EPA Region 8:** Region 8 recommended that WDEQ/WQD allow “certification to NSF Standard 55A (for small UV units, less than or equal to 40 gpm) or the DVGW or ONORM standards. If NSF Standard 55A is allowed, consider including specific requirements for use of a reactor that has the NSF55A certification only (i.e. lamp age counter/ alarm, automatic fail safe solenoid valve that shuts off flow when power is lost or dose is low, etc).”

**Department Response:** WDEQ/WQD has considered the comment. Per our additional discussion with EPA, the passage will state “The bioassay testing and results shall demonstrate validation by an independent third party in full compliance with the U.S. EPA’s Ultraviolet Disinfection Guidance Manual.”

#### **12(k)(v)(C)(I)**

**Darwin Dyck, Tetra Tech:** Mr. Dyck commented: “Do not understand the reference to manufacturer's guidelines for electromagnetic or other flowmeter installation in regards to UV reactors. Flow conditioning vanes and shorter straight pipe diameters should be permitted if allowed by UV reactor manufacturer.”

**Department Response:** WDEQ/WQD disagrees that this passage could cause confusion because it is consistent with the 2018 TSS. Different manufacturers may have different requirements and “flow conditioning vanes” with shorter straight pipes may be acceptable to the approving engineer provided they can be demonstrated to achieve the same result. The requirement is only one of three options allowed by paragraph 12(k)(v)(C) for ultraviolet piping configurations and it does not preclude the use of other technologies. The passage will remain as written.

#### **12(k)(vi)(B)**

**EPA Region 8:** Region 8 recommended that WDEQ/WQD only require “UV transmittance

monitoring for systems that use the calculated dose monitoring strategy. EPA Region 8 has not required systems to monitor the UV transmittance for the intensity set point dose monitoring strategy, or for small reactors that are certified to the NSF 55A standard. UV feed water monitoring conducted prior to UV unit installation must indicate that the range of UV transmittance values in the UV feed water are within the validated operation range of the reactor (with a buffer between the two values recommended).”

**Department Response:** WDEQ/WQD has considered the comment and has revised the passage to “For systems that use the calculated dose monitoring strategy, each reactor shall be capable of measuring or calculating the UV transmittance;”

### 12(m)(iii)

**Darwin Dyck, Tetra Tech, EPA Region 8, and Bryan Seppie:** The commenters noted the proposed minimum applied feed rate of ozone of 15 mg/L is too high and may cause additional problems such as formation of DBPs and excessive bromate.

**Department Response:** WDEQ/WQD has considered the comments and has revised the passage to “If ozone is used for taste and odor control, there shall be at least ~~30~~ 10 minutes of contact time to complete all reactions- and the minimum applied feed rate of ozone shall be 15 mg/L, or the design shall identify a contact time and feed rate that demonstrate the application of ozone will not cause an exceedance of the maximum contaminant levels identified at 40 CFR 143.3.”

### 12(o)

**EPA Region 8:** Region 8 recommended that WDEQ/WQD “consider incorporating the NSF 419 standard for membrane filtration requirements.”

**Department Response:** WDEQ/WQD has considered the comment. As the paragraph already incorporates the requirements of the Membrane Filtration Guidance Manual, incorporating the NSF 419 standard into the paragraph would be duplicative. The passage will remain as written.

### 12(o)(i)

**Ty Ross:** Mr. Ross commented, “Who publishes this manual and where do you get it?”

**Department Response:** WDEQ/WQD has considered the comment. All of the details for materials that are incorporated by reference into Chapter 12 are listed in Section 19. For the Membrane Filtration Guidance Manual, the United States Environmental Protection Agency is the author, and the direct link to the online document is included in the Section 19 details. Additionally, all referenced materials are available for inspection at the WDEQ Cheyenne Office.

### 12(p)(i)(B)

**EPA Region 8:** Region 8 recommended that WDEQ/WQD “change the reference to require demonstration of at least a 3-log removal of particles size 1 micron and above with an associated log reduction credit of 2-logs for Giardia and Cryptosporidium.”

**Department Response:** WDEQ/WQD has considered the comment. Per our additional conversation the passage will state “The filter shall demonstrate at least a ~~2-~~ 3-log removal of particle size 1 micron and above with an associated log reduction credit of 2-logs for Giardia and Cryptosporidium;”

### 12(p)(i)(C)

**EPA Region 8:** Region 8 recommended that WDEQ/WQD “change the challenge testing requirements reference in this section to the LT2ESWTR Toolbox Guidance Manual, Chapter 8. Also consider adopting the NSF 419 standard for bag and cartridge filter challenge testing requirements.”

**Department Response:** WDEQ/WQD has considered the comment and has revised the paragraph as suggested to “Removal efficiency shall be determined through challenge testing as outlined in ~~Membrane Filtration Guidance Manual, Chapter 3~~ Toolbox Guidance Manual, Chapter 8 and NSF/ANSI 419” and has added the LT2ESWTR Toolbox Guidance Manual to the incorporated materials list in Section 19.

### 12(p)(iii)

**EPA Region 8:** Region 8 recommended that WDEQ/WQD “remove the NSF 53 reference and change it to NSF 419 and/or the EPA LT2ESWTR Toolbox Guidance Manual, Chapter 8.”

**Department Response:** WDEQ/WQD has considered the comment and has revised the paragraph to “Filter and housing specifications shall include a description of the materials of construction, surface area per filter, and the minimum and maximum operating pressure, and shall be evaluated under NSF/ANSI 53 meet the requirements of NSF 419 and the Toolbox Guidance Manual, Chapter 8.”

### 12(p)(viii)

**EPA Region 8:** Region 8 recommended that WDEQ/WQD “increase the disinfection treatment requirement for bag and cartridge filtration to 1.0 log Giardia.”

**Department Response:** WDEQ/WQD has considered the comment and has revised the passage to “All surface water or GWUDI systems using bag or cartridge filter technology shall provide at minimum disinfection that meets 4.0-Log virus inactivation

and ~~0.5~~ 1.0-Log Giardia inactivation or shall demonstrate that combined filtration and disinfection will provide 3-log removal.”

## 12(r)

**Darwin Dyck, Tetra Tech:** Mr. Dyck recommended adding an “initial paragraph to cover handling and disposal of typical process waste to include filter backwash waste, filter flushing cycles, filter-to-waste and clean-in-place MF/UF waste. Require backwash waste basin / holding tank where discharging to a sanitary sewer. Also include reference to EPA Filter Backwash Recycle Rule and limitations of recycle flow - 10% of treatment capacity.”

**Department Response:** WDEQ/WQD considered the comment and the section will remain as written. WQD does not feel it is necessary to make additional requirements on specific wastes because it may not be applicable to all types of facilities and applications.

## 12(r)

**Bryan Seppie:** Mr. Seppie commented, “Section 9.3,b of the TSS has not been included by reference. Without the inclusion of 9.3,b, the proposed Chapter 12 rules do not address land application of dewatered sludge except for the liquid lime softening sludge (see (r)(iv)).

Alum Sludge is specifically addressed in subsection (s) but sludge from ferric sulfate or ferric chloride is not. Consider including TSS section 9.3 b, it is an appropriate method to be considered: dependent onsite specific conditions.”

**Department Response:** WDEQ/WQD considered the comment. 2018 TSS Section 9.3(b) applies to sludges that are generated out of the precipitative softening process and overlaps with the passage at 12(r)(iii)(D), which covers mechanical dewatering of sludge. WDEQ/WQD proposes to incorporate 9.5 through 9.5.3, which covers iron or red water wastes. Additionally, WDEQ/WQD has reorganized paragraphs (r) and (s) for clarity.

## 12(r)(ii)

**Ty Ross:** Mr. Ross commented, “and/or is applicable.”

**Department Response:** WDEQ/WQD has considered the comment. Statements that include both “and” and “or” may potentially be unclear and may lead to difficulties in enforcement. WDEQ/WQD purposely clarified the passage to eliminate these difficulties. The passage will remain as written.

## 12(r)(iv-v)



**Ty Ross:** Mr. Ross commented, “may be employed.”

**Department Response:** WDEQ/WQD has considered the comment. WDEQ/WQD has reorganized the paragraph and the suggested edit no longer applies.

**12(s)**

**Cheyenne BOPU:** Cheyenne BOPU asked, “What about ferric sludge?”

**Department Response:** WDEQ/WQD has considered the comment. Ferric waste, or waste filter wash water from iron and manganese removal plants is described in the incorporated 2018 TSS at part 9.5.

**12, Table 3**

**Ty Ross:** Mr. Ross commented, “Table 12-1? Provide the flexibility for the designer to calculate project specific, requ’d CT.”

**Department Response:** WDEQ/WQD has considered the comment. WDEQ/WQD will keep the naming convention for tables that is consistent with other Water Quality Rules. The table title will remain as written. Paragraph (A) allows for flexibility of the baffling factor and contact time if documentation is provided in the permit application.

## **Section 14**

**14(d)(iii)**

**Bryan Seppie:** Mr. Seppie commented that “six air changes an hour is excessive in a pump station where sensitive electrical gear is in a segregated/isolated room. Consider allowing exceptions where applicable.”

**Department Response:** WDEQ/WQD considered the comment. The passage is required by the current version of Chapter 12 and is consistent with EPA’s Wastewater Technology Fact Sheet, In-Plant Pump Stations, EPA 832-F-00-069 September 2000 and regulations from neighboring states. The passage will remain as written.

**14(g)(iii)**

**Darwin Dyck, Tetra Tech:** Mr. Dyck recommended identifying and adding “surge anticipation valves” as acceptable means for surge control.

**Dayton Alsaker:** Mr. Alsaker commented, “For smaller pumps surge control may not always [be] required. Is this saying surge control is always to be provided and that pressure relief valves are not acceptable even with smaller pump stations? I don’t agree with either of these requirements.”

**Bryan Seppie:** Mr. Seppie commented, “Pump and pipeline design must consider surge. Pressure relief valves may provide the appropriate level of protection for some designs. Categorically excluding relief valves should be reconsidered.”

**Department Response:** WDEQ/WQD considered the comment. The purpose of the section is to: 1) require that surge control methods shall be employed, and 2) state explicitly that “pressure relief valves” are not acceptable. WDEQ/WQD does not intend to include specific technologies as options. Other methods such as “surge anticipation valves” may be acceptable provided that their adequacy can be demonstrated to the approving engineer.

Due to the pressure and liquid volume with pipelines, the best practice is to use surge tanks and absorbers to prevent the expelling of liquid into the atmosphere. WDEQ/WQD proposes to revise the passage, without changing the exclusion of relief valves as surge control, to “A surge analysis shall be provided to demonstrate if surge control protection devices shall will be provided needed to protect the piping. Pressure relief valves are not acceptable as surge control.”

#### 14(h)

**Dayton Alsaker:** Mr. Alsaker asked if booster pumps are defined? “It appears this applies to a booster pump installed in a service line, but this should be clarified.”

**Department Response:** WDEQ/WQD considered the comment. Booster pumps are not defined as the term is self-defining. In the subsequent sections, booster pumps are referred to and regulated under various scenarios and “service-line” booster pumps are not explicitly prohibited. The passage will remain as written.

#### 14(h)(v)

**Jason Palmer:** Mr. Palmer asked if this requirement for home booster pumps only affects new construction?

**Andy Hooten:** Mr. Hooten commented: “It is suspected that these exist on private residence's service lines in the area and might be needed in the future depending on future development near the maximum water supply elevation of the system. How are we to proceed? Can these be allowed with proper backflow prevention inside a residential dwelling, or trigger a low hazard rating rather than a B (I)? How are these to be prevented as individual homeowners or contractors may not consult WDEQ standards prior to installation?”

**Department Response:** This is an existing passage that was formerly located at Section 12(o) that applies to any new or modified construction. Individual residence

booster pumps are prohibited; however, booster pumps on water mains that service an area/subdivision with low pressure are allowed. WDEQ/WQD will work with individual communities on a case-by-case basis to address individual residences as needed.

#### **14(i)(i)**

**EPA Region 8:** Region 8 recommended that WDEQ/WQD include “a reference to the discharge pipe requirements for air release / vacuum relief valves on finished water lines that requires 1) an 8 inch minimum air gap and 2) #24 mesh at the discharge...”

**Department Response:** WDEQ/WQD has considered the comment and has revised the paragraph as follows: “Air release valves shall be provided where the pipe crown is dropped in elevation. The discharge pipe from the valve shall have a minimum of an 8-inch air gap and shall be covered with a #24 mesh non-corrodible screen.”

#### **14(i)(ii)**

**Ty Ross:** Mr. Ross circled a stricken “be.”

**Department Response:** WDEQ/WQD has revised the passage to “Each pump shall either have an individual suction line or shall have multiple suction lines that demonstrate similar hydraulic and operating conditions.”

### **Section 15**

**Frank Page:** Mr. Page commented, “The revised standard has removed minimal criteria from the WYDEQ Chapter 12 text and incorporates by reference the 2018 TSS criteria. This will require having to review both sets of regulations. This will likely cause confusion and may prove to be cumbersome. It is suggested that WY coordinate with USEPA Region 8, the 2018 TSS and provide minimum acceptable criteria to be used on Wyoming projects for water. Chapter 12 should also allow discretion the design engineer and the WYDEQ reviewing engineer for the use of professional judgement when needed.”

**Department Response:** WDEQ/WQD has considered the comment. WDEQ/WQD chose to propose the incorporation of the Recommended Standards for Water Works, 2018 Edition (2018 TSS) in accordance with Wyoming Statute (W.S.) § 16-3-103(h) as we have determined that “incorporation of the full text in agency rules would be cumbersome or inefficient given the length or nature of the rules.” WDEQ/WQD chose to incorporate portions of the Ten States Standards and not all of the standards as we realized that some tailoring is necessary. WDEQ/WQD has incorporated the Ten States standards into the rule in a manner that complies with the Wyoming Administrative Procedures Act at W.S. § 16-3-103(h)(ii). The proposed revisions are the minimum standards for the design and construction of public water supplies. While WDEQ/WQD understands that circumstances may arise that require design

engineer and WDEQ discretion, WDEQ/WQD will work with a permittees to seek compliance with Chapter 12 and while not adding an undue burden on a permittee

## **Section 15**

### **15(a)**

**Cheyenne BOPU:** Cheyenne BOPU commented that the 2018 TSS section 7.0.2, Location of finished water storage structures, seems “very restrictive”. “Our existing tanks do not meet this design criterion.”

**Department Response:** WDEQ/WQD considered the comment. Water Quality Rules Chapter 3, Section 9(a)(iii) identifies the requirements for modifications. WDEQ/WQD will issue a permit to modify the facility that requires the facility to meet the minimum design standards that are in effect when the permit to modify is issued that apply to the modification without altering any other minimum design standards that apply to the facility under its existing permit. WDEQ/WQD will work with permittees as needed to seek compliance with Chapter 12, while to the extent possible, minimizing the burden on permittees when bringing existing facilities into compliance.

### **15(c)(ii)**

**Darwin Dyck, Tetra Tech:** Mr. Dyck requested confirmation that “inlet velocity should be a maximum of 10 ft/sec and not a minimum of 10 ft/sec.”

**Dayton Alsaker:** Mr. Alsaker commented: “Mixing is very important and must be provided, however requiring an inlet velocity of 10 fps, seems excessive or restrictive to the design when other considerations on providing adequate mixing/turnover can be considered. This matter is also covered in (d) and (e).”

**Cheyenne BOPU:** Cheyenne BOPU commented: “What about a tank filled by gravity with varying flow rates?” and “The inlet [minimum] velocity is higher than we allow in our transmission mains. This seems like an unneeded energy loss and can limit height of tank. If mixing [is] provided in tank, is this still required?”

**Ben Jordan:** Mr. Jordan noted, “What is the reason for an inlet velocity of 10 feet per second? For systems with storage set at a distance from the wells or water supply, friction losses in the pipeline to achieve the velocity will be very high resulting in increased energy costs, potential increases in pressure class of the transmission lines, and in some instances increases in well casing diameters (with higher construction costs) to overcome the additional head requirements. If flushing is a concern then it would be far cheaper to require flushing hydrants on the fill line.

**Department Response:** WDEQ/WQD considered the comments. The reason for a minimum inlet velocity of 10 fps is to remain applicable as a design standard to any system regardless of

its size; for the purposes of mixing and water age when no other apparatus or method is used such as with equipment, gravity mixing or varying flow rates. This minimum flow rate may not be required by the district engineer if a different but effective method is employed. This passage has since been revised for clarity to include “unless other mixing equipment is employed.” WDEQ/WQD has moved the inlet velocity from the paragraph (c)(i) and has moved it to paragraph (e) as follows, “The minimum inlet velocity shall be 10 ft/sec unless A demonstration of employed mixing system or lower inlet velocity shall be considered to addresses disinfection by-product formation, stratification, stagnation, freezing, and other water age issues.”

### **15(c)(iii)**

**Cheyenne BOPU:** Cheyenne BOPU commented: “This is a little unclear. What about gravity fed (floating) tanks?”

**Department Response:** WDEQ/WQD has considered the comment. After additional conversation with the commenter, Water Quality Rules Chapter 3, Section 9(a)(iii) identifies the requirements for modifications. WDEQ/WQD will issue a permit to modify the facility that requires the facility to meet the minimum design standards that are in effect when the permit to modify is issued that apply to the modification without altering any other minimum design standards that apply to the facility under its existing permit. WDEQ/WQD will work with permittees as needed to seek compliance with Chapter 12, while to the extent possible, minimizing the burden on permittees when bringing existing facilities into compliance.

**Darwin Dyck, Tetra Tech:** Mr. Dyck requested that the device requirements be confirmed and the paragraph should be revised to be “consistent with EPA and District Engineer requirements”; commenting that a “recent project required overflow piping modifications to include both duckbill valve and non-corrodible #4 mesh screen per EPA comment. If sealed flapper valve were used, #4 mesh stainless steel screen would also be required.” Mr. Dyck is concerned that #24 mesh for overflow / drain lines is considered to be too fine.

**Department Response:** WDEQ/WQD considered the comment. The passage will remain as written because it conforms with EPA Region 8 Sanitary Survey requirements, as well as the 2018 TSS Section 7.0.7.a, which is incorporated by reference in this Chapter at Section 15(a).

**Ty Ross:** Mr. Ross commented, “What does this mean? State more clearly. ‘or the storage tank water age of 100 percent filled in a 24 hour period will have an average of greater than two days...”

**Department Response:** WDEQ/WQD has revised the passage to “For designs that demonstrate the storage tank has a small daily demand and a high fire water storage requirement, or the storage tank water age ~~of 100 percent filled in a 24 hour period will have~~

an average of is greater than two days, the design shall demonstrate that a volume equal to at least 20 percent of the tank volume will be delivered to the storage tank each time pumping is initiated.”

**15(f)-(i)(ii)(B)**

**Darwin Dyck, Dayton Alsaker, Craig Barsness, Jeffery Rosenlund, and Frank Page :** The commenters noted their concern towards requiring #24 mesh screen. The commenters requested that screen no finer than #16 be required. The commenters noted concern that #24 mesh is too fine, that this size is too restrictive of airflow, that it plugs too easily, and that freezing can lead to blockages that cause damage.

**Department Response:** WDEQ/WQD has considered these comments. The proposed paragraph allows the applicant options to choose for overflow lines either a mechanical device, such as a sealed flapper or duckbill valve, with a mesh size of #4 or finer (such as #16 mesh), or #24 mesh. For vents, applicants may also choose between #24 mesh or a combination of #24 mesh and a coarser mesh.

The proposed choices for overflow lines and vents are consistent with current EPA sanitary survey requirements and the 2018 TSS. The proposed revisions balance consistency with EPA requirements with design flexibility.

For designs that propose only #24 mesh, the permittee or operator should then inspect vents and overflow lines during operation and maintenance practices. Additionally, the permittee or operator should inspect vents and overflow lines following overflow events, as part of operation and maintenance practices. Design and installation options to allow the removal or temporary removal of #24 mesh during an overflow event should be considered.

WDEQ/WQD understands the concern that #24 mesh may become plugged by ice or frost, which is why the requirement at Section 15(i)(ii) is included. Designs may either include #24 mesh on its own or include #24 mesh in combination with a coarser mesh. WDEQ/WQD expects that simple mechanical devices, such as clamps, may be employed to attach the mesh but would allow for release of the #24 mesh in an overflow or pressure event, while still leaving the coarser mesh in place. An additional example to address freezing would be to include a solar panel with heat tape or heating coils that could aid in preventing freeze/frost.

WDEQ/WQD recognizes existing systems may have physical constraints that could make meeting #24 mesh requirements difficult. Entities with concerns should contact WDEQ/WQD to discuss concerns and options for specific situations with WDEQ/WQD.

WDEQ/WQD has reviewed the potential costs of combining coarser mesh with mechanical devices and finds that the additional devices are not economically unreasonable.

WDEQ has reorganized the passages to more clearly indicate that applicants may choose either #24 mesh or a finer mesh that includes a sealed flapper valve or duckbill valve.

## Section 16

**Andy Hooten:** Mr. Hooten commented: "Current Section 14.a.iv has been removed from the rules/regs – "All service connections shall be constructed in conformance with the Uniform Plumbing Code". Is there a replacement? I assume you intend to no longer allow copper service lines as copper is not listed in 16.b. Please clarify."

Mr. Hooten commented: "Service Lines. It is common, at this time, to install water service lines with SDR9 Poly and sanitary sewer services with SDR35. Several new home builders will change the SS service material to schedule 40 and install both services in the same trench, as allowed by Section P2906 of the 2018 IRC. Is it WDEQ's desire to continue the 10' separation of service lines or will reviewing agencies be able to determine if they desire schedule 40 pipe and single trenches? Which codes/rules/regs govern? Does WDEQ desire to adopt TSS 8.11?"

**Department Response:** WDEQ/WQD considered the comment. While WDEQ/WQD intentionally struck the service line reference to the Uniform Plumbing Code that was previously located at Section 14(a)(iv), we intended to include the 2018 TSS reference to 8.11.1, which includes a reference to local codes for applicable plumbing code requirements and includes a reference to 2018 TSS 2.21 for material requirements, and to 8.12 for service meter information. We have corrected Section 16(a) to include parts 8.11.1 and 8.12.

### 16(a)

**Bryan Seppie:** Mr. Seppie commented, "The proposed Chapter 12 does not include TSS 8.5 which provided a method to address inflow prevention (via AWWA C514). Consider including this section of the TSS."

**Department Response:** WDEQ/WQD considered the comment and has revised the paragraph to include TSS 8.5, which includes 8.5.1 and 8.5.2.

### 16(b)

**Ty Ross:** Mr. Ross commented, "conforms."

**Department Response:** WDEQ/WQD has corrected the passage.

**Ty Ross:** Mr. Ross commented, “Add polyethylene large diameter, AWWA C906.”

**Department Response:** WDEQ/WQD has added this standard to the passage.

#### 16(b)(i)(B)

**American Council of Engineering Companies of Wyoming:** ACEC commented, “It appears that C909 water pipe (molecular-oriented PVC) is not being allowed. It is very similar to C900 PVC pipe, and offers some advantageous properties. Why is C909 being disallowed?” “Why can’t cathodically-protected steel be used as a distribution system pipe material?”

**Department Response:** The American Water Works Association Standard C909 is already incorporated for transmission lines and interconnecting process piping at Chapter 12, Section 11(c)(xvii).

Applicants that wish to install materials not included in the Chapter would need to discuss the options with WDEQ/WQD prior to being granted a permit. Cathodically protected steel pipe would be allowed as long as the Engineering Design Report describes the cathodic protection that is proposed to be used and how it will be designed for the proposed application.

#### 16(b)(iv)

**Andy Hooten, Ty Ross:** Mr. Hooten and Mr. Ross requested the inclusion of AWWA C906 to the Section.

**Department Response:** WDEQ/WQD has edited Section 16 and this standard is now included in paragraph (b)(iv)(B).

#### 16(c)

**Cheyenne BOPU:** Cheyenne BOPU asked if this requirement prevents the use of flanged caps and flanged meters? Cheyenne BOPU asked if this requirement applies to “all restrained joint pipes; e.g. can flanged pipe joints be used in lieu of thrust block if thrust block installation [is] not feasible?”

**Andy Hooten:** Mr. Hooten commented: “Flanged piping is not allowed. Have above-ground installations been considered in regards to this item, i.e. Creek crossings?”

**Department Response:** WDEQ/WQD considered the comments. The condition applies to buried pipe. Above ground flanged connections are allowed. WDEQ/WQD has revised the passage to state “Flanged piping shall ~~only be allowed~~ not be allowed for buried pipe except for connection to valves.”



#### 16(d)(ii)

**Dayton Alsaker:** Mr. Alsaker commented: “So, hydrants cannot be used for flushing of lines not designed to have fire flows? When longer mains are sized at 8" or larger due to the resulting losses because of their length, hydrants can provide a means for the needed flushing.”

**Department Response:** WDEQ/WQD considered the comment. Upon further review of the 2018 TSS, part 8.4 describes these conditions more clearly. WDEQ/WQD proposes to remove 16(d)(ii) and incorporate 2018 TSS part 8.4.

#### 16(e)(ii)

**Ty Ross:** Mr. Ross commented, on the striken ‘in all hydrant leads,’ “Keep this clause.”

**Department Response:** WDEQ/WQD has revised Section 16(a) to incorporate 2018 TSS part 8.4 for hydrants. The concern is addressed with the updated incorporated material. The passage at 16(e)(ii) will remain as written.

#### 16(f)

**Cheyenne BOPU:** Cheyenne BOPU asked if an “air release valve” will suffice for the required provision for “air relief”? Cheyenne BOPU asked if this requirement means that there must be a “fire hydrant at every high point”?

**Department Response:** WDEQ/WQD considered the comment. WDEQ/WQD will remove the passage at 16(f) and will add 2018 TSS 8.5, which covers air relief valves, to Section 16(a), which will allow air-relief valves.

**Bryan Seppie:** Mr. Seppie commented, “Air relief and Vacuum Breakers are essential in most large transmission systems. It is not always practical to provide segregated vent piping to the surface (ex. within paved areas). Alternate designs to drain the vaults or add inflow preventors need to be considered.”

**Department Response:** WDEQ/WQD considered the comment. Per additional conversation with the commenter, WDEQ/WQD notes that the chapter is revised to incorporate 2018 TSS parts 8.5.1 and 8.5.2.

**Ty Ross:** Mr. Ross commented, “Keep the old wording. FH are not the only means of air relief and this instance calls for auto air relief. This revision totally misses intent.”

**Department Response:** WDEQ/WQD has incorporated 2018 TSS 8.5.1 in lieu of maintaining the passage at 16(f).

## 16(g)

**Dayton Alsaker:** Mr. Alsaker recommended allowing an “alternate approach...to design the valve not to discharge into water that might accumulate in the manhole should the installation be subject to possible submergence...” as “designing manholes for air relief valves to prevent submerging the valves under all conditions is difficult.”

**Department Response:** WDEQ/WQD considered the comment. The requirement is an existing one that was previously located at Section 14(e)(i). WDEQ/WQD is concerned that allowing a valve to be submerged could result in a discharge even if it is designed to not discharge. The passage will remain as written.

**Jeffery Rosenlund:** Mr. Rosenlund commented, “The requirement for a manhole to access valves at river crossings. This doesn't make sense in places where we've experienced creek crossings as the manholes would likely be under water. Having a valve in a manhole actually makes it harder to access a valve and close it than if it were in a valve box, especially if the area is flooded by a foot or two of water.”

**Department Response:** The citation was not included in the comment, but WDEQ/WQD expects the comment pertains to Section 16(f)(ii). The requirement is an existing one that was previously located at Section 14(e)(i). WDEQ/WQD is concerned that allowing a valve to be submerged could result in a discharge even if it is designed to not discharge. Applicants that are unable to comply with the permitting requirements would need to discuss the options with WDEQ/WQD prior to being granted a permit.

## 16(h)(iii)

**Ty Ross:** Mr. Ross underlined the phrase “The trench shall be dewatered for all work.”

**Department Response:** WDEQ/WQD needs additional information and will discuss this item with the commenter before providing a formal response.

**Ty Ross:** Mr. Ross commented, “Add "involving pipe that is jointed in the trench".”

**Department Response:** WDEQ/WQD needs additional information and will discuss this item with the commenter before providing a formal response.

## 16(k)(iii)

**Ty Ross:** Mr. Ross struck out “place” and added “include placement of.”

**Department Response:** WDEQ/WQD has considered the comment. The proposed revision does not conform to the construction in the preceding and following passages. As the current passage is clear, it will remain as written.

**16(l)(i)**

**Cheyenne BOPU:** Cheyenne BOPU suggested that this requirement may be less restrictive than the 18TSS because it reads as though the minimum horizontal distance requirement of 10 ft only applies when the vertical distance is less than 1.5 ft, and recommended that minimum horizontal distance be 10 ft, regardless of the vertical distance.

**Department Response:** WDEQ/WQD considered the comment. WDEQ/WQD has revised the paragraph to remove (k)(i) through (k)(iv) and has added 2018 TSS parts 8.8.2 and 8.8.3 to paragraph (a).

**16(k)(v)**

**Cheyenne BOPU:** Cheyenne BOPU recommended adding, “or encased in flow fill”, to the end of the section passage.

**Andy Hooten:** Mr. Hooten commented: “Would having the sanitary sewer pipe be the same material as the water pipe be acceptable rather than a separate conduit pipe i.e. C900 for Sanitary Sewer Pipe (TSS 8.8.4.b)?”

**Ty Ross:** Mr. Ross commented, “Not the only acceptable method, per DEQ policy. Also list sewer installed w/pressure-rated pipe and flow-fill.”

**Department Response:** WDEQ/WQD considered the comment. The reason the passage requires separate conduits is that it prevents possible contamination from leaking pipe or pipe joints when separation cannot be achieved. WDEQ/WQD has revised the passage to the following, “Where the minimum vertical or horizontal separation distances required by incorporation by reference of 2018 TSS parts 8.8.2 and 8.8.3 of paragraph (a) of this Section cannot be met, the sewer or water line shall be placed in a separate conduit pipe or meet the flow-fill requirements of paragraphs (ii) and (iii) of this Paragraph”

**16(l)(iii)(D)**

**Andy Hooten:** Mr. Hooten commented "may be" separated or "shall be" separated? I would suggest the following phrase, "when a pipe crossing is encased in flow-fill the minimum separation distance between the pipes shall be two inches, larger separations are encouraged".

**Department Response:** WDEQ/WQD has corrected the passage to “shall be

separated.”

**Ty Ross:** Mr. Ross struck out “may be” and added “shall be vertically.”

**Department Response:** WDEQ/WQD has considered the comment. The section has been updated to remove “may be” and replaced with “shall be.”

#### 16(m)

**Andy Hooten:** Mr. Hooten commented: “Table 1 and Table 4 are referenced several times in 16.I. I assume all these references should be Table 4. Please clarify.”

**Department Response:** WDEQ/WQD corrected the passage to Table 4.

**Ty Ross:** Mr. Ross commented, “Cross-connection prevention.”

**Department Response:** WDEQ/WQD has considered the comment. As the paragraph pertains to the defined term “cross-connection” and not only to prevention, the passage will remain as written.

#### 16(m)(i)(A)

**Ty Ross:** Mr. Ross commented, “Rethink table labels, as Section # - 1, 2, etc.”

**Department Response:** WDEQ/WQD has considered the comment. WDEQ/WQD will keep the naming convention for tables that is consistent with other Water Quality Rules. The table title will remain as written.

#### 16(m)(i)(A)(I)

**Ty Ross:** Mr. Ross commented, “16-1(or 4 if the current convention is kept.)”

**Department Response:** WDEQ/WQD has corrected the cross-reference. WDEQ/WQD will keep the naming convention for tables that is consistent with other Water Quality Rules. The table title will remain as written.

#### 16(m)(i)(B)(IV)

**Ty Ross:** Mr. Ross commented, “16-1 (or 4).”

**Department Response:** WDEQ/WQD has corrected the cross-reference. WDEQ/WQD will keep the naming convention for tables that is consistent with other Water Quality Rules. The table title will remain as written.

#### 16(m)(i)(D)

**Ty Ross:** Mr. Ross struck out “that have been” and “ous” and added “Hazard.”

**Department Response:** WDEQ/WQD has corrected the passage.

#### 16(m)(i)(D)(I)

**Ty Ross:** Mr. Ross struck out “ous” and added “Hazard.”

**Department Response:** WDEQ/WQD has corrected the passage.

#### 16, Table 4

**Ty Ross:** Mr. Ross added “or 16-1.”

**Department Response:** WDEQ/WQD has considered the comment. WDEQ/WQD will keep the naming convention for tables that is consistent with other Water Quality Rules. The table title will remain as written.

#### 16, Table 4, Note 2

**Ty Ross:** Mr. Ross commented, “Then why isn't this instance checked in the Table?”

**Department Response:** WDEQ/WQD has considered the comment. Low hazard back-siphonage and back-pressure and high-hazard back-siphonage and back-pressure are all checked for the row “reduced pressure principle backflow.” The table will remain as written.

#### 16 (m)(i)(H)

**Jason Palmer:** Mr. Palmer asked, “Who is responsible for having the backflow prevention devices installed at high-hazard non-residential cross-connections inspected and tested, e.g. city or property owners, and who maintains the records?”

**Department Response:** The public water supply is responsible for obtaining testing and certification and is responsible for maintaining the records.

#### Section 17

#### 17(c)(vi)

**Jason Palmer:** Mr. Palmer commented that “Standard Methods” should be accompanied by the ‘current version’.

**Department Response:** WDEQ/WQD considered the comment. WDEQ/WQD is proposing to incorporate by reference the Standard Methods for the Examination of Water and Wastewater from 2018, as noted in Section 19. The proposed incorporation is for a specific version, which may or may not be the "current" version, in accordance with the Administrative Procedures Act, W.S. § 16-3-105(h)(ii). If the Standard Methods for the Examination of Water and Wastewater is revised after the adoption and filing of this rule, WDEQ/WQD will evaluate whether or not to incorporate by reference the new version. If we proceed with incorporating the new version, WDEQ/WQD will proceed with a new rulemaking effort. For clarity, WDEQ/WQD will include the publication year noted in Section 19(b)(xlix) in the reference at 17(c)(vi).

## Section 18

### 18(b)

**American Council of Engineering Companies of Wyoming:** ACEC commented, "Administrator approval of the final O&M manual will now be required prior to plant startup. While in theory this makes some sense, practically this prove very difficult to achieve. Getting all of the O&M manuals together into one document, then submitting and receiving approval from the Administrator, prior to startup will be difficult."

**Department Response:** WDEQ/WQD has considered the comment. The requirement is an existing one that was previously located at Section 16(b). The requirement is consistent with our operation and maintenance requirements for other programs within WDEQ/WQD. Applicants that are unable to comply with the permitting requirements would need to discuss the options with WDEQ/WQD prior to being granted a permit.

## Section 19

**Andy Hooten:** Mr. Hooten commented: "AWWA C901 ¾" through 3 inch for water service C-901-17. This has been updated to C901-20. Which version does WDEQ desire?"

**Department Response:** WDEQ/WQD has updated the reference in Section 19 to C901 to the 2020 version.

**Ty Ross:** Mr. Ross commented, "AWWA C906."

**Department Response:** WDEQ/WQD has added this standard to the list of incorporated materials.

**Water and Waste Advisory Board Comments**  
**December 21, 2021 Meeting**  
**Chapter 12**

**General Comments**

**Lorie Cahn:** Ms. Cahn asked if Chapter 12 needs to include definitions of all of the terms of the 2018 Ten States Standards.

**Department Response:** WDEQ/WQD considered the comment. The 2018 Ten States Standards do not include a section of definitions. However, based on our review of the 2018 Ten States Standards, we do not feel any additional definitions are necessary at this time.

**5(u)**

**Lorie Cahn:** Ms. Cahn recommended revising “mechanically driven drives” to “mechanical drives.”

**Department Response:** WDEQ/WQD revised the passage as requested.

**5(x)**

**Lorie Cahn:** Ms. Cahn noted the defined term “offstream reservoir” is defined, but is not used in the chapter. Ms. Cahn asked WDEQ/WQD to provide the number of offstream reservoir facilities in the State.

**Department Response:** WDEQ/WQD considered the comment. As the term “offstream reservoir” is not used in the chapter, WDEQ/WQD proposes to remove it from Section 5.

WDEQ/WQD consulted our database and EPA records and found that there are between 4 and 20 offstream reservoirs that are permitted in Wyoming.

**5(cc)**

**Lorie Cahn:** Ms. Cahn recommended revising “utilizing” to “use.”

**Department Response:** WDEQ/WQD revised the passage as requested.

**6(b)(iii)**

**Lorie Cahn:** Ms. Cahn recommended revising the stricken “which” to “that” and removing “that” from “that the facility will meet...”

**Department Response:** WDEQ/WQD revised the passage as requested.

**8(c)(ii)**

**Lorie Cahn:** Ms. Cahn noted the passage may be missing helpful grammar and punctuation, such as an “and” before “material” and a comma if “material” does not go with “valve.” Ms. Cahn recommended removing the comma after “valves.”

**Department Response:** WDEQ/WQD revised the passage as follows:

(ii) Profiles of all water lines shall: ~~be shown on the same sheet as the plan view at legible horizontal and vertical scales, with a profile of existing and finished surfaces, pipe size and material, valve size, material and type. The location of all special features such as access manholes, concrete encasements, casing pipes, blowoff valves, and air-vacuum relief valves, etc., shall be shown.~~

(A) ~~be~~ Be shown on the same sheet as the plan view at legible horizontal and vertical scales;

(B) ~~with~~ Show a profile of:

(I) ~~e~~ Existing and finished surfaces;

(II) ~~p~~ Pipe size and material; and

(III) ~~v~~ Valve size, material, and type.

(C) ~~T~~ Show ~~t~~he location of all special features such as access manholes, concrete encasements, casing pipes, blowoff valves, and air-vacuum relief valves ~~shall be shown.~~

**8(c)(iii)(A)**

**Lorie Cahn:** Ms. Cahn noted that the passage is unclear and requested that WDEQ/WQD explain how the passage will be clarified.

**Department Response:** WDEQ/WQD has revised the passage as follows:

~~(formerly Section 7(c)(iii)(A))~~ (A) The bottom of the stream, the elevation of the high- and low water levels, and other topographical features at ~~all locations where the water line is near or crosses streams or lakes.~~ points where:



and

(I) The water line is within 10 feet of streams or lakes;

(II) The water line crosses streams or lakes.

**8(e)(ix)**

**Lorie Cahn:** Ms. Cahn noted the passage is unclear concerning the depth of the elevation. The passage does not specify how far below the penetration the applicant should be in providing the elevation.

**Department Response:** WDEQ/WQD has revised the passage as follows: Provide from the ground surface to the total depth of the drilled borehole to include the elevation and designation of geological formations, water levels, formations penetrated, and other details to describe the proposed well completely;

**8(e)(ii), line 1126 (11/5/21 strike/underline)**

**Lorie Cahn:** Ms. Cahn noted the paragraph is unclear.

**Department Response:** WDEQ/WQD has clarified the passage as follows:

When applicable, The type, size, strength, operating characteristics, rating or requirements for all mechanical and electrical equipment, including machinery, valves, piping, electrical apparatus, wiring, and meters; laboratory fixtures and equipment; operating tools; special appurtenances; and chemicals, ~~when applicable.~~

**8(e)(x)**

**Lorie Cahn:** Ms. Cahn recommended removing the “and” after “screen intervals;”

**Department Response:** WDEQ/WQD revised the passage as requested.

**9(b)(iv)**

**Lorie Cahn:** Ms. Cahn requested that WDEQ/WQD review the passage and clarify “all” since some information may not be known at the time the application is submitted.

**Department Response:** WDEQ/WQD revised the passage to the following:

A determination of the degree of hazard of all [known or anticipated](#) water service connections to be connected to the proposed project. A hazard classification shall be identified for each connection and recommended mitigation measures shall be described for each hazard.

**9(f)(ii)**

**Lorie Cahn:** Ms. Cahn recommended revising “this data” to “these data.”

**Department Response:** WDEQ/WQD revised the passage as requested.

**10(b)**

**Lorie Cahn:** Ms. Cahn recommended adding “that” to “shall demonstrate the.”

**Department Response:** WDEQ/WQD revised the passage as requested.

**10(b)(ii)**

**Lorie Cahn:** Ms. Cahn recommended clarification of the passage.

**Department Response:** WDEQ/WQD revised the passage to “The plant capacity design shall ~~include documentation of the~~ demonstrate consideration of:”

**10(b)**

**Lorie Cahn:** Ms. Cahn recommended adding “that” to “demonstrate the facility will.”

**Department Response:** WDEQ/WQD revised the passage to “demonstrate that the facility will...”

**11(e)(ii)(C)**

**Lorie Cahn:** Ms. Cahn recommended adding “in” to “required Tables 1 and 2 of this Section.”

**Department Response:** WDEQ/WQD revised the passage to “required in Tables 1 and 2...”

**11(e)(vii)(E)**

**Lorie Cahn:** Ms. Cahn recommended removing “;” and “and.” Ms. Cahn recommended replacing the stricken characters with “.” after “annular space.”

**Department Response:** WDEQ/WQD revised the passage as requested.

**11(e)(vii)(E)(II)**

**Lorie Cahn:** Ms. Cahn requested that WDEQ/WQD review the passage at 11(e)(vii)(E)(II) and determine if “the” is necessary to “the 40 CFR Part 141.”

**Department Response:** WDEQ/WQD removed “the.”  
**11(e)(xxvi)**

**Lorie Cahn:** Ms. Cahn recommended removing “an.”

**Department Response:** WDEQ/WQD revised the passage as requested.

**12(b)**

**Lorie Cahn:** Ms. Cahn recommended revising the passage back to the original language.

**Department Response:** WDEQ/WQD revised the passage to “The capacity of the water treatment or water production system shall be designed for the maximum daily demand at the design year.”

**12(e)(vi)**

**Lorie Cahn:** Ms. Cahn noted the passage contains an extra “if.”

**Department Response:** WDEQ/WQD revised the passage and removed the extra “if.”

**12(g)**

**Lorie Cahn:** Ms. Cahn recommended removing “the” from “the flow rates.”

**Department Response:** WDEQ/WQD revised the passage as requested.

**12(i)(x)(B)**

**Lorie Cahn:** Ms. Cahn recommended removing “of the.”

**Department Response:** WDEQ/WQD revised the passage as follows:

Proposed diatomaceous earth filtration shall be pressure or vacuum type units ~~shall be of the pressure or vacuum type.~~

**12(j)(i)(D)**

**Lorie Cahn:** Ms. Cahn noted that "with" should it be "when." "with" seems to tie to the reference to "chlorinator" and this is a timing issue.

**Department Response:** WDEQ/WQD revised the passage as follows:

Standby equipment of sufficient capacity shall be available to replace the largest chlorinator unit, ~~except for a well water systems~~ providing no treatment other than disinfection are exempt from the requirements of this paragraph (D) and are not required to provide standby chlorination equipment

#### **12(k)(i)(A-H) and (k)(ii)(A-N)**

**Lorie Cahn:** Ms. Cahn noted that several words are capitalized that should be lower case.

**Department Response:** WDEQ/WQD revised the passage by changing the incorrectly capitalized words to lower case.

#### **12(k)(iii)(E)**

**Lorie Cahn:** Ms. Cahn recommended revising "with" to "when" or "if."

**Department Response:** WDEQ/WQD revised the passage and the phrase has changed to "The validated dose that meets or exceeds the required dose shall be delivered under maximum flow and design (UVT) condition, ~~with~~ when the larger UV unit is out of service.

#### **12(k)(iv)(G) and 12(k)(vi)(C)**

**Lorie Cahn:** Ms. Cahn recommended revising "headloss" to "head loss."

**Department Response:** WDEQ/WQD revised the passages as requested.

#### **12(l)(i)**

**Lorie Cahn:** Ms. Cahn recommended adding "that" to "designs shall demonstrate."

**Department Response:** WDEQ/WQD revised the passage as requested.

#### **12(l)(ii)(E), 16(l)(i)(B)(III), and 16, Table 4**

**Lorie Cahn:** Ms. Cahn recommended revising "principle" to "principal"

**Department Response:** WDEQ/WQD revised the passages as requested.

**12(l)(ii)(f)**

**Lorie Cahn:** Ms. Cahn noted that “fluoride” is misspelled in the passage.

**Department Response:** WDEQ/WQD corrected the passage as requested.

**12(l)(iv)**

**Lorie Cahn:** Ms. Cahn noted that “loading” is misspelled in the passage.

**Department Response:** WDEQ/WQD corrected the passage as requested.

**12(n)(iv)**

**Lorie Cahn:** Ms. Cahn noted that the passage includes too many uses of “shall.”

**Department Response:** WDEQ/WQD corrected the passage as requested.

**12(o)(iv)**

**Lorie Cahn:** Ms. Cahn noted that “Log” should be lower case.

**Department Response:** WDEQ/WQD corrected the passage as requested.

**12(r)(i)**

**Lorie Cahn:** Ms. Cahn recommended adding “to” or “into” to “discharged directly a sanitary sewer...”

**Department Response:** WDEQ/WQD corrected the passage to “shall be discharged directly into a sanitary sewer...”

**13(b)(ii)**

**Lorie Cahn:** Ms. Cahn recommended revising the construction of the second sentence to match the construction of the first sentence.

**Department Response:** WDEQ/WQD corrected the passage to “Tanks shall maintain structural integrity while in use.”

**14(g)(ii)**

**Lorie Cahn:** Ms. Cahn recommended removing “(4)” from the passage.

**Department Response:** WDEQ/WQD corrected the passage as requested.

**14(i)(ii)**

**Lorie Cahn:** Ms. Cahn noted the use of “manifolded” is unusual in this context.

**Department Response:** WDEQ/WQD revised the passage to the following:

Each pump shall either have an individual suction line or shall have the multiple suction lines ~~shall be manifolded such that they will ensure~~ that demonstrate similar hydraulic and operating conditions.

**15(c)(ii)**

**Lorie Cahn:** Ms. Cahn noted the paragraph is incorrectly numbered.

**Department Response:** WDEQ/WQD corrected the passage as requested.

**16(l)(i)(A)**

**Lorie Cahn:** Ms. Cahn recommended that WDEQ/WQD review the passage and propose revisions for clarity.

**Department Response:** WDEQ/WQD revised the passage to the following:

(A) Applicability. ~~In order to~~ To protect all public water supplies from the possibility of the introduction of contamination due to cross connections, the water supplier shall: ~~require backflow prevention devices for each water service connection in accordance with Table 1 which appears at the end of this section, with the exception of (B)(I) residential water service connections and (B)(II) domestic non-residential water service connections. The water supplier shall take appropriate actions which may include immediate disconnection for any water user that fails to maintain a properly installed backflow prevention device or comply with other measures as identified in Section 14 (i) of these regulations.~~

(l) \_\_\_\_\_ ~~Require~~ Require backflow prevention devices for each water service connection in accordance with ~~Table 1 Table 4 which appears at the end~~ of this sSection, with the exception of (B)(I) residential water service connections and (B)(II) domestic non-residential water service connections.

(II) ~~The water supplier shall~~ Take appropriate actions that may include:

1. Immediate disconnection for any water user that fails to maintain a properly installed backflow prevention device; or

2. ~~comply~~ Compliance with other measures as identified in this Section.

**16(I)(i)(B)(V)**

**Lorie Cahn:** Ms. Cahn recommended revising “utilizing” to “using.”

**Department Response:** WDEQ/WQD corrected the passage as requested.

**17(b)**

**Lorie Cahn:** Ms. Cahn recommended revising “assure” to “ensure.”

**Department Response:** WDEQ/WQD corrected the passage as requested.

**18(a)(ii)(B)**

**Lorie Cahn:** Ms. Cahn recommended removing the extra uses of “the” from the passage.

**Department Response:** WDEQ/WQD corrected the passage as requested.

**18(c)(ii)(A-K)**

**Lorie Cahn:** Ms. Cahn recommended removing the extra uses of “a” from the passages.

**Department Response:** WDEQ/WQD corrected the passages as requested.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

WYOMING WATER AND WASTE ADVISORY BOARD

-----  
RE: WATER AND WASTE ADVISORY BOARD MEETING  
-----

TRANSCRIPT OF MEETING PROCEEDINGS

Pursuant to notice duly given to all parties in interest, this matter came on for meeting on the 15th day of March, 2022, at the hour of 9:06 a.m., before the Wyoming Water and Waste Advisory Board, Ms. Lorie Cahn, Acting Chairman presiding, and Mr. Brian Deurloo, Mr. James Cochran, with Mr. Brian Dickson and Mr. James Peters, Attorney for the Board, also in attendance virtually.

Ms. Nicole Budine, Attorney for the Division;  
Ms. Jennifer Zygmunt, Water Quality Administrator;  
Ms. Lily Barkau, Groundwater Section Manager; Mr. Keenan Hendon, Water and Wastewater Section Manager; and  
Ms. Gina Thompson, Water Quality Division, in attendance, as well as various members of DEQ staff and the public in attendance virtually.



1

2

I N D E X

3

PAGE

4

CALL TO ORDER

3

5

ADMINISTRATOR'S BRIEFING

9

6

RULEMAKING WQR CHAPTER 29

23

7

BRIEFING UPCOMING REVISIONS TO WQR CHAPTER 1

46

8

WQR CHAPTER 12

68

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 P R O C E E D I N G S

2 (Meeting proceedings commenced

3 9:06 a.m., March 15, 2022.)

4 ACTING CHAIR CAHN: Call this meeting to  
5 order, the Water and Waste Advisory Board for the state of  
6 Wyoming on the 16th of March.

7 BOARD MEMBER DEURLOO: 15th.

8 ACTING CHAIR CAHN: 15th of March. Oh,  
9 dear. Thank you.

10 I don't know if, Jennifer, you want to start off.

11 I would --

12 MS. ZYGMUNT: Sure.

13 ACTING CHAIR CAHN: I would -- actually,  
14 maybe just real quick. Our Board Chair Alan Kirkbride  
15 passed away recently, and I just thought -- we thought it  
16 would be nice to have a moment of silence for Alan.

17 (A moment of silence was observed.)

18 ACTING CHAIR CAHN: And I would like to  
19 invite -- if anybody on the Board would like to say  
20 something, please feel free or anybody in DEQ.

21 BOARD MEMBER DEURLOO: I'd just say he was  
22 a good guy. We joined the same day on the Board. We were  
23 Leadership Wyoming classmates. He was a gentle giant. Had  
24 the biggest hands I ever shook, I think, or darn near. He  
25 was a rancher, a gentleman, a Christian, and all-around

1 good guy, so I'll miss him.

2 BOARD MEMBER COCHRAN: He'll be missed.

3 MS. ZYGMUNT: Agreed. We'll miss his  
4 leadership and his kindness and his support for  
5 conservation and natural resources in Wyoming. He was a  
6 no-nonsense guy, and I'm sure he'd want us to continue on  
7 with the business today, and we look forward to the  
8 discussion, but we will miss him deeply. So thank you for  
9 the comments.

10 BOARD MEMBER DEURLOO: Thank you.

11 ACTING CHAIR CAHN: He was really  
12 thoughtful, kind, and fun to work with, and I just really  
13 enjoyed the good, kind person, so we will miss him.

14 Okay. With that, I think we'll do introductions,  
15 and then I'll turn it over to Jennifer.

16 So I'm Lorie Cahn. I'm the acting chair  
17 representing the public at large.

18 BOARD MEMBER COCHRAN: Jim Cochran,  
19 representing local government.

20 BOARD MEMBER DEURLOO: I'm Brian Deurloo.  
21 I represent industry.

22 BOARD MEMBER DICKSON: I'm Brian Dickson,  
23 representing the public at large.

24 MS. ZYGMUNT: Thank you, Madam Chairwoman.  
25 I'll do some DEQ introductions. My name is Jennifer

1 Zygmunt. I am the Water Quality Division Administrator.

2 MS. BARKAU: Lily Barkau, Groundwater  
3 Section Manager in the Water Quality Division.

4 MS. THOMPSON: Gina Thompson, Water Quality  
5 Division Policy and Planning Analyst.

6 MS. ZYGMUNT: And also in the room with us  
7 today we have Keenan Hendon, who is our Water and  
8 Wastewater Section Manager. And Anthony Rivers, also in  
9 the Water and Wastewater Section. They'll be presenting to  
10 us later on today regarding Chapter 12.

11 Via Zoom we will have Lindsay Patterson, our  
12 Standards Program Manager, and David Waterstreet, our  
13 Watershed Section Manager, to talk about Chapter 1 as well.

14 And then to note a couple other people. We have  
15 Nicole Budine, who is Water Quality Division's Attorney  
16 General. And then we also have Jim Peters on via Zoom. He  
17 is the Attorney General for the Board. So he is here to  
18 help with any questions that the Board may have  
19 procedurally. So please know that he is here as a resource  
20 as well.

21 So Madam Chairwoman, I think that covers  
22 introductions. At this point I would suggest to the Board  
23 that we could talk about elections and what the Board's  
24 preference to do there. If you would like to have  
25 reelections at this time or wait until we have a full board

1 again.

2 ACTING CHAIR CAHN: Open it up for  
3 discussion. I think the two ideas on the table are to wait  
4 until we have a full board and Alan is replaced, or elect  
5 officers at this point. So open up for discussion.

6 BOARD MEMBER COCHRAN: I guess I have to  
7 start with a question. What's the time frame typically to  
8 replace a board member?

9 MS. ZYGMUNT: It depends. The governor's  
10 office is aware of the vacancy. Sometimes the governor may  
11 have a candidate in mind, otherwise we will be suggesting  
12 candidates to the governor's office. So I'll put the word  
13 out now that if you have suggestions for a good replacement  
14 for the Board, please feel free to pass those names on to  
15 me and we'll give them to the governor's office.

16 Once they have candidates, I've generally found  
17 it may only take them a few weeks to review the nominations  
18 and make a decision. I would anticipate by the June -- or  
19 second quarter meeting we could have a replacement onboard.

20 ACTING CHAIR CAHN: I would also like to  
21 add that it has taken over a year sometimes to replace  
22 board members. So just keep that in mind, that it doesn't  
23 necessary -- it'd be nice if it happened quickly, but  
24 doesn't necessarily.

25 BOARD MEMBER DEURLOO: And point of

1 clarification on that board member. They can be  
2 nonpartisan now, so it doesn't matter if it's Republican or  
3 Democrat. And should be coming from agriculture, correct?

4 MS. ZYGMUNT: Correct. Right.

5 ACTING CHAIR CAHN: So does the  
6 conservation district count, if somebody was on the  
7 conservation district for agriculture?

8 MS. THOMPSON: I think it's just anyone  
9 whose background or job is related to agriculture. So the  
10 previous agriculture representative had been affiliated  
11 with -- hold on. I'm sorry. Apparently it's muted.

12 Thank you, Jim, for pointing that out. I believe  
13 for the discussion we're discussing reappointment of -- or  
14 appointments of the vacancy.

15 And so the agricultural representative, the  
16 previous gentleman was affiliated with one of the sugar  
17 factories in the state. So I don't -- I don't know if he  
18 was a grower or if he was just affiliated. So I think it's  
19 anyone in ranching or agriculture in general, which, you  
20 know, that's a good wide open sector, so hopefully we'll  
21 have a quick appointment, because there's more applicants  
22 and that kind of thing.

23 ACTING CHAIR CAHN: Any Board discussion?

24 BOARD MEMBER DEURLOO: If you're okay as  
25 the acting -- Madam Chairman, if you're okay as the acting

1 chairman for a while, I'm okay with delaying the vote for  
2 doing a vote on officers for the Board, if you're okay.

3 BOARD MEMBER COCHRAN: I would propose we  
4 put it on the agenda for the next meeting, and if we have  
5 somebody, that will be great. Otherwise, if it's going to  
6 drag on, we'll move forward.

7 ACTING CHAIR CAHN: Brian, any thoughts?

8 BOARD MEMBER DICKSON: This is Brian  
9 Dickson. I'm willing to wait until we have a full board.

10 ACTING CHAIR CAHN: Okay. So I have two --  
11 I hear two ideas on the table. One, wait for a full board,  
12 and one is to do it -- put it on the agenda for the next  
13 meeting. So do I have a motion?

14 BOARD MEMBER DEURLOO: I move that we  
15 conduct business in today's meeting with the Board as  
16 currently structured. And -- and open the discussion for  
17 voting for executive members of the board next meeting.

18 ACTING CHAIR CAHN: Okay. Do I have a  
19 second?

20 BOARD MEMBER COCHRAN: Second.

21 ACTING CHAIR CAHN: Discussion? Okay. All  
22 in favor of the motion say aye?

23 BOARD MEMBER COCHRAN: Aye.

24 BOARD MEMBER DEURLOO: Aye.

25 BOARD MEMBER DICKSON: Aye.

1                   ACTING CHAIR CAHN: Aye. The motion  
2 carries. We'll have this on the agenda at the next  
3 meeting, and in the meantime I'll act as the acting chair.

4                   MS. ZYGMUNT: Okay. Madam Chairwoman,  
5 continuing on. So just a real brief review of the plans  
6 for today. We have three rules to talk to you about. We  
7 will start with Chapter 29, which is a new rule, a fairly  
8 short one that I think we can get through pretty quickly,  
9 involving carbon sequestration permit fees.

10                  After that we'll take a break and hear from the  
11 watershed section about Chapter 1, which is our Surface  
12 Water Quality Standard. We're not going to get into  
13 proposed revisions on that chapter today, but that is a  
14 foundational rule to the Water Quality Division. So I  
15 asked Lindsay and David to start doing some 101 with the  
16 Board to get you prepared to see the changes with that  
17 rule, because they will be extensive. So I think it's a  
18 good opportunity to start reviewing that rule and why it is  
19 important to the Division.

20                  And then we will wrap up with a second  
21 presentation on Chapter 12, which is our Design and  
22 Construction Standards for Public Water Supplies, which we  
23 talked about in December, and we will walk through  
24 presentation and go through the summary of revisions and  
25 response to comments that we have prepared for you.



1           So that is the goal for today. We can see how  
2 the agenda goes and whether or not we go through lunch, and  
3 we can make plans accordingly at that time. But we --  
4 again, we look forward to the discussion on all three of  
5 those rules. These are all good rules. We feel we have  
6 good products, and we look forward to your input and advice  
7 on how we move forward.

8           Before we get into the rules, I did want to take  
9 an opportunity at the beginning of this meeting to just let  
10 the Board know about some concerns I have in both my role  
11 as the executive secretary for the Board and as the Water  
12 Quality Division Administrator. It has come to my  
13 attention that in the recent past we have had several  
14 instances of board members reaching out to Water Quality  
15 Division staff who aren't involved in the rulemaking  
16 projects with questions or concerns about the rules, and --  
17 without notifying me first. And this has been causing a  
18 few problems that I just wanted to discuss with you.

19           First, and simply put, it does undermine my  
20 authority as the administrator to bring rules before this  
21 Board. And I think it also undermines the authority and  
22 the action of this Board to provide advice to us on these  
23 rules before I make a recommendation to the Director to  
24 proceed forward with formal rulemaking.

25           The staff who have been contacted may not have

1 full access to the range of information that I use to make  
2 any decisions in terms of a rule that we bring before you  
3 and a rule that we bring to the Director. And while  
4 they're trying to be helpful in providing information,  
5 again, it may not be the most accurate information to  
6 inform the Board on what we're proposing to move forward  
7 with. It can put them in an awkward spot in that they,  
8 again, want to be helpful, but they may not have the right  
9 information and it could cause confusion. And my concern  
10 is that can cause delays with rulemaking, potentially  
11 overturning years of work that we've put into a rulemaking  
12 decision.

13 Finally, that kind of communication can be  
14 considered ex parte contact or biased decision making. I  
15 do not want to get into the ins and outs of that, but refer  
16 State of Wyoming Board Handbook and some executive orders  
17 that speak to ex parte contacts specifically. Namely, that  
18 if that kind of contact occurs, we may need to read it into  
19 the administrative record. And that's just in the interest  
20 of transparency and making sure that we have unbiased  
21 decision making. So my request to you all is that if you  
22 have questions or concerns, please notify me first. And if  
23 you can't get ahold of me, contact the section manager. We  
24 are more than happy to have that conversation, and we'll  
25 bring in the appropriate staff to have those questions

1 answered.

2           And, again, this is will just make sure we're  
3 following appropriate procedures, documenting things  
4 appropriately, maintain transparency, giving you guys the  
5 right information so that we make effective use of your  
6 time in the time that we have for discussion at these board  
7 meetings.

8           So that is the message I wanted to convey in my  
9 briefing to you all. I appreciate your attention, and I'm  
10 happy to open it up for questions briefly this morning. I  
11 don't want to spend a lot of time discussing this, but I'm  
12 also available offline if we have any questions or concerns  
13 about appropriate procedures as we work through these  
14 rules. Again, having that discussion is not a problem.  
15 There's just an appropriate way to do it to make sure my  
16 staff are protected and you guys, as board members, are  
17 protected in your authority to act under the Environmental  
18 Quality Act.

19           So, Madam Chairwoman, that's the briefing I have  
20 to give you all today, and so I'll stop there, and glad to  
21 take any questions, if there are any.

22           ACTING CHAIR CAHN: I have a question  
23 about -- so if we have a question for staff, we contact  
24 you. You'll then bring in the appropriate -- the  
25 appropriate people, or can we request certain people come

1 in, whether or not they're working on it directly or not --

2 MS. ZYGMUNT: Absolutely.

3 ACTING CHAIR CAHN: -- if they have the  
4 expertise?

5 MS. ZYGMUNT: Yeah. If you know of  
6 somebody within the Division that you would like to be part  
7 of that conversation, please let me know when you notify  
8 me, and we can bring in those staff into the conversation,  
9 if you feel they could help address questions and concerns.  
10 That's not a problem.

11 ACTING CHAIR CAHN: Okay.

12 MS. ZYGMUNT: But then, you know, I and the  
13 section manager can be there to make sure that in addition  
14 to what that staff knows, you also have the information  
15 that I've incorporated into my decision making to the  
16 Director.

17 ACTING CHAIR CAHN: Then I had another  
18 question kind of related to that. On the website -- you  
19 know, I represent the public at large. And on the website  
20 there's no way to contact any board members directly.

21 MS. THOMPSON: That's correct.

22 ACTING CHAIR CAHN: Can you just go over  
23 that again for the new board members why that is?

24 MS. THOMPSON: Sure. So that goes back to  
25 the ex parte concerns as well. Because if someone from the

1 public is contacting you, there's -- there's no anonymity  
2 when we're getting questions and comments from the public.  
3 If they want to contact you, it has to be transparent and  
4 in the public eye. And so we've set it up to where we have  
5 one uniform email address that we use to communicate with  
6 you. But if a member from the public wanted to contact you  
7 directly, they would be able to send an email to that  
8 address, but it ensures that all of you get it at the same  
9 time and that the Division is aware of what the comment is  
10 as well.

11           So everybody gets all the same information at the  
12 same time. It also protects your privacy a little bit,  
13 depending on your level of concern. Before -- you know, at  
14 one point we had all of your physical addresses and your  
15 direct phone numbers on there. And like the agency's  
16 approach for all the advisory boards -- and this is  
17 consistent with the Environmental Quality Council's  
18 approach as well -- is to have a uniform email address, to  
19 not post all of your private information, your contact  
20 information, directly on the website and to make sure that  
21 when one of you is being contacted, you're all being  
22 contacted at the same time.

23           BOARD MEMBER COCHRAN: Madam Chair, I have  
24 a question. A little clarification on that. But we're  
25 okay to reach out to entities that we're representing?

1 Like if I see a comment placed by the Town of Guernsey on  
2 something, I can contact them and get clarification or no?

3 MS. ZYGMUNT: I'm not aware of any concerns  
4 with that.

5 Jim Peters, if you're available to weigh in on  
6 that question, you might be the more appropriate resource  
7 to answer that question.

8 MR. PETERS: Yeah. Happy to chime in  
9 there.

10 I think that communication is fine, but the  
11 important piece, as Gina mentioned, is making sure that  
12 what the results of that communication do become part of  
13 the record. So if you do have communications with entities  
14 related to proposed rules that are outside of the process,  
15 what would be important is that we summarize the contents  
16 of those communications and share that with the  
17 administrators and staff and the fellow board members just  
18 to make sure that they're aware of the communication that  
19 occurred and that it is part of the administrative record.

20 BOARD MEMBER COCHRAN: Thank you.

21 BOARD MEMBER DEURLOO: Madam Chair, may I  
22 ask a question?

23 ACTING CHAIR CAHN: Yes.

24 BOARD MEMBER DEURLOO: Thank you. I hear  
25 you loud and clear on that. Thank you for that

1 clarification. I appreciate it.

2           May I ask a -- just a brief answer. What steps  
3 do you take to take onboard comments from your general  
4 staff? Like if you open up Chapter 12, and, you know,  
5 these folks have been in the field implementing these rules  
6 for the last couple decades, some of them, what steps do  
7 you take to say, Hey, folks, we're going to open this up.  
8 What comments do you have? If you give me an overview on  
9 that, please.

10           MS. ZYGMUNT: Yeah. Thank you for that  
11 question. We do consult heavily with all the appropriate  
12 staff, and that includes staff who you see before you at  
13 these board meetings and staff that don't come to these  
14 board meetings. As an example, for Chapter 12, which we  
15 talked about -- and Keenan will get into this in his  
16 presentation -- we spent several years with most of the  
17 engineers in water and wastewater section having an  
18 opportunity to weigh in on that chapter. Their feedback is  
19 heard, and I take it very seriously. It is very valuable.  
20 If I don't incorporate it into the final decision, it  
21 doesn't mean that it hasn't been heard, it's just been  
22 factored in along with other feedback that I've heard  
23 before to make a decision.

24           So it is standard for -- when we start the  
25 rulemaking process, to have kind of an internal scoping

1 session with staff throughout the section, not just the  
2 section manager, but the folks that are involved in  
3 implementing these rules on a day-to-day basis do get an  
4 opportunity to weigh in on the process as we draft the new  
5 rules.

6 BOARD MEMBER DEURLOO: Excellent. Thank  
7 you.

8 ACTING CHAIR CAHN: I have a question.  
9 What about in a situation where somebody doesn't feel that  
10 they're being heard, and they become like a whistleblower,  
11 let's say. So how are they then protected? How does that  
12 work, and maybe James can help us with this. But how are  
13 they protected, if they have tried and they don't feel like  
14 they're heard, what are the options and -- so...

15 MS. ZYGMUNT: If I understand your question  
16 correctly, you know, staff are always welcome to approach  
17 their supervisor, section manager or me with concerns.  
18 Again, I take those concerns very seriously. I take their  
19 feedback very seriously. And, again, that is weighed into  
20 final decisions that are made.

21 I support open communication with staff, and they  
22 have an opportunity to provide their feedback. But, again,  
23 per the Environmental Quality Act, it is my authority as  
24 administrator to take all that feedback and make a final  
25 decision about the content of the rules that we bring



1 before you and then the content of the rules I recommend  
2 the Director move forward with the formal rulemaking.

3 So I think that's the best way I can answer your  
4 question, Lorie, is that --

5 ACTING CHAIR CAHN: I'm not sure that  
6 answers the question. So, you know, I know that  
7 whistleblowers are protected. So what if -- if something  
8 moves into that kind of a situation, where they're not  
9 feeling like they're heard and they want to, you know, go  
10 outside as a -- like whistleblowing -- whistleblowers are  
11 protected, at least federally. I don't understand how that  
12 works necessarily.

13 MS. ZYGMUNT: Okay. I understand your  
14 question. And I don't know if one of our attorneys can  
15 speak to state laws about whistleblowers. I don't have any  
16 further information at this point in terms of state laws.

17 BOARD MEMBER DEURLOO: James? James is the  
18 attorney; is that right?

19 ACTING CHAIR CAHN: James, can you weigh  
20 in, please?

21 MR. PETERS: Yeah, I'm not sure I have a  
22 whole lot to add at this -- as I understand, I think the  
23 question is if there's, you know, a member of staff that  
24 potentially has concerns with the rules and those concerns  
25 are raised in the appropriate channels. Is your question

1 what -- what is sort of the remedy if that staff member  
2 feels that those concerns haven't been heard? Am I  
3 understanding the question properly?

4 ACTING CHAIR CAHN: Yeah, that's correct.  
5 So if they're -- they become, let's say, a whistleblower --  
6 I'll just use that term, because we all understand what  
7 that means -- and they want to go outside of DEQ, come to  
8 the Board or whatever, is that -- are they protected or is  
9 that not allowed or -- I dont know how that works in the  
10 state of Wyoming.

11 MR. PETERS: That is a great question that  
12 unfortunately I'm not sure I'm able to provide a lot of  
13 color on at this point. But I think as Administrator  
14 Zygmunt mentioned, I think the -- you know, the appropriate  
15 process would be to run that through the agencies, up the  
16 chain of command, essentially, within the agency, within  
17 DEQ.

18 I know that doesn't directly answer your  
19 question, but I'm not sure I've got a whole lot to add, and  
20 I apologize at this point.

21 MS. ZYGMUNT: I know it's not answering  
22 your question directly, Madam Chairwoman, but I can assure  
23 you that it is my policy and the agency's policy to have an  
24 open chain of command, and we encourage that communication.  
25 There is a chance to provide input, but at some point if

1 the decision makers need to make a decision, documentwide,  
2 go through this process with the advisory board, public  
3 notices and the EQC to get further feedback on the rule.  
4 So recognizing broader concerns about whistleblowers, I  
5 think we avoid that situation by having the open chain of  
6 command that we do, and open communication that is  
7 supported by myself and the Director.

8                   ACTING CHAIR CAHN: And I appreciate that,  
9 but I would like maybe, James, you could get back to us on  
10 kind of whistleblower, you know, in the event that somebody  
11 doesn't feel heard, you know, going through the channels,  
12 what kind of protection, you know, there is for  
13 whistleblowers. Just if you can get back to us, James, on  
14 what happens in the state of Wyoming. I appreciate that.  
15 Thanks.

16                   MS. ZYGMUNT: Okay. We will go ahead and  
17 move on to the next agenda item, which will be Chapter 29.  
18 The Board has the proposed rule. Again, you will be  
19 pleased to note this is only a two-and-a-half-page rule, so  
20 it should be a fairly straightforward discussion, but we  
21 are looking forward to talking with you about this proposed  
22 rule.

23                   This is a new rule that establishes injection and  
24 closure fees associated with carbon sequestration  
25 facilities, also known as Class VI Underground Injection

1 Control Wells. Very simply put, carbon sequestration is  
2 the process of injecting carbon dioxide into underground  
3 geologic formations for purposes of long-term storage.

4 As a reminder, Wyoming is the second state in the  
5 nation to have primacy to permit these Class VI wells. We  
6 are very proud of that primacy. North Dakota is the other  
7 state. And the Board reviewed not too long ago Chapter 24,  
8 which is the rule we have to establish the Class VI  
9 permitting process.

10 Wyoming Statute 35-11-13 gives DEQ the authority  
11 to promulgate rules for these injection and closure fees.  
12 And these fees can include a per-ton injection fee or  
13 closure fee during the time that the owner or operator is  
14 injecting carbon dioxide.

15 The funds from the fees go into what is called  
16 the special revenue account, which is also authorized by  
17 statute. And those funds are to be used by the State after  
18 the site closes, the permit is terminated, and then the  
19 State is responsible for long-term monitoring, measurement,  
20 verification of the site. So the funds that go into the  
21 special revenue account are only used for that purpose.

22 Interest in carbon sequestration is high. We  
23 have received one application to date. We are anticipating  
24 more. Lily is fielding quite a few calls from interested  
25 companies, so we do feel it is important to get this rule

1 on the books to make sure once people start injecting, we  
2 are collecting the appropriate fees so we can fund that  
3 special revenue account so the state can do its job after  
4 site closure.

5 I will note that we did not receive any public  
6 comments on this rule. And, finally, I will note that we  
7 will propose a couple additional revisions to the rule  
8 today based on some legislation that was proposed this year  
9 and did pass. That legislation, without getting into too  
10 much detail, was related to long-term liability of these  
11 carbon sequestration sites. So not directly within the  
12 scope of our authority, but it is indirectly related to our  
13 permitting process and site closure, and indirectly related  
14 to these permit fees.

15 So based on some of these discussions that came  
16 out during that bill and its review, we have proposed a few  
17 additional minor revisions to our rule to further  
18 strengthen it with regards to the discussions about  
19 liability. That bill has not yet been signed. We do  
20 anticipate the governor will sign it. If the bill does not  
21 get signed, it is very easy for us to pull out that  
22 language as needed. So we'll pull that up on the screen  
23 and walk you through the additional language that we will  
24 add at that point.

25 But let me stop there, and let me turn it over to

1 Lily to walk through the rule and give you an outline how  
2 this process will go.

3 MS. BARKAU: Good morning. So I'm going to  
4 just walk through Chapter 29, Geological Sequestration  
5 Special Revenue Account Requirements. Starting with  
6 Section 1, I'll just give a brief overview of that  
7 particular section and ask if there's any questions that I  
8 can help clarify.

9 So in Section 1, this describes the authority of  
10 the regulations of the Environmental Quality Act that  
11 allows us to implement this rule.

12 Are there any questions on Section 1?

13 ACTING CHAIR CAHN: No.

14 MS. BARKAU: Section 2 provides definitions  
15 that are included in this rule that may need further  
16 clarification or definition for them, to include carbon  
17 dioxide stream, what a Class VI well is, and so forth.

18 Are there any questions on the definitions?

19 BOARD MEMBER DEURLOO: Madam Chair, I've  
20 got one, please.

21 On Class II well, it states "means any commercial  
22 or non-commercial well used to dispose of water or fluids  
23 directly associated with" and goes on. Water or fluids,  
24 there's -- I wonder if there would be any value just  
25 changing that to "material," so it includes "solid, gases,

1 and liquid." When you do inject down there, there's  
2 part -- it's getting into the minutia of the detail, but  
3 when you do an injection, whether it's CO2, water, or  
4 waste, or something like that, where there's inherently  
5 going to be gases, liquids, and solids in that waste. But  
6 if you only want water and fluids, that's what you get.  
7 But I wanted to have you consider changing it to  
8 "material."

9 MS. BARKAU: I think we can certainly take  
10 that back to consider it. However, this is a definition as  
11 provided by the Wyoming Oil and Gas Conservation  
12 Commission --

13 BOARD MEMBER DEURLOO: Okay. I wondered.

14 MS. BARKAU: -- which we are using their  
15 definition verbatim.

16 BOARD MEMBER DEURLOO: Fair enough. I'm  
17 fine with that.

18 MS. BARKAU: Section 3, Applicability.  
19 This chapter just applies to all owners, operators, and  
20 permittees of Class VI wells.

21 Pretty short section. Any questions on that?

22 BOARD MEMBER DEURLOO: That's the shortest  
23 section I've seen.

24 ACTING CHAIR CAHN: I would like to go back  
25 to the definition -- Definition, Section 2. Sorry.

1 MS. BARKAU: Okay.

2 ACTING CHAIR CAHN: Just minor editorials  
3 in carbon dioxide stream (a), is "any processing" and  
4 any -- the words "any substances," are those words  
5 necessary? And maybe, again, this is a definition from the  
6 legislature, and then we can't do anything with it. But I  
7 would -- I would say carbon dioxide stream means carbon  
8 dioxide plus associated substances derived from the source  
9 materials and process -- source materials, processing and  
10 substances added to the stream.

11 MS. ZYGMUNT: Madam Chairwoman,  
12 understanding the suggestion right now, that definition  
13 matches what we have in Chapter 24.

14 ACTING CHAIR CAHN: Okay.

15 MS. ZYGMUNT: I think we would be hesitant  
16 to reopen Chapter 24 to also change it there.

17 ACTING CHAIR CAHN: Sure.

18 MS. ZYGMUNT: But we can consider those  
19 proposed edits for a future time.

20 ACTING CHAIR CAHN: Yeah. That's fine.

21 MS. ZYGMUNT: Sure.

22 ACTING CHAIR CAHN: And then on (c)(i). I  
23 think there's an extra comma after geologic sequestration.  
24 So "Is not experimental in nature and injects carbon  
25 dioxide stream for geologic sequestration beneath the



1 lowermost formation..." I'm not sure between  
2 "sequestration" and "beneath" the comma is necessary. So I  
3 think it would read better without it.

4 MS. BARKAU: Again, that is one of those  
5 that matches the definition in Chapter 24.

6 ACTING CHAIR CAHN: That's fine. These are  
7 just editorial suggestions, so...

8 MS. ZYGMUNT: We will note that for the  
9 future.

10 ACTING CHAIR CAHN: Thank you. That's all  
11 I have on 2. Sorry.

12 And then -- does anybody have anything on 3 from  
13 the Board?

14 BOARD MEMBER COCHRAN: I have kind of a  
15 general comment, if I could.

16 On the fee, is that consistent with other  
17 injection wells?

18 MS. BARKAU: Currently Wyoming does not  
19 collect fees on our other UIC wells. I can only speak for  
20 Class I and V. I believe the Class III wells are  
21 associated with the mine permit under Land Quality  
22 Division. The Class II wells I'm not familiar if there is  
23 a fee associated with that, since that's under the old  
24 Wyoming Oil and Gas Commission.

25 BOARD MEMBER COCHRAN: So how is the fee

1 set, I guess?

2 MS. ZYGMUNT: Yes. Thank you for the  
3 question, and I think Lily will walk through that once we  
4 get into Section 4 --

5 BOARD MEMBER COCHRAN: Oh, okay. Sorry.

6 MS. ZYGMUNT: -- here, and she'll outline  
7 the process, and I think we may answer your question during  
8 that description.

9 MS. BARKAU: All right. Moving on to  
10 Section 4. These are the Requirements. This goes over how  
11 we will be collecting the fee and utilizing the fee.

12 So to begin with, we are proposing a seven cents  
13 per ton of carbon dioxide injected for the storage during  
14 the period of injection into the subsurface geologic  
15 formations. The fee will be based on reporting  
16 requirements outlined in our Water Quality Rules Chapter  
17 24.

18 The Administrator will provide written notice of  
19 the amount of the fees on an annual basis, and those fees  
20 are due upon receipt.

21 Failure to pay those fees is considered a  
22 violation of Chapter 24.

23 Once those injections cease and the Administrator  
24 receives a plugging and abandonment final report, the  
25 Administrator will assess any remaining fees for that

1 calendar year and provide written notice of those fees to  
2 be provided upon receipt.

3 No further fees are assessed for the special  
4 revenue accounts if injections are not occurring.

5 Upon site closure, the -- this is when use of the  
6 funds occur. An owner or operator may apply for site  
7 closure if they demonstrate the requirements of Section 24  
8 of Chapter 24. There's a pretty extensive list of  
9 requirements to receive site closure certification. We  
10 also will verify the release of all financial assurance  
11 instruments. Those financial assurance instruments are  
12 required during all phases of the carbon sequestration  
13 project. So bonds, liability insurance are required. They  
14 are returned to the owner or operator after the site is  
15 closed.

16 We will be discussing some edits to this section  
17 coming up in regards to the liability bill that's recently  
18 passed legislation, which also includes the transfer of  
19 title. But our primary -- primary focus is certification  
20 of site closure and issuance of a project completion  
21 certificate.

22 We will be evaluating the proposed cost estimate  
23 to ensure that the monies in the special revenue accounts  
24 are sufficient to address monitoring, measurement, and  
25 verification after site closure. Any funds that are needed

1 will be recommended to the director to require those  
2 additional fees.

3           And they will -- the owner or operator will need  
4 to make that additional payment prior to receiving their  
5 certificate of project completion, as well as certification  
6 of site closure.

7           Upon the conditions of site closure, then the  
8 Director will administer the funds in the account. And  
9 that is the process for developing and utilizing the  
10 special revenue accounts, and I'm open for questions now.

11           BOARD MEMBER COCHRAN: I'm good, thanks,  
12 Madam Chair.

13           BOARD MEMBER DEURLOO: Madam Chair, I have  
14 a few questions.

15           Seven cents for each ton, where did that amount  
16 come from?

17           MS. BARKAU: Yes. That amount is actually  
18 consistent with North Dakota, as mentioned the second state  
19 to have primacy. Their assessment came from a worst-case  
20 scenario of cleanup for a corrective action site or a state  
21 Superfund site of what it would take to address additional  
22 measures that are required.

23           BOARD MEMBER DEURLOO: So that calculation  
24 came from the state of North Dakota --

25           MS. BARKAU: Yes.

1 BOARD MEMBER DEURLOO: -- by way of  
2 consultancy, doesn't matter --

3 MS. ZYGMUNT: With our review.

4 MS. BARKAU: With our review.

5 MS. ZYGMUNT: Let me just take the seven  
6 cents. Lily had looked extensively at the research that  
7 North Dakota had completed, and we feel that it is  
8 appropriate for the same purposes here in Wyoming.

9 BOARD MEMBER DEURLOO: Okay. What's a  
10 typical well -- what's a typical CO2 well? I know they're  
11 different, like snowflakes, but how many tons can you put  
12 in a well per day?

13 MS. BARKAU: For example, as part of our  
14 valuation for the seven cents per ton, if we took a project  
15 that was going to be injecting 50 million tons over a  
16 25-year span, you would be looking at about 2 million tons  
17 per year. So the annual -- annual cost would be  
18 approximately \$140,000 per year, with -- at the end of the  
19 25 years you're looking at \$3.5 million to be included in  
20 the special revenue account.

21 While it's in the special revenue account,  
22 there's also interest. And at the end of the project, if  
23 we feel that the 3.5 million is not appropriate or  
24 sufficient based on cost estimates, we will require  
25 additional funds to be included. So a standard corrective

1 action project, a worst-case scenario, can range anywhere  
2 between \$1 million and \$5 million price.

3 BOARD MEMBER DEURLOO: That's just for  
4 plugging and abandonment of a CO2 -- or sequestration well.

5 MS. BARKAU: Excuse me, sorry. Plugging  
6 and abandonment is actually -- that occurs prior to site  
7 closure, and would not be included in this -- this cost.  
8 That cost would be directly paid for by the owner and  
9 operator --

10 BOARD MEMBER DEURLOO: Right.

11 MS. BARKAU: -- prior to site closure.

12 MS. ZYGMUNT: And if I may add to that. So  
13 just to remind the Board, we're talking very long time  
14 frames for Class VI permits.

15 BOARD MEMBER DEURLOO: Uh-huh.

16 MS. ZYGMUNT: Injection may occur for  
17 25 years. But before they can get to site closure, as Lily  
18 mentioned, Chapter 24 outlines some very robust procedures  
19 they have to follow after they cease injecting to get to  
20 site closure. And primarily using both modeling and  
21 data -- and this is further supported by requirements in  
22 the Environmental Quality Act, that they have to show at  
23 least three years consecutive -- three years of consecutive  
24 data that this plume is stable.

25 So by the time they get to site closure, by the

1 time they get to permit termination, it could be another  
2 50 years after site closure -- after they have ceased  
3 injecting. So we're talking about long periods of time.

4 But it's important that we get this injection  
5 fee, and that we get it right and we have the ability to  
6 require additional funds as needed at the cost estimate  
7 when they are putting in for site closure, because the  
8 State will be responsible for the long-term site care after  
9 the site closes and the permit is terminated.

10 So that's our goal is to ensure we have enough  
11 money in that account to carry out the activities the State  
12 will be responsible for in the long-term, which could be  
13 another 50 years after that. So we're talking about very  
14 long periods of time. Obviously none of us will be in our  
15 various positions at that time to make those decisions, but  
16 we are trying to set up the structure to ensure that funds  
17 are available. And the special revenue account was first  
18 envisioned by the 2019 carbon sequestration working group.  
19 That concept was ultimately put into statutes, now being  
20 put into rules. So for some context on the scope of time  
21 that we're looking at and why it's important that we get  
22 this funding and operate to the best that we can.

23 BOARD MEMBER DEURLOO: Thank you.

24 A follow-on question, Madam Chair.

25 Is there any value to indexing this cost per ton

1 to the consumer price index to allow for inflation and  
2 other things like that? I'm sure that's something you  
3 considered.

4 MS. BARKAU: Yes. That is actually  
5 incorporated into the cost estimates. So they're -- during  
6 the life of the project and the injection, they will be  
7 providing an annual cost estimate that includes inflation.  
8 So while the seven cents per ton is for the immediate use,  
9 that cost estimate for the site closure will account for  
10 inflation. And that's where if funds are insufficient at  
11 the end of the site closure, that cost estimate will be  
12 used to require that additional fund.

13 BOARD MEMBER DEURLOO: Thank you. I'm just  
14 trying to make sure we don't get in a pickle that we've  
15 been in in the past, with PNAs and all that stuff.

16 MS. ZYGMUNT: Understood.

17 BOARD MEMBER DEURLOO: I have other  
18 comments, but that's the only one on that one. Thank you.

19 ACTING CHAIR CAHN: Any other Board  
20 questions for Ms. Barkau?

21 BOARD MEMBER DEURLOO: Madam Chair, I have  
22 more comments on Number 4, if you want me to continue.

23 Okay. On 29-2, at the bottom of the page, I  
24 think it's letter (v), "consider project-specific risk  
25 assessments and projected timing of activities." Can we



1 just change that to schedule of activities or estimated  
2 schedule? That is a recommendation changing that. You can  
3 do with that what you may.

4 ACTING CHAIR CAHN: What line are you on?

5 BOARD MEMBER DEURLOO: The very bottom,  
6 (v).

7 ACTING CHAIR CAHN: What line number?

8 BOARD MEMBER DEURLOO: Oh, sorry. 91.  
9 Changing the words "projected timing" to "schedule of  
10 activities." Line number 94, on the next page (vi). It's  
11 a very weak statement, it reads basically the Administrator  
12 will "consider whether sufficient funds are available to  
13 carry out the required activities." I would make a  
14 recommendation that you consider changing it to stronger  
15 language like Administrator will "evaluate and make a  
16 determination whether the funds are sufficient to carry out  
17 the required activities."

18 MS. ZYGMUNT: Madam Chairwoman.

19 Recognizing the comment, and we're happy to consider  
20 stronger wording there, we do need to keep a delineation of  
21 duties in that the Administrator can only consider and  
22 recommend. It will be Director's responsibility to finally  
23 determine if there are sufficient funds or insufficient  
24 funds --

25 BOARD MEMBER DEURLOO: Okay.

1 MS. ZYGMUNT: -- as outlined under (g)  
2 there.

3 BOARD MEMBER DEURLOO: I see.

4 MS. ZYGMUNT: But if there is a better way  
5 to strengthen the Administrator's activity there, we -- we  
6 could say evaluate and consider whether sufficient funds  
7 are available. But, again, it -- my next step then would  
8 be to recommend to the Director, and then he will make the  
9 final decision.

10 BOARD MEMBER DEURLOO: I see. Okay. I --  
11 I like direct language, very direct and not passive, which  
12 most regulations are written, you get a bunch of passive  
13 verbs and so forth.

14 In any case, line number 103, it reads  
15 "...special revenue account to ensure that sufficient funds  
16 are available to carry out the required..." "Carry out,"  
17 I'd just change that to "execute the required activities."

18 And then line 104, following on there, it reads  
19 "...activities on the date at which they may occur." I  
20 see. So that holds -- that reads "ensure that sufficient  
21 funds are available to execute the required activities on  
22 the date in which they may" -- never mind. Okay. Strike  
23 my thought there.

24 Then the next line, 106, it says "Upon  
25 determining the special revenue account..." It seems to me

1 that would probably read better if it starts with "If the  
2 special revenue account balance, including accumulated  
3 interest, is sufficient to cover the proposed cost  
4 estimate," and then insert the word "'then' the Director  
5 shall administer the funds in the account..." So make it  
6 an if/then statement there. That's my only comments on  
7 Section 4.

8 MS. ZYGMUNT: Would you mind reading your  
9 proposed edits one more time? I didn't catch --

10 BOARD MEMBER DEURLOO: That last one?

11 MS. ZYGMUNT: Yes.

12 BOARD MEMBER DEURLOO: Yeah. Sure. So I  
13 would strike -- starting on line 106, strike "upon  
14 determining the" and insert the words If the carrying on  
15 special revenue account balance.

16 And then on line 107, between the word "estimate"  
17 and "the," where -- just put the word "then," t-h-e-n.

18 MS. ZYGMUNT: Okay. Thank you.

19 BOARD MEMBER DEURLOO: Thank you.

20 ACTING CHAIR CAHN: Are there any other  
21 questions from the Board or comments?

22 MS. ZYGMUNT: So before we wrap up the  
23 discussion, if we can show you the additional proposed  
24 language following discussion of the sequestration  
25 language.

1           Go ahead and go up to Section 1, make sure we  
2     have everything.

3           So first change would be simply updating your  
4     cross-reference. So the proposed legislation, the past  
5     legislation creates some new sections of statute. So we  
6     simply need to update the applicable sections of statute to  
7     this rule. So instead of just 313 to 318, we will add 319  
8     and 320.

9           ACTING CHAIR CAHN: Can you tell us what  
10    the title of those rules are?

11           MS. ZYGMUNT: I can. So Section 35-11-318  
12    will now be titled Sequestered and Injected Carbon Dioxide;  
13    Definitions.

14           The new Section 35-11-319 will be Certificate of  
15    Project Completion, Release, Transfer of Title and Custody.

16           And then Madam Chairwoman, the new Section 320 is  
17    the Geologic Sequestration Special Revenue Account,  
18    previously Section 318, now Section 320, with addition of  
19    the two other sections.

20           ACTING CHAIR CAHN: So 318 changed to  
21    Sequestered and Injected CO2?

22           MS. ZYGMUNT: Correct.

23           The next proposed revision we have added to the  
24    rule would be (iv), under (f), and it adds language that  
25    the Administrator shall "Verify that title to the stored or

1 injected carbon dioxide has been transferred to the State  
2 if a certificate of project completion has been issued."  
3 So this refers to a process in the legislation that  
4 establishes a certificate of project completion and just  
5 adds a step here for the Administrator to verify that the  
6 title has been transferred if that certificate has been  
7 issued.

8 BOARD MEMBER COCHRAN: Madam Chair, what  
9 title is that? That's not a surface title.

10 MS. ZYGMUNT: No. It would be title to the  
11 injected carbon dioxide.

12 BOARD MEMBER COCHRAN: It's like a  
13 subsurface ownership?

14 MS. ZYGMUNT: Correct.

15 BOARD MEMBER DEURLOO: Madam Chair. Just  
16 for clarity. The recommendation, can you scroll back up on  
17 that?

18 I might consider changing that around, again,  
19 just making it start with "If a certificate of completion  
20 has been issued, then the Administrator will verify that  
21 title to restore carbon --

22 THE REPORTER: I'm sorry. I can't hear you  
23 very well.

24 BOARD MEMBER DEURLOO: I'd just turn it  
25 around. My -- my exposition writer in high school would

1 say start with "If a certificate of project completion has  
2 been issued, then the Administrator shall verify that title  
3 to the stored or injected carbon dioxide has been  
4 transferred to the State.

5 ACTING CHAIR CAHN: We wouldn't put in  
6 "Administrator shall," because that's on line 78, and we  
7 don't need that.

8 BOARD MEMBER DEURLOO: Take it for what  
9 it's worth. I just recommended maybe turn that around,  
10 because you're hanging the action on the end of it.

11 ACTING CHAIR CAHN: So it would just be, If  
12 a certificate of project completion has been issued, verify  
13 that title -- or verify title to the stored or injected --

14 BOARD MEMBER DEURLOO: Has been transferred  
15 to the State.

16 ACTING CHAIR CAHN: -- has been transferred  
17 to the State.

18 MS. ZYGMUNT: Yeah, we don't have any  
19 concerns if you prefer moving that "if" statement to the  
20 beginning, and the action's still "Administrator verifies."

21 BOARD MEMBER DEURLOO: Yes, please.

22 MS. ZYGMUNT: Okay. Then moving on the  
23 next change. Under (g), adding (ii), The Department shall  
24 not issue a certificate of project completion, if we  
25 determine that there are insufficient funds in the special

1 revenue account.

2           So, again, this is just an additional way to  
3 strengthen this rule, meaning that if we do not feel we  
4 have enough funds in that account for the State to do its  
5 job after site closure, we would not issue a certificate of  
6 project completion, and the injector would remain liable  
7 for future activities. So just an additional way to  
8 strengthen our ability to make sure that all requirements  
9 have been met before liability is transferred to the State  
10 and the State begins its activities of long-term site care.

11           BOARD MEMBER DEURLOO: Madam Chair. And to  
12 be clear, as far as somebody in the industry disagrees with  
13 your assessment, how would they contest that? Would they  
14 take that to the EQC, or how would that be contested?

15           MS. ZYGMUNT: Yes. That's a good question.  
16 And, you know, during this stage, during the review where  
17 they have submitted a site closure plan, and we're  
18 reviewing that to make sure they have met all requirements  
19 of Chapter 24 I think inherent in that process, there would  
20 be discussion with the company if we had concerns. I think  
21 there would be ample opportunity to go back and forth with  
22 that company to document our concerns, see if they can  
23 provide more information. There are many public comment  
24 opportunities during that process as well.

25           BOARD MEMBER DEURLOO: Okay.

1 MS. ZYGMUNT: So that would be another way  
2 to formally document concerns. But then the next answer  
3 would be yes, if we make a formal decision, it would be  
4 appealable to the Environmental Quality Council.

5 BOARD MEMBER DEURLOO: Got it. Thank you.

6 MS. ZYGMUNT: And then last but not least,  
7 under (h), simply updating the statute reference there,  
8 35-11-318 to 320.

9 So Madam Chairwoman, that concludes the  
10 additional revisions we're proposing for Chapter 29.

11 ACTING CHAIR CAHN: Any further Board  
12 discussion?

13 How about members of the public? Is there  
14 anybody in the public that would like to comment?

15 Hearing none, I'll entertain a motion.

16 BOARD MEMBER DEURLOO: Can I ask one more  
17 question, Madam Chair, please? I wrote it on the front  
18 page, and so I forgot to look at it.

19 You said this is becoming more -- this is  
20 becoming maybe popular, that sequestration. Is there a  
21 carbon -- just out of curiosity, is there a carbon credit  
22 scheme that we're working with in the state that's going to  
23 incentivize or entice industry to inject CO2 in this state,  
24 or is there something that's going to drive this?

25 MS. ZYGMUNT: Madam Chairwoman. That's a



1 great question. I believe so. I am not up to speed on  
2 those discussions. I have heard some discussions about  
3 carbon credit markets. I believe Wyoming Energy Authority  
4 would be the better agency to reach out to for more  
5 information. I know we saw at the -- we saw some proposed  
6 legislation early on about carbon credit markets. At this  
7 time, I'm not aware of any further structure, but Lily's  
8 looking at me in a way she may know more than I do. So  
9 I'll let her speak.

10 MS. BARKAU: Madam Chair. So the carbon  
11 credit incentive is being somewhat discussed from the  
12 Wyoming Business Council and the Wyoming Energy Authority.  
13 But in regards to incentives, there is a tax credit called  
14 45Q that is based on -- currently, it's \$50 per ton for  
15 injections over 12 years. Then the current -- there's --  
16 there are current discussions at the federal level to  
17 increase that to possibly \$85 per ton. So lots of  
18 incentives there. For enhanced oil recovery it's about  
19 \$35 per ton. So the incentives are higher in regards to  
20 the storage.

21 BOARD MEMBER DEURLOO: Follow-up question.  
22 So we're charging seven cents, and they're going to get an  
23 80 -- \$50 -- so I can see the incentive for sure.

24 Okay. Well, in the world of -- I'm an industry  
25 rep, so I can't -- I need to be careful how I state this.

1 But, you know, the boom and bust economy, that's not a bad  
2 idea to store up when you can. I'll leave it at that.

3 MS. ZYGMUNT: Well, and if I can add a  
4 comment. Again, when the operator is injecting, they have  
5 to carry significant financial assurance.

6 BOARD MEMBER DEURLOO: Absolutely.

7 MS. ZYGMUNT: Have to carry -- it's a very,  
8 very robust procedure for them to do risk assessment and  
9 establish bonds and financial assurance during the time  
10 they are ability and responsible during the permit term.

11 And, again, this special revenue account is just  
12 funding for long-term maintenance of that site. And I just  
13 wanted to note that because there was confusion as we  
14 worked through this discussion during legislature. The  
15 special revenue account isn't the sole financial backup.  
16 During the time they are carrying an active permit, they  
17 have to carry financial assurance for any unforeseen  
18 circumstances. I know that doesn't directly address your  
19 questions, but it -- there are I think some very well  
20 thought-out processes in terms of the financial  
21 responsibility of the company while they're injecting, and  
22 then what the role of the special revenue account is.

23 BOARD MEMBER DEURLOO: I understand.

24 MS. ZYGMUNT: Again, we think seven cents  
25 per ton is appropriate, but, again, this is going to be a

1 long-term process. And if we have reason to believe in the  
2 future that's not sufficient, I would imagine we'll be back  
3 before you with rules revisions at that time.

4 BOARD MEMBER DEURLOO: I've connected the  
5 dots in my head. Thank you.

6 ACTING CHAIR CAHN: Where are the fees  
7 assessed? The seven cents, where is that written in the --

8 MS. ZYGMUNT: So Madam Chairwoman, the  
9 process, as outlined, again we have the seven cents per ton  
10 established in the rule. Per reporting requirements under  
11 Chapter 24, two times per year they need to submit a report  
12 to us that will tell us how many tons of carbon dioxide  
13 they've injected. So once per year we will send them an  
14 invoice just multiplying that per-ton fee times the number  
15 of tons to come up with the assessed amount that they need  
16 to pay for that calendar year.

17 ACTING CHAIR CAHN: So to change that fee,  
18 then you come back before the Water and Waste Advisory  
19 Board to go out.

20 MS. ZYGMUNT: Correct. It would be a rule  
21 revision that we would bring before the Board, per our  
22 normal procedure.

23 ACTING CHAIR CAHN: Thank you.

24 BOARD MEMBER DEURLOO: I have no further  
25 comments, Madam Chair. Thank you.

1 BOARD MEMBER COCHRAN: I'm good.

2 ACTING CHAIR CAHN: Any more Board  
3 questions? Discussions?

4 Hearing none, I'd entertain a motion.

5 BOARD MEMBER DEURLOO: Let's see what to --  
6 let's discuss what we want to move here.

7 ACTING CHAIR CAHN: I'm assuming you would  
8 like to have us recommend that this go forward to EQC, with  
9 the suggested changes that you have made and not  
10 necessarily -- you'll look at the changes we suggested, but  
11 some of them can't be done. So without the ones that would  
12 affect the def -- or discussions of other rules.

13 I think Brian had some moving, and you have some  
14 changes. So I'm assuming that's what you're looking from  
15 us is a motion that would move this forward with the  
16 changes as discussed to EQC.

17 MS. ZYGMUNT: That is correct.

18 BOARD MEMBER DEURLOO: Okay. I move that  
19 we approve this -- we approve Chapter 9 to be forwarded to  
20 the Environmental Quality Council with the suggested  
21 changes from this Board, as well as the additions to the  
22 chapter as they may become necessary through new  
23 legislation.

24 ACTING CHAIR CAHN: And I would just  
25 discuss our Board cannot approve, so I would just change

1 the language you used to recommend.

2 BOARD MEMBER DEURLOO: Fair enough.

3 BOARD MEMBER COCHRAN: I would second.

4 ACTING CHAIR CAHN: Any further discussion?

5 I have a motion on the table. All in favor say aye.

6 BOARD MEMBER COCHRAN: Aye.

7 BOARD MEMBER DICKSON: Aye.

8 BOARD MEMBER DEURLOO: Aye.

9 ACTING CHAIR CAHN: Aye.

10 Motion carries. Thank you.

11 MS. ZYGMUNT: Madam Chairwoman, next on the  
12 agenda would be about a 20-minute presentation from Lindsay  
13 Patterson and David Waterstreet about Chapter 1. We can  
14 continue on. Lindsay and David are joining virtually. We  
15 can start that presentation now or we can take a break.

16 ACTING CHAIR CAHN: I would like a  
17 five-minute break, if we could. So we'll come back at  
18 10:15.

19 (Meeting proceedings recessed  
20 10:08 a.m. to 10:17 a.m.)

21 ACTING CHAIR CAHN: We're back on the  
22 record. And Lindsay Patterson will be giving us a  
23 presentation on Water Quality Rules Chapter 1. Thank you.

24 MS. ZYGMUNT: Go ahead and take it away,  
25 Lindsay.

1 MS. PATTERSON: Thanks. Good morning,  
2 Madam Chairwoman, Member of the Board and everyone else in  
3 attendance. I'm Lindsay Patterson, as they mentioned.  
4 Hopefully you can hear me okay. Please let me know if you  
5 cannot hear me. Okay. Speak louder?

6 BOARD MEMBER DEURLOO: No. You're good.

7 MS. THOMPSON: You're good.

8 MS. PATTERSON: Okay. Sorry. Your thumbs  
9 are small.

10 Yes, it's good to see many of you, familiar  
11 faces, and I'm looking forward to talking to the Water  
12 Quality Standards with you today and a bit more as time  
13 goes on. We just wanted to give you very high-level  
14 overview of the Water Quality Standards. None of the  
15 specifics yet. We're still in the process of developing  
16 proposed revisions, so hopefully this will help set the  
17 stage for our later conversations.

18 So at their most basic, the Surface Water Quality  
19 Standards, they provide water quality protections for all  
20 Surface waters of the state. So those are from our  
21 smallest ephemeral streams, you know, up to our largest  
22 rivers and reservoirs. So the primary ways that we use the  
23 surface Water Quality Standards are to develop effluent  
24 limits for point source discharges. Those are captured,  
25 the rules in Chapter 2, for instance.

1           And then to develop best management practices for  
2 nonpoint sources of pollution. And we used standards to  
3 determine attainment, whether the standards are being met  
4 or not. And in cases where the standards are being met, we  
5 can use them for protecting our surface waters to make sure  
6 that they stay that way. And if the standards are not  
7 being met, we can use them to -- for restoration planning.

8           So that would identify do we need to revise the  
9 effluent limits that we have for the existing point  
10 sources? Do we need additional or new best management  
11 practices? So those are the primary ways that we are using  
12 the standards. So like many of the other rules that you  
13 guys are talking about that implement both federal and  
14 state regulations, so the Environmental Quality Act, you  
15 guys are well aware, lays out the Administrator will make  
16 recommendations to the Director, specifically related to  
17 Water Quality Standards, the federal Clean Water Act and  
18 implementing regulations for the Clean Water Act, those  
19 provide a lot of the framework for the Water Quality  
20 Standards, sort of the essential elements. So when we  
21 develop the standards, we're going to keep an eye towards  
22 both the Environmental Quality Act and federal Clean Water  
23 Act.

24           So the Clean Water Act lays out a couple of  
25 unique elements that are maybe a little different than the

1 other chapters that you see. So the Clean Water Act  
2 requires that we review our Water Quality Standards at  
3 least every three years. That's known as triennial review.  
4 So we'll hear that word constantly when we talk about  
5 revising Water Quality Standards, only to come to visit you  
6 guys fairly frequently as we adhere to the requirements in  
7 the Clean Water Act.

8           And the Clean Water Act also has an EPA approval  
9 process associated with it, which does make it a little bit  
10 different. The Clean Water Act lays out that states need  
11 to submit their Water Quality Standards for EPA review, and  
12 that the Clean -- the standards aren't effective for Clean  
13 Water Act purposes until they're approved by EPA. And then  
14 in circumstances is where the standards fail to meet the  
15 requirements of the Clean Water Act, EPA can promulgate  
16 standards for states.

17           So back to the framework provided by the Clean  
18 Water Act and the implementing regulations essentially lay  
19 out that the standard should include three main components.  
20 Those are designated uses, water quality criteria, and  
21 antidegradation provisions. And then implementing  
22 regulations you also talk about the standards can include  
23 implementation methods. So we'll walk through each of  
24 these different components.

25           So the designated uses in the Water Quality



1 Standards are essentially what uses we have for the waters,  
2 what goals we establish, and they may not be goals that the  
3 water body is currently achieving. And Clean Water Act use  
4 this terminology of attainment, so they make -- these goals  
5 may not currently be attained.

6           So in Wyoming, the way that our rules are  
7 structured, we have the designated uses laid out across the  
8 top of this table. Drinking water. We have a game fish  
9 use that includes cold water and warm water subcategories.  
10 We have a nongame fish use, a fish consumption use,  
11 aquatic -- other aquatic life. We have recreational uses  
12 to subcategories, primary contact and secondary contact,  
13 wildlife, agriculture, industry, and scenic value uses. So  
14 those are our designated uses in Wyoming.

15           And then we apply those designated uses to  
16 surface waters using a classification system. So you can  
17 see the classes down the left side of the table. So  
18 there's 13 different classes in our Water Quality  
19 Standards. And essentially you can identify which  
20 designated uses apply to particular water bodies if you  
21 know the classification. So if a water body is a 2AB, warm  
22 water, you know, it's designated for drinking water, warm  
23 water game fish, nongame fish, consumption, and so on. So  
24 it's a good way to, you know, sort of structure the  
25 standards so you don't have to list out all of these uses.

1           So the way that the standards lay out of how you  
2 will identify which designated uses, which classifications  
3 apply to particular water bodies is in the Wyoming Surface  
4 Water Classification list. So it's a large document that's  
5 outside of the Chapter 1 -- outside of the rule, that --  
6 here's an example. You can see from the Belle Fourche  
7 drainage, you can see that the Belle Fourche River is  
8 designated as a 2AB warm water, so we know what uses are  
9 assigned to that particular water body based on its  
10 classification. And you can see some of the tributaries to  
11 the Belle Fourche River, Owl Creek, Crow Creek, they're 3B  
12 waters, so we know what designated uses apply to those  
13 designated water bodies.

14           So the Water Quality Standards also lay out the  
15 process for modifying designated uses and provide a process  
16 for the administrator to add or remove uses or to change a  
17 classification after taking public comment, and then also  
18 after completing a use attainability analysis, which is  
19 required under the Clean Water Act. Essentially,  
20 scientific assessment of the factors that affect attainment  
21 of uses. The Clean Water Act regulations lay out six  
22 different factors that you can use to modify uses. And so  
23 those are part of the UAA, use attainability analysis,  
24 process.

25           The regulations also lay out that at a minimum,

1 we have to protect existing uses on a water body. So if  
2 there is aquatic life in a water body, it has to be  
3 protected. That's just sort of as a minimum bar. And  
4 other requirements that we have to take into consideration,  
5 attainable uses.

6 And then just like the Water Quality Standards,  
7 many changes to designated uses are submitted to EPA as a  
8 revised Water Quality Standard. It's just that that  
9 process can happen outside of the rulemaking process, and  
10 you can make updates to that classification list outside of  
11 the rulemaking process.

12 So now that we've covered very briefly designated  
13 uses, we'll move on to water quality criteria. So water  
14 criteria also specified in Chapter 1 are the concentrations  
15 of pollutants or narrative statements that we have in the  
16 standards that are directly assigned with the designated  
17 uses. So we have these criteria that have to protect the  
18 designated uses. In some cases, it's not going to be  
19 appropriate for us to develop numeric criteria, like  
20 concentrations of pollutants. We're going to use a more  
21 general narrative for statements of things that might be  
22 more challenging to derive a specific numeric threshold to  
23 protect the use.

24 So similar to designated uses, water quality  
25 criteria can also be modified, and that's laid out in

1 Chapter 1. And that process, similarly the Administrator  
2 may make recommendations to the Council, but unlike  
3 designated use changes, which can occur outside of the  
4 rulemaking process, water quality criteria changes are made  
5 through the rulemaking process. But similar to designated  
6 use changes, they require the completion of a use  
7 attainability analysis because the water quality criteria  
8 and designated uses are so closely coupled they have to  
9 basically mirror one another. So if you're modifying the  
10 criteria you want to make sure that it's protective of an  
11 attainable use.

12 So that's criteria. And so moving on to  
13 antidegradation provisions. These are essentially the  
14 provisions in the Water Quality Standards that are intended  
15 to maintain and protect the water uses and water quality.  
16 They do provide for a lower net water quality, but only in  
17 certain circumstances. And these provisions are there to  
18 help meet, you know, the requirements of the Clean Water  
19 Act to restore and maintain water quality.

20 So there's three different tiers of  
21 antidegradation that are laid out in the federal  
22 regulations that are repeated in the Water Quality  
23 Standards. So Tier 1 are existing use protections. Tier 2  
24 are high-quality water protections. And then Tier 3 are  
25 existing water quality protections. And I'll just explain

1 each of those in turn so, again, we have kind of that basic  
2 understanding.

3           So the existing use protection -- some of this  
4 can get a little confusing, existing uses, existing  
5 quality, but hopefully this will make it clear. So  
6 existing use protection, basically the Clean Water Act lays  
7 out if a use exists on a water body or has existed since  
8 November 28 of 1975, we need to maintain that use and the  
9 level of water quality that's necessary to protect that  
10 use.

11           And this is sometimes considered kind of the  
12 floor of water quality protections, meaning that we can't  
13 go below that. That's kind of the minimum bar. We always  
14 have to protect that. And it applies to all waters  
15 regardless of, you know, what designated uses there are or  
16 what water quality criteria are applicable.

17           So the second Tier, the Tier 2, are high-quality  
18 water protection. It's a little bit different. It is  
19 specific to situations where the water quality is better  
20 than the Water Quality Standards, and so the intention here  
21 is to maintain that higher water quality except in  
22 circumstances we've gone through, basically a process to  
23 determine that lowering the water quality is going to be  
24 beneficial, you know, for some economic or social  
25 development as occurring in the area. So in that, water

1 quality is really necessary.

2           So in Wyoming, we apply that to all waters that  
3 are designated for drinking water and for fisheries. So  
4 that's our Class 2 waters. States can do it differently.  
5 They can apply it on a water-body-by-water-body basis.  
6 They can do it on a parameter-by-parameter basis. But in  
7 Wyoming we apply it to Class 2 waters. And so those water  
8 bodies are going to require an additional level of review  
9 before allowing new or increased sources of pollution.

10           So Tier 3 are existing quality protections. So  
11 this, again, will layer on top of the existing use  
12 protection. So existing quality protections are specific  
13 to water quality that was present at the time the water  
14 body was designated. So in Wyoming we apply these to our  
15 Class 1 waters.

16           These are Class 1 waters, otherwise known as  
17 outstanding aquatic resources in our policies. These  
18 waters are specifically designated by the Environmental  
19 Quality Council because they're, you know, something  
20 special in the state. They want to have unique protections  
21 applied to them and there's a number of levels of  
22 protection that are applied in the Water Quality Standards  
23 to make sure that we're maintaining the quality. So not  
24 just the uses, we have to maintain the water quality at the  
25 time it was designated.

1           So examples of these are things, like in Wyoming,  
2 national park waters are all Class 1 waters. Wilderness  
3 waters, as of 1999, those are all Class 1 waters, as are a  
4 number of other water bodies in the state that were  
5 specifically designated. I think the most recent  
6 designation happened around 1990. So that's our Class 1  
7 existing quality protections.

8           So now we've covered the three main components of  
9 Water Quality Standards laid out in the Clean Water Act and  
10 implementing regulations. The last component is  
11 implementation methods, which our water quality standards  
12 also include, but essentially these are the provisions that  
13 affect the enforcement application, you know, execution of  
14 surface Water Quality Standards.

15           So in our rules that includes things like how we  
16 are enforcing the standards. We have sections on mixing  
17 zones, testing procedures, how we determine, you know,  
18 flow, or developing effluent limits or looking at  
19 evaluating the standards, credible data requirements,  
20 something that comes over from the Environmental Quality  
21 Act, discharges of specific variances, something that's  
22 laid out until the federal regulations that we also provide  
23 a mechanism in our Water Quality Standards to do these  
24 time-limited modifications to the standards.

25           So that covers the main components of the Water

1 Quality Standards in the Clean Water Act and from the  
2 Environmental Quality Act. In terms of where we are in the  
3 rule revision process, we're currently determining kind of  
4 a scope, and we're working on a draft. I think Jennifer  
5 mentioned at the outset we're expecting the revisions to be  
6 substantive, as you guys have been seeing with your images.  
7 So we want to take our time, make sure, you know, we're  
8 proposing what we feel are appropriate revisions at this  
9 time to address comments that we've received through the  
10 scoping process from the Attorney General's Office.

11           Once we have a solid draft we'll do, you know,  
12 more internal review, make sure that the, you know, users  
13 of the Water Quality Standards are comfortable with the  
14 revisions that we're proposing, you know, make sure that we  
15 haven't overlooked any potential implications of what we're  
16 proposing. So we're looking forward to, you know, getting  
17 additional feedback from other staff.

18           We will have an EPA consultation. As I  
19 mentioned, EPA has a pretty critical role in the  
20 development, adoption, and approval of Water Quality  
21 Standards, so we'll involve them in the process as well.

22           Once we have a proposed draft, we'll come back to  
23 you guys at the advisory board for additional updates,  
24 probably, on more specifics with what we're proposing to  
25 change. And then at some point we will go through a formal



1 comment period and bring the proposed revisions before the  
2 Board.

3 So that is where we are with Chapter 1. I'm  
4 happy to answer any questions that you have.

5 MS. ZYGMUNT: Great. Thank you very much,  
6 Lindsay.

7 Let me first ask, if I may, David Waterstreet,  
8 whom you all know -- David, do you have any further  
9 comments you'd like to provide to the Board at this time?

10 MR. WATERSTREET: Not really particularly.  
11 The only thing I will comment on is the fact that you  
12 really have received just a very high level, a lot of  
13 generalities that is really the top level of our Water  
14 Quality Rules and Regulations. We will be bringing this  
15 back to you with much more detail, and we will make sure to  
16 provide the opportunity for you to get a good understanding  
17 of the rule before we start making decisions. So we'll be  
18 working with Jennifer on that.

19 But in the meantime, we wanted to just begin your  
20 thought process and just let you start to -- for those that  
21 have been familiar with our water quality rules, we do this  
22 on periodic basis. We wanted to give you a heads-up that  
23 we are in development right now. And that's all I have,  
24 Jennifer.

25 MS. ZYGMUNT: Thanks, David.

1           So great presentation, Lindsay. And, again,  
2 there is a lot packed into this rule. It is a very  
3 foundational rule for us. Decisions made in this rule  
4 affect other programs, primarily the point source discharge  
5 permitting program, WYPDES program. So, again, just an  
6 opportunity to get these terms out there. Again, start  
7 outlining the scope of what we'll be looking at before we  
8 bring the revisions to you.

9           Lindsay, David and others have done some very  
10 critical thinking and some very creative thinking on how do  
11 we best develop and revise Chapter 1 to make it more useful  
12 to ourselves and the public. So I'm excited to bring  
13 before you once we work through internal process and we'll  
14 continue with some 101, again, because there is so much of  
15 this rule that affects decisions for the state.

16           Any questions for Lindsay or David or thoughts on  
17 this chapter that we can answer for you now?

18           BOARD MEMBER COCHRAN: Madam Chair. I just  
19 have one question. Are there any new pollutants that you  
20 guys are considering standards for?

21           MS. PATTERSON: Yeah, that's a great  
22 question. We are -- because of the substantive nature of  
23 the changes, we're hoping to minimize the changes to the  
24 water quality criteria at this time, at least based on our  
25 initial discussions. So we want folks to be focused on

1 just, you know, the sort of content rather than the  
2 potential implications. We're trying to minimize the  
3 implications of the changes.

4 MR. WATERSTREET: And I'll just add, that's  
5 our beginning point. So for context, EPA provides guidance  
6 on values from time to time, and they have provided  
7 guidance on some criteria. However, we take that very  
8 seriously. We want to make sure we evaluate those very  
9 thoroughly. And then like Lindsay just mentioned, we do  
10 have some other substantive components of the rule that  
11 we're really wanting to focus on at this time. However, as  
12 we -- as we, Lindsay and myself, propose this up to  
13 Jennifer, we will have further conversation on the timing  
14 of the addressing any values that we have received as  
15 guidance from EPA.

16 ACTING CHAIR CAHN: So I have a question.  
17 If you find a stream that has been degraded since the last  
18 triennial review -- hard to say that -- would you then make  
19 changes to the designated uses, or would there be changes  
20 to the use attainability analysis? Because that was all  
21 fairly new three years ago, I think. The last time we did  
22 this, I think, is when I first saw that use attainability  
23 analysis, I think.

24 MS. ZYGMUNT: Sure. I'll take the first  
25 stab at answering that, and I think Lindsay can add more.

1 We've had use attainability analysis for years and years  
2 and years. It's kind of an evolving process in how we go  
3 about determining those. They can be challenging. In  
4 terms of if we monitor water body and decide that it's  
5 impaired or degraded and is not meeting standards, it goes  
6 on the 303(d) list, after which we then would pursue some  
7 kind of watershed planning effort, total maximum daily  
8 load, and then implement changes to point sources and  
9 nonpoint sources to address that, but in some cases we  
10 could consider site-specific criteria or looking at a UAA  
11 to make sure that they're appropriate designated uses. But  
12 Lindsay, help me out with the response there.

13 MS. PATTERSON: Sure. Yeah, are you  
14 talking, Lorie, about -- I'm sorry, Madam Chairwoman,  
15 apologies -- situations where water body may have changed  
16 since the uses were changed or --

17 ACTING CHAIR CAHN: Yeah, if -- you know,  
18 if you find a stream or a water body is becoming degraded  
19 by the uses that have been designated for it, what's the  
20 process for going about getting that changed if that -- is  
21 that going to be part of this triennial review or --

22 MS. PATTERSON: Yes. So we're required to  
23 review all the Water Quality Standards every three years.  
24 So when we solicit public comment, we open it up so that  
25 people can provide information. We wouldn't want to modify

1 the designated uses if a water body just had become  
2 degraded, you know, we would want to maintain the uses,  
3 whatever is attainable as part of the standards. So like  
4 Jennifer mentioned, if a water body is just degraded from a  
5 point source to nonpoint source, that's something we would  
6 want to address through our integrated report process,  
7 develop some kind of restoration plan for the water body.  
8 If through some other information you determine that the  
9 uses needed to be modified because of, you know, maybe it's  
10 hydrologically modified or, you know, something that  
11 prevents the water body from attaining the uses, that's  
12 where we would go in and modify the uses through the Water  
13 Quality Standards.

14 ACTING CHAIR CAHN: And how -- I'm not sure  
15 how to word this question. How much enforcement, like  
16 checking up on water bodies or enforcement, or is it more  
17 based on -- on -- let's see. Do you have a set number of  
18 streams or water bodies that you would go to to check, or  
19 do you rely on somebody providing information to you that  
20 there's a problem?

21 MS. ZYGMUNT: Yes, Madam Chairwoman.  
22 That's a great question. And that could probably be a  
23 whole separate presentation that David can have his staff  
24 put together in our surface water monitoring program. In  
25 summary, though, they do some random probabilistic surveys

1 to kind of get a high-level sense of what's going on in the  
2 basin, and then we also do targeted studies to assess water  
3 bodies and whether or not they're meeting their uses.

4 Those assessments are, you know, pretty in-depth  
5 studies, but then we also consider data collected by other  
6 entities around the state. Conservation districts may  
7 collect data. USGS, we look at their monitoring data. So  
8 that's a great question.

9 And we, as a part of the 101 that we provide you  
10 on Chapter 1, we can have Jeremy Zumberge speak. He's our  
11 surface water monitoring program manager and might be able  
12 to give you better review about how we look at the state  
13 and do these assessments.

14 David, feel free to add anything here if you'd  
15 like to.

16 MR. WATERSTREET: Just two minor points  
17 that I'll add. And in addition to what Jennifer mentioned,  
18 we do also have compliance and enforcement permitting  
19 program that also guides us in the condition of any  
20 particular stream. And then, yes, we do also take  
21 complaint calls. They're probably -- we probably get, I  
22 don't know, one or two a month during the warmer season.  
23 Sometimes they pick up, sometimes they slow down, but they  
24 also inform us how to proceed with monitoring streams.  
25 They don't directly correlate with our development of Water

1 Quality Standards. All of this information can help inform  
2 us as to the condition of our waters, which in --  
3 adjacently, it also helps Lindsay, when she's preparing her  
4 water quality rules and regulation.

5           However, we do have a lot of waters that are  
6 being monitored on an annual basis through a number of  
7 programs and number of stakeholders.

8           ACTING CHAIR CAHN: So, for example, if you  
9 know, a place where people are going, a pond where people  
10 go in the summer to bathe, swim, play with the kids, or  
11 whatever, got overlooked as a place that was for contact,  
12 and, you know, is full of livestock or something, what  
13 would be the process for getting that re-looked at as a  
14 contact?

15           MS. ZYGMUNT: Yeah, I think if there's a  
16 water body where the public has concerns, particularly in  
17 that example, for public health from recreation exposure.  
18 You know, one step is contact us, and we can look to see if  
19 we have any data, and, you know, discuss the situation and  
20 see if we have monitoring staff that we can go out to  
21 collect some data, or that is where, for example, the  
22 conservation districts often fill that role within a local  
23 area. Conservation districts have very active and  
24 monitoring for recreation use within their boundaries, and  
25 it could be a situation where the conservation district

1 provides some help to better assess whether there is a  
2 public health risk.

3 ACTING CHAIR CAHN: Thank you.

4 BOARD MEMBER DEURLOO: Madam Chair, I've  
5 got a question.

6 Will there be -- Lindsay, this is Brian Deurloo.  
7 Will there be any -- as you go through this assessment, are  
8 we going to look at trash in streams, stuff like that? I  
9 mean, we look at -- we look at selenium and sediment and so  
10 forth, but oftentimes trash is overlooked. Crow Creek is a  
11 perfect example. Killpecker Creek down in Sweetwater  
12 County. Would we be looking at that or not?

13 MS. PATTERSON: Yeah, we currently have  
14 narrative water quality criteria that address solid waste  
15 in our surface waters. So, yeah, we'll be looking at all  
16 of the narrative and numeric criteria that apply as part of  
17 the revision.

18 BOARD MEMBER DEURLOO: Good. Thank you.

19 MS. ZYGMUNT: Any further questions?  
20 Otherwise, just know that we'll continue on with this 101  
21 effort so that when we do provide a draft rule before you,  
22 it should facilitate the review and understanding of what  
23 we're trying to accomplish.

24 BOARD MEMBER DEURLOO: Thank you.

25 MS. ZYGMUNT: All right. Thanks, David and



1 Lindsay.

2 MR. WATERSTREET: Thank you, everybody.

3 BOARD MEMBER DEURLOO: Thank you.

4 MS. PATTERSON: Thank you.

5 MS. ZYGMUNT: Madam Chairwoman, are we good  
6 to continue on?

7 Okay. I will bring up additional staff, and  
8 we'll move on to the final business item of the day, which  
9 is Chapter 12.

10 ACTING CHAIR CAHN: While staff is coming  
11 up here, I believe I -- my question about whistleblower was  
12 probably misspoken. It was brought to my attention  
13 whistleblower, I wasn't using it in the right context.  
14 It's probably more for situation of some -- if somebody is  
15 doing something illegal and so it's -- I certainly don't  
16 mean at all to imply that anybody's doing anything illegal  
17 or there's a whistleblower. So I apologize. I don't think  
18 I understood the -- what a whistleblower really is. So my  
19 apologies. We can ignore --

20 MS. ZYGMUNT: Thank you for the  
21 clarification.

22 BOARD MEMBER DEURLOO: Squeaky wheel,  
23 maybe?

24 ACTING CHAIR CAHN: Yeah, more squeaky  
25 wheel than whistleblower.

1 MS. ZYGMUNT: Great. Thank you for the  
2 clarification.

3 ACTING CHAIR CAHN: I apologize for that  
4 misunderstanding on my part, so...

5 MS. ZYGMUNT: Thank you. And again, we're  
6 committed to having discussions with any of you guys, so  
7 please, please reach out if we can be of help.

8 Oh, Madam Chairwoman, we could use about a  
9 five-minute break, if folks need to use the bathroom and  
10 get some water, and that way we can switch screens to the  
11 different presentation.

12 ACTING CHAIR CAHN: Okay. We'll convene at  
13 five minutes to 11:00.

14 (Meeting proceedings recessed  
15 10:48 a.m. to 10:58 a.m.)

16 MS. ZYGMUNT: Madam Chairwoman, are you  
17 ready to proceed?

18 ACTING CHAIR CAHN: Yeah.

19 MS. ZYGMUNT: Okay. So as the last  
20 business item of the day the Chapter 12, second  
21 presentation to you following our December meeting. Based  
22 on the recommendation of the Board in December, it was  
23 requested that we extend the public comment for this rule,  
24 which we did, extending the comment opportunity through  
25 February 14th.

1                   So without me giving a further overview, I'm just  
2 going to turn it over to Keenan, who has put together a  
3 very good presentation, to walk us through the highlights.  
4 My recommendation is that we let Keenan get through the  
5 presentation and then circle back to specific questions,  
6 chiming in any public comment so that folks can get on with  
7 their day.

8                   Keenan and his team, which, again, I want to  
9 introduce Anthony Rivers as part of that team. I think  
10 he's done a fantastic job of responding to all the public  
11 comments that we received, including during the initial  
12 outreach and then the extended comment period as well. So  
13 he'll walk you through the comments and responses and any  
14 further revisions made to the rule based on those  
15 discussions.

16                   So take it away, Keenan.

17                   MR. HENDON: All right. Thank you,  
18 Jennifer. I'm Keenan Hendon, Water/Wastewater Section  
19 Manager for DEQ.

20                   We're here today to provide an overview of  
21 Chapter 12, how we got here, and a little overview with  
22 regards to this presentation. I want to provide an update  
23 on staff activities since the December WWAB meeting,  
24 provide a recap of the December WWAB meeting, more  
25 information on the 10 States Standards and the Great Lakes

1 Upper Mississippi River Board, also Chapter 12 development,  
2 what's taken place over the past roughly 10 years to get us  
3 to this place right now with our current document. And  
4 then provide a review of comments that we receive during  
5 this first December WWAB meeting, as well as public  
6 comments we received from the extended comment period there  
7 through February 15th.

8           After that, we're going to work our way through  
9 Chapter 12, the reason why we're here today. Go through  
10 Sections 1 through 9, which we did get through December  
11 WWAB meeting. And then we'll go through section by section  
12 with regards to Sections 10 through 19, which we didn't get  
13 through at the meeting.

14           So with that, we'll get started here.

15           Is there to -- oh, there we go.

16           All right. December meeting. We were able to  
17 get through Sections 1 through 9 during that meeting.  
18 There's two topics I think that were identified that we  
19 needed to provide a little more detail on. One of those  
20 was the Great Lakes Upper Mississippi River Board 10 State  
21 Standards or the 2018 Recommended Standards for Water  
22 Works, commonly known, I guess, probably in the industry  
23 with regards to the standards, or the 10 States Standard.  
24 We're referencing it within our document as the 2018 TSS.

25           And on the other item that we needed to review or

1 provide a little more clarity on was the timeline or how we  
2 get here today.

3 BOARD MEMBER DEURLOO: What's CH12D?

4 MR. HENDON: Chapter 12 development.

5 BOARD MEMBER DEURLOO: All right.

6 MR. HENDON: Thanks for the easy question.

7 So GLUMRB, GLUMRB is the abbreviation for Great Lakes Upper  
8 Mississippi River Board. We did have a couple of questions  
9 from the WWAB board with regards to participating in the  
10 Great Lakes Upper Mississippi River Board, and understand  
11 there's a process. Unfortunately, it is only open to the  
12 Upper Mississippi River basin -- or Upper Miss -- or, yeah,  
13 basin states.

14 We can participate in rulemaking and rulemaking  
15 process. We can participate in that process as we see fit.  
16 When they conduct that rulemaking process, they do that  
17 approximately every five to seven years.

18 ACTING CHAIR CAHN: You can or you cannot.

19 MR. HENDON: We can.

20 ACTING CHAIR CAHN: Can.

21 MR. HENDON: Can, c-a-n. They do allow  
22 folks to participate in that rulemaking process.

23 BOARD MEMBER DEURLOO: Because we are part  
24 of the Upper Mississippi watershed anyway.

25 MR. HENDON: Yeah.

1 BOARD MEMBER DEURLOO: Go ahead. Carry on.

2 MR. HENDON: Sounds good. Sounds good.

3 There's close to 40 states that participate -- or  
4 utilize the Great Lakes Upper Mississippi Board Standards.  
5 Numerous towns, special districts, cities, surrounding  
6 states, Montana, Idaho, Dakotas. The 10 states that  
7 comprise GLUMRB, include New York, Illinois, Wisconsin,  
8 Minnesota, Iowa, Indiana, Michigan, Missouri, Ohio and  
9 Pennsylvania. It also includes the province of Ontario,  
10 Canada.

11 The existing Chapter 12 was based off the 1982  
12 standards. And the Great Lakes Upper Mississippi River  
13 Board, they also develop wastewater facilities standards as  
14 well. So should we update Chapter 11, we'll likely see  
15 that document and identity again for incorporation by  
16 reference.

17 If you're looking for the document, this is  
18 essentially what you're going to see when you're reading  
19 the recommended standards for the Great Lakes upper  
20 Mississippi River Board. The document is housed at the  
21 state of Minnesota. I'm not sure if they drew the short  
22 straw or winning straw or how they got selected, but if you  
23 go to their website, this is what you're going to see with  
24 regards to how they refer to themselves as and calling them  
25 the 10 State Standards, GLUMRB.

1           If you want to purchase a copy of the Great Lakes  
2 Upper Mississippi River Board standards, it's available for  
3 19.99 for a hard copy. Digital copy is 13.99. And also  
4 that same -- same digital copy is located on our website  
5 for free. So there's a PDF searchable version available on  
6 our website.

7           So going through the Chapter 12 timeline. Back  
8 in 2013, we decided it was time to start taking a look at  
9 our -- perhaps previous to that too, I'm not sure. But in  
10 working with Gina, who's got -- she's been through the  
11 process from start to finish with regards to 2013 through  
12 today, outreach was originally started back in 2013 to get  
13 comments from public with regards to Chapter 12. Later on  
14 in 2013, the governor, as well as Wyoming DEQ, decided to  
15 reduce Chapter 12 size through the incorporation by  
16 reference.

17           Work was started by staff. There was numerous --  
18 in 2016 we started having working sessions. District  
19 engineers would have working sessions either in Lander,  
20 Casper, Cheyenne. Staff would travel -- in pre-COVID days  
21 where staff could travel and meet in-person and have a good  
22 working session.

23           In 2017, rules were paused due to a number of  
24 staffing issues with the water and wastewater section. But  
25 a little bit later on in 2017, district

1 engineer started more working sessions. In total, they  
2 started in February of 2016, wrapped up in 2019. So,  
3 again, this included all the district engineers as well as  
4 staff from the water/wastewater section, as well as Gina  
5 and perhaps others.

6 So there were a total of 19 working sessions with  
7 staff in order to take their comments, experiences and put  
8 it into the chapter that's before you today.

9 Excuse me. Taking a drink.

10 In 2019, the WWAB reviewed the acidization rules  
11 for wells with regards to Chapter 12 and recommended that  
12 portion of the rules proceed to the EQC. In 2019 -- or  
13 2020, February of 2020, the AG had the opportunity to  
14 review Chapter 12 and provide significant edits to Chapter  
15 12.

16 Subsequently with the public comment and outreach  
17 period heading into the EQC meeting in May, the chapter was  
18 pulled due to the number of public comments that we  
19 received at that time.

20 So what did we do? We decided to have some  
21 public comment outreach with those folks.

22 ACTING CHAIR CAHN: Can you go back to that  
23 last slide?

24 MR. HENDON: Sure.

25 ACTING CHAIR CAHN: Thanks.



1                   MR. HENDON: So after Chapter 12 being  
2 pulled in May and October, there was some public comment  
3 and outreach period. Meetings were held with Weston  
4 Engineering, Wyoming Association of Rural Water Systems.

5                   Heading into September and October of 2021, the  
6 Attorney General and district engineer had the opportunity  
7 to conduct final reviews on chapter.

8                   Heading into the December WWAB meeting, the  
9 public comment period was opened in November --  
10 November 5th, I believe, of 2021. We then held our  
11 December WWAB meeting on December 15th. Determined to  
12 extend the comment period -- comment period was extended to  
13 February 15th. Essentially the comment period's been open  
14 for 101 days with regards to Chapter 12, about three times  
15 your normal comment period for heading into a WWAB meeting.

16                  I just wanted to provide a general timeline,  
17 summary of staff activities with regards to the rulemaking,  
18 district engineering involvement, staff involvement,  
19 outreach to the public. We'll cover more outreach to  
20 commenters going forward with regards to commenters for the  
21 December meeting as well as the February meeting -- or this  
22 March meeting. My apologies.

23                  So, again, there were some kind of questions,  
24 comments, direction given at the December WWAB meeting.  
25 One of those was, again, can we participate. The answer

1 that we got back to us was no, based on that reason.  
2 However, we can participate in the rulemaking process,  
3 participate in the committees, so forth.

4 We do have the 2018 Recommended Standards for  
5 Water Works located on our website for free. It's the same  
6 digital version that's available for purchase. So we were  
7 able to work with Great Lakes Upper Mississippi River Board  
8 folks on getting that to our website.

9 There was kind of numerous comments with regard  
10 to can we introduce the incorporation by reference much  
11 earlier on in the document. So Section 4 has been revised  
12 and introduces the incorporation by reference and  
13 subsequent documents.

14 There was a question with regards to total  
15 elevation that is unclear on the engineering design report  
16 in Section 8 (e), (ix). So that passage has been revised  
17 to provide a total depth of the drilled borehole. We work  
18 with our groundwater folks, as well as district engineer  
19 folks to make sure that we have proper terminology with  
20 regard to calling out industry terms.

21 And then in December, we're thankful for Board  
22 Member Cahn and Gina Thompson. They had a couple working  
23 sessions to go through editorial comments with regards to  
24 the chapter. Hopefully that can aid us all today as we go  
25 through Chapter 12.

1           As we move forward, following the WWAB meeting we  
2 kind of regrouped internally, wanted to reach out to each  
3 of the commenters that provided us comments. Kind of have  
4 a working session more or less with these commenters, make  
5 sure we understood the intent of questions and their  
6 comments that they were providing and make sure that  
7 essentially we were on the same page and understood one  
8 another.

9           So this was done, again for both sets of comments  
10 for the December meeting, as well as folks from the --  
11 submitting for the March meeting here today.

12           ACTING CHAIR CAHN: To all commenters or  
13 just some of them?

14           MR. HENDON: We reached out to all of them.  
15 There we go. Dang technology.

16           So, again, we re-reviewed the comments. We did  
17 reach out to the commenters. Commenters were contacted  
18 initially via email, provided them with a copy of their  
19 comments as well as response to comments.

20           We also had a request in there to coordinate a  
21 meeting or phone call with us to go over their comments and  
22 get those reviewed. We reached out to Darwin Dick with  
23 Tetra Tech, Jason Palmer, Andy Hooten, Brian Sepe with the  
24 City of Green River, Dayton Alsaker and Jeff Rosenlund with  
25 DOWL Engineering.

1 THE REPORTER: You're going to have to slow  
2 down.

3 MR. HENDON: I got to slow down?

4 THE REPORTER: Yes.

5 ACTING CHAIR CAHN: Can you go over that  
6 list again?

7 MR. HENDON: Sure. We'll start at the  
8 beginning. Darwin Dick, Tetra Tech; Jason Palmer, Andy  
9 Hooten, Brian Sepe with the City of Green River; Dayton  
10 Alsaker and Jeff Rosenlund, DOWL Engineering; Dave Engels,  
11 American Council of Engineering Companies of Wyoming;  
12 Cheyenne Board of Public Utilities; EPA Region 8; Wyoming  
13 Association of Rural Water Supplies.

14 Two commenters responded back to us either in  
15 email or over a phone call that basically said they  
16 understood our responses, had no further comments.

17 Four commenters took us up on our offer to have a  
18 meeting and a review session. This included EPA, BOPU,  
19 Andy Hooten with the City of Green River, and Wyoming  
20 Association of Rural Water Supply.

21 Not wanting to get less than a hundred percent,  
22 we conducted further outreach with calls and emails to  
23 track down the outstanding four commenters, and so we were  
24 able to get meetings coordinated with Jason Palmer and  
25 Brian Sepe, with the City of Green River. And then we were

1 able to have phone call conversations with Dayton Alsaker  
2 and Jeff Rosenlund.

3           And just as a matter of course, these meetings  
4 were more than one session, just to make sure that we were  
5 getting their feedback with understanding them and them  
6 understanding us, and then kind of going back to the  
7 drawing board and meeting again to further vet out their  
8 concerns and our responses.

9           Through a phone call with Dave Engels, it was  
10 recommended that we schedule a kind of a Zoom meeting or  
11 info session to the Wyoming Engineering Society's annual  
12 meeting in February. So we reached out to the Wyoming  
13 Engineering Society to see if we can do this.  
14 Unfortunately their schedule -- their dance card was full.  
15 However, we were able to schedule a meeting on  
16 January 27th. We reached out to the Engineering Society.  
17 They sent out information on our meeting to their members.  
18 Reached out to the Wyoming Association of Municipalities to  
19 provide the meeting information to their members. Reached  
20 out to WARWS, provide the information to their members.  
21 And we also sent it out through our listserv available to  
22 us through the state government. And that listserv would  
23 likely contain all the operators, cities, towns, and  
24 engineers that opt into that listserv notification system.

25           Based on that Chapter 12 outreach, we then held a

1 follow-up Q&A session on February 1st with the folks that  
2 wanted to participate. It was a good session. It allowed  
3 people to -- we wanted it to be a week later to allow  
4 people to read, review the documents if they didn't have  
5 them, and then formulate their comments and responses  
6 heading into the February 15th comment deadline.

7 ACTING CHAIR CAHN: How many people  
8 participated in that?

9 MR. HENDON: I want to say we had six  
10 entities show up. A number of folks from WARWS and a  
11 handful of cities and towns.

12 So after the December WWAB meeting, the comment  
13 period was extended through February 15th. We received  
14 comments or submissions from five -- we received five  
15 submissions. Four were comments with regard to Chapter 12.  
16 One was an errant comment with concerns on their water  
17 quality that they were receiving out of the tap. We  
18 provided that individual with direction on where they  
19 needed to go to get that addressed. But the remaining four  
20 commenters provided us with a list of comments or pages of  
21 comments to look through and address, provide responses to.

22 Craig Barsness with Shoshone Municipal Pipeline  
23 had one comment. His comment was concerns with 24 mesh  
24 elevated tanks. And then, again, the remaining three  
25 commenters provided us with a variety of comments on

1 different sections.

2 Meetings were held in person or via Zoom. We had  
3 a good discussion. We had a good review. We had a good  
4 understanding of one another. Overall, it went well.

5 So as we go forward, it might be helpful to pull  
6 out your green version Chapter 12. I believe at the  
7 beginning of the meeting Gina kind of handed out this  
8 addendum to comments as well. There's a number of comments  
9 that, unfortunately, the February outreach we didn't get  
10 all the comments addressed prior to getting your board  
11 packets and materials prepared for you today. So the  
12 addendum kind of covers those outstanding comments that we  
13 were unable to get addressed.

14 And if you want to follow along with regards to  
15 DEQ's response or analysis to comments, that might be  
16 helpful or handy as well. Up to you.

17 MS. ZYGMUNT: But -- just to add to that.  
18 So we do recommend that -- so that we're all working off  
19 the same version, that we have focus on Chapter 12 changes  
20 since 11/5/21. We're also referring to that as the green  
21 strike and underline version. So I think it would helpful  
22 if we all speak from that version, as we have specifics.

23 MS. THOMPSON: You're going to call up that  
24 version?

25 MR. HENDON: No.

1 MS. THOMPSON: No?

2 MR. HENDON: I think we can pull that up  
3 later on, when we -- should we have discussion afterwards.

4 MS. THOMPSON: I would note --

5 MR. HENDON: Because in this presentation  
6 slides, I do have the information available to read off the  
7 slides, which should you want additional context or  
8 clarity, is the reason why I referenced the Chapter 12 as  
9 well as the addendum to comments.

10 MS. THOMPSON: Okay. So I'm getting some  
11 chats that there a lag. Somehow the slides are not moving  
12 along when you're changing.

13 MR. HENDON: So give a pause?

14 MS. THOMPSON: I'm not sure why they're not  
15 moving. Like I can see them move, but I can't see them  
16 move on -- from the Zoom. So just be aware, folks, that  
17 Keenan's reading from the slides, and we'll have them  
18 available at the end, and we will continue to trouble  
19 shoot, but we do have that information. We will have that  
20 information available.

21 ACTING CHAIR CAHN: Is it possible to email  
22 those slides to the people if they indicate in the chat  
23 that they want to see the slides, so that they can go  
24 along? I've had this problem with Zoom before, where it  
25 doesn't -- it goes back to the head -- to the header slide



1 and doesn't move forward for everybody else, even though it  
2 moves forward in the room.

3 MS. THOMPSON: Keenan, if I send that can I  
4 link so they can look, is that possible?

5 MR. HENDON: Uh-huh.

6 MS. THOMPSON: Okay.

7 MR. HENDON: That's probably the best way  
8 to do it.

9 MS. THOMPSON: Thank you.

10 MR. HENDON: So pause for a moment or two  
11 for technology. We'll post a to link the comment section.

12 BOARD MEMBER DEURLOO: Whoa.

13 MR. HENDON: We'll extend it for camera  
14 troubleshooting.

15 (Off-the-record discussion.)

16 ACTING CHAIR CAHN: Let's go ahead.

17 MR. HENDON: Go ahead.

18 ACTING CHAIR CAHN: Yeah.

19 MR. HENDON: Okay. As we move forward, I  
20 just want to bring your attention to the slide layout in  
21 regards to our chapters -- Chapter 12, our sections that  
22 we're going to be looking at.

23 At the top of each slide we're going to cover the  
24 original information that was presented with the change to  
25 each section as presented to the board in December.

1           The bottom portion of the slides are going to  
2 cover any changes that occurred after the December meeting.  
3 Looking to only cover and provide information with regards  
4 to changes -- significant changes in wording or technical  
5 content.

6           Hopefully this can aid in the presentation of  
7 information, maximize the use of everyone's time here  
8 today.

9           So, again, these were the Sections 1 through 9  
10 that we were able to get through at the WWAB meeting in  
11 December. I'm sure there's questions did you guys make any  
12 changes post that December WWAB meeting? The answer to  
13 that question is yes.

14           And so Sections 1 through 3, there were no  
15 changes.

16           Section 4, we updated to outline incorporation by  
17 reference earlier on in the document.

18           Section 5, there was a comment from a commenter  
19 as well as Madam Chair with regard to mechanically driven  
20 drives, changing to mechanical drives.

21           Comment 5(z), this has an asterisk on it, which  
22 is a good time to outline that any time you see an  
23 asterisk, that's a comment we were unable to address in  
24 your materials that were submitted to you by the March 2nd  
25 deadline for your board materials, and so that asterisk is

1 just bringing your attention to a passage that we're going  
2 to call out and explain to you a little further today.

3           Essentially this section the commenter wanted to  
4 provide definitions for each service section type. Section  
5 16 of the -- of Chapter 12 provides information with  
6 regards to connection types that we will refer the  
7 commenter to.

8           Section 6, 6(b), this one has an asterisk with it  
9 as well. It was reorganized due to a formatting issue and  
10 punctuation.

11           Section 7, based on some comments, we revised it  
12 to more clearly describe the two permit process.

13           Section 8, couple of wordsmithing changes with  
14 regard to 8(c)(i) as well as 8(e). On 8(e), the question  
15 was with regards to the design report with regards to well  
16 drawings. Typically you're going to see plans in well  
17 drawings, not a profile for a well.

18           Section 9, 9(a), we reorganized for formatting,  
19 corrected a couple of references.

20           9(g)(ii), we cleared up that passage that was  
21 concerned with regards to having -- having the requirement  
22 of audio narration with the video log. That portion has  
23 been taken out. So it's just a video log of the well  
24 inspection accompanied by a written description.

25           The next one -- ah, the next one, there was

1 concern should the system in the engineer -- or in the  
2 hydraulic model not have fire flow data or fire flow  
3 protection, so we modified that section to provide an  
4 off-ramp so that it's calibrated based on existing fire  
5 hydrant test flow data, when available, or it can be based  
6 on modeling.

7           Sections 10 through 19. 10 sections left to go.  
8 We've overall organized these sections for continuity,  
9 consolidating similar passages in conformity. Sections  
10 have been corrected to address grammar, spelling issues,  
11 remove requirements not within the statutory authority.  
12 And, again, we're looking to provide you information with  
13 regards to significant changes to passage or changes in  
14 technical content.

15           We did receive a number of comments with regards  
16 to does my facility need to come into compliance with this  
17 new chapter? The answer to that question is no. They  
18 remain permitted under their original permit.

19           ACTING CHAIR CAHN: Unless they make  
20 modifications.

21           MR. HENDON: Unless they make a  
22 modification, then they will need to come into compliance  
23 with new regulations.

24           So, again, this is Section 10, the top of the  
25 slide has the information with regards to Section 10 that

1 was modified and changed at the December meeting. We  
2 received several comments on this section, four comments  
3 resulted in the change. One of those comments was with  
4 regards to adopting NSF/ANSI 61 for coatings. This is an  
5 adoption that's referenced going to be commonly seen going  
6 forward within the chapter. NSF stands for the National  
7 Science Foundation, provides regulatory standards on  
8 products or systems. 61 is specifically for drinking water  
9 system components.

10 The remaining three comments were through  
11 conversations with EPA, and essentially ensuring that new  
12 systems are designed and built to requirements of the  
13 primacy agency conducting enforcement.

14 Several commenters provided us with comments to  
15 ensure that DEQ and EPA are on the same page with regards  
16 to design and enforcement requirements.

17 As we go forward in Section 11, 12, 15 and 16,  
18 those are the sections where we probably have the most  
19 content to cover, or the most comments from commenters.  
20 Section 11 we had 29 comments that --

21 ACTING CHAIR CAHN: I'd like to mention, I  
22 think NSF is National Sanitation Foundation and not  
23 National Science Foundation.

24 MR. HENDON: Okay.

25 MS. ZYGMUNT: We'll double-check that.

1                   MR. HENDON: Okay. 16 of the 29 comments  
2 we received resulted in a change. Number of the changes on  
3 the slide provide for better clarify after discussions with  
4 EPA as well as Weston Engineering. The section we're  
5 covering is source development. We received two comments  
6 that were not addressed prior to sending up to DEQ analysis  
7 of comments, back in the comment on our addendum with you  
8 here today.

9                   One of those comments was with regard to pump  
10 tests and providing a definition of a stabilized drawdown.  
11 That definition's now been provided as item in Section  
12 5(aa).

13                   We received another comment with regard to  
14 10 feet of either surface casing or a well with no surface  
15 casing, wanted to know where that kind of came from and  
16 that requirement. It's an existing requirement in their  
17 existing Chapter 12. In looking at surrounding states,  
18 consulting with their groundwater folks as well as district  
19 engineers, it's a standard of practice that takes place  
20 many other states with regards to how they construct wells.  
21 10 feet provides for some bore and well stability, as well  
22 as frost and freezing protection in the various areas  
23 across our state.

24                   Comments on this slide through discussions with  
25 EPA, Nelson Engineering, Weston Engineering. Again, you're

1 going to see a comment with regards to the NSF61 material  
2 addressing concrete aprons. Concrete aprons at one time  
3 were required by EPA, no longer required by EPA. So up to  
4 the designer on how they want to finish off the top of that  
5 wellhead. Should they use concrete, we'll now reference  
6 that as concrete surface or concrete wall. And we also  
7 provide an identified minimum requirements for spring  
8 setback distances, as well as spring wall thicknesses.

9 Two comments that were not addressed prior to  
10 sending our analysis of comments happened to be with the  
11 providing -- or setting the casing 10 feet minimum into the  
12 target aquifer.

13 Upon review and working with the commenter, we  
14 modified the section to align with SEO so that we're on the  
15 same page with regards to well design standards between our  
16 two agencies.

17 The additional comment that we worked on was with  
18 regards to Section 11(f)(i)(A). There was a question with  
19 regards to can various springs be developed? The answer to  
20 that question is yes, those springs can be developed, and  
21 upon further review the 3-foot requirement was deemed not  
22 to be required, so that section was removed.

23 Frost and freezing requirements are covered in  
24 the spring development section later on.

25 Section 12, which is Treatment. We're on the

1 first slide for those following along. We received 36  
2 comments for this section. 14 comments resulted in a  
3 change. A number of the changes on the slide provide for  
4 better clarity after discussions with EPA, Weston  
5 Engineering, Tetra Tech, City of Green River, or BOPU.

6 Just want to bring your attention, a number of  
7 those entities all have either large treatment systems or  
8 they do engineering work on treatment systems.

9 Section 12 added a number of different treatment  
10 options for ozone, ultraviolet, membranes, and media. And  
11 we leveraged the expertise and guidance from EPA in regards  
12 to our UV recommendations. Again, wanted to be on the same  
13 page with regards to design requirements and enforcement  
14 requirements.

15 Moving on to the second slide for Section 12.  
16 These changes were made after discussions with EPA, Weston  
17 Engineering, City of Green River, and BOPU. Again, a  
18 number of these items presented are to ensure that the --  
19 we're meeting -- we're providing design standards that are  
20 in alignment with enforcement requirements.

21 BOARD MEMBER DEURLOO: What's red water  
22 waste? Is that just iron?

23 MR. HENDON: That's just iron and manganese  
24 waste. We had a good conversation with Brian Sepe, the  
25 City of Green River, with regards to iron and manganese



1 waste after treatment and how to get that resolved. We've  
2 incorporated some sections of the 2018 TSS, as well as  
3 re-aligned and formatted Chapter 12 with regards to that  
4 portion, as well as -- we kind of reorganized that section  
5 with lime as well as alum and then red waste.

6 BOARD MEMBER DEURLOO: Thank you.

7 MR. HENDON: All right. Section 13 is a  
8 toughy. I think we're all thankful for the break, perhaps.  
9 But no questions or comments were provided for Section 13  
10 on Chemical Application.

11 Section 14 is Pumping Facilities. We received  
12 six comments. Three comments resulted in a change, and  
13 essentially we're now requiring a surge analysis to  
14 identify if any surge protection devices are necessary.

15 14(i)(i) is, again, to ensure that the design is  
16 meeting EPA requirements should they get inspected.

17 And then 14(i)(ii) was a clarification to ensure  
18 that the suction lines have similar operating conditions.

19 Section 15 is finished water storage. The first  
20 two comments essentially addressed tank turnover, as well  
21 as water age issues. We've kind of revised and provided an  
22 off-ramp with regard to 15(c)(ii), which is now 15(e). The  
23 original language just stated a minimum inlet velocity of  
24 10 feet per second. We revised that to include unless  
25 demonstration of employed mixing or lower inlet velocity

1 addresses water age issues.

2 15(c)(iii), again, is another tank turnover water  
3 age issue, specifically with smaller systems that have a  
4 large supply.

5 15(f)(i)(ii)(b), we've reorganized those passages  
6 with regard to overflows and vent mesh requirements.  
7 Number of comments we received did cover vents and concerns  
8 with regard to 24 mesh. So we wanted to cover that a  
9 little bit more with you today.

10 BOARD MEMBER DEURLOO: Keenan, does that  
11 seem to be a pretty big issue at this time?

12 MR. HENDON: Yeah.

13 BOARD MEMBER DEURLOO: As small as the size  
14 of a mouse or something, right?

15 MR. HENDON: Yeah.

16 BOARD MEMBER DEURLOO: As small --

17 MR. HENDON: That concern -- yes, the --  
18 it's a very small fly EPA is concerned getting into the  
19 supply of the system.

20 BOARD MEMBER DEURLOO: I see.

21 ACTING CHAIR CAHN: That's a tropical fly.  
22 Doesn't live in Wyoming. Hasn't been seen here yet.

23 MR. HENDON: And we do have the information  
24 here. We'll cover that here in just a second, thank you,  
25 with regards to EPA guidance on screen mesh.

1 BOARD MEMBER DEURLOO: Got it.

2 MR. HENDON: And it started --

3 ACTING CHAIR CAHN: I'm having a hard time  
4 finding the slides for those sections. Maybe they got  
5 renumbered. The slide before.

6 MR. HENDON: Okay.

7 ACTING CHAIR CAHN: So 15(c)(ii). So it  
8 was --

9 MR. HENDON: Is now 15(e). Or do I got it  
10 wrong?

11 MS. THOMPSON: No. I think 15(c)(ii)  
12 starts at line 2263.

13 ACTING CHAIR CAHN: Okay.

14 MS. THOMPSON: Then it goes into 15(e),  
15 15(f). Those are down along line 2276 and 2280.

16 ACTING CHAIR CAHN: Okay. Okay. Thank  
17 you.

18 MS. THOMPSON: Uh-huh.

19 MR. HENDON: So what are we requiring in  
20 our existing -- or our proposed Chapter 12? On overflows,  
21 we're recommending mechanical device, such as a flapper or  
22 duckbill valve on the overflow, and number 4 mesh to keep  
23 those mice or birds or bats out of that overflow. Or they  
24 can put 24 mesh on the end of that overflow as well.

25 For vents, openings need to be protected with

1 24 mesh. An existing Chapter 12 requirement for buried  
2 in-ground tanks is that the vent must be covered in  
3 24 mesh.

4 The existing Chapter 12 also states that 24 mesh  
5 may be used on elevated tanks.

6 ACTING CHAIR CAHN: "May be" or "must be"?

7 MR. HENDON: On the existing Chapter 12, it  
8 says "may."

9 ACTING CHAIR CAHN: And the new ones?

10 MR. HENDON: It will be 24 mesh.

11 ACTING CHAIR CAHN: Okay. So for vents,  
12 it's going to say "must," not "may."

13 MR. HENDON: So -- so I'm just covering the  
14 existing Chapter 12 requirements for ground and buried  
15 tanks. An existing requirement for the vents on a ground  
16 and buried tank is 24 mesh. We just wanted to let everyone  
17 know that the proposed and existing are the same.

18 ACTING CHAIR CAHN: Okay.

19 MR. HENDON: However, the existing Chapter  
20 12, on an elevated tank, it had the word "may" for 24 mesh.  
21 We are proposing 24 mesh to be protective vents for all  
22 tanks.

23 ACTING CHAIR CAHN: So elevated tank will  
24 be 24 mesh required.

25 MR. HENDON: Correct. Correct.

1           And so let's -- so we had a number of comments  
2 and concerns and outreach to us with regards to 24 mesh.  
3 So we followed up with the EPA. We'll cover that here in a  
4 little bit further as well.

5           But in talking with EPA, EPA's been requiring 24  
6 mesh on tank vents for all tanks that they inspect since  
7 2014. They inspect tanks in Wyoming, as well as tribal  
8 systems, so they require the implementation of 24 mesh  
9 either on the overflows as well as the tank vents, whether  
10 it's elevated, buried, or ground level.

11           We also had discussions with a commenter with  
12 regards to a new 2018 newly built tank, Cowley tank was  
13 getting built. EPA happened to be in the area, stopped by  
14 to see the construction, learned that the new tank and the  
15 tank vent was going to have 16 mesh installed. The mayor  
16 happened to be on-site at the time. EPA informed the mayor  
17 that, well, when we come by to inspect your new tank, it's  
18 going to have a significant deficiency. Your tank vent on  
19 your elevated brand-new tank is going to have to get in  
20 compliance.

21           So the engineer and the town scrambled to get  
22 that fixed during construction, rather than post  
23 construction. So I think that's an important example of  
24 where we need to ensure that we're requiring design  
25 standards that align with enforcement standards and

1 requirements.

2           So some examples of tank vents that can be  
3 utilized on an elevated tank that provides frost freezing  
4 protection, here's some examples. Almost locally  
5 manufactured, but these are manufactured down in Longmont,  
6 Colorado -- or Wellington, Colorado.

7           Another option. This option here is on an  
8 overflow. This is the city of Riverton. City of Riverton  
9 kind of did a modification on their overflow. When it's  
10 not overflowing, it's sealed with 24 mesh. During an  
11 overflow event, or should they have debris or anything up  
12 in there.

13                         BOARD MEMBER DEURLOO: I like that.

14                         MR. HENDON: It's a pretty slick and easy  
15 idea such that if it is plugged, it can extend, debris can  
16 wash away and perform during an overflow event. And  
17 it's -- it keeps staff busy, pretty easy.

18                         BOARD MEMBER DEURLOO: Is that allowed by  
19 EPA?

20                         MR. HENDON: Uh-huh.

21                         BOARD MEMBER DEURLOO: Very good. Thanks.

22                         ACTING CHAIR CAHN: What are the issues  
23 with that freezing in the winter?

24                         MR. HENDON: So perhaps in the winter,  
25 during an overflow event, most tanks -- I mean, most tanks

1 operate at a lower level in the wintertime. So you  
 2 wouldn't see the fluctuation and volumes that you would see  
 3 in the summertime. So they up -- so instead of having a  
 4 tank full of water, they're going to operate at a lower  
 5 spectrum within their water system. Should they be up  
 6 during an overflow event, that water -- if it's a slow  
 7 trickle, perhaps there's a freezing concern. And perhaps  
 8 they do have issues, then they should perhaps look into a  
 9 flapper valve or duckbill valve.

10 BOARD MEMBER DEURLOO: That's a duckbill on  
 11 the right, correct?

12 MR. HENDON: And on the right, that's a  
 13 duckbill valve.

14 BOARD MEMBER DEURLOO: And that's allowed.

15 MR. HENDON: And that's allowed. So  
 16 there's several options --

17 BOARD MEMBER DEURLOO: Those are bomb proof  
 18 too.

19 MR. HENDON: Yeah.

20 BOARD MEMBER DEURLOO: Yeah, they just --  
 21 it just opens up.

22 MR. HENDON: Yeah, under slight -- and that  
 23 would open under air pressure. So if there's a concern in  
 24 our colder environments, if you're up in Teton County,  
 25 perhaps you don't want to use the Riverton solution, and

1 you want to put in a -- you want to put in that duckbill  
2 valve to avoid any frost or freezing concerns.

3 And, again, here's flapper valve options. Here's  
4 the screen mesh.

5 BOARD MEMBER DEURLOO: That's 24?

6 MR. HENDON: That's 24.

7 BOARD MEMBER DEURLOO: That means 24 holes  
8 per inch?

9 MR. HENDON: Yeah.

10 So this is a EPA Tech Tip Guidance document with  
11 regards to vents, overflows, drain lines, requirement of 24  
12 mesh. And this started -- this document, if we scroll in,  
13 is from April 3rd of 2012.

14 ACTING CHAIR CAHN: And the expense of  
15 flapper valves or duckbills, what kind of expense are we  
16 looking at?

17 MR. HENDON: With most things, they're  
18 going to go up depending on the size of your pipe. But we  
19 thought if you've got a smaller pipe, you're looking at  
20 \$20, \$30. Smaller size, depending on your system, is going  
21 to be in your thousands. But, again, if you're talking a  
22 million-, 2-million-gallon tank, 1500 bucks for a duckbill  
23 valve is a pretty reasonable and economical piece of  
24 equipment.

25 BOARD MEMBER DEURLOO: Thank you for the



1 slide.

2 ACTING CHAIR CAHN: Yeah.

3 BOARD MEMBER DEURLOO: It's very helpful.

4 MR. HENDON: So, again, we had folks  
5 send in numerous questions, concerns. So what did we do?  
6 Went back to EPA, said, Hey, EPA, we want to work with you  
7 on this 24 mesh. What kind of issues are you seeing with  
8 it? Is there a pressure vacuum issue of these tanks  
9 imploding, exploding, freezing, these types of concerns?

10 Again, they've -- in Wyoming and tribal lands,  
11 they've been requiring it since 2014. Initially they  
12 needed to -- initially there was pushback with regards to  
13 getting 24 mesh installed on the tank vents and the  
14 overflows. Now they say when they go out and do  
15 inspections, they hardly ever see anything but 24 mesh.  
16 They're not aware of any event, frost, freezing issues.

17 ACTING CHAIR CAHN: Have you made them  
18 aware of the issues that we've had in Wyoming?

19 MR. HENDON: We've discussed a couple of  
20 the items that at least I'm aware of. If there are other  
21 issues that haven't been brought to our attention, then  
22 they need to be shared with us. But from our  
23 understanding, there were some small, I believe, pipe  
24 separation issues with regard to a spring. But with  
25 regards to -- again, with the enforcement agency conducting

1 the inspections, they're unaware of any frost, freezing,  
2 vacuum pressure.

3 ACTING CHAIR CAHN: So they don't know  
4 about Pine Bluffs?

5 MS. ZYGMUNT: They are very aware of the  
6 town of Pine Bluffs, as are we. And Keenan --

7 MR. HENDON: Oh, so if we're talking about  
8 Pine Bluffs, they're very well aware of Pine Bluffs.

9 MS. THOMPSON: They did a study.

10 MR. HENDON: And they've done a study on  
11 Pine Bluffs. If we want to talk about Pine Bluffs, I think  
12 there's a number of issues that we could review on Pine  
13 Bluffs. We can start with the -- there was a new -- so  
14 they have an existing tank, and they were constructing a  
15 new tank. The contractor on-site crossed the wires on the  
16 pumps. So they continued to fill the old tank instead of  
17 filling their new tank.

18 So what happened? The old tank continued to fill  
19 and fill and fill until it overflowed. Apparently the  
20 overflow had -- it got clogged. So on the end of their  
21 outlet line, it was clogged. Their overflow line had  
22 24 mesh, which was interesting, because they had a flapper  
23 valve installed. So there's an issue, number one. They  
24 had a flapper valve. All they needed was to have a flapper  
25 valve and number 4 mesh installed, likely wouldn't have had

1 a problem.

2           If we go back to the contractor, the issue is the  
3 contractor constructing this system that continued to fill  
4 and fill this tank until it essentially ruptured. There's  
5 probably additional concerns with regard to that design as  
6 why those pumps did not shut off with the significant  
7 backpressure it was likely receiving from overflowing this  
8 tank.

9           So I don't think we can blame Pine Bluffs solely  
10 with regards to installing 24 mesh on the end of that  
11 overflow line. I think there's a number of issues that  
12 likely led to that scenario and that situation. I think  
13 the Town of Pine Bluffs at the time probably should have  
14 hired a forensic engineer to go in and evaluate exactly  
15 what took place and what happened. I know WARWS was  
16 on-site and did an inspection, and that seems to be the  
17 document that's widely circulated. But, again, the  
18 contractor and the Town should likely have had a legal  
19 proceeding to find a solution and the true problem with  
20 regards to what happened in Pine Bluffs.

21           ACTING CHAIR CAHN: What about Star Valley?

22           MR. HENDON: Star Valley? And what is the  
23 issue in Star Valley?

24           ACTING CHAIR CAHN: My understanding is  
25 there was a pump, had waste line number 24. And I think

1 there's somebody from Star Valley actually here, but that  
2 was below grade and it was pressurized and broke.

3 MR. HENDON: And was this a pipe  
4 separation? This is a pipe separation concern? And I  
5 think we're -- at the end of the day, regardless of --

6 ACTING CHAIR CAHN: Waste.

7 MR. HENDON: -- regardless of any system,  
8 we are committed to working with an entity. And I think  
9 this is part of where we're headed with regards to this  
10 slide. DEQ -- or not DEQ. EPA, whenever they issue a  
11 significant deficiency and a correction needed, for an  
12 entity, city, town, et cetera, they recommend hiring an  
13 engineer and getting in coordination with DEQ.

14 So with regards to that, should there ever be an  
15 issue with a city/town having to do retrofit, we're  
16 committed to working with that entity to find a workable  
17 solution. And having extended conversation with the entity  
18 and EPA with regards to if it's vent, drain line, overflow,  
19 or any other matter, truly, we're happy to have those  
20 discussions and find a workable solution for those  
21 entities.

22 MS. ZYGMUNT: Let me just add to that. We  
23 are very aware of the concerns with 24 mesh. And this has  
24 been a landing discussion with stakeholders and EPA. We  
25 have put a lot of careful conversation into this before

1 making the decisions that we had with this chapter, but as  
2 Keenan has outlined, we have to make sure we're not putting  
3 our communities out of compliance with another regulatory  
4 agency. It's just not giving them workable solutions and  
5 causing additional expense.

6 But that said, we are committed that if a  
7 community runs into a situation that they don't think they  
8 can solve with one of the engineering solutions that Keenan  
9 walked you through, we are committed to working with them  
10 and brokering that conversation with EPA to make sure that  
11 we're not leading to situations that go bad for that  
12 community.

13 So, again, we get the issues. We have to put our  
14 communities into compliance, and I think we've found the  
15 right balance of doing that, partnering with EPA, but  
16 advocating for communities.

17 BOARD MEMBER DEURLOO: Madam Chair.  
18 Correct me if I'm wrong, we've got -- we have a lot of the  
19 EPA requirements on it to maintain primacy, I guess.

20 MS. ZYGMUNT: Yeah, we -- EPA retains  
21 primacy or public water supervision system.

22 BOARD MEMBER DEURLOO: Oh.

23 MS. ZYGMUNT: Wyoming has never assumed  
24 primacy. So that's why there's this coordination. Other  
25 states -- all other states do the construction, permitting

1 and public water system supervision. In Wyoming EPA does  
2 the public water supervision. We do the construction,  
3 permitting. So it's more and more important that we're  
4 working together and I think we've had some productive  
5 discussions along these lines.

6           You know, regardless of how we feel about 24 mesh  
7 and whether it's necessary, this is EPA's decision. And  
8 I -- you know, further feedback on 24 mesh and that  
9 requirement should be directed to them, but, again, we  
10 think that between engineering solutions and then working  
11 through case-by-case situations we can make sure our  
12 communities have good solutions and avoid structural damage  
13 like the examples we talked about before.

14           ACTING CHAIR CAHN: What would it take  
15 for -- I can save my comments until later so that we can  
16 get to public comments.

17           MR. HENDON: Okay. Yeah. So along those  
18 lines with regards to the outreach to EPA, which should DEQ  
19 be doing going forward? Again, looking to strengthen  
20 community outreach, provide education, training.

21           We do -- thankfully the legislature approved the  
22 use of set-aside funds through the SRF program, so we can  
23 provide either through third-party outreach --

24           ACTING CHAIR CAHN: SRF?

25           MR. HENDON: State revolving fund.

1           So the state revolving fund set-asides, we can  
2 now use some of that funding either to utilize third  
3 parties. I understand WARWS and MAP, they're currently  
4 working in our communities providing outreach and  
5 education. Perhaps there's more that we can do.

6           And, again, DEQ's committed to working with our  
7 communities, whether it's a tank vent, an overflow, or any  
8 other matter with EPA, so...

9           Section 16. Whew. Section 16. We're in the  
10 Distribution Systems, talking about distribution piping.  
11 We have 31 comments on this section. Eight of those  
12 comments resulted in a change. These -- we worked with the  
13 folks from American Council of Engineering of Wyoming, DOWL  
14 Engineering, BOPU, City of Green River, and Nelson  
15 Engineering with our review.

16           Some sections were updated with regards to water  
17 services and plumbing information for either local or state  
18 plumbing codes to provide better direction and clarity.

19           Sections were updated to include direction on air  
20 relief valves, as well as hydrants and flushing hydrants.

21           And sections were updated to include -- include  
22 flow fill options from DEQ policy as well as separation  
23 distances.

24           We did receive a comment with regards to  
25 dewatered work, wanting to allow work in a watered -- or a

1 trench that may be partially full of water. We opted to  
2 remain and require dewatering in the trench. We think  
3 that's important to have a sanitary, safe trench when  
4 installing pipes, valves or hydrants.

5 BOARD MEMBER DEURLOO: Question, please.  
6 Where can you take that water? So if they have to --  
7 they're working on that -- this is point of interest, and  
8 they have -- they're working on a hydrant downtown, 1st and  
9 Main, or something like that, and they have a trench full  
10 of water, where can they take it? What do they do with  
11 that water?

12 MR. HENDON: Sure. So the City of Cheyenne  
13 currently has a large project going on in front of the  
14 Capitol. They're doing waterlines, as well as storm sewer  
15 lines, big trench, big pipe, high groundwater in that area.  
16 So they brought in their own -- either bring in your over  
17 water buffalo -- that's basically what they did. Bring in  
18 your own water storage tank, put that on-site. So they  
19 just pumped into one of those mobile water storage units.

20 BOARD MEMBER DEURLOO: And then they take  
21 it to --

22 MR. HENDON: And then they haul it offsite.

23 BOARD MEMBER DEURLOO: Thanks.

24 MR. HENDON: Sure.

25 BOARD MEMBER DEURLOO: Assume that because



1 the TSS is too high to pump down a storm sewer; is that  
2 correct? Or --

3 MR. HENDON: It depends on probably the  
4 city's storm sewer system.

5 BOARD MEMBER DEURLOO: Uh-huh.

6 MR. HENDON: And they could have done that  
7 as well, which they did on part of the sections. So  
8 they -- I'm going to guess it depends on your local entity  
9 with regards to where you're pumping that water. Part of  
10 that water within the city of Cheyenne was in a plume with,  
11 what is it, hydrochloric -- chemical for --

12 BOARD MEMBER COCHRAN: TCE?

13 MR. HENDON: TCE. It was in a plume for  
14 TCE. So some of that water did have to get cleaned before  
15 they could put it back into the storm sewer or dispose of  
16 it elsewhere.

17 BOARD MEMBER DEURLOO: I see. Interesting.  
18 Thank you.

19 MR. HENDON: It all depends, again, various  
20 metrics.

21 BOARD MEMBER DEURLOO: Location.

22 MR. HENDON: Section 17 is Laboratory  
23 Requirements. We didn't have any comments resulting in a  
24 change. However, the one comment we did receive resulted  
25 in a publication year being noted in Section 19 for

1 clarity.

2 Section 18, we received one comment, but no  
3 change was implemented based on that comment.

4 Section 19, Incorporation by Reference. If you  
5 want to be put to sleep, good section to read.

6 But we did receive two comments from City of  
7 Green River and Nelson Engineering with regards to  
8 including a C906 pipe alternative for 4-inch and up HDPE,  
9 which we included in a previous section, so we updated it  
10 here as well.

11 The other comment was with regards to a reference  
12 on AWWA C901, and wanted to make sure we incorporated  
13 reference -- or number 2020 -- Version 2020 for that -- for  
14 that component.

15 So with that, I guess we've reviewed sections 1  
16 through 9, re-reviewed it here today. It was originally  
17 reviewed at the December WWAB meeting. Presented Sections  
18 10 through 19 with the significant changes within that  
19 document.

20 Again, Chapter 12 is incorporating by reference  
21 the Great Lakes Upper Mississippi River Board 2018  
22 Recommended Standards for Water Works. Within our document  
23 it's referenced as the 2018 TSS.

24 And with that, I can turn it back to Jennifer.  
25 And I know we also have some public comments that we need

1 to address here as well.

2 MS. ZYGMUNT: Thank you, Keenan.

3 I don't have further comments at this time, so  
4 Madam Chairwoman, it sounds like your preference would be  
5 to go to public comments so people can go on with their  
6 day.

7 ACTING CHAIR CAHN: So I'd like to open it  
8 up now for public comments and please come -- when you --  
9 speak into microphone or come up to the table, give your  
10 name and who you're affiliated with. It's appreciated.  
11 Maybe spelling of it for Kathy. So thank you.

12 Mark, would you like to start?

13 BOARD MEMBER DEURLOO: While we're waiting  
14 for Mark to come up, Madam Chair, I'd like to extend my  
15 appreciation to that thorough review. Thank you. That was  
16 very helpful. And I'm glad that we went through another  
17 public comment period. It's such an important rule. It  
18 sounds like we had some very thorough review of some  
19 excellent Wyoming institutions and people. So I think  
20 we're on the right course here. Appreciate it.

21 MR. HENDON: Thank you.

22 MR. PEPPER: Thank you, Madam Chair. I'm  
23 Mark Pepper. I'm the executive director of the Wyoming  
24 Association of Rural Water Systems. We've been around  
25 since 1989. We work -- for those of you who may not be

1 that familiar with us. We work with all the public water  
2 systems in the state of Wyoming, enabling them to remain in  
3 compliance or come into compliance with the Safe Drinking  
4 Water Act, Clean Water Act, and increasingly the Resource  
5 Conservation Recovery Act, as it relates to solid waste  
6 leaching into groundwater or surface water.

7 Our membership consists of all 99 incorporated  
8 communities and about 150 special districts that own and  
9 operate water or wastewater facilities.

10 First, a kudo to the staff for taking on a  
11 rewrite. A lot of the infrastructure that we're starting  
12 to deal with is about 40 years old, 40, 50 years old. So  
13 nice to have new design standards that are going to be  
14 modern, up to date, versus what we have in the ground now  
15 as they start to replace all that.

16 And I think a general comment I'll make before I  
17 get started too much on just a couple of little bitty  
18 things, is I think we finally have 24 mesh solved. And I  
19 will agree that as it relates to the one tank failure, it  
20 was probably more, in retrospect, as we've gotten further  
21 away from it, it was probably more the overflow sensors and  
22 the pumping -- the pump sensors not turning off that  
23 created more of the problem as opposed to the 24 mesh. The  
24 24 mesh probably didn't help any, but it probably wouldn't  
25 have made much difference.

1           But I think we're all on the same page that if  
2   it's an existing tank permitted, and it's 16 mesh or  
3   greater, we're fine. It's when they make modifications,  
4   and they'll have to come up to 24. Or if they're putting  
5   in a new tank, again, it's nice to have the design  
6   standards.

7           Where I think we ran into a lot of issues was  
8   when retrofits were attempted without the use of a lot of  
9   engineering, and they just put 24 mesh on and the airflow  
10   was pretty well screwed up and it made a lot of different  
11   issues. That's pretty much been solved with the existing  
12   tank permit versus changes or new permits.

13           But a couple of the things that we would like to  
14   see a little bit more -- and I apologize for the lateness.  
15   I've been spending since about September with two of your  
16   other favorite topics, ARPA and the infrastructure bill.  
17   And if we ever get the infrastructure portions of the Build  
18   Back Better, that's even more fun.

19           But we're -- like to look at high water loss.  
20   And we've discussed in the current revision utilizing a  
21   high water loss being greater than 20 percent. We'd like  
22   to -- to entertain dropping that down. In Wyoming, we're  
23   an arid state. Some of the systems are facing a lot of  
24   shortages. 20 percent water loss seems a little high. We  
25   actually advocate in our work that we do that 10 percent is

1 about what we like to look at. We go in and do water loss  
2 calculations, and a lot of places we'll run into 30, 40,  
3 50, 60 percent water loss. Some of that is because the  
4 difference between produced water and the sold water. They  
5 don't sell the water to themselves, so they don't take into  
6 account the swimming pools in the parks or the parks and  
7 some of that kind of stuff. And so we try to go back, get  
8 them to meter all that. Once we get that done, then we  
9 look at the water loss. And if it's 10 percent or less,  
10 we're really happy.

11 If it's 10 percent or more and they've got a  
12 sector of town that's had a lot of water breaks, that's  
13 when we'd like them to kind of do some investigation and  
14 possibly looking at replacements of those sectors as it  
15 relates to -- and we've had a couple of pretty high profile  
16 breaks in the last little bit that require more notices and  
17 all sorts of good stuff. But they've had tons and tons of  
18 breaks, it seems like, in their system. Now with more  
19 money than we'll ever be able to spend probably timely,  
20 they should be able to replace every line in their town.

21 So we would look at 1.1.5(f), and possibly look  
22 at maybe shoot for greater than 15 percent. And -- because  
23 that's just a great indicator of --

24 ACTING CHAIR CAHN: Can you go -- 1.1.5(f),  
25 is that what you said?

1 MR. PEPPER: That's correct.

2 ACTING CHAIR CAHN: In the 10 States  
3 Standards.

4 MR. HENDON: Yes, that is reference to the  
5 10 States Standards.

6 MR. PEPPER: Yes.

7 MR. HENDON: And it's in reference for  
8 systems with -- I'll just read the language of (f). And  
9 it's essentially for systems with a high percentage of  
10 unaccounted for water (generally greater than 20 percent of  
11 water production) a water audit may be required by the  
12 reviewing authority.

13 MR. PEPPER: And we'd be good with less.

14 ACTING CHAIR CAHN: Okay.

15 MR. PEPPER: Just in our daily work we do.

16 ACTING CHAIR CAHN: So you would propose we  
17 would take out -- (f) is in there right now, and we would  
18 take it out.

19 MR. PEPPER: No, (f) is fine. Just drop it  
20 from 20 to 15.

21 MR. HENDON: And I think in order for us to  
22 facilitate that, we'd have to drop (f) and then reinsert  
23 language from F in the document.

24 ACTING CHAIR CAHN: With less than  
25 10 percent.

1 MR. PEPPER: Ah.

2 MR. HENDON: Yeah.

3 MR. PEPPER: Or -- well, okay. Okay. Like  
4 I said, sorry, it was late last night.

5 ACTING CHAIR CAHN: So these are included?

6 BOARD MEMBER DEURLOO: Okay. Thank you.

7 MR. PEPPER: And then 1.1.7.1(f) was  
8 included for surface water source protection measures.  
9 We'd kind of like to see 1.1.7.2 (h), considering that  
10 88 percent of the systems in Wyoming use groundwater. And  
11 while it's a voluntary source water protection planning,  
12 we'd kind of like to see a --

13 ACTING CHAIR CAHN: Can you go over those  
14 numbers slowly again?

15 MR. PEPPER: Okay. 1.1.7.2(h) addresses  
16 groundwater source water protection measures. And we'd  
17 like to see that added. And I'll give a quick -- as quick  
18 as I can, story. So years ago, we were working with a  
19 system doing the source water protection plan. And they  
20 were -- they had existing wells that were in a railroad  
21 right-of-way. And part of the project was they would cap  
22 and plug those -- those existing wells once the new  
23 wells were drilled. Of course, unfortunately, there was  
24 just all sorts of things. But the engineers ended up  
25 utilizing all the money for existing wells and didn't have



1 the money to cap it and abandon the existing wells. So we  
2 were able to work with the railroad, ultimately, and they  
3 ponied up the money to -- to cap those so they -- they  
4 didn't want the liability of open wells in their  
5 right-of-way.

6 In addition to that aspect of it, we filed the  
7 delineations of our source water protection plan for that  
8 particular community and those new wells with BLM. And as  
9 it worked out, one of the oil and gas companies was in the  
10 process of finalizing a permit to drill a new gas well and  
11 frack job. As it worked out, the frack job would have  
12 occurred directly underneath the new water wells. I mean,  
13 absolute positively directly underneath them. There was  
14 10,000 foot of strata, but still -- I know it was when  
15 Pavillion was kind of hot and heavy.

16 So they pulled their permit, reworked their  
17 drilling program, moved about a half mile away and drilled  
18 there as a down-gradient from the town's wells, and hit one  
19 of the largest gas producers in the United States. So they  
20 were happy when it was all said and done. But we just  
21 think source water protection in both groundwater and  
22 surface water should be addressed.

23 7.0.6, water storage age, has been omitted, and  
24 we know that many of the upcoming regulations, lead and  
25 copper revisions, disinfection byproducts review and in a

1 way, water age is going to become paramount. And TSS 2018  
2 recommends no longer than five days on water age. And we  
3 believe this is in agreement with AWWA recommendations. So  
4 we would advocate to add 7.0.6 on the water age.

5 Another area where we spend seems like an  
6 inordinate amount of time in our work, 8.7.2, Bedding, was  
7 omitted. It's important to protect the investments of the  
8 state systems by ensuring a quality bedding material is  
9 used. This isn't always the case. And so I think rather  
10 than giving too much leeway, we dial it in and put 8.7.2  
11 in.

12 And kind of dovetailing on that one is 8.7.9,  
13 which is Separation From Other Utilities, was omitted. And  
14 we find a lot of times where the water, wastewater, and  
15 then other lines are in a trench, tough to dig around them  
16 when you're making repairs, and ends up being more costly  
17 when it's all said and done than doing it -- allowing for  
18 the room to do those repairs to begin with. So we would  
19 ask for 8.7.9 to be added back in for separation from other  
20 utilities.

21 And that's all we really have right now. But --  
22 and, truly, the staff has done a remarkable job in fielding  
23 all of the concerns, as well as updating this thing. It's  
24 massive. We're going to probably be doing corrections and  
25 guidance forever, but -- but -- as things change. But

1 there's just those last few things we thought wouldn't be  
2 too bad.

3 But any questions or -- I'll get out of here --  
4 get out of your hair.

5 MR. HENDON: So we do have -- we do have --  
6 where to start?

7 For bedding, we do have it referenced. It's just  
8 the reference that's a requirement in Section 16 (c)(i), we  
9 recommend ASTM C12 classes for bedding, for distribution  
10 and transmission pipe.

11 ACTING CHAIR CAHN: Okay. Which line  
12 number are you on?

13 MR. PEPPER: Thanks.

14 MR. HENDON: So good news. Thank you.  
15 Good news, we do have that one in there.

16 I'd be happy to go back and take a look at the  
17 question on the water age. We do have a couple of sections  
18 that do address water age as to the tank mixing  
19 requirements in Section 15(c), as well as 15(e). But --  
20 but perhaps the best course would be for us to take your  
21 comments and provide a formal response.

22 MR. PEPPER: Like I say, you might want to  
23 revisit, just because of what's in the proposed revisions.

24 MR. HENDON: I'll take a better look at  
25 what you said with respect to that five days, and with

1 regards to utilities and options we can definitely take a  
2 closer look at that as well.

3 But looks like some of it we do have an answer  
4 to, some of it we need to take a closer look.

5 MR. PEPPER: I do think we do have 24 mesh  
6 solved.

7 MS. ZYGMUNT: Yeah, thank you for your  
8 comment. We'll take a closer look.

9 ACTING CHAIR CAHN: Thank you very much,  
10 Mr. Pepper.

11 MR. PEPPER: Anything else as it comes up,  
12 let me know, but...

13 MR. HENDON: If you get ARPA figured out  
14 too, let us know.

15 MR. PEPPER: I'm on mic.

16 MR. HENDON: That's a longer conversation.

17 BOARD MEMBER DEURLOO: We were just talking  
18 about this. American Recovery Act or something like that.

19 MR. PEPPER: ARPA, American Recovery -- is  
20 it Recovery?

21 BOARD MEMBER DEURLOO: American Recovery  
22 Protection Act.

23 MR. PEPPER: Protection Act.

24 ACTING CHAIR CAHN: Protection Act.

25 BOARD MEMBER DEURLOO: Protection Act,

1     yeah.

2                     MR. PEPPER:   And infrastructure bill.

3                     ACTING CHAIR CAHN:  I worked in munitions,  
4     ARPA is a -- is a munitions thing.

5                     MR. PEPPER:  Well, and that was part of the  
6     governor's veto the other day, because EPA just issued new  
7     ARPA guidance last week.  So we're trying to wade through  
8     all of that.

9                     MR. HENDON:  It was short guidance.  It was  
10    only 56 pages of the guidance.

11                    MR. PEPPER:  Small present.

12                    MR. HENDON:  Small present.

13                    MR. PEPPER:  Thank you.

14                    ACTING CHAIR CAHN:  Thank you very much.

15                    Is there anybody on Zoom that would like to make  
16    public comments, or maybe you're not on Zoom.  Maybe it's  
17    something else.  It is Zoom.  Is there anybody else on  
18    Zoom that would like to make public comments, and -- maybe  
19    one -- raise your hand.  Gina says raise your hand.

20                    MS. THOMPSON:  Not seeing any hands raised.

21                    ACTING CHAIR CAHN:  No hands raised.  I  
22    think this is probably a good time to take a lunch break.  
23    And it's 12:30.  We'll come back at 1:30, if that's okay  
24    with everybody.

25                    (Meeting proceedings recessed)

1 12:35 p.m. to 1:43 p.m.)

2 ACTING CHAIR CAHN: We're going to  
3 reconvene the Water and Waste Advisory Board. And at this  
4 point, I think -- are we ready, Keenan, to open it up for  
5 Board discussion? Do I need to repeat that or -- all  
6 right.

7 So I'm going to open it up for Board discussion.  
8 I don't know if we want to go through chapter by chapter or  
9 whether we want to --

10 MS. ZYGMUNT: If I may make a suggestion.  
11 So it sounds like there were maybe some more discussion  
12 points around the 24 mesh, and maybe we could start there.

13 ACTING CHAIR CAHN: Sure. That's a good  
14 idea.

15 MS. ZYGMUNT: Does that sound good?

16 ACTING CHAIR CAHN: Yeah.

17 MS. ZYGMUNT: Okay. So, Keenan, can you  
18 remind us which section that would be?

19 BOARD MEMBER DEURLOO: I didn't have any  
20 more comments on 24 mesh. Did you?

21 ACTING CHAIR CAHN: I would like a little  
22 bit of a discussion about primacy and how -- what Wyoming  
23 would need to do to get primacy. And maybe -- that would  
24 be helpful, I think, for me.

25 MS. ZYGMUNT: Sure. That is a good

1 question, Madam Chairwoman. Based on previous  
2 conversations I've had with past staff, at this time we  
3 were not considering requesting primacy for the public  
4 water supervision system. My understanding is that past  
5 cost feasibility analyses just indicate that it would be a  
6 significant expansion of the state, the agency's budget,  
7 and of our personnel to pursue that program. And  
8 recognizing that EPA would provide some funds to help  
9 implement that program, it would still be a pretty large  
10 financial burden on the state to pursue primacy. So at  
11 this time, we do not have any intention to pursue that  
12 primacy. Of course, that could be revisited at some point  
13 in the future, but not on the radar right now.

14 ACTING CHAIR CAHN: And I guess I  
15 appreciate that you guys are in a position because EPA has  
16 primacy that would pretty much -- we pretty much have to do  
17 what EPA wants us to do on this one. So it doesn't sound  
18 like there's a whole lot of wiggle room. I mean, I  
19 appreciate that, you know, we do have some -- and I'm going  
20 to get mixed up which -- for discharge or overflow that we  
21 do have some -- or is it air vents? Which one is the one  
22 where we have --

23 MR. HENDON: There are options on tank  
24 vents on the overflows. I guess not tank vents. I  
25 apologize. There's options on the overflows for tanks.

1                   ACTING CHAIR CAHN: Okay.

2                   MR. HENDON: So we can do the mechanical  
3 device --

4                   ACTING CHAIR CAHN: Okay.

5                   MR. HENDON: -- or 24 mesh.

6                   And then tank vents do require the 24 mesh for an  
7 elevated, ground, or buried storage tanks.

8                   ACTING CHAIR CAHN: Okay. And, you know, I  
9 think about, you know, hundred foot high elevated water  
10 storage tank and just wonder, you know --

11                  MR. HENDON: I think we're on the same  
12 page. I think we --

13                  ACTING CHAIR CAHN: -- how do you get up  
14 there inexpensively? I mean, you need a crane that's able  
15 to go a hundred feet?

16                  MR. HENDON: That is -- that is true --

17                  ACTING CHAIR CAHN: An expensive --

18                  MR. HENDON: -- on a retrofit, which would  
19 also be a good reason to ensure that new designs going  
20 forward on tanks are in compliance with the EPA  
21 requirements so that we're not continuing to create a  
22 burden for our communities, especially with these --  
23 perhaps a tank and these overflows.

24                  So there are various options with regard to  
25 pressure or vacuum release vents on tanks that entities



1 could pursue as well. There's also bypass vents that could  
2 be used on those drain lines in the smaller -- these  
3 smaller pipe diameter type systems. So there are numerous  
4 options that folks can pursue. And I think going forward,  
5 as I mentioned, there's the SRF set-aside funds that are  
6 going to be available, where we can provide better  
7 outreach, education, and training to our community, to our  
8 operators, to our public water systems, as well as our  
9 private water systems too, so that we can get these folks  
10 in compliance, have safe drinking water, and ensure that  
11 the design also meets the enforcement criteria.

12 ACTING CHAIR CAHN: And what kind of -- can  
13 you just go over the kinds of modifications that people  
14 would be doing that would require the upgrade and kinds of  
15 modifications that wouldn't require upgrading, that, you  
16 know --

17 MR. HENDON: Sure.

18 ACTING CHAIR CAHN: -- grandfathered in  
19 clause. Because I looked at the definition in the  
20 regulations, and it's not real clear to me.

21 MR. HENDON: Absolutely.

22 ACTING CHAIR CAHN: Maybe it's clear to  
23 everyone else, but to me it's clear as mud.

24 MR. HENDON: And you bring up a good point,  
25 that was a number of commenters kind of had similar

1 questions with regards to when does the permit start, when  
2 does the permit stop. Essentially if you're replacing a  
3 pump -- anything in-kind -- an in-kind replacement would  
4 not need a permit. So if you're needing -- if you had a  
5 pipe rupture and you need to go get that pipe fixed,  
6 replace a valve, address a hydrant, by all means, yes, get  
7 those things fixed, rather than waiting and coming to DEQ  
8 to get a permit.

9           However, if you're -- if you're doing that fix  
10 and you realize, Hey, this pipe is old, aged, and you start  
11 ripping up a number of blocks within -- number of city  
12 blocks to address this fix, then you need to come and get a  
13 permit. So generally anything over a block, half a block,  
14 we're looking -- as far as pipe distance goes, we would  
15 expect to see a permit. You're going to have a number of  
16 perhaps service connections, pressure differential, other  
17 things for us to look at and evaluate.

18           ACTING CHAIR CAHN: So one of the comments  
19 that I would have on your response to comments, a lot of  
20 times it just says, you know, look here for modifications.

21           MR. HENDON: Yeah.

22           ACTING CHAIR CAHN: And I guess my thought  
23 would be just put in a sentence like you said, you know --

24           MR. HENDON: Absolutely. And we are  
25 looking -- so internally we've discussed along with 24

1 mesh, along with what requires a permit, generating an FAQ  
2 page or section, so that folks know and they can get that  
3 information quickly on our website. And we can also  
4 address it within our comments -- response to comments as  
5 well. Because we think that would be a beneficial use for  
6 folks and provide them with clear -- better direction.

7                   ACTING CHAIR CAHN: Okay. And I should  
8 have started off by saying, you know, I really appreciate  
9 all that you guys have done. I know that I asked, you  
10 know, at the last meeting that you go back to commenters  
11 and staff, and you've done that. And I really appreciate  
12 what you've done. It's really helpful. And I think it's  
13 improved. You know, I think -- and I also am glad that we  
14 extended the public comment period, because I think we got  
15 some good comments. It's a pretty --

16                   MR. HENDON: We would agree with you.

17                   ACTING CHAIR CAHN: This is my doctor's  
18 appointment tomorrow, so I have to get it. I'm sorry.  
19 I'll be right back.

20                   MR. HENDON: Sure.

21                   (Off-the-record discussion.)

22                   ACTING CHAIR CAHN: Where was I?

23                   MS. ZYGMUNT: I think we agree.

24                   MR. HENDON: 24 mesh.

25                   MS. ZYGMUNT: Yeah. And we appreciate the

1 feedback from the December meeting.

2           And, again, Keenan has done a really good job  
3 about how to do effective outreach, and we've learned some  
4 things that we'll take to new rulemaking projects. So I  
5 think we have a better product because of comment. At this  
6 point in time I think we have good responses and have had  
7 good productive discussion with commenters. Again, we'll  
8 consider the comments that Mark Pepper gave to us this  
9 morning, and come up with written responses to those  
10 comments.

11           But I'll turn it back over to you in terms of  
12 where you'd like to take the conversation today.

13           ACTING CHAIR CAHN: Okay. I guess just  
14 another sort of big picture comment that I have is, you  
15 know, there's lots and lots of very small water systems in  
16 use in the state, campgrounds, rest stops, little parks.

17           MR. HENDON: Absolutely.

18           ACTING CHAIR CAHN: And, you know, I'm  
19 concerned about -- you know, I guess my question is, is  
20 there a way of having some kind of de minimis that says if  
21 you, you know, serve less than a certain number of  
22 households, people, or size system, that we can say you  
23 don't have to follow all of these regulations? So, for  
24 instance, I'm concerned about the storage. So if -- if  
25 people have to have, you know, small -- small systems,

1 campground, whatever, has to have a second well or storage  
2 tank that can store -- you know, so you have to have twice  
3 as much as your daily demand, whatever the term is, and  
4 you're only being used seasonally, you know, then you can  
5 have water aging problems in the tank, because you have too  
6 much water, and then you have to dump that water out.

7           And so it seems like one-size-fits-all doesn't  
8 seem to work. I think a lot of the problems in Wyoming  
9 where there's lots of small water systems, a small  
10 subdivision, a small, you know, restaurant. I mean, you  
11 can think of a million situations.

12           MR. HENDON: Scenarios, right.

13           ACTING CHAIR CAHN: Yeah, scenarios. Yeah,  
14 thank you.

15           So I'm just wondering if there's a way of saying,  
16 okay, if you're less than this, this doesn't apply,  
17 because, you know, these aren't year-round -- I don't know  
18 if it has to be year-round. Anyways, you probably thought  
19 of this, I'm sure, so I'll let you answer, but that's my  
20 concern.

21           MR. HENDON: We -- so absolutely we have  
22 thought of that with regards to your transient noncommunity  
23 water systems, your RV parks, campgrounds, things of that  
24 nature. You know, there is the two-well requirement or the  
25 storage requirement, as you mentioned. It is something

1 that we have looked into and addressed. Internally we've  
2 discussed it. I want to say based on our internal  
3 discussions, we left the criteria as-is, as it was existing  
4 with regards to these systems. I'm not sure if Jennifer  
5 has additional ideas or thoughts with regards to these  
6 systems, on these types.

7 MS. ZYGMUNT: It's a good question, and  
8 it's one that's on our radar, and one that we've been  
9 talking with Mark, with Wyoming Association --

10 ACTING CHAIR CAHN: Mark Pepper.

11 MS. ZYGMUNT: Mark Pepper.

12 MR. HENDON: Mark Pepper.

13 MS. ZYGMUNT: -- about extensively and it  
14 is a big need in the state to figure out how to help these  
15 transient systems, and particularly, as we see more tourism  
16 within the state, you know, some of these seasonal  
17 facilities are seeing increased visitation. You know, they  
18 may be overloaded. They may not have originally developed  
19 the site to have their well and their septic system  
20 appropriately sited, and they grow and become a public  
21 water system well, and then they need to make some choices  
22 about how to manage water/wastewater on the property. So  
23 we're seeing a lot of challenges, and I think probably the  
24 first thing that needs to happen is we need to find  
25 resources for more technical assistance for those

1 facilities. And Keenan mentioned earlier that there was  
2 some legislation that opened up some state revolving fund  
3 set-aside money for the State to potentially pursue that  
4 could be used for technical assistance for these transient  
5 communities.

6           So we plan to continue having these discussions  
7 with WARWS and other groups, and I think the place to start  
8 would be better technical assistance to make sure they have  
9 appropriate resources and can be in compliance. I think in  
10 terms of the one-size-fits-all approach, I can absolutely  
11 understand that may be the case. I don't know that I'm  
12 able today to talk about specifics where we could make  
13 adjustments, but I think that's something that we can keep  
14 in mind as we continue to look at this rule and those  
15 systems while also making sure keeping those facilities in  
16 compliance with EPA PWSS system.

17           So I hear your concern. I can't give you  
18 specific commitments right now, but we will keep that in  
19 mind as we work with these transient systems.

20           ACTING CHAIR CAHN: Okay. I think that --  
21 to me, that's a real showstopper. That's a really  
22 important issue. So, yeah, if you can add it, you know,  
23 next time we look at this, if -- if we don't -- I mean, I'm  
24 only one person on the Board, but if the Board chooses to  
25 pass this on to EQC, then you'll be looking at it years

1 down the road. But if the Board chooses not to recommend  
2 going to EQC, then I would like to see you looking at that  
3 some more.

4 MR. HENDON: Sure.

5 ACTING CHAIR CAHN: I think it's really  
6 important.

7 MR. HENDON: Right.

8 ACTING CHAIR CAHN: You know, and I think  
9 about campgrounds where -- you know, state parks, whatever,  
10 where -- so the well runs dry, you just say there's -- you  
11 shut down that campground, and say, okay, we're done for  
12 the season a little earlier, this marina, this whatever --

13 MR. HENDON: Yeah.

14 ACTING CHAIR CAHN: -- you know, we're done  
15 a little early.

16 MR. HENDON: Yep. There's definitely  
17 likely some options that --

18 ACTING CHAIR CAHN: And I'm really  
19 concerned about -- not just -- I mean, it's one thing if  
20 they're going from seasonal to permit, or they've got way  
21 more people, what you're addressing on the opposite end of  
22 the scale where they -- I'm looking at the opposite from  
23 what Jennifer's looking at --

24 MS. ZYGMUNT: I see.

25 ACTING CHAIR CAHN: -- where are we



1       oversizing and making it too extensive for them, because,  
2       you know, they're seasonal and transient, whatever, so...

3               Thanks. Okay. That's kind of a big-picture one  
4       from me.

5               Okay. So I'm wondering if we want to start with  
6       Chapter 10, because we didn't get to 10 on --

7                       BOARD MEMBER DEURLOO: Section 10?

8                       ACTING CHAIR CAHN: Section. Thank you.

9       Sorry. Excuse me.

10                      MS. ZYGMUNT: Madam Chairwoman, if I could  
11       make a suggestion, and it might be beneficial, if we could  
12       ask if Mr. Dickson has any big-picture comments he'd like  
13       to share.

14                      ACTING CHAIR CAHN: Sure. Brian, do you  
15       have any big-picture comments? You'll have to go off mute.

16                      BOARD MEMBER DICKSON: No. I'm fine the  
17       way it is.

18                      ACTING CHAIR CAHN: Other board members  
19       have some big picture -- other comments, big picture?

20                      BOARD MEMBER DEURLOO: No, thank you.

21                      BOARD MEMBER COCHRAN: No.

22                      ACTING CHAIR CAHN: So I guess my question  
23       is do we want to go through chapter -- chapter, thank  
24       you -- Section 10 on, or do we want to start back at the  
25       beginning again with my questions?

1                   So I don't know. Keenan, whatever works best for  
2 you.

3                   MS. ZYGMUNT: Madam Chairwoman, I think  
4 we'll leave it to the Board's preference. You know, we are  
5 happy to answer any questions and thoughts that we would  
6 like to discuss. We are not planning on kind of going  
7 through a page-by-page, line-by-line review. I think given  
8 the presentation we heard this morning, I think we can go  
9 section by section, just open it up to questions or  
10 comments in that section. We can move forward that way.

11                   ACTING CHAIR CAHN: What do you guys  
12 prefer, starting with 1 or starting with 10?

13                   BOARD MEMBER DEURLOO: I like to plow new  
14 ground.

15                   ACTING CHAIR CAHN: Plow new ground? Okay.  
16 We'll start with 10.

17                   BOARD MEMBER DEURLOO: Plow new ground,  
18 sometimes plant the seed and -- so answer to your question,  
19 start at Section 10?

20                   ACTING CHAIR CAHN: Start at Section 10.  
21 So on page 12-16 of the green copy.

22                   BOARD MEMBER DEURLOO: 12-16.

23                   ACTING CHAIR CAHN: All right. So I -- my  
24 first question is on page 12-18. It's line 818. And I  
25 understand the change made was because EPA required that.

1 It deleted "for plants for the maximum daily flow of 50,000  
2 gallons per day or more..." And that is a little bit of my  
3 one-size-fits-all. We had something that allowed us to  
4 rethink that. So maybe you can talk about the discussions  
5 with EPA on that.

6 MR. HENDON: Sure.

7 ACTING CHAIR CAHN: And whether there's any  
8 wiggle room.

9 MR. HENDON: Sure. And with regards to the  
10 meters, we did a search for meters and meter cost. We  
11 didn't see a significant cost or rise with regards to a  
12 meter requiring instantaneous flow rate. They're going to  
13 be -- the meter would not provide additional burden to the  
14 entity or the user to provide an instantaneous flow rate.  
15 With it being a requirement with EPA from their guidance,  
16 we went ahead and incorporated that change.

17 ACTING CHAIR CAHN: Okay. And then I just  
18 have -- and I'll go over -- and I'll get with you on a few  
19 other editorials later. Okay. Let me just look -- I've  
20 got to look in all the places for Section 10 to see what I  
21 have. So in the response to comment from Ty Ross, on  
22 10(b)(i), on page 16 of the comments. I think the  
23 reference to 10(b)(iv) is wrong. I think it should be  
24 10(b)(ii).

25 That's the same doctor's office. I'm sorry.

1 BOARD MEMBER DEURLOO: Yeah, take it. You  
2 do what you got to do.

3 (Off-the-record discussion.)

4 ACTING CHAIR CAHN: Really sorry.

5 MS. ZYGMUNT: Madam Chairwoman, we're in  
6 agreement with that correction, and we'll modify that --

7 THE REPORTER: Excuse me.

8 MS. ZYGMUNT: We're in agreement with that  
9 correction, and we will modify that response to comments.

10 ACTING CHAIR CAHN: Okay. And then I guess  
11 it's the same -- let's see, page -- it's the same question  
12 about EPA comment on page 17, where the greater than  
13 .5 million gallons per day or population greater than 3300,  
14 that also disappeared, got deleted. And I'm wondering --  
15 I'm wondering if that's something with wiggle room.

16 So there was language, maybe it's in the -- maybe  
17 it's in the 10 States Standards.

18 MR. HENDON: Gotcha. In the -- so on that  
19 one, this was a comment where we were requiring --  
20 essentially EPA's giving us an off-ramp to allow either/or.

21 ACTING CHAIR CAHN: Okay.

22 MR. HENDON: So we viewed that as a win --

23 ACTING CHAIR CAHN: Okay.

24 MR. HENDON: -- versus the language that we  
25 had. And so they were saying you keep the language you

1 have, you're going to be doubling up your meters and  
2 providing an additional burden to your communities. But if  
3 you go with what we're proposing, you can get away with  
4 just a meter, or you can continue to have two of these  
5 meters.

6 ACTING CHAIR CAHN: Okay. So they required  
7 getting rid of that language --

8 MR. HENDON: They said, Hey, you know --

9 ACTING CHAIR CAHN: Give and take.

10 MR. HENDON: Yeah, it was a little give and  
11 take. They said, Hey, we can give you a bit of an off-ramp  
12 here with regard to benefits to your users.

13 ACTING CHAIR CAHN: That's all I have on  
14 Section 10.

15 MR. HENDON: Okay.

16 ACTING CHAIR CAHN: So...

17 Okay. Section 11, Source Development. And I'll  
18 ask the Board, please interrupt me or just raise your hand  
19 or -- if you have something on Section 10.

20 BOARD MEMBER DEURLOO: Sure. I'm good.

21 BOARD MEMBER COCHRAN: I have a comment on  
22 Section 11, if you're moving there.

23 ACTING CHAIR CAHN: Okay. Great.

24 BOARD MEMBER COCHRAN: Page 12-22, line  
25 978, it talks about a 10-foot setback for property lines.

1 It seems to me you need to be more consistent with your  
2 other setbacks, because you're either putting the burden on  
3 another landowner not to install things you're setting back  
4 from, or you're putting it outside the operator's capacity  
5 to stop those things from occurring. So I think they  
6 either need to have agreement from the other landowner that  
7 those things won't occur or your setbacks need to be  
8 consistent with your other setbacks.

9 MR. HENDON: Okay. And so in looking at  
10 page 12-22, you would recommend perhaps it follows the  
11 setbacks kind of at the top of the page, perhaps, with  
12 the --

13 BOARD MEMBER COCHRAN: Yeah.

14 MR. HENDON: -- 50-foot.

15 BOARD MEMBER COCHRAN: Or the -- you know,  
16 you've got 500 feet from absorption field.

17 MR. HENDON: Yeah. And I think that --  
18 yeah. That is -- that is definitely something for us to  
19 look at and consider, and I think we're probably looking at  
20 from a construction standpoint with regards --

21 BOARD MEMBER COCHRAN: At least design  
22 standards. If they can get agreement from the other  
23 landowner, I'm not going to put any of those things in  
24 there, that works for me too, you know.

25 MR. HENDON: Right.

1 BOARD MEMBER COCHRAN: Thank you, Madam  
2 Chair.

3 ACTING CHAIR CAHN: Anyone else from the  
4 Board have comments on Section 11?

5 Okay. So I have questions in terms of the 10  
6 States Standards. Why was 3.2.1.1, the source capacity,  
7 why was that removed? So that is under Quantity, Source  
8 Capacity, "The total developed groundwater source capacity,  
9 unless otherwise specified by the reviewing authority,  
10 shall equal or exceed the design maximum day demand with  
11 the largest producing well out of service."

12 MS. THOMPSON: That was in response to a  
13 comment from Mr. Ben Jordan --

14 ACTING CHAIR CAHN: Okay.

15 MS. THOMPSON: -- who noted that 3.2.1.1 is  
16 not agreed -- there was a conflict with I believe it was  
17 Section 11(e)(i). And so we looked at the concern and took  
18 out the reference --

19 ACTING CHAIR CAHN: Okay.

20 MS. THOMPSON: -- because of a conflict  
21 later in the section.

22 ACTING CHAIR CAHN: Okay.

23 MR. HENDON: Yes, I think we took out the  
24 reference to the 10 States Standards, but we already -- we  
25 essentially have that language within Chapter 12 under

1 (e) (i) on page 12-21.

2 ACTING CHAIR CAHN: All right. Then the --  
3 so let's see. I think -- I have a note that 3.2.6.5 in the  
4 10 States Standards conflicts with line 1067. And I --  
5 Gina, thank you for sending me a copy of this. It was  
6 really helpful for the review to have the 10 States  
7 Standards.

8 So 3.2.6.5 is limestone or sandstone wells.  
9 Actually, maybe that's now -- that's been changed. 1067  
10 has been changed. Right or not?

11 MR. HENDON: I think it may get changed  
12 with that proposed language change.

13 ACTING CHAIR CAHN: Do you remember what it  
14 was?

15 MR. HENDON: I'm going to guess it got  
16 moved down within the document.

17 ACTING CHAIR CAHN: Oh, is this the one  
18 where -- I'll have to see the new wording.

19 So this is for wells without permanent casing.  
20 And is this where the -- we going to be grouted into the  
21 next -- to the formation, right?

22 MR. HENDON: Yeah, this is in order to  
23 comply with SEO.

24 ACTING CHAIR CAHN: Okay.

25 MR. HENDON: So essentially the casing's



1 going to extend through that layer, and will be grouted in  
2 that layer.

3 ACTING CHAIR CAHN: Okay.

4 MR. HENDON: And then extend 10 feet  
5 minimum --

6 ACTING CHAIR CAHN: Okay.

7 MR. HENDON: -- into that target aquifer to  
8 comply.

9 ACTING CHAIR CAHN: So this 10 feet -- in  
10 the top 10 feet, that's gone now, that's on my --

11 MR. HENDON: Yeah.

12 ACTING CHAIR CAHN: Okay. Good. Thank  
13 you.

14 MR. HENDON: That should be gone.

15 ACTING CHAIR CAHN: Okay. Good. Thank  
16 you.

17 But so then is it necessary to have 3.2.6.5 for  
18 limestone or sandstone wells to have the 50 feet, "Where  
19 the depth of the unconsolidated is more than 50 feet, the  
20 permanent casing shall be firmly seated in uncreviced  
21 unbroken rock." And "Grouting requirements determined by  
22 the reviewing authority."

23 And if it's "...less than 50 feet, the depth of  
24 casing and grout shall be at least 50 feet or as determined  
25 by the reviewing authority." So I guess that gives us some

1 flexibility.

2 MR. HENDON: I think it provides

3 flexibility.

4 ACTING CHAIR CAHN: Okay.

5 MR. HENDON: And the design engineers to

6 work with our district engineers to make their case,

7 either -- one way or the other.

8 ACTING CHAIR CAHN: Okay. And then the

9 next thing is in citing 3.2.7 on line 838. It's a little

10 bit confusing for me, with -- if you cite 3.2.7, but then

11 say -- in my mind that implies all of 3.2.7, but I think

12 you're not implying, because then it is broken down to

13 3.2.7.3 and .4 and .6 and .7 and .8. So I'm wondering

14 if -- and all that 3.2.7 says is a title, Well Pumps,

15 Discharge Piping and Appurtenances. So I'm thinking you

16 would delete the line that says 3.2.7, Well Pumps,

17 Discharge Piping and Appurtenances.

18 MS. THOMPSON: Yeah. We can remove that

19 from the paragraph.

20 ACTING CHAIR CAHN: Okay. Good.

21 And I guess that, in my mind, kind of brings up

22 an issue of checking all of the citations in each section

23 of the TSS to make sure that there isn't an overlying --

24 you know, a bigger --

25 MR. HENDON: A bigger -- yeah, we're

1 covering something more than we need to.

2 ACTING CHAIR CAHN: It implies that  
3 somebody's confused, so just to check.

4 Okay. All right. So then on line 845, it's  
5 Section 11(c). So first -- okay. It just -- I'm thinking  
6 how this flows. The first thing we're talking about is  
7 source development, surface water intake structures, and  
8 then we go to service connections and groundwater source  
9 development, isolation distances, but between those we have  
10 transmission lines interconnecting process piping. And all  
11 that stuff seems kind of out of place. So it seems like  
12 transmission and piping should come after source  
13 development. So it just doesn't flow to me.

14 MR. HENDON: Okay.

15 ACTING CHAIR CAHN: So I would suggest  
16 moving that section.

17 MR. HENDON: Kind of a layout?

18 ACTING CHAIR CAHN: Yeah.

19 MR. HENDON: Okay.

20 ACTING CHAIR CAHN: So it's kind of  
21 organizational, as you're going through and thinking about  
22 this stuff --

23 MR. HENDON: Sure.

24 ACTING CHAIR CAHN: -- going from the  
25 source out to --

1 MR. HENDON: So you go from the --

2 ACTING CHAIR CAHN: -- the transmission --

3 you know, you're going from the --

4 MR. HENDON: To the transmission --

5 ACTING CHAIR CAHN: The source to --

6 THE REPORTER: One at a time, please.

7 ACTING CHAIR CAHN: Okay. Sorry.

8 MR. HENDON: Sorry, Kathy.

9 ACTING CHAIR CAHN: Okay. I'll let you  
10 guys figure out where it belongs, but...

11 Okay. Then I think there was a comment made --  
12 I don't remember who made it -- on line 938, which is  
13 Section 11(b)(i). That the language -- so the language  
14 reads "Proposed designs shall include a minimum of two  
15 wells supplying twice the daily demand, or one well and  
16 finished water storage that together equal twice the  
17 maximum daily demand."

18 And I think the question really is -- I know the  
19 answer, but the way it's written, it could -- you could  
20 argue each well would supply two times the daily demand.  
21 And I think what we mean is combined wells supply two times  
22 the daily demand. So I think the problem is with the  
23 wording "two wells supplying twice the maximum daily..."  
24 So I think we can either say two wells together supplying  
25 twice the daily demand, or two wells combined, or something

1 in there to indicate that it isn't each well supplying it  
2 two times, so...

3 And then --

4 BOARD MEMBER COCHRAN: But it is each well  
5 supplying once.

6 ACTING CHAIR CAHN: Yeah.

7 BOARD MEMBER COCHRAN: You can't have one  
8 well supplying one and three-quarter and one well supplying  
9 a quarter.

10 ACTING CHAIR CAHN: Yeah, you can. Because  
11 it's the --

12 BOARD MEMBER COCHRAN: Not if your big one  
13 shuts down.

14 ACTING CHAIR CAHN: Well, so you have twice  
15 the daily demand you have together with two wells. So if  
16 one -- oh, so you're saying if one -- oh, if one's only  
17 half of the daily demand, that --

18 MR. HENDON: Yeah, I think they both need  
19 to supply twice the maximum daily demand so that should one  
20 go down, the other is capable of providing the same supply.

21 ACTING CHAIR CAHN: So they each have to  
22 supply the daily demand.

23 MR. HENDON: Yes.

24 ACTING CHAIR CAHN: So then it would be --  
25 so if you had one smaller well, now you're going to drill a

1 new well to increase your capacity, you can't have one  
2 supplying a quarter of the daily, the new one supplying --

3 MR. HENDON: The combination --

4 ACTING CHAIR CAHN: -- 1.75.

5 MR. HENDON: -- gets you -- gets you all  
6 the way there? No. Short answer is no. It would need to  
7 be two wells providing twice the maximum.

8 ACTING CHAIR CAHN: Each well.

9 MR. HENDON: Each.

10 ACTING CHAIR CAHN: Each well provides  
11 twice the daily demand.

12 MR. HENDON: Each one.

13 ACTING CHAIR CAHN: So now you have four  
14 times the daily demand.

15 MR. HENDON: So I think that goes back to  
16 your original concern with regards to smaller systems.

17 ACTING CHAIR CAHN: Yeah. Definitely.

18 MR. HENDON: And an off-ramp for smaller  
19 systems.

20 ACTING CHAIR CAHN: Especially now I  
21 understand it to mean --

22 MR. HENDON: Yeah, for your smaller  
23 systems.

24 ACTING CHAIR CAHN: But if you have one  
25 well in the finished water storage, you only have twice the

1 maximum daily demand. So that doesn't make sense to me  
2 that the wells -- two wells would have to provide twice as  
3 much as a well and storage -- finished storage water tank.  
4 That doesn't make sense.

5 MR. HENDON: Noted. We can take a look at  
6 it.

7 MS. ZYGMUNT: We understand the concern.

8 ACTING CHAIR CAHN: Okay.

9 MS. ZYGMUNT: But, again, there's some good  
10 reasons for requirements, we'll take a look at the wording  
11 and make sure first that it's clear what we mean, and then  
12 recognize that ties into your one-size-fits-all comment.

13 ACTING CHAIR CAHN: The next comment I have  
14 is on Table 1, at the bottom of page 12-21. So if you go  
15 and reference to Chapter 15, the septic tank minimum  
16 distance to well for septic tanks for water supply wells is  
17 a hundred feet from a public water supply to a septic. So  
18 I'm wondering why we have 50 feet. And I'm going to pull  
19 up Chapter 15.

20 MS. THOMPSON: Did you mean Chapter 25, the  
21 small wastewater chapter?

22 ACTING CHAIR CAHN: Yeah, 25.

23 MS. THOMPSON: Okay.

24 ACTING CHAIR CAHN: Sorry.

25 MS. THOMPSON: That's okay. I wanted to

1 make sure --

2 ACTING CHAIR CAHN: I can't read my own  
3 handwriting.

4 MS. THOMPSON: I wanted to make sure,  
5 because I was thinking we had rescinded 15.

6 ACTING CHAIR CAHN: Sorry.

7 MS. THOMPSON: But it's --

8 ACTING CHAIR CAHN: It's so hard to keep  
9 track of what's in -- there's so many rules we've looked at  
10 over the years, it's hard to keep track of the chapter  
11 names. So, yes, I meant Chapter 25. I apologize. I was  
12 just going to pull it up, so I have it.

13 Okay. So Chapter 25 is septic tanks, soil  
14 absorption systems, and other small wastewater systems.  
15 And it's requiring a hundred feet so -- and I can -- I can  
16 search for that, if you want.

17 MR. HENDON: If you look at page 25-8, the  
18 top line for wells, the offset distance for the well to a  
19 septic tank is 50 feet. To the absorption system in  
20 Chapter 25 shows 100 feet. And the proposed Chapter 12, we  
21 have 200 feet.

22 ACTING CHAIR CAHN: Okay. I'm looking at  
23 septic tank, not the absorption. So looking at Table 4 in  
24 Chapter 25, Public Water Supply Wells, minimum horizontal  
25 setbacks for domestic wastewater in feet from public water



1 supply well to a septic tank or equivalent is a hundred,  
2 and here it's 50. So I'm on -- I don't have line numbers,  
3 but it's in -- it's the second row in Table 4.

4 MR. HENDON: Yep. I agree with you.

5 ACTING CHAIR CAHN: Okay.

6 MS. ZYGMUNT: We will review both tables  
7 and make any corrections to Chapter 12.

8 ACTING CHAIR CAHN: Okay.

9 MR. HENDON: Thank you, Lorie.

10 ACTING CHAIR CAHN: And how do you know --  
11 I'm not sure where I -- can't always follow my thinking.

12 So small wastewater systems defined -- oh, okay.  
13 In 35-11-103(c) (ix), a single residential unit serving no  
14 more than four families or 2,000 gallons per day -- gallons  
15 sewage per day is for a small wastewater system, and I'm  
16 wondering if that might be a place to help us with small  
17 public water supplies. You know, I don't know.

18 MR. HENDON: That 2,000 --

19 ACTING CHAIR CAHN: I don't know what the  
20 answer is for how to define a de minimis that could be more  
21 flexible. So that's a place to look.

22 MS. ZYGMUNT: Yeah. I 'm understanding  
23 your comment. We can consider that, but that might be a  
24 long-term project, particularly if we're going to propose  
25 statute changes, that's going to require legislative

1 authority to do that. But we'll think about that. We  
2 understand what you're asking us to consider.

3 ACTING CHAIR CAHN: Okay. And then in  
4 Table 12, septic tank distance -- isolation distance for  
5 domestic sewage flows greater than 2,000 gallons per day,  
6 septic tank you have 50 feet. And then Table 7 of Chapter  
7 25, which I have to find. I believe it's a hundred --  
8 hundred feet again. So there's a disconnect.

9 MS. ZYGMUNT: Yeah. We will do the same  
10 corrections there.

11 ACTING CHAIR CAHN: Next comment --  
12 question I have is on line 6961, says --

13 THE REPORTER: Lorie, can you keep your  
14 voice up when you read.

15 ACTING CHAIR CAHN: Sorry. Okay.

16 So line 60 talks about -- well, starting at line  
17 57. So it's 11(e) -- so hard to do this -- (ii)(C). "If  
18 domestic wastewater is the only wastewater present and the  
19 design domestic sewage flow is greater than 10,000 gallons  
20 per day, or non-domestic wastewater is present the required  
21 isolation shall be determined by a subsurface study in  
22 accordance with the requirements with Water Quality Rules  
23 Chapter 3, Section 17(b), but shall not be less than those  
24 required in Tables 1 and 2 of this Section."

25 So I wrote I'm confused because when I went to

1 Chapter 3, Section 17(b), public water supplies are exempt  
2 from 3-17(b) in the opening paragraph Section 17, unless I  
3 misunderstood it. Maybe you can --

4 MR. HENDON: I have this is the --

5 ACTING CHAIR CAHN: I don't have it pulled  
6 up. Maybe you can pull it up, Gina, and look at it.

7 MS. THOMPSON: This particular one I know  
8 we discussed it with our attorney. I'm just trying to find  
9 the response, because she explained -- and I don't want to  
10 word it improperly and confuse the record, so...

11 ACTING CHAIR CAHN: Do you want to get back  
12 on that one?

13 MS. ZYGMUNT: We will note it. Again, I'm  
14 recalling that conversation with our attorney as well. I'm  
15 feeling confident that that is the appropriate language,  
16 but we will double-check that --

17 ACTING CHAIR CAHN: Okay.

18 MS. ZYGMUNT: -- and run it by Nicole as  
19 well.

20 ACTING CHAIR CAHN: Get back with us on  
21 that.

22 MS. ZYGMUNT: We can respond back to the  
23 Board at some point, yeah.

24 ACTING CHAIR CAHN: Okay. Great. And  
25 again I'm going to bring up the acidizing section. Where

1 does that start? Oh, it starts on line 993. And last  
2 meeting we talked a little about -- little bit about  
3 acidizing, and that there was a situation, was it in  
4 Gillette, where DEQ thought the problem was from  
5 acidization procedures, but then it turned out not to be.  
6 And that that had brought up issues that hadn't maybe  
7 addressed.

8           And someplace else in here, in this chapter,  
9 there's actually -- no, it's in response to comments, where  
10 you say, well, we're not going to address that because it  
11 doesn't happen very often in Wyoming, or wherever. So I  
12 just want to point out that if this acidizing -- you know,  
13 we're talking about a page on acidizing, if it hasn't  
14 happened yet. So it is kind of regulating for the  
15 unhappened [sic] or the anticipated issue, whereas in the  
16 other place, you know, you bring up we don't have to worry  
17 about it, it doesn't happen much in Wyoming. So in my mind  
18 that's a little bit of a --

19           MR. HENDON: A disconnect?

20           ACTING CHAIR CAHN: -- disconnect. And I  
21 would suggest removing this acidizing stuff, and maybe it  
22 belongs in the policy that you're, you know -- because --

23           MS. ZYGMUNT: The concern's noted. And we  
24 can look in the response to comments and see a further one  
25 that you're thinking of, if we need to provide some more

1 rationale. It is my intent to keep the well acidization  
2 language in the rule at this time. I feel, again, the  
3 Gillette-Madison, while it ultimately did not prove to be  
4 the acidizing activities, it does raise some concerns that  
5 we could tighten up our regulations to make sure that we  
6 are protecting public water supplies, individual  
7 homeowners' wells, during those activities, even if it's  
8 not occurring very often or we think it's unlikely to  
9 occur. And I'm speaking partly on behalf of my predecessor  
10 who felt that it was important to keep this language in the  
11 rule.

12 ACTING CHAIR CAHN: And I guess I just feel  
13 like it's new -- a new day, you know.

14 MS. ZYGMUNT: I will note that the Board  
15 approved this language in 2019.

16 ACTING CHAIR CAHN: Yeah. I know that.

17 MS. ZYGMUNT: So we have had these  
18 discussions before. So at this time I'm not willing to  
19 take that language out of the rule. But I understand your  
20 concerns, and we can be consistent in our rationale.

21 ACTING CHAIR CAHN: And especially with  
22 trying to keep the rules concise --

23 MS. ZYGMUNT: Sure.

24 ACTING CHAIR CAHN: -- and shorten the  
25 rules, so -- and if it -- if you had any policy and then it

1 were to become an issue down the road -- you know, if you  
2 have it in policy, then it's in there for people as a  
3 guidance.

4 MS. ZYGMUNT: The key there is if it's a  
5 policy, it is not regulatorily enforceable. And so if we  
6 had concerns where we needed to take actions on these  
7 rules, it needs to be in the rule and not a policy.

8 ACTING CHAIR CAHN: Okay. I'm trying to  
9 remember I just have a note that on 1062 -- 1061, I think  
10 Ben Jordan had brought up that gravel pack wells. It's not  
11 really appropriate to have them gravel packed. You know,  
12 so I think -- I'm not -- I can't remember what your  
13 response was, but I think the response was you aren't going  
14 to change it.

15 MR. HENDON: We're planning not to change  
16 it. But if you also notice, we did change the language to  
17 include filter pack. Depending on the documents that you  
18 utilize or you read, gravel pack is a common term when  
19 doing wells. So filter pack is another terms that's used  
20 with regards to wells and providing that packing material.  
21 So we've provided both options, I guess both conventions  
22 with regards to the section. Going through the 10 States  
23 Standards, everything they reference is gravel pack.

24 ACTING CHAIR CAHN: So do they have a  
25 definition of gravel pack? We're not talking about big

1 pieces of gravel, as -- which would not be appropriate,  
2 so...

3 MR. HENDON: Yep. And also note we did  
4 talk this comment over with Ben, and he was -- he thought  
5 our solution was a good one.

6 ACTING CHAIR CAHN: Okay. All right.  
7 That's fine with me, then.

8 MR. HENDON: And I would say that when we  
9 met them, with their commenters, we did come to a mutual  
10 understanding.

11 ACTING CHAIR CAHN: Okay. Great. That  
12 sounds good.

13 MR. HENDON: So what we were intending to  
14 move forward with.

15 ACTING CHAIR CAHN: Okay.

16 MS. ZYGMUNT: And, Madam Chairwoman, if I  
17 could interject. We're at 2:30, just a little bit past. I  
18 think we have about an hour or less for Mr. Deurloo to get  
19 to his commitment. I would like to make sure we review the  
20 rest of the rule to make sure we get the Board's advice on  
21 all the sections. So while I don't want to rush the  
22 conversation, this is productive, I would just like to keep  
23 an eye on the time to make sure we can accommodate the  
24 board member.

25 BOARD MEMBER DEURLOO: Let me see if I can

1 push it back a little bit too.

2 ACTING CHAIR CAHN: We have the room until  
3 4:00; is that correct?

4 MS. THOMPSON: Uh-huh.

5 MS. ZYGMUNT: Yes.

6 BOARD MEMBER DEURLOO: I have until 4:00  
7 too. So thanks.

8 ACTING CHAIR CAHN: And then -- okay. On  
9 line 1089, on page 12-25, with regards to flowing wells.  
10 It says "Overflows shall discharge a minimum of 18 inches  
11 above grade..." and those wells, it's going to be hard to  
12 protect from freezing, so how do you -- you know, if the  
13 water's not flowing back into the well, why -- why couldn't  
14 you also, you know, allow a below-ground vault or be in the  
15 side of a hill or being partially buried or something that  
16 can allow additional ways to keep the wells from freezing,  
17 because if you have -- if you're not, you know, you get a  
18 cold snap and got water in that part of the well.

19 MR. HENDON: We can look at that comment  
20 and see if we do not have it addressed somewhere else in  
21 the section.

22 ACTING CHAIR CAHN: And then on line 1095,  
23 in the mineralized water, the -- one of the commenters  
24 wanted it to be put up to a thousand, and we have it  
25 defined back in the front as 500. So I guess one of the



1 things -- and this might not be the place for it, but the  
2 total dissolved solids is a secondary standard from EPA,  
3 and not at 500 and not a primary drinking water standard,  
4 so I'm just thinking -- and they consider anything over a  
5 thousand to be un -- unfit for human consumption. So there  
6 are mineralized water sources that people are using in  
7 Wyoming. So when we get back to the definition, if we  
8 could allow up to the thousand, you know -- so are we --  
9 because it's being used in the state -- it's being used  
10 successfully, so --

11 MR. HENDON: Yeah, I think it was -- so  
12 the -- we did discuss this with the commenter as well. We  
13 did leave it at the 500, as existing in our current Chapter  
14 12. Of the 16, 17 or so commenters, we only did receive  
15 the one comment with regards to mineralized water. We did  
16 leave it at the 500 secondary requirement.

17 MS. THOMPSON: Additionally, in the comment  
18 response we are requiring treatment. We're just saying if  
19 you are encountering that mineralized water with the TDS,  
20 we just want to protect that new well from that. So we  
21 aren't requiring treatments down to -- we aren't requiring  
22 treatment of that mineralized water.

23 ACTING CHAIR CAHN: Okay.

24 MS. THOMPSON: It's that we don't want it  
25 mixing with other nonmineralized water.

1                   ACTING CHAIR CAHN: Okay.

2                   MS. THOMPSON: Because obviously you if  
3 hadn't planned on treating it and you had an incident, now  
4 you get to treat, right?

5                   ACTING CHAIR CAHN: Okay. But then we go  
6 down to line 1103, applications that propose to use  
7 mineralized water as a public water supply shall  
8 demonstrate the treatment will comply with the Drinking  
9 Water Quality Standards required by 40 CFR. Now, 40 CFR  
10 141 has both the secondary and primary drinking water  
11 standards in it. So if you say you must comply with this,  
12 now you're taking a secondary standard and saying you must  
13 comply with a secondary standard. And I'm -- it seems  
14 like -- in the -- it seems like that needs to be reworded.  
15 So maybe you say shall demonstrate the treatment will  
16 comply with the Primary Drinking Water Quality Standards  
17 required by 40 CFR 141. So you're not implying they're  
18 going to have to treat to a secondary standard, so...

19                   MS. ZYGMUNT: We'll look into clarifying  
20 that.

21                   ACTING CHAIR CAHN: On line 11 -- 1112, so  
22 1-1-1-2, (viii), the casing shall be a required size to  
23 convey liquid. I think the word "size" is kind of  
24 indeterminate. Are we talking about length? Are talking  
25 about, you know, interior -- inside diameter, whatever? So

1 perhaps I think you're meaning diameter. So maybe just  
2 change it. I don't know if you mean -- I'm okay with  
3 either -- just leave it at diameter. Not inside or  
4 outside, but just diameter.

5 MR. HENDON: Okay.

6 ACTING CHAIR CAHN: And then I would --  
7 after pressure -- so "Casing shall be of required diameter  
8 to convey liquid at a specified injection/recovery rate and  
9 pressure," then you had ", shall be a required size..." So  
10 I think you can just go "comma and" to allow for sampling.

11 So -- and then I think then Jordan had mentioned  
12 in one of his comments that all of (viii) could be -- and  
13 (ix) could be deleted if you incorporated the 10 States  
14 Standards 3.2.4. And so I had -- I didn't understand why  
15 you wouldn't just incorporate by reference 3.2.4.

16 BOARD MEMBER DEURLOO: You want this here?  
17 Anthony, you want this?

18 MR. RIVERS: Are you done with it?

19 BOARD MEMBER DEURLOO: Yeah. Go ahead.

20 MR. RIVERS: Thank you.

21 BOARD MEMBER DEURLOO: Thank you.

22 ACTING CHAIR CAHN: I mean, I guess that's  
23 something just to take away and not necessarily answer  
24 today. But I thought, you know, if all of that -- all  
25 Section 3.2.4 looked good, since you're already

1 incorporating by standard -- by reference --

2 MS. ZYGMUNT: We'll look at that one, Madam  
3 Chairwoman.

4 ACTING CHAIR CAHN: Okay. On line 1179, in  
5 your response to comments you said you would change this to  
6 say the finished grade should slope at 1 inch per foot, and  
7 it didn't get changed in my copy, so just -- I'm sorry. I  
8 said see my note, now I don't know where my note is.  
9 Sorry.

10 Okay. Okay. I have a question on line 1198,  
11 where it says "Each well shall have a device capable of  
12 measuring the total well discharge and shall have a device  
13 capable of measuring the total discharge from the field if  
14 there's more than one pump in operation. And I just -- I  
15 don't understand why the total well filled -- like if each  
16 well meant -- it's just a question. I don't understand it.  
17 If each well measures its flow, why need each well to  
18 measure total discharge from the whole field? Why wouldn't  
19 you just add them up? So I'm missing something.

20 MR. HENDON: Yeah, I thought we changed  
21 this.

22 MS. THOMPSON: If that's easier, we had a  
23 discussion with the commenter where -- because it was one  
24 of Mr. Jordan's comments.

25 MR. HENDON: Yeah, I thought we changed

1 this to just a meter at each well.

2 MS. THOMPSON: I thought so too.

3 ACTING CHAIR CAHN: Okay. Great. Good.

4 MR. HENDON: So to do just what you said.

5 ACTING CHAIR CAHN: Okay. Great. I missed  
6 that.

7 MR. HENDON: I thought we changed that,  
8 but --

9 ACTING CHAIR CAHN: Okay. Good. Thank  
10 you. It's a little hard when I think those changes came in  
11 last night or something. Okay.

12 BOARD MEMBER COCHRAN: Madam Chair.

13 ACTING CHAIR CAHN: Yes.

14 BOARD MEMBER COCHRAN: You guys already  
15 have a requirement to meter at each well. I wonder if this  
16 one is more towards you need to measure the total -- or,  
17 you know, some way to calculate the total field.

18 MR. HENDON: We can look at that and see if  
19 that -- if it's just capable under meter at each well,  
20 or -- because most systems should already have --  
21 theoretically should have this data and the information and  
22 technology available to capture that well field data and  
23 provide that information.

24 BOARD MEMBER COCHRAN: That's why I thought  
25 this one was more leaning towards the total aquifer --

1 MR. HENDON: Gotcha. Gotcha.

2 BOARD MEMBER COCHRAN: -- production.

3 MR. HENDON: We'll look at it, clarify it.

4 ACTING CHAIR CAHN: I have one more on  
5 Section 11, and it's page 12-28, line 1240 to 1242 and I  
6 believe in the response to comments you have said you'd  
7 make a change, but I don't see the change in my copy, so...

8 MR. HENDON: Thank you.

9 ACTING CHAIR CAHN: Okay. That's all I  
10 have. Oh, wait a minute. One more.

11 For line [sic] 12-84, (vii), very last part of  
12 the chapter, it says "Spring boxes shall comply with the  
13 finished water storage requirement of Section 14 of this  
14 Chapter," And I believe they're in Section 15.

15 MR. HENDON: You are correct.

16 ACTING CHAIR CAHN: Okay.

17 MR. HENDON: Yep.

18 ACTING CHAIR CAHN: And let's see, this  
19 brings up my concern about small systems. So if springs  
20 don't supply fire water, do they need these requirements,  
21 so no air vents and all these associated problems with that  
22 24 mesh screen and water levels in the spring aren't going  
23 to fluctuate very much, half a foot or something. So it  
24 seems like here's another example of where maybe we don't  
25 have to --

1                   MR. HENDON: Again, I think we have to  
2 ensure we're providing design standards that comply with  
3 the enforcement agency.

4                   ACTING CHAIR CAHN: Okay. Enough said,  
5 huh?

6                   MR. HENDON: So we can --

7                   ACTING CHAIR CAHN: See if there's wiggle  
8 room.

9                   MR. HENDON: We can pursue those options,  
10 but, again, I would hate to put an entity behind the 8-ball  
11 and have to pursue additional costs to upgrade their  
12 system.

13                   ACTING CHAIR CAHN: Okay. All right.  
14 Section 12.

15                   So I hope I'm going to get through these. I'm  
16 afraid by 3:30 I'm not, but I'm trying. I don't want to  
17 speak too fast for Kathy.

18                   Okay. Section 12, the list of TSS things we're  
19 citing are out of order, so it jumps from 3.4. -- 4.3.4.9  
20 to 4.3.1. And 4.3.4.2 out of place. And 4.36, those are  
21 out of place.

22                   MS. ZYGMUNT: We'll double-check the order.

23                   ACTING CHAIR CAHN: Then, yeah, 4.4.3 is  
24 out of place. (A), (b) and (d) are out of place.

25                   MS. THOMPSON: We can go through and make

1 sure that is in the correct order.

2 ACTING CHAIR CAHN: Then when you list 4.6  
3 on line 1302, when you list 4.6 through 4.6.14, that is all  
4 of 4.6. So I think you should just state 4.6.

5 Then on line 1300, it says 4.4.5 --

6 THE REPORTER: Can you repeat those? I'm  
7 sorry.

8 ACTING CHAIR CAHN: Sorry.

9 THE REPORTER: They just run together.

10 ACTING CHAIR CAHN: Okay. Line 1300, it  
11 says 4.4.5 through 4.4.5, so it's the same thing.

12 MS. THOMPSON: So that's going to appear  
13 several times in the remainder of that paragraph. So we  
14 can go through and make those shorter as appropriate, if  
15 there's -- if it's not including the whole section, we  
16 would leave it in, but if it is including that whole  
17 section, we'll take out that "through" for consistency with  
18 how we're citing it in the rest of the chapter.

19 ACTING CHAIR CAHN: And then I note that  
20 when it's 4. -- no, you fixed that. Okay.

21 And then same thing with 9.3. It implies all of  
22 it. So it should probably say through whatever. Okay.  
23 I'll let you guys. I'll move on.

24 MS. ZYGMUNT: We'll do a thorough review of  
25 all the TSS citations and make sure they're clear, so I



1 don't think we need to spend our time going through each of  
2 those, recognizing that those are really good catches. We  
3 will ensure we do a thorough review of those.

4 ACTING CHAIR CAHN: Okay. On line -- let's  
5 see. Page 12-36, I have a note -- oh, it just says -- I  
6 think it could be changed to the maximum feed point  
7 backpressure shall not exceed 110 psi unless a chlorine  
8 solution pump is used, because then you go on "Where the  
9 backpressure exceeds 110 psi, a chlorine solution pump  
10 shall be used." I think that can just be shortened. Would  
11 mean the same thing.

12 MS. ZYGMUNT: To the back -- I'm sorry.  
13 Could you read --

14 ACTING CHAIR CAHN: Okay. So after not --  
15 line 1581, after 110 psi, it would just state "unless a  
16 chlorine feed solution pump gets used," and then get rid of  
17 the next sentence.

18 MS. ZYGMUNT: Yep. Thank you. Understood.

19 ACTING CHAIR CAHN: I can go over this  
20 other stuff with Gina. Go over this with Gina. Okay.  
21 That's another one for Gina.

22 Okay. Line -- page 12-39, line 1748. This -- I  
23 found reading this thing about -- about pipe diameters  
24 really confusing to read, and so is it additional pipe  
25 length above the minimum may be required in accordance with

1 the manufacturer's guidelines rather than additional pipe  
2 diameters above the minimum? So -- the whole thing of  
3 consisting of a minimum of 10 pipe diameters use straight  
4 pipe upstream, are we talking about --

5 BOARD MEMBER DEURLOO: Taking a 10-inch --  
6 you have a 10-inch pipe, turn it on the side, it's going to  
7 be 10-inch -- how many?

8 BOARD MEMBER COCHRAN: Needs to be a  
9 hundred inches above.

10 BOARD MEMBER DEURLOO: Needs to be hundred  
11 inches above.

12 ACTING CHAIR CAHN: So could we say the  
13 piping configuration shall consist of a minimum length  
14 equivalent to 10 pipe diameters?

15 MS. THOMPSON: I believe that language is  
16 consistent with the EPA guidance manual. I believe that  
17 they use the -- that's how they are gauging it --

18 ACTING CHAIR CAHN: Okay. All right.

19 MS. THOMPSON: -- is in pipe diameters.

20 BOARD MEMBER DEURLOO: Pretty typical  
21 engineering speak.

22 ACTING CHAIR CAHN: Okay. Good.

23 All right. Page 12-41, line 1823. I don't think  
24 there is hydrofluosilic acid. I think it's  
25 hydrofluorosilicic acid. So I would spell it

1 h-y-d-r-o-f-l-u-o-r-o-s-i-l-i-c-i-c. And same on line  
2 1831. I Googled that and couldn't find it.

3 BOARD MEMBER DEURLOO: You're amazing.

4 ACTING CHAIR CAHN: I'm a nerd.

5 BOARD MEMBER DEURLOO: Yeah.

6 ACTING CHAIR CAHN: I'm a grammar nerd.

7 I'm the person who corrects books that I buy. It's a  
8 curse, believe me.

9 Okay. I can go over these ones with Gina.

10 On line -- on page 12-43, line 1894, the word --  
11 and the next line, the word "absorption" with a B, and  
12 adsorb is used. But granulated activating carbon adsorbs,  
13 not absorbs. So those should be adsorption and adsorb.

14 On page 12-44, line 1950, where you mention the  
15 membrane filtration guidance manual, which I know is in the  
16 back, but in order to find it in the back, could we add  
17 that it's U.S. EPA Membrane Filtration Guides so that  
18 somebody could go to the back under U. S. EPA?

19 MS. ZYGMUNT: We can do that.

20 MR. HENDON: Yeah.

21 ACTING CHAIR CAHN: Okay. All right. Then  
22 on line 1964, we talk about "Bag and cartridge filters  
23 shall comply with following requirements:" and then we say  
24 "Facilities that proposed bag or cartridge filters shall  
25 comply with the procedures..." So it seems like there's

1 some redundancy there. So maybe Gina and I can work on how  
2 to shorten that up. Maybe bag and cartridge filters shall  
3 comply with the following requirements, and then (i) would  
4 be "...procedures identified in Section 6 of this Chapter."

5 MS. ZYGMUNT: Uh-huh.

6 ACTING CHAIR CAHN: So I thank you for  
7 fixing the -- the reference was for membrane filters,  
8 should have been for bag and cartridges,, so good catch  
9 there.

10 On line 2006 on the next page, you were going to  
11 add "or shall demonstrate that combined filtration and  
12 disinfection shall provide 3-log removal" and that didn't  
13 get added on my copy.

14 MS. ZYGMUNT: Uh-huh.

15 ACTING CHAIR CAHN: Okay. The next  
16 question I have is on page 12-46, line 2030. And we talk  
17 about simple well systems. And so it says "The sanitary  
18 and laboratory waste from water treatment plants, pumping  
19 stations or simple well systems shall not be recycled to  
20 any part of the water plant." So my question is what's a  
21 well system -- simple well system and where's it defined,  
22 and what have you done differently for a not simple system?  
23 So is there -- is there -- if it's not simple, what is it?

24 MR. HENDON: We'll look into that and get  
25 back to you.

1                   ACTING CHAIR CAHN: Okay. All right.

2 Chapter 13. Section -- Chapter -- ah, Section 13.

3                   BOARD MEMBER DEURLOO: I have just a couple  
4 on 12.

5                   ACTING CHAIR CAHN: Okay.

6                   BOARD MEMBER DEURLOO: Minor. Madam Chair.

7                   So on page 12-33, line 1465, it states that  
8 "...two identical pumps shall be provided." I might  
9 recommend that say "...two pumps with similar  
10 specifications," rather than being identical. Sometimes  
11 they go out of stock, you know.

12                  MR. HENDON: You can only get what they  
13 got.

14                  BOARD MEMBER DEURLOO: Yeah. Then just  
15 kind of a note for punctuation on 12-37 -- on page 12-37, I  
16 recommend consistency. I see you have (ii), and then you  
17 go down (a) ends with semicolon, (b) ends in semicolon, and  
18 the (d) you stop with the semicolons. It should be  
19 semicolon, semicolon all the way down, and then the period  
20 isn't until the very end of the listing.

21                  MS. THOMPSON: We'll check that to make  
22 sure that there aren't any weird sentences in there, and  
23 we'll correct the construction of the grammar at the end as  
24 well.

25                  BOARD MEMBER DEURLOO: It's all over the

1 place, I've noticed it. I'm only pointing it out on this  
2 page, but there's missing semicolons and colons.

3 MS. ZYGMUNT: Mr. Deurloo, what page is  
4 that?

5 BOARD MEMBER DEURLOO: This one's 12-37.

6 MS. ZYGMUNT: Thank you.

7 BOARD MEMBER DEURLOO: If I can just set  
8 somebody down for an hour and I go through every one of  
9 them.

10 MR. HENDON: Yeah. Thanks.

11 BOARD MEMBER DEURLOO: I had something  
12 else, but it was minor. No big deal.

13 ACTING CHAIR CAHN: Go ahead.

14 BOARD MEMBER DEURLOO: I don't remember  
15 where it was.

16 ACTING CHAIR CAHN: Well, interrupt us if  
17 you think of it.

18 Any other Board comments on Section 12?

19 BOARD MEMBER DEURLOO: No, ma'am.

20 ACTING CHAIR CAHN: Okay. Hearing none,  
21 Section 13, so...

22 BOARD MEMBER DEURLOO: 14 -- oh, 13.

23 ACTING CHAIR CAHN: 13. In line 2094,  
24 5.1.11, it says "...herein incorporated by reference for  
25 day tanks," but 5.1.11 is day tanks. So I think we can

1 delete "...is herein incorporated."

2 MS. THOMPSON: I see that happening in that  
3 section. We will take that out.

4 ACTING CHAIR CAHN: Okay. I'm on Section  
5 14. We might actually get through Section 16 today. Okay.  
6 Pumping Facilities. So line 12 -- on page 12-49, the very  
7 top of the page, line 2165 through 2167, (iv). And we're  
8 talking here about "Pump design shall comply with the  
9 following requirements:" It seems like to me -- and I'm  
10 not an engineer, but "The calculated total dynamic head for  
11 pumping units shall be based on pipe friction, pressure  
12 losses from pipe entrances, exits, appurtenances such as  
13 valves and bends, static head of the design flow." To me  
14 that seems like really unnecessarily prescriptive. That an  
15 engineer doing the design is going to know that. It's kind  
16 of like -- I don't know.

17 BOARD MEMBER DEURLOO: If you're building a  
18 house, make sure you have a roof and walls and floor?

19 ACTING CHAIR CAHN: Yeah. Yeah. Exactly.  
20 That's a good analogy.

21 MR. HENDON: It kind of goes along those  
22 lines of what Board Member Deurloo had to say.

23 ACTING CHAIR CAHN: I would think if  
24 they're designing it, if they have to take that into  
25 account, just didn't seem like we need to mention it.

1 So...

2 Okay. My last comment on Section -- oh, I have  
3 editorials, so...

4 I don't understand what 2209 through 2211 means.  
5 Each pump shall either have an individual suction line or  
6 the lines shall have multiple suction lines that  
7 demonstrates similar hydraulic and operating conditions.  
8 Oh, it's an "or."

9 MS. THOMPSON: So this was -- this was an  
10 edit that we did to address a comment on the term  
11 manifolded. So the line previously read that each pump  
12 shall either -- each pump shall have an individual suction  
13 line or the line shall be manifolded such that they will  
14 ensure similar hydraulic and operating conditions. And I  
15 believe the manifolded was being used in an unusual and  
16 unclear way. So the -- in order to keep the intent of the  
17 passage, we reworked it so that each pump shall either have  
18 an individual suction line or shall have multiple suction  
19 lines that demonstrate similar hydraulic and operating  
20 conditions.

21 ACTING CHAIR CAHN: I don't understand that  
22 they demonstrate similar hydraulic and operating  
23 conditions. So similar between --

24 BOARD MEMBER COCHRAN: Each other.

25 ACTING CHAIR CAHN: -- each of the multiple



1 lines?

2 MS. THOMPSON: Yes.

3 ACTING CHAIR CAHN: And what about the  
4 individual --

5 BOARD MEMBER DEURLOO: Basically what it's  
6 saying is you can have a pump with, say, one 4-inch inlet  
7 or three 2-inch inlets coming into it, and it would have  
8 similar flow characteristics on the inflow of the pump.

9 ACTING CHAIR CAHN: So the demonstrating  
10 similar hydraulic operating conditions is not between the  
11 multiple suction lines, it's between each of the multiple  
12 suction lines. It's between --

13 BOARD MEMBER COCHRAN: It's the pumps.

14 BOARD MEMBER DEURLOO: It's the pumps.

15 BOARD MEMBER COCHRAN: So you want your  
16 pumps to have the same pressure and flow so they're pulling  
17 the same amount from the suction lines. If not, one's  
18 pulling more than the other.

19 ACTING CHAIR CAHN: Okay. So they'll have  
20 multiple suction lines that demonstrate similar hydraulic  
21 and operating conditions to the individual suction line.

22 BOARD MEMBER COCHRAN: Individual pumps.

23 ACTING CHAIR CAHN: Can you maybe reword it  
24 so somebody like me understands it? Maybe I'm the only one  
25 that doesn't understand it.

1                   MR. HENDON: Perhaps we can break up that  
2 sentence so that it's clear it's just for hydraulic  
3 operating conditions for one pump, period. Multiple pumps  
4 need to operate under similar hydraulic conditions. So we  
5 can address that.

6                   BOARD MEMBER DEURLOO: No, it doesn't tell  
7 you about one pump.

8                   ACTING CHAIR CAHN: It's one pump. It's  
9 still one pump. That's why it's confusing.

10                  THE REPORTER: One at a time.

11                  MR. HENDON: Got ya. Yes. I'm with you.  
12 We'll address it so we address the suction lines versus  
13 singular or multiple.

14                  ACTING CHAIR CAHN: Okay.

15                  BOARD MEMBER DEURLOO: Sorry. I'm good.

16                  ACTING CHAIR CAHN: Anybody on the Board  
17 have anything on Section 14 or Section 15?

18                  BOARD MEMBER DEURLOO: I don't.

19                  BOARD MEMBER COCHRAN: I don't have any  
20 comments.

21                  ACTING CHAIR CAHN: No?

22                  BOARD MEMBER COCHRAN: I'm good.

23                  ACTING CHAIR CAHN: Section 15. I think  
24 it's in response to comments here where BDOR said their  
25 existing tanks don't meet this 7.0.2 finished water storage

1 structures, and that is an example where the response to  
2 the comments is.

3 MR. HENDON: Yeah. And that's Board of  
4 Public Utilities. They had several existing tanks that I  
5 believe do not meet the partially buried or buried tank  
6 requirements. But, again, their tanks would still comply  
7 with the operating as a storage tank under their original  
8 permit.

9 ACTING CHAIR CAHN: So this is where you  
10 mentioned the requirements for modifications that I talked  
11 about in kind of a general comment in the response. So  
12 you're going to issue a permit to modify the facility and  
13 it's not really answering the question. I think their  
14 question is what are we going to do because our existing  
15 tanks don't meet this design criteria. And I think the  
16 answer is going to be as long as you don't modify them  
17 you're okay. So...

18 MR. HENDON: Excuse me. We did sit down  
19 with the Board of Public Utilities. We met with Bryce  
20 Dorr, Frank Strong, and we walked them through our comments  
21 and our response to comments. And we listened to their  
22 concerns and they understood that their tank would remain  
23 in compliance. When they came back to us and they needed  
24 to do a vent or should they need to address some other  
25 issue, we would definitely work with them on their tank and

1 their existing tank that was originally permitted.

2 ACTING CHAIR CAHN: Okay. And again, I  
3 always come up with the same thought in my head when we  
4 hear that existing things that are working and operating  
5 fine, are we imposing some kind of overkill for it --

6 MR. HENDON: Yeah. And --

7 ACTING CHAIR CAHN: -- or do we have to.

8 MR. HENDON: And again, we're more than  
9 happy to work with systems and entities should there be a  
10 concern from EPA on having to address the significant  
11 deficiency that was extremely burdensome or unrealistic for  
12 their facility. We're happy to further that discussion and  
13 work with those communities.

14 BOARD MEMBER DEURLOO: Madam Chair, I do  
15 have one question. I've got one. Page 12-51, line 2290.  
16 It says installation of a number 4 mesh noncorrodible  
17 screen. Is that supposed to be number 4 or is it supposed  
18 to be number 24?

19 MR. HENDON: That is number 4.

20 BOARD MEMBER DEURLOO: Number 4. Okay.  
21 Just making sure.

22 MR. HENDON: On that one they do get the  
23 number 4 option so long as they have a mechanical device.

24 BOARD MEMBER DEURLOO: Got it. Okay.

25 ACTING CHAIR CAHN: That's all I have on

1 15.

2 I haven't gone through my responses to comments  
3 as I'm going through. So I might have to cross-reference  
4 if we have time, come back to that.

5 Section 16, anybody on the Board have comments?

6 BOARD MEMBER DEURLOO: Not at this time.

7 BOARD MEMBER COCHRAN: I'm good.

8 ACTING CHAIR CAHN: You're good? Okay.

9 I've got questions on page 12-54 on line 2408  
10 about manholes. And this was a comment that I believe --  
11 page -- page 46 of comments. So this was brought up by  
12 actually several people. This is 16(g), so Dayton Alsaker,  
13 Jeffrey Rosenlund. And so one -- okay. One general  
14 comment in response to comments by saying we considered  
15 this comment, the requirement is an existing one that was  
16 previously located. To me if we're updating the  
17 regulations because they're 40 years old, we should be  
18 looking at existing ones, if we don't need to be doing  
19 them, we should be changing them. I don't think it's just  
20 good enough to say, well, it was already existing, so  
21 therefore we're good. I think we need to look into whether  
22 it makes sense.

23 So the old rules should be updated in another way  
24 besides adding more requirements, maybe removing some if  
25 they're unnecessary. And so I think that having -- you

1 know, manholes are really hard to keep water out of. And  
2 to say -- you just make a manhole that keeps the water out,  
3 I don't think that is really very good. So let's say you  
4 try to coat it. Concrete -- if it's concrete manhole,  
5 they're going to leak, even if you coat the surface. If  
6 you -- you know, if you -- if it's fiberglass, it can  
7 float. If it does flood, which a lot of manholes do flood,  
8 you're going to get a lot of really rusty piping and valves  
9 and stuff down in there, really hard to manipulate when  
10 they're rusty. And also to get down in there is a whole  
11 safety issue. There's a whole entry into confined spaces  
12 issue. So I want -- I think it was Jeffrey Rosenlund said  
13 let's look at valve boxes. Well, to me that's a really  
14 good idea.

15 MR. HENDON: Yeah, and they do have that  
16 under chambers.

17 ACTING CHAIR CAHN: Excuse me?

18 MR. HENDON: The section in question,  
19 manholes or chambers for automatic air relief valves shall  
20 be designed to prevent submerging the valve with  
21 groundwater or with surface water.

22 BOARD MEMBER DEURLOO: So chambers is --

23 MR. HENDON: I think they can --

24 ACTING CHAIR CAHN: Is a valve box.

25 MR. HENDON: I think they can have that

1 option.

2 ACTING CHAIR CAHN: I guess I didn't  
3 understand what chambers was.

4 MR. HENDON: It can also be a concrete box.  
5 It could be --

6 ACTING CHAIR CAHN: Okay.

7 MR. HENDON: But we can go back and we can  
8 provide a better option or clarification on it.

9 ACTING CHAIR CAHN: Okay. And then -- and  
10 then what about having like let's say a valve box or  
11 chamber, which I don't understand that term. But on either  
12 side of the creek, rather than directly under the creek.

13 MR. HENDON: We're not recommending a box  
14 in the creek. We're recommending it on either side of the  
15 creek.

16 ACTING CHAIR CAHN: Okay.

17 MR. HENDON: That's our recommendation.

18 ACTING CHAIR CAHN: Okay.

19 MR. HENDON: And to ensure that it's far  
20 enough away from the creek you're not going to have  
21 groundwater issues. We're not recommending putting in a  
22 manhole, chamber, meter pit, meter box.

23 ACTING CHAIR CAHN: So you have to be above  
24 the flood line?

25 MR. HENDON: It doesn't have to be above

1 the flood line.

2 ACTING CHAIR CAHN: Because you might have  
3 to go very far.

4 MR. HENDON: But you might have to go very  
5 far. But we're recommending it on either side of that  
6 crossing, whatever that crossing might be, and to ensure --  
7 to the best -- again, understanding your site conditions to  
8 the best of their ability to put it in a safer, less moist  
9 environment.

10 ACTING CHAIR CAHN: Okay. So maybe just  
11 look at the wording on chambers, because that was not --

12 MR. HENDON: Sure, we can address that.

13 ACTING CHAIR CAHN: -- obvious to me.

14 Okay. That's all I have on Section 16.

15 Anybody have anything on Section 17 or 18 or 19  
16 from the Board?

17 BOARD MEMBER DEURLOO: I do not. Not at  
18 this time.

19 ACTING CHAIR CAHN: I have nothing on 17.  
20 Nothing on 18. And I just had a question, when we were  
21 talking about you added in NSF61. Can you tell me -- show  
22 me where that is on here? I didn't see it added in.

23 MS. THOMPSON: It's Section 19(a)(iii),  
24 line 2791. It's American National Standards Institute.

25 ACTING CHAIR CAHN: Okay. Okay. So I



1 guess I was looking for green, because it -- I think the  
2 comments said you added that in. So thank you. That  
3 answers that.

4 Okay. That does my comments on -- it's 3:15. Do  
5 you need to leave at 3:30, you don't.

6 BOARD MEMBER DEURLOO: I need by 3:45.

7 MS. ZYGMUNT: Madam Chairwoman, if I can  
8 back up to a previous comment you asked for response on, on  
9 page 1222.

10 ACTING CHAIR CAHN: I'm sorry, Jennifer.  
11 Can you repeat that.

12 MS. ZYGMUNT: Yeah. Page 1222.

13 ACTING CHAIR CAHN: 1222.

14 MS. ZYGMUNT: And recognizing we will check  
15 the distances, Table 1, Table 2, there was a comment  
16 regarding (c) on that page, starting on line 957. Gina did  
17 find summary of our Attorney General's --

18 ACTING CHAIR CAHN: Oh, great.

19 MS. ZYGMUNT: -- analysis of that. And her  
20 interpretation is that is referring to specifically  
21 Section -- or, I'm sorry, Chapter 3, Section 17(b). It  
22 does not apply to all of Section 17 in the rule, which you  
23 are correct is not applied public water systems. But this  
24 cross-reference does make that 17(b) subsection applicable  
25 in this scenario. It just means that the whole Section 17

1 does not apply to public water systems.

2 ACTING CHAIR CAHN: Okay.

3 MS. ZYGMUNT: So we would propose leaving  
4 that language as is based on her --

5 ACTING CHAIR CAHN: Okay. Thank you.  
6 Because I missed that, so...

7 MS. ZYGMUNT: Yeah. It's a good question.  
8 Thank you.

9 ACTING CHAIR CAHN: All right. I'll try to  
10 hold it to break.

11 BOARD MEMBER DEURLOO: Keep going, man.

12 MS. ZYGMUNT: You're doing great.

13 BOARD MEMBER DEURLOO: Keep going.

14 ACTING CHAIR CAHN: So Section 3, somebody  
15 had a question -- it's titled Timing of Compliance with  
16 These Regulations, and I think somebody said there isn't  
17 any timing. Well, can we just rename it like Applicability  
18 of These Regulations or something that would --

19 MR. HENDON: Coverage of these regulations?

20 ACTING CHAIR CAHN: Yeah. Yeah.

21 MS. THOMPSON: Similarly worded -- titled  
22 to other --

23 ACTING CHAIR CAHN: Okay.

24 MS. THOMPSON: -- things in other chapters,  
25 which is why we thought to put it in here, it seemed

1 appropriate. And while it doesn't use the word "timing"  
2 conceptually --

3 ACTING CHAIR CAHN: Right.

4 MS. THOMPSON: -- it refers to --

5 ACTING CHAIR CAHN: It does refer to time.

6 MS. THOMPSON: Yeah.

7 MS. ZYGMUNT: But we will consider that as  
8 a broader global change. We'll talk about that with our  
9 attorney.

10 ACTING CHAIR CAHN: So, let's see, the  
11 mineralized water on page 12-4, you were going to talk  
12 about. So here it is more than continual 500, so we'll  
13 leave that.

14 Okay. Section 6 -- and you guys on the Board,  
15 please interrupt me if you have something.

16 BOARD MEMBER DEURLOO: We will.

17 ACTING CHAIR CAHN: Okay. Section 6.

18 Okay. I'm conceptually really confused with the title of  
19 the section and -- and (a) of that section. So it's  
20 Facilities and Systems Not Specifically Covered by these  
21 Standards is the title of Section 6. But then it goes on  
22 "Each application for a permit to construct a facility  
23 under this section shall be evaluated on a case-by-case  
24 basis..." So I just get -- do you see where I'm confused?  
25 Facilities are not covered, but then everything covered is

1 evaluated on case-by-case, so...

2 MS. ZYGMUNT: So Madam Chairwoman, this  
3 section gives the administrator some discretion to look at  
4 systems that may not have been envisioned at the time you  
5 wrote these rules, or new innovative technologies that  
6 still meet the intent of this rule, and gives me the  
7 authority to work with my staff on a case-by-case basis to  
8 permit that accordingly, if it does not specifically fall  
9 within, you know, the specifications that we've outlined.  
10 We would look at those kind of pilot projects very closely,  
11 but that is the intent of this section, if that helps  
12 answer your question.

13 ACTING CHAIR CAHN: All right. On line  
14 2 -- that's editorial. I'll go over that with Gina.

15 All right. So page 12-6, line 264, when we're  
16 talking about these two individual permits, and we  
17 originally had initially issued permits, so it seems to me  
18 there's two permits in order. There's a first one and then  
19 there's the next one. So by taking out the word  
20 "initially" on line 266, I'm wondering if we're still  
21 confusing things because it still says the issue permit and  
22 there's two of them. So can we say something like the  
23 first issued permit?

24 MR. HENDON: So Gina and I had discussions  
25 on this one as well, with regards to when a permit is

1 issued there's only one permit number issued for that  
2 facility. And so the language that we came up with was to  
3 follow that one permit number issuance. Perhaps there's  
4 still a better way to revise this.

5 ACTING CHAIR CAHN: So there aren't two  
6 individual permits. There's only one. So on line 264, am  
7 I understanding you to say there's only one permit?

8 MS. THOMPSON: There's one permit number.  
9 There are two authorizations.

10 ACTING CHAIR CAHN: Okay.

11 MS. THOMPSON: Which is bureaucratic,  
12 right?

13 ACTING CHAIR CAHN: Okay.

14 MS. THOMPSON: But it's potato, potato.  
15 But essentially they apply, we give them one number. And  
16 then when they follow those additional steps in that  
17 section, they submit additional information and we give  
18 them an additional written authorization.

19 ACTING CHAIR CAHN: Okay.

20 MS. THOMPSON: So it's --

21 BOARD MEMBER DEURLOO: Who are you  
22 authorizing? Are you authorizing the applicant or are you  
23 authorizing the well?

24 MR. THOMPSON: I believe that we're  
25 authorizing the applicant to construct the well, and then

1 we are authorizing connection of the well to their  
2 distribution system.

3 BOARD MEMBER DEURLOO: Okay. Madam Chair,  
4 I might recommend that we restate that sentence. Say of  
5 the administrative -- administrator, whoever it is, will  
6 authorize the applicant to construct, develop, and test the  
7 well for the applicable issued permit.

8 ACTING CHAIR CAHN: How about the first  
9 line, 264, we say for applications that include wells, the  
10 individual permit will be issued in two phases. Or there  
11 are two phases, something like that. That -- in two -- in  
12 two steps. So there's really not -- now you're telling me  
13 there's not two individual permits, there's really only  
14 one.

15 MS. THOMPSON: They get an initial  
16 authorization, and they get a second authorization to  
17 connect.

18 ACTING CHAIR CAHN: Okay. For applications  
19 that include wells, the individual permits will be issued  
20 as follows:

21 MS. THOMPSON: I think potentially --

22 ACTING CHAIR CAHN: Initially -- the  
23 applicant will be authorized to --

24 MR. HENDON: It's two authorizations.

25 ACTING CHAIR CAHN: -- contest the well,

1 and, second, the applicant will be required to submit --

2 MR. HENDON: Right. So I think we can  
3 re-word it for authorizations and for their permit, step  
4 one --

5 ACTING CHAIR CAHN: Yeah.

6 MR. HENDON: -- step two.

7 ACTING CHAIR CAHN: Yeah.

8 BOARD MEMBER DEURLOO: And you're not --  
9 you're authorizing the applicant to construct the well,  
10 then you're authorizing the applicant to develop and test  
11 the well, right? Was that your phases?

12 MR. HENDON: All of that would be one  
13 phase. Connecting it --

14 BOARD MEMBER DEURLOO: Got it.

15 MR. HENDON: -- would be the second phase.

16 ACTING CHAIR CAHN: Okay. On line -- oh,  
17 that's editorial. Okay.

18 Then on the next page, (iii), there's the word  
19 "initial appearance" on line 280, and then it's been struck  
20 from 283. So just continue with whatever you come up with  
21 for that.

22 I'm on to Section 8. We might even finish.

23 BOARD MEMBER DEURLOO: Heck yeah.

24 ACTING CHAIR CAHN: Heck yeah.

25 MR. HENDON: Heck yeah.

1 BOARD MEMBER DEURLOO: Did you get that,  
2 Kathy?

3 ACTING CHAIR CAHN: Okay. I have a note  
4 that line 302 -- I'm not sure I understand my note right  
5 now. Parts -- so TSS parts 1.2 through 1.6, my note says  
6 has better info than Section 8(e), so maybe I'm thinking  
7 it's good to follow that and maybe delete some of 8(e) if  
8 it's already in 1.3 through 1.6, but I don't have the  
9 specifics right now.

10 MS. ZYGMUNT: So my understanding, just to  
11 make sure, that the TSS references aren't duplicative with  
12 what we have in --

13 ACTING CHAIR CAHN: Yeah, if it's  
14 duplicative, take it out.

15 MS. ZYGMUNT: Okay.

16 ACTING CHAIR CAHN: On line 338, the old  
17 wording was "or" before. So the bottom line is within 10  
18 feet of streams and lakes or the waterline across streams  
19 or lakes. So I'm questioning whether "and" or "or" is  
20 correct there on line 338. So just to --

21 MS. ZYGMUNT: We'll check that.

22 ACTING CHAIR CAHN: Yeah. Okay.

23 The next -- the next comment I have -- actually  
24 this one came from Ben Jordan. On page 12-9, on his -- his  
25 response for (e), all of (e), was that basically including



1 this here -- he used the word "bizarre," that this was  
2 bizarre. And I would agree, because we're talking about  
3 plans, and -- okay, well, first of all, TSS 1.1.2(f) has  
4 (i) and (ii). But to go over the assembled order, size,  
5 and length of casing and liners, casing wall thickness,  
6 grouting depths -- grouting depths was in the TSS.

7 MR. HENDON: Madam Chair.

8 ACTING CHAIR CAHN: Yeah.

9 MR. HENDON: So in talking with Ben about  
10 this comment, his "bizarre" reference was to require all of  
11 this information on a plan and profile drawing.

12 ACTING CHAIR CAHN: In the plan as well as  
13 in the profile drawing.

14 MS. THOMPSON: No, it was on the drawing.

15 MR. HENDON: So his comment was requiring  
16 this on a profile drawing does not make sense for well  
17 construction.

18 ACTING CHAIR CAHN: Okay.

19 MR. HENDON: I would agree. So we changed  
20 the verbiage so that plans for well construction shall  
21 include. The very first statement here at 380, originally  
22 it said "plans and profile drawings for well construction  
23 shall include," to which Ben said, This is bizarre. Why  
24 would I include this on a profile? Because a profile  
25 doesn't provide --

1                   ACTING CHAIR CAHN: Okay.

2                   MR. HENDON: -- the information.

3                   ACTING CHAIR CAHN: Okay.

4                   MR. HENDON: It's just going to provide you  
5 a point on the map where that well is going to be located.  
6 Your plans and drawings are going to have the rest of this  
7 information requested below item (e) here.

8                   ACTING CHAIR CAHN: Okay. But as we move  
9 along, further down, we start to get into (xii), well test  
10 data including, and then all these things, static water  
11 level, depth of test pumping -- pump setting, time of  
12 starting and ending each test cycle, drawdown, you're not  
13 going to know that when you've got plans. That's all  
14 later. So I look at everything -- well, test data is stuff  
15 that, you know, you're not going to be able to get. So at  
16 this point, you need that information after they've  
17 developed the well and tested it, and so --

18                   MR. HENDON: And perhaps we could right  
19 there at (xii), well test data concluding, if available. I  
20 know a number of times Water Development Commission will  
21 pay for a well to be built, constructed, things of that  
22 nature, prior to coming in to getting permitted --

23                   ACTING CHAIR CAHN: Okay. Great.

24                   MR. HENDON: -- for a public water system.

25                   ACTING CHAIR CAHN: If available.

1 MR. HENDON: And so that information may  
2 already be readily available.

3 ACTING CHAIR CAHN: Good.

4 MR. HENDON: Based on those activities by  
5 water development.

6 ACTING CHAIR CAHN: Okay. And that's the  
7 same for location of any blast charges.

8 MR. HENDON: Correct.

9 ACTING CHAIR CAHN: That's also -- yeah.  
10 So just look through that list, and -- so -- and then on  
11 line -- go back up to 406, the page before. From the  
12 ground surface to the total depth of the drill, something's  
13 missing there. I don't know what's supposed to --

14 BOARD MEMBER DEURLOO: Drilled well?

15 ACTING CHAIR CAHN: Yeah. Drilled wells?  
16 well? I don't know.

17 MR. HENDON: Which one?

18 ACTING CHAIR CAHN: But then --

19 BOARD MEMBER DEURLOO: Line 406.

20 ACTING CHAIR CAHN: Yeah. And then --

21 MS. ZYGMUNT: We'll make that correction.

22 ACTING CHAIR CAHN: And then the other  
23 details to describe the proposed well completely. That's  
24 in the TSS. Water levels in the TSS. And, again,  
25 formations penetrated, you might not know that on an

1 exploration well, but you're not -- so, again, that's the  
2 if available category. So --

3 And then Section 9, and then we're done. So I'll  
4 try to get this done in 15 minutes.

5 On line 572, on page 12-13, one of the commenters  
6 was looking for a definition of aquifer. Is it okay to say  
7 "as defined in Wyoming Statute 41-3-901"? Are we allowed  
8 to do that just to help them? Instead of in response to  
9 comments, that's where you put it, so just --

10 MS. THOMPSON: Not unless we're tying it to  
11 an action.

12 ACTING CHAIR CAHN: Okay.

13 MS. THOMPSON: So if we wanted them to  
14 demonstrate something based on that statutory citation,  
15 then it's appropriate to include it. But if we're -- if  
16 we're just saying like as a redirect, we're being advised  
17 against doing that, because it's not -- it's not an  
18 enforceable line. So we have to -- we have to structure  
19 it --

20 ACTING CHAIR CAHN: So even though they  
21 have to provide the description of the geology of the  
22 aquifer, you can't refer to --

23 MS. THOMPSON: No. I'm saying that if  
24 you want -- if you tie it to a statute, it has to be very  
25 clear what you're bringing in from the statute. So, for

1 instance -- and I'm not committing to doing this, I'm just  
2 kind of giving an illustration -- we would say something to  
3 the effect of a description of the geology of the aquifer  
4 that demonstrates compliance with statute whatever, or a  
5 description of the geology, you know, and overlying strata  
6 that meets, you know, the description of -- you have to --  
7 in order to bring in cross-references, whether it be to  
8 other rules or statute, it has to have an action or a  
9 timing.

10               So like let's say we had something in the statute  
11 that says when you, you know, apply for a well under this  
12 aquifer category, you know, thou shalt do this in addition  
13 to the items at statute whatever. So we have to tie it to  
14 an action --

15               ACTING CHAIR CAHN: Okay.

16               MS. THOMPSON: -- or a timing.

17               BOARD MEMBER DEURLOO: Madam Chair, can we  
18 put the definition of aquifer at the front in definitions?  
19 Would that help?

20               MS. ZYGMUNT: I believe we discussed a  
21 definition of aquifer, and if I recall correctly, the -- or  
22 the input from our Attorney General is that that's a broad  
23 enough term it does not require a definition in this rule.

24               BOARD MEMBER DEURLOO: Okay.

25               ACTING CHAIR CAHN: That's interesting,

1 because --

2 MS. THOMPSON: We're working with the SEO's  
3 definition as well. And we have definitions of aquifer,  
4 which may not be identical. But we're not governing the  
5 aquifer here. The SEO is. So we were running into some  
6 trickiness because we have overlapped with a sister agency  
7 who has authority over that well construction. And we're  
8 not determining the aquifer. We just want some  
9 construction to happen, right?

10 MS. ZYGMUNT: I will revisit that question  
11 with Nicole, our Attorney General, to see -- get her  
12 thoughts on adding the definition. At this time I'm not  
13 really inclined to. I think it's, for the purposes of this  
14 rule --

15 ACTING CHAIR CAHN: Yeah, because it's  
16 defined differently in different places.

17 MS. ZYGMUNT: It is.

18 ACTING CHAIR CAHN: It's sticky, but that's  
19 kind of why it's important maybe to provide a definition.  
20 I don't know. Maybe it's okay not to do it, and then we  
21 have some wiggle room, I mean is it perched water? You  
22 know, it gets complicated.

23 MS. ZYGMUNT: We'll look into that. We'll  
24 provide a response either way. Again, we'll look at it in  
25 the perspective of the context of this rule, though.

1                   ACTING CHAIR CAHN: Okay. 12-13, line 579,  
2 that (i) paragraph. Talking about some likely drilling and  
3 completion challenges, and I feel like that will be faced,  
4 including a description of drilling and completion  
5 practice, blah, blah. It seems premature. This won't be  
6 known beforehand. So, again, it would be back on to if  
7 known from exploration wells or --

8                   MR. HENDON: And I think within that  
9 engineering design report provided to our district  
10 engineers, we're looking to see if they're aware of any  
11 difficult drilling areas, providing difficult information  
12 or concerns that they may have to overcome --

13                   ACTING CHAIR CAHN: Yes.

14                   MR. HENDON: -- in regards to the  
15 implementation of the project.

16                   ACTING CHAIR CAHN: If known.

17                   MR. HENDON: Basically if known.

18                   ACTING CHAIR CAHN: The fact.

19                   MR. HENDON: Back to the if available,  
20 perhaps.

21                   ACTING CHAIR CAHN: Yeah, is it important,  
22 if known.

23                   BOARD MEMBER DEURLOO: Madam Chair, so I  
24 just noticed this. On that same line, line 579, we have a  
25 repeat of (ii).

1 MS. THOMPSON: Yes, we do.

2 MS. ZYGMUNT: Okay.

3 ACTING CHAIR CAHN: Good catch.

4 And then line 596, the information required in  
5 (e) of this section, I think it should be (f).

6 BOARD MEMBER DEURLOO: Where?

7 ACTING CHAIR CAHN: On the next page, line  
8 596.

9 MS. THOMPSON: Okay.

10 ACTING CHAIR CAHN: And then on 605 through  
11 line 611, again, well bond logging in statement of  
12 completion and description of well from the SEO. Again,  
13 that's not necessarily known ahead of time, so --

14 MS. THOMPSON: That is actually under the  
15 conversion of an existing well into a public water supply  
16 well.

17 MR. HENDON: Yeah.

18 ACTING CHAIR CAHN: Oh, okay. It's from --

19 MR. HENDON: So under item (g), engineering  
20 design reports for conversion of existing well --

21 ACTING CHAIR CAHN: Oh, okay. Thank you.

22 MR. HENDON: -- into a public water supply  
23 shall include -- and hopefully they do have that  
24 information as it helps that process.

25 ACTING CHAIR CAHN: Okay. Great. On page



1 12-15 -- hey, we're almost done with Section 9. One page  
2 to go.

3 This is under the hydraulic analysis that I --  
4 demonstrates how a peak hour, average day, maximum day, and  
5 maximum day plus fire flows..." I was going to say do we  
6 need -- do we say if required or provided, will be improved  
7 by upsizing, if appropriate, or something. It seemed a  
8 little -- maybe this was inconsistent of Ben Jordan's. I'm  
9 not sure.

10 MR. HENDON: Ben's was a little bit --

11 ACTING CHAIR CAHN: Different.

12 MR. HENDON: Was a little bit different.

13 His comment was with regard to item I think (lii), "The  
14 hydraulic model shall:" --

15 ACTING CHAIR CAHN: Okay.

16 MR. HENDON: -- be calibrated based on  
17 existing fire hydrant test flow data when available --

18 ACTING CHAIR CAHN: Okay.

19 MR. HENDON: -- or based on modeling.

20 ACTING CHAIR CAHN: So then my question is,  
21 again, they won't always have fire flow. So if required or  
22 provided or will be improved by upsizing if appropriate.  
23 So just some wiggle room there.

24 MR. HENDON: Yeah. And I think the  
25 question -- are you looking at (li) of the modeling

1 result --

2 ACTING CHAIR CAHN: No. I'm looking above  
3 that at lines -- I'm looking at (j)(A), (B) on the top of  
4 the page, 12-15. Hydraulic analysis that demonstrates how  
5 a peak hour, average day, maximum day --

6 MR. HENDON: Uh-huh.

7 ACTING CHAIR CAHN: -- fire flows will be  
8 improved by upsizing.

9 MR. HENDON: Gotcha, yeah.

10 ACTING CHAIR CAHN: So wiggle room --

11 MR. HENDON: And providing an off-ramp if  
12 required or if they --

13 ACTING CHAIR CAHN: Yeah.

14 MR. HENDON: I see what you're saying.

15 ACTING CHAIR CAHN: Okay. And then -- then  
16 we have -- I think Ben's comments were on line -- on (1),  
17 on 662, for new water mains, how can we have a hydraulic  
18 model -- I think -- did you fix that?

19 MR. HENDON: We did.

20 ACTING CHAIR CAHN: Okay. Great.

21 MR. HENDON: Yeah.

22 ACTING CHAIR CAHN: Okay. Okay. Yep.

23 Okay. That addresses my comments. Not the comment  
24 responses, but my comments on the changes that were made,  
25 things we saw. So I still might have a few comments on

1 comment responses, but we don't have time, so...

2 All right. So I think at this point, Jennifer,  
3 why don't you tell us what you're looking at for us -- from  
4 us.

5 MS. ZYGMUNT: Yes. Thank you, Madam  
6 Chairwoman. So this has been incredibly valuable feedback,  
7 a really good discussion, both at the December meeting and  
8 this meeting. Really appreciate all the things that were  
9 caught and the suggestions to places where we can be clear  
10 and add some more flexibility when appropriate. So very  
11 useful discussion.

12 What I am looking to do at this point is I feel  
13 that we are ready to move forward to the EQC. I think we  
14 have a good product. I think we can address your comments.  
15 And any of your feedback today where we need to provide you  
16 with a response, those would be documented and the feedback  
17 goes to the EQC that summarizes our interactions with the  
18 board and what your advice on this rule was.

19 So at this time I am looking forward to going to  
20 the EQC. I would like to get your advice -- any further  
21 advice on the rule. You are always welcome to not advise  
22 us to move forward. If that is your decision, I would ask  
23 for some very clear feedback as to why, so we can  
24 communicate that -- communicate to the Environmental  
25 Quality Council. Or if your motion is that you advise us

1 to move forward, to document any further feedback in  
2 addition to the revisions that we noted have gone on in the  
3 discussion today.

4 So that's my inclination at this time with this  
5 rule.

6 ACTING CHAIR CAHN: I feel like we're not  
7 quite there yet. I feel like we're much closer than we  
8 were. But I think there was some comments that came in,  
9 public comment today, that we haven't gotten back -- we  
10 need to get back. And I think there's a few areas where we  
11 say we're going to look at that, and I think there's enough  
12 of them. So my personal feeling -- but I'm only one of the  
13 board members. My personal feeling is we're not quite  
14 ready, but we're close.

15 MS. ZYGMUNT: Understood.

16 ACTING CHAIR CAHN: But I'm not comfortable  
17 that we're close enough. Typically when our Board advises  
18 we go to EQC, there's really editorial here, editorial  
19 there. I don't think we're quite there yet.

20 And I also would maybe like to work with Keenan,  
21 if I could, or with you, Jennifer, on the responses that --  
22 you know, if -- I don't know if it's okay for me to work  
23 directly with you guys on my comments on responses to  
24 comments that don't affect making a change in rule, but  
25 just in the -- but just in the responses to comments, maybe

1 we could work on those. I can give you my feedback. And  
2 that wouldn't hold this up, but if that's okay. I don't  
3 know if I have to do that at a board meeting or -- because  
4 that's not saying this is a change I'd like to see in the  
5 rules. This is how you address comments, so...

6 MS. ZYGMUNT: Yes, Madam Chairwoman, thank  
7 you for your input. And with all due respect, I understand  
8 your concerns. I understand that your preference would be  
9 that we bring the rule back, and I'd like to understand  
10 recommendations from the other board members as well, and  
11 for you guys to make a motion that you feel is appropriate.

12 I will repeat, you know, we have had this rule in  
13 two public notices -- or extended public notice for over  
14 100 days. I think we've done our due diligence in getting  
15 comments. I do think we have successfully gotten through  
16 the whole rule between Keenan's presentation and the  
17 discussion today. And, again, I think we have very good  
18 feedback.

19 If you feel there's a better way that we can  
20 document our feedback to the EQC -- document to the  
21 advisory board's feedback to the EQC, I think we would be  
22 happy to entertain a specific memo in this case. If I do  
23 decide to move forward despite the Board's advice, we would  
24 be happy to make sure that is documented thoroughly to make  
25 sure that your feedback is heard by the Environmental

1 Quality Council. But it always is. That's nothing new.

2 We always communicate with boards in packets.

3           So, again, it is my inclination to keep moving  
4 forward with this rule. I don't feel like another advisory  
5 board meeting is necessary. Again, I think this discussion  
6 has been very effective and has given us the advice we need  
7 to do one more review of this rule. It sounds like you  
8 would like to work with Gina on some editorial comments.

9           ACTING CHAIR CAHN: Yeah. I still feel  
10 like the issue of small water systems, it's really a big  
11 deal, and it's really important, especially transients. So  
12 I'm not comfortable with you saying, well, we'll just work  
13 it and we'll go forward to EQC and we'll tell EQC about  
14 your concerns. I want to see how that's worked.

15           MS. ZYGMUNT: Madam Chairwoman, let me make  
16 sure I'm clear. That exercise is a long-term exercise. In  
17 terms of the evaluating these small transient communities  
18 compared to the specifications and specifications we've had  
19 on the books since 1984, 1985, that's going to require some  
20 significant thinking, and, in my opinion, some discussions  
21 with our Attorney General. I feel that is better long-term  
22 project. Again, as we start working with board on  
23 technical assistance to these communities, that is where we  
24 can get some short-term gains.

25           The question about small transient communities is

1 absolutely understood, but that is a longer-term effort  
2 that we would need to dig into, and I would say do further  
3 outreach on, but I don't see we need to hold up what we  
4 have accomplished with Chapter 12 at this time.

5 ACTING CHAIR CAHN: So what you're saying  
6 at this point is that there's going to be no relief for  
7 small transient systems as this goes forward. That there's  
8 no opportunity for that at all in updating the rules?

9 MS. ZYGMUNT: We will continue working with  
10 the small transient systems as we always have. But we do  
11 need to make sure that they are in compliance. And a lot  
12 of these specifications and compliance with this rule also  
13 helps assure that they would be in compliance with EPA's  
14 PWSS system.

15 So, again, we have always worked with them, and  
16 we will continue working with them to make sure they are in  
17 compliance. If there are areas where it is not feasible  
18 for them, they don't feel that it is feasible for them to  
19 come into compliance with the rule, again, we'll work with  
20 them on a case-by-case basis. And I will note, as we've  
21 seen, there is some administrator flexibility to make sure  
22 somebody is obeying the intent of the rule. That is some  
23 broad flexibility, and it comes down to very thorough case  
24 by case analysis. So I can't speak to specifics, but we  
25 would deal with those situations as they arise.

1                   ACTING CHAIR CAHN: Is there any  
2 requirement from the legislature or anything that as new  
3 rules are implemented, that you have to look at the cost to  
4 the state of Wyoming, to the regulated community? Do you  
5 have to look at the increase in cost that the --

6                   MS. THOMPSON: Yes. It's specifically  
7 required in the authorizing statute when we bring rules to  
8 you. It's under the 302 paragraphs. We have several  
9 things that we consider, and economic reasonableness is one  
10 of them.

11                   ACTING CHAIR CAHN: And so that analysis  
12 has been done for this?

13                   MS. ZYGMUNT: It would have been done  
14 during the original rulemaking.

15                   ACTING CHAIR CAHN: But this update. So if  
16 this goes forward to EQC, do you -- have you done that  
17 analysis? I mean, that --

18                   MS. ZYGMUNT: I don't believe we do that  
19 for rules revisions.

20                   ACTING CHAIR CAHN: Only for the first time  
21 the rule is permitted?

22                   MS. THOMPSON: I believe that we -- we  
23 don't do a formal separate document that illustrates a  
24 line-by-line analysis of the economical -- economic  
25 reasonableness of each line. It's the overall rule. And



1 especially new items that we're considering, or removal of  
2 an old item, when we are making those changes, are we being  
3 economically reasonable? And by offering training or  
4 offering assistance from our training partners and offering  
5 funding possibilities for these small systems as well, we  
6 can balance out that economic reasonableness. We're not  
7 demanding that everyone come into compliance, and we're  
8 not -- you know, your funding is on your own.

9           When we look at this in light of the funding  
10 opportunities we have and the training opportunities we  
11 have, and, you know, other partner agencies, these are  
12 economically reasonable.

13           ACTING CHAIR CAHN: So there's not an  
14 analysis of increasing costs that updating these rules  
15 would impose?

16           MS. THOMPSON: No, we do not have a  
17 separate formal document.

18           ACTING CHAIR CAHN: Okay. And -- I lost my  
19 train of thought. I'm sorry.

20           MS. ZYGMUNT: That's all right.

21           BOARD MEMBER DEURLOO: Can I ask a question  
22 while you're trying to grab that train, Madam Chair?

23           So two questions for you. First one is, is there  
24 a timing -- internal timeline that you're trying to meet  
25 with Section 12 that you would push it forward without

1 another review? That's number one.

2 MS. ZYGMUNT: Understood. And if I may,  
3 I'll go ahead and answer that question.

4 BOARD MEMBER DEURLOO: Please do.

5 MS. ZYGMUNT: There's no timeline on this  
6 rule, meaning there's no specific reasons that I need to  
7 get this to the EQC. However, I need to look at my staff's  
8 time efficiently, what resources we have. We have many  
9 other rules we need to be working on this year. For many  
10 different reasons. I feel that the two advisory board  
11 meetings that we have had have accomplished the -- the  
12 mission of the advisory board, as it's outlined in the  
13 Environmental Quality Act.

14 So in the interest of keeping all of our projects  
15 moving along, balancing resources with other projects,  
16 again, it is my determination the most efficient way is to  
17 keep this moving forward to the EQC.

18 BOARD MEMBER DEURLOO: I see. As a  
19 follow-up question. So depending on how many more rules  
20 you want to look at, chapters you want to look at this  
21 year -- maybe you could touch on that quickly -- would it  
22 benefit you that we move our Q2 meeting to April, like  
23 within 30 to 45 days or something like that, so we could  
24 look again at section -- or Chapter 29 and Chapter 12, get  
25 those off the book? Maybe do a quick introduction to the

1 next big chapter you want to look at, that we move our Q2  
2 meeting up.

3 MS. ZYGMUNT: Yeah. Thank you for the  
4 question and the suggestion. Again, at this time it's more  
5 that I don't feel another meeting is necessary, not -- not  
6 the timing of that meeting per se. Preparing for these  
7 meetings, every meeting is preceded by public notice  
8 comment. Again this has been --

9 BOARD MEMBER DEURLOO: Every one?

10 MS. ZYGMUNT: Yes. We have to have the  
11 rule out for 30-day public comment, my understanding.

12 ACTING CHAIR CAHN: Now, we've had meeting  
13 where we haven't included new public comment, when it was  
14 just Board comment. We can say there's been enough -- that  
15 was in the past. We can say there's been enough public  
16 comment, we're just going to address Board comments at this  
17 point. So we've had that in the past.

18 MS. ZYGMUNT: Okay.

19 ACTING CHAIR CAHN: I don't know if that's  
20 still allowed, but we've certainly done it in the past.

21 MS. ZYGMUNT: That was not my  
22 understanding, but I appreciate you mentioning that. I can  
23 look into that.

24 ACTING CHAIR CAHN: We have had meetings  
25 where we have not opened it up to public comment for sure

1 in the past, so...

2 MS. ZYGMUNT: Okay.

3 ACTING CHAIR CAHN: And I would be okay,  
4 because I think, you know, with that, just addressing  
5 the -- already the comment that we got today and public  
6 comment plus the Board comments, I would be okay with that,  
7 and not opening it up for additional public comment if  
8 we're allowed to do that. We used to be.

9 MS. ZYGMUNT: Understood. Understood.

10 ACTING CHAIR CAHN: And I would be okay  
11 with moving up the quarter -- second quarter meeting to  
12 what's convenient for you guys. We can move it up.

13 MS. ZYGMUNT: Before we adjust the timing  
14 of that meeting, I would need to consult with Administrator  
15 Engels, Solid and Hazardous Waste Division. Her staff may  
16 not be able to bring rules packages before you by that  
17 date. And also our plan to bring Chapter 1 with further  
18 101 back to you.

19 Again, I know -- I'm departing from past  
20 practices. And so I appreciate your feedback. Again, I  
21 need to balance the role of this Board, which is very  
22 important in the rulemaking process. Again, I'm just so  
23 pleased with the feedback we got today, because this is  
24 extremely helpful. I think we have accomplished the  
25 purpose of this step of the rulemaking process, and there's

1 still more to come as you know. Before the EQC, there will  
2 be another 45-day public comment as well, but I have not  
3 heard any feedback today that I don't think that we can  
4 address through further revisions to the rule, and  
5 documenting the Board's feedback and our responses to some  
6 final comments from Mr. Pepper today and from the Board in  
7 documentation that we provide to the EQC.

8           And, again, you guys are free to make a motion  
9 that you feel is appropriate. And if you want to make a  
10 motion that does not advise me to move forward, you're free  
11 to do that. I would ask for specific feedback. If I do  
12 choose to move forward after that, that feedback will be  
13 very clearly presented to the EQC.

14           So I still encourage you make the motion you  
15 think is appropriate as a Board, but I want to be clear  
16 about where I'm at and what my thoughts are on what we've  
17 accomplished in this rule, and I feel we've accomplished  
18 the Board providing the advice that we need to move forward  
19 with formal rulemaking.

20           ACTING CHAIR CAHN: I don't know if it's  
21 appropriate for me to make a motion or if the board  
22 members should make the motion. If it's okay for a chair  
23 to make -- acting chair to make a motion, I don't know. I  
24 think it's typically not done.

25           BOARD MEMBER COCHRAN: Madam Chair, I would

1 propose that the Water Quality Division consider the  
 2 proposed revisions and advice given today and to proceed to  
 3 the proposed revision -- proceed with the proposed  
 4 revisions to the Environmental Quality Council.

5 ACTING CHAIR CAHN: Okay. Discussion?

6 BOARD MEMBER DEURLOO: My discussion is  
 7 this is going to be a tough vote, but the -- I have lived  
 8 by the mantra several times and got myself out of hot water  
 9 with bosses by saying, Do you want it done right, or do you  
 10 want it done right now? And there's two distinct  
 11 differences between having it done right and having it done  
 12 right now.

13 And we only see those rules every -- I think the  
 14 first or second time I've seen Chapter 12 in like three or  
 15 four years, and I get -- I understand with -- especially at  
 16 post-COVID, the strain that you must have with your staff  
 17 and so forth, getting them focused in all the work you want  
 18 to do. So I'm just kind of expounding here right now. I  
 19 still don't know which way I'm going to vote, but I would  
 20 always caution, as little as we see these things, it's  
 21 better to get them done right rather than expeditiously.  
 22 So...

23 ACTING CHAIR CAHN: So do I have -- I have  
 24 a motion on the floor. Do I have more discussion?

25 BOARD MEMBER DEURLOO: We don't have a

1 second yet? We haven't heard from Brian.

2 ACTING CHAIR CAHN: We don't have a second.

3 So I don't hear a second. So I think there's no vote at  
4 this point, so...

5 BOARD MEMBER DEURLOO: Correct. So we  
6 can't vote on it.

7 So do we need another motion?

8 ACTING CHAIR CAHN: We can -- if we want to  
9 do a different motion. I mean, I would like to --

10 MS. ZYGMUNT: I think Mr. Cochran would  
11 need to withdraw the motion if there's not a second.

12 BOARD MEMBER COCHRAN: No, it would die for  
13 lack of a second.

14 MS. ZYGMUNT: Right.

15 ACTING CHAIR CAHN: Okay. Then further  
16 discussion or do we want to adjourn?

17 BOARD MEMBER DEURLOO: Let's see what this  
18 motion brings. Let's see what happens here.

19 ACTING CHAIR CAHN: Okay.

20 BOARD MEMBER DEURLOO: I move that the  
21 advisory board not recommend this for the review of the  
22 Environmental Quality Council at this point until we can  
23 review it again at our second quarter meeting.

24 ACTING CHAIR CAHN: We have a motion on the  
25 table. Do I hear a second?

1 BOARD MEMBER DICKSON: This is Brian  
2 Dickson. I'll second that.

3 ACTING CHAIR CAHN: Discussion?

4 BOARD MEMBER COCHRAN: Just a point of  
5 order. My motion was the same thing. By dying, does the  
6 same thing you're asking for now, except you're -- you're  
7 trying to make a negative motion.

8 BOARD MEMBER DEURLOO: You moved --

9 BOARD MEMBER COCHRAN: So it's a nonaction.

10 BOARD MEMBER DEURLOO: You moved to  
11 recommend it to the EQC.

12 BOARD MEMBER COCHRAN: Right.

13 BOARD MEMBER DEURLOO: I am moving to  
14 review it again.

15 BOARD MEMBER COCHRAN: It's still --

16 BOARD MEMBER DEURLOO: Do you think we  
17 should amend my motion, Jim?

18 BOARD MEMBER COCHRAN: I'm just saying if  
19 we leave it the way it is --

20 ACTING CHAIR CAHN: It's the same thing.

21 BOARD MEMBER COCHRAN: -- it is the same  
22 thing.

23 ACTING CHAIR CAHN: Without a motion. So  
24 do you want to withdraw your motion?

25 BOARD MEMBER DEURLOO: I'm confused.



1                   BOARD MEMBER COCHRAN: We can go ahead and  
2 vote on it. It's just a point of order.

3                   MS. THOMPSON: Additionally, your attorney  
4 is still online. If you want to ask a clarifying question,  
5 Jim may be able to provide it to you.

6                   ACTING CHAIR CAHN: Okay. Do we need to  
7 make a motion to continue this to the next meeting?

8                   MR. PETERS: I think it's always beneficial  
9 if there is firm direction. What we had originally was a  
10 motion that failed for lack of a second. While we might be  
11 able to imply what that means, I think it would be better  
12 for the record, more clear for the record. We have a  
13 motion, a second currently before us that the board perhaps  
14 consider taking some sort of action on that motion to give  
15 clear direction.

16                   ACTING CHAIR CAHN: Thank you for that  
17 clarification.

18                   Any further Board discussion on the motion on the  
19 floor?

20                   BOARD MEMBER DEURLOO: I see what you're  
21 saying, Jim. I see what you're saying now.

22                   No, I don't believe I have any more discussion.

23                   ACTING CHAIR CAHN: Hearing none, then all  
24 in favor of the motion on the floor say aye.

25                   BOARD MEMBER COCHRAN: Aye.

1                   ACTING CHAIR CAHN: Aye.

2                   BOARD MEMBER DEURLOO: Aye.

3                   BOARD MEMBER DICKSON: Aye.

4                   ACTING CHAIR CAHN: Motion carries.

5                   Thank you.

6                   MS. ZYGMUNT: All right. Thank you very  
7 much. I will take all that into consideration, and we'll  
8 get back to you with next steps.

9                   BOARD MEMBER DEURLOO: Okay.

10                  MS. ZYGMUNT: Thank you very much for all  
11 your help today. Again the feedback today was incredibly  
12 valuable. We do greatly appreciate your time.

13                  ACTING CHAIR CAHN: Gina, do you want -- I  
14 don't know on the record or off the record. Do we need to  
15 talk about dates we are or aren't available? Or do you  
16 want to do that by email?

17                  BOARD MEMBER DEURLOO: Let's close the  
18 meeting.

19                  MS. THOMPSON: Yeah, let's let Kathy off  
20 the hook.

21                  ACTING CHAIR CAHN: Okay. The meeting is  
22 adjourned. Meeting is adjourned.

23                                 (Meeting proceedings concluded

24                                 4:01 p.m., March 15, 2022.)

25

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

C E R T I F I C A T E

I, KATHY J. KENDRICK, a Registered Professional Reporter, do hereby certify that I reported by machine shorthand the foregoing proceedings contained herein, constituting a full, true and correct transcript.

Dated this 5th day of April, 2022.

  
KATHY J. KENDRICK  
Registered Professional Reporter



**Proposed Revisions to Water Quality Rules, Chapter 12, Design and Construction Standards for Public Water Systems**

**Analysis of Comments Received at the March 15, 2022 Water and Waste Advisory Board Meeting**



**April 20, 2022**

Prepared by:

Wyoming Department of Environmental Quality

Water Quality Division

Water and Wastewater Section

**Commenters:**

Mark Pepper, Wyoming Association of Rural Water Systems (WARWS)

**Chapter 12 Comments and Responses**

**Mark Pepper:** Mr. Pepper noted that 2018 TSS Part “1.1.5 f discusses high water loss being greater than 20%. In an arid state such as Wyoming, where some of systems are facing water shortages, 20% water loss seems too high.” Mr. Pepper recommended revising to “ >15% for starters...” as WARWS advises that “water loss above 10% should be investigated and leaks may be occurring or lost revenue from uncalibrated meters.”

**Department Response:** WDEQ/WQD considered the comment. The recommended change would modify 2018 TSS Part “1.1.5 f” to reduce 20% water loss down to 15% or 10%. The WDEQ/WQD notes that this 2018 TSS passage is discretionary—it provides an example of high percentage of water loss being greater than 20% but does not limit an agency from considering less than 20% as being a high percentage of water loss. At the Administrator’s discretion, the WDEQ/WQD can require a water audit of a system due a high percentage of water loss and can evaluate on a case-by-case basis what constitutes a high percentage of water loss. WDEQ/WQD plans to explore options to provide additional training and outreach to address system awareness of high water loss in our communities and is committed to working with WARWS and other partners on this initiative.

**Mark Pepper:** Mr. Pepper noted that 2018 TSS Part “1.1.7.1 f was included for surface water source protection measures, but 1.1.7.2 h, groundwater source protection measures was omitted. Mr. Pepper notes that “with 88% of the systems utilizing groundwater for their drinking water source, we should place some value on protecting the groundwater. As an example, in our source water protection planning, we often utilize this concept so that principally county installed septic or other potential harmful activities are not approved by county boards upgradient from municipal water wells or at least some mitigation measures are taken to lessen potential contamination.”

**Department Response:** WDEQ/WQD considered the comment. WDEQ/WQD has intentionally omitted 1.1.7.2.h as it includes Part 3.2.3.3, wellhead protection plans. Since WDEQ/WQD intends to continue addressing wellhead protection planning and other source water protection planning on a voluntary basis, 1.1.7.2.h will not be incorporated by reference at this time as doing so would require wellhead protection plans. However, 1.1.7.2.h also includes Part 3.2.3.2, continued sanitary protection, which WDEQ/WQD will add to Section 11(a).

WDEQ/WQD recognizes the importance of groundwater as a source of drinking water in Wyoming and has many programs, both regulatory and voluntary, in place to protect

groundwater quality. WDEQ/WQD will continue to encourage communities that use groundwater for drinking water to develop wellhead protection plans and looks forward to working with WARWS to strengthen our voluntary source water protection program, including continuing our work with WARWS to provide training and outreach that will benefit communities.

**Mark Pepper:** Mr. Pepper noted that 2018 TSS Part “7.0.6 Water storage age was omitted. We know that with many upcoming regulations (Lead and Copper revisions, Disinfection Byproducts review), water age is paramount. TSS 2018 recommends no longer than 5 days on water age. We believe this is in agreement with AWWA recommendations.”

**Department Response:** WDEQ/WQD considered the comment. Water storage age is included in Chapter 12 in Section 15(c) and 15(e). The draft Chapter currently does not address a maximum day exceedance for water age. Based on further review and research, WDEQ/WQD will include 2018 TSS Part 7.0.6 in Section 15(a) so that Chapter 12 includes a 5-day maximum for water age and aligns with AWWA.

**Mark Pepper:** Mr. Pepper noted that 2018 TSS Part “8.7.2 Bedding was omitted. It is important to protect the investments of the state and the systems by ensuring quality bedding material is used. This isn’t the case on some projects.”

**Department Response:** WDEQ/WQD considered the comment and notes that pipe bedding requirements are provided in Chapter 12, Section 16(i), which requires that “Distribution system bedding shall be in accordance with ASTM C12 Classes A, B, or C for rigid pipe. Flexible pipe bedding shall be designed in accordance with ASTM D2321 Class I, II, or III.”

**Mark Pepper:** Mr. Pepper noted that 2018 TSS Part “8.7.9 Separation from other utilities was omitted. Again, while you would assume that design engineers would consider maintenance of distribution pipes and ability to dig around them important, alas, that is often not the case.”

**Department Response:** WDEQ/WQD considered the comment. WDEQ/WQD will revise Section 16(a) to include 2018 TSS 8.7.8 and 8.7.9 for clarity on aggressive soil provisions and ideal utility separation distances.

**Water and Waste Advisory Board Comments  
March 15, 2022 Meeting  
Chapter 12**

**(line numbers based on April 20, 2022 green copy)**

**General Comments**

**Lorie Cahn:** Ms. Cahn recommended including a description of what would require a permit modification in the response to comments document as the current response is unclear.

**Department Response:** WDEQ/WQD plans to provide permittee guidance that identifies frequently asked questions and WDEQ/WQD's responses to further clarify what activities require permit modifications. Additionally, WDEQ/WQD encourages applicants to contact our district engineers or the Water and Wastewater Section Manager with questions concerning modifications. WDEQ/WQD also plans to provide training, education opportunities, and outreach to stakeholders about the revised Chapter 12 once it is promulgated; these events will include information and guidance about applying for and modifying permits.

**Lorie Cahn:** Ms. Cahn recommended verifying the passages in each section that references the TSS and recommends removing redundant language and references that are only titles and that do not contain requirements.

**Department Response:** WDEQ/WQD reviewed each section that references the TSS 2018 for typographic errors and made additional edits to remove redundant wording throughout the document. WDEQ/WQD is developing a TSS 2018 crosswalk and additional guidance documents to aid users in the implementation of Chapter 12.

**Lorie Cahn:** Ms. Cahn recommended WDEQ/WQD correct the response to commenter Ty Ross for reference 10(b)(i), as the current answer is incorrect and should be 10(b)(ii),

**Department Response:** WDEQ/WQD will not revise the response to comments document but notes Ms. Cahn's comment for the record.

**Brian Deurloo:** Mr. Deurloo recommended that WDEQ/WQD review the punctuation in the chapter and ensure that semi-colons and periods are used consistently.

**Department Response:** WDEQ/WQD reviewed the chapter as requested and adjusted the punctuation as appropriate.

### **Section 3**

**Lorie Cahn:** Ms. Cahn requested that WDEQ/WQD rename the section to “applicability of these regulations” instead of “timing” since this term is not used in the section.

**Department Response:** WDEQ/WQD notes that Section 3 is consistent with other Water Quality Rules because the timing of compliance with a chapter, or grandfathering, is an important topic to permittees. WDEQ/WQD also notes the chapter already contains an applicability section, which describes the facilities that are required to comply with the chapter. WDEQ/WQD has structured both the “timing of compliance” section and the “applicability” section in a manner that is consistent with other Water Quality Rules. As the section clearly describes timing in relation to permit coverage, WDEQ/WQD will leave the title as written.

### **Section 6**

**Lorie Cahn:** Ms. Cahn noted the title and contents of the section are confusing.

**Department Response:** As discussed at the meeting, WDEQ/WQD uses the section as written to give the Administrator flexibility in permitting new technologies that are not specifically described in the rule, but which meet the intent of the rule.

### **Section 7**

#### **7(g)(ii) and 7(g)(iii)**

**Lorie Cahn and Brian Deurloo:** Ms. Cahn and Mr. Deurloo advised WDEQ/WQD to clarify the passages further and to ensure active language is used to clarify what the Administrator is authorizing and what is being authorized.

**Department Response:** WDEQ/WQD has revised the section to the following:

(ii) For applications that include wells, the Department will issue one permit with the following phased authorizations:



(A) The issued permit will authorize the well to be constructed, developed, and tested;

(B) Applicants shall then submit well test data and water quality data for Administrator review; and

(C) Upon the Administrator's approval of the well test data and water quality data, the Director shall modify the issued permit to authorize connection of the distribution system to the well.

(iii) Applicants for water storage tanks may follow an alternative procedure when the final plans and specifications for the tank cannot be submitted with the initial permit application due to project bidding constraints. In these instances, the Department will issue a permit through the following phased authorizations:

(A) The issued permit will authorize the project to initiate the bidding process. Applicants shall ensure the project bidding documentation includes a requirement that the final water storage tank design complies with the requirements of this Chapter.

(B) Applicants shall then submit final documentation and specifications for the water storage tank that demonstrate the design is consistent with the requirements of this Chapter. Upon the Administrator's approval of the final tank documentation specifications, the Director shall modify the issued permit to authorize the construction of the water storage tank and foundation.

(iv) Applicants that use the phased authorization procedures in this paragraph (g) shall request a pre-application meeting with the applicable Division district engineer prior to submission of the permit application package to ensure efficient coordination of the submittals of all reports, plans, and specifications, and Division review timelines.

## ***Section 8***

### **8(a)**

**Lorie Cahn:** Ms. Cahn recommends revising the order of the phrasing in the paragraph and removing part of 8(e) if duplicated in the TSS references.

**Department Response:** WDEQ/WQD has compared paragraph (e) to the incorporated material at paragraph (a) and has stricken the passages that overlap with the subparagraphs under (e).

### **8(c)(iv)(A)(I-II)**

**Lorie Cahn:** Ms. Cahn recommended reviewing the passage and verifying whether “or” or “and” is correct at the end of (iv)(A)(I).

**Department Response:** WDEQ/WQD has reviewed the passage and has corrected the end of (iii)(A)(I) to “or”. WDEQ/WQD has revised the paragraph as follows:

(A) The bottom of the stream, the elevation of the high- and low-water levels, and other topographical features at points where the water line:

(I) ~~The water line is~~ located within 10 feet of streams or lakes; ~~and or~~

(II) ~~The water line c~~crosses streams or lakes.

### **8(e)(v)**

**Lorie Cahn:** Ms. Cahn noted the paragraph is missing a word after “total depth of the drilled.”

**Department Response:** WDEQ/WQD has corrected the passage to include the term “borehole”.

### **8(e)(vii) and (viii)**

**Lorie Cahn:** Ms. Cahn noted the well test data may not be available at the time of the application and is likely to be available later in the process.

**Department Response:** WDEQ/WQD revised the passages as follows:

- (vii) The location of any blast charges, if available; and
- (viii) Existing well test data, including:

**Section 9**

**9(f)(v)**

**Lorie Cahn:** Ms. Cahn recommended adding a reference to the statutory definition of “aquifer” that WDEQ/WQD referenced in the response to comments.

**Department Response:**

WDEQ/WQD has considered the recommendation. At this time, the WDEQ/WQD has determined that a reference to the statutory definition of “aquifer” that WDEQ/WQD referenced in the previous response to comments is not necessary to clarify this passage. The WDEQ/WQD will provide guidance on this topic in the training, education, and outreach it plans to conduct following promulgation of the revised Chapter 12. Applicants that are uncertain as to whether they will drill through multiple aquifers should contact the appropriate district engineer for further guidance.

**9(f)(iv)**

**Lorie Cahn:** Ms. Cahn recommended adding “if known” to the passage as the information may not be available at the time of application.

**Department Response:** WDEQ/WQD added “if known” to the passage.

**9(g)(ii)**

**Lorie Cahn:** Ms. Cahn noted that the cross-reference to paragraph (e) is incorrect and should be changed to paragraph (f).

**Department Response:** WDEQ/WQD corrected the cross-reference.

**9(j)(ii)**

**Lorie Cahn:** Ms. Cahn recommended adding “if required.”

**Department Response:** WDEQ/WQD has revised the passage to “Hydraulic analysis that demonstrates how peak hour, average day, maximum day, and maximum day plus fire flows, if fire flows are available, will be improved by upsizing; and”

### **Section 11**

**Lorie Cahn:** Ms. Cahn recommended revising Section 11 by beginning with the source and organizing the rest of the section out from the source.

**Department Response:** WDEQ/WQD has evaluated and researched the comment. During the drafting phase of the rule, the District Engineers laid out the content of Section 11 in the order of events they thought were the most logical from an engineering standpoint. Section 11 also follows the order of events of the TSS 2018. The order of items in Section 11 will remain unchanged.

### **11(a), Line 870**

**Lorie Cahn:** Ms. Cahn recommended removing the reference to TSS 3.2.7 as all of 3.2.7 is not incorporated.

**Department Response:** WDEQ/WQD has removed 3.2.7 from 11(a).

### **Section 11, Table 1 and 2.**

**Lorie Cahn and Jim Cochran:** - Ms. Cahn and Mr. Cochran noted the setbacks in the tables section are inconsistent with the setbacks in Water Quality Rules Chapter 25. Mr. Cochran recommended making the two chapters consistent or obtaining agreements from landowners related to permit applications to ensure siting conflicts do not occur.

**Department Response:** WDEQ/WQD has reviewed both the setback tables in Chapters 12 and 25 and has revised the setback distances from public water supply wells to septic tanks to 100 feet, for consistency with Chapter 25.

### **11(e)(i)**

**Lorie Cahn:** Ms. Cahn notes that there are lots of very small water systems, campgrounds, rest stops, little parks. Ms. Cahn wondered if there is a way of having some kind of de minimus that allows facilities that serve less than a certain number of households, people, or size system to have an exemption from some of the regulations. For instance, if a small system such as campgrounds, rest stops, little parks, are required to have a second well, or a storage tank—they have to have twice as much as the daily demand. Since these are seasonal there can be water aging problems. Ms. Cahn is concerned that a one size fits all doesn't seem to work, and she is concerned about oversizing systems and making them too expensive.

Ms. Cahn wondered if using the definition for small wastewater systems would be a good starting point for assisting small public water systems.

Ms. Cahn noted the current passage seems to indicate that each well has to supply twice the maximum daily demand. The passage does not seem to make sense alongside the passage that follows that requires one well and storage.

**Department Response:** After reviewing the comment and practices of other states, WDEQ/WQD has revised the paragraph and has added a new passage at (C) as follows:

(i) Proposed designs shall include a minimum of:

(A) Two wells that are each capable of supplying the ~~maximum~~ average daily demand with the largest producing well out of service; or

(B) One well and finished water storage that together equal twice the maximum daily demand; or

(C) For public water supplies that are not community water systems or noncommunity nontransient water systems, as determined by the Administrator, one well that is capable of supplying the maximum daily demand.

### **11(e)(ii)(C)**

**Lorie Cahn:** Ms. Cahn notes the paragraph requires compliance with Water Quality Rules Chapter 3, Section 17(b), but Chapter 3, Section 17(a) seems to exclude public water supplies from the requirements in the section.

**Department Response:** As discussed during the meeting and as confirmed with our Attorney General's Office, the passages of Chapter 3, Section 17(b) are the steps that will be required for the subsurface study but the reference to this paragraph does not mean all of Chapter 3, Section 17 applies.

#### **11(e)(iii)(C)**

**Jim Cochran:** Mr. Cochran noted the 10-foot setback is inconsistent with other setbacks in the section and that it may be impractical for future landowners.

**Department Response:** WDEQ/WQD has reviewed the passage as discussed and has revised it as follows:

Wells shall be located at least ~~10~~ 50 feet from any property line.

#### **11(e)(v)**

**Lorie Cahn:** Ms. Cahn noted that the new requirements for acidizing seem to be regulating for an infrequent event or an event that has not happened yet. Ms. Cahn recalled that in a comment response WDEQ/WQD had declined to make a revision due to a situation not happening in Wyoming. Ms. Cahn recommended striking the acidization requirements and doing a policy instead for consistency with the comment response.

**Department Response:** WDEQ/WQD was unable to determine to which comment response Ms. Cahn is referring. The WWAB had previously approved the proposed acidization passages at the October 17, 2019 meeting. As the requirements allow WDEQ/WQD to collect information that is needed for the WDEQ/WQD to ensure the acidization activities do not negatively impact underground sources of drinking water, WDEQ/WQD will leave the acidization passages as part of the rule.

#### **11(e)(vii)(C)(I)**

**Lorie Cahn:** Ms. Cahn wondered if TSS 3.2.6.5 conflicts with line [1115] (11(e)(vii)(C)(I)).

**Department Response:** TSS 3.2.6.5 covers limestone or sandstone wells. However, the passage on line [1115], 11(e)(vii)(C)(I) falls under gravel-packed or artificial filter-packed wells. As noted in the March 15, 2022 Addendum to Analysis of Comments,

WDEQ/WQD will leave the casing requirements at 11(e)(vii)(C)(I) and (II) as written as the current requirements provide stability and frost protection. However, at 11(e)(vii)(D), WDEQ/WQD committed to revising the casing requirement for wells that encounter naturally flowing water for consistency with the State Engineer's Office casing requirements.

### **11(e)(vii)(D)(I)**

**Lorie Cahn:** Ms. Cahn wondered if the water is not flowing back into the well, why couldn't WDEQ/WQD allow a below-ground vault or some additional way to keep the well from freezing.

**Department Response:** Buried well discharge lines or below-ground vaults with well discharge have demonstrated contamination when the below-grade discharge line becomes submerged by groundwater. Freezing considerations have been addressed previously in the section. This paragraph has been revised to the following:

"The well discharge or overflow line installations must connect to the well casing at least 12 inches above ground and be valved. The size of the air gap between the overflow line from the well to drainage structure shall be twice the diameter of the well overflow pipe. Overflow water must be drained and diverted to prevent ponding around the well casing."

### **11(e)(vii)(E) and 11(e)(vii)(E)(II)**

**Lorie Cahn:** Ms. Cahn noted that for mineralized water, one of the commenters wanted 1000. Ms. Cahn explained the total dissolved solids is a secondary drinking water standard and that EPA considers anything over 1000 unfit for human consumption. Ms. Cahn recommended that WDEQ/WQD revise the language referring to 40 CFR 141, as this reference contains both secondary and primary standards. Ms. Cahn recommended rewording the reference to only refer to the primary drinking water standard and to remove the implication that applicants would be required to treat mineralized water.

**Department Response:** The intent behind the passage at Section 11(e)(vii)(E)(II) is to ensure that if the applicant proposes to use water that meets the definition of "mineralized," then the proposed design will produce water that complies with the applicable standards in Part 141. The mineralized water is a trigger that will require WDEQ/WQD to review any treatment design options that EPA will require to be

installed and operated so that the resulting water meets the drinking water standards that EPA will enforce. The passage does not require systems to comply with specific primary or secondary standards, which falls under the authority of EPA. WDEQ/WQD has clarified the passage as follows:

“(II) Applicants that propose to use mineralized water as a public water supply shall demonstrate ~~the~~ that any necessary treatment will comply with the drinking water quality standards required by 40 CFR Part 141.

### **11(e)(viii)**

**Lorie Cahn:** Ms. Cahn recommended clarifying the passage to indicate “diameter” and recommends removing extra “shall.” Ms. Cahn recommended incorporating all of 3.2.4 and removing all of (viii) and (ix) per Mr. Jordan’s comment.

**Department Response:** WDEQ/WQD has reviewed 2018 TSS Part 3.2.4 against 11(e)(viii) and 11(e)(ix). Part 3.2.4 will be added to 11(a), with the subparts stricken from that paragraph, and 11(e)(viii) and 11(e)(ix) will be stricken, which makes the comments concerning “diameter” and redundant uses of “shall” obsolete.

WDEQ/WQD has reviewed all formal public comments received, including those from Mr. Jordan. We did not receive a specific request to incorporate 2018 TSS 3.2.4 prior to this recommendation being made at the March 15, 2022 meeting. As a reminder, in order for WDEQ/WQD to adhere to rulemaking procedures, all public comments must be received by the WDEQ/WQD according to the instructions provided in each public notice, or the public may read comments into the record during meetings when public comments are being accepted. Executive Order No. 1981-12 outlines actions to take should board members receive additional comments directly from interested parties.

### **11(e)(x)**

**Lorie Cahn:** Ms. Cahn noted the response to comments document indicates WDEQ/WQD would revise the statement, but the revision is not incorporated into the draft chapter.

**Department Response:** WDEQ/WQD verified the passage included in Chapter 12 is the language proposed in the response to comments document.



#### 11(e)(xvi)

**Lorie Cahn and Jim Cochran:** Ms. Cahn wondered why the passage requires each well to measure the total discharge from the whole field and why the applicant couldn't just add the individual well information together. Mr. Cochran noted the chapter already requires a meter.

**Department Response:** WDEQ/WQD has revised the paragraph to the following: "An instantaneous and totalizing flow meter equipped with nonvolatile memory shall be installed on the discharge line of each well in accordance with the manufacturer's specifications. Meters installed on systems with variable frequency drives shall be capable of accurately reading the full range of flow rates."

WDEQ/WQD has also revised 11(e)(xiv) to: "An accessible check valve, which is not located in the pump column, shall be installed in the discharge line of each well between the pump and the shut-off valve. Additional check valves shall be located in the pump column as necessary to prevent negative pressures on the discharge piping."

#### 11(f)(v)(B)

**Lorie Cahn:** Ms. Cahn noted the response to comments document indicates WDEQ/WQD would revise the statement, but the revision is not incorporated into the draft chapter.

**Department Response:** WDEQ/WQD reviewed the passage proposed in the response to comments document and revised the Chapter as follows:

"Made of concrete with a minimum width or wall thickness of six inches or other material that meets the requirements of Section 15(b)(ii) of this Chapter;"

#### 11(f)(xiii)

**Lorie Cahn:** Ms. Cahn noted the reference to Section 14 is incorrect and the correct reference is Section 15. Ms. Cahn also wondered if springs need to be subject to all of the requirements in Section 15 if they are not providing fire water.

**Department Response:** WDEQ/WQD corrected the cross-reference as requested and revised the passage as follows: "Spring boxes designs shall comply with ~~the finished water~~

storage requirements of Section 15(a), (b), (f-j), and (l) of this Chapter, Combined spring box and finished water storage designs shall comply with Section 15 of this Chapter.

## **Section 12**

### **12(a)**

**Lorie Cahn:** Ms. Cahn noted the incorporated material is listed out of order, and that “through” is inconsistently used, which leads to confusion as to what applies.

**Department Response:** WDEQ/WQD reviewed the incorporations of the TSS 2018 and corrected the passage as discussed.

### **12(k)(ii)(G)(II)**

**Brian Deurloo:** Mr. Deurloo recommends revising the passage from “identical” to “equivalent.”

**Department Response:** WDEQ/WQD revised the passage as requested.

### **12(j)(i)(C)**

**Lorie Cahn:** Ms. Cahn recommended revising the passage to “the maximum feed point backpressure shall not exceed 100 psi unless a chlorine solution pump is used.”

**Department Response:** WDEQ/WQD revised the passage as requested.

### **12(n)**

**Lorie Cahn:** Ms. Cahn notes the term “hydrofluosilic” acid is misspelled and should be “hydrofluorosilicic.”

**Department Response:** WDEQ/WQD corrected the term as recommended.

### **12(o)(i)**

**Lorie Cahn:** Ms. Cahn notes the term “absorb” is used in the passage, but granulated activated carbon “adsorbs.”

**Department Response:** WDEQ/WQD corrected the passage as requested.

#### **12(q)(i) and (ii)**

**Lorie Cahn:** Ms. Cahn requested the incorporated manual include the phrase “US EPA.”

**Department Response:** WDEQ/WQD revised the references as requested.

#### **12(r)**

**Lorie Cahn:** Ms. Cahn recommended removing redundancy in paragraph (r) and (r)(i).

**Department Response:** WDEQ/WQD combined the passages and renumbered the section as needed.

#### **12(r)(xii)**

**Lorie Cahn:** Ms. Cahn noted the response to comments document indicates WDEQ/WQD would revise the statement, but the revision is not incorporated into the draft chapter.

**Department Response:** WDEQ/WQD corrected the passage to include the language proposed in the response to comments.

#### **12(t)(i)**

**Lorie Cahn:** Ms. Cahn notes the phrase “simple well system” is used in the passage and wonders where is the definition of this term and what the requirements would be for a non-simple well system.

**Department Response:** WDEQ/WQD removed “simple” from the passage.

### ***Section 13***

#### **13(a)**

**Lorie Cahn:** Ms. Cahn identified that “are herein incorporated by reference” was used repeatedly in the passage and recommended striking the unnecessary uses.

**Department Response:** WDEQ/WQD corrected the passage as requested.

## ***Section 14***

### **14(g)(iv)**

**Lorie Cahn:** Ms. Cahn noted the passage seems unnecessarily prescriptive and does not seem necessary.

**Department Response:** WDEQ/WQD notes the passage has been in the rule since 1985 and is part of common engineering design practices to determine headloss. WDEQ/WQD has not received comments or feedback from applicants that indicate the passage is unnecessary or burdensome. WDEQ/WQD uses the submitted information to verify the proposed design will meet the requirements of paragraphs (g)(i)-(iii) to ensure the overall design will meet the intent of the Environmental Quality Act. The passage will remain as written.

### **14(i)(ii)**

**Lorie Cahn:** Ms. Cahn noted the revision does not clarify the requirement.

**Department Response:** WDEQ/WQD has reviewed the section and determined the section will revert to include original proposed language, which included the term “manifolded”. The original term and language is common in the industry, and the language is used by numerous EPA Region 8 and 9 states. WDEQ/WQD will restore the paragraph to :

“Each pump shall either have an individual suction line or the suction lines shall be manifolded such that they demonstrate similar hydraulic and operating conditions.”

## ***Section 16***

### **16(g)**

**Lorie Cahn:** Ms. Cahn noted that WDEQ/WQD’s response to the public comment on the passage is insufficient. Ms. Cahn notes that manholes are difficult to keep water out—coatings leak, fiberglass can flood, flooding can cause rust/difficult use, safety issues. Ms. Cahn asked WDEQ/WQD to look at valve boxes and the wording on chambers to clarify that these are synonymous.

**Department Response:** WDEQ/WQD has evaluated the passage and determined it is duplicative with the inclusion of TSS 2018 8.5- Air Relief Valves. WDEQ/WQD will remove Section 16(g).

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

WYOMING WATER AND WASTE ADVISORY BOARD

-----  
RE: WATER AND WASTE ADVISORY BOARD SPECIAL MEETING  
-----

TRANSCRIPT OF SPECIAL MEETING PROCEEDINGS

Pursuant to notice duly given to all parties in interest, this matter came on for special meeting on the 3rd day of May, 2022, at the hour of 9:07 a.m., before the Wyoming Water and Waste Advisory Board, Ms. Lorie Cahn, Acting Chairman, presiding, and Mr. Brian Deurloo and Mr. Brian Dickson in attendance virtually, with Mr. James Cochran in attendance. And Mr. James Peters and Carl Edelman, Attorneys for the Board, also in attendance virtually.

Ms. Nicole Budine, Attorney for the Division;  
Ms. Jennifer Zygmunt, Water Quality Administrator;  
Mr. Keenan Hendon, Water and Wastewater Section Manager;  
Mr. Anthony Rivers, Water/Wastewater Regulatory & Enforcement Engineer; and Ms. Gina Thompson, Water Quality Division; and Mr. Bryce Dorr, Cheyenne BOPU, in attendance; as well as various members of DEQ staff and the public in attendance virtually.

1 P R O C E E D I N G S

2 (Special meeting proceedings commenced  
3 9:07 a.m., May 3, 2022.)

4 MS. ZYGMUNT: Good morning, Lori. Thanks  
5 for joining us today. Okay. With that, Chairwoman Cahn,  
6 I'll let you start the meeting for us this morning.

7 ACTING CHAIR CAHN: Okay. This is a  
8 special meeting of the Water and Waste Advisory Board to  
9 discuss Chapter 12. And I'll turn it over to DEQ.  
10 Actually, let's first introduce everybody who's here. From  
11 the Board, I'm Lorie Cahn. I'm the acting chair  
12 representing the public at large.

13 BOARD MEMBER DEURLOO: Hi. This is Brian  
14 Deurloo -- Brian Deurloo here, and I'm representing  
15 industry.

16 BOARD MEMBER DICKSON: I'm Brian Dickson,  
17 representing the public at large.

18 BOARD MEMBER COCHRAN: Jim Cochran, just  
19 member. The reason I say that is I attended training --  
20 board training last week, and they talked about who you're  
21 representing, and they said that that's only for the  
22 purposes of appointing board members. Once you're  
23 appointed, you represent the whole state. So maybe we  
24 should just drop who we're representing and assume we're  
25 representing the whole state. So with that, I'll turn it

1 back to Lorie.

2 ACTING CHAIR CAHN: Okay. Thank you very  
3 much. I appreciate it.

4 And how about DEQ, introduce who you have there.

5 MS. ZYGMUNT: Great. Thank you, Lorie.

6 So my name is Jennifer Zygmunt. I am the Water  
7 Quality Division Administrator.

8 MR. HENDON: Keenan Hendon, Water and  
9 Wastewater Section Manager.

10 MS. THOMPSON: Gina Thompson, Policy and  
11 Planning Analyst for the Water Quality Division.

12 MR. RIVERS: Anthony Rivers. I'm here for  
13 Water and Wastewater Section.

14 MS. ZYGMUNT: And I'll turn it over to our  
15 Attorney General's Office. We've got a few people from the  
16 Attorney General's, so I'll let them introduce themselves,  
17 starting with Jim.

18 MR. PETERS: I'm Jim Peters at the Attorney  
19 General's Office representing the advisory board. Also  
20 joined with by Carl Edelman today, also at the Attorney  
21 General's Office. He'll be taking over representing the  
22 advisory board after today's meeting, so going forward.  
23 But I'll let him introduce himself.

24 MS. ZYGMUNT: Carl, if you're speaking, we  
25 can't hear you. You're still on mute. He may have had to



1 step away.

2 So, Nicole, do you want to introduce yourself?

3 MS. BUDINE: Yeah. Sure. Hi. This is  
4 Nicole Budine, and I'm at the Attorney General's Office,  
5 representing the Water Quality Division of DEQ.

6 MS. ZYGMUNT: Thanks, Nicole.

7 And, Madam Chairwoman, we do have somebody from  
8 the public here in the Cheyenne office, if you'd like them  
9 to introduce themselves. That's you.

10 MR. DORR: Bryce Dorr with Cheyenne Board  
11 of Public Utilities.

12 MS. ZYGMUNT: Great. Thank you.

13 ACTING CHAIR CAHN: I'm sorry. Could you  
14 repeat that? I couldn't hear you.

15 MR. DORR: Sure. Bryce Dorr, Cheyenne  
16 Board of Public Utilities.

17 ACTING CHAIR CAHN: Thank you.

18 Okay. Administrator Zygmunt, if you want to  
19 proceed.

20 MS. ZYGMUNT: Sure. Thank you.

21 So thank you everybody for your time today. As  
22 Chairwoman Cahn indicated, this is a special meeting that  
23 we have convened to review Chapter 12. I will just give a  
24 brief introduction, and then I will turn it over to Keenan  
25 to walk us through the revisions.

1           So just as a reminder, this is our Division's  
2   third presentation to the WWAB for Chapter 12, Design and  
3   Construction Standards for Public Water Systems. This  
4   special meeting follows the meeting that we had on  
5   March 15th. We have met previously with the Board in  
6   December. So two quarterly meetings with the Board. We  
7   have had an opportunity to review the entire rule and  
8   receive feedback.

9           The purpose, again, of this meeting today is to  
10   review the revisions that we made following the discussion  
11   and additional comments that we received from both the  
12   Board and the public at the March 15th meeting.

13           Again, at that meeting, it was the Board's  
14   recommendation that DEQ did not proceed forward with formal  
15   rulemaking. So we considered that advice and wanted to  
16   honor the Board's request to have another opportunity to  
17   review the revisions that we have made to this rule, again  
18   following the discussion that we had on March 15th.

19           So, again, thank you for your time today. We're  
20   looking forward to showing you the final revisions that we  
21   have made to the rule and the response to comments that we  
22   have put together, again, per the Board's comments at the  
23   March 15th meeting, the additional comments we received  
24   from the Wyoming Association of Rural Water Systems at that  
25   meeting as well.

1           As a reminder, we did not put the rule back out  
2 for public notice with this meeting. That was a decision  
3 made given the length of time that we have already had this  
4 rule out for public comment. We've had it out for  
5 approximately 100 days. Received good feedback during that  
6 public comment period and have responded to all comments  
7 with personal outreach to each commenter.

8           And before I turn it over to Keenan, I just want  
9 to say that we have received a lot of good feedback on this  
10 rule during this process. And that's both in the content  
11 of the rule as well as our processes. And we feel that we  
12 have a good product to present to you today, but I just  
13 want to, again, thank the Board for your feedback over the  
14 past few meetings, because it's not only informed the rule,  
15 but I think it's caused us to reconsider, again, some of  
16 our processes associated with rulemaking, how we best do  
17 outreach, how we best do scoping, how we respond to  
18 comments and how we best present information to you and  
19 work efficiently with the Board to get your feedback and  
20 recommendations on our rules.

21           I -- you know, both Keenan and I are new --  
22 fairly new to the Division still. You know, we took over  
23 this chapter midstream and I think we have had some good  
24 discussions internally based on your feedback about how we  
25 can improve things moving forward.

1           So this is a discussion that I would like to  
2 continue with the Board, and one with Administrator Engels  
3 at one of our regularly scheduled meetings. Again, we're  
4 interested in finding the best way to present information  
5 to you, get your advice on these rules, and make the best  
6 use of your time, and I think we've had some good insight  
7 into how we do that, and how we reach out to the public to  
8 get feedback on our rules.

9           So I think it's been a good discussion over the  
10 past few meetings. Again, we're looking forward to  
11 presenting our revisions to you today. And, again, just  
12 know that we are committed to continued conversation on how  
13 we improve the process moving forward in the interest of  
14 your time as well as staff time here and making sure we get  
15 the best public input that we can.

16           So unless there are any questions for me, I will  
17 pause there and turn it over to Keenan to walk through the  
18 revisions.

19                       MR. HENDON: So hearing no further  
20 comments, we'll go ahead and get started with reviewing  
21 Chapter 12 and the comments that we received from the March  
22 WWAB meeting from the board members, as well as the public  
23 commenter, Mark Peppers with the Wyoming Association of  
24 Rural Water Systems.

25           Just as a reminder, Sections 1 through 9 were

1 reviewed at the December WWAB meeting. They were  
2 re-reviewed at the March meeting. And Sections 10 through  
3 19 were also reviewed at the March WWAB meeting as well.

4 As we work our way through the comments, for the  
5 board members, as well as Mark Peppers with WARWS, we've  
6 kind of streamlined those comments, and we'll take those in  
7 section order as we work our way through the response to  
8 comments document that has been distributed to everyone  
9 here today.

10 So with that, we'll just go ahead and get started  
11 with our general comments that we received on Chapter 12.  
12 And our first comment is from Ms. Cahn, who recommended  
13 including a description of what would require a permit  
14 modification in the response to comments document as the  
15 current response is unclear.

16 DEQ's response -- or the Department response, we  
17 plan to provide permittee guidance that identifies  
18 frequently asked questions and DEQ's responses to further  
19 clarify what activities require permit modifications. DEQ  
20 also plans to provide training, outreach, and educational  
21 opportunities to reach our stakeholders about revised  
22 Chapter 12 once it's promulgated. These events will  
23 include information and guidance about applying for and  
24 modifying permits.

25 Additionally, DEQ would recommend stakeholders to

1 conduct outreach with our district engineers, as well as  
2 reach out to headquarters with any questions or concerns.

3 Our next comment under General Comments from  
4 Ms. Cahn, recommended verifying the passages in each  
5 section that reference the 10 States Standards and  
6 recommends removing redundant language and references that  
7 are only titles that do not contain requirements.

8 The Department response, DEQ has reviewed each  
9 section that references the 10 States Standards for  
10 typographical errors and made additional edits to remove  
11 any redundant wording throughout the document.  
12 Additionally, DEQ is developing a 10 States Standards  
13 crosswalk and additional guidance documents to aid users in  
14 the implementation of Chapter 12.

15 ACTING CHAIR CAHN: Keenan, when will that  
16 be available?

17 MR. HENDON: Those documents will be  
18 available once the rule's promulgated.

19 Had a technical glitch here. Just a moment.

20 Moving on to our next comment, was from Ms. Cahn,  
21 who recommended DEQ correct the response to commenter Ty  
22 Ross for reference 10(b)(i), as the current answer is  
23 incorrect and should be 10(b)(ii).

24 The Department response, DEQ will not revise the  
25 response to comment documents, but does note Ms. Cahn's

1 comment for the record. We did discuss this with the  
2 commenter during our outreach session, and this comment was  
3 addressed to the satisfaction of both parties.

4 Next comment is from Brian Deurloo. Brian  
5 recommended that DEQ review the punctuation in the chapter  
6 and ensure semicolons and periods are used consistently.

7 DEQ has reviewed the chapter as requested and  
8 adjusted the punctuation as appropriate.

9 And that concludes our General Comments. Just in  
10 summary, with some of these changes to the document, the  
11 formatting of the document has been changed in order and  
12 presentation. And as an example, I'd like to draw your  
13 attention to page 4 or 5 of the proposed Chapter 12.

14 On page 4 you'll see a new definition for  
15 stabilized drawdown. And on the other side you'll see  
16 page 5, you can see some formatting changes that just will  
17 be -- that shows the section as presented just a bit  
18 differently, because there's been no content change.

19 So as we work our way through the chapter, you  
20 will see some of these highlights in green as we work our  
21 way through the document that we won't be covering, but  
22 it's just what we did to address some of the punctuation,  
23 formatting, and other requests that we have received.

24 MS. ZYGMUNT: Are there any questions from  
25 the Board on these General Comments? Otherwise, we'll

1 continue on. Okay. Thumbs up.

2 Go ahead, Keenan.

3 MR. HENDON: All right. So we are on to  
4 the next comment. It's located in Section 3, page 1, line  
5 30.

6 The comment is from Ms. Cahn, requesting DEQ  
7 rename the section to "applicability of these regulations"  
8 instead of "timing," since this term is not used in the  
9 section.

10 DEQ notes that Section 3 is consistent with other  
11 Water Quality Rules, because the timing of compliance with  
12 the chapter or grandfathering is an important topic to  
13 permittees. DEQ also notes the chapter already contains an  
14 applicability section which describes the facilities that  
15 are required to comply with the chapter. DEQ has  
16 structured both the timing of compliance section and the  
17 applicability section in a manner that is consistent with  
18 other Water Quality Rules and section title aligns with  
19 other DEQ regulations.

20 The section describes timing in relation to  
21 permit coverage. DEQ intends to leave the title as  
22 written.

23 Our next comment is located in Section 6, on page  
24 5, line 194. Comment is from Ms. Cahn. Notes that the  
25 title and contents of the section are confusing.



1           DEQ's response, as discussed at the March  
2 meeting, DEQ uses the section as written to give the  
3 Administrator flexibility in permitting new technologies  
4 that are not specifically described in the rule, but which  
5 meet the intent of the rule.

6           The title and language aligns with other DEQ  
7 regulations and will leave the title as written.

8           Excuse me. Our next comment is located in  
9 Section 7. We are looking at Section 7(g)(ii) and  
10 7(g)(iii) located on page 6 starting at line 268. The  
11 comment is from Ms. Cahn and Mr. Deurloo, who advised DEQ  
12 clarify the passage further to ensure active language is  
13 used to clarify what the Administrator is authorizing and  
14 what is being authorized.

15           The passage in question -- the passage in  
16 question is with regards to the two-phase permitting  
17 process. And we've corrected the language and cleaned the  
18 passage to better identify it to be a two-part  
19 authorization process for permitting of wells and storage  
20 tanks.

21           Our next comment is located on Section 8. We are  
22 looking at Section 8(a), page 7, line 311. Ms. Cahn  
23 recommends revising the order of the phrasing in the  
24 paragraph and removing part 8(e), if duplicated in the 10  
25 States Standards references.

1           DEQ has compared paragraph 8(a) to paragraph 8(e)  
2 and incorporated the material and removed the passages that  
3 overlap in part 8(e). If you're looking for the  
4 information that's located -- 8(a) is located on page 7,  
5 line 311. 8(e) starts on page 10, page 427 for the  
6 stricken components that overlapped.

7           Our next comments is Section 8. It's located on  
8 page 8, line 357. It is Section 8(c)(iv)(A)(I) to (II).  
9 Ms. Cahn recommended reviewing the passage and verifying  
10 whether "or" or "and" is the correct usage at the end of  
11 (A)(I).

12           We reviewed the passage and corrected it to "or"  
13 is the correct word usage.

14           Our next comment is located at Section 8(e)(v),  
15 line 446, page 10. And Ms. Cahn had noted the paragraph is  
16 missing a word after the "total depth of the drilled." DEQ  
17 has corrected the passage to "total depth of the drilled  
18 borehole."

19           ACTING CHAIR CAHN: Why that doesn't show  
20 up as green --

21           MS. THOMPSON: Because I missed a  
22 formatting mark.

23           MR. HENDON: Yeah. We probably missed a  
24 formatting mark when we were trying to get -- essentially  
25 with regards to our green version versus clean version

1 versus tracking all changes with regard to our rule change  
2 chapter. Apologize for the confusion.

3 Our next comment is with regards to Section  
4 8(e)(vii) to (viii) located on page 10, on lines 452 and  
5 454. Ms. Cahn had noted that the well test data may not be  
6 available at the time of application and is likely to be  
7 available later in the process.

8 We revised the passage as presented for (vii) to  
9 include "The location of any blast charges, if available;  
10 and," for (viii), "existing well test data, including:" as  
11 listed.

12 Moving on to our next section. We're in Section  
13 9 now. We're going to discuss two comments we received  
14 from Mark Pepper with WARWS. These are located at Section  
15 9(a), line 509 on page 12. Mr. Pepper's first comment he  
16 notes that the 2018 10 States Standards Part 1.1.5 f  
17 discusses high water loss being greater than 20 percent.  
18 In arid state such as Wyoming, where some of the systems  
19 are facing water shortages, 20 percent water loss seems too  
20 high. Mr. Pepper recommended revising it to greater than  
21 15 percent for starters, as WARWS advises that water loss  
22 above 10 percent should be investigated and leaks may be  
23 occurring or lost revenue may be incurred from uncalibrated  
24 meters.

25 Part 1.1.5 f reads, For systems with high

1 percentage of unaccounted for water (generally greater than  
2 20 percent of water production), a water audit may be  
3 required by the reviewing authority.

4 In reviewing the response DEQ has considered it  
5 and the recommended change would modify parts of the 2018  
6 10 States Standards to reduce the 20 percent water loss  
7 down to 15 or 10 percent. DEQ notes that this 2018 TSS  
8 passage is discretionary. It provides an example of what  
9 high percentage of water loss might be and provides that at  
10 20 percent, but does not limit the agency from considering  
11 values less than 20 percent as being a high percentage of  
12 water loss.

13 Additionally, the water audit is at the  
14 Administrator's discretion, and DEQ could require it upon  
15 review, and evaluate it on a case-by-case basis. DEQ plans  
16 to explore options to provide the additional training and  
17 outreach to address system awareness of high water loss and  
18 is looking forward to working with WARWS on continued  
19 efforts with our community.

20 Our next comment is from Mark Pepper as well.  
21 Section 9(a). Again, Mr. Pepper notes that the 2018 TSS  
22 Part 1.1.7.1 f was included for surface water protection  
23 measures, but 1.1.7.2 h, groundwater source protection  
24 measures was omitted. Mr. Pepper notes with 88 percent of  
25 systems utilizing groundwater for their drinking water

1 source, we should place value on protecting the  
2 groundwater. As an example, in our source water protection  
3 planning, we often utilize this concept so that principally  
4 county-installed septics or other potential harmful  
5 activities are not approved by county boards upgradient  
6 from municipal water wells or at least some mitigation  
7 measures are taken to lessen potential contamination.

8 DEQ has considered the comment, and has  
9 intentionally omitted 1.1.7.2 h, as it references and  
10 includes TSS Part 3.2.3.3, wellhead protection plans.  
11 Since DEQ intends to continue addressing wellhead  
12 protection planning and other source water protection  
13 planning on a voluntary basis, 1.1.7.2 h will not be  
14 incorporated by reference at this time.

15 However, 1.1.7.2 h also includes a reference to  
16 Part 3.2.3.2, for continued sanitary protection of the well  
17 site from potential contamination, which DEQ will include  
18 and add to Section 11(a).

19 DEQ fully recognizes the importance of  
20 groundwater as a source of drinking water in Wyoming, and  
21 has many programs, both regulatory and voluntary, in place  
22 to protect groundwater quality. We intend to continue and  
23 encourage our communities that use groundwater for drinking  
24 water to develop wellhead protection plans and look forward  
25 to working with WARWS to strengthen our voluntary source

1 water protection program, including our work with WARWS, to  
2 provide training and outreach and benefits to our  
3 communities.

4 Our next comment is located on Section 9(f)(ii).  
5 That was the original reference in the March meeting. It  
6 is now located at 9(f)(v), page 15, line 642. Ms. Cahn had  
7 recommended adding a reference to the statutory definition  
8 of aquifer that DEQ referenced in response to comments.

9 DEQ has considered the recommendation and at this  
10 time DEQ's determined that a reference to the statutory  
11 definition of aquifer that DEQ referenced in the previous  
12 responses to comments is not necessary to clarify this  
13 passage. DEQ will provide guidance on this topic, and,  
14 again, training, education, and outreach, and plans to  
15 conduct following promulgation of the revised Chapter 12.  
16 Applicants that are uncertain as to whether they will drill  
17 through multiple aquifers should contact the appropriate  
18 district engineer or reach out to headquarters for further  
19 guidance.

20 Next comment is located at Section 9(f)(iv), line  
21 637 on page 14. Ms. Cahn recommended adding "if known" to  
22 the passage as the information may not be available at the  
23 time of application.

24 DEQ has added "if known" to the passage.

25 Our next comment is located at Section 9(g)(ii)

1 on page 15, line 656. And Ms. Cahn noted that the  
 2 cross-reference to paragraph (e) is incorrect and should be  
 3 changed to paragraph (f).

4 DEQ has corrected the cross-reference.

5 Our next comment is located at Section 9(j)(ii),  
 6 line 710 on page 16. And Ms. Cahn recommended adding "if  
 7 required."

8 DEQ looked into the passage and modified it as  
 9 presented, and it is now -- now reads as the following:  
 10 "Hydraulic analysis that demonstrates how peak hour,  
 11 average day, maximum day, and maximum day plus fire flows,  
 12 if fire flows are available, will be improved by upsizing;  
 13 and"...

14 Okay. Our next comment takes us to Section 11.  
 15 We're starting Section 11 on page 20. Ms. Cahn had  
 16 recommended revising Section 11 by beginning with the  
 17 source and organizing the rest of the section out from the  
 18 source.

19 ACTING CHAIR CAHN: Keenan?

20 MR. HENDON: Yes, Lorie.

21 ACTING CHAIR CAHN: I'm just wondering --  
 22 I'm worried about the comments that I want to make on the  
 23 comment responses are going to get lost if we don't address  
 24 them as -- as chapter by chapter. I'm not sure how you  
 25 want to do this. If you want to go through everything and

1 then go over board discussion, or if you want us to address  
2 them as you get to them.

3 MS. ZYGMUNT: Yeah, Madam Chairwoman, so I  
4 recommend if you have questions, that you raise them as we  
5 go. And let me just clarify. Are you -- do you have  
6 questions about our response to comments or further  
7 questions about the rule itself?

8 ACTING CHAIR CAHN: Both. But the first --  
9 the first one would be on changes that were made, not in  
10 response to a comment.

11 MS. ZYGMUNT: Can you give me an example?  
12 I don't know that I'm quite following what feedback you'd  
13 like to provide.

14 ACTING CHAIR CAHN: So if we can back up to  
15 page 12-4, line 166, back in the definitions.

16 MS. ZYGMUNT: Okay.

17 ACTING CHAIR CAHN: Section 5, you added  
18 the definition of stabilized drawdown.

19 MS. ZYGMUNT: That is correct.

20 ACTING CHAIR CAHN: And I want to look at  
21 the construction of that. So if you look at line 170,  
22 excuse me, "...and plotted measurements that have not shown  
23 a trend of decreasing water level." And that follows "The  
24 water column is measured from pre-test static water  
25 level..." and it really belongs with the first sentence,



1 because it's talking about stable -- the water level not  
2 changing over at least a six-hour period of constant  
3 pumping flow rate. So I think after flow rate we can say  
4 "and plotted measurements have not shown a trend decreasing  
5 water level," because I think it's all good information,  
6 but it's in the wrong order.

7 MS. ZYGMUNT: Let me turn it back over to  
8 Keenan. I know Keenan mentioned this revision.

9 Keenan, can you remind the group again why we  
10 added this definition and where it came from.

11 MR. HENDON: This came from a pump test  
12 clarification request from I believe a commenter, Ben  
13 Jordan, wanting to know what stabilized drawdowns would be  
14 for a pump test to make sure that we were consistent across  
15 districts in our state. We revised the section per  
16 request, and then upon further evaluation, it was  
17 determined to include a new definition for stabilized  
18 drawdown.

19 With regards to Lorie's comment, we can move the  
20 plotted measurements to the first sentence.

21 MS. ZYGMUNT: Madam Chairwoman, can you  
22 read the revised definition as you're proposing?

23 ACTING CHAIR CAHN: Yeah. Stabilized  
24 drawdown means a water level that is not fluctuated by more  
25 than plus or minus 0.5 foot for each 100 feet of water in

1 the well over at least a six-hour period of constant  
2 pumping flow rate. And plotted measurements that have not  
3 shown a trend of decreasing water level. I know it's a  
4 long sentence, but...

5 And then the next sentence would be the water  
6 column is pressured from pre-test, and it would just stay  
7 the same as it is through pre-test static water level to  
8 the top of the deepest water-bearing fracture that  
9 contributes at least 10 percent of total well yield.

10 MS. ZYGMUNT: Okay. Thank you. We can  
11 make that revision.

12 ACTING CHAIR CAHN: Okay. Thank you.

13 MS. ZYGMUNT: Okay. Madam Chairwoman, I  
14 would like to turn it back over to Keenan, unless there  
15 were further comments you had on these sections that we  
16 have already reviewed the revisions for.

17 ACTING CHAIR CAHN: Okay. Just give me a  
18 second to cross-check here. I'm good.

19 And I would just ask the other board members if  
20 you have any comments, please feel free to ask to be  
21 recognized. Thank you.

22 MS. ZYGMUNT: Great. Thank you, Madam  
23 Chairwoman.

24 Keenan, turn it back to you.

25 MR. HENDON: Sure. So we were in Section

1 11. We'll just go ahead and start I think where we left  
2 off. We were looking at page 20 on Section 11. And  
3 Ms. Cahn had recommended revising Section 11 by beginning  
4 with the source and organizing the rest of the section out  
5 from the source.

6 DEQ has evaluated and researched the comment, and  
7 during drafting of the rule, district engineers laid out  
8 the content of Section 11 in the order of the events they  
9 thought were the most logical from an engineering  
10 standpoint.

11 Additionally, Section 11 also follows the order  
12 of events of the 10 States Standards. And at this time the  
13 order of items in Section 11 will remain unchanged.

14 Our next comment is located on Section 11(a),  
15 line 870 to line 904 on page 20. Ms. Cahn recommended  
16 removing the references to TSS 3.2.7 as all of these 3.2.7  
17 is not incorporated.

18 DEQ has removed 3.2.7 from 11(a).

19 Our next comment takes us to Tables 1 and 2 in  
20 Section 11. These start on page 23 at line 1033. Ms. Cahn  
21 and Mr. Cochran noted the setbacks in the table sections  
22 are inconsistent with the setbacks in the Water Quality  
23 Rules Chapter 25. Mr. Cochran recommended making the two  
24 chapters consistent or obtain agreements from landowners  
25 related to permit applications to ensure citing conflicts

1 do not occur.

2 DEQ has reviewed both the setback tables in  
3 Chapter 12 and 25 and has revised the setback distances for  
4 public water supply wells and septic tanks to 100 feet for  
5 consistency with Chapter 25.

6 Our next comment is located in Section 11(e)(i),  
7 line 1013 on page 23. Ms. Cahn notes there are several --  
8 there are lots of very small water systems, campgrounds,  
9 rest stops, little parks. Ms. Cahn wondered if there is a  
10 way of having some kind of de minimis that allow facilities  
11 that serve less than a certain number of households, people  
12 or size systems to have an exemption from some of the  
13 regulations. For instance, if a small system such as a  
14 campground, rest stop, little park, are required to have a  
15 second well or storage tank, they have to have twice as  
16 much the daily demand. Since these are seasonal, there can  
17 be water aging problems. Ms. Cahn is concerned that a  
18 one-size-fits-all doesn't seem to work and concerned about  
19 oversizing systems and making them too expensive.

20 Ms. Cahn also wondered if using the definition  
21 for small water systems would be a good starting point for  
22 assisting small public water systems.

23 Ms. Cahn also noted the current passage seems to  
24 indicate each well has to supply twice the maximum daily  
25 demand. The passage does not seem to make sense, alongside

1 the passage that follows that requires one well in storage.

2 DEQ response, after reviewing the comment, doing  
3 some research, looking into what other states provide, DEQ  
4 has revised the paragraph and has added a new passage at  
5 section (C). We think we've got a good solution that will  
6 target our full suite of public water systems we see in the  
7 state of Wyoming with this solution. And we've proposed to  
8 read the new passage. Proposed design shall include a  
9 minimum of: (A) Two wells that are each capable of  
10 supplying the maximum average daily demand with the largest  
11 producing well out of service; or (B) One well and  
12 finished water storage that together equal twice the  
13 maximum daily demand; or (C) for public water supplies that  
14 are not community water systems or noncommunity trans --  
15 nontransient water systems, as determined by the  
16 Administrator, one well that is capable of supplying the  
17 max daily demand.

18 ACTING CHAIR CAHN: Keenan, I appreciate  
19 the changes and appreciate you guys looking into this. I  
20 mean, it's very important changes.

21 I'm confused about the wording on line 1023 and  
22 1024. I don't understand the intent, because there's non  
23 and non and not all in the same sentence. So I get the  
24 first part, for public water supplies that are not  
25 community water systems, I get that. But the second part,

1 or noncommunity nontransient water systems, is that water  
2 supplies that are not noncommunity nontransient water  
3 systems?

4 MR. HENDON: Sure.

5 ACTING CHAIR CAHN: So there's too many  
6 "nots" and "nons" for me to understand it. So if you could  
7 explain it, and maybe we can reword it to make it more  
8 clear.

9 MR. HENDON: Sure. Essentially what our  
10 solution is kind of addition by subtraction method. The  
11 community water systems are defined by statute.  
12 Noncommunity nontransient water systems are also defined by  
13 statute. So both of those systems would qualify in (A) and  
14 (B).

15 We do not have a definition to fit a nontransient  
16 noncommunity system, which is what we're looking to find a  
17 solution for for our campgrounds and RVs, single gas  
18 station-type situations.

19 MS. ZYGMUNT: So, Madam Chairwoman, let me  
20 just add to that. So we are using established definitions  
21 in our statutes. And as Keenan indicated, we're using the  
22 two that are defined to -- by inference, to find the third,  
23 which is not defined in statute. And so it does a nice  
24 job, though, of explaining that if you're not a community  
25 water system, or if you're not one of these noncommunity

1 nontransient water systems as defined in statute then item  
 2 (C) would apply to you.

3           So it's a simple way of targeting that third  
 4 category, which is not defined in statute, but which are  
 5 the systems that you pointed out in your comment. So it  
 6 gets to what we're trying to do, which is to give that  
 7 flexibility for these small transient noncommunity systems,  
 8 but it's the most elegant, simple way we can do it right  
 9 now without having that third definition in our statutes.

10           ACTING CHAIR CAHN: Okay.

11           MS. ZYGMUNT: I know it's not the best  
 12 wording, but if you refer back to the definitions in our  
 13 statutes, it does -- it is clear.

14           ACTING CHAIR CAHN: Okay. So do we need to  
 15 add the word after "or," should we add "not" noncommunity  
 16 nontransient water systems and maybe give an example such  
 17 as?

18           MS. ZYGMUNT: I think we can add the word  
 19 "not" in after "or," but for the purposes of our rules, I  
 20 would not want to add an example. We could further clarify  
 21 some examples in guidance, as we work with people, but I  
 22 would hesitate to put examples into our rules.

23           ACTING CHAIR CAHN: Okay.

24           MS. ZYGMUNT: And, Keenan, I believe I  
 25 interrupted you.

1                   MR. HENDON: Yeah. I was just going to  
 2 echo Jennifer's comment, that we could address this in  
 3 "frequently asked questions" and perhaps write a waterfall  
 4 for an example in that situation.

5                   ACTING CHAIR CAHN: So I think I'm a little  
 6 bit confused about being not nontransient water systems.  
 7 So a lot of the -- I guess maybe I don't understand the  
 8 transient and nontransient. If you can explain that,  
 9 because I guess from -- well, go ahead and explain what  
 10 nontransient is.

11                   MS. ZYGMUNT: Maybe provide an example,  
 12 Keenan, if you can.

13                   MR. HENDON: Sure. So the community water  
 14 system definition means a public water supply that has at  
 15 least 15 service connections used year-round, year-round by  
 16 residents, or that regularly provide water to at least 25  
 17 residents year-round, including but not limited to  
 18 municipalities and water districts. A nontransient  
 19 noncommunity water system means a public water supply,  
 20 which is not a community water system and which regularly  
 21 provides service to at least 25 of the same persons for  
 22 more than six months of the year, where those persons are  
 23 not full-time residents, including but not limited to  
 24 schools, factories, and office buildings.

25                   So what we are saying is if you are not a



1 community water system or if you are not a nontransient  
2 noncommunity water system, then you can qualify -- which  
3 typically an RV, a campground, a single gas station,  
4 perhaps a single restaurant, would qualify in our section  
5 (C) --

6 ACTING CHAIR CAHN: Okay.

7 MR. HENDON: -- category, and it would  
8 provide that solution to them.

9 ACTING CHAIR CAHN: Okay. Great. Then I  
10 would suggest we add the word "or not," like we've  
11 discussed. But I would reverse noncommunity nontransient  
12 to be nontransient noncommunity, which is what you just  
13 read out of the statute.

14 MR. HENDON: Sure. We can do that too.

15 ACTING CHAIR CAHN: Okay. So I think, even  
16 though I had a hard time understanding the language --

17 MR. HENDON: Sure.

18 ACTING CHAIR CAHN: -- I think this  
19 addresses my concern that a campground that only has  
20 needs -- you know, has water supply well for six months or  
21 something and it's closed the rest of the year, they don't  
22 have -- they can get by with -- they can just supply the  
23 maximum daily demand.

24 MR. HENDON: Correct.

25 ACTING CHAIR CAHN: Okay. Great. Okay.

1 Thank you very much. I appreciate that.

2 MR. HENDON: Sure. We're quite pleased as  
3 well to find a solution to that one.

4 MS. ZYGMUNT: Do you want to talk briefly  
5 about what other states do? Okay. No?

6 MR. HENDON: No.

7 Section -- our next comment is on 11(e)(ii)(C).  
8 We are looking at page 24, line 1042. Ms. Cahn notes the  
9 paragraph requires compliance with Water Quality Rules  
10 Chapter 3, Section 17(b), but Chapter 3, Section 17(a)  
11 seems to exclude public water supplies from requirements of  
12 the section.

13 DEQ's response, we did discuss this at the March  
14 meeting and we set to confirm with our Attorney General's  
15 Office the requirements of this passage. And the passages  
16 of Chapter 3, Section 17(b) are the steps that will be  
17 required for the subsurface study. But the reference to  
18 this paragraph does not mean all of Chapter 3, Section 17  
19 would apply.

20 Our next comment is on page 24, 11(e)(iii)(C).  
21 It kind of ties back into our previous comments on  
22 setbacks, that Mr. Cochran noted the 10-foot setback is  
23 inconsistent with the other setbacks in the section, and it  
24 may be impractical for landowners and future landowners.

25 DEQ has reviewed the passage, did some research,

1 looked at what our surrounding regions eight states have  
2 done and have modified the passage to the following: Wells  
3 shall be located at least 50 feet from any property line.

4 Our next comment is located at 11(e)(v), line  
5 1091, page 25. Ms. Cahn noted that the new requirements  
6 for acidizing seemed to be regulating for an infrequent  
7 event or an event that has not happened yet. Ms. Cahn  
8 recalled that in the comment response DEQ had declined to  
9 make a revision due to a situation not happening in  
10 Wyoming. Ms. Cahn recommended striking the acidization  
11 requirements and doing a policy instead of -- instead for  
12 consistency with the comment response.

13 DEQ is unable to determine at which part or  
14 section Ms. Cahn was referring to with regards to the  
15 acidization. The WWAB had previously approved the proposed  
16 acidization passages of the October 17, 2019, meeting. As  
17 the requirements allow DEQ to collect information that is  
18 needed for DEQ to ensure acidization activities do not  
19 negatively impact underground sources of drinking water,  
20 DEQ will leave the acidization packages as part of the  
21 rule.

22 Our next comment is located on page 26, Section  
23 11(e)(vii)(C)(II). Ms. Cahn wondered if the TSS 3.2.6.5  
24 conflicts with line 1164, 11(e)(vii)(C)(I).

25 DEQ's reviewed the comment, TSS 3.2.6.5 covers

1 limestone or sandstone wells. However, the passage on line  
2 1164 falls under gravel packed or artificial packed wells.  
3 There is no conflict.

4           Additionally, with this review, as noted at the  
5 March 15, 2022, addendum to analysis of comments, DEQ will  
6 leave the casing requirements in at the 11(e) (vii) (C) (I)  
7 and (II) as written as the current requirements provides  
8 stability and cross-protection.

9           Additionally, on line 1172, page 26,  
10 11(e) (vii) (D), DEQ committed to revising the casing  
11 requirements for wells that encounter naturally flowing  
12 water for consistency with the state engineer's office for  
13 casing requirements, and that portion has been corrected.

14           Our next comment is with regards to  
15 11(e) (vii) (D) (I), page 27, line 1183. Ms. Cahn wondered if  
16 water is not flowing back into the well, why couldn't DEQ  
17 allow a below-ground vault or some additional way to keep  
18 the vault from freezing.

19           This section is in regards to discussing artesian  
20 wells. Buried well, discharge lines, or below-ground  
21 vaults with well discharge have demonstrated contamination  
22 when the below-grade discharge lines become submerged by  
23 groundwater. Freezing considerations have been addressed  
24 previously in the section. The paragraph has been revised  
25 to include the following:

1           For an overflow on an artesian well, the well  
2 discharge or overflow line, installations must connect to  
3 the well casing at least 12 inches above ground and be  
4 valved. The size of the air gap between the overflow line  
5 from the well to drainage structures shall be twice the  
6 diameter of the well overflow pipe. Overflow water must be  
7 drained and diverted to prevent ponding around the well  
8 casing.

9           This information is similar to what you would see  
10 for the state of Idaho or Utah.

11           Our next comment is located on page 27, Section  
12 11(e) (vii) (E) and 11(e) (vii) (E) (II). Ms. Cahn noted that  
13 for mineralized water, one of the commenters wanted 1,000  
14 per milliliter TDS. Ms. Cahn -- for TDS. Ms. Cahn  
15 explained that total dissolved solids and a secondary  
16 drinking water standard and EPA considers anything over  
17 1,000 unfit for human consumption. Ms. Cahn recommended  
18 that DEQ revise the language referring to 40 CFR 141,  
19 drinking water standards, as this reference contains both  
20 secondary and primary standards. Ms. Cahn recommended  
21 rewording the reference to only refer to primary drinking  
22 water standards and to remove the implication that  
23 applicants be required to treat mineralized water.

24           DEQ has looked into the comment. The intent  
25 behind the passage at Section 11(e) (vii) (E) (II) is to

1 ensure that if the applicant proposes to use water that  
2 meets the definition of mineralized, then the proposed  
3 design will produce water that complies with the applicable  
4 standards in Part 141 of the CFR.

5           The mineralized water is a trigger that will  
6 require DEQ to review any treatment design options EPA  
7 might require to be installed and operated so that the  
8 resulting water system meets the drinking water standards  
9 that EPA will enforce. The passage does not require  
10 systems to comply with specific primary or secondary  
11 standards, which falls under the authority of EPA.

12           DEQ has clarified the passage as follows:  
13 Applicants that propose to use mineralized water as a  
14 public water supply shall demonstrate that any necessary  
15 treatment will comply with the drinking water quality  
16 standards required by 40 CFR 141.

17           ACTING CHAIR CAHN: Thank you for that  
18 clarification. And I'll also clarify that I misspoke in  
19 that comment, because 141 just has the primary drinking  
20 water standards, and my concern was about the secondary in  
21 there in 143. So thank you for your changes.

22           MR. HENDON: Sure. Okay. Our next comment  
23 is located on 11(e)(viii), page 27, line 1215. Ms. Cahn  
24 recommended clarifying the passage to indicate diameter and  
25 recommends removing extra "shall" or "shalls." Ms. Cahn

1 also recommended incorporating all 3.2.4 and removing all  
2 of (e)(viii) and (ix) per Mr. Jordan's comment.

3 DEQ has reviewed the 2018 TSS Part 3.2.4 against  
4 11(e)(viii) and (ix). Part 3.2.4 will be added to 11(a)  
5 with the subparts stricken from the paragraph. And  
6 11(e)(vii) and (ix) will be stricken as well. With  
7 removing of these parts, it makes the concerns with regard  
8 to diameter and the use of "shall" obsolete.

9 DEQ has reviewed all formal public comments that  
10 we have received including those from Mr. Jordan. We did  
11 not receive a specific request to incorporate the 2018 TSS  
12 3.2.4 prior to the recommendation being made at the  
13 March 15, 2022, meeting. Just as a reminder, in order for  
14 DEQ to adhere to rulemaking procedures, all public comments  
15 must be received by DEQ according to the instructions  
16 provided in each public notice or the public may read  
17 comments into the record during the meetings when public  
18 comments are being accepted. Executive order number  
19 1981-12 outlines actions to take should the board members  
20 receive additional comments directly from interested  
21 parties.

22 ACTING CHAIR CAHN: I would just like to  
23 clarify the comment that I made. Because Mr. Jordan  
24 made -- I had notice in the margin of my document and I  
25 had -- that Mr. Jordan had made comments on section

1 (viii) -- (viii) and (ix), and then I also had my own  
2 comment about removing -- or incorporating 3.2.4. And so  
3 in response to Mr. Jordan's comment that he made in the --  
4 on the record, I had scribbled some notes of my own about  
5 how we could resolve his comment and also incorporate. So  
6 I think in the end everything has ended up the way it  
7 should be. We're in agreement.

8 I apologize for any confusion on the way I might  
9 have worded it, because when I had notes, it sometimes it  
10 was hard to tell -- so --

11 MR. HENDON: Sounds good.

12 ACTING CHAIR CAHN: -- what was my note and  
13 what was Mr. Jordan's comments. So they got muddled, I  
14 think, in this response. So I just wanted to clarify there  
15 were two different things, and the resolution that you have  
16 proposed works for me, and I would assume that you've  
17 talked to Mr. Jordan and it probably works for him. But  
18 anyways, thank you.

19 MR. HENDON: Thank you. Thank you, Lorie,  
20 for the additional information.

21 Moving on to our next comment. We're located in  
22 Section 11(e)(x), line 1282, page 29. This used to be  
23 11(e)(xii). And Ms. Cahn had noted the response to comment  
24 document indicates DEQ would revise this statement, but the  
25 revision is not incorporated into the draft chapter.



1           DEQ did look into the passage, and it is the  
2 language proposed in response to comments document.

3           ACTING CHAIR CAHN: So where -- so where is  
4 the green --

5           MR. HENDON: Unfortunately, we do have a  
6 couple of glitches with regard to green versus not green  
7 within the greenline version. And, again, we apologize for  
8 that.

9           MS. ZYGMUNT: Keenan, can you remind what  
10 the wording change was there.

11          MS. THOMPSON: There was an apron in here.

12          MR. HENDON: The original comment from the  
13 commenter had concerns about a concrete apron being placed.  
14 There's probably debate in the engineering community as to  
15 whether to use the word "apron" or not use the word  
16 "apron," so we use the terminology "concrete floor."

17          MS. ZYGMUNT: Madam Chairwoman, does that  
18 help answer your question?

19          ACTING CHAIR CAHN: I'm lost on what line  
20 we're on now.

21          MR. HENDON: 1282.

22          ACTING CHAIR CAHN: Excuse me.

23          MR. HENDON: We're on line 1282. I believe  
24 Gina has it up on the presentation screen.

25          ACTING CHAIR CAHN: Okay. Thank you.

1                   MR. HENDON: Okay. Our next comment is  
2 located on page 29, Section 11(e)(xvi), line 1304. And  
3 Ms. Cahn wondered why the passage requires each well to  
4 measure total discharge from the whole field and why the  
5 applicant couldn't just add the additional well information  
6 together. And Mr. Cochran also noted the chapter requires  
7 -- already requires a meter.

8                   And DEQ has looked into the request and the  
9 passage and modified it as follows. An instantaneous  
10 totalizing flow meter equipped with nonvolatile memory  
11 shall be installed on the discharge line of each well in  
12 accordance with the manufacturer's specifications. Meters  
13 installed on systems with variable frequency drives shall  
14 be capable of accurately reading full range of flow rates.

15                   With this revision we also revised 11(e)(xiv) to  
16 the following: An accessible check valve, which is not  
17 located in the pump column, shall be installed in the  
18 discharge line of each well between the pump and shutoff  
19 valve. Additional check valves shall be located in the  
20 pump column as necessary to prevent negative pressures on  
21 the discharge piping.

22                   Our next comment is located on page 30, Section  
23 11(f)(v)(B). Ms. Cahn had noted the response to comment  
24 document indicates DEQ would revise the statement, but the  
25 revision did not get incorporated into the draft chapter.

1           DEQ reviewed the passage and proposed in response  
2 to comments and revised the chapters as follows: Made of  
3 concrete or other material that meets the requirement of  
4 Section 15(b)(ii) of this chapter. And this is in regards  
5 to spring walls.

6           And it's a nice tie-in to our next comment. On  
7 11(f)(xiii) page 31, line 1396. Ms. Cahn noted the  
8 reference to Section 14 is incorrect, and the correct  
9 reference is Section 15. This reference has been  
10 corrected. Ms. Cahn also wondered if springs need to be  
11 subject to all the requirements in Section 15 if they're  
12 not providing fire water.

13           DEQ looked into it, and we've revised the passage  
14 as follows: Spring box design shall comply with Section 15  
15 (a), (b), (f) through (j) and (l) of this chapter.  
16 Combined spring box and finished water storage design shall  
17 comply with Section 15 of this chapter.

18           So we think that --

19           ACTING CHAIR CAHN: So --

20           MR. HENDON: -- that provides a good  
21 off-ramp between the two.

22           ACTING CHAIR CAHN: So, Keenan, does that  
23 mean that if they're not -- I mean, the word "not providing  
24 fire water" is not included. So can you explain to me --  
25 there's --

1                   MR. HENDON: Yeah, I think -- if I recall  
2 correctly, in our discussion back in March, you had  
3 concerns that if -- if we reference a spring box to the  
4 full requirements of Section 15, which was finished water  
5 storage, that they would have to meet all those  
6 requirements with regards to water age, tank turnover,  
7 mixing, as well as their additional fire storage that they  
8 might provide. And so what we've done is excluded -- if  
9 it's just a small -- small spring box to collect the water  
10 that then gets dispersed to a storage tank at a later  
11 destination, then that storage tank at a later destination  
12 would have to meet Section 15.

13                   ACTING CHAIR CAHN: Can you be a little  
14 more specific with regards to fire water?

15                   MR. HENDON: Sure.

16                   ACTING CHAIR CAHN: I'm not following,  
17 so...

18                   MR. HENDON: Sure. So, again, a spring box  
19 needs to comply with Sections 15(a), (b), (f) through (j)  
20 and (l). Your question and concern is with regards to  
21 section (c), storage facility design shall demonstrate.  
22 And in that section is when fire water is required for the  
23 storage tank under Section 15. So, again, 15(c) does not  
24 apply to a spring box.

25                   ACTING CHAIR CAHN: Okay. Thank you.

1 MR. HENDON: With regards to -- okay.

2 ACTING CHAIR CAHN: Go ahead. Finish your  
3 thought.

4 MR. HENDON: It came and went as fast as --

5 MS. ZYGMUNT: Madam Chairwoman, does that  
6 explanation answer your question?

7 ACTING CHAIR CAHN: Yes.

8 MS. ZYGMUNT: Okay. Great. Thank you.

9 MR. HENDON: We're into Section 12 now,  
10 we're looking at 12(a), page 32, line 1406. Ms. Cahn notes  
11 the incorporated material is listed out of order, and that  
12 "through" is inconsistently used, which leads to confusion  
13 as to what applies.

14 DEQ reviewed the incorporations of TSS 2018 and  
15 corrected the necessary parts of the passage as discussed.

16 Our next comment is --

17 ACTING CHAIR CAHN: Oh, excuse me. I have  
18 a lot of comments on section (a). I would suggest we take  
19 a five-minute break. It's basically -- come back at 20  
20 after, and we can go over my comments on section (a),  
21 12(a). Thank you.

22 MR. HENDON: Okay.

23 ACTING CHAIR CAHN: So we're --

24 (Special meeting proceedings recessed  
25 10:14 a.m. to 10:23 a.m.)

1 MS. ZYGMUNT: Madam Chairwoman, are you  
2 ready to get going?

3 ACTING CHAIR CAHN: Yes. Let's reconvene.

4 MS. ZYGMUNT: So, Madam Chairwoman, it  
5 sounded like you had further feedback on 12(a). Let's go  
6 ahead and take any further comments there.

7 ACTING CHAIR CAHN: That's correct.

8 MS. ZYGMUNT: Okay.

9 ACTING CHAIR CAHN: Again, there is out of  
10 order things on here. So, for instance, 4.4.1 comes after  
11 4.4.3, and 4.3.4.2 on line 1408, 4.3.4.4, et cetera, that  
12 comes before 4.3.1.1. So things are -- for one, things are  
13 out of order, and I think that makes it very confusing for  
14 anybody who is trying to go back and forth between what's  
15 in the rule and what's in the 10 States Standards.

16 So first of all, it's out of order. Second --  
17 let's take individual things. So -- so first of all, did  
18 you follow the out of order? So on line 1408, 4.3.4.2  
19 number through 4.3.4.9(b)(e)(f), the design of sand  
20 filters, that's in the wrong place.

21 MR. HENDON: So noted.

22 ACTING CHAIR CAHN: Also on line 1415,  
23 4.4.1(a), (b), contact time, CT, and points of application,  
24 those are also out of order, so...

25 MS. ZYGMUNT: Yes, Madam Chairwoman. Good

1 comment. We will review this entire section and make sure  
2 things are in order.

3 ACTING CHAIR CAHN: Okay. The next  
4 issue -- I'm going have to flip -- okay. It's 4.4,  
5 disinfection on line 1414, it's still confusing to me as to  
6 what's included. And so if we flip back to the 10 States  
7 Standards to 4.4.4 -- sorry, 4.4, disinfection is on  
8 line -- page 62.

9 Maybe, Gina, you can pull that up. It's page 62.

10 MS. THOMPSON: Uh-huh. Right there.

11 ACTING CHAIR CAHN: Okay. So by including  
12 4.4, disinfection, it's unclear -- to me that would mean  
13 all of Section 4.4, disinfection. But you don't intend to  
14 include 4.4.2, and so -- and then it kind of picks and  
15 chooses 4.4.1 is in there in a different section, 4.4.3(a)  
16 and (d) are in there, and 4.4.4.3 is in there. So I think  
17 it's really ambiguous, because -- maybe you need to specify  
18 4.4 only par -- first two paragraphs, or something, because  
19 4.4, disinfection, is the entire Section 4.4. It's all  
20 about disinfection. But that's not your intent.

21 MS. ZYGMUNT: Yeah.

22 ACTING CHAIR CAHN: You've excluded  
23 sections.

24 MS. ZYGMUNT: Yeah. Good comment. I think  
25 we're considering here.

1                   Keenan, do you have any thoughts?

2                   MR. HENDON: Yeah we can review the 4.4 to  
3 include -- I can check with Gina to check with the AG's  
4 folks to see what we can do to just capture the first two  
5 paragraphs so that we're clear we're not capturing the  
6 entire section. And then we can clarify 4.4.3 to identify  
7 that we're just capturing (a), (b) and (d).

8                   ACTING CHAIR CAHN: Yeah, which I think --  
9 yeah. And then it goes on, because you've got automatic  
10 switch-over and cross-connection, protection, pipe  
11 material, chloramines.

12                   MR. HENDON: Yeah. So we have specific  
13 components that we've selected out of that section.

14                   ACTING CHAIR CAHN: Yeah.

15                   MR. HENDON: So we can -- we'll work to  
16 find the solution to make it clear that we're just  
17 targeting the first two paragraphs of 4.4.

18                   ACTING CHAIR CAHN: Okay. All right. And  
19 then the next question I have is on 4.5.2.19. So it's on  
20 line 1418. Let's see. 4 -- 4.5.2.19. 4 -- okay.  
21 4.5.2.19 is on page 78, Gina. Okay. And the title that  
22 you have is 4.5.2.19, and then on the next line it says  
23 "softening," but softening is not part of the title for  
24 construction materials and housing. So if you look back at  
25 line 417 -- no, sorry -- 1419, it has a list, 4.5.2.13(a)



1 through (f), which has to do with brine and salt storage  
2 tanks. And then 4.5.2.14, which is salt and brine storage  
3 capacity. And then --

4 MR. HENDON: Yep. It looks as though we  
5 need to include the named descriptions for each of these.

6 ACTING CHAIR CAHN: Okay. And then when  
7 you look at 4.1 -- so 4.6, line 1419, starting with 4.6,  
8 through 4.6.14, anion exchange treatment. In that case,  
9 all of 4.6 is included? I don't see anything that's  
10 omitted. So I think we could delete the through 4.6.14,  
11 because it just -- we're including all the 4.6, anion  
12 exchange treatment.

13 MR. HENDON: So noted.

14 MS. ZYGMUNT: We can make that correction.

15 ACTING CHAIR CAHN: And then 9.5, this is  
16 now on line 1425, on "red water" waste. Again, it's  
17 confusing to say you're going 9.5 to 9.5.3, because you're  
18 not including all of 9.5. You're excluding everything  
19 after 9.5.3.

20 MR. HENDON: So we can -- so we can address  
21 that to do what we've done with the previous sections and  
22 just address 9.5, 9.5.1, 9.5.2 and 9.5.3.

23 ACTING CHAIR CAHN: Yeah. So I have more  
24 comments in other places. Maybe when we get through all  
25 the comments we can then go through the situations like

1 that in the TSS. So, okay, that's it for Section 12(a) for  
2 me.

3 MR. HENDON: Okay. We are back in Section  
4 12. We are looking at comment from Brian Deurloo located  
5 on page 36, line 1587, located in Section 12(k)(ii)(G)(II).  
6 Mr. Deurloo recommends revising the passage from identical  
7 to equivalent.

8 DEQ has revised the passage as requested.

9 MS. THOMPSON: I will note on the record  
10 that it looks like the formatting mark got missed. I  
11 believe my helpful Word Wizard didn't help -- it didn't  
12 catch everything to point out changes, so...

13 MR. HENDON: Unfortunately, it's not green.

14 MS. THOMPSON: But it is "equivalent."

15 ACTING CHAIR CAHN: What line number is  
16 that?

17 MR. HENDON: 1587, page 36.

18 Moving on to the next comment we are looking --  
19 the original comment and reference was Section 12(j)(i)(C).  
20 It is now located in Section 12(l)(i)(D)(II), page 39, line  
21 1734. Ms. Cahn recommended revising the passage to the  
22 maximum fee point back pressure shall not exceed 100 psi  
23 unless the chlorine solution pump is used.

24 The DEQ has revised the passage as requested.

25 Our next comment is located on page 44, line

1 1978, Section 12(n). Ms. Cahn notes the term hydrofluo --  
2 hydrofluosilic acid is misspelled and should be  
3 hydrofluorosilicic.

4 DEQ's corrected the term as recommended.

5 Page -- our next comment is located at page  
6 12(o)(i), line 2052, page 46. Ms. Cahn notes the term  
7 absorb is used in the passage, but granulated activated  
8 carbon adsorbs.

9 The DEQ has corrected the passage as suggested.

10 Our next comment is located at Section 12(q)(i)  
11 and (ii). Ms. Cahn's requested the incorporated manual  
12 include the phrase "US EPA."

13 DEQ's revised the references as requested.

14 Our next comment is located at Section 12(r),  
15 page 48, line 2139. Ms. Cahn recommended removing  
16 redundancy in paragraph (r) and (r)(i).

17 DEQ has combined the passages and renumbered the  
18 section as recommended.

19 Our next --

20 ACTING CHAIR CAHN: Again -- again we're  
21 not seeing the red line -- the green.

22 MS. THOMPSON: Right. So I'm going to pull  
23 up the previous one and I'll read to you what it says. I  
24 used a wizard in Microsoft Word that was supposed to show  
25 me changes, and it didn't do it as consistently as I would

1 have hoped. So that I could make those formatting marks in  
2 this version.

3 MR. HENDON: Dang wizards.

4 MS. THOMPSON: Okay. So previously the  
5 paragraph led in with bag and cartridge filters shall  
6 comply with the following requirements: Paragraph (i),  
7 facilities that propose bag or cartridge filters shall  
8 comply with the procedures identified in Section 6 of this  
9 chapter.

10 And then (A), filter performance will be based on  
11 cryptosporidium oocyst removal. So we took out the  
12 additional language -- we took out bag and cartridge  
13 filters shall comply with the following requirements. Here  
14 at P, and then renumbering this based on other renumbering  
15 that needed to happen in the section.

16 MS. ZYGMUNT: Madam Chairwoman, does that  
17 address your comment?

18 ACTING CHAIR CAHN: Yeah. It's just been  
19 confusing not having the green so --

20 MS. ZYGMUNT: Understood. And I will just  
21 reiterate that Gina has to manage three different versions.  
22 Obviously sometimes we do miss some of the formatting  
23 changes. We do our very best to not do that, and we will  
24 continue to do so moving forward. So we apologize for the  
25 confusion today, but again, the main take-home message for

1 your comment there is we made the proposed edits, took out  
2 the redundancy and streamlined that passage, but did not  
3 change any of the meaning.

4 ACTING CHAIR CAHN: Yeah. Thank you.

5 MS. ZYGMUNT: Sure.

6 MR. HENDON: Our next comment is located at  
7 12(r)(xii), line 2176 on page 49. Ms. Cahn noted that the  
8 response to comment document indicates DEQ would revise the  
9 statement, but the revision is not incorporated into the  
10 draft of the chapter.

11 DEQ has corrected the passage to include the  
12 language proposed in the response to comments. The missing  
13 language was the following: Or shall demonstrate that  
14 combined filtration and disinfection will provide 3-log  
15 removal.

16 Our next -- our next comment is located at  
17 Section 12(t)(i), line 2202, page 49. Ms. Cahn notes the  
18 phrase simple well system is used in the passage, and  
19 wonders where is the definition of this term and what the  
20 requirements would be for a nonsimple well system.

21 When the chapter was being proposed, Chapter 12,  
22 at one time there was a -- two types of well systems I  
23 think had been identified. One was for a -- what was the  
24 word --

25 MS. THOMPSON: Complex.

1                   MR. HENDON: -- complex well. We had a  
2 complex well and a simple well. Based on the revisions,  
3 complex well was removed, which left simple well. This  
4 cleans it up. We are removing the word "simple." And it  
5 will now just read "well system." Please note that the  
6 document you have does not reflect the change in removal of  
7 the word "simple," but we will have that corrected.

8                   Our next comment is located in Section 13. We're  
9 looking at Section 13(a), line 2271, page 51. Ms. Cahn had  
10 identified that "are herein incorporated by reference" was  
11 used repeatedly in the passage and recommended striking  
12 unnecessary uses.

13                   DEQ has gone through and revised the passage as  
14 requested.

15                   ACTING CHAIR CAHN: Again, I'm not seeing  
16 green.

17                   MS. THOMPSON: So at line -- at the  
18 reference to 5.4.1(d) (7 through 10), 5.4.1(f) and (h), we  
19 used "are herein incorporated by reference" after every  
20 reference at the end of that paragraph. So we've stricken  
21 those. And so we only have it once now. It used to appear  
22 multiple times, but now we only have it here.

23                   ACTING CHAIR CAHN: Okay. Thanks.

24                   MR. HENDON: So it's now a capstone at the  
25 end of the section.

1           Our next comment is with regard to Section 14.  
2 We're looking at Section 14(g) (iv), line 2346, on page 52.  
3 Ms. Cahn noted the passage seems unnecessarily prescriptive  
4 and does not seem necessary.

5           DEQ would like to note the passage has been in  
6 the rule since 1985 and is part of common engineering  
7 design practices to determine head loss in a system. DEQ  
8 has not received comments or feedback from applicants or  
9 engineers that would indicate the passage is unnecessary or  
10 burdensome.

11           DEQ uses the submitted information to verify the  
12 proposed design will meet the requirements of paragraphs  
13 (g) (i) to (iii), to ensure the overall design will meet the  
14 intent of the Environmental Quality Act to ensure that we  
15 have adequate pressures within our water system. We intend  
16 to leave the passage as written.

17           Our next comment is located with -- in Section  
18 14. It's located at (i) (ii), line 2390, 3553. Ms. Cahn  
19 has noted the revision does not clarify the requirement.

20           This was a response to an initial request at the  
21 December meeting. DEQ has reviewed and re-reviewed the  
22 section, done some additional research, determined the  
23 section will revert to the original language which includes  
24 the term "manifolded." The original term and language is  
25 common in the industry. It's language used also by

1 numerous surrounding Region 8 and 9 states. And we intend  
2 to restore the paragraph to the following: Each pump shall  
3 either have an individual suction line or the suction lines  
4 shall be manifolded such they demonstrate similar hydraulic  
5 operating conditions.

6 Our next comment is in Section 15. This is a  
7 comment from Mark Pepper with WARWS. It's located in  
8 Section 15(a), line 2398, page 54. Mr. Pepper noted that  
9 the 2018 TSS Part 7.0.6, water storage age, was omitted.  
10 We know that with many upcoming regulations (lead and  
11 copper revision, disinfection byproducts review), water age  
12 is paramount. The TSS 2018 recommends no longer than five  
13 days on water storage. We believe this to be in agreement  
14 with AWWA recommendations.

15 DEQ has considered the comment. Water age is  
16 included in Chapter 12, in Sections 15(c) and 15 (e). The  
17 draft chapter does not address a maximum day exceedance for  
18 water storage. Based on further review and research, DEQ  
19 will include the 2018 TSS Part 7.0.6 in Section 15(a) in  
20 Chapter 12.

21 Section 16 is our next comment. This is a  
22 comment, again, from Mark Pepper. Mark Pepper -- the  
23 comment is in request to Section 16(a), line 2529 to 30,  
24 page 56. Mr. Pepper had noted the 2018 TSS Part 8.7.9,  
25 separation from other utilities, was omitted. Again while



1 you assume design engineers would consider maintenance of  
2 distribution pipes and ability to be important, sometimes  
3 that's not the case.

4 DEQ considered the comment and will revise  
5 Section 16(a) to include 2018 TSS 8.7.8 and 8.7.9 for  
6 clarity on aggressive soil provision and ideal utilities  
7 separation distances.

8 Our next comment is located in the Section 16,  
9 16(a), page 56, line 2597 on page 58. Comment is from  
10 Mr. Pepper. Mr. Pepper noted the 2018 TSS Part 8.7.2,  
11 bedding was omitted. It's important to protect the  
12 investments of the State and the system by ensuring quality  
13 bedding material is used, and this isn't the case on some  
14 projects.

15 DEQ's considered the comment. We agree pipe  
16 bedding requirements are important, and they are provided  
17 in Chapter 12, Section 16(i), which describes that  
18 distribution system bedding shall be in accordance with  
19 ASTM C12 Classes A, B, C for rigid pipe. And flexible pipe  
20 bedding shall be designed in accordance with ASTM D2321  
21 Class I, II, or III.

22 We are to our next comment. It is comment 16(g).  
23 Ms. Cahn noted that DEQ's response to the public comment on  
24 the passage is insufficient. Ms. Cahn notes that manholes  
25 are difficult to keep water out -- coatings leak,

1 fiberglass can flood, flooding can cause rust/ difficult to  
2 use safety issues. Ms. Cahn asked DEQ to look at valve  
3 boxes and the wording on "chambers" to clarify these are  
4 synonymous.

5           So I think this is -- this is kind of a -- I  
6 think there's multiple parts to this comment and question.  
7 16(g) was in relation to air relief valves and automatic  
8 air relief valves. We have incorporated the TSS 2018 8.5,  
9 which would remove Section 16(g). However, chambers,  
10 vaults, and manholes would not be synonymous with a valve  
11 box. And for an automatic air relief valve, that would  
12 need to be installed in a chamber vault or manhole for  
13 maintenance, access, and operations of that automatic air  
14 relief valve.

15           For a valve, I think the second part of this  
16 question was in relation to a river crossing that was  
17 proposed by one of the commenters. And, again, this part  
18 is covered in the 10 States Standards under Section 8.9.2  
19 underwater crossings. And with regards to underwater  
20 crossing, we would require valves on either side. And  
21 valves should be easily accessible and not subject to  
22 flooding. So they could be placed in a chamber, vault,  
23 manhole or valve box or other provided solution.

24           And with that, that takes us through the comments  
25 that we had received from the WWAB board members at the

1 March 15th board meeting. That also includes the comments  
2 we had received from public comment through Mark Pepper  
3 with WARWS.

4 And with that, I'll turn it back over to  
5 Jennifer.

6 ACTING CHAIR CAHN: Excuse me. I want to  
7 go back to that last comment.

8 MR. HENDON: Sure.

9 ACTING CHAIR CAHN: It says that 16 --  
10 16(g) has been struck. But I don't -- can we go to page  
11 12-58.

12 MS. THOMPSON: Yeah. Let me read in what  
13 was stricken and didn't appear in my review. So what had  
14 previously been in there was a passage numbered as (g) that  
15 stated manholes or chambers for automatic air relief valves  
16 shall be designed to prevent submerging the valve with  
17 groundwater or surface water. And so we have stricken that  
18 because it is redundant with 8.5 in the 10 States Standards  
19 which covers air relief valves.

20 ACTING CHAIR CAHN: So that -- the big red  
21 line -- the green line/strikeout should have been included.

22 MS. THOMPSON: It should have appeared  
23 there when I looked for it, but it didn't, yes.

24 MR. HENDON: We forgot to send you guys the  
25 invisible ink to make it show back up.

1 MS. THOMPSON: Right.

2 ACTING CHAIR CAHN: Yeah. Okay.

3 MS. ZYGMUNT: So, again, Madam Chairwoman,  
4 members of the Board, that does conclude our presentation  
5 to review the revisions that we have made since March 15th.  
6 If there are no further questions -- well, let me first  
7 ask. Are there any further questions about the revisions  
8 we have made or further discussion you'd like to have?

9 ACTING CHAIR CAHN: I probably have some  
10 questions on the TSS. What's included, what's not, and  
11 why. So you'll have to bear with me.

12 MS. ZYGMUNT: Does that go back to 12(a)?

13 ACTING CHAIR CAHN: No. It's probably --  
14 I'm starting at the beginning of the TSS. So the first  
15 section that we incorporate is the engineer's report,  
16 1.1.1. And the part that precedes that, if you -- under  
17 1.1 says where pertinent presents the following  
18 information. And I think we need to include that  
19 "where pertinent." So if you look at the TSS, page 2.

20 MS. ZYGMUNT: Madam Chairman, can you  
21 repeat the comment? I'm not understanding what your  
22 suggestion is.

23 ACTING CHAIR CAHN: Okay. I think it would  
24 be clear -- so the section -- the engineering design report  
25 in the TSS has an introductory paragraph that says the

1 engineer's report for waterworks improvements shall, where  
2 pertinent, present the following information. And then it  
3 starts out with 1.1.1. And we -- so do you see that above  
4 it, the -- the four -- the line right above -- the second  
5 line?

6 MS. ZYGMUNT: Yes.

7 ACTING CHAIR CAHN: And it says "...where  
8 pertinent, present the following information." And what  
9 we're doing is starting to incorporate in the engineer's  
10 report starting at 1.1.1, and we're missing the "where  
11 pertinent." So I think that that's a really important part  
12 of the engineering design report. That's a lot of the  
13 problems I have with the engineering design report, is  
14 things are not always pertinent that are -- and so I think  
15 we're miss -- I think that needs to be included somehow.

16 MS. ZYGMUNT: Yeah. Yes, Madam Chairwoman,  
17 understanding your comment, I think I would disagree and  
18 push back in that we have already reviewed the sections of  
19 the 10 States Standards that we feel are applicable to the  
20 engineering design reports that we need. And I know we've  
21 discussed specific aspects of those reports that are  
22 applicable. And I think I would disagree -- and I'm going  
23 to ask Keenan to speak up next -- that we need to further  
24 clarify by adding language "where pertinent." I think we  
25 have already incorporated the sections that we feel are

1 needed for the engineering design report.

2 MR. HENDON: I think -- if we include the  
3 word "pertinent," we open ourselves up to go down a rabbit  
4 hole to argue with our engineers or the applicants as far  
5 as what is and what isn't pertinent. So we are requesting  
6 the information we want to receive in order to review their  
7 permit application so that we can ensure that they are  
8 complying with the necessary parts of the DEQ regulations,  
9 as well as meeting the drinking water quality requirements.

10 ACTING CHAIR CAHN: Okay. So then if we go  
11 down to 1.1.7, sources of water supply, that two little  
12 lines is not included, and so to me I don't understand why  
13 we're parsing out -- it just says describe the proposed  
14 sources or sources of water supply to be developed, the  
15 reason for their selection, and provide information as  
16 follows. And I don't understand why a little two sent --  
17 you know, sentence like that is parsed -- is cut out.

18 MS. ZYGMUNT: Again, Madam Chairwoman, we  
19 are incorporating by reference specific sections of the 10  
20 States Standards. We're not taking the whole manual. So  
21 again, in our review and development of this chapter, we  
22 have already vetted what sections we feel we need to pull  
23 into our rule to be regulatory requirements for our  
24 design and construction standards. I am a bit concerned  
25 about going through the whole 10 States Standards -- and

1 I appreciate your comments and I appreciate your  
2 perspective -- but, again, I think we've already vetted  
3 what we are and are not including through what we have  
4 pulled into our rule and what we've already reviewed under  
5 the past two meetings.

6 MR. HENDON: And in addition to kind of  
7 support that, the district engineers have gone through this  
8 document. We've had over 20 meetings with regard to the  
9 10 States Standards, the incorporation by reference,  
10 revisions to Chapter 12. So we've taken into consideration  
11 their comments, direction and insight.

12 Your comment with regards to 1.1.7, sources of  
13 water, we do address those specifically in the chapter, for  
14 source water sources, groundwater sources, and so forth.

15 MS. ZYGMUNT: So let me just interject  
16 here, Madam Chairwoman. We are at 11:00, which is the end  
17 of the time I had allotted for this special meeting.  
18 Again, recognizing that it sounds like you have further  
19 thoughts on the 10 States Standards, again, I'll just make  
20 the general comment that I feel we have already reviewed  
21 the specific sections that are appropriate to include or  
22 not include.

23 In the interest of time and making good use of  
24 everybody's time today, I would ask if we can, rather than  
25 going item by item through the 10 States Standards, are

1 there broader questions -- or comments that you can provide  
2 to us to consider for future rule packages in terms of how  
3 we incorporate by reference? We'd be happy to hear that  
4 feedback. But I've not incorporated time into the meeting  
5 today to go through the 10 States Standards in detail.

6           However, I would be interested in hearing from  
7 board members how you would like to proceed. I think as  
8 you're probably aware, I am looking for a recommendation  
9 from the Board, your advice to move forward with formal  
10 ruling making before the close of the meeting today. Or if  
11 that is not the advice the Board, I would like to know what  
12 your advice is so we can take that into consideration with  
13 the director and decide how we would like to proceed  
14 forward.

15           So since we're at the end of the allotted time  
16 for the meeting today, I would like to get, Madam  
17 Chairwoman, your thoughts how to proceed forward, along  
18 with feedback from the other board members.

19           ACTING CHAIR CAHN: Okay. Does any board  
20 member want to say something before I do?

21           BOARD MEMBER DEURLOO: No. I'll wait to  
22 hear your comments, Madam Chairwoman.

23           ACTING CHAIR CAHN: Okay. I still have  
24 some comments that I think are important regarding the 10  
25 States Standards, and we obviously don't have enough time



1 allotted for it. I did -- I have some concerns right off  
2 the bat about this meeting. And I'll say that according to  
3 the -- let me just grab my sources here. According to the  
4 Public Meetings Act that the boards are required to comply  
5 by, and does not -- that doesn't apply to directors and  
6 administrators. Special meetings are called by the  
7 presiding officer of the Board of the -- and so I'm a  
8 little bit concerned about a couple of things. One is the  
9 fact that this meeting was not called by the Board, and it  
10 was called by DEQ. So I'm a little bit concerned about  
11 some of the things that we do today being null and void.  
12 So that -- I'll just say that.

13 I have some concerns about not incorporating  
14 enough time to discuss comments, when I did let DEQ know in  
15 email that -- I had Brian's email, and I asked DEQ to  
16 please forward it on to the -- to Jim Cochran and Brian  
17 Dickson. And I don't know if that was actually forwarded  
18 to them.

19 That said, that I did have some concerns that we  
20 hadn't gone over in the other meeting. So I'm just -- I  
21 also mentioned in that email that I was going to be out of  
22 cell phone range and internet range for quite a long time  
23 before the meeting. So I have just seen this stuff  
24 basically late last night, and at 5:30 this morning.

25 So I'm also -- I have a lot of concerns. I have

1 another concern about the fact that in the email that I  
2 sent out, I mentioned that I was not going to be  
3 available -- you guys -- I was presented with two weeks of  
4 which we could have this meeting, and of those two weeks,  
5 up until yesterday, the whole first week and up until  
6 yesterday, I was not available and I said I was not  
7 available, and yet, even though this meeting's supposed to  
8 be called by the chair of the meeting, the Doodle poll went  
9 out asking everybody if they could meet last week, and  
10 during days I said I could not meet. So I have concerns  
11 about that, we'll just -- then --

12           So, basically, since I haven't had a lot of time  
13 to look at these changes -- and every time I look at this  
14 document, it's complicated, particularly because we are  
15 bouncing back and forth between the 10 States Standards and  
16 the proposed rule. And to do a thorough review, all of us  
17 have to really -- to do our jobs, we have to look at both.  
18 And it's time consuming to do that, and it's confusing.  
19 And every time I look at this, I see something new. Maybe  
20 less and less as time goes on, because we're catching a lot  
21 of these things, but I still do see new things.

22           And so with the volume of public comments that we  
23 received and for new board members, it was a significant  
24 volume of public comments compared to other regulations  
25 we've looked at on this board. And the amount of changes

1 that -- which is good. You know, I'm really pleased to see  
2 all the changes. And I really appreciate all the work that  
3 DEQ and the board and the public have done to bring this  
4 rule, I think it would be prudent to have one more public  
5 comment period and consider it at our next regularly  
6 scheduled board meeting, quarterly board meeting, which is  
7 coming up here pretty quick, have a public comment period,  
8 including comments at the meeting.

9 And I know that, you know, Jennifer and Keenan,  
10 you mentioned you're new to this. And, you know, I'm --  
11 I've been on the board for over 20 years, and we often have  
12 brought back a proposed rule again to the public in these  
13 types of circumstances. And this has happened many times  
14 in the past. And during my tenure on the board -- and I  
15 don't think it's unreasonable to do this one more time.  
16 And I just think it's -- it's a big change to the rule and  
17 it just -- to make the changes to the rule just takes time  
18 to try to get it right. So that's my 2 cents, and I'll  
19 open it up for Board discussion.

20 MS. ZYGMUNT: Thank you, Madam Chairwoman.  
21 Before we hear from other board members, let me just  
22 respond to a few logistic questions there.

23 First, in terms of appropriate procedures, I'll  
24 just remind the Board that the Water Quality Division  
25 Administrator is the executive secretary for the Board. So

1 I -- I feel it is appropriate for me to have called the  
2 meeting. We can double-check with the Attorney Generals,  
3 but I feel we're in accordance with proper procedures in  
4 order to call this meeting. So I'm not concerned about the  
5 proceedings being null and void. But thank you for raising  
6 that issue.

7 Good comments, Madam Chairwoman. Let me stop  
8 there and give the other board members chance to provide  
9 feedback.

10 BOARD MEMBER DEURLOO: Well, if nobody else  
11 is going to say anything, I guess I will. That's a tough  
12 one. I have a -- I said this at the last meeting too. Do  
13 we want the rule done right or do we want the rule done  
14 right now? I have a lot of faith in both -- the whole team  
15 around the table.

16 Jennifer, you and your team have done an  
17 excellent job of updating the -- and capturing what the  
18 comments -- mainly from Lorie's camp, but from the rest of  
19 the Board as well. So congratulations. Good job on that.

20 I would have a difficult time veering away from  
21 Chairman Cahn's recommendation, just because of her tenure  
22 on the board over 20 years. And I really defer a lot to  
23 her decision-making process on this, because I don't know  
24 how many times she's seen Section 12, but I'll bet you this  
25 isn't the first time. Probably the third or fourth or

1 fifth time.

2                   So I don't know -- I will follow Chairwoman  
3 Cahn's recommendation on this and go from there. Thank  
4 you.

5                   MS. ZYGMUNT: Thanks, Brian.

6                   ACTING CHAIR CAHN: Are there other board  
7 members that would like to comment?

8                   BOARD MEMBER COCHRAN: Madam Chair, this is  
9 Jim Cochran. I guess the only thing I would add is that  
10 there's been several opportunities for public comment, and  
11 it seems like that's kind of dried up and they're no longer  
12 commenting. And I don't know if that's wrong, they've got  
13 all their comments in, they're just tired of looking at  
14 this, or -- so I don't know, maybe it's time -- time to at  
15 least consider moving on.

16                   We're not the final say on this chapter. It  
17 still has to go to the EQC for final comments and changes.  
18 I'm sure we're welcome to comment at their meetings. So  
19 if -- if the public's ready and the staff's ready to move  
20 on, I think I'm ready too. So that would be the only thing  
21 I would add.

22                   ACTING CHAIR CAHN: Okay. Thank you, Jim.  
23 And I would just like to add that we specifically did not  
24 request public comments -- or did not allow public comments  
25 for this meeting. And I think the recommendation probably

1 came from me. And I think that the reason for that was  
2 that we were still going through comments -- we were still  
3 going through board comments on them, so I guess I felt  
4 like we still had some words to work on before we would go  
5 back out to the public for comments. So I'll just leave it  
6 at that.

7 MS. ZYGMUNT: Let me add in a few more  
8 thoughts procedurally based on Jim's comments. So from  
9 here, before we can proceed to formal rulemaking before I  
10 make -- well, first, I, as the administrator, will make  
11 recommendation to the Director. If the Director decides to  
12 proceed forward, we first go to governor's office to get  
13 approval to move forward. Advisory board feedback would be  
14 communicated to the governor's office at that time, and  
15 then if we go forward to the EQC, the advisory board's  
16 comments are provided to the Council as part of the  
17 information package.

18 So I think, Jim, it is a fair comment, just to  
19 support what you said, any advisory board feedback and  
20 discussion is included with the packet that goes to the  
21 Council, and we would discuss that with the governor's  
22 office as well. So I just want to make sure that the Board  
23 knows that your feedback is not lost. And, again, the --  
24 the Board's role as per statutes is to advise the  
25 administrator on the content of the rule before I make a

1 formal recommendation to the Director to move forward.

2           To the public notice, I would question the need  
3 to have another public comment opportunity. The board  
4 seemed pretty clear in our March meeting that we had done  
5 extensive public comment opportunity. Again, the rule was  
6 out for approximately 100 days. We did get some  
7 substantial feedback. But, again, my team here reached out  
8 personally to all of those commenters. And to our  
9 knowledge, everybody, you know, was -- was -- felt their  
10 comments had been heard and resolved with the responses  
11 that we provided.

12           It was the Board's direction not to do public  
13 comment with this meeting. I would be hesitant to say that  
14 I feel the need to do another public comment opportunity if  
15 we decided to bring this back to the advisory board one  
16 more time. Furthermore, there will be a public comment  
17 opportunity associated with the EQC meeting.

18           ACTING CHAIR CAHN: And, you know, I would  
19 just say it's not unusual to go back out, once -- you know,  
20 once we have most of the comments incorporated, to go back  
21 out for one last time. And the hope would be that we  
22 wouldn't get a lot of comments, but I think because  
23 typically with the extent of changes that are made, that's  
24 kind of how, as a board, we weigh whether or not we think  
25 we should have additional public comments. And there have

1 been, you know, significant substantial and significant  
2 changes, which is good. And hopefully, you know, the  
3 public will say, hey, I like this now, you know. And I  
4 think we'd have a lot more confidence going forward if we  
5 just get one more chance to look at this, and, you know,  
6 catch -- there's always something that we can catch to make  
7 it a better rule.

8           And I think, you know, if it had been minor  
9 changes since the public had last seen it and made their  
10 comments, that would be a way to say, no, we don't need to  
11 go back out. But they're significant changes, and, you  
12 know, we want this rule to be as good as we can get it.

13           MS. ZYGMUNT: Absolutely. We are all  
14 interested in a good product. And, again, I'm going to  
15 speak for the work that my team has done. I do think we  
16 have that good product. I think I would disagree that the  
17 revisions made since the last time the public comment --  
18 public has seen this are substantial. Again, I think these  
19 are all revisions that the public could comment on prior to  
20 the EQC meeting if appropriate.

21           Again, recognizing that Keenan and I are new to  
22 the position, neither of us are new to public comment  
23 opportunities such as this, and we do understand the  
24 importance of public transparency, but I do feel we have  
25 achieved that with this rule package.



1                   BOARD MEMBER DEURLOO: Madam Chairman,  
 2 question for Ms. Zygmunt. Has it ever been where a Board  
 3 Member of the -- from our advisory board makes a public  
 4 comment to the EQC?

5                   MS. THOMPSON: Yes, sir.

6                   BOARD MEMBER DEURLOO: For example, I know  
 7 we're commenting on it right now, but if there's some other  
 8 things that are stuck in people's craw or something like  
 9 that, that we make a -- an overall comment to the EQC for  
 10 their review?

11                   MS. ZYGMUNT: Yeah, thanks for the  
 12 question. Brian, I may ask Jim Peters to speak to that  
 13 issue in terms of the advisory board's role here and the  
 14 mission to advise the administrator versus role of the EQC.

15                   Jim, would you help us out with that.

16                   MR. PETERS: Yeah. Happy to jump in. So I  
 17 guess my first -- first piece -- or first answer is I'm not  
 18 aware of that has occurred before. As the administrator  
 19 mentioned, obviously, the Board's duty and role is to  
 20 consult with and advise the Administrator and the Director  
 21 on the adoption of rules. The statutes don't reference  
 22 advising, consulting, commenting, EQC. So as I would read  
 23 the statutes on the advisory board, the main duty of the  
 24 board is advising the Administrator and the Director on the  
 25 rules.

1 Does that help answer your question, Brian?

2 ACTING CHAIR CAHN: I know --

3 BOARD MEMBER DEURLOO: Yeah.

4 ACTING CHAIR CAHN: -- from experience

5 there was an example where somebody from the Board went to  
6 EQC. It has happened. And EQC did not move forward with  
7 that rule.

8 MS. THOMPSON: Yes, I'd like to clarify  
9 also that at that time, when that board member discussed it  
10 with the EQC, that board member was encouraged to note that  
11 they were representing themselves as a private individual,  
12 and that they were not representing the Board. So when --  
13 when that happened, they were not representing the Board in  
14 front of the EQC. They were representing themselves.

15 And it is correct that that rulemaking was  
16 returned to the agency to do additional work.

17 MS. ZYGMUNT: So, again, you know, what --  
18 as I would put it, you know, this -- these meetings are the  
19 Board's opportunity to advise me before I go to the  
20 director with my recommendation. Again, the packet that we  
21 put together for the Environmental Quality Council will  
22 include all of the transcripts from the meetings, and it  
23 will provide a summary of the Board's feedback. And, in  
24 this case, there will be, you know, fairly lengthy summary  
25 because we've had, you know, three meetings. And so it

1 will -- we will capture the Board's feedback and final  
2 recommendation and advice on the rule. So that is  
3 communicated to the EQC. But, again, I would say in terms  
4 of your role in advising me on how I move forward, these  
5 meetings are the place to do that. It does not preclude  
6 anybody going to the EQC outside of the role as the  
7 advisory board to provide comments on a rule package,  
8 though.

9 ACTING CHAIR CAHN: Are there other Board  
10 comments?

11 BOARD MEMBER DEURLOO: I don't know. I see  
12 both sides.

13 Lorie, how -- how -- I get your -- I get your  
14 point on this, and your -- I'm so thankful for your  
15 thoroughness and dedication to this. What are your  
16 feelings about just moving this forward to the EQC?

17 ACTING CHAIR CAHN: I'm not in favor at  
18 this time, but I'm optimistic that with one more go at it,  
19 with time to go over additional comments, that we can move  
20 forward. I'm optimistic.

21 BOARD MEMBER DEURLOO: Do we -- okay. To  
22 Jim's -- Board Member Jim's comments where -- I don't  
23 disagree with you. It seems like some of the public  
24 comments have kind of dried up, and we've given them a lot.  
25 Is the -- is the main issue -- you're doing the

1 cross-reference with the 10 States Standards, like more  
2 picking up your comments, Lorie? And maybe I didn't hear  
3 you. You probably voiced it, but I didn't pick up on it.  
4 Is the concern mainly with getting more comments from the  
5 public or addressing your cross-references and comments?

6 ACTING CHAIR CAHN: I think both. Both.  
7 You know, I would like to know how the public sees the  
8 changes that we've made. And, you know, and hopefully it  
9 sits better with them. I don't think it sits -- you know,  
10 there was some significant issues that the public brought  
11 up. And I'm hoping that, you know, we addressed most of  
12 their comments. But just because we've -- they've had a  
13 response to the comments doesn't mean that they would  
14 necessarily not still have issues.

15 MS. ZYGMUNT: Madam Chairwoman, can you  
16 explain why the public notice before the EQC meeting would  
17 not serve the same purpose to gather the final feedback on  
18 the rule that the Board has advised us on?

19 ACTING CHAIR CAHN: I think that our board  
20 tends to play a more technical role than EQC. And  
21 typically I think EQC relies on the advisory boards to  
22 really work out a lot of the technical issues so that when  
23 it comes up to them, it's really ready for their review and  
24 signature, you know, passing on to the governor for  
25 signature. So I think that I see our board as a -- as a --

1 the board that really gets into the nitty-gritty details.

2 MS. ZYGMUNT: Sure. Sure. And I would  
3 agree with that overall assessment. I will, you know,  
4 again state that I think we have accomplished that. I  
5 think you guys have given us a very thorough review of this  
6 rule. I also feel that my staff have done a very thorough  
7 review of the 10 States Standards and a very thorough job  
8 in preparing this rule.

9 You know, there's -- this is a big rule. It is  
10 detailed. There's a lot that goes into it, but I feel like  
11 we have done our due diligence in updating the rule  
12 accurately and reviewing the technical standards that are  
13 appropriate for this rule. And, again, with the feedback  
14 that you have already given us, I feel that we have the  
15 product that we need to move forward competently to the EQC  
16 so that they know they have a vetted product between DEQ's  
17 extensive work over the past five, six plus years, in  
18 addition to the Board's advice through these past three  
19 meetings.

20 MR. HENDON: And to add onto that, heading  
21 into the March meeting, staff here at DEQ reached out to  
22 each and every commenter that provided us comments to  
23 address those comments one by one. We went through those  
24 comments, provided them with our response, and came to a  
25 mutual understanding, either on their side or our side.

1           So with regards to additional public comments  
2 with regards to the chapter, I'm curious, is there feedback  
3 that you're getting, Ms. Cahn, that we are unaware of here  
4 in Cheyenne?

5           ACTING CHAIR CAHN: No. Not at all. I  
6 just -- you know, when I look at cross-walking between the,  
7 you know, proposed regulation and the TSS, I'm still  
8 finding issues. For instance, you know, I'm looking at my  
9 notes, there's some rapid mix disconnects between the two.  
10 And so it just gives me pause that, you know, we didn't get  
11 a lot -- I didn't get a lot of time for this meeting, a lot  
12 of notice for it, a lot of -- and so I just -- I'm still  
13 seeing things that are disconnect, and even with not a lot  
14 of time looking at it.

15           So -- and it's just not -- in my tenure, it's not  
16 at all unusual to go out, you know, one more time when you  
17 make changes like this to go to the public again. So --  
18 and I think that -- that would be -- give me a whole lot  
19 more assurance that -- I mean, I don't know what the public  
20 thinks. I have no idea. But I know that --

21           MS. ZYGMUNT: And Lorie --

22           ACTING CHAIR CAHN: -- from the volume of  
23 comments that we did get, that there was a lot of concern,  
24 and I think we should give the public, you know, one more  
25 opportunity to look at the whole thing with all the

1 changes. And I think they deserve that. You know, this  
2 rule hasn't changed for 40 years. If we wait two or three  
3 more months -- you know, when's our next meeting? I think  
4 it's in June. You know, if we -- it's May now. So, you  
5 know, we're not talking about a huge delay. And I think  
6 that the -- the ability to -- for EQC to have confidence in  
7 it, I think the Board support, and, you know, seeing there  
8 are no more public comments, I think that would really help  
9 this rule when it goes to EQC.

10 So I think our probability of success is much  
11 greater if we go -- if we do this one more time.

12 MS. ZYGMUNT: Yeah. Thank you, Madam  
13 Chairwoman. And I appreciate your perspective. I would  
14 still voice my disagreement that, again, in my 18 years  
15 here at DEQ, I think we've gone above and beyond what we  
16 need to do for public notice with the recognition that the  
17 public again will have another 45-day public comment period  
18 prior to the Environmental Quality Council meeting to  
19 review the final rule.

20 As we do outreach events around the state, we  
21 continue to remind people about Chapter 12, and we will  
22 continue to do so to let them know it will be going to the  
23 Council, and there will be another opportunity to provide  
24 public comment. So we will continue to push that public  
25 transparency and encourage people, if they have further

1 comments on the chapter, to do so prior to the EQC.

2           So I don't think we're sacrificing public  
3 transparency. And, again, I think my staff have done --  
4 again, they've gone above and beyond to respond to the  
5 public comments that we received on this, and it's giving  
6 me some ideas on how we move forward and how to standardize  
7 some ways that we respond to public comments. So I think  
8 we've learned a lot from this process, but I think we have  
9 fully vetted public input at this step with, again, the  
10 recognition that there is still public opportunity to  
11 comment before the EQC.

12           So I am not hearing any further feedback. I will  
13 leave it to the Board if you would like to provide me any  
14 more specific advice to capture in our notes, or if you  
15 would like to voice a formal recommendation through a  
16 motion.

17           BOARD MEMBER DICKSON: This is Brian  
18 Dickson. I'm hearing two very compelling arguments,  
19 because I agree with both of them. But I think that with  
20 the work that this staff has done and the work that this  
21 Board has done, I think we're ready to move on. I would  
22 move that we -- we -- we approve the changes that have been  
23 made in Chapters 12 that we have reviewed at our last  
24 meetings and today.

25           ACTING CHAIR CAHN: We have a motion on the



1 floor. Do I have a second?

2 BOARD MEMBER COCHRAN: Madam Chair, this is  
3 Jim Cochran. I would second.

4 ACTING CHAIR CAHN: Board discussion?

5 Okay. Hearing none. All in favor say aye.

6 BOARD MEMBER COCHRAN: Aye.

7 BOARD MEMBER DICKSON: Aye.

8 ACTING CHAIR CAHN: We're going to have to  
9 do it one at a time. I can't tell who says aye.

10 BOARD MEMBER COCHRAN: Jim Cochran, aye.

11 BOARD MEMBER DICKSON: Brian Dickson, aye.

12 ACTING CHAIR CAHN: All opposed, nay.

13 BOARD MEMBER DEURLOO: Nay.

14 ACTING CHAIR CAHN: Okay. Motion does not  
15 carry.

16 So I think that is time to adjourn our meeting.

17 MS. ZYGMUNT: Great. Thank you very much.

18 Appreciate the discussion. I will take the advice and  
19 the -- that failed motion into consideration and talk with  
20 our director, and we will be in touch and let you know how  
21 we decide to move forward.

22 ACTING CHAIR CAHN: Okay. Thank you very  
23 much.

24 MS. ZYGMUNT: All right. Thank you,  
25 everyone.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

ACTING CHAIR CAHN: Meeting adjourned.

BOARD MEMBER DEURLOO: Thank you.

(Special meeting proceedings concluded  
11:31 a.m., May 3, 2022.)

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

C E R T I F I C A T E

I, KATHY J. KENDRICK, a Registered Professional Reporter, do hereby certify that I reported by machine shorthand the foregoing proceedings contained herein, constituting a full, true and correct transcript.

Dated this 27th day of May, 2022.

  
KATHY J. KENDRICK  
Registered Professional Reporter



**Water and Waste Advisory Board Comments**  
**May 3, 2022 Meeting**  
**Chapter 12**

**General Comments**

**Lorie Cahn:** Ms. Cahn advised WDEQ/WQD to include 2018 TSS 1.1, specifically the phrase “where pertinent” in Chapter 12.

**Department Response:** As discussed at the May 3, 2022 meeting, WDEQ/WQD will not include the reference and the phrase “where pertinent” as the phrase may lead to confusion and potential enforcement issues.

**Lorie Cahn:** Ms. Cahn advised WDEQ/WQD to include 2018 TSS 1.1.7 in Chapter 12.

**Department Response:** As noted at the May 3, 2022 meeting, WDEQ/WQD will not include the reference as the part applies to sources of water that are addressed in Chapter 12 and the inclusion would be redundant.

**Lorie Cahn:** Ms. Cahn noted that she did not think that WDEQ/WQD provided enough time for her to review and discuss her comments on the chapter. Ms. Cahn noted that she did not think that WDEQ/WQD adequately considered her limited availability for the May 3, 2022 meeting. She explained that she needed to thoroughly review both the 2018 TSS and the proposed revisions to Chapter 12 and that her review was time-consuming and confusing. Ms. Cahn noted that she discovered other potential conflicts in her comparison of the 2018 TSS to Chapter 12. Ms. Cahn noted concern at the volume of public comments received for Chapter 12. Ms. Cahn advised WDEQ/WQD to provide an additional comment period and Water and Waste Advisory Board presentation as she thinks the revisions that WDEQ/WQD proposed since the March 15, 2022 are significant. Ms. Cahn explained that she believes the role of the WWAB is to provide a technical review to ensure rules are ready for the Environmental Quality Council’s review and adoption.

**Department Response:** WDEQ/WQD reviewed our correspondence with Ms. Cahn regarding the scheduling of the May 3, 2022 Water and Waste Advisory Board (WWAB) Special Meeting. In the March 26, 2022 email that Ms. Cahn sent to Administrator Zygmunt and WDEQ/WQD rulemaking staff, she indicated she would be available the weeks of April 18-22, May 3-6, and May 9-13.

WDEQ/WQD compared Ms. Cahn’s request to staff availability and sent a scheduling poll to the four WWAB members and to WDEQ/WQD staff to find a date that would provide a quorum of the WWAB and adequate participation by WDEQ/WQD staff. Due to the nature of the WWAB members’ schedules and the WDEQ/WQD staff schedules, finding meeting dates that work for everyone can be difficult. If WWAB members are unable to attend a scheduled meeting but there is a quorum, WDEQ/WQD would

potentially proceed with scheduling and would explain to board members that are unavailable for a particular meeting date that they may request that another board member or the WDEQ/WQD Administrator read the unavailable board member's comments into the record.

However, in the case of the May 3, 2022 meeting, all four board members indicated in their poll responses that they would be available on May 3. WDEQ/WQD staff, meeting space, and a court reporter were also available on May 3. On April 4, 2022, WDEQ/WQD staff sent a calendar invitation to the WWAB and WDEQ/WQD staff that the next meeting would be on May 3. The WQD did not receive further correspondence from Ms. Cahn regarding her availability for the May 3 meeting.

WDEQ/WQD understands that it can be confusing to review the 2018 TSS and the proposed revisions to Chapter 12 as both documents contain public water supply requirements that pertain to complex engineering designs. However, the WDEQ/WQD's drafting process to consider the incorporation of the 2018 TSS into Chapter 12 was thorough, the material we are proposing to incorporate is appropriate, and we have addressed comments received from the comment opportunities provided between November 5, 2021 and March 15, 2022. Comments from both the public and the WWAB have provided helpful feedback that the WDEQ/WQD has used to refine and improve incorporation by reference of the 2018 TSS into the proposed rule.

As WDEQ/WQD had received only one additional public comment at the March 15, 2022 meeting after conducting thorough and individualized outreach with entities that had submitted public comments before the March 15, 2022 meeting, WDEQ/WQD agreed with the WWAB's request to close the public comment period as it seemed the public was satisfied with WDEQ/WQD's resolution of comments and updated revisions. WDEQ/WQD revised Chapter 12 after the March 15, 2022 meeting in response to WWAB advice and the one public comment received during the meeting. However, the changes were not substantively different from what the public had seen previously, were a logical outgrowth of public discussion, and are in line with the scope proposed in all of the public notices. Therefore, the WDEQ/WQD disagrees that an additional public comment opportunity would add value at this time, and, as discussed during the May 3 meeting, a 45-day formal rulemaking public comment opportunity will be provided in advance of the EQC meeting.

WDEQ/WQD appreciates the specific feedback that all board members have provided to WDEQ/WQD throughout the Chapter 12 rulemaking process; this feedback has helped to improve the proposed rule. WDEQ/WQD has provided the WWAB with three opportunities to provide advice, and the WWAB has provided advice on the rule in its entirety. Therefore, the WQD has determined that the WWAB has satisfied its statutory requirement to advise the Administrator per Wyoming Statutes § 35-11-114(b).

WDEQ/WQD has openly and thoroughly considered the WWAB advice, and proposed

revisions to Chapter 12 satisfy the provisions and purposes of the Environmental Quality Act. At this time, the WQD Administrator will recommend that the Director proceeds with proposing the adoption of Chapter 12 to the EQC.

### **11(e)(i)**

**Lorie Cahn:** Ms. Cahn recommended revising the proposed edit to “or not noncommunity nontransient nontransient noncommunity water systems...”

**Department Response:** WDEQ/WQD corrected the passage as advised.

### **12(a)**

**Lorie Cahn:** Ms. Cahn identified areas in 12(a) where the references were out of numerical order. For the references to 2018 TSS Part 4.4, 4.6, and 9.5. Ms. Cahn explained the references are unclear as to what parts are included. Ms. Cahn identified additional 2018 TSS references that included incorrect titles.

**Department Response:** WDEQ/WQD reviewed the references in Section 12(a) and corrected titles and numerical order as needed. For 2018 Part 4.4, WDEQ/WQD has stricken the reference and added in the passages from the 2018 TSS to Chapter 12, Section 12(l).