

Darwin Dyck

Follow up comments are being provided upon further review of Chapter 12. This subject matter is primarily related to the type of wells allowed by Chapter 12, and if dug wells should still be permitted. Chapter 12 makes reference to dug wells that shall be constructed according to State Engineer's Office. Chapter 12 also includes concrete piping for well casing material which is assumed to be for dug wells. Dug wells are older technology and would typically deliver groundwater under direct influence of surface water. Subsequently, how and where are procedures for classifying wells as groundwater wells or groundwater wells under direct influence of surface water? Are there Microscopic Particulate Analysis (MPA) requirements covered that confirm classification of shallower water wells? Also, are shallow horizontal infiltration galleries or in-bank filtration options available as options for raw water intakes? Appropriate classification of wells will dictate level of treatment required per results of MPAs.