

1 **CHAPTER 12**

2 **Design and Construction Standards for Public Water Supplies**

3 **Section 1. Authority.**

4  
5  
6  
7 These standards are promulgated pursuant to the Wyoming Environmental Quality Act,  
8 specifically, § 35-11-302.

9  
10 **Section 2. Applicability.**

11  
12 (a) This Chapter contains the minimum standards for the design and construction of  
13 public water supplies that are required to obtain a permit under Wyoming Statute (W.S.) § 35-  
14 11-301(a)(iii) and Water Quality Rules Chapter 3.

15  
16 (i) All applicants for a Water Quality Rules Chapter 3 permit to construct,  
17 install, modify, or operate a public water supply facility shall comply with all minimum  
18 standards of this Chapter.

19  
20 (ii) No permit to construct, install, modify, or operate a public water supply  
21 facility shall be issued to a facility that does not comply with the minimum standards of this  
22 Chapter.

23  
24 (iii) All public water supply facilities shall be constructed, installed, and  
25 operated in accordance with permits issued pursuant to this Chapter.

26  
27 (b) The construction, installation, or modification of any component of a public water  
28 supply facility requires a permit to construct.

29  
30 **Section 3. Timing of Compliance with These Regulations.**

31  
32 Any facility covered by an individual or general permit issued pursuant to Water Quality  
33 Rules, Chapter 3, prior to the effective date of this Chapter shall remain covered under that  
34 permit. New construction or modification of existing permitted facilities must obtain  
35 authorization under a new permit, in accordance with Water Quality Rules Chapter 3, Section  
36 4(d) or Section 5(e), subject to the requirements of this Chapter.

37  
38 **Section 4. Incorporation By Reference of Recommended Standards for Water**  
39 **Works 2018 Edition.**

40  
41 (a) This Chapter incorporates sections of the Recommended Standards for Water  
42 Works, A Report of the Water Supply Committee of the Great Lakes--Upper Mississippi River  
43 Board of State and Provincial Public Health and Environmental Managers, 2018 Edition, referred  
44 to as "2018 TSS," as noted in Section 8(a), Section 9(a), Section 10(a), Section 11(a), Section  
45 12(a), Section 13(a), Section 14(a), Section 15(a), Section 16(a), Section 17(a), and Section  
46 19(a)(lviii) of this Chapter.

47  
48 (b) The State term “Administrator” shall replace the term “reviewing authority” used  
49 in the Recommended Standards for Water Works 2018 Edition.

50  
51 (c) The State term “shall” shall replace the term “should” used in the Recommended  
52 Standards for Water Works 2018 Edition.

53  
54 **Section 5. Definitions.**

55  
56 (a) The following definitions supplement those contained in W.S. § 35-11-103 of the  
57 Wyoming Environmental Quality Act.

58  
59 (b) “Auxiliary source of supply” means any water supply on or available to the water  
60 user's system other than an approved public water supply acceptable to the water supplier. These  
61 auxiliary waters may include water from another supplier's public potable water supply or any  
62 natural source(s), such as a well, spring, river, stream, harbor, and so forth; used waters; or  
63 industrial fluids. These waters may be contaminated or polluted, they may be objectionable or  
64 they may be from a water source that the water supplier is uncertain of sanitary control.

65  
66 (c) “Average daily demand” means the total annual water use divided by the number  
67 of days the system was in operation.

68  
69 (d) “Backflow” means the undesirable reversal of flow of water or mixtures of water  
70 and other liquids, gases, or other substances into the distribution system of the public water  
71 supply from any other source or sources.

72  
73 (e) “Backflow incident” means any identified backflow to a public water supply  
74 distribution system or to the potable water piping within the water user's system benefitting from  
75 a water service connection to the public water supply distribution system.

76  
77 (f) “Back-pressure” means a form of backflow caused when the pressure of the water  
78 user’s system is greater than that of the water supply system whether caused by a pump, elevated  
79 tank, elevated piping, boiler, pressurized process, pressurized irrigation system, or air pressure.

80  
81 (g) “Back-siphonage” means a form of backflow caused by negative or reduced  
82 pressure in the water supply system whether caused by loss of pressure due to high water  
83 demands, a line break, or excessive firefighting flows.

84  
85 (h) “Calculated Dose” means the reduction equivalent dose (RED) calculated using  
86 the dose-monitoring equation that was developed through validation testing.

87  
88 (i) “Contamination” means an impairment of a public water supply by the  
89 introduction or admission of any foreign substance that degrades the quality of the potable water  
90 or creates a health hazard.

91

92 (j) “Cross-connection” means any actual or potential connection between a potable  
93 water supply and any other source or system through which it is possible to introduce  
94 contamination into the system.

95  
96 (k) “Degree of hazard” means either a high or low hazard situation where a substance  
97 may be introduced into a public water supply through a cross-connection. The degree of hazard  
98 or threat to public health is determined by a hazard classification.

99  
100 (l) “Domestic services” means services using potable water for ordinary living  
101 processes.

102  
103 (m) “Dual check” means a device conforming to American Association of Sanitary  
104 Engineers (ASSE) Standard #1024 consisting of two independently acting check valves.

105  
106 (n) “Groundwater source” includes all water obtained from dug, drilled, bored, jetted,  
107 or driven wells; springs that are developed so that the water does not flow on the ground and that  
108 are protected to preclude the entrance of surface contamination; and collection wells.

109  
110 (o) “Hazard classification” means a determination by a Hazard Classification  
111 Surveyor as to high hazard or low hazard and the potential cause of backflow as either back-  
112 pressure or back-siphonage.

113  
114 (p) “Hazard Classification Survey” means inspection of a premises to identify the  
115 potable water systems, the location of any potential cross-connections to the potable water  
116 systems, the hazard of the potential backflow, the physical identification of any backflow devices  
117 or methods present, and the inspection status of any backflow devices or methods recorded and  
118 certified by a qualified Hazard Classification Surveyor.

119  
120 (q) “Hazard Classification Surveyor” means an individual certified by the USC-  
121 Foundation for Cross-Connection Control and Hydraulic Research as Cross Connection Control  
122 Specialist (USC-FCCCHR), the ASSE as a Cross-Connection Control Surveyor, or another state  
123 certification program submitted with the permit application and approved by the Administrator,  
124 or an individual who is a water distribution system operator also certified as a backflow device  
125 tester employed by the public water supplier for the service where the survey is being conducted.

126  
127 (r) “High hazard” means a situation created when any substance that is or may be  
128 introduced into a public water supply poses a threat to public health through poisoning, the  
129 spread of disease or pathogenic organisms, or any other public health concern.

130  
131 (s) “Isolated” when referring to cross-connections means the properly approved  
132 backflow prevention devices have been installed at each point of cross-connection within the  
133 water user's system.

134  
135 (t) “Low hazard” means a situation created when any substance that is or may be  
136 introduced into a public water supply does not pose a threat to public health but that does  
137 adversely affect the aesthetic quality of the potable water.

138  
139  
140  
141  
142  
143  
144  
145  
146  
147  
148  
149  
150  
151  
152  
153  
154  
155  
156  
157  
158  
159  
160  
161  
162  
163  
164  
165  
166  
167  
168  
169  
170  
171  
172  
173  
174  
175  
176  
177  
178  
179  
180  
181

(u) “Maximum daily demand” means the demand for water exerted on the system over a period of 24 consecutive hours, for the period during which such demand is greatest.

(v) “Maximum hourly demand” means the highest single-hour demand exerted on the system. This may or may not occur on the maximum day.

(w) “Mechanical sludge equipment” means the equipment used to physically remove solids from a water treatment process. This may include mechanical drives that use scrapers or differential water levels to collect the sludge.

(x) “Mineralized water” means any water containing more than 500 mg/L total dissolved solids.

(y) “Minor field change” means any in-field adjustment due to previously unknown physical constraints of the project site that do not affect the project’s scope. Minor field changes still allow full compliance with the requirements of this Chapter and are shown on the submitted, post-construction as-built plan set for the Division in red.

(zz) “Primary disinfection” means disinfection that kills or inactivates bacteria, viruses, and other potentially harmful organisms in drinking water.

(aa) “Reduction Equivalent Dose” means the ultraviolet (UV) dose derived by entering the log inactivation measured during full-scale reactor testing into the UV dose-response curve that was derived through collimated beam testing. RED values are always specific to the challenge microorganism used during experimental testing and the validation test conditions for full-scale reactor testing.

(bb) “Required Dose” means the UV dose in units of mJ/cm<sup>2</sup> req needed to achieve the target log inactivation for the target pathogen.

(cc) “Secondary disinfection” means disinfection that provides longer lasting water treatment as the water moves through pipes to consumers.

(dd) “Stabilized drawdown” means a water level that has not fluctuated by more than plus or minus 0.5 foot for each 100 feet of water in the well over at least a six-hour period of constant pumping flow rate. The water column is measured from pre-test static water level to the top of the deepest water bearing fracture that contributes at least 10 percent of total well yield, and plotted measurements that have not shown a trend of decreasing water level.

(ee) “Surface water source” includes all tributary streams and drainage basins, natural lakes, and artificial reservoirs or impoundments upstream from the point of the water supply intake.

182 (ff) “Validated Dose” means the UV dose in units of mJ/cm<sup>2</sup> delivered by the UV  
183 reactor as determined through validation testing that is compared to the required dose to  
184 determine log inactivation credit.

185  
186 (gg) “Water service connection” means any water line or pipe connected to a  
187 distribution supply main or pipe for the purpose of conveying water to a water user's system.

188  
189 (hh) “Water supplier” means any entity that owns or operates a public water supply,  
190 whether public or private.

191  
192 (ii) “Water user” means any entity, whether public or private, with a water service  
193 connection to a public water supply and includes customers of a public water supplier.

194  
195 (jj) “Water user's system” means that portion of the user's water system between the  
196 water service connection and the point of use. This system includes all pipes, conduits, tanks,  
197 fixtures, and appurtenances used to convey, store, or use water provided by the public water  
198 supply.

199  
200 **Section 6. Facilities and Systems not Specifically Covered by these Standards.**

201  
202 (a) Each application for a permit to construct a facility under this section shall be  
203 evaluated on a case-by-case basis using the best available technology. The Administrator may  
204 approve applications demonstrating the constructed facility can meet the purpose of the  
205 Wyoming Environmental Quality Act and this Chapter.

206  
207 (b) The following information shall be included with the application for a permit to  
208 construct, install, modify, or operate a public water supply facility not specifically covered by  
209 these standards:

210  
211 (i) Data obtained from:

212  
213 (A) A full scale, comparable installation that demonstrates the  
214 acceptability of the design; or

215  
216 (B) A pilot plant operated under the design condition for a sufficient  
217 length of time to demonstrate the acceptability of the design; or

218  
219 (C) A theoretical evaluation of the design that demonstrates a  
220 reasonable probability the facility will meet the design objectives.

221  
222 (ii) An evaluation of the flexibility of making corrective changes to the  
223 constructed facility in the event it does not function as planned.

224  
225 (c) If an applicant wishes to construct a pilot plant to provide the data necessary to  
226 meet the requirements of this Section, the applicant must obtain a permit to construct.  
227

**Section 7. Permits, Permit Application, and Recordkeeping Requirements.**

(a) Applications for a permit to construct, install, modify, or operate a public water supply shall comply with the requirements of Water Quality Rules Chapter 3, Section 6.

(b) The application shall include the following components:

(i) An engineering design report that meets the requirements of Section 9 of this Chapter;

(ii) A construction plan that meets the applicable requirements of Sections 8, 10, 11, 12, 13, 14, 15, 16, and 17 of this Chapter;

(iii) An operation and maintenance plan that meets the requirements of Section 18 of this Chapter; and

(iv) Any additional information required by the Administrator.

(c) The application and components required by this Chapter shall be submitted to the Division in a format required by the Administrator.

(d) The application shall include certification under penalty of perjury that the applicant has secured and will maintain permission for Department personnel and their invitees to access the facility, including permission to:

(i) Access the land where the facility is located;

(ii) Collect resource data as defined by W.S. § 6-3-414(e)(iv); and

(iii) Enter and cross all properties necessary to access the facility if the facility cannot be directly accessed from a public road.

(e) Sections of permit applications that represent engineering work shall be sealed, signed, and dated by a licensed professional engineer as required by W.S. § 33-29-601.

(f) Sections of permit applications that represent geologic work shall be sealed, signed, and dated by a licensed professional geologist as required by W.S. § 33-41-115.

(g) The Administrator may allow an alternative two-step permitting and application procedure for wells and water storage tank project applicants that meet the following requirements:

(i) For applications that include wells, the Department will issue one permit with the following phased authorizations:

273 (A) The issued permit will authorize the well to be constructed,  
274 developed, and tested;

275  
276 (B) Applicants shall then submit well test data and water quality data  
277 for Administrator review; and

278  
279 (C) Upon the Administrator’s approval of the well test data and water  
280 quality data, the Director shall modify the issued permit to authorize connection of the  
281 distribution system to the well.

282  
283 (iii) Applicants for water storage tanks may follow an alternative procedure  
284 when the final plans and specifications for the tank cannot be submitted with the initial permit  
285 application due to project bidding constraints. In these instances, the Department will issue a  
286 permit through the following phased authorizations:

287  
288 (A) The issued permit will authorize the project to initiate the bidding  
289 process. Applicants shall ensure the project bidding documentation includes a requirement that  
290 the final water storage tank design complies with the requirements of this Chapter.

291  
292 (B) Applicants shall then submit final documentation and  
293 specifications for the water storage tank that demonstrate the design is consistent with the  
294 requirements of this Chapter. Upon the Administrator’s approval of the final tank documentation  
295 specifications, the Director shall modify the issued permit to authorize the construction of the  
296 water storage tank and foundation.

297  
298 (iv) Applicants that use phased authorization procedures in this paragraph (g)  
299 shall request a pre-application meeting with the applicable Division district engineer prior to  
300 submission of the permit application package to ensure efficient coordination of the submittals of  
301 all reports, plans, and specifications, and Division review timelines.

302  
303 **Section 8. Plans and Specifications.**

304  
305 (a) 2018 TSS, part 1.2-1.2.2(r), plans; 1.3-1.3(e), specifications; 1.4-1.4(m), design  
306 criteria; 1.5, revisions to approved plans; and 1.6, additional information required; are herein  
307 incorporated by reference.

308  
309 (b) All plans for waterworks and treatment facilities shall also include the name of  
310 the real estate owner, the owner of the project, and the location of the project.

311  
312 (c) Plans for transmission and distribution lines shall include:

313  
314 (i) The information required in paragraph (a) of this Section;

315  
316 (ii) A detailed plan view at a legible scale of each reach of the water line  
317 showing all existing and proposed streets, adjacent structures, physical features, and existing  
318 locations of utilities that indicates:

319  
320  
321  
322  
323  
324  
325  
326  
327  
328  
329  
330  
331  
332  
333  
334  
335  
336  
337  
338  
339  
340  
341  
342  
343  
344  
345  
346  
347  
348  
349  
350  
351  
352  
353  
354  
355  
356  
357  
358  
359  
360  
361  
362  
363

(A) The location and size of all water lines, valves, access manholes, air-vacuum release stations, thrust blocking, and other appurtenances; and

(B) Pertinent elevations.

(iii) Profiles of all water lines that are shown on the same sheet as the plan view at legible horizontal and vertical scales and that show:

(A) Profiles of:

(I) Existing and finished surfaces;

(II) Pipe size and material; and

(III) Valve size, material, and type.

(B) The location of all special features such as access manholes, concrete encasements, casing pipes, blowoff valves, and air-vacuum relief valves.

(iv) Special detail drawings scaled and dimensioned to show the following:

(A) The bottom of the stream, the elevation of the high- and low-water levels, and other topographical features at points where the water line:

(I) Is located within 10 feet of streams or lakes; or

(II) Crosses streams or lakes.

(B) A cross-section drawing of the pipe bedding; and

(C) Additional features of the pipe or its installation that are not otherwise covered by specifications.

(v) The location of any sewer lines within 30 feet horizontally of water lines. Sewers that cross water lines shall be shown on the profile drawings.

(d) Plans for storage tanks, pumping stations, and water treatment facilities shall show the relation of the proposed project to the remainder of the system and shall include:

(i) The information required in paragraph (a) of this Section;

(ii) The seal and signature of the Wyoming Professional Engineer providing the design;



- 364 (iii) The site location and layout including:  
 365  
 366 (A) Topographic and physical features, including embankments;  
 367  
 368 (B) The proposed arrangement of pumping or treatment units;  
 369  
 370 (C) Existing facilities;  
 371  
 372 (D) Existing and proposed piping and valving arrangements;  
 373  
 374 (E) The route to access the facility;  
 375  
 376 (F) The power supply;  
 377  
 378 (G) Fencing; and  
 379  
 380 (H) The proposed location of clearwells, waste ponds, and sludge  
 381 ponds.  
 382  
 383 (iv) Schematic flow diagram(s) and hydraulic profile(s) for facility-treated  
 384 water;  
 385  
 386 (v) A flow diagram for sludge and wastewater flows; and  
 387  
 388 (vi) Plan(s) and section view(s) of each treatment facility process unit with  
 389 specific construction details, features, and pertinent elevations including but not limited to the  
 390 following:  
 391  
 392 (A) Inlet and outlet devices;  
 393  
 394 (B) Baffles;  
 395  
 396 (C) Valves;  
 397  
 398 (D) Arrangement of automatic control devices;  
 399  
 400 (E) Mixers;  
 401  
 402 (F) Motors;  
 403  
 404 (G) Chemical feeders;  
 405  
 406 (H) Sludge scrapers;  
 407  
 408 (I) Sludge disposal; or  
 409

- 410 (J) Other mechanical devices.
- 411
- 412 (e) Plans for well construction shall include:
- 413
- 414 (i) The information required in paragraph (a) of this Section;
- 415
- 416 (ii) Assembled order, size, and length of casing and liners;
- 417
- 418 (iii) The well test method and allowable tolerance;
- 419
- 420 (iv) The locations of all caisson construction joints and porthole assemblies on
- 421 drawings, if a radial water collector is proposed;
- 422
- 423 (v) From the ground surface to the total depth of the drilled borehole, the
- 424 elevation and designation of geological formations, water levels, formations penetrated, and
- 425 other details to describe the proposed well completely;
- 426
- 427 (vi) Screen locations, size of screen openings, and screen intervals;
- 428
- 429 (vii) The location of any blast charges, if available; and
- 430
- 431 (viii) Existing well test data, including:
- 432
- 433 (A) Test pump capacity-head characteristics;
- 434
- 435 (B) Static water level;
- 436
- 437 (C) Depth of test pump setting;
- 438
- 439 (D) Time of starting and ending each test cycle;
- 440
- 441 (E) Pumping rate;
- 442
- 443 (F) Pumping water level;
- 444
- 445 (G) Drawdown; and
- 446
- 447 (H) Water recovery rate and levels.
- 448
- 449 (f) Plans for water lines, pump stations, treatment facilities, wells, storage, or
- 450 additions/modifications to existing systems or facilities shall be accompanied by technical
- 451 specifications that include:
- 452
- 453 (i) The information required in paragraph (a) of this Section;
- 454
- 455 (ii) Identification of construction materials;

- 456  
457 (iii) When applicable, the type, size, strength, operating characteristics, rating  
458 or requirements for all mechanical and electrical equipment, including machinery, valves, piping,  
459 electrical apparatus, wiring, and meters; laboratory fixtures and equipment; operating tools;  
460 special appurtenances; and chemicals;  
461
- 462 (iv) Construction and installation procedure for materials and equipment;  
463
- 464 (v) Requirements and tests of materials and equipment to meet design  
465 standards;  
466
- 467 (vi) Performance tests for the operation of completed works and component  
468 units;  
469
- 470 (vii) Specialized requirements for tests, analyses, disinfection techniques, and  
471 other special needs;  
472
- 473 (viii) A demonstration that all water service connections will be provided with  
474 backflow prevention devices in accordance with the requirements of Section 16(m) of this  
475 Chapter; and  
476
- 477 (ix) If technical specifications have been independently permitted by the  
478 Department for statewide use, the title, date, and permit approval identification number in lieu of  
479 providing technical specifications.  
480

## 481 **Section 9 Engineering Design Report.**

- 482
- 483 (a) 2018 TSS, parts 1.1-1.1.1(d), engineers report, general information; 1.1.2-  
484 1.1.2(c), engineers report, extent of water works system; 1.1.4-1.1.4(c), engineers report, soil,  
485 groundwater conditions, and foundation problems; 1.1.5-1.1.5(f), engineers report, water use  
486 data; 1.1.6-1.1.6(b), engineers report, flow requirements; 1.1.7-1.1.7.1(f), engineers report,  
487 sources of water supply, surface water sources; 1.1.7.2-1.1.7.2(g), engineers report, sources of  
488 water supply, groundwater sources; 1.1.8, engineers report, proposed treatment processes; 1.1.9,  
489 engineers report, sewerage system available; 1.1.10, engineers report, waste disposal; 1.1.15-  
490 1.1.15(d), engineers report, pumping facilities; 1.1.16-1.1.16(c), engineers report, storage; and  
491 1.1.17-1.1.17(d), engineers report, security, contingency planning, and emergency preparedness;  
492 are herein incorporated by reference.  
493
- 494 (b) An engineering design report shall be submitted with each application and shall  
495 include the following required elements:  
496
- 497 (i) The information required in paragraph (a) of this Section;  
498
- 499 (ii) A description by narrative, analyses, and calculations of the project  
500 purpose and intent in order to support the project plans and specifications;  
501

- 502 (iii) A description of known or suspected problems, needs, or requirements,  
503 and the reasoning used to arrive at the proposed solution;  
504
- 505 (iv) An identification of problems and solutions related to but not limited to  
506 the following:  
507
- 508 (A) Water quantity and quality;  
509
- 510 (B) Compliance with the Safe Drinking Water Act, 42 U.S.C. §300f et  
511 seq.; and  
512
- 513 (C) Operational requirements, redundancy, maintenance, and  
514 reliability.  
515
- 516 (v) A determination of the degree of hazard of all known or anticipated water  
517 service connections to be connected to the proposed project. A hazard classification shall be  
518 identified for each connection and recommended mitigation measures shall be described for each  
519 hazard.  
520
- 521 (c) The engineering design report for all new water distribution system extensions  
522 shall include the following required elements:  
523
- 524 (i) The information required in paragraph (a) of this Section;  
525
- 526 (ii) A description of the service area including scaled vicinity plan map(s) of  
527 the project with regard to adjacent and proposed development, elevations, and topographic  
528 features; and  
529
- 530 (iii) Current and projected system water use data and flow requirements to  
531 include maximum hourly demand and per capita maximum daily flows;  
532
- 533 (iv) Information on fire protection and fire flow capabilities of the proposed  
534 system.  
535
- 536 (d) The engineering design report for all treatment facilities shall include the  
537 following required elements:  
538
- 539 (i) The information required in paragraph (a) of this Section;  
540
- 541 (ii) A description of the facility site and location, including a scaled site plan,  
542 and:  
543
- 544 (A) Present and projected facility property boundaries;  
545
- 546 (B) Flood protection indicating predicted elevation of 25- and 100-year  
547 flood stages;

548  
549  
550  
551  
552  
553  
554  
555  
556  
557  
558  
559  
560  
561  
562  
563  
564  
565  
566  
567  
568  
569  
570  
571  
572  
573  
574  
575  
576  
577  
578  
579  
580  
581  
582  
583  
584  
585  
586  
587  
588  
589  
590  
591

(C) Present and proposed access for the purpose of operation, maintenance, and compliance inspection;

(D) Distances from:

(I) Current habitation;

(II) The closest major treated water transmission line;

(III) The closest treated water storage facility; and

(IV) The water source.

(E) Fencing and security;

(F) Topographic features and contours with indicated datum; and

(G) Soil and subsurface geological characteristics, including a soils investigation report of the proposed site suitable for structural design of the proposed facilities.

(iii) A description of the service area, including scaled vicinity plan map(s) of the project with regard to adjacent and proposed development, elevations, and topographic features;

(iv) A detailed description of the recycle flows and procedures for reclamation of recycle streams; and

(v) A detailed description of disposal techniques for settled solids, including a description of the ultimate disposal of sludge.

(e) Engineering design reports for new surface water sources shall include the following required elements:

(i) The information required in paragraph (a) of this Section;

(ii) A description of water quantity available during average and driest years of record that contains details of:

(A) Any diversion records; and

(B) Diversion dams, impoundments, or reservoirs that may impact design considerations or long-term water availability.

592 (iii) A tabulation of water quality data that describes the biological,  
593 radiological, and chemical water quality sufficient to determine necessary treatment processes  
594 that:

595  
596 (A) For surface water source testing, include at least one sampling  
597 event during spring runoff and at least one sampling event during late summer or early fall low  
598 flow; and  
599

600 (B) Includes data that are sufficient for the Division to determine that  
601 the processes safely and reliably comply with water quality standards required by 40 CFR Part  
602 141.  
603

604 (f) Engineering design reports for new groundwater sources shall include:

605 (i) The information required in paragraph (a) of this Section;  
606  
607

608 (ii) A description of the geology of the aquifer(s) and overlying strata;  
609

610 (iii) Tabulated water quality testing data for biological, radiological, and  
611 chemical water quality sufficient to determine necessary treatment processes and sufficient for  
612 the Administrator to determine that the processes safely and reliably meet water quality  
613 standards required by 40 CFR Part 141;  
614

615 (iv) If known, a summary of the likely drilling and completion challenges that  
616 will be faced, including a description of the engineering design, management, monitoring, and  
617 drilling and completion practices that will be used to successfully construct the well in  
618 accordance with this Chapter; and  
619

620 (v) For wells that will be drilled through multiple aquifers, applicants shall  
621 request a pre-application meeting with the applicable Division district engineer to discuss:  
622

623 (A) The boring advancement, well sealing, well development, and  
624 methods used to determine the adequacy of the well seal; and  
625

626 (B) The methods that will be used to overcome lost circulation, bore  
627 instability, and deviations from vertical alignment.  
628

629 (g) Engineering design reports for conversion of an existing well into a public water  
630 supply well shall include the following required elements:  
631

632 (i) The information required in paragraph (a) of this Section;  
633

634 (ii) The information required in paragraph (f) of this Section;  
635

636 (iii) The submission of the State Engineer's Office (SEO) Statement of  
637 Completion and Description of Well; and

638  
639  
640  
641  
642  
643  
644  
645  
646  
647  
648  
649  
650  
651  
652  
653  
654  
655  
656  
657  
658  
659  
660  
661  
662  
663  
664  
665  
666  
667  
668  
669  
670  
671  
672  
673  
674  
675  
676  
677  
678  
679  
680  
681  
682  
683

(iv) A video log of the well inspection accompanied by a written description of the location, shape, and estimated size of any holes, breaches, corroded areas in the casing, if any, that includes:

(A) If any damage to the casing is found, a description of how defective areas will be repaired and if there is a need for additional well bond logging; or

(B) If well bond logging is not recommended, a description of the technical justification and an alternative means of certifying the adequacy of the well seal to protect the water source.

(h) Engineering design reports for new water treatment facilities shall include the following required elements:

(i) The information required in paragraph (a) of this Section;

(ii) A description of all water treatment chemical requirements, including dosage and feed rates, delivery, handling, and storage;

(iii) A description of automatic operation and control systems, including basic operation, manual override operation, and maintenance requirements; and

(iv) A description of the on-site laboratory facilities and a summary of those tests to be conducted on-site. If no on-site laboratory is provided, a description of plant control and water quality testing requirements, and where the testing will be conducted shall be included.

(i) Engineering design reports for water treatment facility modifications shall describe:

(i) The information required in paragraph (a) of this Section;

(ii) The purpose of the facility modification;

(iii) All proposed new equipment, tankage, and chemical treatment processes, including a description of the modification's effect on treatment system reliability, water quantity and quality; and

(iv) A listing of the new equipment design criteria and the associated chemicals.

(j) Engineering design reports for water main upsizing or looping projects shall describe the purpose of the water main upsizing or looping project and shall include the following required elements:

(i) The information required in paragraph (a) of this Section;

684  
685  
686  
687  
688  
689  
690  
691  
692  
693  
694  
695  
696  
697  
698  
699  
700  
701  
702  
703  
704  
705  
706  
707  
708  
709  
710  
711  
712  
713  
714  
715  
716  
717  
718  
719  
720  
721  
722  
723  
724  
725  
726  
727  
728  
729

(ii) Hydraulic analysis that demonstrates how peak hour, average day, maximum day, and maximum day plus fire flows, if fire flows are available, will be improved by upsizing; and

(iii) A table that summarizes the hydraulic model results.

(k) Engineering design reports for water main removal and replacements shall describe the purpose of the replacement and identify the existing main size, material type, and condition, and shall include the following required elements:

(i) The information required in paragraph (a) of this Section;

(ii) For any main replacement(s), the replacement main size, material type, and dimension ratio;

(iii) For projects that consist of main replacements in multiple discrete locations, an aerial image that shows all replacement pipeline segments, including new valves, with called-out pipe diameters and lengths;

(iv) A description of the protective measures that will be taken at locations where the new water main will cross a sewer or storm sewer when standard horizontal and vertical separations cannot be met; and

(v) For projects where asbestos cement may be encountered, a discussion of the disposal, or abandonment method to be used.

(l) Engineering design reports for new water mains shall describe the purpose of the new water main and shall include the information required in paragraph (a) of this Section. If the water main will provide service to a new development the engineering design report shall include the following required elements:

(i) The modeling result from a hydraulic analysis that demonstrates that the design will meet the requirements of Section 16(d)(i-ii) of this Chapter;

(ii) A demonstration that the hydraulic model was calibrated based on existing fire hydrant test flow data, when available, or based on modeling; and

(iii) Identification of any impacts the new fire flow demand will have on finished storage and pumping systems over the required fire flow duration.

#### **Section 10. Design Requirements for Preliminary Treatment and Redundancy.**

(a) 2018 TSS, parts 2.9-2.9(c), monitoring equipment; 2.10, sample taps; 2.11, facility water supply; and 2.14, piping color code are herein incorporated by reference.



730 (b) The proposed design shall demonstrate that the capacity of the water treatment or  
731 water production system is designed for the maximum daily demand at the design year based on  
732 historical usage records.

733  
734 (i) Where water use records are not available to establish water use, the  
735 design shall include an equivalent per capita water use of at least 125 gallons per day (gpd) for  
736 average daily water demand and 340 gpd for maximum daily water demand.

737  
738 (ii) The plant capacity design shall demonstrate consideration of:  
739  
740 (A) Maximum daily water demand;  
741  
742 (B) Agricultural water use;  
743  
744 (C) Industrial water use; and  
745  
746 (D) Filter backwash quantities. In the absence of data, filter backwash  
747 quantity shall be five percent of the maximum daily demand.

748  
749 (c) The structural design shall demonstrate consideration of:

750  
751 (i) The seismic zone;  
752  
753 (ii) Groundwater; and  
754  
755 (iii) Soil support that demonstrates:

756  
757 (A) The applicant has conducted soils investigations or has included  
758 documentation of adequate previous soils investigations used to develop the structural design;

759  
760 (B) Basin slabs have been designed to successfully resist the  
761 hydrostatic uplift pressure or include an area dewatering system; and

762  
763 (C) Consideration of long-span breakage in basins designed to resist  
764 uplift.

765  
766 (d) Proposed treatment facilities locations shall demonstrate that:

767  
768 (i) No sources of pollution will affect the quality of the water supply or  
769 treatment system;

770  
771 (ii) The facility location is not within 500 feet of landfills, garbage dumps, or  
772 wastewater treatment systems; and  
773

774 (iii) All treatment process structures, mechanical equipment, and electrical  
775 equipment will be protected, accessible, and remain fully operational during the maximum flood  
776 of record or the 100-year flood, whichever is greater.

777  
778 (e) Proposed treatment shall demonstrate that the facility will produce potable water  
779 that is bacteriologically, chemically, radiologically, and physically safe, as required by 40 CFR  
780 Part 141.

781  
782 (f) Designs for proposed treatment facilities with 100,000 gpd capacity and over shall  
783 include duplicate units, as a minimum, for chemical feed, flocculation, clarification,  
784 sedimentation, filtration, and disinfection.

785  
786 (g) Designs for proposed treatment facilities under 100,000 gpd capacity shall  
787 include:

- 788  
789 (i) Duplicate units as described in paragraph (f) of this Section; or  
790  
791 (ii) Finished water system storage equal to twice the maximum daily demand;  
792 and

793  
794 (iii) Demonstration of consideration of plant design flexibility to account for  
795 future changes in source water quality, unexpected need to modify process piping, service area  
796 expansion, changing treatment technologies, and equipment life cycles and upgrades.

797  
798 (h) All treatment facility pumping shall provide the maximum daily demand flow  
799 with the largest single-unit not in service. Finished water pumping in combination with finished  
800 water storage that floats on the distribution systems shall provide the maximum hourly demand  
801 with the largest single-unit not in service. For designs that include fire protection, pumping, and  
802 finished water storage that floats on the system shall provide the fire demand plus the maximum  
803 daily demand, or the maximum hourly demand, whichever is greater.

804  
805 (i) Where the finished water storage volume that floats on the distribution system is  
806 not capable of supplying the maximum daily demand, the proposed design shall include  
807 alternative power for the finished water pumps that demonstrates:

808  
809 (i) The combined finished water storage volume and pumping capacity  
810 supplied by alternative power will be at least adequate to provide the maximum daily demand;  
811 and

812  
813 (ii) The alternative power source will include engine generators, engine drive  
814 pumps, or a second independent electrical supply that will provide sufficient power to run the  
815 system.

816  
817 (j) Process equipment, filters and appurtenances, disinfection, chemical feed and  
818 storage, electrical and controls, and pipe galleries shall be located in suitable structures.

819

820 (k) All equipment not required to be in or on open basins, such as clarifier drives and  
821 flocculators, shall be located in heated, lighted, and ventilated structures.

822

823 (l) Piping shall be buried below frost level, placed in heated structures, or provided  
824 with heat and insulated.

825

826 (m) Structure entrances shall be above grade.

827

828 (n) Selected construction materials shall provide water tightness, corrosion  
829 protection, and resistance to weather variations.

830

831 (o) NSF/ANSI/CAN 61-2020/NSF/ANSI/CAN 600-2021 certified coatings used to  
832 protect structures, equipment, and piping shall be suitable for atmospheres containing moisture  
833 and low concentrations of chlorine.

834

835 (p) Surfaces exposed in chemical areas shall be protected from chemical attack.

836

837 (q) Paints shall not contain lead, mercury, or other toxic metals or chemicals.

838

839 (r) All enclosed spaces shall be provided with forced ventilation, except pumping  
840 station wetwells or clearwells that meet the following requirements:

841

842 (i) In areas where there are open treatment units exposed to the room,  
843 ventilation shall be provided to limit relative humidity to less than 85 percent but not less than  
844 six air changes per hour; and

845

846 (ii) Ventilation in electrical and equipment rooms shall limit the temperature  
847 rise in the room to less than 15 degrees Fahrenheit above ambient with at least six air changes  
848 per hour.

849

850 (s) Service transformers and other critical electrical equipment shall be located above  
851 the 100-year flood and above grade. Transformers shall be located so that they are remote or  
852 protected by substantial barriers from traffic. Motor controls shall be located in superstructures  
853 and in rooms that do not contain corrosive atmospheres.

854

855 (t) All treatment facilities shall have a flow-measuring device provided for raw water  
856 influent and clear well effluent and each shall provide totalized flow. The accuracy of the device  
857 shall be at least plus or minus two percent of span and shall meet the following requirements:

858

859 (i) Automatic controls shall be designed to permit manual override; and

860

861 (ii) The meter shall also record the instantaneous flow rate.

862

863 (u) Water treatment plants with a capacity of 500,000 gpd or more shall be provided  
864 with continuous water turbidimeters (including recorders) that demonstrate compliance with the

865 Guidance Manual for Compliance with the Surface Water Treatment Rules, Turbidity  
866 Provisions.

867

868 **Section 11. Source Development.**

869

870 (a) 2018 TSS, parts 3.1.4.1-3.1.4.1(i), surface water, structures, design of intake  
871 structures; 3.1.4.3-3.1.4.3(f) surface water, structures, offstream raw water storage reservoir;  
872 3.1.6-3.1.6.3, surface water, impoundments and reservoirs; 3.2.3.2, groundwater, location,  
873 continued sanitary protection; 3.2.4-3.2.4.14(b)(4), groundwater, general well construction;  
874 3.2.5-3.2.5.4, groundwater, testing and records; 3.2.6.1-3.2.6.1(c), groundwater, aquifer types  
875 and construction methods--special conditions, sand or gravel wells; 3.2.6.2-3.2.6.2(b)(7),  
876 groundwater, aquifer types and construction methods--special conditions, gravel pack material;  
877 3.2.6.4-3.2.6.4(d), groundwater, aquifer types and construction methods--special conditions,  
878 infiltration lines; 3.2.6.5-3.2.6.5(b), groundwater, aquifer types and construction methods--  
879 special conditions, limestone or sandstone wells; 3.2.7.3-3.2.7.3(c)(3), groundwater, well pumps,  
880 discharge piping and appurtenances, discharge piping; 3.2.7.4-3.2.7.4(d), groundwater, well  
881 pumps, discharge piping and appurtenances, pitless well units; 3.2.7.6, groundwater, well pumps,  
882 discharge piping and appurtenances, casing vent; 3.2.7.7-3.2.7.7(b), groundwater, well pumps,  
883 discharge piping and appurtenances, water level measurement; 3.2.7.8-3.2.7.8(b), groundwater,  
884 well pumps, discharge piping and appurtenances, observation wells; are herein incorporated by  
885 reference.

886

887 (b) Surface water intake structures that operate in the winter shall be capable of  
888 minimizing the formation of ice on the intake.

889

890 (c) Transmission lines and interconnecting process piping shall be capable of  
891 withstanding the forces and conditions they will be subject to and comply with the following  
892 specifications for water service, as applicable:

893

894 (i) AWWA C200;

895

896 (ii) AWWA C207;

897

898 (iii) AWWA C208;

899

900 (iv) AWWA C220;

901

902 (v) AWWA C228;

903

904 (vi) AWWA C300;

905

906 (vii) AWWA C301;

907

908 (viii) AWWA C302;

909

910 (ix) AWWA C303;

- 911
- 912 (x) AWWA C304;
- 913
- 914 (xi) AWWA C900;
- 915
- 916 (xii) AWWA C901;
- 917
- 918 (xiii) AWWA C903;
- 919
- 920 (xiv) AWWA C904;
- 921
- 922 (xv) AWWA C906;
- 923
- 924 (xvi) AWWA C907;
- 925
- 926 (xvii) AWWA C909;
- 927
- 928 (xviii) AWWA C950;
- 929
- 930 (xix) ASTM A53;
- 931
- 932 (xx) ASTM A134;
- 933
- 934 (xxi) ASTM A135;
- 935
- 936 (xxii) ASTM A139;
- 937
- 938 (xxiii) ASTM D2846;
- 939
- 940 (xxiv) ASTM F480;
- 941
- 942 (xxv) ASTM F645;
- 943
- 944 (xxvi) ASTM F877;
- 945
- 946 (xxvii) ASTM F23891;
- 947
- 948 (xxviii) ASTM F2806;
- 949
- 950 (xxix) ASTM F2855;
- 951
- 952 (xxx) ASTM F2969;
- 953
- 954 (xxxi) API 5L:
- 955
- 956 (A) Grade B;

- 957
- 958 (B) Grade X42;
- 959
- 960 (C) Grade X46;
- 961
- 962 (D) Grade X52;
- 963
- 964 (E) Grade X56;
- 965
- 966 (F) Grade X60;
- 967
- 968 (G) Grade X65;
- 969
- 970 (H) Grade X70; or
- 971
- 972 (I) Grade X80.
- 973

974 (d) Designs shall not include any customer service connection from the raw water  
 975 transmission line to the treatment plant unless there are provisions to treat the water to meet the  
 976 requirements of this Chapter, or the sole purpose of the service is for irrigation or agricultural  
 977 water use. For irrigation agricultural services, applicants shall conduct a hazard classification and  
 978 implement appropriate backflow prevention.

979  
 980 (e) Designs that include groundwater source development shall comply with the  
 981 following requirements:

982  
 983 (i) Proposed designs shall include a minimum of:

984  
 985 (A) Two wells that are each capable of supplying the average daily  
 986 demand with the largest producing well out of service;

987  
 988 (B) One well and finished water storage that together equal twice the  
 989 maximum daily demand; or

990  
 991 (C) For public water supplies that are not community water systems or  
 992 nontransient noncommunity water systems, as determined by the Administrator, one well that is  
 993 capable of supplying the maximum daily demand.

994  
 995 (ii) Wells shall maintain the following minimum isolation distances:

996  
 997 (A) If domestic wastewater is the only wastewater present and the  
 998 design domestic sewage flow is less than 2,000 gpd, the following minimum isolation distance  
 999 shall be maintained:

1000  
 1001 Table 1. Isolation Distances for Domestic Sewage Flows Less than 2,000 gpd  
 1002

| <u>Source of Domestic Wastewater</u>        | <u>Minimum Distance to Well</u> |
|---|---------------------------------|
| Storm and Sanitary Sewer Collection Systems | 50 feet                         |
| Septic tank                                 | 100 feet                        |
| Absorption system                           | 200 feet                        |

1003  
 1004 (B) If domestic wastewater is the only wastewater present and the  
 1005 design domestic sewage flow is greater than 2,000 gpd but less than 10,000 gpd, the following  
 1006 minimum isolation distances shall be maintained:

1007  
 1008 Table 2. Isolation Distances for Domestic Sewage Flows Greater than 2,000 gpd

| <u>Source of Domestic Wastewater</u>        | <u>Minimum Distance to Well</u> |
|---|---------------------------------|
| Storm and Sanitary Sewer Collection Systems | 50 feet                         |
| Septic tank                                 | 100 feet                        |
| Absorption system                           | 500 feet                        |

1009  
 1010 (C) If domestic wastewater is the only wastewater present and the  
 1011 design domestic sewage flow is greater than 10,000 gallons per day or non-domestic wastewater  
 1012 is present the required isolation distance shall be determined by a subsurface study, in  
 1013 accordance with the requirements of Water Quality Rules Chapter 3, Section 4, but shall not be  
 1014 less than those required in Tables 1 and 2 of this Section.

1015  
 1016 (iii) Wells shall maintain the following minimum isolation distances from  
 1017 buildings and property lines:

1018  
 1019 (A) When a well is outside of a building, the well shall be located so  
 1020 that the surface casing has a clearance radius of a minimum of 10 feet horizontally and will clear  
 1021 any projection from the building;

1022  
 1023 (B) When a well is located inside a building:

1024  
 1025 (I) The top of the casing and any other well opening shall not  
 1026 terminate in the basement of the building, or in any pit or space that is below natural ground  
 1027 surface unless the well is completed with a properly protected submersible pump or provided  
 1028 with provisions for drainage to the ground surface that is not subject to flooding by surface  
 1029 water;

1030  
 1031 (II) Wells located in a structure shall be accessible to pull the  
 1032 casing, pipe, or pump; and

1033  
 1034 (III) The structure shall have overhead access.

1035  
 1036 (C) Wells shall be located at least 50 feet from any property line.

1037  
1038 (iv) Applicants for wells shall complete testing and maintain records as  
1039 follows:

1040  
1041 (A) Yield and drawdown tests shall be performed on every production  
1042 well after construction or subsequent treatment and prior to placement of the permanent pump.  
1043 The test methods shall be clearly indicated in the specifications. The test pump capacity, at  
1044 maximum anticipated drawdown, shall be at least 1.5 times the design rate anticipated. The well  
1045 shall be test pumped at the desired yield (design capacity) of the well for at least 24 consecutive  
1046 hours after stabilized drawdown. Alternatively, the well may be pumped at a rate of 150 percent  
1047 of the desired yield for at least six continuous hours after stabilized drawdown.

1048  
1049 (B) Every well shall be tested for plumbness and alignment in  
1050 accordance with AWWA A100.

1051  
1052 (v) In addition to meeting the requirements of Section 8 of this Chapter, plans  
1053 for wells developed through acidizing activities shall also include the following elements:

1054  
1055 (A) Information on the geology of the area that contains descriptions  
1056 of:

1057  
1058 (I) Known or potential faults, fractures, springs, karst features  
1059 (such as sinkholes and other similar features) within a one-mile radius of the proposed well; and

1060  
1061 (II) Faults and fractures that may extend from the acidized zone  
1062 into overlying and underlying geologic formations and a description of any measures that will be  
1063 taken to ensure that the acidized solution does not migrate into any of those geologic formations.

1064  
1065 (B) For wells developed within a radius of one mile of existing wells,  
1066 applicants shall submit plans that analyze the risk and mitigation measures to be taken to prevent  
1067 impacts to those wells and the risk and mitigation measures for any potential effects to each  
1068 existing well;

1069  
1070 (C) Existing information on the location of other wells (such as water  
1071 supply, oil and gas, mineral development wells) within a one-mile radius of the proposed well,  
1072 including any wells that intercept the acidized zone, and for wells that intercept the acidized  
1073 zone:

1074  
1075 (I) An analysis of whether or not those wells that intercept the  
1076 acidized zone have been properly plugged and abandoned;

1077  
1078 (II) An analysis of whether or not those wells have been  
1079 properly cased and cemented; and

1080



1081 (III) A description of what measures will be or have been taken  
1082 to prevent the acidized solution from migrating vertically in the annular space or casing of the  
1083 existing wells into overlying or underlying geologic formations.

1084  
1085 (D) A description of the borehole drilling phase and what measures  
1086 will be taken to minimize the introduction of lost circulation materials into aquifers when  
1087 encountering under-pressured geologic formations or other factors that may lead to a loss of  
1088 circulation;

1089  
1090 (E) A description of the acid injection process and the measures that  
1091 will be taken to ensure that injection pressures do not create fractures in the overlying and  
1092 underlying geologic formations and through which the acidized solution may migrate;

1093  
1094 (F) A description of the volume and content of the acid and any other  
1095 chemical compounds to be used during acidizing activities, including the management of the acid  
1096 and chemical compounds prior to acidizing and final disposition of any acid, water, or chemical  
1097 mixtures recovered from the well after acidizing activities are completed;

1098  
1099 (G) A description of the measures that will be or have been taken to  
1100 ensure that the recovery of the acidized solution is of sufficient duration and volume to eliminate  
1101 the potential for acidic impacts to other wells completed within the injection zone; and

1102  
1103 (H) A description of the methods to be performed to establish the  
1104 placement and integrity of the annular seal and casing prior to acidization of the well.

1105  
1106 (vi) During any well construction or modification, the well and surrounding  
1107 area shall be adequately protected to prevent any groundwater contamination. Surface water shall  
1108 be diverted away from the construction area.

1109  
1110 (vii) All wells shall comply with the following construction standards:

1111  
1112 (A) Dug wells shall be constructed according to the State Engineer's  
1113 standards;

1114  
1115 (B) Drilled, driven, jetted, or bored wells shall have an unperforated  
1116 casing that extends from a minimum of 12 inches above the concrete surface and 18 inches  
1117 above natural ground surface and the design shall demonstrate compliance with Water Quality  
1118 Rules, Chapter 26, Section 8;

1119  
1120 (C) In gravel-packed wells or artificial filter-packed wells, aquifers  
1121 containing inferior quality water shall be sealed by pressure grouting, or with special packers or  
1122 seals, to prevent such water from moving vertically in gravel-packed portions of the well.  
1123 Gravel-packed wells shall meet the following sealing requirements:

1124

1125 (I) If a permanent surface casing is not installed, the annular  
1126 opening between the casing and the drill hole shall be sealed in the top 10 feet with concrete or  
1127 cement grout; or

1128  
1129 (II) If a permanent surface casing is installed, it shall extend to  
1130 a depth of at least 10 feet. The annular opening between this outer casing and the inner casing  
1131 shall be covered with a metal or cement seal.

1132  
1133 (D) When naturally flowing water is encountered in a well,  
1134 unperforated casing shall extend into the confining layer overlying the water-bearing zone. This  
1135 casing shall be adequately sealed with cement grout into the confining zone and shall extend at  
1136 least 10 feet into the target aquifer to prevent both surface and subsurface leakage from the  
1137 water-bearing zone. The method of construction shall be such that during the placing of the grout  
1138 and the time required for it to set, no water shall flow through or around the annular space  
1139 outside the casing, and no water pressure sufficient to disturb the grout prior to final set shall  
1140 occur. Drilling operations shall not be continued into the water-bearing zone until the grout has  
1141 set completely. If leakage occurs around the well casing or adjacent to the well, the well shall be  
1142 recompleted with any seals, packers, or casing necessary to eliminate the leakage completely.

1143  
1144 (I) Flowing wells shall be constructed to control the flow of  
1145 water from the well. The well grouting shall be engineered to prevent the movement of water  
1146 along the well casing and to prevent the migration of pressurized water into upper aquifers. A  
1147 flow control device shall be installed into the wellhead to control the flow of water from the well.  
1148 The well discharge or overflow line installations must connect to the well casing at least 12  
1149 inches above ground and be valved. The size of the air gap between the overflow line from the  
1150 well to drainage structure shall be twice the diameter of the well overflow pipe. Overflow water  
1151 must be drained and diverted to prevent ponding around the well casing.

1152  
1153 (II) There shall be no direct connection between any discharge  
1154 pipe and a sewer or other source of pollution.

1155  
1156 (E) If mineralized water or water known to be polluted is encountered  
1157 during the construction of a well, the aquifer or aquifers containing such inferior quality of water  
1158 shall be adequately cased or sealed off to prevent water from entering the well and to prevent  
1159 water from moving up or down the annular space.

1160  
1161 (I) For wells that penetrate multiple aquifers, mineralized  
1162 water shall be excluded from the well if water is taken from other, non-mineralized aquifers.

1163  
1164 (II) Applicants that propose to use mineralized water as a  
1165 public water supply shall demonstrate that any necessary treatment will comply with the drinking  
1166 water quality standards required by 40 CFR Part 141.

1167  
1168 (F) Existing oil or gas wells, private water wells, or exploration test  
1169 holes that can be completed to conform to all minimum construction standards required by this

1170 Chapter may be converted for use as a public water supply well. The permit application shall  
1171 identify all actions to be completed to achieve compliance with this Chapter.

1172  
1173 (viii) The minimum grout thickness for public water supply wells shall be  
1174 determined in accordance with AWWA Standard A100, part 4.7.8.3.

1175  
1176 (ix) Well seals shall meet the following requirements:

1177  
1178 (A) The annular space shall be sealed to protect against contamination  
1179 or pollution by the entrance of surface or shallow subsurface waters; and

1180  
1181 (B) Annular seals shall be installed to provide protection for the casing  
1182 against corrosion, to ensure the structural integrity of the casing, and to stabilize the upper  
1183 formation.

1184  
1185 (x) Upper terminal well designs that include a concrete floor shall  
1186 demonstrate a slope of one inch per foot away from the casing.

1187  
1188 (xi) Well pumps shall be located at a point above the top of the well screen.

1189  
1190 (xii) An accessible check valve that is not located in the pump column shall be  
1191 installed in the discharge line of each well between the pump and the shut-off valve. Additional  
1192 check valves shall be located in the pump column as necessary to prevent negative pressures on  
1193 the discharge piping.

1194  
1195 (xiii) A pitless adaptor or well house shall be used where needed to protect the  
1196 water system from freezing.

1197  
1198 (xiv) A frost pit may be used only in conjunction with a properly protected  
1199 pitless adaptor.

1200  
1201 (xv) Wells with diameters that are greater than four inches shall be equipped  
1202 with an air line for water level measurements or, in the case of a flowing artesian well, with a  
1203 pressure gauge that will indicate pressure.

1204  
1205 (xvi) An instantaneous and totalizing flow meter equipped with nonvolatile  
1206 memory shall be installed on the discharge line of each well in accordance with the  
1207 manufacturer's specifications. Meters installed on systems with variable frequency drives shall  
1208 be capable of accurately reading the full range of flow rates.

1209  
1210 (xvii) Test wells and groundwater sources that are sealed for plugging and  
1211 abandonment in accordance with requirements of Water Quality Rules Chapter 26, Section 11  
1212 shall be sealed by filling with neat cement grout. The filling materials shall be applied to the well  
1213 hole through a pipe, or tremie.

1214

1215 (xviii) Designs for groundwater sources that are subject to 40 CFR  
1216 141.402(a)(1)(i) and either 40 CFR 141.402(a)(1)(ii) or 40 CFR 141.402(a)(1)(iii) shall  
1217 demonstrate compliance with 40 CFR 141.402(e).

1218  
1219 (f) Facilities that include spring development shall meet the following requirements:  
1220

1221 (i) Spring collection systems shall be constructed to collect spring water  
1222 while preventing contamination of the source from the ground surface or other contaminant  
1223 sources.

1224  
1225 (ii) Seepage springs shall have a trench for the collection site that extends at  
1226 least six inches into the impervious layer, but not entirely through the impervious layer.  
1227 Concentrated springs shall be developed down to bedrock.

1228  
1229 (iii) A bed of clean and disinfected rock that extends the width of the spring  
1230 from which water is being collected shall be installed at the collection site.

1231  
1232 (iv) The collection site shall:

1233 (A) Be covered with 60 mil plastic sheeting or an equivalent puncture-  
1234 proof and water-proof barrier; and  
1235

1236 (B) Be protected from damage during back-fill and re-grading of the  
1237 site to the original surface elevation with protective fabric or sand.  
1238

1239  
1240 (v) Collecting walls shall be:

1241 (A) Constructed immediately downstream of the collection site; and  
1242

1243 (B) Made of concrete, or other material that meets the requirements of  
1244 Section 15(b)(ii) of this Chapter;  
1245

1246  
1247 (vi) The spring water collection pipe shall be installed in accordance with the  
1248 USDA NRCS Part 631 National Engineering Handbook, Chapter 32, part 631.3201(b)(iii) for  
1249 delivery pipes and shall meet the following requirements:

1250 (A) The size of the collection pipe shall be sufficient to convey the  
1251 flow of the spring; and  
1252

1253 (B) Pipe material and appurtenances shall comply with allowable well  
1254 construction material for water distribution in accordance with the standards listed in paragraph  
1255 (c) of this Section.  
1256

1257 (vii) Appropriate bedding and cover material shall protect the spring collection  
1258 system from damage and freezing.  
1259

1260

1261 (viii) The Administrator shall determine the spring protection area, based on the  
 1262 information submitted in the engineering design report required by Section 8 of this Chapter,  
 1263 which shall be no less than the isolation distances in (e)(ii) of this Section. The Administrator  
 1264 may require additional setback distances if the engineering design report demonstrates the  
 1265 additional distance is required to prevent contamination of the source from the ground surface or  
 1266 other contaminant sources.

1267  
 1268 (ix) All potential sources of contamination shall be removed from the spring  
 1269 protection area.

1270  
 1271 (x) The spring collection site shall include fencing or other protective features  
 1272 that are constructed and secured to exclude large animals and unauthorized persons from  
 1273 entering the protection area.

1274 (A) Fencing shall be designed to withstand animals and snow loading.  
 1275 Other protective systems may be proposed.

1276 (B) Fencing shall include an entry point to allow access by authorized  
 1277 persons for inspection and maintenance activities.

1278  
 1279 (xi) The spring collection site shall include a diversion ditch that is constructed  
 1280 on the upstream side of the spring collection site to route surface water flows away from the  
 1281 collection area. The diversion ditch shall be located a minimum of 10 feet away from the  
 1282 collection wall.  
 1283  
 1284

1285 (xii) The spring collection site shall be equipped to disinfect water prior to  
 1286 distribution and shall include sampling ports before and after the disinfection application point.  
 1287 The equipment shall be maintained and available to operate for its intended use.  
 1288

1289 (xiii) Spring box designs shall comply Section 15(a), (b), (f-j), and (l) of this  
 1290 Chapter. Combined spring box and finished water storage designs shall comply with Section 15  
 1291 of this Chapter.  
 1292

1293 (xiv) All designs for the spring collector box and collecting walls shall be  
 1294 performed by a Wyoming registered professional engineer. The plans or contractor furnished  
 1295 information shall be signed and sealed by a Wyoming registered professional engineer.  
 1296  
 1297

## 1298 **Section 12. Treatment.**

1299 (a) 2018 TSS, parts 4.2.1, 4.2.1(b)-(c), clarification, presedimentation; 4.2.2-4.2.2(c),  
 1300 clarification, coagulation; 4.2.4, 4.2.4(b)-4.2.4(d)(3), coagulation, sedimentation; 4.3.1.1,  
 1301 filtration, rapid rate gravity filters, pretreatment; 4.3.1.4-4.3.1.4(o), filtration, rapid rate gravity  
 1302 filters, structural details and hydraulics; 4.3.1.6-4.3.1.6(d)(2)(d), filtration, rapid rate gravity  
 1303 filters, filter material; 4.3.1.6(d)(4), filtration, rapid rate gravity filters, filter material, granular  
 1304 activated carbon (GAC); 4.3.1.6(e)-4.3.1.6(e)(1)(b), filtration, rapid rate gravity filters, filter  
 1305 material, support media; 4.3.3.6-4.3.3.6(b), filtration, diatomaceous earth filtration, pre-coat;  
 1306

1307 4.3.3.7-4.3.3.7(c), filtration, diatomaceous earth filtration, body feed; 4.3.3.8-4.3.3.8(e),  
 1308 filtration, diatomaceous earth filtration, filtration; 4.3.3.10- 4.3.3.10(a)(4), filtration,  
 1309 diatomaceous earth filtration, appurtenances; 4.3.4.2, filtration, slow sand filters, number;  
 1310 4.3.4.4, filtration, slow sand filters, rates of filtration; 4.3.4.5, filtration, slow sand filters,  
 1311 underdrains; 4.3.4.6-4.3.4.6(e), filtration, slow sand filters, filter material; 4.3.4.7, filtration, slow  
 1312 sand filters, filter gravel; 4.3.4.8, filtration, slow sand filters, depth of water on filter beds;  
 1313 4.3.4.9, 4.3.4.9(b), (e) and (f), filtration, slow sand filters, control appurtenances; 4.4.1- 4.4.1(b),  
 1314 disinfection, contact time, CT, and point(s) of application; 4.4.3- 4.4.3(d), disinfection, testing  
 1315 equipment; 4.4.4.3, disinfection, chlorine, automatic switch-over; 4.4.4.7, disinfection, chlorine,  
 1316 cross-connection protection; 4.4.4.8, disinfection, chlorine, pipe material; 4.4.5, disinfection,  
 1317 chloramines; 4.4.6.1, disinfection, ozone, design considerations; 4.4.6.2- 4.4.6.2(e), disinfection,  
 1318 ozone, feed gas preparation; 4.4.6.3- 4.4.6.3(d), disinfection, ozone, ozone generator; 4.4.6.4-  
 1319 4.4.6.4(b), disinfection, ozone, ozone contactors; 4.4.6.5-4.4.6.5(g), disinfection, ozone, ozone  
 1320 destruction unit; 4.4.6.6, disinfection, ozone, piping materials; 4.4.6.7-4.4.6.7(c), disinfection,  
 1321 ozone, joints and connections; 4.4.6.8-4.4.6.8(h), disinfection, ozone, instrumentation; 4.4.6.9-  
 1322 4.4.6.9(h), disinfection, ozone, alarms; 4.4.6.11-4.4.6.11(c), disinfection, ozone, construction  
 1323 considerations; 4.5.1, softening, lime or lime-soda process; 4.5.1.1, softening, lime or lime-soda  
 1324 process, hydraulics; 4.5.1.3, softening, lime or lime-soda process, chemical feed point; 4.5.1.4,  
 1325 softening, lime or lime-soda process, rapid mix; 4.5.1.5, softening, lime or lime-soda process,  
 1326 stabilization; 4.5.1.6-4.5.1.6(b), softening, lime or lime-soda process, sludge collection; 4.5.1.7,  
 1327 softening, lime or lime-soda process, sludge disposal; 4.5.1.8, softening, lime or lime-soda  
 1328 process, disinfection; 4.5.1.9, softening, lime or lime-soda process, plant start-up; 4.5.2.1,  
 1329 softening, cation exchange process, pre-treatment requirements; 4.5.2.2, softening, cation  
 1330 exchange process, design; 4.5.2.3, softening, cation exchange process, design; 4.5.2.4, softening,  
 1331 cation exchange process, depth of resin; 4.5.2.5, softening, cation exchange process, flow rates;  
 1332 4.5.2.7, softening, cation exchange process, underdrains and supporting gravel; 4.5.2.8,  
 1333 softening, cation exchange process, brine distribution; 4.5.2.9, softening, cation exchange  
 1334 process, cross-connection control; 4.5.2.10, softening, cation exchange process, bypass piping  
 1335 and equipment; 4.5.2.11, softening, cation exchange process, additional limitations; 4.5.2.13-  
 1336 4.5.2.13(f), softening, cation exchange process, brine and salt storage tanks; 4.5.2.14, softening,  
 1337 cation exchange process, salt and brine storage capacity; 4.5.2.15, softening, cation exchange  
 1338 process, brine pump or eductor; 4.5.2.18, softening, cation exchange process, construction  
 1339 materials; 4.5.2.19, softening, cation exchange process, housing; 4.5.3, softening, water quality  
 1340 test equipment; 4.6-4.6.14, anion exchange treatment; 4.7-4.7.11, aeration; 4.8, iron and  
 1341 manganese control; 4.8.1-4.8.1.3, iron and manganese control, removal by oxidation, detention  
 1342 and filtration; 4.8.2, iron and manganese control, removal by the lime-soda softening process;  
 1343 4.8.3-4.8.3(f), iron and manganese control, removal by manganese coated media filtration; 4.8.4,  
 1344 iron and manganese control, removal by ion exchange; 4.8.6-4.8.6(d), iron and manganese  
 1345 control, sequestration by polyphosphates; 4.8.7-4.8.7(e), iron and manganese control,  
 1346 sequestration by sodium silicates; 4.8.8, iron and manganese control, sampling taps; 4.9.3-  
 1347 4.9.3(e), stabilization and corrosion control, carbon dioxide addition; 4.9.5, 4.9.5(c)-4.9.5(c)(9),  
 1348 stabilization and corrosion control, phosphates, design; 4.9.6-4.9.6.1(c)(4), stabilization and  
 1349 corrosion control, pH/alkalinity adjustment; 4.10, taste and odor control; 4.10.1, taste and odor  
 1350 control, flexibility; 4.10.2, taste and odor control, chlorination; 4.10.3, taste and odor control,  
 1351 chlorine dioxide; 4.10.4-4.10.4(f), taste and odor control, powdered activated carbon; 4.10.8,  
 1352 taste and odor control, potassium permanganate; 4.11, membrane technologies for public water

1353 supplies; 4.11.1-4.11.1(c), membrane technologies for public water supplies, pilot  
1354 study/preliminary investigations; 4.11.2-4.11.2(l)(4), membrane technologies for public water  
1355 supplies, general design considerations; 4.11.3-4.11.3(h), membrane technologies for public  
1356 water supplies, systems treating surface water or GWUDI; 5.4.7-5.4.7(f), specific chemicals,  
1357 fluoride; 5.4.8, specific chemicals, activated carbon; 9.3-9.3(a)(2), precipitative softening sludge,  
1358 lagoons; 9.4.1-9.4.1(h), alum sludge, lagoons; 9.5-9.5.1(k), red water waste, sand filters; 9.5.2-  
1359 9.5.2(g), red water waste, lagoons; 9.5.3, red water waste, discharge to community sanitary  
1360 sewer; are herein incorporated by reference.

1361  
1362 (b) The capacity of the water treatment or water production system shall be designed  
1363 for the maximum daily demand at the design year.

1364  
1365 (c) Presedimentation shall be required for raw waters that have episodes of turbidity  
1366 in excess of 1,000 Nephelometric turbidity units (NTU) for a period of one week or longer.

1367  
1368 (d) Basins shall meet the following requirements:

1369  
1370 (i) Basins without mechanical sludge collection equipment shall have a  
1371 minimum detention time of three days;

1372  
1373 (ii) Basins with mechanical sludge collection equipment shall have a  
1374 minimum detention time of three hours;

1375  
1376 (iii) Basins shall have a bottom slope to drain of ¼ inch per foot without  
1377 mechanical sludge collection equipment and two inches per foot with mechanical sludge  
1378 collection equipment; and

1379  
1380 (iv) Basins shall have a minimum of one, eight-inch drain line to completely  
1381 dewater the facility.

1382  
1383 (e) Rapid dispersal of chemicals throughout the water shall be accomplished by  
1384 mechanical mixers, jet mixers, static mixers, or hydraulic jump and shall meet the following  
1385 requirements:

1386  
1387 (i) For mechanical mixers, the minimum Gt (velocity gradient (sec-1) x t  
1388 (sec)) provided at maximum daily flow shall be 27,000;

1389  
1390 (ii) The detention time in a flash mixing chamber shall not exceed 30 seconds  
1391 at maximum daily flow conditions; and

1392  
1393 (iii) The basin shall have a drain.

1394  
1395 (f) Flocculation shall comply with the following requirements:

1396  
1397 (i) Mechanical flocculators shall be used for low-velocity agitation of  
1398 chemically treated water.

- 1399
- 1400 (ii) The minimum detention time of 10 minutes shall be provided.
- 1401
- 1402 (iii) Basins shall have a minimum of one drain line to dewater the facility.
- 1403
- 1404 (iv) The velocity gradient (G value) shall be adjustable through the use of
- 1405 variable speed drives. The velocity gradient for single basin systems shall be 30 sec<sup>-1</sup>, 20 sec<sup>-1</sup>
- 1406 in the final basin of a two-stage system, and 10 sec<sup>-1</sup> in the final basin of a three-stage system.
- 1407
- 1408 (v) The tip speed for a single-speed drive system shall not exceed 3 feet per
- 1409 second (ft/sec). Variable speed drives shall provide tip speeds between 0.5 and 3.0 ft/sec.
- 1410
- 1411 (vi) The velocity of flocculated water through pipes or conduits to settling
- 1412 basins shall not be less than 0.5 ft/sec or greater than 1.5 ft/sec.
- 1413
- 1414 (g) Sedimentation basins shall comply with the following requirements:
- 1415
- 1416 (i) The maximum diameter in circular basins shall be 80 feet.
- 1417
- 1418 (ii) The minimum basin side water depth shall be eight feet if mechanical
- 1419 sludge collection equipment is provided or basin sludge hopper segments are less than 100
- 1420 square feet in surface area and 15 feet if basins are manually cleaned.
- 1421
- 1422 (iii) The outer walls of the settling basin shall extend at least 12 inches above
- 1423 the surrounding ground and provide at least 12 inches of freeboard to the water surface. Where
- 1424 the basin walls are less than four feet above the surrounding ground, a fence or other debris
- 1425 barrier shall be provided on the wall.
- 1426
- 1427 (iv) Basin bottoms shall slope toward the drain at not less than one inch per
- 1428 foot where mechanical sludge collection equipment is provided and ¼ inch per foot where no
- 1429 mechanical sludge collection equipment is provided.
- 1430
- 1431 (v) The basin overflow rate shall not exceed 1,000 gpd/ft<sup>2</sup> at design
- 1432 conditions.
- 1433
- 1434 (vi) Mechanical sludge collection shall be provided if settleable organics are
- 1435 present in the water or the source water exceeds secondary maximum contaminant levels
- 1436 identified at 40 CFR 143.3.
- 1437
- 1438 (vii) Pipes for removing sludge shall not be less than six inches in diameter and
- 1439 arranged to facilitate cleaning. Valves on sludge lines shall be located outside the tank.
- 1440
- 1441 (h) Facilities with softening sedimentation or clarification for softened groundwater
- 1442 sources shall meet the following requirements:
- 1443



1444 (i) The basin overflow rate shall not exceed 21,000 gpd/ft<sup>2</sup> at the design flow;  
1445 and

1446  
1447 (ii) Mechanical sludge removal shall be provided and shall be designed to  
1448 handle a load of 40 lbs/ft of collector scraper arm length.  
1449

1450 (i) Solids contact units are acceptable for combined softening and clarification of  
1451 well water where water quality characteristics are not variable and flow rates are uniform and  
1452 consistent. Solids contact units shall meet the requirements of paragraphs (c) and (e) of this  
1453 Section and may be considered under the following circumstances:  
1454

1455 (i) Solids contact units may be considered for use as clarifiers without  
1456 softening when they are designed as conventional sedimentation units; and  
1457

1458 (ii) Solids contact units may be used for other treatment processes such as  
1459 rapid mixing or flocculation when the individual components of the units are designed for that  
1460 specific treatment process.  
1461

1462 (j) Tube clarifiers that are horizontal or steeply inclined may be used when designed  
1463 as follows:  
1464

1465 (i) The maximum flow rate shall be less than 2.0 gpm/ft<sup>2</sup> based on the surface  
1466 area of the basin covered by the tubes;  
1467

1468 (ii) The top of the tubes shall be more than 12 inches from the underside of  
1469 the launder and more than 18 inches from the water surface and the spacing of the effluent  
1470 launder shall not be more than three times the distance from the water surface to the top of the  
1471 tube modules;  
1472

1473 (iii) Sludge shall be removed using 45-degree or steeper hoppers, or devices that remove settled sludge from  
1474 the basin floor using differential hydraulic level; and  
1475  
1476

1477 (iv) A method of tube cleaning shall be provided that may include provisions  
1478 for a rapid reduction in clarifier water surface elevation, a water jet spray system, or an air scour  
1479 system. If cleaning is automatic, controls shall cease clarifier operation during tube cleaning and  
1480 a 20-minute rest period.  
1481

1482 (k) Filtration systems shall comply with the following requirements:  
1483

1484 (i) Vertical or horizontal pressure filters shall not be used on surface waters.  
1485 Pressure filters may be used for groundwater filtration, including iron and manganese removal;  
1486

1487 (A) Slow rate sand filters may be used when maximum turbidity is less  
1488 than 50 NTU and the turbidity present is not caused by colloidal clay; and  
1489

- 1490 (B) Maximum color shall not exceed 30 units.  
 1491  
 1492 (ii) Washwater troughs shall comply with the following requirements:  
 1493  
 1494 (A) Washwater troughs shall not cover more than 25 percent of the  
 1495 filter area;  
 1496  
 1497 (B) The minimum distance between the bottom of the trough and the  
 1498 top of the unexpanded media shall be 12 inches;  
 1499  
 1500 (C) The minimum distance between the weir of the trough and the  
 1501 unexpanded media shall be 30 inches;  
 1502  
 1503 (D) There shall be no more than six feet clear distance between  
 1504 troughs;  
 1505  
 1506 (E) The trough and wastewater line shall be sized for a filter backwash  
 1507 rate of 20 gpm/ft<sup>2</sup> plus a surface wash rate of 2 gpm/ft<sup>2</sup>;  
 1508  
 1509 (F) The backwash system shall be sized to provide a minimum  
 1510 backwash flowrate of 20 gpm/ft<sup>2</sup> or a rate necessary to provide a 50 percent expansion of the  
 1511 filter bed;  
 1512  
 1513 (G) The system and wash water storage shall be designed to provide  
 1514 two, 20-minute washes in rapid succession and shall meet the following requirements:  
 1515  
 1516 (I) If only one filter is provided, the backwash system needs to  
 1517 provide only one 20-minute backwash; and  
 1518  
 1519 (II) If pumps are used to convey water to the filter(s) or to the  
 1520 wash water tank, two equivalent pumps shall be provided.  
 1521  
 1522 (H) Washwater shall be filtered and disinfected;  
 1523  
 1524 (I) The washwater rate shall be controlled on the main wash water line  
 1525 and the flowrates shall be metered and indicated;  
 1526  
 1527 (J) Air-assisted backwash systems may be used when the design  
 1528 precludes disturbing the gravel support and the minimum flowrate for air-assisted backwash shall  
 1529 be 12 gpm/ft<sup>2</sup>;  
 1530  
 1531 (K) A surface wash system shall be provided and shall meet the  
 1532 following requirements:  
 1533  
 1534 (I) The system shall be capable of supplying 0.5 gpm/ft<sup>2</sup> for a  
 1535 system with rotating arms and 2 gpm/ft<sup>2</sup> for fixed nozzles, at a minimum pressure of 50 psi; and

1536  
1537  
1538  
1539  
1540  
1541  
1542  
1543  
1544  
1545  
1546  
1547  
1548  
1549  
1550  
1551  
1552  
1553  
1554  
1555  
1556  
1557  
1558  
1559  
1560  
1561  
1562  
1563  
1564  
1565  
1566  
1567  
1568  
1569  
1570  
1571  
1572  
1573  
1574  
1575  
1576  
1577  
1578  
1579  
1580

(II) The surface wash can be air-assisted.

(L) Both backwash and surface wash supply systems shall be provided with adequate backflow prevention;

(iii) Single media beds shall use either clean crushed anthracite or a sand and anthracite mixture, the media shall have an effective size of 0.45 – 0.55 mm and a uniformity coefficient not greater than 1.65, and shall meet the following requirements:

(A) When gravel is used as supporting media, it shall consist of coarse aggregate in which most of it is round and of similar size and shape;

(B) Gravel as supporting media shall have sufficient strength and hardness to resist degradation during handling and use, be free of harmful materials and exceed the minimum density requirements; and

(C) The gravel shall also comply with AWWA B100 specifications.

(iv) Dual media coal sand filters shall consist of a coarse layer of coal not less than 15 inches deep above a layer of fine sand not less than eight inches deep on a torpedo sand or garnet layer of support not less than three inches on gravel support.

(v) Filter bottoms and strainer systems shall be limited to pipe, perforated pipe laterals, tile block, and perforated tile block. Perforated plate bottoms or plastic nozzles shall not be used.

(vi) Every filter shall have:

(A) Influent and effluent taps;

(B) A head loss gauge;

(C) An indicating effluent turbidimeter;

(D) A waste drain for draining the filter component to waste;

(E) A filter rate flow meter;

(F) Polymer feed facilities including polymer mixing, storage tank and at least one feed pump for each filter compartment; and

(G) Recorders on the turbidimeters if the facility has a capacity in excess of 0.5 MGD.

1581 (vii) Filter rate control shall be such that the filter is not surged. The filter rate  
 1582 of flow shall not change more than 0.3gpm/ft<sup>2</sup> per minute. A filter that stops and restarts during a  
 1583 cycle shall have a filter-to-waste system installed. Declining flow rate filters shall not be used  
 1584 unless the flow rate for each filter is controlled to a rate less than allowed in paragraph (j)(iii) of  
 1585 this Section and there are four more individual filters.

1586  
 1587 (viii) A filter to waste cycle shall be provided after the filter backwash  
 1588 operation. The filter to waste cycle shall be at least 10 minutes.

1589  
 1590 (ix) Multi-media filter beds shall contain a depth of fine media made up of  
 1591 anthracite (specific gravity 1.5), silica sand (specific gravity 2.6), and garnet sand or ilmenite  
 1592 (specific gravity 4.2-4.5). The bed depths and distribution shall be determined by the water  
 1593 quality and shall meet the following requirements:

1594  
 1595 (A) There shall not be less than 10 inches of fine sand and 24 inches of  
 1596 anthracite;

1597  
 1598 (B) The relative size of the media shall be such that the hydraulic  
 1599 grading of the material during backwash will result in a pore space that progressively goes from  
 1600 coarse to fine in the direction of flow;

1601  
 1602 (C) The multi-media shall be supported on two layers of special high-  
 1603 density gravel placed above the conventional silica gravel supporting bed;

1604  
 1605 (D) The special gravel shall have a specific gravity not less than 4.2;

1606  
 1607 (E) The bottom layer shall consist of particles passing U.S. Standard 5  
 1608 mesh sieves and retained in U.S. Standard 12 mesh sieves and shall be 1 ½ inches thick; and

1609  
 1610 (F) The top layer shall consist of particles passing U.S. Standard 12  
 1611 mesh sieves and retained in U.S. Standard 20 mesh sieves and shall be 1 ½ inches thick.

1612  
 1613 (x) Diatomaceous earth filtration shall comply with the following  
 1614 requirements:

1615  
 1616 (A) Diatomaceous earth filters may be used under the following  
 1617 circumstances:

1618  
 1619 (I) To remove turbidity from surface waters where turbidities  
 1620 entering the filters do not exceed 10 NTU and where total raw water coliforms do not exceed 100  
 1621 organisms/100 mL;

1622  
 1623 (II) Where the raw water quality exceeds the previously  
 1624 mentioned limits when flocculation and sedimentation are used preceding the filters; and

1625  
 1626 (III) To remove iron from groundwaters.

1627  
1628 (B) The proposed diatomaceous earth filtration shall include pressure  
1629 or vacuum type units; and  
1630

1631 (C) A precoating system shall be provided.  
1632

1633 (D) The proposed diatomaceous earth filtration shall include a  
1634 continuous monitoring turbidimeter with recorder on each filter effluent for plants treating  
1635 surface water.  
1636

1637 (l) All designs that propose supplies of surface water, groundwater under the direct  
1638 influence of surface water, and groundwater that does not meet 40 CFR Part 141 or where other  
1639 treatment is provided, shall include disinfection via one of the following methods:  
1640

1641 (i) Chlorine;  
1642

1643 (ii) Chloramines, recommended only for secondary disinfection;  
1644

1645 (iii) Chlorine dioxide;  
1646

1647 (iv) Ozone;  
1648

1649 (v) Ultraviolet light; or  
1650

1651 (vi) Other disinfecting agents that demonstrate reliable application equipment  
1652 is available and that include testing procedures for a residual that is recognized in Standard  
1653 Methods for the Examination of Water and Wastewater 2018.  
1654

1655 (m) All designs that require disinfection shall demonstrate that:  
1656

1657 (i) The system will maintain a detectable residual throughout the distribution  
1658 system; and  
1659

1660 (ii) The applicant has considered the formation of disinfection byproducts  
1661 when selecting the disinfection.  
1662

1663 (n) Disinfection equipment shall comply with the following requirements:  
1664

1665 (i) Chlorination equipment shall comply with NSF/ANSI/CAN 61-  
1666 2020/NSF/ANSI/CAN 600-2021 and the following requirements:  
1667

1668 (A) Positive displacement pumps shall be provided for solution feed  
1669 gas chlorinators or hypochlorite feeders;  
1670

1671 (B) The chlorine solution injector/diffuser shall provide a rapid and  
1672 thorough mix with all the water being treated;

1673  
 1674  
 1675  
 1676  
 1677  
 1678  
 1679  
 1680  
 1681  
 1682  
 1683  
 1684  
 1685  
 1686  
 1687  
 1688  
 1689  
 1690  
 1691  
 1692  
 1693  
 1694  
 1695  
 1696  
 1697  
 1698  
 1699  
 1700  
 1701  
 1702  
 1703  
 1704

(C) If the application point is to a pipeline discharging to a clearwell, the chlorine shall be added to the center of the pipe at least 10 pipe diameters upstream of the discharge into the clearwell;

(D) Gas chlorinators shall comply with the following requirements:

(I) The injector/eductor shall be selected based on solution pressure, injector water flowrate, feed point backpressure, and chlorine solution line length and size;

(II) The maximum feed point backpressure shall not exceed 110 psi unless a chlorine solution pump is used; and

(III) Gauges shall be provided for chlorine solution pressure, feed water pressure, and chlorine gas pressure or vacuum.

(E) Standby equipment of sufficient capacity shall be available to replace the largest chlorinator unit. Well systems providing no treatment other than disinfection are exempt from the requirements of this paragraph (E) and are not required to provide standby chlorination equipment.

(ii) Points of application and contact time shall comply with the following requirements:

(A) Filtration types shall comply with the contact time and minimum chlorine residuals required in Table 3 of this Section after the appropriate baffling factor has been applied to the reactor. Contact times assume a baffling factor of 0.1 unless documentation justifying the use of a higher baffling factor is provided. Contact time requirements are based on worst-case operating conditions of water temperature of 32.9 degrees Fahrenheit and pH of 9.

Table 3. Required Contact Time and Residual by Filtration Type

| <b>Filtration Type</b>  | <b>Required Contact Time (minutes), 0.4 mg/L minimum chlorine residual</b> | <b>Required Contact Time (minutes), 1.0 mg/L minimum chlorine residual</b> |
|---|--|--|
| Conventional Filtration   | 162.5  | 73   |
| Direct Filtration, Bag or Cartridge Filtration, Slow Sand Filtration, Diatomaceous Earth Filtration | 325  | 146  |
| Membrane Filtration (MF or UF)  | 30   | 12   |

1705  
 1706

1707 (B) When chlorine is applied to a groundwater source to maintain a  
 1708 residual, no contact time is required.

1709  
 1710 (o) Systems that propose disinfection via ultraviolet light shall comply with the  
 1711 following requirements:

1712  
 1713 (i) Proposed designs for ultraviolet light shall include the following  
 1714 information in the ultraviolet reactor influent water quality analysis:

- 1715 (A) Influent temperature (degrees Fahrenheit);
- 1716 (B) UV transmittance (UVT) at a reported wavelength of 254 nm and a  
 1717 pathlength of 1 cm;
- 1718 (C) A description of the UVT range over a 12-month period;
- 1719 (D) Total hardness (mg/L as CaCO<sub>3</sub>);
- 1720 (E) pH;
- 1721 (F) Alkalinity (mg/L as CaCO<sub>3</sub>);
- 1722 (G) Total iron (mg/L) influent < 0.3mg/L;
- 1723 (H) Calcium (mg/L); and
- 1724 (I) Total manganese (mg/L) influent <0.03 mg/L

1725  
 1726 (ii) Proposed designs for ultraviolet disinfection systems shall include the  
 1727 following information:

- 1728 (A) The maximum, average, and minimum flowrates;
- 1729 (B) A matrix that identifies paired flow and ultraviolet treatment  
 1730 values;
- 1731 (C) A description of the organisms targeted for inactivation;
- 1732 (D) Log inactivation requirements;
- 1733 (E) Operating approach (UV intensity vs. calculated dose);
- 1734 (F) Maximum and minimum operating pressures;
- 1735 (G) Maximum pressure at the UV reactor;

1752

- 1753 (H) UV system redundancy;  
 1754  
 1755 (I) Lamp cleaning strategy;  
 1756  
 1757 (J) Mercury trap for broken UV lamps;  
 1758  
 1759 (K) Maximum headloss through the UV reactor;  
 1760  
 1761 (L) A demonstration that the UV reactor(s) shall be hydrostatically  
 1762 tested to 1.5 times the rated operating pressure;  
 1763  
 1764 (M) A demonstration that the UV reactor(s) shall be designed to ensure  
 1765 that plant personnel can change lamps and the UV intensity meter without draining the reactor;  
 1766 and  
 1767  
 1768 (N) A demonstration that the units shall meet NSF/ANSI/CAN  
 1769 Standard 61.  
 1770  
 1771 (iii) Ultraviolet treatment systems shall be designed to comply with the  
 1772 Ultraviolet Disinfection Guidance Manual for the Final LT2ESWTR and the following dose  
 1773 requirements:  
 1774  
 1775 (A) The UV disinfection system shall deliver a validated dose that  
 1776 meets or exceeds the required dose at the end of lamp life, with fouled sleeves.  
 1777  
 1778 (B) The minimum required validated dose used for system design shall  
 1779 incorporate a Combined Age and Fouling Factor (CAF), calculated as:  
 1780  
 1781 
$$\text{CAF} = \text{EOLL} \times \text{FF}.$$
  
 1782  
 1783 EOLL is the ratio of the lamp output at the end of life relative to the new  
 1784 lamp output  
 1785  
 1786 FF is the fouling factor.  
 1787  
 1788 (C) The EOLL shall be 75 percent of the new lamp output.  
 1789  
 1790 (D) The FF shall be:  
 1791  
 1792 (I) 0.5 for UV systems with no sleeve wiping system;  
 1793  
 1794 (II) 0.75 for UV systems with mechanical wiping only; or  
 1795  
 1796 (III) 0.95 for UV systems with a combined online chemical and  
 1797 mechanical cleaning.  
 1798



1799 (E) The validated dose that meets or exceeds the required dose shall be  
1800 delivered under maximum flow and design (UVT) condition, when the larger UV unit is out of  
1801 service.

1802  
1803 (iv) Ultraviolet disinfection shall comply with the following validation  
1804 requirements:

1805  
1806 (A) The applicant shall submit the manufacturer’s bioassay validation  
1807 report for the proposed UV reactor with the permit application;

1808  
1809 (B) The bioassay testing and results shall demonstrate validation by an  
1810 independent third party in full compliance with the Ultraviolet Disinfection Guidance Manual for  
1811 the Final LT2ESWTR;

1812  
1813 (C) The owner and engineer shall submit a certification to the  
1814 Administrator if validation requirements are adjusted and identify each of the equipment and  
1815 system modifications required to ensure that the appropriate dosage is provided for the  
1816 inactivation requirements;

1817  
1818 (D) Bioassay testing shall evaluate reactor performance over the range  
1819 of:

1820  
1821 (I) Flowrates (maximum, average, and minimum);

1822  
1823 (II) UVT from 70 percent to 98 percent (measured at 254 nm, 1  
1824 cm path length); and

1825  
1826 (III) RED at maximum flowrate and design UVT conditions.

1827  
1828 (E) The bioassay testing shall incorporate the range of design and  
1829 operating conditions described in paragraph (o)(i) of this Section for UV Light;

1830  
1831 (F) Extrapolations to flowrates, UV transmittance values, or UV doses  
1832 outside the range actually tested, are not permitted; and

1833  
1834 (G) Bioassay testing shall also verify that the head loss generated by  
1835 the proposed reactor is less than or equal to the specified limits.

1836  
1837 (v) Ultraviolet disinfection hydraulics shall comply with the following  
1838 requirements:

1839  
1840 (A) The inlet and outlet piping configuration to the UV reactor shall  
1841 result in a UV dose delivery that is equal to or greater than the dose delivered when the UV  
1842 reactor was validated;

1843

1844 (B) If the UV reactor validation is performed off-site, the applicant  
1845 shall refer to the validation report to determine the validated inlet and outlet conditions that apply  
1846 to the site-specific requirements; and

1847  
1848 (C) Ultraviolet hydraulic piping shall comply with at least one of the  
1849 following requirements:

1850  
1851 (I) The piping configuration shall consist of a minimum of 10  
1852 pipe diameters of straight pipe upstream and five pipe diameters of straight pipe downstream of  
1853 the UV reactors, with additional pipe diameters above the minimum if required by the  
1854 manufacturer's guidelines for electromagnetic or other flowmeter installation;

1855  
1856 (II) The inlet and outlet piping configurations shall be identical  
1857 to those constructed for the UV reactor validation; or

1858  
1859 (III) If on-site validation or custom off-site validation is  
1860 planned, the inlet and outlet piping hydraulics must be designed according to the manufacturer's  
1861 recommendations and to accommodate any site-specific constraints.

1862  
1863 (vi) Ultraviolet control and measurement instrumentation for each reactor shall  
1864 comply with the following requirements:

1865  
1866 (A) Each reactor shall be capable of measuring UV intensity and lamp  
1867 status (on/off);

1868  
1869 (B) For systems that use the calculated dose monitoring strategy, each  
1870 reactor shall be capable of measuring or calculating the UV transmittance;

1871  
1872 (C) Piping for each UV reactor shall be sized and configured in  
1873 accordance with the validated operating conditions and maintain equal head loss through each  
1874 reactor over the range of validated flowrates. Each UV reactor shall not be by-passed;

1875  
1876 (D) Each UV reactor train shall have a dedicated flow meter to confirm  
1877 the validated operating conditions;

1878  
1879 (E) UV lamps in the UV reactor shall be submerged at all times during  
1880 operation;

1881  
1882 (F) The specific configuration of the UV reactor(s) within a facility  
1883 will dictate the use of air release, air/vacuum, or combination air valves to prevent air pockets  
1884 and negative pressure conditions and the design shall verify that the UV manufacturer was  
1885 consulted to determine any equipment-specific air release and pressure control valve  
1886 requirements;

1887  
1888 (G) Each UV reactor shall have the piping configured so that it can be  
1889 isolated and removed from service while the other UV reactor(s) remain in service; and

1890  
1891 (H) A booster pump shall be used if the head loss constraints indicate  
1892 that a pump is necessary. The UV reactor shall be sized accordingly.  
1893

1894 (vii) The applicant shall describe the dose monitoring strategy and the  
1895 operational approach for the UV reactor that complies with the approaches described in  
1896 Ultraviolet Disinfection Guidance Manual for the Final LT2ESWTR, part 3.5.2.  
1897

1898 (viii) The cleaning system for each UV reactor shall comply with the following  
1899 requirements:  
1900

1901 (A) Each UV reactor shall be equipped with an automatic online  
1902 mechanical lamp sleeve cleaning system and may include optional chemical cleaning;  
1903

1904 (B) The UV sensor shall include mechanical cleaning capabilities with  
1905 an automatically initiated and controlled cleaning cycle; and  
1906

1907 (C) The UV reactor(s) shall be fully operational and shall provide  
1908 validated dose requirements during system cleaning.  
1909

1910 (ix) The minimum spare parts kept at a facility shall include the following:  
1911

1912 (A) 20 percent of the UV Lamps;  
1913

1914 (B) Five percent of the lamp sleeves; and  
1915

1916 (C) One UV intensity sensor.  
1917

1918 (p) Facilities that propose disinfection via fluoridation and defluoridation shall  
1919 comply with the following requirements:  
1920

1921 (i) Fluoride storage designs shall demonstrate that:  
1922

1923 (A) Fluoride storage tanks shall be covered;  
1924

1925 (B) All other storage shall be inside a building; and  
1926

1927 (C) Storage tanks of hydrofluorosilicic acid shall be vented to the  
1928 atmosphere at a point outside the building.  
1929

1930 (ii) Fluoride feed equipment shall meet the following requirements:  
1931

1932 (A) There shall be scales or weight loss recorders for dry chemical  
1933 feeds and the feeders shall be accurate to within five percent of any desired feed rate;  
1934

- 1935 (B) The application of hydrofluorosilicic acid, if into a horizontal pipe,  
1936 shall be in the lower half of the pipe;  
1937
- 1938 (C) Fluoride compounds shall not be added before lime soda or ion  
1939 exchange softening;  
1940
- 1941 (D) A fluoride solution shall be applied by a positive displacement  
1942 pump;  
1943
- 1944 (E) The solution shall not be injected into a point of negative pressure;  
1945
- 1946 (F) All fluoride feed lines and dilution water lines shall be isolated  
1947 from the potable water supplies by either an air gap above the solution tank or a reduced pressure  
1948 principal backflow preventer;  
1949
- 1950 (G) Water used for sodium fluoride solution shall have a hardness not  
1951 exceeding 45 mg/L; and  
1952
- 1953 (H) Flow meters for treated water flow and fluoride solution water  
1954 shall be provided.  
1955
- 1956 (iii) Provisions shall be made to allow the transfer of dry fluoride compounds  
1957 from shipping containers to storage bins or hoppers that minimize the quantity of fluoride dust  
1958 that enters the room where the equipment is installed and shall meet the following requirements:  
1959
- 1960 (A) The transfer system shall be equipped with an exhaust fan and dust  
1961 filter that places the hopper or storage bin under negative pressure;  
1962
- 1963 (B) Air exhausted from fluoride handling equipment shall discharge  
1964 through a dust filter to the atmosphere outside the building and shall not discharge within 50 feet  
1965 of a fresh air intake for the building; and  
1966
- 1967 (C) A floor drain shall be provided for cleaning equipment and  
1968 maintenance.  
1969
- 1970 (iv) The following methods are acceptable for fluoride removal:  
1971
- 1972 (A) Activated alumina may be used in open gravity filters or pressure  
1973 filter tanks;  
1974
- 1975 (B) The minimum media depth shall be five feet;  
1976
- 1977 (C) The loading rate shall not exceed 4 gpm/ft<sup>2</sup>;  
1978
- 1979 (D) The mesh size for the alumina media shall be between #28 and  
1980 #48;

- 1981 (E) Media regeneration facilities shall be provided and shall include  
1982 both weak caustic and weak acid systems; and  
1983  
1984 (F) Bone char filtration or lime softening with magnesium addition  
1985 may be used.  
1986  
1987 (v) Water that is unstable due either to natural causes or to subsequent  
1988 treatment shall be stabilized.  
1989  
1990 (vi) Facilities shall have the capability of feeding both acid and alkalinity.  
1991  
1992 (vii) Unstable water created by ion exchange softening shall be stabilized by an  
1993 alkali feed.  
1994  
1995 (viii) Laboratory equipment shall be provided to determine the effectiveness of  
1996 stabilization treatment. This shall include testing equipment for hardness, calcium, alkalinity, pH,  
1997 and magnesium at a minimum.  
1998  
1999 (q) Taste and odor control equipment shall comply with the following requirements:  
2000  
2001 (i) Open or closed, granular activated carbon adsorption units may be used to  
2002 absorb organics for taste and odor control, subject to the following requirements:  
2003  
2004 (A) The loading rate shall not exceed 10 gpm/ft<sup>2</sup>;  
2005  
2006 (B) The minimum empty bed contact time shall be 20 minutes;  
2007  
2008 (C) The pH of the water shall be less than 9.0 with a turbidity of less  
2009 than 2 NTU when using packed beds;  
2010  
2011 (D) There shall be provisions for moving the carbon to and from the  
2012 contactors;  
2013  
2014 (E) Contactors may be upflow or downflow design. A single unit is  
2015 acceptable for countercurrent upflow designs. Downflow designs shall have two or more parallel  
2016 units;  
2017  
2018 (F) Contactors shall be designed as open gravity or pressure bed;  
2019  
2020 (G) Pressure contactors shall have an air-vacuum relief valve fitted  
2021 with a stainless-steel screen to prevent plugging;  
2022  
2023 (H) The contactor materials of construction shall be concrete, steel, or  
2024 fiberglass-reinforced plastic and shall meet the following requirements:  
2025  
2026 (I) Steel vessels shall be protected against corrosion; and

- 2027  
2028 (II) Inlet and outlet screens shall be made of stainless steel or  
2029 other suitable materials.  
2030  
2031 (I) There shall be provisions for flow reversal and bed expansion that  
2032 meet the following requirements:  
2033  
2034 (I) Backwashing facilities shall provide up to 50 percent bed  
2035 expansion; and  
2036  
2037 (II) Backwashing facilities shall meet the backwash criteria as  
2038 rapid filters.  
2039  
2040 (ii) If ozone is used for taste and odor control, there shall be at least 10  
2041 minutes of contact time to complete all reactions and the minimum applied feed rate of ozone  
2042 shall be 1 mg/L, or the design shall identify a contact time and feed rate that demonstrate the  
2043 application of ozone will not cause an exceedance of the maximum contaminant levels identified  
2044 at 40 CFR 143.3.  
2045  
2046 (r) Designs that include the addition of phosphates for stabilization and corrosion  
2047 control shall demonstrate the evaluation of reactions with aluminum and impacts on wastewater  
2048 treatment plants to overcome the secondary impacts of phosphates that may potentially limit  
2049 their use.  
2050  
2051 (s) Designs that propose anion-exchange treatment shall include a pH/alkalinity feed  
2052 system unless otherwise approved by the Administrator.  
2053  
2054 (t) Microscreens shall comply with the following requirements:  
2055  
2056 (i) A microscreen shall be allowed as a supplement to treatment, but it shall  
2057 not be used in place of filtration or coagulation;  
2058  
2059 (ii) The screen shall be capable of removing suspended matter from the water  
2060 by straining;  
2061  
2062 (iii) Screens shall be made of corrosion-resistant material;  
2063  
2064 (iv) Bypass piping around the unit shall be provided;  
2065  
2066 (v) There shall be protection against back siphonage when potable water is  
2067 used for washing the screen; and  
2068  
2069 (vi) Wash water shall be wasted and not recycled to the microscreen.

2070  
2071  
2072  
2073  
2074  
2075  
2076  
2077  
2078  
2079  
2080  
2081  
2082  
2083  
2084  
2085  
2086  
2087  
2088  
2089  
2090  
2091  
2092  
2093  
2094  
2095  
2096  
2097  
2098  
2099  
2100  
2101  
2102  
2103  
2104  
2105  
2106  
2107  
2108  
2109  
2110  
2111  
2112  
2113  
2114  
2115

(u) Membrane technologies shall comply with the following requirements:

(i) Proposed membrane treatment processes shall comply with the requirements of Section 6 of this Chapter. Protocols for pilot plant testing shall incorporate guidance or procedures from the US EPA Membrane Filtration Guidance Manual, Chapter 6.

(ii) All proposed membrane filters shall demonstrate third-party validation for the removal of Giardia or Cryptosporidium. Removal efficiency shall be determined through challenge testing as outlined in the US EPA Membrane Filtration Guidance Manual and one of the following:

(A) Membranes that are used as final compliance filters of a multiple treatment barrier approach shall meet the requirements of 40 CFR Part 141; or

(B) All surface water or groundwater under direct influence (GWUDI) systems using membrane technology shall demonstrate minimum disinfection that meets 4.0-log virus inactivation.

(v) Facilities that propose bag and cartridge filters shall comply with the procedures identified in Section 6 of this Chapter and the following requirements:

(i) Filter performance will be based on Cryptosporidium oocyst removal;

(ii) The filter shall demonstrate at least a 3-log removal of particle size 1 micron and above with an associated log reduction credit of 2-logs for Giardia and Cryptosporidium;

(iii) Removal efficiency shall be determined through challenge testing as outlined in Toolbox Guidance Manual, Chapter 8 and NSF/ANSI 419-2018;

(iv) The performance demonstration shall be specific to the corresponding housing and type or model of filter. Any other combination of housing and filter that could be used for treatment shall also demonstrate filter efficiency;

(v) Applicants shall include documentation that the proposed bag or cartridge filter has received third-party validation for the removal of Giardia and Cryptosporidium;

(vi) Filter and housing specifications shall include a description of the materials of construction, surface area per filter, and the minimum and maximum operating pressure, and the specifications shall meet the requirements of NSF/ANSI 419-2018 and the Toolbox Guidance Manual, Chapter 8;

(vii) System components such as housing, bags, cartridges, gaskets, and O-rings shall comply with NSF/ANSI/CAN 61 for leaching of contaminants;

- 2116 (viii) A means for monitoring the performance of the filter shall be provided and  
2117 shall include at a minimum flow meters and valves, pressure gauges, and sample taps;  
2118
- 2119 (ix) The proposed design shall specify chemical compatibility limitations;  
2120
- 2121 (x) A minimum of two filter housings shall be provided;  
2122
- 2123 (xi) Bag or cartridge filters that are used as final compliance filters of a  
2124 multiple treatment barrier approach shall meet the requirements of 40 CFR Part 141; and  
2125
- 2126 (xii) All surface water or GWUDI systems using bag or cartridge filter  
2127 technology shall provide at minimum disinfection that meets 4.0-log virus inactivation and 1.0-  
2128 log Giardia inactivation or shall demonstrate that combined filtration and disinfection will  
2129 provide 3-log removal.  
2130
- 2131 (w) Pre-engineered water treatment plants shall comply with the following  
2132 requirements:  
2133
- 2134 (i) Pre-engineered water treatment plants shall be permitted on a case-by-case  
2135 basis for specific process applications and flow rates. Multiple units may be installed in parallel  
2136 to accommodate flow rates;  
2137
- 2138 (ii) Pre-engineered water treatment plant equipment shall be designed in  
2139 accordance with NSF/ANSI/CAN 61 and NSF/ANSI/CAN 372;  
2140
- 2141 (iv) Pre-engineered water treatment plants shall comply with the procedures in  
2142 Section 6 of this Chapter to obtain data that demonstrates the treatment effectiveness of the  
2143 treatment for the source water and the proposed application; and  
2144
- 2145 (v) Each component and process of the pre-engineered water treatment plant  
2146 shall demonstrate compliance with the applicable design criteria of the respective treatment  
2147 processes of this Chapter.  
2148
- 2149 (x) Wastes shall be handled and disposed of as follows:  
2150
- 2151 (i) The sanitary and laboratory waste from water treatment plants, pumping  
2152 stations, or well systems, shall not be recycled to any part of the water plant, and shall be  
2153 discharged directly into a sanitary sewer when feasible or a permitted on-site disposal system;  
2154
- 2155 (ii) Brine waste from ion exchange plants, demineralization plants, and other  
2156 similar facilities may not be recycled to the water plant and shall meet the following  
2157 requirements:  
2158
- 2159 (A) Where discharging to a sanitary sewer, a holding tank shall be  
2160 provided to prevent the overloading of the sewer and interference with the waste treatment  
2161 process; and



2162  
2163 (B) Where disposal to an off-site waste treatment system is proposed,  
2164 the sewer and treatment facility shall have the required capacity and dilution capability.

2165  
2166 (iii) Acceptable methods of treatment and disposal of lime softening sludge  
2167 are:

2168  
2169 (A) Sludge lagoons, provided that the design of sludge lagoons  
2170 includes:

2171  
2172 (I) The location of the lagoon shall be protected from the 100-  
2173 year flood;

2174  
2175 (II) A means of diverting surface water runoff so that it does  
2176 not flow into the lagoon;

2177  
2178 (III) The freeboard shall be a minimum of three feet;

2179  
2180 (IV) An adjustable decanting device for recycling the overflow;

2181 and

2182  
2183 (V) An accessible effluent sampling point.

2184  
2185 (B) Land application of liquid lime softening sludge that demonstrates  
2186 compliance with Water Quality Rules Chapter 11, Part E;

2187  
2188 (C) Disposal at a landfill;

2189  
2190 (D) Mechanical dewatering of sludge may be used;

2191  
2192 (E) Recalcination of sludge may be used; and

2193  
2194 (F) Lime sludge drying beds shall not be allowed.

2195  
2196 (iv) Acceptable methods of treatment and disposal of alum sludge are as  
2197 follows:

2198  
2199 (A) Lagoons may be used as storage and interim disposal. Lagoons  
2200 used for storage shall have a volume of at least 100,000 gallons for every 1,000,000 gpd of  
2201 facility water treating capacity.

2202  
2203 (B) Alum sludge may be discharged to the sanitary sewer only when  
2204 the system is capable of handling the waste and with the approval of the owner of the sewer  
2205 system.

2206  
2207 (C) Mechanical dewatering may be used.

- 2208
- 2209 (D) Alum sludge drying beds may be used.
- 2210
- 2211 (E) Alum sludge may be acid-treated and recovered.
- 2212
- 2213 (F) Disposal at a landfill.
- 2214
- 2215 (v) Designs that propose disposal of waste filter wash water from iron and manganese
- 2216 removal plants that include sand filters shall demonstrate the inclusion of a separate structure,
- 2217 unless otherwise approved by the Administrator.
- 2218

2219 **Section 13. Chemical Application.**

2220

2221 (a) 2018 TSS, parts 5.0.2 and 5.0.2(f), general, chemical application; 5.0.3-5.0.3(h),

2222 general, general equipment design; 5.1.2-5.1.2(e)(4), feed equipment, control; 5.1.3-5.1.3(c),

2223 feed equipment, dry chemical feeders; 5.1.4-5.1.4(d), feed equipment, positive displacement

2224 solution feed pumps; 5.1.5-5.1.5(d), feed equipment, liquid chemical feeders-siphon control;

2225 5.1.6-5.1.6(d), feed equipment, cross-connection control; 5.1.8-5.1.8(e), feed equipment, in-plant

2226 water supply; 5.1.9(a)(1-3), (b), and (d)(1-2), feed equipment, storage of chemicals; 5.1.10-

2227 5.1.10(j), feed equipment, bulk liquid storage tanks; 5.1.11-5.1.11(h), feed equipment, day tanks;

2228 5.1.12-5.1.12(e), feed equipment, feed lines; 5.1.13-5.1.13(d); feed equipment, handling; 5.1.14-

2229 5.1.14(b), feed equipment, housing; 5.3.2, operator safety, respiratory protection equipment;

2230 5.3.3, operator safety, chlorine gas leak detection; 5.4.1(d)(1-5) and (7-10), (f), and (h)(1-5),

2231 specific chemicals, chlorine gas; 5.4.2-5.4.2(b), specific chemicals, acids and caustics; 5.4.3-

2232 5.4.3(c)(5), specific chemicals, sodium chlorite; 5.4.4-5.4.4(b)(5), specific chemicals, sodium

2233 hypochlorite; are herein incorporated by reference.

2234

2235 (b) Chemical application facility designs shall comply with the following

2236 requirements:

2237

2238 (i) A separate feeder shall be used for each chemical applied; and

2239

2240 (ii) Chemical storage tanks shall be constructed of materials that are resistant

2241 to the chemicals stored. Tanks shall maintain structural integrity while in use.

2242

2243 (c) Chemical application facilities shall include an alarm for high effluent turbidity,

2244 low chlorine residual, and chlorine leaks when chlorine gas is used. The alarm shall be located at

2245 an attended location.

2246

2247 **Section 14. Pumping Facilities**

2248

2249 (a) 2018 TSS, parts 6.1-6.1.1(e), location; 6.2, 6.2(b)-(e), pumping stations; 6.2.1-

2250 6.2.1(d), pumping stations, suction well; 6.2.2-6.2.2(b), pumping stations, equipment servicing;

2251 6.3.2, pumps, pump priming; 6.6.1, appurtenances, valves; 6.6.3-6.6.3(d), appurtenances, gauges

2252 and meters; 6.6.4-6.6.4(b), appurtenances, water seals; 6.6.5, appurtenances, controls; 6.6.6,

2253 appurtenances, standby power; are herein incorporated by reference.

2254  
2255  
2256  
2257  
2258  
2259  
2260  
2261  
2262  
2263  
2264  
2265  
2266  
2267  
2268  
2269  
2270  
2271  
2272  
2273  
2274  
2275  
2276  
2277  
2278  
2279  
2280  
2281  
2282  
2283  
2284  
2285  
2286  
2287  
2288  
2289  
2290  
2291  
2292  
2293  
2294  
2295  
2296  
2297  
2298  
2299

- (b) Stairways or ladders shall be provided between all floors and in pits or compartments that must be entered.
- (c) Pumping facilities shall be heated to maintain a minimum temperature of 40 degrees Fahrenheit if typically unoccupied and 50 degrees Fahrenheit if normally occupied.
- (d) Pumping station ventilation designs shall demonstrate that:
  - (i) All areas of the pumping station that are accessible shall be ventilated;
  - (ii) Ventilation may be continuous or intermittent;
  - (iii) Drywell ventilation shall provide:
    - (A) At least six air changes per hour if continuous; and
    - (B) At least 30 air changes per hour if intermittent with an automatic start upon operator entry into the area.
  - (iv) Wetwell ventilation shall provide 12 continuous air changes per hour or 60 intermittent air changes per hour and be designed to permit the use of portable blowers that will exhaust the space and supply fresh air during the access periods.
- (e) Dehumidification equipment shall be provided in below-ground pumping stations. The equipment shall be sized to maintain a dewpoint at least two degrees Fahrenheit below the coldest anticipated temperature of the water to be conveyed in the pipes.
- (f) All pumping stations that are manned four or more hours per day shall be provided with potable water, lavatory, and toilet facilities. The waste shall be discharged to the sanitary sewer or an on-site waste treatment system.
- (g) Pump design shall comply with the following requirements:
  - (i) At least two pumps shall be provided. With the largest pump out of service, the remaining pump or pumps shall be capable of providing the maximum pumping capacity of the system.
  - (ii) Pumps shall be selected such that the net positive suction head required (NPSHR) is less than the net positive suction head available (NPSHA) minus four feet based on hydraulic conditions and the altitude of the pump installation. If this condition cannot be satisfied, a means of priming shall be provided.
  - (iii) A surge analysis shall be provided to demonstrate if surge protection devices will be needed to protect the piping. Pressure relief valves are not acceptable as surge control.

2300  
2301  
2302  
2303  
2304  
2305  
2306  
2307  
2308  
2309  
2310  
2311  
2312  
2313  
2314  
2315  
2316  
2317  
2318  
2319  
2320  
2321  
2322  
2323  
2324  
2325  
2326  
2327  
2328  
2329  
2330  
2331  
2332  
2333  
2334  
2335  
2336  
2337  
2338  
2339  
2340  
2341  
2342  
2343

(iv) The calculated total dynamic head for pumping units shall be based on pipe friction, pressure losses from pipe entrances, exits, appurtenances (such as valves and bends), and static head at the design flow.

(v) The station shall have a flow rate indicator and totalizing meter, and a method of recording the total water pumped.

(h) Booster pumps shall comply with the following requirements:

(i) Booster pumps shall not produce less than 5 psi in suction lines. If the suction line has service connections, the pressure shall be at least 35 psi during normal operation and shall have a low-pressure cutoff switch to maintain at least 20 psi.

(ii) For booster pumps used for fire suppression, no person shall install or maintain a water service connection to any premises where a fire pump has been installed on the service line to or within such premises unless the pump is equipped with one of the following:

(A) A low suction throttling valve or pilot-operated valve installed in the discharge piping that maintains positive pressure in the suction piping while monitoring pressure in the suction piping through a sensing line. The valve shall throttle the discharge of the pump when necessary so that suction pressure will not be reduced below 20 psi gauge when the pump is operating; or

(B) A variable-speed suction limiting control that is used to maintain a minimum positive suction pressure at the pump inlet by reducing the pump driver speed while monitoring pressure in the suction piping through a sensing line. The limiting control shall be set so that the suction pressure will not be reduced below 20 psi gauge while the pump is operating.

(iii) Automatic or remote-controlled pumps shall have a range between the start and cutoff pressure that will prevent the pump from cycling more than one start every 15 minutes.

(iv) In-line booster pumps shall be accessible for maintenance. There shall be access openings, as needed, to allow the removal of the pump.

(v) Individual home booster pumps shall not be allowed for any individual service from the public water supply main.

(vi) Un-manned or remotely controlled pump stations shall have an alarm at an operator attended location for any conditions that may affect the continuous delivery of water.

(i) Pumping facility valves shall comply with the following requirements:

2344 (i) Air release valves shall be provided where the pipe crown is dropped in  
 2345 elevation. The discharge pipe from the valve shall have a minimum of an 8-inch air gap and shall  
 2346 be covered with a #24 mesh non-corrodible screen.

2347  
 2348 (ii) Each pump shall either have an individual suction line or the suction lines  
 2349 shall be manifolded such that they demonstrate similar hydraulic and operating conditions.

2350

2351 **Section 15. Finished Water Storage**

2352

2353 ((a) 2018 TSS, parts 7.0.1-7.0.1(c), general, sizing; 7.0.2-7.0.2(b), general, location of  
 2354 finished water storage structures; 7.0.3, general, protection from contamination; 7.0.4, general,  
 2355 security; 7.0.5, general, drains; 7.0.6, general, stored water age; 7.0.8-7.0.8.2(b), general, access;  
 2356 7.0.9-7.0.9(e), general, vents; 7.0.10-7.0.10(f), general, roof and sidewall; 7.0.17-7.0.17(c),  
 2357 general, painting and/or cathodic protection; 7.0.18-7.0.18(c), general, disinfection; 7.1.1,  
 2358 treatment plant storage, filter washwater tanks; 7.2-7.2.4, hydropneumatic tank systems; are  
 2359 herein incorporated by reference.

2360

2361 (b) Finished water storage structures shall comply with the following requirements:

2362

2363 (i) Water storage structures shall comply with the following standards for  
 2364 storage tanks, standpipes, ground storage reservoirs that are described in AWWA M42,  
 2365 clearwells, and elevated storage:

2366

- 2367 (A) AWWA D100;
- 2368
- 2369 (B) AWWA D102;
- 2370
- 2371 (C) AWWA D103;
- 2372
- 2373 (D) AWWA D104;
- 2374
- 2375 (E) AWWA D106;
- 2376
- 2377 (F) AWWA D107;
- 2378
- 2379 (G) AWWA D108;
- 2380
- 2381 (H) AWWA D110;
- 2382
- 2383 (I) AWWA D115;
- 2384
- 2385 (J) AWWA D120; and
- 2386
- 2387 (K) AWWA D121.
- 2388

2389 (ii) All tank and foundation design shall be performed by a Wyoming  
2390 registered professional engineer. The plans or contractor-furnished information shall be signed  
2391 and sealed by a Wyoming registered professional engineer.

2392  
2393 (iii) All new or modified water storage tanks shall have the inlet and outlet  
2394 connections separated from each other as much as is practical.

2395  
2396 (c) Storage facility designs shall demonstrate:

2397  
2398 (i) The average daily demand will require a daily fill of 20 percent of the total  
2399 storage volume for surface water sources and 10 percent for groundwater sources.

2400  
2401 (ii) For designs that demonstrate the storage tank has a small daily demand  
2402 and a high fire water storage requirement, or the storage tank water age average is greater than  
2403 two days, the design shall demonstrate that a volume equal to at least 20 percent of the tank  
2404 volume will be delivered to the storage tank each time pumping is initiated.

2405  
2406 (iii) For designs with well systems that provide a minimum of two wells that  
2407 can supply either the maximum hourly demand or the fire demand, whichever is greater, storage  
2408 is not required. These systems shall demonstrate that they will provide alternative power for the  
2409 finished water pumps.

2410  
2411 (d) Storage structure design shall eliminate short-circuiting.

2412  
2413 (e) The minimum inlet velocity shall be 10 ft/sec unless demonstration of employed  
2414 mixing system or lower inlet velocity addresses disinfection by-product formation, stratification,  
2415 stagnation, freezing, and other water age issues.

2416  
2417 (f) Overflow and drain lines shall:

2418  
2419 (i) Be protected with a mechanical device such as:

2420  
2421 (A) A sealed flapper valve or duckbill valve; or

2422  
2423 (B) A #24 mesh non-corrodible screen.

2424  
2425 (ii) For overflow lines that are protected with a mechanical device, include  
2426 installation of a #4 mesh non-corrodible screen or finer to prevent the entrance of birds or  
2427 rodents;

2428  
2429 (iii) For overflow lines that are protected with #24 mesh non-corrodible screen,  
2430 demonstrate prevention of screen clogging that would lead to structural storage tank damage;

2431  
2432 (iv) Include installation of the screen within the overflow line at a location that  
2433 is not susceptible to vandalism and that allows for the overflow line to be operational during an  
2434 overflow event;

- 2435  
2436                   (v)     Provide access to the screen with the smallest openings for replacement;  
2437 and  
2438  
2439                   (vi)    Demonstrate that the screen with the smallest openings will be the  
2440 outermost screen.  
2441  
2442                   (g)     Overflow designs shall demonstrate the provisions that will be included to prevent  
2443 mechanical devices from freezing shut.  
2444  
2445                   (h)     Overflow lines shall not be considered as vents.  
2446  
2447                   (i)     Vents shall be designed to protect the tank from contaminants including but not  
2448 limited to surface water, stormwater runoff, insects, rodents, and birds.  
2449  
2450                   (i)     All openings shall be protected with #24 mesh non-corrodible screen or a  
2451 combination of #24 mesh and coarser mesh non-corrodible screen.  
2452  
2453                   (ii)    The design shall demonstrate consideration of site conditions, freezing,  
2454 frosting, and provide justification including precautions for snow depth.  
2455  
2456                   (A)     The design shall demonstrate consideration of frost-free or frost-  
2457 proof vents; and  
2458  
2459                   (B)     The design shall demonstrate consideration of pressure/vacuum,  
2460 frost-proof release vents that will need to protect openings with #24 mesh non-corrodible screen.  
2461  
2462                   (j)     Down-turned vent openings shall be at least 24 inches above the nearest  
2463 horizontal surface.  
2464  
2465                   (k)     Elevated tanks shall be designed to remove snow via tank geometry to prevent  
2466 snow build-up clogging vents.  
2467  
2468                   (l)     Vent designs shall include calculations that verify the required volume of flow is  
2469 achievable through the proposed vent pipe and screen combination.  
2470  
2471                   (m)     Finished water plant water storage shall comply with the following requirements:  
2472  
2473                   (i)     Clearwell storage shall be sized, in conjunction with distribution system  
2474 storage, to relieve the filter of having to follow fluctuations in water use. Where water is pumped  
2475 from clearwell storage to the system, an overflow shall be provided.  
2476  
2477                   (ii)    If unfinished water is stored in compartments adjacent to finished water,  
2478 the unfinished and finished water shall be separated by double walls.  
2479

2480 (iii) Receiving basins and wetwells shall be designed as finished water storage  
 2481 structures and shall comply with the requirements of this Section.

2482

2483 **Section 16. Distribution Systems.**

2484

2485 (a) 2018 TSS, parts 8.2-8.2.4(b), system design; 8.3, valves; 8.4-8.4.4(d), hydrants;  
 2486 8.5-8.5.2(c), air relief valves; 8.6, valve, meter, and blow-off chambers; 8.7.3, installation of  
 2487 water mains, cover; 8.7.4, installation of water mains, blocking; 8.7.6, installation of water  
 2488 mains, pressure and leakage testing; 8.7.7, installation of water mains, disinfection; 8.7.8,  
 2489 installation of water mains, external corrosion; 8.7.9, installation of water mains, separation from  
 2490 other utilities; 8.8.2-8.8.2(b), separation distances from contamination sources, parallel  
 2491 installation; 8.8.3-8.8.3(b), separation distances from contamination sources, crossings; 8.8.6,  
 2492 separation distances from contamination sources, sewer manholes, inlets, and structures; 8.9-  
 2493 8.9.1, surface water crossings, above-water crossings; 8.9.2-8.9.2(c); surface water crossings,  
 2494 under water crossings; 8.11.1, water services and plumbing, plumbing; 8.12, service meters; are  
 2495 herein incorporated by reference.

2496

2497 (b) Distribution systems shall be constructed of commercial pipe that conforms to the  
 2498 following standards:

2499

2500 (i) PVC pipe:

2501

2502 (A) Less than four inches diameter, ASTM D 2241; or

2503

2504 (B) Four inches and larger diameter, AWWA C900.

2505

2506 (ii) Ductile iron, AWWA C151;

2507

2508 (iii) Fiberglass pressure pipe, AWWA C950;

2509

2510 (iv) Polyethylene pipe:

2511

2512 (A) ¾ inch through three inches diameter, AWWA C901;

2513

2514 (B) Four inches through 65 inches diameter, AWWA C906; or

2515

2516 (v) Other material submitted with the permit application and approved by the  
 2517 Administrator.

2518

2519 (c) Flanged piping shall not be allowed for buried pipe except for connection to  
 2520 valves.

2521

2522 (d) New water mains shall be sized after the hydraulic analysis required by Section  
 2523 9(l)(i) of this Chapter and the design shall demonstrate that:

2524



- 2525 (i) At maximum day demand plus current State of Wyoming-required fire  
2526 flow, or the fire flow of an authority having jurisdiction, the pressure in the municipal  
2527 distribution system will not fall below 20 pounds per square inch (psi); and  
2528
- 2529 (ii) The normal system working pressure shall be greater than 35 psi.  
2530
- 2531 (e) When fire protection is provided, the water main system shall be designed to also  
2532 serve fire flows.  
2533
- 2534 (f) Hydrants shall:  
2535
- 2536 (i) Have hydrant leads that are a minimum of six inches in diameter;  
2537
- 2538 (ii) Have valves installed;  
2539
- 2540 (iii) Be protected from freezing at hydrant leads and barrels;  
2541
- 2542 (iv) Where groundwater levels are above the gravel drain area, hydrants shall  
2543 be pumped dry or otherwise dewatered and hydrant weep holes shall not be used; and  
2544
- 2545 (v) Have drains that are not connected to or located within 10 feet of a  
2546 sanitary sewer or storm drain.  
2547
- 2548 (g) Fire hydrants or active service taps may be substituted for air relief in 6- and 8-  
2549 inch lines.  
2550
- 2551 (h) Where excavation is performed for distribution systems:  
2552
- 2553 (i) The trench bottom shall be excavated for the bell of the pipe;  
2554
- 2555 (ii) All rock shall be removed within six inches of the pipe; and  
2556
- 2557 (iii) The trench shall be dewatered for all work.  
2558
- 2559 (i) Distribution system bedding for rigid pipe shall be designed in accordance with  
2560 ASTM C12 Classes A, B, or C. Flexible pipe bedding shall be designed in accordance with  
2561 ASTM D2321 Class I, II, or III.  
2562
- 2563 (j) Distribution system pipe shall be joined to ensure a watertight fitting and installed  
2564 in accordance with the following standards, as applicable:  
2565
- 2566 (i) For ductile iron pipe, AWWA C600;  
2567
- 2568 (ii) For PVC pipe, AWWA M23; and  
2569
- 2570 (iii) For HDPE pipe, AWWA M55.

- 2571  
2572 (k) Backfill for distribution systems shall:  
2573  
2574 (i) Be performed without disturbing pipe alignment;  
2575  
2576 (ii) Not contain debris, frozen material, unstable material, or large clods;  
2577  
2578 (iii) Not contain rocks or stones that are greater than three inches in diameter  
2579 within two feet of pipe; and  
2580  
2581 (iv) Be compacted to a density equal to or greater than the surrounding soil.  
2582  
2583 (l) Distribution systems shall meet the following requirements for separation of water  
2584 mains from sanitary and storm sewers:  
2585  
2586 (i) Where the minimum vertical or horizontal separation distances required  
2587 by incorporation by reference of 2018 TSS parts 8.8.2 and 8.8.3 of paragraph (a) of this Section  
2588 cannot be met, the sewer or water line shall be placed in a separate conduit pipe or meet the  
2589 flow-fill requirements of paragraphs (ii) and (iii) of this Paragraph (l);  
2590  
2591 (ii) Flow-fill for pipelines shall comply with the following:  
2592  
2593 (A) Cement-treated fill, non-shrink backfill, low-density concrete  
2594 backfill, or structural backfill may be used as flow-fill when the material has a 28-day  
2595 compressive strength of 30-60 psi;  
2596  
2597 (B) The pipe to be encased shall be laid on a four to six-inch of bed of  
2598 washed gravel that has been widened, with the walls of the trench benched away from the center-  
2599 line of the trench, so the pipe is uniformly supported over the length or supported on blocks no  
2600 further than 10 feet apart;  
2601  
2602 (C) The flow-fill and washed gravel or blocks shall rest on an  
2603 undisturbed trench bottom;  
2604  
2605 (D) The pipe shall not move laterally or float during placement of the  
2606 flow-fill and the line and grade of the pipe shall be maintained; and  
2607  
2608 (E) The flow-fill shall extend from trench sidewall to trench sidewall  
2609 and extend at least two inches above the top of the pipe.  
2610  
2611 (iii) Flow-fill for pipe crossings shall comply with the following:  
2612  
2613 (A) To the extent possible, there shall be no joints or taps within nine  
2614 feet of the crossing;  
2615

2616 (B) The flow-fill shall extend from undisturbed earth at the bottom of  
2617 the lower pipe to at least two inches above the top of the upper pipe;

2618  
2619 (C) The block of flow-fill shall be wide enough to ensure the structural  
2620 integrity of the installation; and

2621  
2622 (D) Pipes that cross one another shall be separated by a minimum of  
2623 two inches when encased in flow-fill.

2624  
2625 (m) Cross-connections shall comply with the following requirements:

2626  
2627 (i) There shall be no water service connection installed or maintained  
2628 between a public water supply and any water user whereby unsafe water or contamination may  
2629 backflow into the public water supply.

2630  
2631 (A) To protect all public water supplies from the possibility of the  
2632 introduction of contamination due to cross-connections, the water supplier shall:

2633  
2634 (I) Require backflow prevention devices for each water service  
2635 connection in accordance with Table 4 of this Section, with the exception of (B)(I) residential  
2636 water service connections and (B)(II) domestic non-residential water service connections;

2637  
2638 (II) Take appropriate actions that may include:

2639  
2640 1. Immediate disconnection for any water user that  
2641 fails to maintain a properly installed backflow prevention device; or

2642  
2643 2. Compliance with other measures as identified in  
2644 this Section.

2645  
2646 (III) Any high hazard non-residential connection to any public  
2647 water supply shall be protected by the backflow prevention device required by Table 4.

2648  
2649 (IV) Water suppliers shall establish record keeping and  
2650 management procedures to ensure that requirements of this regulation for installation and  
2651 maintenance of backflow prevention devices are being met.

2652  
2653 (B) The method of backflow control, selected from Table 4, shall be  
2654 determined based upon the degree of hazard of the cross-connection and the cause of the  
2655 potential backflow. Hazards shall be classified as high hazard or low hazard. The potential cause  
2656 of the backflow shall be identified as being back-siphonage or back-pressure.

2657  
2658 (I) Residential water service connections shall be considered  
2659 to be low hazard back-siphonage connections unless determined otherwise by a Hazard  
2660 Classification.

2661

2662 (II) Domestic non-residential water service connections (such  
2663 as schools without laboratories, churches, office buildings, warehouses, and motels) shall be  
2664 considered to be low hazard back-pressure connections unless determined otherwise by a Hazard  
2665 Classification conducted by the water supplier.

2666  
2667 (III) Any water user's system with an auxiliary source of supply  
2668 shall be considered to be a high hazard, back-pressure cross-connection. A reduced pressure  
2669 principle backflow device shall be installed at the water service connection to any water user's  
2670 system with an auxiliary source of supply.

2671  
2672 (IV) All water loading stations shall be considered high hazard  
2673 connections. A device, assembly, or method consistent with Table 4 shall be provided.

2674  
2675 (V) Non-domestic commercial or industrial water service  
2676 connections (such as restaurants, refineries, chemical mixing facilities, sewage treatment plants,  
2677 mortuaries, laboratories, laundries, dry cleaners, irrigation systems, and facilities producing or  
2678 using hazardous substances) shall be considered to be high hazard back-pressure connections  
2679 unless determined otherwise by a Hazard Classification. For some of these service connections, a  
2680 Hazard Classification may result in a determination of a back-siphonage or low hazard  
2681 classification. The backflow prevention device required shall be appropriate to the degree of  
2682 hazard established by the Hazard Classification. Where potential high hazards exist within the  
2683 non-residential water user's system, even though such high hazards may be isolated at the point  
2684 of use, an approved backflow prevention device shall be installed and maintained at the water  
2685 service connection.

2686  
2687 (C) Determination of the hazard classification of a water service  
2688 connection is the responsibility of the water supplier. The water supplier may require the water  
2689 user to furnish a Hazard Classification Survey to be used to determine the Hazard Classification.

2690  
2691 (D) Hazard Classification Surveys that have been conducted by Hazard  
2692 Classification Surveyors that have been certified by another state certification program shall  
2693 include the following information for Administrator approval:

2694  
2695 (I) Documentation that indicates the Hazard Classification  
2696 Surveyor has received certification from the regulatory agency that issued the current  
2697 certification that states the name of the Hazard Classification Surveyor, the status of their  
2698 certification, the date originally issued, the expiration date, and the classification for which the  
2699 Hazard Classification Surveyor is certified; and

2700  
2701 (II) Any disciplinary action imposed against the applicant; if  
2702 any.

2703  
2704 (E) All backflow prevention devices shall be in-line serviceable  
2705 (repairable), in-line testable except for devices meeting ASSE 1024, and installed in accordance  
2706 with manufacturer instructions and applicable plumbing codes.

2707

2708 (F) All backflow prevention devices must have a certification by an  
 2709 approved third-party certification agency. Approved certification agencies are:

- 2710
- 2711 (I) American Society of Sanitary Engineers (ASSE);
- 2712
- 2713 (II) International Association of Plumbing/Mechanical officials  
 2714 (IAPMO); and
- 2715
- 2716 (III) Foundation for Cross-Connection Control and Hydraulic  
 2717 Research, University Of Southern California (USC-FCCCHR).
- 2718

2719 (G) Backflow prevention devices at water service connections shall be  
 2720 inspected and certified by a certified backflow assembly tester at the time of installation.  
 2721 Certification of the assembly tester shall be by one of the following:

- 2722
- 2723 (I) The American Society of Sanitary Engineers (ASSE); or
- 2724
- 2725 (II) American Backflow Prevention Association (ABPA).
- 2726

2727 (H) Backflow prevention devices installed at high hazard non-  
 2728 residential cross-connections shall be inspected and tested on an annual basis by a certified  
 2729 backflow assembly tester.

2730

2731 (I) If any device is found to be defective or functioning improperly, it  
 2732 shall be immediately repaired or replaced. Failure to make necessary repairs to a backflow  
 2733 prevention device will be cause for the water service connection to be terminated.

2734

2735 (J) All public water suppliers shall report any high hazard backflow  
 2736 incident within seven days to the Division. The backflow incident shall be reported on a form  
 2737 provided by the Administrator.

2738

2739 (ii) Neither steam condensate nor cooling water from engine jackets or other  
 2740 heat exchange devices shall be returned to the public water supply after it has passed through the  
 2741 water service connection.

2742

2743

Table 4. Backflow Prevention Devices, Assemblies and Methods

| Device,<br>Assembly, or<br>Method | Degree of Hazard   |                   |                    |                   | Notes  |
|-----------------------------------|--------------------|-------------------|--------------------|-------------------|--|
|                                   | Low Hazard         |                   | High Hazard        |                   |  |
|                                   | Back-<br>Siphonage | Back-<br>Pressure | Back-<br>Siphonage | Back-<br>Pressure |  |
| Airgap                            | X                  | X                 | X                  | X                 | See Note 1<br>and Note 2                       |
| Atmospheric<br>Vacuum<br>Breaker  | X                  |                   | X                  |                   | Not allowed<br>under<br>continuous<br>pressure |

|                                       |   |   |   |   |                                    |
|---------------------------------------|---|---|---|---|------------------------------------|
| Spill-proof Pressure-type Vacuum      | X |   | X |   |                                    |
| Double Check Valve Backflow Preventer | X | X |   |   |                                    |
| Pressure Vacuum Breaker               | X |   | X |   |                                    |
| Reduced Pressure Principal Backflow   | X | X | X | X | See Note 2,                        |
| Dual Check                            | X |   |   |   | Restricted to residential services |

2744  
 2745  
 2746  
 2747  
 2748  
 2749  
 2750  
 2751  
 2752  
 2753  
 2754  
 2755  
 2756  
 2757  
 2758  
 2759  
 2760  
 2761  
 2762  
 2763  
 2764  
 2765  
 2766  
 2767  
 2768  
 2769  
 2770

Note 1: Minimum Airgap for Water Distribution. For spouts with an effective opening diameter of ½ inch or less, the minimum airgap when the discharge is not affected by side walls shall be one inch. The minimum airgap when the discharge is affected by sidewalls shall be 1 ½ inches. For effective openings greater than ½ inch, the minimum airgap shall be two times the effective opening diameter when the discharge is not affected by sidewalls. The minimum airgap when the discharge is affected by sidewalls shall be three times the effective opening diameter.

Note 2: Extreme Hazards. In the case of any water user’s system where, in the opinion of the water supplier or the Administrator, an undue health threat is posed because of the presence of extremely toxic substances or potential back pressures in excess of the design working pressure of the device, the water supplier may require an airgap at the water service connection to protect the public water system.

**Section 17. Laboratory Requirements.**

(a) 2018 TSS, parts 2.8.1-2.8.1(h), testing equipment, is herein incorporated by reference.

(b) Test procedures for analysis of monitoring samples shall conform to the Standard Methods for the Examination of Water and Wastewater.

(c) All treatment plants shall have the capability to perform or contract for the self-monitoring analytical work required by the Safe Drinking Water Act, 42 U.S.C. §300f et seq. All plants shall, in addition, be capable of performing or contracting the analytical work required to ensure good management and control of plant operation and performance.

2771 (d) All laboratories used for the tests, analysis, and monitoring required by this  
 2772 Section shall meet the following requirements:

2773  
 2774 (i) The laboratory shall be located away from vibrating machinery or  
 2775 equipment that might have adverse effects on the performance of laboratory instruments or the  
 2776 analyst and shall be designed to prevent adverse effects from vibration.

2777  
 2778 (ii) Walls shall have an easily cleaned, durable, and impervious surface.

2779  
 2780 (iii) Cabinet and storage space shall be provided for dust-free storage of  
 2781 instruments and glassware. Benchttop height shall be 30 inches. Benchttops shall be field joined  
 2782 into a continuous surface with acid, alkali, and solvent-resistant cement.

2783  
 2784 (iv) Fume hoods shall be provided where reflux or heating of toxic or  
 2785 hazardous materials is required. A hood shall not be situated near a doorway unless a secondary  
 2786 means of exit is provided. All fume hood switches, electrical outlets, and utility and baffle  
 2787 adjustment handles shall be located outside the hood. Light fixtures shall be explosion-proof. 24-  
 2788 hour continuous exhaust capability shall be provided. Exhaust fans shall be explosion-proof.

2789  
 2790 (v) The laboratory shall have a minimum of two sinks per 400 square feet (not  
 2791 including cup sinks). Sinks shall be double well with drainboards and shall be made of epoxy  
 2792 resin or plastic. All water fixtures shall have reduced pressure zone backflow preventers. Traps  
 2793 shall be constructed of glass, plastic, or lead and be accessible for cleaning.

2794  
 2795 (vi) Distilled water shall conform to the quality specified by Standard Methods  
 2796 for the Examination of Water and Wastewater 2018.

2797  
 2798 (e) Portable testing equipment shall be provided where necessary for operational  
 2799 control testing.

2800  
 2801 **Section 18. Operation and Maintenance Manuals.**

2802  
 2803 (a) Each new or modified treatment or pumping facility shall have an operation and  
 2804 maintenance manual (O & M Manual) located at the facility. The manuals shall provide the  
 2805 following information as a minimum:

2806  
 2807 (i) Introduction;

2808  
 2809 (ii) Description of facilities and unit processes within the plant from influent  
 2810 structures through effluent structures;

2811  
 2812 (A) The size, capacity, model number (where applicable), and intended  
 2813 loading rate of facilities and unit processes;

2814  
 2815 (B) A description of each unit, including the function, controls,  
 2816 lubrication, and maintenance schedule;

- 2817  
2818 (C) A description of start-up operations, routine operations, abnormal  
2819 operations, emergency or power outage operations, bypass procedures, and safety;  
2820  
2821 (D) Flow diagrams of the entire process, as well as individual unit  
2822 processes that show the flow options under the various operational conditions listed in paragraph  
2823 (a)(ii) of this Section; and  
2824  
2825 (E) The design criteria for each unit process, including the number,  
2826 type, capacity, sizes, and other relevant information.  
2827  
2828 (iii) Plant control system;  
2829  
2830 (iv) Utilities and systems;  
2831  
2832 (v) Emergency procedures, including:  
2833  
2834 (A) Details of emergency operations procedures for possible  
2835 foreseeable emergencies, such as power outage, equipment failure, development of unsafe  
2836 conditions, and other emergency conditions;  
2837  
2838 (B) Emergency operations valve positions, flow control settings, and  
2839 other information to ensure continued operation of the facility at maximum possible efficiency  
2840 during emergencies; and  
2841  
2842 (C) Emergency notification procedures to be followed to protect health  
2843 and safety under various emergency conditions.  
2844  
2845 (vi) Permit requirements and other regulatory requirements;  
2846  
2847 (vii) Staffing needs;  
2848  
2849 (viii) Index of manufacturers' manuals;  
2850  
2851 (ix) Index of equipment maintenance manuals; and  
2852  
2853 (x) General information on safety in and around the plant and its components,  
2854 including the following safety information:  
2855  
2856 (A) Each unit process discussion shall include applicable safety  
2857 procedures and precautions; and  
2858  
2859 (B) For unit processes or operations having extreme hazards (such as  
2860 chlorine and closed tanks), the discussion shall detail appropriate protection, rescue procedures,  
2861 and necessary safety equipment.  
2862



2863 (b) Administrator approval of the final O & M Manual is required prior to plant  
2864 startup.

2865  
2866 (c) Public water supply facilities shall have an equipment maintenance manual  
2867 located at the facility for each piece of equipment. Each equipment maintenance manual shall:  
2868

2869 (i) Have a typewritten table of contents for each volume arranged in a  
2870 systematic order;

2871  
2872 (ii) Include the following general contents:

2873  
2874 (A) Product data;

2875  
2876 (B) Drawings;

2877  
2878 (C) Written text as required to supplement product data for the  
2879 particular installation;

2880  
2881 (D) Copies of each warranty, bond, and service contract issued;

2882  
2883 (E) Descriptions of unit and component parts;

2884  
2885 (F) Operating procedures;

2886  
2887 (G) Maintenance procedures and schedules;

2888  
2889 (H) Service and lubrication schedule;

2890  
2891 (I) Sequence of control operation;

2892  
2893 (J) Parts list; and

2894  
2895 (K) Recommended spare parts list.

2896  
2897 (iii) Include a section on troubleshooting that shall include:

2898  
2899 (A) Typical operation problems and solutions; and

2900  
2901 (B) A telephone number for factory troubleshooting assistance.

2902  
2903 (iv) Meet the requirements of the engineer and contractor for installation and  
2904 startup of equipment.

2905  
2906 **Section 19. Incorporation by Reference.**

2907

2908 (a) The following codes, standards, rules, and regulations referenced in this Chapter  
 2909 are incorporated by reference:

2910

2911 (i) American National Standards Institute/National Sanitation Foundation  
 2912 Standard 53, Drinking Water Treatment Units - Health Effects (2019), referred to as “NSF/ANSI  
 2913 53,” available at <https://webstore.ansi.org/Standards/NSF/NSFANSI532020>;

2914

2915 (ii) American National Standards Institute/National Sanitation Foundation  
 2916 Standard 55, Ultraviolet Microbiological Water Treatment Systems (2020), referred to as  
 2917 “NSF/ANSI 55,” available at <https://webstore.ansi.org/Standards/NSF/NSFANSI552021>;

2918

2919 (iii) American National Standards Institute/National Sanitation Foundation  
 2920 Standard 61, Drinking Water System Components - Health Effects NSF/ANSI/CAN 61-  
 2921 2020/NSF/ANSI/CAN 600-2021, referred to as “NSF/ANSI/CAN 61-2020/NSF/ANSI/CAN  
 2922 600-2021,” available at <https://webstore.ansi.org/Standards/NSF/NSFANSI612021600>;

2923

2924 (iv) American National Standards Institute/National Sanitation Foundation  
 2925 Standard 372, Drinking Water System Components-Lead Content 372-20, referred to as  
 2926 “NSF/ANSI/CAN 372-20,” available at  
 2927 <https://webstore.ansi.org/Standards/NSF/NSFANSI3722020>;

2928

2929 (v) American National Standards Institute/National Sanitation Foundation  
 2930 Standard 419, Public Drinking Water Equipment Performance – Filtration, referred to as  
 2931 “NSF/ANSI 419-2018,” available at  
 2932 <https://webstore.ansi.org/Standards/NSF/NSFANSI4192018>;

2933

2934 (vi) American Petroleum Institute Specification 5L, Line Pipe, Forty-Sixth  
 2935 Edition (2019), referred to as “API 5L,” available at  
 2936 [https://www.techstreet.com/api/standards/api-spec-5l?gateway\\_code=api&product\\_id=2010552](https://www.techstreet.com/api/standards/api-spec-5l?gateway_code=api&product_id=2010552);

2937

2938 (vii) American Water Works Association Standard A100, Water Wells, A100-  
 2939 20, referred to as “AWWA A100-20,” available at  
 2940 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/83080725>;

2941

2942 (viii) American Water Works Association Standard C200, Steel Water Pipe, 6  
 2943 In. (150 mm) and Larger, C200-17 (2017), referred to as “AWWA C200,” available at  
 2944 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/63106282>;

2945

2946 (ix) American Water Works Association Standard C300, Reinforced Concrete  
 2947 Pressure Pipe, Steel-Cylinder Type, C300-11 (2011), referred to as “AWWA C300,” available at  
 2948 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/59483818>;

2949

2950 (x) American Water Works Association Standard C301, Prestressed Concrete  
 2951 Pressure Pipe, Steel-Cylinder Type, C301-14 (2014), referred to as “AWWA C301,” available at  
 2952 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/81647229>;

2953

- 2954 (xi) American Water Works Association Standard C600, Installation of  
 2955 Ductile-Iron Mains and Their Appurtenances, C600-10 (2010), referred to as “AWWA C600,”  
 2956 available at <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/25724>;  
 2957
- 2958 (xii) American Water Works Association Standard C601, AWWA Standard for  
 2959 Disinfecting Water Mains, C601-81 (1981), referred to as “AWWA C601,” available at  
 2960 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/18646>;  
 2961
- 2962 (xiii) American Water Works Association Standard C652, Disinfection of Water  
 2963 Storage Facilities, C652 (2011), referred to as “AWWA C652,” available at  
 2964 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/81912774>;  
 2965
- 2966 (xiv) American Water Works Association Standard C900, Polyvinyl Chloride  
 2967 (PVC) Pressure Pipe and Fabricated Fittings, 4 In. Through 12 In. (100 mm through 300 mm),  
 2968 for Water Transmission and Distribution, C900-07 (2007), referred to as “AWWA C900,”  
 2969 available at <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/18943>;  
 2970
- 2971 (xv) American Water Works Association Standard C901, Polyethylene (PE)  
 2972 Pressure Pipe and Tubing, 3/4 in. (19 mm) through 3 in. (76 mm), for Water Service, C901- 20  
 2973 (2020), referred to as “AWWA C901,” available at  
 2974 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/86488411>;  
 2975
- 2976 (xvi) American Water Works Association Standard C906, Polyethylene (PE)  
 2977 Pressure Pipe and Fittings, 4 in. through 65 In. (100 mm Through 1,650 mm), for Waterworks,  
 2978 C906-21 (2021), referred to as “AWWA C906,” available at  
 2979 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/105341623>;  
 2980
- 2981 (xvii) American Water Works Association Standard C950, Fiberglass Pressure  
 2982 Pipe, C950-13 (2013), referred to as “AWWA C950,” available at  
 2983 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/34040472>;  
 2984
- 2985 (xviii) American Water Works Association Standard D100, Welded Carbon Steel  
 2986 Tanks for Water Storage, D100-11 (2011), referred to as “AWWA D100-11,” available at  
 2987 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/28162>;  
 2988
- 2989 (xvix) American Water Works Association Standard D102, Coating Steel Water-  
 2990 Storage Tanks, D102-17 (2017), referred to as “AWWA D102-21,” available at  
 2991 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/92298590>;  
 2992
- 2993 (xx) American Water Works Association Standard D103, Factory-Coated  
 2994 Bolted Carbon Steel Tanks for Water Storage, D103-19, referred to as “AWWA D103-19,”  
 2995 available at <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/80453600>;  
 2996
- 2997 (xxi) American Water Works Association Standard D104-17, Automatically  
 2998 Controlled, Impressed-Current Cathodic Protection for the Interior of Steel Water Storage,  
 2999

3000 referred to as “AWWA D104-17,” available at  
3001 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/65522513>;  
3002  
3003 (xxii) American Water Works Association Standard D106-20, Sacrificial anode  
3004 Cathodic Protection Systems for the Interior Submerged Surfaces of Steel Water Storage Tanks,  
3005 referred to as “AWWA D106-20,” available at  
3006 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/84700967>;  
3007  
3008 (xxiii) American Water Works Association Standard D107-16, Composite  
3009 Elevated Tanks for Water Storage, referred to as “AWWA D107-16,” available at  
3010 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/54635993>;  
3011  
3012 (xxiv) American Water Works Association Standard D108-19, Aluminum Dome  
3013 Roofs for Water Storage Facilities, referred to as “AWWA D108-19,” available at  
3014 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/80933896>;  
3015  
3016 (xxv) American Water Works Association Standard D110-13 (R18), Wire- and  
3017 Strand-Wound, Circular, Prestressed Concrete Water Tanks, referred to as “AWWA D110-13  
3018 (R18),” available at [https://engage.awwa.org/PersonifyEbusiness/Store/Product-](https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/72304450)  
3019 [Details/productId/72304450](https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/72304450);  
3020  
3021 (xxvi) American Water Works Association Standard D115-20, Tendon-  
3022 Prestressed Concrete Water Tanks, referred to as “AWWA D115-20,” available at  
3023 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/83072907>;  
3024  
3025 (xxvii) American Water Works Association Standard D120-19, Thermosetting  
3026 Fiberglass-Reinforced Plastic Tanks, referred to as “AWWA D120-19,” available at  
3027 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/79004100>;  
3028  
3029 (xxviii) American Water Works Association Standard D121-12, Bolted  
3030 Aboveground Thermosetting Fiberglass Reinforced Plastic Panel-Type Tanks for Water Storage,  
3031 referred to as “AWWA D121-12,” available at  
3032 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/29429>;  
3033  
3034 (xxix) American Water Works Association Standard M23-20, PVC Pipe –  
3035 Design and Installation, Third Edition, M23, referred to as “AWWA M23-20,” available at  
3036 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/81145714>;  
3037  
3038 (xxx) American Water Works Association Standard M55-20, PE Pipe-Design  
3039 and Installation, Second Edition, M55, referred to as “M55-20,” available at  
3040 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/84701177>;  
3041  
3042 (xxxi) American Water Works Association Manual M42, Steel Water Storage  
3043 Tanks, 2013, referred to as “AWWA M42,” available at  
3044 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/36253113>;  
3045

3046 (xxxii) American National Standards Institute ASSE Standard 1024, Dual Check  
 3047 Backflow Preventers, ASSE 1024-17 (2017), referred to as “ASSE 1024,” available at  
 3048 <https://webstore.ansi.org/Standards/ASSE-Sanitary/ASSEStandard10242017>;

3049  
 3050 (xxxiii) ASTM International Standard A53, Standard Specification for Pipe, Steel,  
 3051 Black and Hot-Dipped, Zinc-Coated, Welded and Seamless, A53M-18 (2018), referred to as  
 3052 “ASTM A53, available at [https://www.astm.org/a0053\\_a0053m-18.html](https://www.astm.org/a0053_a0053m-18.html);

3053  
 3054 (xxxiv) ASTM International Standard A134, Standard Specification for Pipe,  
 3055 Steel, Electric-Fusion (Arc)-Welded (Sizes NPS 16 and Over), A134M-18 (2018), referred to as  
 3056 “ASTM A134,” available at <https://webstore.ansi.org/standards/astm/astma134a134m18>;

3057  
 3058 (xxxv) ASTM International Standard A135, Standard Specification for Electric-  
 3059 Resistance-Welded Steel Pipe, A135M-19 (2019), referred to as “ASTM A135,” available at  
 3060 <https://webstore.ansi.org/standards/astm/astma135a135m19>;

3061  
 3062 (xxxvi) ASTM International Standard ASTM A139 / A139M – 16, Standard  
 3063 Specification for Electric-Fusion (Arc)-Welded Steel Pipe (NPS 4 and Over), (2016), referred to  
 3064 as “ASTM A139,” available at [https://www.astm.org/a0139\\_a0139m-16.html](https://www.astm.org/a0139_a0139m-16.html);

3065  
 3066 (xxxvii) ASTM International Standard A409, Standard Specification for  
 3067 Welded Large Diameter Austenitic Steel Pipe for Corrosive or High-Temperature Service,  
 3068 A409M-15 (2015), referred to as “ASTM A409,” available at  
 3069 <https://webstore.ansi.org/Standards/ASTM/ASTMA409A409M15>;

3070  
 3071 (xxxviii) ASTM International Standard C12, Standard Practice for Installing  
 3072 Vitrified Clay Pipe Lines, C12-17 (2017), referred to as “ASTM C12,” available at  
 3073 <https://webstore.ansi.org/standards/astm/astmc1217>;

3074  
 3075 (xxxix) ASTM International Standard C14, Standard Specification for  
 3076 Nonreinforced Concrete Sewer, Storm Drain, and Culvert Pipe, C14-15a (2015), referred to as  
 3077 “ASTM C14,” available at  
 3078 [https://webstore.ansi.org/standards/astm/astmc1415a?gclid=Cj0KCQiA95aRBhCsARIsAC2xvfxIaQ66MqCuC40LMUwG0WMe0kbvHUvuxW6F3Nc7jy92bGyVdNFHiaoaAo-uEALw\\_wcB](https://webstore.ansi.org/standards/astm/astmc1415a?gclid=Cj0KCQiA95aRBhCsARIsAC2xvfxIaQ66MqCuC40LMUwG0WMe0kbvHUvuxW6F3Nc7jy92bGyVdNFHiaoaAo-uEALw_wcB);

3080  
 3081 (xl) ASTM International Standard C76, Standard Specification for Reinforced  
 3082 Concrete Culvert, Storm Drain, and Sewer Pipe, C76-19a (2019), referred to as “ASTM C76,”  
 3083 available at <https://webstore.ansi.org/Standards/ASTM/ASTMC7619a>;

3084  
 3085 (xli) ASTM International Standard D2321, Standard Practice for Underground  
 3086 Installation of Thermoplastic Pipe for Sewers and Other Gravity-Flow Applications, D2321-18  
 3087 (2018), referred to as “ASTM D2321,” available at  
 3088 <https://webstore.ansi.org/Standards/ASTM/ASTMD232118>;

3089  
 3090 (xlii) ASTM International Standard D2846, Standard Specification for  
 3091 Chlorinated Poly(Vinyl Chloride) (CPVC) Plastic Hot- and Cold-Water Distribution Systems,

3092 ASTM D2846/D2846M-19A (2019), referred to as “ASTM D2846,” available at  
3093 <https://webstore.ansi.org/Standards/ASTM/ASTMD2846D2846M19a>;

3094  
3095 (xliii) ASTM International Standard D2996, Standard Specification for  
3096 Filament-Wound “Fiberglass” (Glass-Fiber-Reinforced Thermosetting-Resin) Pipe, D2996-17  
3097 (2017), referred to as “ASTM D2996,” available at  
3098 <https://webstore.ansi.org/Standards/ASTM/ASTMD299617>;

3099  
3100 (xliv) ASTM International Standard D2997, Standard Specification for  
3101 Centrifugally Cast “Fiberglass” (Glass-Fiber-Reinforced Thermosetting-Resin) Pipe, D2997-15  
3102 (2015), referred to as “ASTM D2997,” available at  
3103 <https://webstore.ansi.org/Standards/ASTM/ASTMD299715>;

3104  
3105 (xlv) ASTM International Standard D3517, Standard Specification for  
3106 “Fiberglass” (Glass-Fiber-Reinforced Thermosetting-Resin) Pressure Pipe, D3517-19 (2019),  
3107 referred to as “ASTM D3517,” available at  
3108 <https://webstore.ansi.org/Search/Find?in=1&st=ASTM+D3517-19>;

3109  
3110 (xlvi) ASTM International Standard F480, Standard Specification for  
3111 Thermoplastic Well Casing Pipe and Couplings Made in Standard Dimension Ratios (SDR),  
3112 SCH 40 and SCH 80, F480-14 (2014), referred to as “ASTM F480,” available at  
3113 <https://webstore.ansi.org/Standards/ASTM/ASTMF48014>;

3114  
3115 (xlvii) ASTM International Standard F645, Standard Guide for Selection, Design,  
3116 and Installation of Thermoplastic Water- Pressure Piping Systems, ASTM F645-18b, (2018),  
3117 referred to as “ASTM F645,” available at  
3118 <https://webstore.ansi.org/Standards/ASTM/ASTMF64518b>;

3119  
3120 (xlviii) ASTM International Standard F877, Standard Specification for  
3121 Crosslinked Polyethylene (PEX) Hot- and Cold-Water Distribution Systems, ASTM F877-20,  
3122 (2020), referred to as “ASTM F877,” available at  
3123 <https://webstore.ansi.org/Standards/ASTM/ASTMF87720>;

3124  
3125 (xlix) ASTM International Standard F2389, Standard Specification for Pressure-  
3126 rated Polypropylene (PP) Piping Systems, ASTM F2389-21, (2021), referred to as “ASTM  
3127 F2389,” available at <https://webstore.ansi.org/Standards/ASTM/ASTMF238921>;

3128  
3129 (l) ASTM International Standard F2806, Standard Specification for  
3130 Acrylonitrile-Butadiene-Styrene (ABS) Plastic Pipe (Metric SDR-PR), ASTM F2806-20, (2020),  
3131 referred to as “ASTM F2806,” available at  
3132 <https://webstore.ansi.org/Standards/ASTM/ASTMF280620>;

3133  
3134 (li) ASTM International Standard F2855, Standard Specification for  
3135 Chlorinated Poly(Vinyl Chloride)/Aluminum/Chlorinated Poly(Vinyl Chloride) (CPVC-AL-  
3136 CPVC) Composite Pressure Tubing ASTM F2855-19, (2019), referred to as “ASTM F2855,”  
3137 available at <https://webstore.ansi.org/Standards/ASTM/ASTMF285519>;

- 3138  
 3139 (lii) ASTM International Standard F2969, Standard Specification for  
 3140 Acrylonitrile-Butadiene-Styrene (ABS) IPS Dimensioned Pressure Pipe ASTM F2969-12(2020),  
 3141 (2020), referred to as “ASTM F2969,” available at  
 3142 <https://webstore.ansi.org/Standards/ASTM/ASTMF2969122020>;  
 3143  
 3144 (liii) Standard Methods for the Examination of Water and Wastewater,  
 3145 published by American Public Health Association, American Water Works Association, and  
 3146 Water Environment Federation, 23rd Edition (2018), referred to as “Standard Methods for the  
 3147 Examination of Water and Wastewater 2018,” available at  
 3148 <https://engage.awwa.org/PersonifyEbusiness/Store/Product-Details/productId/65266295>;  
 3149  
 3150 (liv) Code of Federal Regulations 40 CFR Part 141, in effect as of July 1, 2011,  
 3151 available at: <http://www.ecfr.gov>;  
 3152  
 3153 (lv) Code of Federal Regulations 40 CFR 143.3, in effect as of July 1, 2021;  
 3154 available at: <http://www.ecfr.gov>;  
 3155  
 3156 (lvi) Code of Federal Regulations 40 CFR 173.3(e), in effect as of November 7,  
 3157 2018, available at: <http://www.ecfr.gov>;  
 3158  
 3159 (lvii) United States Department of Agriculture, Natural Resources Conservation  
 3160 Service, Part 631 National Engineering Handbook, Chapter 32 Well Design and Spring  
 3161 Development, Part 631.3201(b)(iii), in effect as of January 2010, referred to as “USDA NRCS  
 3162 Part 631 National Engineering Handbook,” available at  
 3163 <https://directives.sc.egov.usda.gov/OpenNonWebContent.aspx?content=26985.wba>;  
 3164  
 3165 (lviii) Recommended Standards for Water Works, published by Great Lakes  
 3166 Upper Mississippi River Board of State and Provincial Public Health and Environmental  
 3167 Managers, (2018), referred to as “2018 TSS,” available at  
 3168 [https://www.mngovpublications.com/catalog/Default.asp?CatalogID=21656&Provider\\_ID=1241](https://www.mngovpublications.com/catalog/Default.asp?CatalogID=21656&Provider_ID=1241868)  
 3169 [868](https://www.mngovpublications.com/catalog/Default.asp?CatalogID=21656&Provider_ID=1241868);  
 3170  
 3171 (lix) United States Environmental Protection Agency, Long Term 2 Enhanced  
 3172 Surface Water Treatment Rule Toolbox Guidance Manual, 2010, referred to as “Toolbox  
 3173 Guidance Manual,” available at <https://nepis.epa.gov/Exe/ZyPDF.cgi?Dockey=P1009JLI.txt>;  
 3174  
 3175 (lx) United States Environmental Protection Agency, Ultraviolet Disinfection  
 3176 Guidance Manual For The Final Long Term 2 Enhanced Surface Water Treatment Rule, 2006,  
 3177 referred to as “Ultraviolet Disinfection Guidance Manual for the Final LT2ESWTR,” available at  
 3178 <https://nepis.epa.gov/Exe/ZyPDF.cgi?Dockey=600006T3.txt>; and  
 3179  
 3180 (lxi) United States Environmental Protection Agency, Membrane Filtration  
 3181 Guidance Manual, 2005, referred to as “US EPA Membrane Filtration Guidance  
 3182 Manual,” available at  
 3183 <https://nepis.epa.gov/Exe/ZyNET.exe/P1008S15.TXT?ZyActionD=ZyDocument&Client=EPA&>

3184 Index=2006+Thru+2010&Docs=&Query=&Time=&EndTime=&SearchMethod=1&TocRestrict  
3185 =n&Toc=&TocEntry=&QField=&QFieldYear=&QFieldMonth=&QFieldDay=&IntQFieldOp=0  
3186 &ExtQFieldOp=0&XmlQuery=&File=D%3A%5Czyfiles%5CIndex%20Data%5C06thru10%5C  
3187 Txt%5C00000021%5CP1008S15.txt&User=ANONYMOUS&Password=anonymous&SortMeth  
3188 od=h%7C-  
3189 &MaximumDocuments=1&FuzzyDegree=0&ImageQuality=r75g8/r75g8/x150y150g16/i425&D  
3190 isplay=hpfr&DefSeekPage=x&SearchBack=ZyActionL&Back=ZyActionS&BackDesc=Results  
3191 %20page&MaximumPages=1&ZyEntry=1&SeekPage=x&ZyPURL.

3192

3193 (b) For these codes, standards, rules, and regulations incorporated by reference:

3194

3195 (i) The Environmental Quality Council has determined that incorporation of  
3196 the full text in these rules would be cumbersome or inefficient given the length or nature of the  
3197 rules.

3198

3199 (ii) This Chapter does not incorporate later amendments or editions of  
3200 incorporated codes, standards, rules, and regulations.

3201

3202 (iii) All incorporated codes, standards, rules, and regulations are available for  
3203 public inspection at the Department's Cheyenne office. Contact information for the Cheyenne  
3204 office may be obtained at <http://deq.wyoming.gov> or from (307) 777-7937.