

BEFORE THE ENVIRONMENTAL QUALITY COUNCIL
STATE OF WYOMING

In the Matter of the Appeal)
And Petition for Review of:)
BART Permit No. MD-6040)
(Jim Bridger Power Plant); and) Docket No. 10-2801
BART Permit No. MD-6042)
(Naughton Power Plant).)

**RESPONSE TO PACIFICORP'S MOTION FOR PARTIAL SUMMARY
JUDGMENT**

PacifiCorp's Initial BART applications for JB Units 1-4

EXHIBIT 2



William K. Lawson
1407 W. North Temple, Suite 330
Salt Lake City, Utah 84116
801-220-4581

Reviewer KR
Copy to:
Cynthia _____
D.E. _____
File: 6040

January 12, 2007

David A. Finley
Wyoming Department of Environmental Quality
Administrator, Air Quality Division
122 West 25th Street
Cheyenne, Wyoming 82002



Re: PacifiCorp Jim Bridger Units 1, 2, 3 and 4 Best Available Retrofit Technologies Studies

Dear Dave:

Enclosed you will find the best available retrofit technology (BART) analyses that have been completed for Jim Bridger units 1, 2, 3 and 4. Over the next few weeks, we will be forwarding the reports for Dave Johnston units 3 and 4, Wyodak, and Naughton units 1, 2 and 3.

Although these regional haze BART reviews are done on a source-by-source basis, it is important to consider how these individual components come together as a whole. For that reason, I am providing the anticipated schedule of the pollution control projects PacifiCorp will be completing over the next several years.

In 2005, PacifiCorp anticipated spending \$812 million for additional pollution control equipment. Since that time, additional control projects have been identified. These projects, when combined with the higher costs of labor and equipment have increased the expected expenditures to over one billion dollars, the majority of which will be spent over the next five years. PacifiCorp's approach and commitment to reducing power plant emissions and improving regional air quality is indeed significant and aggressive.

I look forward to working with you and the Wyoming Division of Air quality to complete this review and move forward with the implementation of the proposed pollution control projects.

Sincerely,

William K. Lawson
PacifiCorp Energy
Environmental Manager

Attachment - Timing of PacifiCorp's Pollution Control Projects
Enclosures - Jim Bridger units 1, 2, 3 and 4 BART Analysis

Timing of PacifiCorp's Pollution Control Projects			
Plant Name	Scrubber Installations & Upgrades	Low NOx Burner Installation	Precipitator Upgrades / Baghouse Installations
WYOMING PLANTS			
Dave Johnston 3	New Scrubber -2010	2010	
Dave Johnston 4	New Scrubber -2011	2011	Sep-2011
Jim Bridger 1	Scrubber upgrade -2010	2010	
Jim Bridger 2	Scrubber upgrade -2009	Completed 2005	
Jim Bridger 3	Scrubber upgrade -2011	2007	
Jim Bridger 4	Scrubber upgrade -2008	2012	
Naughton 1	New Scrubber -2012	2012	
Naughton 2	New Scrubber -2011	2011	
Naughton 3	Scrubber upgrade -2014	2014	2014
Wyodak	Scrubber upgrade - 2011	2011	
UTAH PLANTS			
Hunter 1	Scrubber upgrade 2010	2010	2010
Hunter 2	Scrubber upgrade 2011	2011	2011
Hunter 3		2007	
Huntington 1	Scrubber upgrade 2010	2010	2010
Huntington 2	Completed 2006	Completed 2006	Completed 2006
ARIZONA PLANT			
Cholla 4	New Scrubber - 2008	2008	2008

Final Report

BART Analysis for Jim Bridger Unit 1

Prepared For:

PacifiCorp
1407 West North Temple
Salt Lake City, Utah 84116

January 12, 2007

Prepared By:

CH2MHILL
215 South State Street, Suite 1000
Salt Lake City, Utah 84111

Final Report



BART Analysis for Jim Bridger Unit 1

Prepared For:

PacifiCorp
1407 West North Temple
Salt Lake City, Utah 84116

January 12, 2007

Prepared By:

CH2MHILL
215 South State Street, Suite 1000
Salt Lake City, Utah 84111

Executive Summary

Background

In response to the Regional Haze Rule and Best Available Retrofit Technology (BART) regulations and guidelines, CH2M HILL was requested to perform a BART analysis for PacifiCorp's Jim Bridger Unit 1 (hereafter referred to as Jim Bridger 1). A BART analysis has been conducted for the following criteria pollutants: oxides of nitrogen (NO_x), sulfur dioxide (SO₂), and particulate matter less than 10 microns in aerodynamic diameter (PM₁₀). The Jim Bridger Station consists of four 530 megawatt (MW) units with a total generating capacity of 2,120 MW. Because the total generating capacity of the Jim Bridger Station exceeds 750 MW, presumptive BART limits apply to Jim Bridger 1, based on the United States Environmental Protection Agency's (EPA) guidelines. BART emissions limits must be achieved within five years after the State Implementation Plan (SIP) is approved by the EPA. A compliance date of 2014 was assumed for this analysis.

In completing the BART analysis, technology alternatives were investigated and potential reductions in NO_x, SO₂, and PM₁₀ emissions rates were identified. The following technology alternatives were investigated, listed below by pollutant:

NO_x emission controls:

- Low NO_x burners with over-fire air
- Rotating opposed fire air
- Low NO_x burners with selective non-catalytic reduction system (SNCR)
- Low NO_x burners with selective catalytic reduction (SCR) system

SO₂ emission controls:

- Optimize current operation of existing wet sodium flue gas desulfurization (FGD) system
- Upgrade wet sodium FGD system to achieve an SO₂ emission rate of 0.10 lb/MMBtu
- New dry FGD system

PM₁₀ emission controls:

- Sulfur trioxide (SO₃) injection flue gas conditioning system on existing electrostatic precipitator
- Polishing fabric filter

BART Engineering Analysis

The specific steps in a BART engineering analysis are identified in the Code of Federal Regulations (CFR) at 40 CFR 51 Appendix Y, Section IV. The evaluation must include:

1. The identification of available, technically feasible, retrofit control options

2. Consideration of any pollution control equipment in use at the source (which affects the availability of options and their impacts)
3. The costs of compliance with the control options
4. The remaining useful life of the facility
5. The energy and non-air quality environmental impacts of compliance
6. The degree of visibility improvement which may reasonably be anticipated from the use of BART

These steps are incorporated into the BART analysis as follows:

Step 1 – Identify All Available Retrofit Control Technologies

Step 2 – Eliminate Technically Infeasible Options

- The identification of available, technically feasible, retrofit control options
- Consideration of any pollution control equipment in use at the source (which affects the applicability of options and their impacts)

Step 3 – Evaluate Control Effectiveness of Remaining Control Technologies

Step 4 – Evaluate Impacts and Document the Results

- The costs of compliance with the control options
- The remaining useful life of the facility
- The energy and non-air quality environmental impacts of compliance

Step 5 – Evaluate Visibility Impacts

- The degree of visibility improvement which may reasonably be anticipated from the use of BART

Separate analyses have been conducted for NO_x, SO₂, and PM₁₀ emissions. All costs included in the BART analyses are in 2006 dollars, and costs have not been escalated to the assumed 2014 BART implementation date.

Coal Characteristics

The main source of coal burned at Jim Bridger 1 will be the Bridger Underground Mine. Secondary sources are the Bridger Surface Mine, the Bridger Highwall Mine, the Black Butte Mine, and the Leucite Hills Mine. These coals are ranked as subbituminous, but are closer in characteristics to bituminous coal in many of the parameters influencing NO_x formation. These coals have higher nitrogen content than coals from the Powder River Basin (PRB), which represent the bulk of subbituminous coal use in the U.S. This BART analysis has considered the higher nitrogen content and different combustion characteristics of PRB coals, as compared to those coals used at Jim Bridger 1, and has evaluated the effect of these qualities on NO_x formation and achievable emission rates.

Recommendations

NO_x Emission Control

The BART presumptive NO_x limit assigned by EPA for tangentially-fired boilers burning subbituminous coal is 0.15 lb/MMBtu. However, as documented in this analysis, the characteristics of the Jim Bridger coals are more closely aligned with bituminous coals, with a presumptive BART NO_x limit of 0.28 lb/MMBtu.

CH2M HILL recommends the existing low-NO_x burners with over-fire air (LNB w/OFA) as BART for Jim Bridger 1, based on the projected significant reduction in NO_x emissions, reasonable control costs, and the advantages of no additional power requirements or non-air quality environmental impacts. NO_x reductions are expected to be similar to those realized at Jim Bridger 2. CH2M HILL recommends that the unit be permitted at a rate of 0.26 lb/MMBtu.

SO₂ Emission Control

CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 1, based on the significant reduction in SO₂ emissions, reasonable control costs, and the advantages of minimal additional power requirements and minimal non-air quality environmental impacts. This upgrade approach will meet the BART presumptive SO₂ limit of 0.15 lb/MMBtu.

PM₁₀ Emission Control

CH2M HILL recommends finalizing the permitting of the flue gas conditioning system to enhance the performance of the existing electrostatic precipitator (ESP) as BART for Jim Bridger 1, based on the significant reduction in PM₁₀ emissions, reasonable control costs, and the advantages of minimal additional power requirements and no non-air quality environmental impacts.

Control Scenario 1

These BART selections, which include installing low NO_x burners with over-fire air, upgrading the existing FGD system, and operating the existing electrostatic precipitator with an SO₃ flue gas conditioning system, are identified as Scenario 1 throughout this report.

BART Modeling Analysis

CH2M HILL used the CALPUFF modeling system to assess the visibility impacts of emissions from Jim Bridger 1 at Class I areas. The Class I areas potentially affected are located more than 50 kilometers, but less than 300 kilometers, from the Jim Bridger Plant.

The Class I areas include the following wilderness areas (WA):

- Bridger WA
- Fitzpatrick WA
- Mt. Zirkel WA

Because Jim Bridger 1 will simultaneously control NO_x, SO₂, and PM₁₀ emissions, four post control atmospheric dispersion modeling scenarios were developed to cover the range of effectiveness for combining the individual NO_x, SO₂ and PM₁₀ control technologies under evaluation. These modeling scenarios, and the controls assumed, are as follows:

- **Scenario 1:** New LNB w/OFA modifications, upgraded wet FGD system, and flue gas conditioning for enhanced ESP performance. As indicated previously, this scenario represents PacifiCorp's preliminary BART selection.
- **Scenario 2:** New LNB w/OFA modifications, upgraded wet FGD system, and new polishing fabric filter.
- **Scenario 3:** New LNB w/OFA modifications and SCR, upgraded wet FGD system, and flue gas conditioning for enhanced ESP performance.
- **Scenario 4:** New LNB w/OFA modifications and SCR, upgraded wet FGD system, and new polishing fabric filter.

Visibility improvements for all emission control scenarios were analyzed, and the results were compared utilizing a Least-Cost Envelope, as outlined in the draft EPA 1990 New Source Review Workshop Manual (NSR Manual).

Least-Cost Envelope Analysis

EPA has adopted the Least-Cost Envelope Analysis Methodology as an accepted methodology for selecting the most reasonable, cost-effective controls. Incremental cost-effectiveness comparisons focus on annualized cost and emission reduction differences between dominant alternatives. The dominant set of control alternatives is determined by generating what is called the envelope of least-cost alternatives. This is a graphical plot of total annualized costs for a total emissions reductions for all control alternatives identified in the BART analysis.

To evaluate the impacts of the modeled control scenarios on the three Class I areas, the total annualized cost, cost per deciview (dV) reduction, and cost per reduction in number of days above 0.5 dV were analyzed. This report provides a comparison of the average incremental costs between relevant scenarios for the three Class I areas; the total annualized cost versus number of days above 0.5 dV, and the total annualized cost versus 98th percentile delta-deciview (Δ dV) reduction.

Results of the Least-Cost Envelope Analysis validate the selection of Scenario 1, based on incremental cost and visibility improvements. Scenario 2 (LNB w/OFA, upgraded wet FGD, and polishing fabric filter) is eliminated, because it is to the left of the curve formed by the "dominant" control alternative scenario, which indicates a scenario with lower improvement and/or higher costs. Scenario 3 (LNB w/OFA and SCR, upgraded wet FGD, and flue gas conditioning for enhanced ESP performance) is not selected due to very high incremental costs, on the basis of both a cost per day of improvement and cost per dV reduction. While Scenario 4 (LNB w/OFA and SCR, upgraded wet FGD, and polishing fabric filter) provides some potential visibility advantage over Scenario 1, the projected improvement is less than half a dV, and the projected costs are excessive. Therefore, Scenario 1 represents BART for Jim Bridger 1.

Just-Noticeable Differences in Atmospheric Haze

Studies have been conducted that demonstrate only dV differences of approximately 1.5 to 2.0 dV or more are perceptible by the human eye. Deciview changes of less than 1.5 cannot be distinguished by the average person. Therefore, the modeling analysis results indicate that only minimal, if any, observable visibility improvements at the Class I areas studied would be expected under any of the control scenarios. Thus, the results indicate that even though PacifiCorp will be spending many millions of dollars at this single unit, and over a billion dollars when considering its entire coal fleet, only minimal discernable visibility improvements may result.

Contents

Acronyms and Abbreviations	iv
1.0 Introduction	1-1
2.0 Present Unit Operation.....	2-1
3.0 BART Engineering Analysis	3-1
3.1 Applicability.....	3-1
3.2 BART Process.....	3-1
3.2.1 BART NO _x Analysis.....	3-2
3.2.2 BART SO ₂ Analysis.....	3-14
3.2.3 BART PM ₁₀ Analysis.....	3-16
4.0 BART Modeling Analysis.....	4-1
4.1 Model Selection	4-1
4.2 CALMET Methodology.....	4-1
4.2.1 Dimensions of the Modeling Domain.....	4-1
4.2.2 CALMET Input Data	4-3
4.2.3 Validation of CALMET Wind Field.....	4-6
4.3 CALPUFF Modeling Approach.....	4-6
4.3.1 Background Ozone and Ammonia.....	4-6
4.3.2 Stack Parameters.....	4-7
4.3.3 Emission Rates.....	4-7
4.3.4 Post Control Scenarios	4-7
4.3.5 Modeling Process.....	4-10
4.3.6 Receptor Grids	4-10
4.4 CALPOST.....	4-10
4.5 Presentation of Modeling Results	4-11
4.5.1 Degree of Visibility Change for Baseline vs. Preferred Scenario.....	4-11
5.0 Preliminary Assessment and Recommendations	5-1
5.1 Least-Cost Envelope Analysis	5-1
5.1.1 Analysis Methodology	5-1
5.1.2 Analysis Results.....	5-8
5.2 Just-Noticeable Differences in Atmospheric Haze	5-8
6.0 References	6-1

Tables

2-1 Unit Operation and Study Assumptions.....	2-1
2-2 Coal Sources and Characteristics	2-3
3-1 Coal Characteristics Comparison.....	3-4
3-2 NO _x Control Technology Emission Rate Ranking	3-7
3-3 NO _x Control Cost Comparison	3-11
3-4 SO ₂ Control Technology Emission Rates	3-14
3-5 SO ₂ Control Cost Comparison (Incremental to Existing FGD System)	3-16

3-6	PM ₁₀ Control Technology Emission Rates	3-18
3-7	PM ₁₀ Control Cost Comparison (Incremental to Existing ESP)	3-18
4-1	User-Specified CALMET Options.....	4-3
4-2	BART Model Input Data.....	4-8
4-3	Average Natural Levels of Aerosol Components	4-11
4-4	Costs and Visibility Modeling Results for Baseline Vs. Post-Control Scenarios at Class I Areas	4-12
5-1	Control Scenario Results for the Bridger Class 1 Wilderness Area	5-2
5-2	Control Scenario Results for the Fitzpatrick Class 1 Wilderness Area	5-3
5-3	Control Scenario Results for the Mt. Zirkel Class 1 Wilderness Area	5-3
5-4	Bridger Class I Wilderness Area Incremental Analysis Data	5-4
5-5	Fitzpatrick Class I Wilderness Area Incremental Analysis Data	5-4
5-6	Mt. Zirkel Class I Wilderness Area Incremental Analysis Data.....	5-4

Figures

3-1	Illustration of the Effect of Agglomeration on the Speed of Coal Combustion ..	3-3
3-2	Plot of Typical Nitrogen Content of Various Coals and Applicable Presumptive BART NO _x Limits	3-5
3-3	Plot of Typical Oxygen Content of Various Coals and Applicable Presumptive BART NO _x Limits	3-5
3-4	First Year Control Cost for NO _x Air Pollution Control Options.....	3-13
3-5	First Year Control Cost for PM ₁₀ Air Pollution Control Options	3-20
4-1	Extent of Modeling Domain.....	4-2
4-2	Surface and Upper Air Station Used.....	4-5
5-1	Least Cost Envelope Bridger WA Class I Area Reduction	5-5
5-2	Least Cost Envelope Bridger WA Class I Area 98 th Percentile.....	5-5
5-3	Least Cost Envelope Fitzpatrick WA Class I Area Reduction	5-6
5-4	Least Cost Envelope Fitzpatrick WA Class I Area 98 th Percentile.....	5-6
5-5	Least Cost Envelope Mt. Zirkel WA Class I Area Reduction	5-7
5-6	Least Cost Envelope Mt. Zirkel WA Class I Area 98 th Percentile.....	5-7

Appendices

A	Economic Analysis
B	2006 Wyoming BART Protocol
C	Just-Noticeable Differences in Atmospheric Haze Dr. Ronald Henry

Acronyms and Abbreviations

BACT	Best Available Control Technology
BART	Best Available Retrofit Technology
CALDESK	Program to display data and results
CALMET	Meteorological data preprocessing program for CALPUFF
CALPOST	Post-processing program for calculating visibility impacts
CALPUFF	Gaussian puff dispersion model
COHPAC	Compact Hybrid Particulate Collector
dV	deciview
Δ dV	delta deciview, change in deciview
DEQ	Department of Environmental Quality
ESP	electrostatic precipitator
EPA	United States Environmental Protection Agency
Fuel NO _x	oxidation of fuel bound nitrogen
FGC	flue gas conditioning
FGD	flue gas desulfurization
<i>f</i> (RH)	relative humidity factors
ID	internal diameter
kW	kilowatts
kW-Hr	kilowatt-hour
LAER	lowest achievable emission rate
lb/MMBtu	pounds per million British Thermal Units
LNB	low-NO _x burner
LOI	loss on ignition
MMBtu	Million British Thermal Units
MM5	Mesoscale Meteorological Model, Version 5
MW	megawatts
N ₂	nitrogen
NO	nitric oxide
NO _x	oxides of nitrogen
NWS	National Weather Service
OFA	over-fire air
PM ₁₀	particulate matter less than 10 microns in aerodynamic diameter

PRB	Powder River Basin
ROFA	Rotating Opposed Fire Air
S&L	Sargent & Lundy
SCR	selective catalytic reduction system
SIP	State Implementation Plan
SNCR	selective non-catalytic reduction system
SO ₂	sulfur dioxide
SO ₃	sulfur trioxide
Thermal NO _x	high temperature fixation of atmospheric nitrogen in combustion air
USGS	U.S. Geological Survey
WA	Wilderness Area
WDEQ-AQD	Wyoming Department of Environmental Quality – Air Quality Division

1.0 Introduction

Best Available Retrofit Technology (BART) guidelines were established as a result of United States Environmental Protection Agency (EPA) regulations intended to reduce the occurrence of regional haze in national parks and other Class I protected air quality areas in the United States¹. These guidelines provide guidance for states when determining which facilities must install additional controls, and the type of controls that must be used. Facilities eligible for BART installation were built between 1962 and 1977, and have the potential to emit more than 250 tons/year of visibility-impairing pollutants.

The Wyoming Department of Environmental Quality (DEQ) BART regulations state that each source subject to BART must submit a BART application for a construction permit by December 15, 2006. PacifiCorp received an extension from the Wyoming DEQ to submit the BART report for Jim Bridger Unit 1 by January 12, 2007. This report to the Wyoming DEQ must include a BART analysis, and a proposal and justification for BART at the source.

The State of Wyoming has identified those eligible in-state facilities that are required to reduce emissions under BART, and will set BART emissions limits for those facilities. This information will be included in the State of Wyoming State Implementation Plan (SIP), which the State has estimated will be formally submitted to the EPA by early 2008. The EPA BART guidelines also state that the BART emission limits must be fully implemented within five years of EPA's approval of the SIP.

There are five basic elements related to BART, when addressing the issue of emissions for the identified facilities:

- Any existing pollution control technology in use at the source
- The cost of the controls
- The remaining useful life of the source
- The energy and non-air environmental impacts of compliance
- The degree of improvement in visibility which may reasonably be anticipated from the use of such technology

This report documents the BART analysis that was performed on Jim Bridger 1 by CH2M HILL for PacifiCorp. The analysis was performed for the pollutants NO_x, SO₂, and particulate matter less than 10 microns in aerodynamic diameter (PM₁₀), because they are the primary criteria pollutants that affect visibility.

Section 2.0 of this report provides a description of the present unit operation, including a discussion of coal sources and characteristics. The BART Engineering Analysis is provided in Section 3.0, by pollutant type. Section 4.0 provides the methodology and results of the BART

¹ 40 CFR Part 51: Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations; Final Rule. 70 Federal Register, 39103-39172, July 6, 2005.

Modeling Analysis, followed by recommendations in Section 5.0. References are provided in Section 6.0. Appendices provide more detail on the Economic Analysis, the 2006 Wyoming BART Protocol, and a paper by Dr. Ronald Henry, titled, *Just Noticeable Differences in Atmospheric Haze*.

2.0 Present Unit Operation

The Jim Bridger Station consists of four units with a total generating capacity of 2,120 megawatts (MW). Jim Bridger 1 is a nominal 530 net MW unit located approximately 35 miles northeast of Rock Springs, Wyoming. Unit 1 is equipped with a tangentially fired pulverized coal boiler with low NO_x burners manufactured by Combustion Engineering. The unit was constructed with a Flakt wire frame electrostatic precipitator (ESP). The unit contains a Babcock & Wilcox wet sodium flue gas desulfurization (FGD) system with three absorber towers installed in 1990. An Emerson Ovation distributed control system (DCS) was installed in 2006.

Jim Bridger 1 was placed in service in 1974. Its current economic depreciation life is through 2040; however, this analysis is based on a 20 year life for BART control technologies. Assuming a BART implementation date of 2014, this will result in an approximate remaining useful life for Jim Bridger 1 of 20 years from the installation date of any new or modified BART-related equipment. This report does not attempt to quantify any additional life extension costs needed to allow the unit and these control devices at Jim Bridger 1 to operate until 2040.

Table 2-1 lists additional unit information and study assumptions for this analysis.

TABLE 2-1
Unit Operation and Study Assumptions
Jim Bridger 1

General Plant Data	
Site Elevation (feet above MSL)	6669
Stack Height (feet)	500
Stack Exit ID (feet) /Exit Area (sq. ft.)	24 /452.4
Stack Exit Temperature (°F)	140
Stack Exit Velocity (ft/sec)	84.0
Stack Flow (ACFM)	2,281,182
Latitude (deg: min: sec)	41:44:07 north
Longitude (deg: min: sec)	108:47:12 west
Annual Unit Capacity Factor (%)	90
Net Unit Output (MW)	530
Net Unit Heat Rate (Btu/kW-Hr)(100% load)	10,400 (as measured by fuel throughput)
Boiler Heat Input (MMBtu/Hr)(100% load)	6,000 (as measured by CEM)
Type of Boiler	Tangentially fired
Boiler Fuel	Coal
Coal Sources	Bridger Mine, Black Butte Mine, Leucite Hills Mine
Coal Heating Value (Btu/lb)*	9,660
Coal Sulfur Content (wt. %)*	0.58
Coal Ash Content (wt. %)*	10.3

TABLE 2-1
Unit Operation and Study Assumptions
Jim Bridger 1

Coal Moisture Content (wt. %)*	19.3
Coal Nitrogen Content (wt. %)*	0.98
Current NO _x Controls	Low NO _x burners
NO _x Emission Rate (lb/MMBtu)	0.45
Current SO ₂ Controls	Sodium based wet scrubber
SO ₂ Emission Rate (lb/MMBtu)	0.3
Current PM ₁₀ Controls	Electrostatic Precipitator
PM ₁₀ Emission Rate (lb/MMBtu)**	0.045

* Coal characteristics based on Bridger Underground Mine (primary coal source)

** Based on maximum historic emission rate from 1999 – 2001, prior to installation of the SO₃ injection system.

The BART presumptive NO_x limit for tangential-fired boilers burning subbituminous coal is 0.15 lb/MMBtu and the BART presumptive NO_x limit for burning bituminous coal is 0.28 lb/MMBtu. The main sources of coal burned at Jim Bridger 1 are the Bridger Mine and secondarily the Black Butte Mine and Leucite Hills Mine. These coals are ranked as subbituminous, but are closer in characteristics to bituminous coal in many of the parameters influencing NO_x formation. These coals have higher nitrogen content than coals from the Powder River Basin (PRB), which represent the bulk of subbituminous coal used in the U.S. This BART analysis has considered the higher nitrogen content and the different combustion characteristics of PRB coals, as compared to those coals used at Jim Bridger 1, and has evaluated the effect of these qualities on NO_x formation and achievable emission rates. Coal sources and characteristics are summarized in Table 2-2. The primary source of coal will be the Bridger Underground Mine, and data on coal from this source were used in the modeling analysis. For the coal analysis that is presented in Section 3.2.1, the data from all the coal sources were used.

TABLE 2-2
Coal Sources and Characteristics
Jim Bridger 1

Mines	Ultimate Analysis (% dry basis)												
	Moist. %	Ash %	Volatile Matter %	Fixed Carbon %	Btu/lb	Sulfur %	MAF (Btu/lb)	Hydrogen	Carbon	Sulfur	Nitrogen	Oxygen	Ash
Bridger Mine Underground	19.3	10.3	32.2	38.3	9660	0.58	13712	4.66	69.2	0.72	1.22	11.8	12.4
Max	Not enough data yet to run statistical analysis for variability												
Min	Not enough data yet to run statistical analysis for variability												
Bridger Mine Surface	19.1	10.6	32.3	38.0	9390	0.57	13340	4.38	37.4	0.71	1.26	13.2	13.0
Max	20.5	12.5	35.5	41.9	9800	0.72	13500	4.69	4.0	0.90	1.43	14.8	15.8
Min	17.5	9.0	31.0	36.0	9000	0.49	13100	4.00	64.3	0.60	1.14	11.7	11.2
Bridger Mine Highwall	18.0	9.5	33.0	39.5	9700	0.58	13500	No samples of separate highwall coal					
Max	Not enough data yet to run statistical analysis for variability												
Min	Not enough data yet to run statistical analysis for variability												
Black Butte Mine	20.0	9.2	33.3	35.6	9450	0.45	13330	4.43	68.7	0.56	1.47	13.4	11.5
Max	21.1	10.8	35.4	41.9	10275	0.62	13500	4.66	70.5	0.78	1.69	14.8	13.6
Min	18.0	7.6	29.9	36.8	9180	0.33	13140	4.21	66.1	0.41	1.25	11.6	9.7
Leucite Hills Mine (through 2009)	19.4	11.5	30.7	38.3	9080	0.64	13140	4.20	66.0	0.81	1.48	13.2	14.4
Max	23.0	15.0	33.0	43.0	10250	0.90	13800	4.70	70.0	1.20	1.64	17.1	19.0
Min	17.0	8.0	28.3	33.6	8000	0.40	12300	3.70	61.0	0.50	1.32	10.5	10.0

3.0 BART Engineering Analysis

This section presents the required BART engineering analysis.

3.1 Applicability

In compliance with regional haze requirements, the State of Wyoming must prepare and submit visibility SIPs to the EPA for Class I areas. The State has estimated that the formal submittal of the SIPs will occur by early 2008. The first phase of the regional haze program is the implementation of BART emission controls on all BART eligible units, within five years after EPA approval of the SIP.

3.2 BART Process

The specific steps in a BART engineering analysis are identified in the Code of Federal Regulations (CFR) at 40 CFR 51 Appendix Y, Section IV. The evaluation must include:

1. The identification of available, technically feasible, retrofit control options
2. Consideration of any pollution control equipment in use at the source (which affects the availability of options and their impacts)
3. The costs of compliance with the control options
4. The remaining useful life of the facility
5. The energy and non-air quality environmental impacts of compliance, and
6. The degree of visibility improvement which may reasonably be anticipated from the use of BART

These steps are incorporated into the BART analysis as follows:

Step 1 – Identify All Available Retrofit Control Technologies

Step 2 – Eliminate Technically Infeasible Options

- The identification of available, technically feasible, retrofit control options
- Consideration of any pollution control equipment in use at the source (which affects the applicability of options and their impacts)

Step 3 – Evaluate Control Effectiveness of Remaining Control Technologies

Step 4 – Evaluate Impacts and Document the Results

- The costs of compliance with the control options
- The remaining useful life of the facility
- The energy and non-air quality environmental impacts of compliance

Step 5 – Evaluate Visibility Impacts

- The degree of visibility improvement which may reasonably be anticipated from BART use.

In order to minimize costs in the BART analysis, consideration was made of any pollution control equipment in use at the source, the costs of compliance associated with the control options, and the energy and non-air quality environmental impacts of compliance using these existing control devices. In some cases, enhancing the performance of the existing control equipment was considered. Other scenarios with new control equipment were also developed.

Separate analyses have been conducted for NO_x, SO₂, and PM₁₀ emissions. All costs included in the BART analysis are in 2006 dollars, and costs have not been escalated to the assumed 2014 BART implementation date.

3.2.1 BART NO_x Analysis

NO_x formation in coal-fired boilers is a complex process that is dependent on a number of variables, including operating conditions, equipment design, and coal characteristics.

3.2.1.1 Formation of NO_x

During coal combustion, NO_x is formed in three different ways. The dominant source of NO_x formation is the oxidation of fuel-bound nitrogen (fuel NO_x). During combustion, part of the fuel-bound nitrogen is released from the coal with the volatile matter, and part is retained in the solid portion (char). The nitrogen chemically bound in the coal is partially oxidized to nitrogen oxides (NO and NO₂) and partially reduced to molecular nitrogen (N₂). A smaller part of NO_x formation is due to high temperature fixation of atmospheric nitrogen in the combustion air (thermal NO_x). A very small amount of NO_x is called “prompt” NO_x. Prompt NO_x results from an interaction of hydrocarbon radicals, nitrogen, and oxygen.

In a conventional pulverized coal burner, air is introduced with turbulence to promote good mixing of fuel and air, which provides stable combustion. However, not all of the oxygen in the air is used for combustion. Some of the oxygen combines with the fuel nitrogen to form NO_x.

Coal characteristics directly and significantly affect NO_x emissions from coal combustion. Coal ranking is a means of classifying coals according to their degree of metamorphism in the natural series, from lignite to subbituminous to bituminous and on to anthracite. Lower rank coals, such as the subbituminous coals from the PRB, produce lower NO_x emissions than higher rank bituminous coals, due to their higher reactivity and lower nitrogen content. The fixed carbon to volatile matter ratio (fuel ratio), coal oxygen content, and rank are good relative indices of the reactivity of a coal. Lower rank coals release more organically bound nitrogen earlier in the combustion process than do higher rank bituminous coals. When used with low NO_x burners, subbituminous coals create a longer time for the kinetics to promote more stable molecular nitrogen, and hence result in lower NO_x emissions.

Coals from the PRB are classified as subbituminous C and demonstrate the high reactivity and low NO_x production characteristics described above. Based on data from the Energy Information Administration (EIA), PRB coals currently represent 88 percent of total U.S. subbituminous production and 73 percent of western coal production. Most references to “western” coal and subbituminous coal infer PRB origin and characteristics. Emissions standards differentiating

between bituminous and subbituminous coals are presumed to use PRB coal as the basis for the subbituminous standards, due to their dominant market presence and unique characteristics.

There are a number of western coals that are classified as subbituminous, however, they border on being ranked as bituminous and do not display many of the qualities of PRB coals, including most of the low NO_x forming characteristics. Coals from the Bridger, Black Butte, and Leucite Hills mines fall into this category.

As defined by the American Society for Testing and Materials, the only distinguishing characteristic that classifies the coals used at Jim Bridger 1 as subbituminous rather than bituminous – that is, they are “agglomerating” as compared to “non-agglomerating”. Agglomerating as applied to coal is “the property of softening when it is heated to above about 400°C in a non-oxidizing atmosphere, and then appearing as a coherent mass after cooling to room temperature.” Because the agglomerating property of coals is the result of particles transforming into a plastic or semi-liquid state when heated, it reflects a change in surface area of the particle. Thus, with the application of heat, agglomerating coals would tend to develop a non-porous surface, while the surface of non-agglomerating coals would become even more porous with combustion. As shown by Figure 3-1, the increased porosity provides more particle surface area, resulting in more favorable combustion conditions. This non-agglomerating property assists in making subbituminous coals more amenable to controlling NO_x , by allowing less air to be introduced during the initial ignition portion of the combustion process. The coals from the Bridger, Black Butte and Leucite Hills mines just barely fall into the category of non-agglomerating coals. While each of these coals is considered non-agglomerating, they either do not exhibit those properties of non-agglomerating coals or exhibit them to only a minor degree. The conditions during combustion of typical non-agglomerating coals that make it easier to control NO_x emissions do not exist during combustion of the Bridger blends of coals.

FIGURE 3-1
Illustration of the Effect of Agglomeration on the Speed of Coal Combustion
Jim Bridger 1




Table 3-1 shows key characteristics of a typical PRB coal, compared to coals from the Bridger Mine, Black Butte, and Leucite Hills, as well as coal from Twentymile, which is a representative western bituminous coal.

TABLE 3-1
Coal Characteristics Comparison
Jim Bridger 1

Parameter	Typical PRB	Bridger Mine	Black Butte	Leucite Hills	Twentymile
Nitrogen (% dry)	1.10	1.26	1.47	1.48	1.85
Oxygen (% dry)	16.2	13.2	13.4	13.2	7.19
Coal rank	Sub C	Sub B	Sub B	Sub B	Bitum. high volatility B

As shown in Table 3-1, although Bridger, Black Butte, and Leucite Hills are classified as subbituminous, they all exhibit higher nitrogen content and lower oxygen content than the PRB coal. The higher nitrogen content is an indication that more nitrogen is available to the combustion process and higher NO_x emissions are likely. Oxygen content can be correlated to the reactivity of the coal, with more reactive coals generally containing higher levels of oxygen. More reactive coals tend to produce lower NO_x emissions, and they are also more conducive to reduction of NO_x emissions through the use of combustion control measures, such as low NO_x burners and over-fire air (OFA). These characteristics indicate that higher NO_x formation is likely with coal from the Bridger, Black Butte, and Leucite Hills mines, rather than with PRB coal. The Bridger, Black Butte, and Leucite Hills coals all contain quality characteristics that fall between a typical PRB coal and Twentymile. Twentymile is a clearly bituminous coal that produces higher NO_x, as has been demonstrated at power plants burning this fuel.

Figures 3-2 and 3-3 graphically illustrate the relationship of nitrogen and oxygen content to the BART presumptive NO_x limits for the coals listed in Table 3-1. Each chart identifies the presumptive BART limit associated with a typical bituminous and subbituminous coal, and demonstrates how the Jim Bridger coal falls between these two general coal classifications.

The Bridger blend data point represents a combination of coals from the Bridger Mine, Black Butte, and Leucite Hills that has been used at Jim Bridger 1, and indicates the average NO_x emission rate achieved during the years 2003-2005. The Jim Bridger 2 data point consists of the same blend of coals as Jim Bridger 1, and represents the NO_x emission rate achieved after installation of Alstom's current state of the art TFS2000 LNB and OFA system. The long-term sustainable emission rate for this system is expected to be 0.24 lb/MMBtu. All four units at Jim Bridger consist of identical boilers; while there may be some differences in performance among them, installation of the TFS2000 firing system at Jim Bridger 1 would likely result in performance and NO_x emission rates comparable to those at Jim Bridger 2.

Figures 3-2 and 3-3 both demonstrate that for the Jim Bridger units with the TFS2000 low NO_x emission system installed and burning a combination of the Bridger, Black Butte, and Leucite Hill coals, the likely NO_x emission rate will be closer to the bituminous end (0.28) of the BART presumptive NO_x limit range, rather than the BART presumptive NO_x limit of 0.15 lb/MMBtu

for subbituminous coal. All these factors are consistent with the observed sustainable rate of 0.24 lb/MMBtu.

FIGURE 3-2
Plot of Typical Nitrogen Content of Various Coals and Applicable Presumptive BART NO_x Limits
Jim Bridger 1





FIGURE 3-3
Plot of Typical Oxygen Content of Various Coals and Applicable Presumptive BART NO_x Limits
Jim Bridger 1



Coal quality characteristics also impact the design and operation of the boiler and associated auxiliary equipment. Minor changes in quality can sometimes be accommodated through operational adjustments or changes to equipment. It is important to note, however, that consistent variations in quality or assumptions of “average” quality for performance projections can be problematic. This is particularly troublesome when dealing with performance issues that are very sensitive to both coal quality and combustion conditions, such as NO_x formation. There is significant variability in the quality of coals burned at Jim Bridger 1. In addition to burning coal from Black Butte and Leucite Hills, Jim Bridger 1 burns coal supplied from the Bridger Mine consisting of three sources: underground, surface, and highwall operations. Each of these coal sources has different quality characteristics, as well as inherent variability in composition of the coal within the mine.

Several of the coal quality characteristics and their effect on NO_x formation have been previously discussed. There are some additional considerations that illustrate the complexity of achieving and maintaining consistent low NO_x emissions with pulverized coal on a shorter term, such as a 30-day rolling average basis.

Good combustion is based on the “three Ts”: time, temperature and turbulence. These parameters along with a “design” coal are taken into consideration when designing a boiler and associated firing equipment such as fans, burners, and pulverizers. If a performance requirement such as NO_x emission limits is subsequently changed, conflicts with other performance issues can result.

Jim Bridger 1 is located at an altitude of 6,669 feet above sea level. At this elevation, atmospheric pressure is lower (11.5 pounds per square inch) as compared with sea level pressure of 14.7 pounds per square inch. This lower pressure means that less oxygen is available for combustion for each volume of air. In order to provide adequate oxygen to meet the requirements for efficient combustion, larger volumes of air are required. When adjusting air flows and distribution to lower NO_x using low NO_x burners and overfire air, original boiler design restrictions again limit the modifications that can be made and still achieve satisfactory combustion performance.

Another significant factor in controlling NO_x emissions is the fineness of the coal entering the burners. Fineness is influenced by the grindability index (Hardgrove) of the coal. Finer coal particles promote release of volatiles and assist char burnout due to more surface area exposed to air. NO_x reduction with high volatile coals is improved with greater fineness and with proper air staging. The lower rank subbituminous coals such as PRB coals are quite friable and easy to grind. Coals with lower Hardgrove Grindability Index values, such as those used at Jim Bridger 1, are more difficult to grind and can contribute to higher NO_x levels. In addition, coal fineness can deteriorate over time periods between pulverizer maintenance and service as pulverizer grinding surfaces wear.

In summary, when all the factors of agglomeration versus non-agglomeration, nitrogen and oxygen content of the coals, and the grindability index are taken into account, this analysis demonstrates that, for the coal used at Jim Bridger 1, the more applicable presumptive BART limit is 0.28 lb/MMBtu. The BART analysis for NO_x emissions from Jim Bridger 1 is further described below.

3.2.1.2 Step 1: Identify All Available Retrofit Control Technologies

The first step of the BART process is to evaluate NO_x control technologies with practical potential for application to Jim Bridger 1, including those control technologies identified as Best Available Control Technology (BACT) or lowest achievable emission rate (LAER) by permitting agencies across the United States. A broad range of information sources have been reviewed in an effort to identify potentially applicable emission control technologies. Jim Bridger 1 NO_x emissions are currently controlled through the use of good combustion practices and OFA.

The following potential NO_x control technology options were considered:

- New/modified low-NO_x burners (LNB) with advanced OFA
- Rotating Opposed Fire Air (ROFA)
- Conventional selective non-catalytic reduction system (SNCR)
- Selective catalytic reduction system (SCR)

3.2.1.3 Step 2: Eliminate Technically Infeasible Options

For Jim Bridger 1, a tangential-fired configuration burning subbituminous coal, technical feasibility will primarily be determined by physical constraints, boiler configuration, and on the ability to achieve the regulatory presumptive limit (used as a guide) of 0.28 lb NO_x/MMBtu. Jim Bridger 1 has an uncontrolled NO_x emission rate of 0.45 lb/MMBtu.

For this BART analysis, information pertaining to LNBs, OFA, SNCR, and SCR were based on the Multi-Pollutant Control Report dated October, 2002 (S&L Study). The cost estimates for SCR and SNCR were updated by Sargent & Lundy (S&L) in October 2006. PacifiCorp provided additional emissions data and costs developed by boiler vendors for LNBs and OFA. Also, CH2M HILL solicited a proposal from Mobotec for their ROFA technology.

With SNCR, an amine-based reagent such as ammonia, or more commonly urea, is injected into the furnace within a temperature range of 1,600° F to 2,100° F, where it reduces NO_x to nitrogen and water. NO_x reductions of up to 40 to 60 percent have been achieved, although 15 to 30 percent is more realistic for most applications. SNCR is typically applied on smaller units. Adequate reagent distribution in the furnaces of large units can be problematic.

Table 3-2 summarizes the control technology options evaluated in this BART analysis, along with projected NO_x emission rates. All technologies can meet the applicable presumptive BART limit of 0.28 lb/MMBTU.

TABLE 3-2
NO_x Control Technology Emission Rate Ranking
Jim Bridger 1

Technology	Projected Emission Rate (lb/MMBtu)
Presumptive BART Limit	0.28
LNB w/OFA	0.24
ROFA	0.22

TABLE 3-2
 NO_x Control Technology Emission Rate Ranking
 Jim Bridger 1

Technology	Projected Emission Rate (lb/MMBtu)
LNB w/OFA & SNCR	0.20
LNB w/OFA & SCR	0.07

3.2.1.4 Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

Preliminary vendor proposals, such as those used to support portions of this BART analysis, may be technically feasible and provide expected or guaranteed emission rates; however, they include inherent uncertainties. These proposals are usually prepared in a limited time frame, may be based on incomplete information, may contain over-optimistic conclusions, and are non-binding. Therefore, emission rate values obtained in such preliminary proposals must be qualified, and it must be recognized that contractual guarantees are established only after more detailed analysis has been completed. The following subsections describe the control technologies and the control effectiveness evaluated in this BART analysis.

New LNBs with OFA System. The mechanism used to lower NO_x with low NO_x burners is to stage the combustion process and provide a fuel rich condition initially; this is so oxygen needed for combustion is not diverted to combine with nitrogen and form NO_x. Fuel-rich conditions favor the conversion of fuel nitrogen to N₂ instead of NO_x. Additional air (or OFA) is then introduced downstream in a lower temperature zone to burn out the char.

Both LNBs and OFA are considered to be a capital cost, combustion technology retrofit. For LNB retrofits to units configured with tangential-firing such as Jim Bridger 1, it is generally necessary to increase the burner spacing; this prevents interaction of the flames from adjacent burners and reduces burner zone heat flux. These modifications usually require boiler waterwall tube replacement.

Information provided to CH2M HILL by PacifiCorp – based on the S&L Study and data from boiler vendors – indicates that new LNB and OFA retrofit at Jim Bridger 1 would result in an expected NO_x emission rate of 0.24 lb/MMBtu. PacifiCorp has indicated that this rate corresponds to a vendor guarantee, not a vendor prediction, and they believe that this emission rate can be sustained as an average between overhauls. This emission rate represents a significant reduction from the current NO_x emission rate, and is below the more applicable presumptive NO_x emission rate of 0.28 lb/MMBtu.

ROFA. Mobotec markets ROFA as an improved second generation OFA system. Mobotec states that “the flue gas volume of the furnace is set in rotation by asymmetrically placed air nozzles. Rotation is reported to prevent laminar flow, so that the entire volume of the furnace can be used more effectively for the combustion process. In addition, the swirling action reduces the maximum temperature of the flames and increases heat absorption. The combustion air is also mixed more effectively”. A typical ROFA installation will have a booster fan(s) to supply the high velocity air to the ROFA boxes, and Mobotec would propose two 4,000 to 4,300 Hp fans for Jim Bridger 1.

Mobotec expects to achieve a NO_x emission rate of 0.18 lb/MMBtu using ROFA technology. An operating margin of 0.04 lb/MMBtu was added to the expected rate due to Mobotec's limited ROFA experience with western subbituminous coals. Under the Mobotec proposal, primarily based on ROFA equipment, the operation of existing LNB and OFA ports will be analyzed. While a typical installation does not require modification to the existing LNB system, and the existing OFA ports are not used, results of computational fluid dynamics modeling will determine the quantity and location of new ROFA ports. The Mobotec proposal includes bent tube assemblies for OFA port installation. Mobotec does not provide installation services, because they believe that the Owner can more cost effectively contract for these services. However, they do provide one onsite construction supervisor during installation and startup.

SNCR. Selective non-catalytic reduction is generally utilized to achieve modest NO_x reductions on smaller units. With SNCR, an amine-based reagent such as ammonia – or more commonly urea – is injected into the furnace within a temperature range of 1,600°F to 2,100°F, where it reduces NO_x to nitrogen and water. NO_x reductions of up to 60 percent have been achieved, although 20 to 40 percent is more realistic for most applications.

Reagent utilization, which is a measure of the efficiency with which the reagent reduces NO_x, can range from 20 to 60 percent, depending on the amount of reduction, unit size, operating conditions, and allowable ammonia slip. With low reagent utilization, low temperatures, or inadequate mixing, ammonia slip occurs, allowing unreacted ammonia to create problems downstream. The ammonia may render fly ash unsaleable, react with sulfur to foul heat exchange surfaces, and/or create a visible stack plume. Reagent utilization can have a significant impact on economics, with higher levels of NO_x reduction generally resulting in lower reagent utilization and higher operating cost.

Reductions from higher baseline concentrations (inlet NO_x) are lower in cost per ton, but result in higher operating costs, due to greater reagent consumption. To reduce reagent costs, S&L has assumed that combustion modifications including LNBS and advanced OFA, capable of achieving a projected NO_x emission rate of 0.24 lb/MMBtu. At a further reduction of 15 percent in NO_x emission rates for SNCR would result in a projected emission rate of 0.20 lb/MMBtu.

SCR. SCR works on the same chemical principle as SNCR but SCR uses a catalyst to promote the chemical reaction. Ammonia is injected into the flue-gas stream, where it reduces NO_x to nitrogen and water. Unlike the high temperatures required for SNCR, in SCR the reaction takes place on the surface of a vanadium/titanium-based catalyst at a temperature range between 580° F to 750° F. Due to the catalyst, the SCR process is more efficient than SNCR and results in lower NO_x emissions. The most common type of SCR is the high-dust configuration, where the catalyst is located downstream from the boiler economizer and upstream of the air heater and any particulate control equipment. In this location, the SCR is exposed to the full concentration of fly ash in the flue gas that is leaving the boiler. The high-dust configuration is assumed for Jim Bridger 1. In a full-scale SCR, the flue ducts are routed to a separate large reactor containing the catalyst. With in-duct SCR, the catalyst is located in the existing gas duct, which may be expanded in the area of the catalyst to reduce flue gas flow velocity and increase flue gas residence time. Due to the higher removal rate, a full-scale SCR was used as the basis for analysis at Jim Bridger 1.

S&L prepared the design conditions and cost estimates for SCR at Jim Bridger 1. As with SNCR, it is generally more cost effective to reduce NO_x emission levels as much as possible through combustion modifications, in order to minimize the catalyst surface area and ammonia requirements of the SCR. The S&L design basis for LNB w/OFA and SCR results in a projected NO_x emission rate of 0.07 lb/MMBtu. Additional catalyst surface was included in the SCR design to accommodate the characteristics of the coal used at Jim Bridger 1..

Level of Confidence for Vendor Post-Control Emissions Estimates. In order to determine the level of NO_x emissions needed to consistently achieve compliance with an established goal, a review of typical NO_x emissions from coal-fired generating units was completed. As a result of this review, it was noted that NO_x emissions can vary significantly around an average emissions level. This variance can be attributed to many reasons, including coal characteristics, unit load, boiler operation including excess air, boiler slagging, burner equipment condition, coal mill fineness, and so forth.

The steps utilized for determining a level of confidence for the vendor expected value are as follows:

1. Establish expected NO_x emissions value from vendor.
2. Evaluate vendor experience and historical basis for meeting expected values.
3. Review and evaluate unit physical and operational characteristics and restrictions. The fewer variations there are in operations, coal supply, etc., the more predictable and less variant the NO_x emissions are.
4. For each technology expected value, there is a corresponding potential for actual NO_x emissions to vary from this expected value. From the vendor information presented, along with anticipated unit operational data, an adjustment to the expected value can be made.

3.2.1.5 Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

Energy Impacts. Installation of LNBs and modification to the existing OFA systems are not expected to significantly impact the boiler efficiency or forced draft fan power usage. Therefore, these technologies will not have energy impacts.

The Mobotec ROFA system requires installation and operation of two 4,000 to 4,300 Hp ROFA fans (6,410 kW total). The SNCR system would require approximately 530 kW of additional power.

SCR retrofit impacts the existing flue gas fan systems, due to the additional pressure drop associated with the catalyst, which is typically a 6- to 8-inch water gage increase. Total additional power requirements for SCR installation at Jim Bridger 1 are estimated at approximately 3,280 kW, based on the S&L Study.

Environmental Impacts. Mobotec has predicted that CO emissions, and unburned carbon in the ash, commonly referred to as LOI (loss on ignition), would be the same or lower than prior levels for the ROFA system.

SNCR and SCR installation could impact the salability and disposal of fly ash due to ammonia levels, and could potentially create a visible stack plume, which may negate other visibility improvements. Other environmental impacts involve the storage of ammonia, especially if anhydrous ammonia is used, and the transportation of the ammonia to the power plant site.

Economic Impacts. Costs and schedules for the LNBs and OFA, SNCR, and SCR were furnished to CH2M HILL by PacifiCorp, developed using S&L's internal proprietary database, and supplemented (as needed) by vendor-obtained price quotes. The relative accuracy of these cost estimates is stated by S&L to be in the range of ± 20 percent. Cost for the ROFA system was obtained from Mobotec.

A comparison of the technologies on the basis of costs, design control efficiencies, and tons of NO_x removed is summarized in Table 3-3, and the first year control costs in Figure 3-4. The complete Economic Analysis is contained in Appendix A.

TABLE 3-3
NO_x Control Cost Comparison
Jim Bridger 1


Factor	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR
Total Installed Capital Costs	\$8.7 Million	\$20.5 Million	22.1 Million	\$129.6 Million
Total First Year Fixed & Variable O&M Costs	\$0.1 Million	\$2.6 Million	\$1.5 Million	\$3.3 Million
Total First Year Annualized Cost	\$0.9 Million	\$4.6 Million	\$3.6 Million	\$15.6 Million
Power Consumption (MW)	0	6.4	0.5	3.3
Annual Power Usage (1000 MW-Hr/Yr)	0	50.6	4.2	25.8
NO _x Design Control Efficiency	46.7%	51.1%	55.6%	84.4%
NO _x Removed per Year (Tons)	4,967	5,440	5,913	8,987
First Year Average Control Cost (\$/Ton of NO _x Removed)	\$181/ton	\$843/ton	\$613/ton	\$1,736/ton
Incremental Control Cost (\$/Ton of NO _x Removed)	\$181/ton	\$7,797/ton	\$2,885/ton	\$3,894/ton

Preliminary BART Selection. PacifiCorp selects Low-NO_x Burners with OFA as BART for Jim Bridger 1 based on its significant reduction in NO_x emissions, reasonable control cost, and no additional power requirements or environmental impacts. LNB w/OFA does not meet the EPA presumptive limit of 0.15 lb/MMBtu for subbituminous coal, but it does meet an emission rate that falls between the bituminous coal presumptive limit of 0.28 lb/MMBtu and the 0.15 lb/MMBtu limit for subbituminous coal, which, as discussed in the section on coal quality, is appropriate for this unit.

3.2.1.6 Step 5: Evaluate Visibility Impacts

Please see Section 4.0, BART Modeling Analysis.

FIGURE 3-4
 First Year Control Cost for NO_x Air Pollution Control Options
 Jim Bridger 1



3.2.2 BART SO₂ Analysis

SO₂ forms in the boiler during the combustion process, and is primarily dependent on coal sulfur content. The BART analysis for SO₂ emissions on Jim Bridger 1 is described below.

3.2.2.1 Step 1: Identify All Available Retrofit Control Technologies

A broad range of information sources were reviewed, in an effort to identify potentially applicable emission control technologies for SO₂ at Jim Bridger 1; this included control technologies identified as BACT or LAER by permitting agencies across the United States.

The following potential SO₂ control technology options were considered:

- Optimize current operation of existing wet sodium FGD system
- Upgrade wet sodium FGD system to meet SO₂ emission rate of 0.10 lb/MMBtu
- New dry FGD system

3.2.2.2 Step 2: Eliminate Technically Infeasible Options

Technical feasibility will primarily be based on the regulatory presumptive limit (used as a guideline) of 95 percent reduction in SO₂ emissions, or 0.15 lb/MMBtu. Based on the coal that Jim Bridger 1 currently burns, the unit would be required to achieve an 87.5 percent SO₂ removal efficiency to meet the presumptive limit of 0.15 lb/MMBtu.

Table 3-4 summarizes the control technology options evaluated in this BART analysis, along with projected SO₂ emission rates. Only one technology option can meet the applicable presumptive BART limit of 0.15 lb/MMBtu.

TABLE 3-4
SO₂ Control Technology Emission Rates
Jim Bridger 1

Technology	Projected Emission Rate (lb/MMBtu)
Presumptive BART Limit	0.15
Upgrade Existing Wet Sodium System	0.10
Optimize Existing Wet Sodium System	0.20
New Dry FGD System	0.21

Wet Sodium FGD System. Wet sodium FGD systems operate by treating the flue gas in large scrubber vessels with a soda ash solution. The scrubber mixes the flue gas and alkaline reagent using a series of spray nozzles to distribute the reagent across the scrubber vessel. The sodium in the reagent reacts with the SO₂ in the flue gas to form sodium sulfite and sodium bisulfite, which are removed from the scrubber and disposed.

The wet sodium FGD system at Jim Bridger 1 currently achieves approximately 78 percent SO₂ removal to achieve an SO₂ outlet emission rate of 0.27 lb/MMBtu. Optimizing the existing wet FGD system is projected to achieve an SO₂ outlet emission rate of 0.20 lb/MMBtu (83.3 percent SO₂ removal). Optimization would be accomplished by partially closing the

bypass damper to reduce the routine bypass flue gas flow used to reheat the treated flue gas from the scrubber, relocating the opacity monitor, and modifying the system to minimize scaling problems.

Upgrading the wet FGD system would achieve an SO₂ outlet emission rate of 0.10 lb/MMBtu (91.7 percent SO₂ removal). Upgrading the system would involve closing the bypass damper to eliminate the routine bypass flue gas flow used to reheat the treated flue gas from the scrubber, relocating the opacity monitor, adding new fans, adding a stack liner and drains for wet operation, and using a refined soda ash reagent. It is considered to be technically infeasible for the present wet FGD system to achieve a 95 percent SO₂ removal (0.06 lb/MMBtu) on a continuous basis since this high level of removal must be incorporated into the original design of the scrubber.

Optimizing the existing wet sodium scrubbing FGD system is projected to achieve an outlet emission rate of 0.20 lb/MMBtu, which would not meet the presumptive limit of 0.15 lb SO₂/MMBtu. Therefore, this option is eliminated as technically infeasible for this analysis. An upgraded wet sodium scrubbing FGD system is projected to achieve an outlet emission rate of 0.10 lb/MMBtu (91.7 percent SO₂ removal), which would meet the presumptive limit of 0.15 lb SO₂/MMBtu for Jim Bridger 1.

New Dry FGD System. The lime spray dryer typically injects lime slurry in the top of the absorber vessel with a rapidly rotating atomizer wheel. The rapid speed of the atomizer wheel causes the lime slurry to separate into very fine droplets that intermix with the flue gas. The SO₂ in the flue gas reacts with the calcium in the lime slurry to form dry calcium sulfate particles. At Jim Bridger 1 this dry particulate matter would be captured downstream in the existing ESP, along with the fly ash. A lime spray dryer system typically produces a dry waste product suitable for landfill disposal.

The dry FGD system with the existing ESP is projected to achieve 82.5 percent SO₂ removal at Jim Bridger 1. This would result in a controlled SO₂ emission rate of 0.21 lb/MMBtu, based on an uncontrolled SO₂ emission rate of 1.20 lb/MMBtu. Therefore, this option cannot meet the presumptive limit of 0.15 lb SO₂/MMBtu, and is eliminated from further analysis.

3.2.2.3 Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

When evaluating the control effectiveness of SO₂ reduction technologies, each option can be compared against benchmarks of performance. One such benchmark is the presumptive BART emission limit because Jim Bridger 1 is required to meet this limit. As indicated previously, the presumptive limit for SO₂ on a BART-eligible coal burning unit is 95 percent removal, or 0.15 lb/MMBtu.

The projected emission rate for an upgraded wet sodium FGD system for Jim Bridger 1 would be 0.10 lb/MMBtu. This option would meet the presumptive SO₂ limit of 0.15 lb/MMBtu.

3.2.2.4 Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

Energy Impacts. Upgrading the existing wet sodium FGD system would require an additional 530 kW of power.

Environmental Impacts. There will be incremental additions to scrubber waste disposal and makeup water requirements, and a reduction of the stack gas temperature from 140°F to 120°F due to elimination of reheating by the bypassed flue gas.

Economic Impacts. A summary of the costs and amount of SO₂ removed for the upgraded wet sodium FGD system is provided in Table 3-5. The complete Economic Analysis is contained in Appendix A.

TABLE 3-5
SO₂ Control Cost Comparison (Incremental to Existing FGD System)
Jim Bridger 1

Factor	Upgraded Wet FGD
Total Installed Capital Costs	\$13.0 Million
Total First Year Fixed & Variable O&M Costs	\$1.3 Million
Total First Year Annualized Cost	\$2.5 Million
Additional Power Consumption (MW)	0.5
Additional Annual Power Usage (1000 MW-Hr/Yr)	4.2
Incremental SO ₂ Design Control Efficiency	62.5% (91.7% based on Uncontrolled SO ₂)
Incremental Tons SO ₂ Removed per Year	3,950
First Year Average Control Cost (\$/Ton of SO ₂ Removed)	632
Incremental Control Cost (\$/Ton of SO ₂ Removed)	632

Preliminary BART Selection. CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 1, based on significant reduction in SO₂ emissions (meeting presumptive limit of 0.15 lb/MMBtu), reasonable control costs, and the advantages of minimal additional power requirements and environmental impacts.

3.2.2.5 Step 5: Evaluate Visibility Impacts

Please see Section 4.0, BART Modeling Analysis.

3.2.3 BART PM₁₀ Analysis

Jim Bridger 1 is currently equipped with an electrostatic precipitator (ESP). ESPs remove particulate matter from the flue gas stream by charging fly ash particles with a very high direct current voltage, and attracting these charged particles to grounded collection plates. A layer of collected particulate matter forms on the collecting plates and is removed by periodically rapping the plates. The collected ash particles drop into hoppers below the precipitator and are removed periodically by the fly ash-handling system. Historically, the ESP at Jim Bridger 1 has controlled PM₁₀ emissions to levels below 0.045 lb/MMBtu.

The BART analysis for PM₁₀ emissions at Jim Bridger 1 is described below. For the modeling analysis in Section 4.0, PM₁₀ was used as an indicator for PM, and PM₁₀ includes PM_{2.5} as a subset.

3.2.3.1 Step 1: Identify All Available Retrofit Control Technologies

Two retrofit control technologies have been identified for additional PM control:

- Flue gas conditioning
- Polishing fabric filter (baghouse) downstream of Existing ESP

Another available control technology is replacing the existing ESP with a new fabric filter. However, because the environmental benefits that would be achieved by a replacement fabric filter are also achieved by installing a polishing fabric filter downstream of the existing ESP at lower costs, installation of a full fabric filter was not considered in the analysis.

3.2.3.2 Step 2: Eliminate Technically Infeasible Options

Flue Gas Conditioning. If the fly ash from coal has high resistivity, such as fly ash from subbituminous coal, the ash is not collected effectively in an ESP. This is because the high resistivity makes the particles less willing to accept an electrical charge. Adding flue gas conditioning (FGC), which is typically accomplished by injection of sulfur trioxide (SO₃), will lower the resistivity of the particles so that they will accept more charge and allow the ESP to collect the ash more effectively. Flue gas conditioning systems can account for large improvements in collection efficiency for small ESPs.

Polishing Fabric Filter. A polishing fabric filter could be added downstream of the existing ESP at Jim Bridger 1. One such technology is licensed by the Electric Power Research Institute, and referred to as a COHPAC (Compact Hybrid Particulate Collector). The COHPAC collects the ash that is not collected by the ESP, thus acting as a polishing device. The ESP needs to be kept in service for the COHPAC fabric filter to operate effectively.

The COHPAC fabric filter is about one-half to two-thirds the size of a full size fabric filter, because the COHPAC has a higher air-to-cloth ratio (7 to 9:1), compared to a full size pulse jet fabric filter (3.5 to 4:1).

3.2.3.3 Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

The existing ESP at Jim Bridger 1 is achieving a controlled PM emission rate of 0.045 lb/MMBtu. Utilizing flue conditioning upstream of the existing ESP is projected to reduce PM emissions to approximately 0.030 lb/MMBtu. Adding a COHPAC fabric filter downstream of the existing ESP is projected to reduce PM emissions to approximately 0.015 lb/MMBtu.

The PM₁₀ control technology emission rates are summarized in Table 3-6.

TABLE 3-6
PM₁₀ Control Technology Emission Rates
Jim Bridger 1

Control Technology	Short-Term Expected PM ₁₀ Emission Rate (Lb/MMBtu)
Flue Gas Conditioning	0.030
Polishing Fabric Filter	0.015

3.2.3.4 Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

Energy Impacts. Energy is required to overcome the additional pressure drop from the COHPAC fabric filter and associated ductwork. Therefore, a COHPAC retrofit will require an ID fan upgrade and upgrade of the auxiliary power supply system.

A COHPAC fabric filter at Jim Bridger 1 would require approximately 3.4 MW of power, equating to an annual power usage of approximately 26.7 million kW-Hr.

There is only a small power requirement of approximately 50 kw associated with flue gas conditioning.

Environmental Impacts. There are no negative environmental impacts from the addition of a COHPAC polishing fabric filter or flue gas conditioning system.

Economic Impacts. A summary of the costs and PM removed for COHPAC and flue gas conditioning is recorded in Table 3-7, and the first-year control costs for flue gas conditioning and fabric filters are shown in Figure 3-5. The complete Economic Analysis is contained in Appendix A.

TABLE 3-7
PM₁₀ Control Cost Comparison (Incremental to Existing ESP)
Jim Bridger 1

Factor	Flue Gas Conditioning	Polishing Fabric Filter
Total Installed Capital Costs	\$0	\$48.4 Million
Total First Year Fixed & Variable O&M Costs	\$0.2 Million	\$1.8 Million
Total First Year Annualized Cost	\$0.2 Million	\$ 6.4 Million
Additional Power Consumption (MW)	0.05	3.4
Additional Annual Power Usage (1000 MW-Hr/Yr)	0.4	26.7
Incremental PM Design Control Efficiency	33.3%	66.7%
Incremental Tons PM Removed per Year	355	710

TABLE 3-7
 PM₁₀ Control Cost Comparison (Incremental to Existing ESP)
 Jim Bridger 1


Factor	Flue Gas Conditioning	Polishing Fabric Filter
First Year Average Control Cost (\$/Ton of PM Removed)	495	8,973
Incremental Control Cost (\$/Ton of PM Removed)	495	17,452

Preliminary BART Selection. PacifiCorp selects flue gas conditioning as BART for Jim Bridger 1 based on its significant reduction in PM emissions, reasonable control cost, minimum additional power requirements and no environmental impacts.

3.2.3.5 Step 5: Evaluate Visibility Impacts

Please see Section 4.0, BART Modeling Analysis.

FIGURE 3-5
First Year Control Cost for PM Air Pollution Control Options
Jim Bridger 1



4.0 BART Modeling Analysis

4.1 Model Selection

CH2M HILL used the CALPUFF modeling system to assess the visibility impacts of emissions from Jim Bridger 1 at nearby Class I areas. The Class I areas potentially affected are located more than 50 kilometers but less than 300 kilometers from the Jim Bridger 1 facility. The Class I areas include the following wilderness areas (WA):

- Bridger WA
- Fitzpatrick WA
- Mt. Zirkel WA

The CALPUFF modeling system includes the CALMET meteorological model, a Gaussian puff dispersion model (CALPUFF) with algorithms for chemical transformation and deposition, and a post processor capable of calculating concentrations, visibility impacts, and deposition (CALPOST). The CALPUFF modeling system was applied in a full, refined mode. Version numbers of the various programs in the CALPUFF system used by CH2M HILL were as follows:

- CALMET Version 5.53a, Level 040716
- CALPUFF Version 5.711a, Level 040716
- CALPOST Version 5.51, Level 030709

4.2 CALMET Methodology

4.2.1 Dimensions of the Modeling Domain

CH2M HILL used the CALMET model to generate a three-dimensional wind field and other meteorological parameters suitable for use by the CALPUFF model. A modeling domain was established to encompass the Jim Bridger 1 facility and allow for a 50-km buffer around the Class I areas that were within 300 km of the facility. Grid resolution was 4 km. Figure 4-1 shows the extent of the modeling domain. Except when specifically instructed otherwise by the Wyoming Department of Environmental Quality – Air Quality Division (WDEQ-AQD), CH2M HILL followed the methodology spelled out in the WDEQ-AQD BART Modeling Protocol, a copy of which is included in this report as Appendix B.

CH2M HILL used the Lambert Conformal Conic map projection for the analysis due to the large extent of the domain. The latitude of the projection origin and the longitude of the central meridian were chosen at the approximate center of the domain. Standard parallels were drawn to represent 1/6 and 5/6 of the north-south extent of the domain to minimize distortion in the north-south direction.

FIGURE 4-1
Extent of Modeling Domain
Jim Bridger 1




Figure 4-1
Jim Bridger Source-Specific
Class I Areas to be Addressed



CH2MHILL

FILE: \\C:\CORP\BART\GTS\INTERP\ARTFILES\JIM BRIDGER CLASSIFIED\FIGURES\FIG 4-1.DWG

The default technical options listed in TRC Companies, Inc.'s (TRC) current example CALMET.inp file were used for CALMET. Vertical resolution of the wind field included ten layers, with vertical face heights as follows (in meters):

- 0, 20, 40, 100, 140, 320, 580, 1020, 1480, 2220, 3500

Other user-specified model options were set to values established by WDEQ-AQD, which appear in Table 3 of Appendix B. Table 4-1 lists the key user-specified options used for this analysis.

TABLE 4-1
User-Specified CALMET Options
Jim Bridger 1

CALMET Input Parameter	Value
CALMET Input Group 2	
Map projection (PMAP)	Lambert Conformal
Grid spacing (DGRIDKM)	4
Number vertical layers (NZ)	10
Top of lowest layer (m)	20
Top of highest layer (m)	3500
CALMET Input Group 4	
Observation mode (NOOBS)	0
CALMET Input Group 5	
Prog. Wind data (IPROG)	14
(RMAX1)	30
(RMAX2)	50
Terrain influence (TERRAD)	15
(R1)	5
(R2)	25
CALMET Input Group 6	
Max mixing ht (ZIMAX)	3500

4.2.2 CALMET Input Data

CH2M HILL ran the CALMET model to produce three years of analysis: 2001, 2002, and 2003. WDEQ-AQD provided 12-km resolution Mesoscale Meteorological Model, Version 5 (MM5) meteorological data fields that covered the entire modeling domain for each study year.

These three data sets were chosen because they are current and have been evaluated for quality. The MM5 data were used as input to CALMET as the "initial guess" wind field. The initial guess wind field was adjusted by CALMET for local terrain and land use effects to generate a

Step 1 wind field, and further refined using local surface observations to create a final Step 2 wind field.

Surface data for 2001-2003 were obtained from the National Climatic Data Center. CH2M HILL processed the data from the National Weather Service's Automated Surface Observing System (ASOS) network for all stations that are in the domain. The surface data were obtained in abbreviated DATSAV3 format. A conversion routine available from the TRC website was used to convert the DATSAV3 files to CD-144 format for input into the SMERGE preprocessor and CALMET.

Land use and terrain data were obtained from the U.S. Geological Survey (USGS). Land use data were obtained in Composite Theme Grid format from the USGS, and the Level I USGS land use categories were mapped into the 14 primary CALMET land use categories. Surface properties such as albedo, Bowen ratio, roughness length, and leaf area index were computed from the land use values. Terrain data were taken from USGS 1-degree Digital Elevation Model data, which primarily derive from USGS 1:250,000 scale topographic maps. Missing land use data were filled with values that were assumed appropriate for the missing area.

Precipitation data were obtained from the National Climatic Data Center. All available data in fixed-length, TD-3240 format were obtained for the modeling domain. The list of available stations that have collected complete data varies by year, but CH2M HILL processed all available stations/data within the domain for each year. Precipitation data were prepared with the PXTRACT/PMERGE processors in preparation for use within CALMET.

Upper-air data were prepared for the CALMET model with the READ62 preprocessor for the following stations:

- Denver, Colorado
- Salt Lake City, Utah
- Riverton, Wyoming
- Rapid City, South Dakota

Figure 4-2 shows the locations of surface and upper air stations within the MM5 modeling domain.

FIGURE 4-2
Surface and Upper Air Station Locations
Jim Bridger 1




Figure 4-2
Surface and Upper Air Stations Used in the
Jim Bridger BART Analysis



CH2MHILL

310 US GOVERNMENT PRINTING OFFICE: 2003 O 300340 11/03/03

4.2.3 Validation of CALMET Wind Field

CH2M HILL used the CALDESK data display and analysis system (v2.97, Enviromodeling Ltd.) to view plots of wind vectors and other meteorological parameters to evaluate the CALMET wind fields. The CALDESK displays were compared to observed weather conditions, as depicted in surface and upper-air weather maps from the National Oceanic and Atmospheric Administration Central Library U.S. Daily Weather Maps Project (http://docs.lib.noaa.gov/rescue/dwm/data_rescue_daily_weather_maps.html).

4.3 CALPUFF Modeling Approach

For the BART control technology visibility improvement modeling, CH2M HILL followed WDEQ-AQD guidance provided in the document titled *BART Air Modeling Protocol - Individual Source Visibility Assessments for BART Control Analyses* (September, 2006).

A modeling protocol titled *Modeling Protocol for BART Control Technology Improvement Modeling Analysis* (CH2M HILL, August, 2006) was submitted to WDEQ-AQD for review. In the protocol, CH2M HILL described how the general CALMET/CALPUFF approach recommended by the WDEQ-AQD would be used to model Jim Bridger 1.

CH2M HILL drove the CALPUFF model with the meteorological output from CALMET over the modeling domain described earlier. The CALPUFF model was used to predict visibility impacts for the pre-control (baseline) scenario for comparison to the predicted impacts for post-control scenarios for Jim Bridger 1.

4.3.1 Background Ozone and Ammonia

Hourly values of background ozone concentrations were used by CALPUFF for the calculation of SO₂ and NO_x transformation with the MESOPUFF II chemical transformation scheme. CH2M HILL obtained hourly ozone data from the following stations located within the modeling domain for 2001, 2002, and 2003:

- Rocky Mountain National Park, Colorado
- Craters of the Moon National Park, Idaho
- Highland, Utah
- Thunder Basin National Grasslands, Wyoming
- Yellowstone National Park, Wyoming
- Centennial, Wyoming
- Pinedale, Wyoming

For periods of missing hourly ozone data, the chemical transformation relied on a monthly default value of 44 parts per billion. Background ammonia was set to 2 parts per billion. Both of these background values were taken from the WDEQ-AQD document *BART Air Modeling Protocol - Individual Source Visibility Assessments for BART Control Analyses* (September, 2006).

4.3.2 Stack Parameters

The stack parameters used for the baseline modeling reflect those that are in place under the current permit for Jim Bridger 1. Post-control stack parameters reflect the anticipated changes associated with installation of the control technology alternatives that are being evaluated. The maximum heat input rate of 6,000 MMBtu/hr was used to calculate a maximum emission rate. Measured velocities and stack flow rates were used in the modeling to represent a worst-case situation.

4.3.3 Emission Rates

Pre-control emission rates for Jim Bridger 1 reflect peak 24-hour average emissions that may occur under the source's current permit. The emission rates reflect actual emissions under normal operating conditions, as described by the EPA in the *Regional Haze Regulations and Guidelines for Best Available Retrofit Technology Determinations; Final Rule* (40 CFR Part 51; July 6, 2005, pg 39129).

CH2M HILL used available continuous emission monitoring data to determine peak 24-hour emission rates. Data reflected operations from the most recent 3 to 5 year period, unless a more recent period was more representative. Allowable short-term (24-hour or shorter period) emissions or short-term emission limits were used if continuous emission monitoring data were not available.

Emissions were modeled for the following pollutants:

- SO₂
- NO_x
- Coarse particulate (PM_{2.5}<diameeter<PM₁₀)
- Fine particulate (diameeter<PM_{2.5})
- Sulfates

Post-control emission rates reflect the effects of the emissions control scenario under consideration. Modeled pollutants were the same as those listed for the pre-control scenario.

4.3.4 Post Control Scenarios

Four post control modeling scenarios were developed to cover the range of effectiveness for the combination of the individual NO_x, SO₂ and PM control technologies being evaluated. The selection of each control device was made based on the engineering analyses performed in Section 3 for reasonable technologies that would meet or exceed the presumptive BART levels for each pollutant.

- **Scenario 1:** New LNB w/OFA modifications, upgraded wet FGD system and flue gas conditioning for enhanced ESP performance. As indicated previously, this scenario represents CH2M HILL's preliminary BART recommendation.
- **Scenario 2:** New LNB w/OFA modifications, upgraded wet FGD system and new polishing fabric filter
- **Scenario 3:** New LNB w/OFA modifications and SCR, upgraded wet FGD system and flue gas conditioning for enhanced ESP performance.

- **Scenario 4:** New LNB w/OFA modifications and SCR, upgraded wet FGD system and new polishing fabric filter.

The ROFA option and LNB w/OFA & SCR option for NO_x control were not included in the modeling scenarios because their control effectiveness is between the LNB w/OFA option and the SCR option. Modeling of NO_x, SO₂ and PM controls alone was not performed because any final BART solution will include a combination of control technologies for NO_x, SO₂ and PM.

Table 4-2 presents the stack parameters and emission rates used for the Jim Bridger 1 analysis for baseline and post-control modeling. In accordance with the WDEQ BART modeling protocol, elemental carbon stack emissions and organic aerosol emissions were not modeled.

TABLE 4-2
BART Model Input Data
Jim Bridger 1

	Baseline	Post Control Scenario 1	Post Control Scenario 2	Post Control Scenario 3	Post Control Scenario 4
	Current Operations with wet FGD and ESP	LNB with OFA, Upgrade Wet FGD & FGC for Enhanced ESP Performance	LNB with OFA, Upgrade Wet FGD, New Fabric Filter	LNB with OFA and SCR, Upgrade Wet FGD & FGC for Enhanced ESP Performance	LNB with OFA and SCR, Upgrade Wet FGD, New Fabric Filter
Heat Input (MMBtu/hr)	6,000	6,000	6,000	6,000	6,000
SO ₂ Stack Emissions (lb/MMBTU)	0.3	0.10	0.10	0.10	0.10
SO ₂ Stack Emissions (lb/hr)	1600	600	600	600	600
NO _x Stack Emissions (lb/MMBTU)	0.45	0.24	0.24	0.07	0.07
NO _x Stack Emissions (lb/hr)	2,700	1,440	1,440	420	420
PM ₁₀ Stack Emissions (lb/MMBTU)	0.045	0.030	0.015	0.030	0.015
PM ₁₀ Stack Emissions (lb/hr)	270	180	90.0	180	90
PM ₁₀ -PM _{2.5} Stack Emissions (lb/hr) ⁽¹⁾	116	77.4	51.3	77.4	51.3
PM _{2.5} -PM ₀ Stack Emissions (lb/hr) ⁽¹⁾	154	103	38.7	103	38.7
HF Stack Emissions (lb/MMBTU)	0.00055	0.00055	0.00055	0.00055	0.00055
HF Stack Emissions (lb/hr)	3.3	3.3	3.3	3.3	3.3
HCl Stack Emissions (lb/MMBTU)	0.00075	0.00075	0.00075	0.00075	0.00075
HCl Stack Emissions (lb/hr)	4.5	4.5	4.5	4.5	4.5
H ₂ SO ₄ Stack Emissions (lb/MMBTU)	0.0092	0.0092	0.0092	0.0158	0.0158
H ₂ SO ₄ Stack Emissions (lb/hr)	55.2	55.20	55.20	94.80	94.80
H ₂ SO ₄ as SO ₄ Stack Emissions (lb/hr)	54.1	54.07	54.07	92.87	92.87
(NH ₄) ₂ SO ₄ Stack Emissions (lb/MMBTU)				0.00117	0.00117

TABLE 4-2
BART Model Input Data
Jim Bridger 1

	Baseline	Post Control Scenario 1	Post Control Scenario 2	Post Control Scenario 3	Post Control Scenario 4
	Current Operations with wet FGD and ESP	LNB with OFA, Upgrade Wet FGD & FGC for Enhanced ESP Performance	LNB with OFA, Upgrade Wet FGD, New Fabric Filter	LNB with OFA and SCR, Upgrade Wet FGD & FGC for Enhanced ESP Performance	LNB with OFA and SCR, Upgrade Wet FGD, New Fabric Filter
(NH ₄) ₂ SO ₄ Stack Emissions (lb/hr)				7.02	7.02
(NH ₄) ₂ SO ₄ as SO ₄ Stack Emissions (lb/hr)				5.10	5.10
(NH ₄)HSO ₄ Stack Emissions (lb/MMBtu)				0.00204	0.00204
(NH ₄)HSO ₄ as SO ₄ Stack Emissions (lb/hr)				12.2	12.2
(NH ₄)HSO ₄ as SO ₄ Stack Emissions (lb/hr)				10.22	10.22
Total Filterable PM ₁₀ (lb/hr) (Incl. PM _{2.5})	278	188	97.8	187.8	97.8
Total Sulfate (as SO ₄) (lb/hr)	54.1	54.1	54.1	108.2	108.2
Stack Conditions					
Stack Height (feet)	500	500	500	500	500
Stack Height (m)	152	152	152	152	152
Stack Exit Diameter (feet)	24.00	24.00	24.00	24.00	24.00
Stack Exit Diameter (m)	7.32	7.32	7.32	7.32	7.32
Stack Exit Temperature (°F)	140	120	140	140	140
Stack Exit Temperature (°K)	333.2	322.0	333.2	333.2	333.2
Stack Exit Flow (acfm)	2,281,182	2,205,179	2,437,627	2,437,627	2,437,627
Stack Exit Area (ft ²)	452	452	452	452	452
Stack Exit Velocity (fps) ⁽²⁾	84.04	81.24	89.81	89.81	89.81
Stack Exit Velocity (m/s)	25.75	24.76	27.37	27.37	27.37

Notes:

(1) Based on AP-42, Table 1.1-6, as percent of PM₁₀. See factors below.

	ESP	Baghouse
PM ₁₀ -PM _{2.5} Stack Emissions (lb/hr)	43	57
PM _{2.5} -PM ₀ Stack Emissions (lb/hr)	57	43

(2) Scenarios 2, 3, and 4 were not remodeled at the lower, correct velocity of 81.24 fps due to lack of time and the fact that the conclusions to select Scenario 1 would not have changed.

4.3.5 Modeling Process

The CALPUFF modeling for the control technology options for Jim Bridger 1 followed this sequence:

- Model pre-control (baseline) emissions
- Model preferred post-control scenario (if applicable)
- Determine degree of visibility improvement
- Model other control scenarios
- Determine degree of visibility improvement
- Factor visibility results into BART “5-step” evaluation

4.3.6 Receptor Grids

Discrete receptors for the CALPUFF modeling were placed at uniform receptor spacing along the boundary and in the interior of each area of concern. Class I area receptors were taken from the National Park Service (NPS) database for Class I area modeling receptors. The TRC COORDS program was used to convert all latitude/longitude coordinates to Lambert Conformal Conic coordinates, including receptors, meteorological stations, and source locations.

4.4 CALPOST

The CALPOST processor was used to determine 24-hour average visibility results with output specified in deciview (dV) units. Calculations of light extinction were made for each pollutant modeled. The sum of all extinction values were used to calculate the delta-dV change relative to natural background. Default light extinction coefficients for each pollutant, as shown below, were used.

- | | |
|---------------------------------|------|
| • Ammonium sulfate | 3.0 |
| • Ammonium nitrate | 3.0 |
| • PM coarse (PM ₁₀) | 0.6 |
| • PM fine (PM _{2.5}) | 1.0 |
| • Organic carbon | 4.0 |
| • Elemental carbon | 10.0 |

CALPOST visibility Method 6 was used to determine the visibility impacts. Monthly relative humidity factors [f (RH)] were used in the light extinction calculations to account for the hygroscopic characteristics of nitrate and sulfate particles. Table 5 of the Wyoming BART Air Modeling Protocol (Appendix B) lists the monthly f (RH) factors for the Class I areas. These values were used for the particular Class I area being modeled.

The natural background conditions as a reference for determining the delta-dV (Δ dV) change represented the 20 percent best natural visibility days. The EPA BART guidance document provided dV values for the 10 percent best days for each Class I area, but did not provide individual species concentration data for the 20 percent best background conditions. Species concentrations corresponding to the 20 percent best days were calculated for each Class I area by scaling back the annual average species concentrations given in Table 2-1 of *Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule*. A separate scaling

factor was derived for each Class I area such that, when multiplied by the Guidance table annual concentrations, the 20 percent best days dV value for that area would be calculated. This procedure was taken from *Protocol for BART-Related Visibility Improvement Modeling Analysis in North Dakota* (North Dakota Department of Health; October 26, 2005). However, the Wyoming BART Air Modeling Protocol provided natural background concentrations of aerosol components to use in the BART analysis. Table 4-3 lists the annual average species concentrations from the BART protocol.

TABLE 4-3
Average Natural Levels of Aerosol Components
Jim Bridger 1

Aerosol Component	Average Natural Concentration (micrograms per cubic meter) for Mt. Zirkel Class I Wilderness Area	Average Natural Concentration (micrograms per cubic meter) for Fitzpatrick and Bridger Class I Wilderness Areas
Ammonium Sulfate	0.046	0.045
Ammonium Nitrate	0.038	0.038
Organic Carbon	0.179	0.178
Elemental Carbon	0.008	0.008
Soil	0.190	0.189
Coarse Mass	1.141	1.136

Note: Taken from Table 6 of the Wyoming BART Air Modeling Protocol

4.5 Presentation of Modeling Results

This section presents the results of the CALPUFF visibility improvement modeling analysis for Jim Bridger 1.

4.5.1 Degree of Visibility Change for Baseline vs. Preferred Scenario

CH2M HILL modeled Jim Bridger 1 for the baseline and its post-control Scenario 1. The post-control scenario included emission rates for SO₂, NO_x, and PM₁₀ that would be achieved if BART state-of-the-art technology were installed on Unit 1.

Baseline (and post-control) 98th percentile results were greater than 0.5 ΔdV for the Bridger WA, Fitzpatrick WA, and Mt. Zirkel WA. The 98th percentile results for each Class I area are presented in Table 4-4.

TABLE 44
Costs and Visibility Modeling Results for Baseline Vs. Post-Control Scenarios at Class I Areas
Jim Bridger 1

Scenario	First Year Cost	Class I Area	Highest (Adv)	98th Percentile (Adv)	No. of Days Above 0.5 DV	Cost per DV Reduction	Reduction in No. of Days Above 0.5 DV	Incremental Cost per DV Reduction	Incremental Cost per Reduction in No. of Days Above 0.5 DV
Baseline - Current Operation with Wet FGD and ESP									
Scenario 1 - LNB w/OFA, upgraded wet FGD system, FGC for enhanced ESP performance.	\$3,392,440	Fitzpatrick WA	1.695	0.267	3	\$16,309,808	\$848,110	\$265,275,788	NA
	\$3,392,440	ML Zihkel WA	2.313	1.463	35	\$5,759,697	\$242,317	\$424,441,260	NA
Scenario 2 - LNB w/OFA, upgraded wet FGD system, and new polishing fabric filter.	\$9,759,059	Bridger WA	1.584	0.403	7	\$24,892,211	\$750,697	\$265,275,788	NA
	\$9,759,059	Fitzpatrick WA	1.379	0.292	3	\$43,762,596	\$2,439,765	\$424,441,260	NA
	\$9,759,059	ML Zihkel WA	1.308	0.807	21	\$14,876,614	\$697,076	\$641,143	NA
Scenario 3 - LNB w/OFA and SCR, upgraded wet FGD system, FGC for enhanced ESP performance	\$18,093,916	Bridger WA	1.022	0.404	3	\$46,167,346	\$1,084,348	\$5,334,856,773	\$2,083,714
	\$18,093,916	Fitzpatrick WA	0.792	0.163	2	\$57,993,320	\$3,616,783	\$93,650,076	\$8,334,857
	\$18,093,916	ML Zihkel WA	0.894	0.537	8	\$18,539,666	\$570,145	\$30,869,840	\$641,143
Scenario 4 - LNB w/OFA and SCR, upgraded wet FGD system, new polishing fabric filter.	\$24,460,535	Bridger WA	0.986	0.393	3	\$60,666,116	\$1,438,856	\$578,783,537	NA
	\$24,460,535	Fitzpatrick WA	0.772	0.158	2	\$77,162,570	\$4,692,107	\$1,273,323,781	\$1,665,971
	\$24,460,535	ML Zihkel WA	0.868	0.521	8	\$25,956,697	\$905,946	\$397,913,681	NA
Baseline - Current Operation with Wet FGD and ESP									
Scenario 1 - LNB w/OFA, upgraded wet FGD system, FGC for enhanced ESP performance.	\$3,392,440	Fitzpatrick WA	1.169	0.418	7	\$8,481,100	\$565,407	\$93,650,076	\$1,665,971
	\$3,392,440	ML Zihkel WA	1.931	0.967	17	\$3,981,737	\$109,434	\$21,648,979	\$1,041,857
Scenario 2 - LNB w/OFA, upgraded wet FGD system, and new polishing fabric filter.	\$9,759,059	Bridger WA	1.082	0.407	6	\$23,744,669	\$1,394,151	\$578,783,537	\$6,986,619
	\$9,759,059	Fitzpatrick WA	1.878	0.964	18	\$11,414,104	\$325,302	\$2,122,206,301	\$9,366,619
	\$9,759,059	ML Zihkel WA	1.115	0.579	10	\$14,591,868	\$476,156	\$21,648,979	\$1,041,857
Scenario 3 - LNB w/OFA and SCR, upgraded wet FGD system, FGC for enhanced ESP performance	\$18,093,916	Bridger WA	0.592	0.235	1	\$31,895,485	\$1,507,828	\$53,088,260	\$1,665,971
	\$18,093,916	Fitzpatrick WA	0.583	0.247	1	\$42,838,064	\$2,038,378	\$2,122,206,301	NA
	\$18,093,916	ML Zihkel WA	1.097	0.571	10	\$19,589,787	\$643,688	\$795,827,363	NA

TABLE 4-4
Costs and Visibility Modeling Results for Baseline Vs. Post-Control Scenarios at Class 1 Areas
Jim Bridger 1

Scenario	First Year Cost	Class / Area	Highest (ADV)	98th Percentile (ADV)	No. of Days Above 0.5 ADV	Cost per dV Reduction	Cost per Reduction in No. of Days Above 0.5 dV	Incremental Cost per dV Reduction	Incremental Cost per Reduction in No. of Days Above 0.5 dV
Baseline - Current Operation with Wet FGD and ESP									
Scenario 1 - LNB w/OFA, upgraded wet FGD system, FGC for enhanced ESP performance.	\$3,392,440	Bridger WA	1,193	0.482	7	\$3,355,784	\$339,244	\$172,070,781	\$5,366,619
	\$3,392,440	Fitzpatrick WA	1,202	0.237	3	\$15,077,511	\$446,110		NA
	\$3,392,440	Mt. Zirkel WA	1,219	0.839	19	\$10,007,198	\$130,478		NA
Scenario 2 - LNB w/OFA, upgraded wet FGD system, and new polishing fabric filter.	\$9,759,059	Bridger WA	1,156	0.455	6	\$22,029,478	\$887,187	\$159,165,473	\$5,366,619
	\$9,759,059	Fitzpatrick WA	1,177	0.239	3	\$43,702,596	\$2,439,795		NA
	\$9,759,059	Mt. Zirkel WA	1,239	0.839	18	\$14,808,891	\$361,447		NA
Scenario 3 - LNB w/OFA and SCR, upgraded wet FGD system, FGC for enhanced ESP performance	\$18,093,916	Bridger WA	0.993	0.316	3	\$31,089,202	\$1,292,423	\$59,992,998	\$2,778,286
	\$18,093,916	Fitzpatrick WA	0.795	0.163	2	\$60,514,768	\$3,618,793	\$109,669,188	\$8,334,857
	\$18,093,916	Mt. Zirkel WA	0.764	0.546	8	\$17,879,383	\$489,025	\$23,611,492	\$33,485
Scenario 4 - LNB w/OFA and SCR, upgraded wet FGD system, new polishing fabric filter.	\$24,460,535	Bridger WA	0.951	0.304	3	\$41,179,351	\$1,747,181	\$530,551,575	NA
	\$24,460,535	Fitzpatrick WA	0.718	0.158	2	\$80,462,285	\$4,892,107	\$1,273,323,781	NA
	\$24,460,535	Mt. Zirkel WA	0.741	0.535	8	\$23,910,591	\$681,098	\$978,783,537	NA
Scenario 1									
		Bridger WA				\$7,398,311	\$270,743		
		Fitzpatrick WA				\$13,289,473	\$753,876		
		Mt. Zirkel WA				\$5,582,865	\$180,743		
Scenario 2									
		Bridger WA				\$20,070,603	\$737,315	\$499,483,240	NA
		Fitzpatrick WA				\$37,089,564	\$2,091,227	-\$726,694,885	NA
		Mt. Zirkel WA				\$13,899,870	\$461,275	\$792,131,979	\$5,366,619
Scenario 3									
		Bridger WA				\$31,616,079	\$1,072,795	-\$2,748,617,487	\$2,315,238
		Fitzpatrick WA				\$50,121,191	\$2,915,131	\$85,469,168	\$8,112,228
		Mt. Zirkel WA				\$17,337,032	\$545,108	\$25,376,770	\$839,829
Scenario 4									
		Bridger WA				\$41,790,873	\$1,450,274	\$533,025,009	NA
		Fitzpatrick WA				\$66,820,973	\$3,940,864	\$1,565,294,621	NA
		Mt. Zirkel WA				\$23,158,992	\$736,913	\$590,841,527	NA

Sample Calculations: Cost per dV Reduction for Scenario 1 for 2001:
 $= \$3,392,440 / (0.786 - 0.427) = \$9,193,605$
 Sample Calculations: Cost per Reduction in No. of Days Above 0.5 dV for 2001:
 $= \$3,392,440 / (20 - 7) = \$260,957$

5.0 Preliminary Assessment and Recommendations

As a result of the completed technical and economic evaluations, and consideration of the modeling analysis for Jim Bridger 1, the preliminary recommended BART controls for NO_x, SO₂, and PM are as follows:

- New LNBS and modifications to the OFA system for NO_x control
- Upgrade wet sodium FGD for SO₂ control
- Add flue gas conditioning upstream of existing ESPs for PM control

The above recommendations were identified as Scenario 1 for the modeling analysis described in Section 4.0. Visibility improvements for all emission control scenarios were analyzed, and the results are compared below, utilizing a Least-Cost Envelope, as outlined in the draft EPA 1990 *New Source Review Workshop Manual (NSR Manual)*.

5.1 Least-Cost Envelope Analysis

The total annualized cost, cost per dV reduction, and cost per reduction in number of days above 0.5 dV for the scenarios modeled in Section 4 to determine the impact on the three Class I areas are listed in Tables 5-1 through 5-3. A comparison of the incremental costs between relevant scenarios is shown in Tables 5-4 through 5-6. The total annualized cost versus number of days above 0.5 dV, and the total annualized cost versus 98th percentile ΔV reduction are shown in Figures 5-1 to 5-6 for the three Class I areas.

5.1.1 Analysis Methodology

Page B-41 of the New Source Review (NSR) Manual, EPA states that “Incremental cost-effectiveness comparisons should focus on annualized cost and emission reduction differences between dominant alternatives. Dominant set of control alternatives are determined by generating what is called the envelope of least-cost alternatives. This is a graphical plot of total annualized costs for a total emissions reductions for all control alternatives identified in the BACT analysis...”

An analysis of incremental cost effectiveness has been conducted. This analysis was performed in the following way. First, the control option scenarios are ranked in ascending order of annualized total costs as shown in Tables 5-1 through 5-3. The incremental cost effectiveness data, expressed per day and per dV, represents a comparison of the different scenarios, and is summarized in Tables 5-4 through 5-6 for each of the three wilderness areas. Then the most reasonable smooth curve of least-cost control option scenarios is plotted for each analysis. Figures 5-1 through 5-6 present the two analyses (cost per dV reduction and cost per reduction in number of days above 0.5 dV) for each of the three Class I areas impacted by the operation of Jim Bridger 1.

In Figure 5-1, the four scenarios are compared as a graph of total annualized cost versus number of days above 0.5 dV. EPA states that "In calculating incremental costs, the analysis should only be conducted for control options that are dominant among all possible options". In Figure 5-1, the dominant set of control options, Scenarios 1 and 3, represent the least-cost envelope depicted by the curvilinear line connecting them. Scenarios 2 and 4 are inferior options and should not be considered in the derivation of incremental cost effectiveness. Scenarios 2 and 4 represent inferior controls, because Scenario 1 provides approximately same amount of visibility impact reduction for less cost than Scenario 2; and similarly, Scenario 3 will provides approximately the same amount of visibility impact reduction for less cost than Scenario 4. The incremental cost effectiveness is determined by the difference in total annual costs between two contiguous scenarios divided by the difference in emissions reduction.

TABLE 5-1
Control Scenario Results for the Bridger Class 1 Wilderness Area
Jim Bridger 1

Scenario	Controls	98th Percentile dV Reduction	Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet FGD and ESP	0.0	0.0	\$0.0	\$0.0	\$0.0
1	LNB with OFA, Upgrade Wet FGD & FGC for Enhanced ESP Performance	0.5	13.0	\$3.4	\$7.4	\$0.3
2	LNB with OFA, Upgrade Wet FGD, New Fabric Filter	0.5	13.7	\$9.8	\$20.0	\$0.7
3	LNB with OFA and SCR, Upgrade Wet FGD & FGC for Enhanced ESP Performance	0.7	17.3	\$18.1	\$31.6	\$1.1
4	LNB with OFA and SCR, Upgrade Wet FGD, New Fabric Filter	0.7	17.3	\$24.5	\$41.8	\$1.5

TABLE 5-2
Control Scenario Results for the Fitzpatrick Class 1 Wilderness Area
Jim Bridger 1

Scenario	Controls	98th Percentile dV Reduction	Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet FGD and ESP	0.0	0.0	\$0.0	\$0.0	\$0.0
1	LNB with OFA, Upgrade Wet FGD & FGC for Enhanced ESP Performance	0.3	4.7	\$3.4	\$13.3	\$0.8
2	LNB with OFA, Upgrade Wet FGD, New Fabric Filter	0.3	20.7	\$9.8	\$371	\$2.1
3	LNB with OFA and SCR, Upgrade Wet FGD & FGC for Enhanced ESP Performance	0.4	6.7	\$18.1	\$50.1	\$2.9
4	LNB with OFA and SCR, Wet FGD, Fabric Filter	0.4	15.3	\$24.5	\$66.8	\$3.9

TABLE 5-3
Control Scenario Results for the Mt. Zirkel Class 1 Wilderness Area
Jim Bridger 1

Scenario	Controls	98th Percentile dV Reduction	Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet FGD and ESP	0.0	0.0	\$0.0	\$0.0	\$0.0
1	LNB with OFA, Upgrade Wet FGD & FGC for Enhanced ESP Performance	0.7	23.7	\$3.4	\$6.6	\$0.2
2	LNB with OFA, Upgrade Wet FGD, New Fabric Filter	0.7	23.7	\$9.8	\$13.7	\$0.5
3	LNB with OFA and SCR, Upgrade Wet FGD & FGC for Enhanced ESP Performance	1.1	34.0	\$18.1	\$17.3	\$0.6
4	LNB with OFA and SCR, Upgrade Wet FGD, New Fabric Filter	1.1	34.0	\$24.5	\$23.2	\$0.7

TABLE 5-4
Bridger Class I Wilderness Area Incremental Analysis Data
Jim Bridger 1

Options Compared	Incremental Reduction in Days Above 0.5 dV (Days)	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	13.0	0.5	\$0.3	\$6.7
Scenario 1 and Scenario 3	4.3	0.2	\$3.4	\$89.6
Scenario 3 and Scenario 4	0.0	0.01	N/A	\$531.

TABLE 5-5
Fitzpatrick Class I Wilderness Area Incremental Analysis Data
Jim Bridger 1

Options Compared	Incremental Reduction in Days Above 0.5 dV (Days)	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	4.7	0.3	\$0.7	\$12.2
Scenario 1 and Scenario 3	2.7	0.1	\$5.5	\$127.
Scenario 3 and Scenario 4	0.0	0.004	N/A	\$1,469.

TABLE 5-6
Mt. Zirkel Class I Wilderness Area Incremental Analysis Data
Jim Bridger 1

Options Compared	Incremental Reduction in Days Above 0.5 dV (Days)	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	23.7	0.7	\$0.1	\$4.9
Scenario 1 and Scenario 3	10.3	0.4	\$1.4	\$39.5
Scenario 3 and Scenario 4	0.0	0.01	N/A	\$546.

FIGURE 5-1
Least Cost Envelope Bridger Class I WA Days Reduction
Jim Bridger 1




FIGURE 5-2
Least Cost Envelope Bridger Class I WA 98th Percentile Reduction
Jim Bridger 1




FIGURE 5-3
Least Cost Envelope Fitzpatrick Class I WA Days Reduction
Jim Bridger 1




FIGURE 5-4
Least Cost Envelope Fitzpatrick Class I WA 98th Percentile Reduction
Jim Bridger 1




FIGURE 5-5
 Least Cost Envelope Mt. Zirkel Class I WA Days Reduction
 Jim Bridger 1





FIGURE 5-6
 Least Cost Envelope Mt. Zirkel Class I WA 98th Percentile Reduction
 Jim Bridger 1



5.1.2 Analysis Results

Results of the Least Cost Analysis, shown in Tables 5-1 through 5-6 and Figures 5-1 through 5-4 on the preceding pages, confirm the selection of Scenario 1, based on incremental cost and visibility improvements. Scenario 2 is eliminated because it is to the left of the curve formed by the “dominant” control alternative scenarios, which indicates a scenario with lower improvement and/or higher costs. Scenario 3 is not selected due to very high incremental costs on the basis of both a cost per day of improvement and a cost per dV reduction. While Scenario 4 provides some potential visibility advantage over Scenario 1, the projected improvement is less than half a dV, and the projected costs are excessive.

Analysis of the results for the Jim Bridger WA Class 1 Area in Tables 5-1 and 5-4 and Figures 5-1 and 5-2 illustrates the conclusions stated above. The greatest reduction in 98th percentile dV and number of days exceeding 0.5 dV is between the Baseline and Scenario 1. The incremental cost effectiveness for Scenario 1 compared to the Baseline is reasonable at \$260,000/day and \$6.74 Million/dV. However, the incremental cost effectiveness for Scenario 3 compared to Scenario 1 is excessive at \$3.39 Million/day and \$89.64 Million/dV. Therefore, Scenario 1 represents BART for Jim Bridger 1.

5.2 Recommendations

5.2.1 NO_x Emission Control

The BART presumptive NO_x limit assigned by EPA for tangentially-fired boilers burning subbituminous coal is 0.15 lb/MMBtu. However, as documented in Section 3.2.1.1, the characteristics of the Jim Bridger coals are more closely aligned with bituminous coals, with a presumptive BART NO_x limit of 0.28 lb/MMBtu.

CH2M HILL recommends the existing low-NO_x burners with over-fire air (LNB w/OFA) as BART for Jim Bridger 1, based on the projected significant reduction in NO_x emissions, reasonable control costs, and the advantages of no additional power requirements or non-air quality environmental impacts. NO_x reductions are expected to be similar to those realized at Jim Bridger 2. CH2M HILL recommends that the unit be permitted at a rate of 0.26 lb/MMBtu.

5.2.2 SO₂ Emission Control

CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 1, based on the significant reduction in SO₂ emissions, reasonable control costs, and the advantages of minimal additional power requirements and minimal non-air quality environmental impacts. This upgrade approach will meet the BART presumptive SO₂ limit of 0.15 lb/MMBtu.

5.2.3 PM₁₀ Emission Control

CH2M HILL recommends finalizing the permitting of the flue gas conditioning system to enhance the performance of the existing electrostatic precipitator (ESP) as BART for Jim Bridger 1, based on the significant reduction in PM₁₀ emissions, reasonable control costs, and

the advantages of minimal additional power requirements and no non-air quality environmental impacts.

5.3 Just-Noticeable Differences in Atmospheric Haze

Conclusions reached in the reference document "Just-Noticeable Differences in Atmospheric Haze" by Dr. Ronald Henry of the University of Southern California (Appendix C), state that only dV differences of approximately 1.5 to 2.0 dV, or more are perceivable by the human eye. Deciview changes of less than 1.5 cannot be distinguished by the average person. Therefore, the modeling analysis results indicate that only minimal, if any, observable visibility improvements at the Class I areas studied would be expected under any of the scenarios. Thus the results indicate that even though many millions of dollars will be spent, only minimal if any noticeable visibility improvements may result.

Finally, it should be noted that none of the data were corrected for natural obscuration where water in various forms (fog, clouds, snow or rain) or other naturally caused aerosols obscure the atmosphere. During the period of 2001 through 2003, there were several mega-wildfires that lasted for many days and could have had a significant impact of background visibility in these Class I areas. If natural obscuration were to reduce the reduction in visibility impacts modeled for the Jim Bridger 1 facility, the effect would be to increase the costs per dV reduction that are presented in this report.

6.0 References

BART Air Modeling Protocol - Individual Source Visibility Assessments for BART Control Analyses. September, 2006.

Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule.

Multi-Pollutant Control Report. October, 2002, updated October 2006

Protocol for BART-Related Visibility Improvement Modeling Analysis in North Dakota. North Dakota Department of Health. October 26, 2005.

Regional Haze Regulations and Guidelines for Best Available Retrofit Technology Determinations; Final Rule (40 CFR Part 51; July 6, 2005, pg 39129)

S&L Study Multi-Pollutant Control Report. October, 2002, updated October 2006

United States Environmental Protection Agency, 1990. *New Source Review Workshop Manual - Prevention of Significant Deterioration and Nonattainment Area Permitting.* October 1990.

Appendices

APPENDIX A

Economic Analysis

PacifiCorp BART Analysis Report Tables

Jim Bridger Unit 1

TABLE 3-1 NO _x Control Technology Emission Rate Ranking Jim Bridger Unit 1	
Technology	Projected Emission Rate (lb/MMBtu)
LNB w/OFA	0.24
ROFA	0.22
LNB w/OFA & SNCR	0.20
LNB w/OFA & SCR	0.07

TABLE 3-2 NO _x Control Cost Comparison Jim Bridger Unit 1						
Factor	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR		
Total Installed Capital Costs	\$ 8.7 Million	\$ 20.5 Million	\$ 22.1 Million	\$ 129.6 Million		
Total First Year Fixed & Variable O&M Costs	\$ 0.1 Million	\$ 2.6 Million	\$ 1.5 Million	\$ 3.3 Million		
Total First Year Annualized Cost	\$ 0.9 Million	\$ 4.6 Million	\$ 3.6 Million	\$ 15.6 Million		
Power Consumption (MW)	-	6.41	0.53	3.28		
Annual Power Usage (Million kW-Hr/Yr)	-	50.6	4.2	25.8		
NO _x Design Control Efficiency	46.7%	51.1%	55.6%	84.4%		
Tons NO _x Removed per Year	4,967	5,440	5,913	8,987		
First Year Average Control Cost (\$/Ton of NO _x Removed)	181	843	613	1,736		
Incremental Control Cost (\$/Ton of NO _x Removed)	181	7,797	2,885	3,894		

TABLE 3-3 SO ₂ Control Technology Emission Rate Ranking Jim Bridger Unit 1	
Control Technology	Short-Term Expected SO ₂ Emission Rate (Lb/MMBtu)
N/A	N/A
N/A	N/A
Upgraded Wet FGD	0.10

PacifiCorp BART Analysis Report Tables

Jim Bridger Unit 1

TABLE 3-4
SO₂ Control Cost Comparison
Jim Bridger Unit 1


Factor	N/A	N/A	Upgraded Wet FGD
Total Installed Capital Costs			13.0 Million
Total First Year Fixed & Variable O&M Costs			1.3 Million
Total First Year Annualized Cost			2.5 Million
Power Consumption (MW)			0.53
Annual Power Usage (Million kW-Hr/Yr)			4.2
SO ₂ Design Control Efficiency			62.5%
Tons SO ₂ Removed per Year			3,950
First Year Average Control Cost (\$/Ton of SO ₂ Removed)			632
Incremental Control Cost (\$/Ton of SO ₂ Removed)			632


TABLE 3-5
PM₁₀ Control Technology Emission Ranking
Jim Bridger Unit 1


Control Technology	Short-Term Expected PM ₁₀ Emission Rate (Lb/MMBtu)
Flue Gas Conditioning	0.030
Fabric Filter	0.015

TABLE 3-6
PM₁₀ Control Cost
Jim Bridger Unit 1

Factor	Flue Gas Conditioning	Fabric Filter
Total Installed Capital Costs	\$ -	\$ 48.4 Million
Total First Year Fixed & Variable Operations & Maintenance Costs	\$ 0.2 Million	\$ 1.8 Million
Total First Year Annualized Cost	\$ 0.2 Million	\$ 6.4 Million
Power Consumption (MW)	0.05	3.39
Annual Power Usage (Million kW-Hr/Yr)	0.4	26.7
PM Design Control Efficiency	33.33%	66.67%
Tons PM Removed per Year	365	710
First Year Average Control Cost (\$/Ton of PM Removed)	495	8,973
Incremental Control Cost (\$/Ton of SO ₂ Removed)	495	17,452







PacifiCorp BART Analysis Scenarios

3 Jim Bridger Unit 1

Select Unit:	
Index No.	Name of Unit
1	Dave Johnston Unit 3
2	Jim Bridger Unit 1
3	Jim Bridger Unit 2
4	Jim Bridger Unit 3
5	Jim Bridger Unit 4
6	Naughton Unit 1
7	Naughton Unit 2
8	Naughton Unit 3
9	Wyodak Unit 1
10	

Scenario	Naughton			
	DJ Unit 4	NTN Unit 1	NTN Unit 2	NTN Unit 3
Scenario - Current Operation with ESP	Scenario - Current Operation with Venturi Scrubber	Scenario - Current Operation with ESP	Scenario - Current Operation with ESP	Scenario - Current Operation with Wet FGD and ESP
Scenario 1 - LNB with OFA, Dry FGD, Existing ESP	Scenario 1 - LNB with OFA, Dry FGD, Fabric Filter	Scenario 1 - LNB with OFA, Dry FGD, ESP	Scenario 1 - LNB with OFA, Dry FGD, ESP	Scenario 1 - LNB with OFA, Wet FGD, ESP
Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter
Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP
Scenario 4 - LNB with OFA and SCR, Wet FGD, Existing ESP, New Stack	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	Scenario 4 - LNB with OFA and SCR, Wet FGD, ESP, New Stack	Scenario 4 - LNB with OFA and SCR, Wet FGD, ESP, New Stack	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter
First Year Cost	First Year Cost	First Year Cost	First Year Cost	First Year Cost
N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A

Scenario	Jim Bridger			
	JB Unit 1	JB Unit 2	JB Unit 3	JB Unit 4
Scenario - Current Operation with Wet FGD and ESP	Scenario - Current Operation with Wet FGD and ESP	Scenario - Current Operation with Wet FGD and ESP	Scenario - Current Operation with Wet FGD and ESP	Scenario - Current Operation with Dry FGD, Fabric Filter
Scenario 1 - LNB with OFA, Wet FGD, ESP	Scenario 1 - LNB with OFA, Wet FGD, ESP	Scenario 1 - LNB with OFA, Wet FGD, ESP	Scenario 1 - LNB with OFA, Wet FGD, ESP	Scenario 1 - LNB with OFA, Dry FGD, Fabric Filter
Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	Scenario 2 - LNB with OFA and SCR, Dry
Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	Scenario 3 - LNB with OFA and SCR, Wet FGD, Fabric Filter, New Stack
Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	Scenario 4 - N/A
First Year Cost	First Year Cost	First Year Cost	First Year Cost	First Year Cost
\$ 3,392,440	\$ 3,392,440	\$ 3,392,440	\$ 3,392,440	N/A
\$ 9,759,059	\$ 9,759,059	\$ 9,759,059	\$ 9,759,059	N/A
\$ 18,093,916	\$ 18,093,916	\$ 18,093,916	\$ 18,093,916	N/A
\$ 24,480,535	\$ 24,480,535	\$ 24,480,535	\$ 24,480,535	N/A

ECONOMIC ANALYSIS SUMMARY

Jim Bridger Unit 1

Boiler Design:

Tangential-Fired PC

Parameter	NOx Control				SO2 Control		PM Control	
	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
Case	1	2	3	4	5	6	9	10
NOx Emission Control System	LNCFS-1 & Windbox Mods.	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	LNCFS-1 & Windbox Mods.	LNCFS-1 & Windbox Mods.	LNCFS-1 & Windbox Mods.
SO2 Emission Control System	Wet FGD ESP	Wet FGD ESP	Wet FGD ESP	Wet FGD ESP	Wet FGD ESP	Upgraded Wet FGD ESP	Wet FGD ESP	Wet FGD ESP
PM Emission Control System	Wet FGD ESP	Wet FGD ESP	Wet FGD ESP	Wet FGD ESP	Wet FGD ESP	Wet FGD ESP	Wet FGD ESP	Wet FGD ESP
TOTAL INSTALLED CAPITAL COST (\$)	0	8,700,001	20,628,122	22,127,239	129,575,495	12,995,900	0	48,386,333
FIRST YEAR O&M COST (\$)								
Operating Labor (\$)	0	0	0	0	0	0	0	0
Maintenance Material (\$)	0	28,000	42,000	123,000	190,000	25,560	0	51,089
Maintenance Labor (\$)	0	42,000	63,000	184,500	285,000	17,033	10,000	78,649
Administrative Labor (\$)	0	0	0	0	0	0	0	0
TOTAL FIXED O&M COST	0	70,000	105,000	307,500	475,000	42,593	10,000	127,749
Makeup Water Cost	0	0	0	0	0	30,503	0	0
Reagent Cost	0	0	0	1,005,811	912,848	533,206	145,854	0
SCR Catalyst / FF Bag Cost	0	0	0	0	594,000	0	0	300,040
Waste Disposal Cost	0	0	0	0	0	442,959	0	0
Electric Power Cost	0	2,525,012	2,525,012	208,926	1,281,005	208,926	19,710	1,395,844
TOTAL VARIABLE O&M COST	0	2,525,012	2,525,012	1,214,937	2,197,853	1,216,583	165,564	1,835,984
TOTAL FIRST YEAR O&M COST	0	70,000	2,633,012	1,522,337	3,272,853	1,268,176	175,564	1,783,732
FIRST YEAR DEBT SERVICE (\$)	0	827,612	1,952,766	2,104,916	12,328,235	1,236,652	0	4,602,887
TOTAL FIRST YEAR COST (\$)	0	8,955,260	23,583,890	24,739,155	141,903,733	14,235,158	175,564	53,615,159
Power Consumption (MW)	0.0	0.0	5.4	0.5	3.3	0.5	0.1	3.4
Annual Power Usage (Million kWh/yr)	0.0	0.0	50.6	4.2	26.8	4.2	0.4	26.7
CONTROL COST (\$/Ton Removed)								
NOx Removal Rate (%)	0.0%	46.7%	51.1%	55.8%	84.4%	0.0%	0.0%	0.0%
NOx Removed (Tons/Yr)	0	4,967	5,440	5,913	8,987	0	0	0
First Year Average Control Cost (\$/Ton NOx Rem.)	0	181	843	613	1,736	0	0	0
Incremental Control Cost (\$/Ton NOx Removed)	0	2-1	3-2	4-2	5-4	0	0	0
SO2 Removal Rate (%)	77.8%	0.0%	0.0%	0.0%	0.0%	62.5%	0.0%	0.0%
SO2 Removed (Tons/Yr)	0	0	0	0	0	3,950	0	0
First Year Average Control Cost (\$/Ton SO2 Rem.)	0	0	0	0	0	532	0	0
Incremental Control Cost (\$/Ton SO2 Removed)	Base	0	0	0	0	8-1	0	0
PM Removal Rate (%)	59.47%	0.00%	0.00%	0.00%	0.00%	0.00%	33.33%	66.67%
PM Removed (Tons/Yr)	0	0	0	0	0	0	355	710
First Year Average Control Cost (\$/Ton PM Rem.)	0	0	0	0	0	0	495	8,973
Incremental Control Cost (\$/Ton PM Removed)	Base	0	0	0	0	0	495	17,452
PRESENT WORTH COST (\$)	0	9,555,260	52,687,883	40,725,706	169,562,733	28,372,107	2,145,015	69,935,356

INPUT CALCULATIONS

Boiler Design: Tangential-Fired PC

Jim Bridger Unit 1

Parameter	NOx Control				SO2 Control		PM Control		Comments	
	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	Upgraded Wet FGD	Wet FGD	Flue Gas Conditioning	Fabric Filter		
Case	1	2	3	4	5	6	7	8	9	10
Current Operation	LNCFCS-1 & Windbox Wets FGD	LNCFCS-1 & Windbox Wets FGD	LNCFCS-1 & Windbox Wets FGD	LNCFCS-1 & Windbox Wets FGD	LNCFCS-1 & Windbox Wets FGD	LNCFCS-1 & Windbox Wets FGD	LNCFCS-1 & Windbox Wets FGD	LNCFCS-1 & Windbox Wets FGD	LNCFCS-1 & Windbox Wets FGD	LNCFCS-1 & Windbox Wets FGD
NOx Emission Control System	ESP	ESP	ESP	ESP	ESP	ESP	ESP	ESP	ESP	Fabric Filter
PM Emission Control System	ESP	ESP	ESP	ESP	ESP	ESP	ESP	ESP	ESP	Fabric Filter
Unit Design and Coal Characteristics										
Type of Unit	PC	PC	PC	PC	PC	PC	PC	PC	PC	PC
Net Power Output (KW)	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000
Net Plant Heat Rate (Btu/KW-Hr)	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320
Boiler Fuel	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground
Coal Heating Value (Btu/lb)	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660
Coal Sulfur Content (wt %)	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%
Coal Ash Content (wt %)	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%
Boiler Heat Input Each (MMBtu/Hr)	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000
Boiler Flow Rate (Lb/Hr)	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077
(MMBtu/Yr)	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284
(MMBtu/Yr)	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846
Emissions										
Uncontrolled SO2 (Lb/Hr)	7,216	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602
(Lb/MMBtu)	1.20	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27
(Lb Moles/Hr)	112.54	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00
(Tons/Yr)	28,421	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315
SO2 Removal Rate (%)	77.8%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
(Lb/Hr)	5,608	0	0	0	0	0	0	0	0	0
(Ton/Yr)	22,106	0	0	0	0	0	0	0	0	0
SO2 Emission Rate (Lb/Hr)	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602
(Lb/MMBtu)	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27
(Tons/Yr)	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315
Uncontrolled NOx (Lb/Hr)	2,700	2,700	2,700	2,700	2,700	2,700	2,700	2,700	2,700	2,700
(Lb/MMBtu)	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45
(Lb Moles/Hr)	89.96	89.96	89.96	89.96	89.96	89.96	89.96	89.96	89.96	89.96
(Tons/Yr)	10,643	10,643	10,643	10,643	10,643	10,643	10,643	10,643	10,643	10,643
NOx Removal Rate (%)	0.0%	46.7%	51.1%	55.6%	84.4%	0%	0%	0%	0%	0%
(Lb/Hr)	0	1,260	1,380	1,500	2,280	0	0	0	0	0
(Lb Moles/Hr)	0	41.98	45.98	49.98	75.97	0	0	0	0	0
(Ton/Yr)	0	4,957	5,440	5,913	8,987	0	0	0	0	0
NOx Emission Rate (Lb/Hr)	2,700	1,440	1,320	1,200	420	2,700	2,700	2,700	2,700	2,700
(Lb/MMBtu)	0.45	0.24	0.22	0.20	0.07	0.45	0.45	0.45	0.45	0.45
(Tons/Yr)	10,643	5,678	5,203	4,730	1,656	10,643	10,643	10,643	10,643	10,643
Uncontrolled Fly Ash (Lb/Hr)	51,177	270	270	270	270	270	270	270	270	270
(Lb/MMBtu)	8.530	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045
(Lb Moles/Hr)	1705.3	9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0
(Tons/Yr)	201,739	1,064	1,064	1,064	1,064	1,064	1,064	1,064	1,064	1,064
Fly Ash Removal Rate (%)	99.47%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
(Lb/Hr)	50,907	0	0	0	0	0	0	0	0	0
(Ton/Yr)	200,674	0	0	0	0	0	0	0	0	0
Fly Ash Emission Rate (Lb/Hr)	270	270	270	270	270	270	270	270	270	270
(Lb/MMBtu)	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045
(Tons/Yr)	1,064	1,064	1,064	1,064	1,064	1,064	1,064	1,064	1,064	1,064

Parameter	Current Operation	NOx Control				SO2 Control	PM Control		Comments
		LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR		Flue Gas Conditioning	Fabric Filter	
Case	1	2	3	4	5	8	9	10	
General Plant Data									
Annual Operation (Hours/Year)	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	
Annual On-Site Power Plant Capacity Factor	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	
Economic Factors									
Interest Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	
Discount Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	
Plant Economic Life (Years)	20	20	20	20	20	20	20	20	
Installed Capital Costs									
NOx Emission Control System (\$2008)	0	8,700,001	20,528,122	22,127,239	129,575,495	0	0	0	
SO2 Emission Control System (\$2008)	0	0	0	0	0	12,999,900	0	0	
PM Emission Control System (\$2008)	0	0	0	0	0	0	0	48,386,333	
Total Emission Control Systems (\$2008)	0	8,700,001	20,528,122	22,127,239	129,575,495	12,999,900	0	48,386,333	
NOx Emission Control System (\$1996)	0	16	39	42	244	0	0	0	
SO2 Emission Control System (\$1996)	0	0	0	0	0	25	0	0	
PM Emission Control System (\$1996)	0	0	0	0	0	0	0	51	
Total Emission Control Systems (\$1996)	0	16	39	42	244	25	0	51	
Total Fixed Operating & Maintenance Costs									
Operating Labor (\$)	0	0	0	0	0	0	0	0	
Maintenance Material (\$)	0	28,000	42,000	123,000	190,000	25,550	0	51,099	
Maintenance Labor (\$)	0	42,000	63,000	184,500	285,000	17,033	10,000	76,649	
Administrative Labor (\$)	0	0	0	0	0	0	0	0	
Total Fixed O&M Cost (\$)	0	70,000	105,000	307,500	475,000	42,583	10,000	127,748	
Annual Fixed O&M Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Water Cost									
Makeup Water Usage (Gpm)	0	0	0	0	0	53	0	0	
Unit Price (\$/1000 Gallons)	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	
First Year Water Cost (\$)	0	0	0	0	0	30,503	0	0	
Annual Water Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Reagent Cost									
Unit Cost (\$/Ton)	None	None	None	Urea	Anhydrous NH3	Soda Ash	Elemental Sulfur	None	
(\$/Lb)	0.00	0.00	0.00	370	400	80.00	370	0.00	
Molar Stoichiometry	0.00	0.00	0.00	0.185	0.200	0.040	0.185	0.00	
Reagent Purity (Wt.%)	100%	100%	100%	100%	100%	1.02	100%	90%	
Reagent Usage (Lb/Hr)	0	0	0	690	678	1,891	100	0	
First Year Reagent Cost (\$)	0	0	0	1,005,811	912,848	533,208	145,854	0	
Annual Reagent Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
SCR Catalyst / FF Bag Replacement Cost									
Annual SCR Catalyst (m3) / No. FF Bags	0	0	0	198	0	0	0	0	
SCR Catalyst (\$/m3) / Bag Cost (\$/ea.)	3,000	3,000	3,000	3,000	3,000	104	3,000	104	
First Year SCR Catalyst / Bag Replace. Cost (\$)	0	0	0	594,000	0	0	0	300,040	
Annual SCR Catalyst / Bag Cost Esc. Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
FGD Waste Disposal Cost									
FGD Solid Waste Disposal Rate, Dry (Lb/Hr)	0	0	0	0	0	4,518	0	0	
FGD Waste Disposal Unit Cost (\$/D/Ton)	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	
First Year FGD Waste Disposal Cost (\$)	0	0	0	0	0	442,958	0	0	
Annual Waste Disposal Cost Esc. Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Auxiliary Power Cost									
Auxiliary Power Requirement (% of Plant Output) (MW)	0.00%	0.00%	1.21%	0.40%	0.62%	0.10%	0.01%	0.64%	
Unit Cost (\$/2006/MW-Hr)	0.00	0.00	6.41	0.55	3.26	0.53	0.05	3.35	
First Year Auxiliary Power Cost (\$)	0	50,000	50,000	209,926	1,291,005	208,926	19,710	1,355,944	
Annual Power Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	

Input Tables

Table 1 - Cases

Index No.	Name of Unit Case	NOx Control			SO2 Control			PM Control		
		Existing	2	3	4	5	6	7	8	9
1	Dave Johnston Unit 3	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	Dry FGD w/ESP	Dry FGD w/Fabric Filter	Wet FGD w/ESP	N/A	Fabric Filter
2	Dave Johnston Unit 4	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	N/A	Dry FGD w/Fabric Filter	Wet FGD w/Fabric Filter	N/A	Fabric Filter
3	Jim Bridger Unit 1	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	N/A	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
4	Jim Bridger Unit 2	Current Operation	Exist. LNB w/OFA	ROFA	SNCR	N/A	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
5	Jim Bridger Unit 3	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	N/A	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
6	Jim Bridger Unit 4	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	N/A	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
7	Naughton Unit 1	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	Dry FGD w/ESP	Dry FGD w/Fabric Filter	Wet FGD w/ESP	Flue Gas Conditioning	Fabric Filter
8	Naughton Unit 2	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	Dry FGD w/ESP	Dry FGD w/Fabric Filter	Wet FGD w/ESP	Flue Gas Conditioning	Fabric Filter
9	Naughton Unit 3	Current Operation	Exist. LNB w/OFA	ROFA	SNCR	N/A	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
10	Wyodak Unit 1	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	Upgraded Dry FGD	N/A	Wet FGD	Flue Gas Conditioning	Fabric Filter

Table 2 - Unit Design and Coal Characteristics

Index No.	Name of Unit	Current Emission Control Systems				Unit Design			Coal Quality			
		NOx	SO2	PM	PM	Boiler Design	Net Power Output (kW)	NET Plant Heat Rate (Btu/kWh-Hr)	Coal	Heating Value, HHV (Btu/Lb)	Sulfur Content (Wt.%)	Ash Content (Wt.%)
1	Dave Johnston Unit 3	None	None	ESP	ESP	3-Coal Burner, Opposed Wall-Fired PC	250,000	11,200	Dry Fox PRB	7,784	0.47%	5.01%
2	Dave Johnston Unit 4	Windbox Mod., LINCFS-1 & Windbox Mods.	Lime Added to Venturi Scrubber	Venturi Scrubber	Venturi Scrubber	Tangentia-Fired PC	350,000	11,390	Dry Fox PRB	7,784	0.47%	5.01%
3	Jim Bridger Unit 1	None	Wet FGD	ESP	ESP	Tangentia-Fired PC	530,000	11,320	Underground	9,660	0.58%	10.30%
4	Jim Bridger Unit 2	LNB - TFS 2000	Wet FGD	ESP	ESP	Tangentia-Fired PC	530,000	11,320	Underground	9,660	0.58%	10.30%
5	Jim Bridger Unit 3	Windbox Mod., LINCFS-1 & Windbox Mods.	Wet FGD	ESP	ESP	Tangentia-Fired PC	530,000	11,320	Underground	9,660	0.58%	10.30%
6	Jim Bridger Unit 4	Windbox Mod., LINCFS-1 & Windbox Mods.	Wet FGD	ESP	ESP	Tangentia-Fired PC	530,000	11,320	Underground	9,660	0.58%	10.30%
7	Naughton Unit 1	None	None	ESP	ESP	Tangentia-Fired PC	173,000	10,694	Kemmerer Mine	9,970	0.60%	4.64%
8	Naughton Unit 2	None	None	ESP	ESP	Tangentia-Fired PC	225,000	10,574	Kemmerer Mine	9,970	0.60%	4.64%
9	Naughton Unit 3	LINCFS II LNB	Wet FGD	ESP	ESP	Tangentia-Fired PC	355,000	10,335	Kemmerer Mine	9,970	0.60%	4.64%
10	Wyodak Unit 1	LNB	Dry FGD	ESP	ESP	Opposed Wall-Fired PC	335,000	12,087	Clove Point Mine	7,977	0.65%	7.46%

Table 3 - Emissions

Index No.	Names of Unit	Current Emission Rates (Lb/MMBtu)		NOx Control Emission Rates (Lb/MMBtu)		SO2 Control Emission Rates (Lb/MMBtu)		PM Emission Rates (Lb/MMBtu)				
		Controlled	Controlled NOx	Case 2	Case 3	Case 4	Case 5	Case 6	Case 7	Case 8	Case 9	Case 10
1	Dave Johnston Unit 3	1.20	0.70	0.200	0.27	0.21	0.20	0.07	0.21	0.15	0.10	0.015
2	Dave Johnston Unit 4	0.35	0.48	0.061	0.15	0.19	0.12	0.07	N/A	0.15	0.10	0.015
3	Jim Bridger Unit 1	0.27	0.45	0.045	0.24	0.22	0.20	0.07	N/A	0.15	0.10	0.015
4	Jim Bridger Unit 2	0.27	0.24	0.074	0.24	0.22	0.20	0.07	N/A	0.15	0.10	0.015
5	Jim Bridger Unit 3	0.27	0.45	0.057	0.24	0.22	0.20	0.07	N/A	0.15	0.10	0.015
6	Jim Bridger Unit 4	0.17	0.45	0.030	0.24	0.22	0.20	0.07	N/A	0.15	0.10	0.015
7	Naughton Unit 1	1.20	0.58	0.056	0.24	0.28	0.18	0.07	0.18	0.15	0.10	0.015
8	Naughton Unit 2	1.20	0.54	0.064	0.24	0.28	0.18	0.07	0.18	0.15	0.10	0.015
9	Naughton Unit 3	0.60	0.45	0.094	0.35	0.30	0.25	0.07	N/A	0.15	0.10	0.015
10	Wyodak Unit 1	0.50	0.50	0.030	0.23	0.22	0.18	0.07	0.25	N/A	0.10	0.015

Table 4 - Case 1 O&M Costs (Current Operation)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoch.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ -	\$ -	\$ -	-	None	-	-
2	Dave Johnston Unit 4	\$ -	\$ -	\$ -	\$ -	-	None	-	-
3	Jim Bridger Unit 1	\$ -	\$ -	\$ -	\$ -	-	None	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	-	None	-	-
5	Jim Bridger Unit 3	\$ -	\$ -	\$ -	\$ -	-	None	-	-
6	Jim Bridger Unit 4	\$ -	\$ -	\$ -	\$ -	-	None	-	-
7	Naughton Unit 1	\$ -	\$ -	\$ -	\$ -	-	None	-	-
8	Naughton Unit 2	\$ -	\$ -	\$ -	\$ -	-	None	-	-
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	-	None	-	-
10	Wyodak Unit 1	\$ -	\$ -	\$ -	\$ -	-	None	-	-

Table 5 - Case 2 O&M Costs (LNB w/OFA)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoch.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ 40,000	\$ 60,000	\$ -	-	None	-	-
2	Dave Johnston Unit 4	\$ -	\$ 36,000	\$ 54,000	\$ -	-	None	-	-
3	Jim Bridger Unit 1	\$ -	\$ 28,000	\$ 42,000	\$ -	-	None	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	-	None	-	-
5	Jim Bridger Unit 3	\$ -	\$ 25,000	\$ 42,000	\$ -	-	None	-	-
6	Jim Bridger Unit 4	\$ -	\$ 25,000	\$ 42,000	\$ -	-	None	-	-
7	Naughton Unit 1	\$ -	\$ 32,000	\$ 48,000	\$ -	-	None	-	-
8	Naughton Unit 2	\$ -	\$ 32,000	\$ 48,000	\$ -	-	None	-	-
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	-	None	-	-
10	Wyodak Unit 1	\$ -	\$ 24,000	\$ 36,000	\$ -	-	None	-	-

Table 6 - Case 3 O&M Costs (Mobotec ROFA)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ 60,000	\$ 90,000	\$ -	-	None	-	2.76
2	Dave Johnston Unit 4	\$ -	\$ 54,000	\$ 81,000	\$ -	-	None	-	4.33
3	Jim Bridger Unit 1	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41
4	Jim Bridger Unit 2	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41
5	Jim Bridger Unit 3	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41
6	Jim Bridger Unit 4	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41
7	Naughton Unit 1	\$ -	\$ 48,000	\$ 72,000	\$ -	-	None	-	1.42
8	Naughton Unit 2	\$ -	\$ 48,000	\$ 72,000	\$ -	-	None	-	2.61
9	Naughton Unit 3	\$ -	\$ 48,000	\$ 72,000	\$ -	-	None	-	4.47
10	Wyodak Unit 1	\$ -	\$ 36,000	\$ 54,000	\$ -	-	None	-	5.22

Table 7 - Case 4 O&M Costs (LNB w/OFA & SNCR)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ 98,000	\$ 147,000	\$ -	-	Urea	0.41	0.23
2	Dave Johnston Unit 4	\$ -	\$ 105,000	\$ 157,500	\$ -	-	Urea	0.45	0.33
3	Jim Bridger Unit 1	\$ -	\$ 123,000	\$ 184,500	\$ -	-	Urea	0.45	0.53
4	Jim Bridger Unit 2	\$ -	\$ 95,000	\$ 142,500	\$ -	-	Urea	0.45	0.52
5	Jim Bridger Unit 3	\$ -	\$ 122,000	\$ 183,000	\$ -	-	Urea	0.45	0.52
6	Jim Bridger Unit 4	\$ -	\$ 123,000	\$ 184,500	\$ -	-	Urea	0.45	0.53
7	Naughton Unit 1	\$ -	\$ 83,000	\$ 124,500	\$ -	-	Urea	0.45	0.16
8	Naughton Unit 2	\$ -	\$ 93,000	\$ 139,500	\$ -	-	Urea	0.51	0.22
9	Naughton Unit 3	\$ -	\$ 75,000	\$ 112,500	\$ -	-	Urea	0.45	0.33
10	Wyodak Unit 1	\$ -	\$ 93,000	\$ 139,500	\$ -	-	Urea	0.45	0.34

Table 8 - Case 5 O&M Costs (LNB w/OFA & SCR)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ 155,000	\$ 232,500	\$ -	-	Anhydrous NH3	1.00	1.57
2	Dave Johnston Unit 4	\$ -	\$ 165,000	\$ 247,500	\$ -	-	Anhydrous NH3	1.00	2.29
3	Jim Bridger Unit 1	\$ -	\$ 190,000	\$ 285,000	\$ -	-	Anhydrous NH3	1.00	3.28
4	Jim Bridger Unit 2	\$ -	\$ 162,000	\$ 243,000	\$ -	-	Anhydrous NH3	1.00	3.25
5	Jim Bridger Unit 3	\$ -	\$ 190,000	\$ 285,000	\$ -	-	Anhydrous NH3	1.00	3.22
6	Jim Bridger Unit 4	\$ -	\$ 190,000	\$ 285,000	\$ -	-	Anhydrous NH3	1.00	3.36
7	Naughton Unit 1	\$ -	\$ 132,000	\$ 198,000	\$ -	-	Anhydrous NH3	1.00	0.88
8	Naughton Unit 2	\$ -	\$ 160,000	\$ 240,000	\$ -	-	Anhydrous NH3	1.00	1.34
9	Naughton Unit 3	\$ -	\$ 156,000	\$ 234,000	\$ -	-	Anhydrous NH3	1.00	1.99
10	Wyodak Unit 1	\$ -	\$ 181,000	\$ 271,500	\$ -	-	Anhydrous NH3	1.00	2.42

Table 9 - Case 6 O&M Costs (Dry FGD)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Annual FF Bag Replace.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 506,128	\$ 714,175	\$ 476,928	\$ -	173	Lime	1.15	-	2.49
2	Dave Johnston Unit 4	\$ -	\$ -	\$ -	\$ -	-	Lime	-	-	-
3	Jim Bridger Unit 1	\$ -	\$ -	\$ -	\$ -	-	Lime	-	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	-	Lime	-	-	-
5	Jim Bridger Unit 3	\$ -	\$ -	\$ -	\$ -	-	Lime	-	-	-
6	Jim Bridger Unit 4	\$ -	\$ -	\$ -	\$ -	-	Lime	-	-	-
7	Naughton Unit 1	\$ 506,128	\$ 597,643	\$ 391,762	\$ -	120	Lime	1.40	-	1.64
8	Naughton Unit 2	\$ 506,128	\$ 860,174	\$ 573,044	\$ -	165	Lime	1.40	-	2.25
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	-	Lime	-	-	-
10	Wyodak Unit 1	\$ -	\$ 21,900	\$ 14,600	\$ -	25	Lime	1.10	-	0.11

Table 10 - Case 7 O&M Costs (Dry FGD w/Fabric Filter)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Annual FF Bag Replace.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 506,128	\$ 714,175	\$ 476,928	\$ -	173	Lime	1.15	1,457	3.88
2	Dave Johnston Unit 4	\$ 506,128	\$ 1,102,288	\$ 734,858	\$ -	248	Lime	1.10	1,798	4.54
3	Jim Bridger Unit 1	\$ -	\$ -	\$ -	\$ -	-	Lime	-	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	-	Lime	-	-	-
5	Jim Bridger Unit 3	\$ -	\$ -	\$ -	\$ -	-	Lime	-	-	-
6	Jim Bridger Unit 4	\$ -	\$ -	\$ -	\$ -	-	Lime	-	-	-
7	Naughton Unit 1	\$ 506,128	\$ 632,660	\$ 459,286	\$ -	120	Lime	1.16	866	2.66
8	Naughton Unit 2	\$ 506,128	\$ 905,190	\$ 640,568	\$ -	165	Lime	1.15	1,193	3.63
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	-	Lime	-	-	-
10	Wyodak Unit 1	\$ -	\$ -	\$ -	\$ -	-	Lime	-	-	-

Table 11 - Case 8 O&M Costs (Wet FGD)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Annual FF Bag Replace.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 809,804	\$ 1,182,587	\$ 788,391	\$ -	230	Lime	1.02	-	3.45
2	Dave Johnston Unit 4	\$ 809,804	\$ 1,430,784	\$ 953,856	\$ -	330	Lime	1.02	1,798	6.29
3	Jim Bridger Unit 1	\$ -	\$ 25,550	\$ 17,033	\$ -	53	Soda Ash	1.02	-	0.53
4	Jim Bridger Unit 2	\$ -	\$ 25,550	\$ 17,033	\$ -	52	Soda Ash	1.02	-	0.52
5	Jim Bridger Unit 3	\$ -	\$ 25,550	\$ 17,033	\$ -	27	Soda Ash	1.02	-	0.52
6	Jim Bridger Unit 4	\$ -	\$ 25,550	\$ 17,033	\$ -	160	Lime	1.05	-	2.40
7	Naughton Unit 1	\$ 809,804	\$ 963,689	\$ 642,393	\$ -	220	Lime	1.05	-	3.30
8	Naughton Unit 2	\$ 809,804	\$ 1,226,386	\$ 877,591	\$ -	86	Soda Ash	1.02	-	0.33
9	Naughton Unit 3	\$ -	\$ 21,900	\$ 14,600	\$ -	82	Lime	1.02	-	1.75
10	Wyodak Unit 1	\$ 303,677	\$ 328,496	\$ 218,998	\$ -	-	-	-	-	-

Table 12 - Case 9 O&M Costs (Flue Gas Conditioning)

Index No.	Name of Unit	Annual Fixed O&M Costs					Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Usage (Lb/Hr)	Annual FF Bag Replaces.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ -	\$ -	\$ -	\$ -	-	None	-	-	-
2	Dave Johnston Unit 4	\$ -	\$ -	\$ -	\$ -	\$ -	-	None	-	-	-
3	Jim Bridger Unit 1	\$ -	\$ -	\$ 10,000	\$ -	\$ -	-	Elemental Sulfur	100	-	0.05
4	Jim Bridger Unit 2	\$ -	\$ -	\$ 10,000	\$ -	\$ -	-	Elemental Sulfur	100	-	0.05
5	Jim Bridger Unit 3	\$ -	\$ -	\$ 10,000	\$ -	\$ -	-	Elemental Sulfur	100	-	0.05
6	Jim Bridger Unit 4	\$ -	\$ -	\$ 10,000	\$ -	\$ -	-	Elemental Sulfur	33	-	0.05
7	Naughton Unit 1	\$ -	\$ -	\$ 10,000	\$ -	\$ -	-	Elemental Sulfur	43	-	0.05
8	Naughton Unit 2	\$ -	\$ -	\$ 10,000	\$ -	\$ -	-	Elemental Sulfur	67	-	0.05
9	Naughton Unit 3	\$ -	\$ -	\$ 10,000	\$ -	\$ -	-	Elemental Sulfur	63	-	0.05
10	Wyodak Unit 1	\$ -	\$ -	\$ 10,000	\$ -	\$ -	-	Elemental Sulfur	63	-	0.05

Table 13 - Case 10 O&M Costs (Fabric Filter)

Index No.	Name of Unit	Annual Fixed O&M Costs					Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Annual FF Bag Replaces.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ 45,016	\$ 67,524	\$ -	\$ -	-	None	-	1,457	1.38
2	Dave Johnston Unit 4	\$ -	\$ 68,133	\$ 102,199	\$ -	\$ -	-	None	-	1,798	2.35
3	Jim Bridger Unit 1	\$ -	\$ 51,089	\$ 76,649	\$ -	\$ -	-	None	-	2,885	3.39
4	Jim Bridger Unit 2	\$ -	\$ 51,089	\$ 76,649	\$ -	\$ -	-	None	-	2,885	3.37
5	Jim Bridger Unit 3	\$ -	\$ 51,089	\$ 76,649	\$ -	\$ -	-	None	-	2,827	3.33
6	Jim Bridger Unit 4	\$ -	\$ 51,089	\$ 76,649	\$ -	\$ -	-	None	-	2,885	3.39
7	Naughton Unit 1	\$ -	\$ 45,016	\$ 67,524	\$ -	\$ -	-	None	-	866	1.01
8	Naughton Unit 2	\$ -	\$ 48,666	\$ 72,999	\$ -	\$ -	-	None	-	1,193	1.38
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	\$ -	-	None	-	1,799	2.06
10	Wyodak Unit 1	\$ -	\$ 48,666	\$ 72,999	\$ -	\$ -	-	None	-	1,798	2.06

Table 14 - Major Materials Design and Supply Costs

Index No.	Name of Unit Case -->	NOx Control			SO2 Control			PM Control	
		2	3	4	6	7	8	9	10
1	Dave Johnston Unit 3	\$ 3,221,912	\$ 3,556,617	\$ 5,173,000	\$ 83,871,000	\$ 142,077,000	\$ 106,865,669	\$ -	\$ 18,359,000
2	Dave Johnston Unit 4	\$ 2,673,501	\$ 4,343,192	\$ 7,171,085	\$ -	\$ 137,267,000	\$ 176,174,384	\$ -	\$ 30,853,530
3	Jim Bridger Unit 1	\$ -	\$ 6,058,955	\$ 9,528,000	\$ 80,923,000	\$ -	\$ 8,010,093	\$ -	\$ 29,814,000
4	Jim Bridger Unit 2	\$ -	\$ 6,058,955	\$ 9,528,000	\$ 80,923,000	\$ -	\$ 8,010,093	\$ -	\$ 29,814,000
5	Jim Bridger Unit 3	\$ 2,981,982	\$ 6,058,955	\$ 9,419,000	\$ 95,009,000	\$ -	\$ 3,549,000	\$ -	\$ 29,814,000
6	Jim Bridger Unit 4	\$ 2,881,982	\$ 6,058,955	\$ 9,528,000	\$ 37,292,000	\$ 26,819,000	\$ 44,000,000	\$ 800,000	\$ 15,482,000
7	Naughton Unit 1	\$ 2,502,123	\$ 2,675,792	\$ 7,257,000	\$ 47,934,000	\$ 39,262,000	\$ 56,000,000	\$ 800,000	\$ 16,359,000
8	Naughton Unit 2	\$ 2,570,874	\$ 3,123,533	\$ 8,784,000	\$ 67,373,000	\$ -	\$ 2,963,000	\$ 800,000	\$ 20,106,000
9	Naughton Unit 3	\$ -	\$ 4,351,377	\$ 11,203,578	\$ 72,479,000	\$ -	\$ 1,247,051	\$ -	\$ -
10	Wyodak Unit 1	\$ 3,187,635	\$ 4,500,245	\$ 7,234,660	\$ -	\$ 996,100	\$ -	\$ 1,247,051	\$ -

CAPITAL COST

Jim Bridger Unit 1

Parameter	NOX Control			SO2 Control			Upgraded Wet FGD			Flue Gas Conditioning			Fabric Filter		
	ROFA	LNB WFOFA & SNCR	LNB WFOFA & SCR	N/A	LNB WFOFA & SNCR	LNB WFOFA & SCR	Wet FGD	Wet FGD	Wet FGD	Wet FGD	Wet FGD	Wet FGD	Wet FGD	Wet FGD	
Major Materials Design and Supply															
Contingency															
EPC Premium															
Baker Reinforcement (Allowance)															
Sales Tax															
Escalation															
Contingency on Address															
Subtotal															
Contingency															
Total Capital Cost for LNB WFOFA or ROFA															
Major Materials Design and Supply															
Contingency															
EPC Premium															
Baker Reinforcement (Allowance)															
Sales Tax															
Escalation															
Contingency on Address															
Subtotal															
Contingency															
Total Capital Cost for Dry/Wet FGD, FGC or FF															

Jim Bridger Unit 1												
LNB w/OFA												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NDX Removed)	
0	2013											
1	2014	70,000							827,612	887,612	181	
2	2015	71,400							827,612	899,012	181	
3	2016	72,828							827,612	900,440	181	
4	2017	74,285							827,612	901,897	182	
5	2018	75,770							827,612	903,382	182	
6	2019	77,286							827,612	904,888	182	
7	2020	78,831							827,612	906,443	183	
8	2021	80,408							827,612	908,020	183	
9	2022	82,016							827,612	909,628	183	
10	2023	83,656							827,612	911,269	183	
11	2024	85,330							827,612	912,942	184	
12	2025	87,036							827,612	914,648	184	
13	2026	88,777							827,612	916,389	185	
14	2027	90,562							827,612	918,165	185	
15	2028	92,394							827,612	919,976	185	
16	2029	94,271							827,612	921,823	186	
17	2030	96,095							827,612	923,707	186	
18	2031	98,017							827,612	925,629	186	
19	2032	99,977							827,612	927,589	187	
20	2033	101,977							827,612	929,589	187	
Present Worth (% of PW)		855,250	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	8,700,001	9,555,250	100.0%	

Jim Bridger Unit 1												
ROFA												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NDX Removed)	
0	2013											
1	2014	105,000					2,528,012	2,528,012	1,952,795	4,580,807	843	
2	2015	107,100					2,578,573	2,578,573	1,952,795	4,638,468	853	
3	2016	109,242					2,630,144	2,630,144	1,952,795	4,692,182	863	
4	2017	111,427					2,682,747	2,682,747	1,952,795	4,746,970	873	
5	2018	113,655					2,736,402	2,736,402	1,952,795	4,802,853	883	
6	2019	115,928					2,791,130	2,791,130	1,952,795	4,859,854	893	
7	2020	118,247					2,846,953	2,846,953	1,952,795	4,917,995	904	
8	2021	120,612					2,903,882	2,903,882	1,952,795	4,977,299	915	
9	2022	123,024					2,961,970	2,961,970	1,952,795	5,037,789	926	
10	2023	125,486					3,021,209	3,021,209	1,952,795	5,099,489	937	
11	2024	127,994					3,081,633	3,081,633	1,952,795	5,162,423	949	
12	2025	130,554					3,143,266	3,143,266	1,952,795	5,226,616	961	
13	2026	133,165					3,206,131	3,206,131	1,952,795	5,292,092	973	
14	2027	135,829					3,270,254	3,270,254	1,952,795	5,358,878	985	
15	2028	138,545					3,335,659	3,335,659	1,952,795	5,427,000	998	
16	2029	141,316					3,402,372	3,402,372	1,952,795	5,496,484	1,010	
17	2030	144,142					3,470,415	3,470,415	1,952,795	5,567,358	1,023	
18	2031	147,025					3,539,828	3,539,828	1,952,795	5,639,649	1,037	
19	2032	149,965					3,610,624	3,610,624	1,952,795	5,713,386	1,050	
20	2033	152,965					3,682,837	3,682,837	1,952,795	5,788,688	1,064	
Present Worth (% of PW)		1,282,875	2.4%	0.0%	0.0%	0.0%	30,866,686	30,866,686	20,528,122	52,697,663	100.0%	

LNB w/OFA & SNCR												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)	
0	2013	307,500	-	1,005,811	-	-	208,926	1,214,737	2,104,916	3,627,153	613	
1	2014	313,650	-	1,025,927	-	-	213,105	1,239,032	2,104,916	3,657,598	619	
2	2015	319,823	-	1,046,446	-	-	217,367	1,263,812	2,104,916	3,688,651	624	
3	2016	326,321	-	1,067,375	-	-	221,714	1,289,088	2,104,916	3,720,326	629	
4	2017	332,648	-	1,088,722	-	-	226,148	1,314,870	2,104,916	3,752,634	635	
5	2018	339,505	-	1,110,496	-	-	230,671	1,341,168	2,104,916	3,785,589	640	
6	2019	346,295	-	1,132,706	-	-	235,285	1,367,991	2,104,916	3,819,202	646	
7	2020	353,221	-	1,155,381	-	-	239,990	1,395,351	2,104,916	3,853,488	652	
8	2021	360,285	-	1,178,468	-	-	244,790	1,423,258	2,104,916	3,888,459	658	
9	2022	367,491	-	1,202,037	-	-	249,686	1,451,723	2,104,916	3,924,130	664	
10	2023	374,941	-	1,226,078	-	-	254,680	1,480,757	2,104,916	3,960,514	670	
11	2024	382,338	-	1,250,588	-	-	259,773	1,510,373	2,104,916	3,997,663	676	
12	2025	389,584	-	1,275,611	-	-	264,989	1,540,580	2,104,916	4,035,461	683	
13	2026	397,784	-	1,301,124	-	-	270,288	1,571,352	2,104,916	4,074,062	689	
14	2027	405,740	-	1,327,146	-	-	275,673	1,602,619	2,104,916	4,113,475	696	
15	2028	413,656	-	1,353,689	-	-	281,167	1,634,376	2,104,916	4,153,646	703	
16	2029	422,132	-	1,380,763	-	-	286,811	1,667,573	2,104,916	4,194,621	709	
17	2030	430,574	-	1,408,378	-	-	292,547	1,700,955	2,104,916	4,236,415	717	
18	2031	439,186	-	1,436,546	-	-	298,398	1,734,643	2,104,916	4,279,045	724	
19	2032	447,969	-	1,465,276	-	-	304,356	1,769,042	2,104,916	4,322,528	731	
20	2033	457,000	-	1,494,571	-	-	310,422	1,804,171	2,104,916	4,367,505	738	
Present Worth		3,756,990	-	12,286,848	-	-	2,552,627	14,841,477	22,127,239	40,725,706	344	
(% of PW)		9.2%	0.0%	30.2%	0.0%	0.0%	6.3%	36.4%	54.3%	100.0%		

LNB w/OFA & SCR												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)	
0	2013	475,000	-	912,848	594,000	-	1,291,005	2,787,853	12,326,235	15,589,088	1,736	
1	2014	484,500	-	931,105	605,880	-	1,316,825	2,853,810	12,326,235	15,684,545	1,743	
2	2015	494,190	-	948,727	617,998	-	1,343,162	2,910,886	12,326,235	15,731,311	1,750	
3	2016	504,074	-	968,722	630,358	-	1,370,025	2,969,104	12,326,235	15,769,413	1,758	
4	2017	514,155	-	988,056	642,965	-	1,397,425	3,028,486	12,326,235	15,808,876	1,766	
5	2018	524,438	-	1,007,858	655,824	-	1,425,374	3,089,056	12,326,235	15,849,129	1,774	
6	2019	534,927	-	1,028,015	668,940	-	1,453,881	3,150,837	12,326,235	15,891,989	1,782	
7	2020	545,626	-	1,048,576	682,319	-	1,482,959	3,213,954	12,326,235	15,936,174	1,790	
8	2021	556,538	-	1,069,547	695,985	-	1,512,618	3,278,151	12,326,235	16,085,714	1,798	
9	2022	567,669	-	1,090,988	709,885	-	1,542,870	3,343,693	12,326,235	16,160,904	1,789	
10	2023	579,022	-	1,112,767	724,083	-	1,573,728	3,410,557	12,326,235	16,237,587	1,807	
11	2024	590,603	-	1,135,012	738,684	-	1,605,202	3,478,779	12,326,235	16,315,824	1,815	
12	2025	602,416	-	1,157,712	753,356	-	1,637,306	3,548,354	12,326,235	16,395,616	1,824	
13	2026	614,463	-	1,180,966	768,402	-	1,670,053	3,619,321	12,326,235	16,477,004	1,833	
14	2027	626,752	-	1,204,484	783,770	-	1,703,454	3,691,708	12,326,235	16,560,019	1,843	
15	2028	639,287	-	1,228,573	799,446	-	1,737,523	3,765,542	12,326,235	16,644,695	1,852	
16	2029	652,073	-	1,253,145	815,435	-	1,772,273	3,840,853	12,326,235	16,731,064	1,862	
17	2030	665,115	-	1,278,208	831,743	-	1,807,718	3,917,670	12,326,235	16,819,161	1,871	
18	2031	678,417	-	1,303,772	848,378	-	1,843,673	3,996,023	12,326,235	16,909,019	1,881	
19	2032	691,985	-	1,329,847	865,346	-	1,880,751	4,075,944	12,326,235	17,000,675	1,892	
20	2033	705,820	-	1,356,422	882,751	-	1,918,964	4,158,171	12,326,235	17,094,164	1,902	
Present Worth		5,803,480	-	11,153,043	7,257,405	-	15,773,310	34,183,758	129,575,485	169,582,733	943	
(% of PW)		3.4%	0.0%	6.6%	4.3%	0.0%	9.3%	20.2%	76.4%	100.0%		

Jim Bridger Unit 1												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton SO2 Removed)	
0	2013											
1	2014	42,583	30,503	533,206	-	442,858	206,926	1,215,593	1,236,652	2,452,245	632	
2	2015	43,435	31,113	543,870	-	451,818	213,105	1,236,905	1,236,652	2,473,557	638	
3	2016	44,303	31,735	554,747	-	460,854	217,367	1,236,987	1,236,652	2,473,639	645	
4	2017	45,189	32,370	565,842	-	470,071	221,714	1,236,987	1,236,652	2,473,639	651	
5	2018	46,093	33,017	577,159	-	479,472	226,148	1,236,987	1,236,652	2,473,639	658	
6	2019	47,015	33,678	588,702	-	489,062	230,671	1,236,987	1,236,652	2,473,639	665	
7	2020	47,955	34,351	600,476	-	498,843	235,285	1,236,987	1,236,652	2,473,639	672	
8	2021	48,914	35,038	612,486	-	508,820	239,980	1,236,987	1,236,652	2,473,639	679	
9	2022	49,883	35,736	624,735	-	518,996	244,750	1,236,987	1,236,652	2,473,639	686	
10	2023	50,880	36,464	637,230	-	529,376	249,686	1,236,987	1,236,652	2,473,639	694	
11	2024	51,908	37,163	649,975	-	539,964	254,680	1,236,987	1,236,652	2,473,639	701	
12	2025	52,946	37,925	662,974	-	551,773	260,969	1,236,987	1,236,652	2,473,639	709	
13	2026	54,005	38,665	676,234	-	564,044	267,688	1,236,987	1,236,652	2,473,639	717	
14	2027	55,085	39,459	689,758	-	576,873	274,849	1,236,987	1,236,652	2,473,639	725	
15	2028	56,187	40,248	703,554	-	590,164	282,471	1,236,987	1,236,652	2,473,639	733	
16	2029	57,311	41,053	717,625	-	603,987	290,611	1,236,987	1,236,652	2,473,639	742	
17	2030	58,457	41,874	731,977	-	618,249	299,288	1,236,987	1,236,652	2,473,639	750	
18	2031	59,626	42,711	746,617	-	633,054	308,500	1,236,987	1,236,652	2,473,639	759	
19	2032	60,819	43,566	761,549	-	648,307	318,250	1,236,987	1,236,652	2,473,639	768	
20	2033	62,035	44,437	776,780	-	664,100	328,536	1,236,987	1,236,652	2,473,639	777	
Present Worth (% of PW)		520,271	372,679	6,514,628	-	5,412,000	2,352,627	14,861,935	12,999,900	28,372,107	359	
		1.8%	1.3%	23.0%	0.0%	19.1%	9.0%	52.3%	45.8%	100.0%		


Upgraded Wet FGD

Jim Bridger Unit 1												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton PM Removed)	
0	2013											
1	2014	10,000	-	145,854	-	-	19,710	165,564	-	175,564	495	
2	2015	10,200	-	148,771	-	-	20,104	168,875	-	179,075	505	
3	2016	10,404	-	151,747	-	-	20,506	172,253	-	182,657	515	
4	2017	10,612	-	154,761	-	-	20,916	175,698	-	186,310	525	
5	2018	10,824	-	157,877	-	-	21,335	179,212	-	190,036	536	
6	2019	11,041	-	161,035	-	-	21,761	182,796	-	193,837	546	
7	2020	11,262	-	164,255	-	-	22,197	186,452	-	197,714	557	
8	2021	11,487	-	167,540	-	-	22,641	190,181	-	201,669	568	
9	2022	11,717	-	170,861	-	-	23,093	193,985	-	205,701	579	
10	2023	11,951	-	174,209	-	-	23,555	197,864	-	209,815	590	
11	2024	12,190	-	177,595	-	-	24,026	201,822	-	213,915	601	
12	2025	12,434	-	181,011	-	-	24,507	205,856	-	218,012	612	
13	2026	12,682	-	184,478	-	-	24,997	210,000	-	222,252	623	
14	2027	12,936	-	188,078	-	-	25,497	214,175	-	226,598	634	
15	2028	13,195	-	191,711	-	-	26,007	218,468	-	231,053	645	
16	2029	13,459	-	195,390	-	-	26,527	222,827	-	235,598	656	
17	2030	13,728	-	200,226	-	-	27,057	227,264	-	240,102	667	
18	2031	14,002	-	204,231	-	-	27,597	231,830	-	244,632	679	
19	2032	14,282	-	208,315	-	-	28,151	236,466	-	249,249	707	
20	2033	14,568	-	212,482	-	-	28,714	241,195	-	253,964	721	
Present Worth (% of PW)		122,179	-	1,782,023	-	-	240,814	2,022,837	-	2,145,015	302	
		5.7%	0.0%	83.1%	0.0%	0.0%	11.2%	94.3%	0.0%	100.0%		


Flue Gas Conditioning

Fabric Filter												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton PM Removed)	
0	2013											
1	2014	127,749	-	-	300,040	-	1,335,944	1,635,984	4,602,887	6,366,619	8,873	
2	2015	130,304	-	-	305,041	-	1,363,663	1,668,703	4,602,887	6,401,884	9,023	
3	2016	132,910	-	-	312,162	-	1,389,916	1,702,076	4,602,887	6,437,874	9,074	
4	2017	135,568	-	-	318,405	-	1,417,714	1,736,119	4,602,887	6,474,573	9,125	
5	2018	138,279	-	-	324,773	-	1,446,069	1,770,841	4,602,887	6,512,007	9,178	
6	2019	141,045	-	-	331,266	-	1,474,990	1,806,258	4,602,887	6,550,190	9,232	
7	2020	143,866	-	-	337,894	-	1,504,490	1,842,393	4,602,887	6,589,136	9,287	
8	2021	146,743	-	-	344,652	-	1,534,579	1,879,231	4,602,887	6,628,861	9,343	
9	2022	149,678	-	-	351,545	-	1,565,271	1,916,816	4,602,887	6,669,380	9,400	
10	2023	152,671	-	-	358,576	-	1,596,577	1,955,152	4,602,887	6,710,710	9,458	
11	2024	155,725	-	-	365,747	-	1,628,508	1,994,255	4,602,887	6,752,866	9,518	
12	2025	158,839	-	-	373,062	-	1,661,078	2,034,140	4,602,887	6,795,868	9,578	
13	2026	162,016	-	-	380,523	-	1,694,300	2,074,823	4,602,887	6,839,126	9,640	
14	2027	165,256	-	-	388,134	-	1,728,188	2,116,319	4,602,887	6,884,462	9,703	
15	2028	168,562	-	-	395,896	-	1,762,749	2,158,646	4,602,887	6,930,094	9,767	
16	2029	171,933	-	-	403,814	-	1,798,004	2,201,819	4,602,887	6,976,638	9,833	
17	2030	175,371	-	-	411,891	-	1,833,965	2,245,855	4,602,887	7,024,113	9,900	
18	2031	178,879	-	-	420,128	-	1,870,644	2,290,772	4,602,887	7,072,538	9,968	
19	2032	182,456	-	-	428,531	-	1,908,057	2,336,588	4,602,887	7,121,931	10,038	
20	2033	186,108	-	-	437,102	-	1,946,218	2,383,319	4,602,887	7,172,312	10,109	
Present Worth (% of PW)		1,560,813	0.0%	0.0%	3,665,845	5.2%	16,322,365	19,888,210	48,386,333	69,935,556	100.0%	
		2.2%					23.3%	28.6%	68.2%			

First Year Cost for Air Pollution Control Options



Present Worth Cost for Air Pollution Control Options



APPENDIX B

2006 Wyoming BART Protocol

BART Air Modeling Protocol
Individual Source Visibility Assessments
for BART Control Analyses

September, 2006

State of Wyoming
Department of Environmental Quality
Air Quality Division
Cheyenne, WY 82002

Table of Contents

1.0	INTRODUCTION	3
2.0	OVERVIEW	4
3.0	EMISSIONS DATA FOR MODELING	7
3.1	Baseline Modeling	7
3.2	Post-Control Modeling.....	8
4.0	METEOROLOGICAL DATA.....	9
5.0	CALPUFF MODEL APPLICATION.....	12
6.0	POST PROCESSING	15
7.0	REPORTING	19

1.0 INTRODUCTION

The U.S. EPA has issued final amendments to the Regional Haze Regulations, along with Guidelines for Best Available Retrofit Technology (BART) Determinations.⁽¹⁾ The guidelines address the methodology for determining which facilities must apply BART (sources subject-to-BART) and the evaluation of control options.

The State of Wyoming used air quality modeling in accordance with the EPA Guidelines to determine the Wyoming sources which are subject-to-BART. This Protocol defines the specific methodology to be used by those sources for determining the improvement in visibility to be achieved by BART controls.

The methodology presented in this Protocol is consistent with EPA guidance and the Air Quality Division (AQD) determination of subject-to-BART sources. It is intended that all Wyoming sources that must conduct BART analyses will use this Protocol for their evaluation of control technology visibility improvement. Any deviations from the procedures described herein must be approved by the Division prior to implementation.

⁽¹⁾ 40 CFR Part 51: Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations; Final Rule. 70 Federal Register, 39103-39172, July 6, 2005.

2.0 OVERVIEW

Wyoming AQD determined that eight facilities (sources) in the state are subject-to-BART. The sources are listed in Table 1. Division modeling indicated that each of these sources causes or contributes to visibility impairment in one or more Class I areas. Each source must conduct a BART analysis to define Best Available Retrofit Technology (BART) applicable to that source, and quantify the improvement in Class I visibility associated with BART controls. This Protocol sets out the procedures for quantifying visibility improvement. Other aspects of the full BART analysis are not addressed here.

There are many Class I areas within and surrounding Wyoming (See Figure 1). On the basis of distance from subject-to-BART sources, topography, meteorology, and prior modeling, the AQD has determined that only five Class I areas need be addressed in BART individual source analyses. These are Badlands and Wind Cave National Parks in South Dakota, Mt. Zirkel Wilderness Area in Colorado, and Bridger and Fitzpatrick Wilderness Areas in Wyoming. Sources in eastern Wyoming have been shown to have greatest visibility impacts at the two South Dakota Class I areas, and western Wyoming sources have maximum impacts at Bridger and Fitzpatrick Wilderness Areas, and Mt. Zirkel. Visibility improvement at these highest impact areas will provide the best measure of the effectiveness of BART controls.

Each facility should carry out modeling with the CALPUFF modeling system for the Class I areas specified in Table 2. The AQD will provide meteorological input for CALMET for the years 2001, 2002, and 2003. The model domain covered by the AQD meteorological data is centered in southwest Wyoming, and extends roughly from Twin Falls, ID in the west to the Missouri River in the east, and from Denver in the south to Helena, MT in the north. The domain is shown, along with Class I areas, in Figure 1.

Sources may wish to utilize a smaller domain for CALPUFF modeling. Smaller domains are acceptable if they provide adequate additional area beyond the specific source and Class I areas being addressed. Figure 1 includes a "southwest Wyoming" domain which represents the minimum acceptable area for sources impacting the Bridger and Fitzpatrick Wilderness Areas, and the Mt. Zirkel Wilderness Area, and a "northeast Wyoming" domain as a minimum area for Badlands and Wind Cave National Parks modeling.

The CALPUFF model should be used with each of the three years of meteorological data to calculate visibility impacts for a baseline (existing emissions) case, and for cases reflecting BART controls. The control scenarios are to include individual scenarios for proposed BART controls for each pollutant (SO_2 , NO_x , and particulate matter), and a combined scenario representing application of all proposed BART controls. If desired, additional modeling may be performed for controls that are not selected as BART. This might be done, for example, to provide data useful in identifying the control technologies that represent BART. However, visibility modeling is required only for the proposed BART controls.

Table 1. Wyoming Sources Subject-to-BART

Basin Electric	Laramie River Power Plant	Boilers #1,2,3
FMC Corporation	Granger Soda Ash Plant	Boilers #1,2
FMC Corporation	Green River Sodium Plant	Three boilers
General Chemical Co.	Green River Soda Ash	Two boilers
PacifiCorp	Dave Johnson Power Plant	Boilers #3,4
PacifiCorp	Jim Bridger Power Plant	Boilers #1-4
PacifiCorp	Naughton Power Plant	Boilers #1,2,3
PacifiCorp	Wyodak Power Plant	Boiler

Results of visibility modeling will be presented as a comparison between baseline impacts and those calculated for the BART control scenarios. Quantitative measures of impact will be the 98th percentile deciview change (Δdv) relative to the 20% best days natural background, and the number of days with deciview change exceeding 0.5 (EPA Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations, 70 FR 39103). Results should be presented for each year.

Table 2. Source-Specific Class I Areas to be Addressed

Source	Class I Areas to be Evaluated
Basin Electric Laramie River	Wind Cave NP, Badlands NP
FMC Corporation Granger Soda Ash	Bridger WA, Fitzpatrick WA
FMC Corporation Sodium Products	Bridger WA, Fitzpatrick WA
General Chemical Green River Soda Ash	Bridger WA, Fitzpatrick WA
Pacificorp Dave Johnston	Wind Cave NP, Badlands NP
Pacificorp Jim Bridger	Bridger WA, Fitzpatrick WA, Mt. Zirkel WA
Pacificorp Naughton Plant	Bridger WA, Fitzpatrick WA
Pacificorp Wyodak	Wind Cave NP, Badlands NP

3.0 EMISSIONS DATA FOR MODELING

CALPUFF model input requires source (stack) – specific emission rates for each pollutant, and stack parameters (height, diameter, exit gas temperature, and exit gas velocity). Per EPA BART guidance, these parameters must be representative of maximum actual 24-hour average emitting conditions for baseline (existing) operation, and maximum proposed 24-hour average emissions for future (BART) operations.

3.1 Baseline Modeling

Sources are required to utilize representative baseline emission conditions if data are available; baseline emissions must be documented. Possible sources of emission data are stack tests, CEM data, fuel consumption data, etc. Remember that emissions should represent maximum 24-hour rates. EPA BART guidance states that you should “Use the 24-hour average actual emission rate from the highest emitting day of the meteorological period modeled (for the pre-control scenario).” Thus, baseline conditions should reference data from 2001 through 2003 (or 2004).

As a minimum, modeled emissions must include:

SO ₂	sulfur dioxide
NO _x	oxides of nitrogen
PM _{2.5}	particles with diameter less than 2.5µm
PM _{10-2.5}	particles with diameters greater than 2.5µm but less than or equal to 10 µm

If the fraction of PM₁₀ in the PM_{2.5} (fine) and PM_{10-2.5} (coarse) categories cannot be determined all particulate matter should be assumed to be PM_{2.5}.

In addition, direct emissions of sulfate (SO₄) should be included where possible. Sulfate can be emitted as sulfuric acid (H₂SO₄), sulfur trioxide (SO₃), or as sulfate compounds; emissions should be quantified as the equivalent mass of SO₄.

When test or engineering data are not available to specify SO₄ emissions or the relative fractions of fine and coarse particles, use can be made of speciation profiles available from Federal Land Managers at the website <http://ww2.nature.nps.gov/air/permits/ect/index.cfm>. Profiles are available for a number of source type and control technology combinations. The FLM speciation factors are acceptable if data are available for the appropriate source type.

Emissions of VOC (volatile organic compounds), condensable organics measured in stack tests, and elemental carbon components of PM₁₀ do not need to be included for BART modeling. The only other pollutant noted in EPA BART guidance is ammonia (NH₃). Though ammonia is not believed to be a significant contributor to visibility

impairment in most cases in Wyoming, it could be important for sources with significant ammonia emissions – for example from some NO_x control systems. Sources that are expected to emit ammonia (in pre-or post-control configurations) should include ammonia emissions in their model input.

If quantitative baseline emissions data are unavailable and sources believe that the maximum 24-hour emission rates estimated by the Division (presented in the Subject-to-BART final report) are representative of baseline conditions for their facility, they may be used for baseline modeling. However, emissions of sulfate and ammonia (if applicable) should be included based on the best available test information or speciation factors from current literature.

3.2 Post-Control Modeling

All pollutants described above should be included for each post-control scenario. Post-control emissions (maximum 24-hour average) will generally be the baseline emissions multiplied by a control factor appropriate to the BART control. However, some proposed controls may simply increase the efficiency of existing controls; others may result in an increase in emissions of one pollutant while controlling another. These factors must all be considered in defining emission rates for post-control modeling. Any changes in stack parameters resulting from control application must also be included.

The required visibility assessment will include the effect of each proposed BART control. For example, if a source proposes to add a scrubber for SO₂ control, low NO_x burners for NO_x control, and a baghouse for particulate control, four sets of visibility results should be developed:

- Use of SO₂ control alone
- Use of NO_x control alone
- Use of particulate control alone
- Use of proposed combination of all three controls

All pollutants should be modeled in each CALPUFF model run, but the modeled emissions should reflect only the specific controls or combination of controls addressed in that run.

Additional modeling could be necessary in situations where a facility is comprised of more than one subject-to-BART source, and different BART controls are applicable to different sources. Excessive modeling to address multiple control combinations is not necessary; however, visibility modeling should quantify the effect of BART controls on all affected sources for each pollutant, and of all facility BART controls combined.

4.0 METEOROLOGICAL DATA

Wyoming AQD will provide MM5 meteorological data fields for years 2001, 2002, and 2003 that can be utilized as input to CALMET. The MM5 output will have 12 kilometer resolution and cover the full domain shown in Figure 1.

Mesoscale meteorological data (MM5) were developed and evaluated as part of the AQD's southwest Wyoming NO₂ increment analysis. Three years of MM5 data at 36 km resolution were used to initialize 12 km MM5 simulations. The 12km MM5 modeling used identical physics options to the original 36 km runs. CALMM5 was then used as a preprocessor to produce CALMET – ready MM5 data input files. Quality assurance was performed by comparing the original MM5 output on the 36km national RPO grid to the 12 km MM5 output and observations.

The CALMET model (version 5.53a, level 040716) should be used to prepare meteorological input for CALPUFF. The user may select a domain smaller than the MM5 domain for CALMET and CALPUFF modeling if desired. Figure 1 shows minimum domain areas for modeling of western and eastern Wyoming BART sources. Four kilometer resolution should be specified for CALMET output.

CALMET processing should use the AQD MM5 data, and appropriate surface, upper air, and precipitation data. Figure 2 shows the locations of surface and upper air stations within the MM5 model domain. The MM5 data are used as the initial guess wind field; this wind field is then adjusted by CALMET for terrain and land use to generate a step 1 wind field, and refined using surface and upper air data to create the final step 2 wind field.

Surface, upper air, and precipitation data can be obtained from the National Climatic Data Center. Land use and terrain data are available from the U.S. Geological Survey. Data can be formatted for use in CALMET with standard conversion and processing programs available with the CALMET/CALPUFF software.

Table 3 provides a listing of applicable CALMET input variables for BART meteorological processing. The table includes inputs that are specific to Wyoming BART modeling. Inputs not shown in Table 3 are not relevant to the present application, are dependent on the specific model domain of the user, use model default values, or are obvious from the context.

Table 3. CALMET Control File Inputs

Variable	Description	Value
Input Group 1		
IBYR	Year	2001
		2002
		2003
IBTZ	Base time zone	7
IRTYPE	Run type	1
LCALGRD	Compute data fields for CALGRID	T
Input Group 2		
PMAP	Map projection	LCC
DGRIDKM	Grid spacing (km)	4
NZ	Number of layers	10
ZFACE	Cell face heights (m)	0
		20
		40
		100
		140
		320
		580
		1020
		1480
		2220
		3500
Input Group 4		
NOOBS	No observation Mode	0
Input Group 5		
IWFCOD	Model selection variable	1
IFRADJ	Froude number adjustment	1
IKINE	Kinematic effects	0
IOBR	Use O'Brien procedure	0
ISLOPE	Slope flow effects	1
IEXTRP	Extrapolate surface wind observations	-4
ICALM	Extrapolate calm surface winds	0
BIAS	Biases for weights of surface and upper air stations	All 0
RMIN2	Minimum distance for extrapolation	-1
I PROG	Use gridded prognostic model output	14
ISTEPPG	Time Step (hours)	1
LVARY	Use varying radius of influence	F

Table 3. CALMET Control File Inputs (continued)

Variable	Description	Value
RMAX 1	Maximum radius of influence (km)	30
RMAX 2	Maximum radius of influence (km)	50
RMIN	Minimum radius of influence (km)	0.1
TERRAD	Radius of influence for terrain (km)	15
R1	Relative weighting of first guess wind field and observations (km)	5
R2	Relative weighting aloft (km)	25
IDIOPT 1	Surface temperature	0
IDIOPT 2	Upper air lapse rate	0
ZUPT	Lapse rate depth (m)	200
IDIOPT 3	Average wind components	0
IUPWND	Upper air station	-1
ZUPWND (1)	Bottom and top of layer for domain	1, 1000
ZUPWND (2)	scale winds (m)	1, 1000
IDIOPT4	Surface wind components	0
IDIOPT5	Upper air wind components	0
Input Group 6		
IAVEZI	Spatial averaging	1
MNMDAV	Max search radius	1
HAFANG	Half angle for averaging (deg)	30
ILEVZI	Layer of winds in averaging	1
ZIMAX	Maximum overland mixing height (m)	3500
ITPROG	3D temperature source	1
IRAD	Interpolation type	1
TRADKM	Radius of influence -- temperature (km)	500
NUMTS	Maximum number of Stations	5
IAVET	Spatial averaging of temperatures	1
NFLAGP	Precipitation interpolation	2

5.0 CALPUFF MODEL APPLICATION

The CALPUFF model (version 5.711a, level 040716) will be used to calculate pollutant concentrations at receptors in each Class I area. Application of CALPUFF should, in general, follow the guidance presented in the Interagency Workgroup on Air Quality Modeling (IWAQM) Phase 2 report (EPA - 454/R98-019) and the EPA Regional Haze Regulations and Guidelines for BART Determinations (70 FR 39103).

Appropriate CALPUFF control file inputs are in Table 4. Note should be taken of the basis for several of the recommended CALPUFF inputs.

- Building downwash effects need not be included. Because of the transport distances involved and the fact that most sources have tall stacks, building downwash is unlikely to have a significant effect on model-predicted concentrations
- Puff splitting is not required. The additional computation time necessary for puff splitting is not justified for purposes of BART analyses.
- Hourly ozone files should be used to define background ozone concentration. Data are available from the following sites within the model domain.
 - Rocky Mountain NP, CO
 - Craters of the Moon NP, ID
 - AIRS - Highland UT
 - Mountain Thunder, WY
 - Yellowstone NP, WY
 - Centennial, WY
 - Pinedale, WY

The background ozone concentration shown in Table 4 is used only when hourly data are missing.

- A constant background ammonia concentration of 2.0 ppb is specified. This value is based upon monitoring data from nearby states and IWAQM guidance. Experience suggests that 2.0 ppb is conservative in that it is unlikely to significantly limit nitrate formation in the model computations.
- MESOPUFF II chemical transformation rates should be used.
- The species to be modeled should be the seven identified in CALPUFF: SO₂, SO₄, NO_x, HNO₃, NO₃, PM_{2.5}, and PM_{10-2.5}. If ammonia (NH₃) is emitted it should be added to the species list. In most cases, all pollutants modeled will also be emitted, except for HNO₃ and NO₃.

Concentration calculations should be made for receptors covering the areas of the Class I areas being addressed. Receptors in each Class I area will be those designated by the Federal Land Managers and available from the National Park Service website.

Table 4. CALPUFF Control File Inputs

Variable	Description	Value
	Input Group 1	
METRUN	Control parameter for running all periods in met file	1
IBYR	Starting year	2001 2002 2003
XBTZ	Base time zone	7
NSPEC	Number of chemical species modeled	7 (or 8)
NSE	Number of species emitted	5 (or 6)
METFM	Meteorological data format	1
	Input Group 2	
MGAUSS	Vertical distribution in near field	1
MCTADJ	Terrain adjustment method	3
MCTSG	Subgrid scale complex terrain	0
MSLUG	Elongated puffs	0
MTRANS	Transitional plume rise	1
MTIP	Stack tip downwash	1
MSHEAR	Vertical wind shear	0
MSPLIT	Puff splitting allowed?	0
MCHEM	Chemical mechanism	1
MAQCHEM	Aqueous phase transformation	0
MWET	Wet removal	1
MDRY	Dry deposition	1
MDISP	Dispersion Coefficients	3
MROUGH	Adjust sigma for roughness	0
MPARTL	Partial plume penetration of inversions	1
MPDF	PDF for convective conditions	0
	Input Group 4	
PMAP	Map projection	LCC
DGRIDKM	Grid spacing	4

Table 4. CALPUFF Control File Inputs (continued)

ZFACE	Cell face heights (m)	0
		20
		40
		100
		140
		320
		580
		1020
		1480
		2220
		3500
	Input Group 6	
NHILL	Number of terrain features Input Group 7	0
Dry Gas Depo	Chemical parameters for dry gas deposition	Defaults
	Input Group 8	
Dry Part. Depo	Size parameters for dry particle deposition SO ₄ , NO ₃ , PM ₂₅ PM ₁₀	Defaults 6.5, 1.0
	Input Group 11	
MOZ	Ozone Input option	1
BCKO3	Background ozone – all months (ppb)	44.0
BCKNH3	Background ammonia – all months (ppb)	2.0
	Input Group 12	
XMAXZI	Maximum mixing height (m)	3500
XMINZI	Minimum mixing height (m)	50

6.0 POST PROCESSING

Visibility impacts are calculated from the CALPUFF concentration results using CALPOST. CALPOST version 5.51, level 030709 should be used; the output from CALPOST will provide the highest deciview impact on each day from all receptors within each Class I area modeled.

For some CALPUFF applications such as deposition calculations, the POSTUTIL program is used prior to CALPOST. POSTUTIL is also used to repartition total nitrate by accounting for ammonia limiting. The ammonia limiting calculation in POSTUTIL should not be applied for Wyoming BART modeling. If you believe that ammonia limiting is appropriate for a specific BART analysis, justification should be discussed with the Division prior to its used.

Visibility calculations by CALPOST for BART purposes use Method 6. This method requires input of monthly relative humidity factors, $f(RH)$, for each Class I area. The EPA guidance document provides appropriate data for each area. Table 5 lists monthly $f(RH)$ factors to use for the Wyoming, Colorado, and South Dakota areas to be addressed in BART modeling. The factors shown in Table 5 include averages for the adjacent Class I areas, and are within 0.2 units of the Guideline table values for the individual Class I areas.

Natural background conditions as a reference for determination of the delta-dv change due to a source should be representative of the 20% best natural visibility days. EPA BART guidance provides the 20% best days deciview values for each Class I area on an annual basis, but does not provide species concentration data for the 20% best background conditions. These concentrations are needed for input to CALPOST.

Annual species concentrations corresponding to the 20% best days were calculated for each Class I area to be addressed, by scaling back the annual average concentrations given in Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule (Table 2-1). A separate scaling factor was derived for each Class I area such that, when multiplied by the Guidance table annual concentrations, the 20% best days deciview value for that area would be calculated. The scaled aerosol concentrations were averaged for the Bridger and Fitzpatrick WAs, and for Wind Cave and Badlands NPs, because of their geographical proximity and similar annual background visibility. The 20% best days aerosol concentrations to be used for each month for Wyoming BART evaluations are listed in Table 6.

Table 7 is a list of inputs for CALPOST. These inputs should be used for all BART visibility calculations. Output from CALPOST should be configured to provide a ranked list of the highest delta-deciview values in each Class I area. The 98th percentile delta-deciview value and the number of values exceeding 0.5 can then be determined directly from the CALPOST output.

Table 5. Monthly f(RH) Factors for Class I Areas

Month	Wind Cave NP Badlands NP	Bridger WA Fitzpatrick WA	Mt. Zirkel WA
January	2.65	2.50	2.20
February	2.65	2.30	2.20
March	2.65	2.30	2.00
April	2.55	2.10	2.10
May	2.70	2.10	2.20
June	2.60	1.80	1.80
July	2.30	1.50	1.70
August	2.30	1.50	1.80
September	2.20	1.80	2.00
October	2.25	2.00	1.90
November	2.75	2.50	2.10
December	2.65	2.40	2.10

Table 6. Natural Background Concentrations of Aerosol Components for 20% Best Days for BART Analyses ($\mu\text{g}/\text{m}^3$)

Aerosol Component	Wind Cave NP Badlands NP	Fitzpatrick WA Bridger WA	Mt. Zirkel WA
Ammonium Sulfate	.047	.045	.046
Ammonium Nitrate	.040	.038	.038
Organic Carbon	.186	.178	.179
Elemental Carbon	.008	.008	.008
Soil	.198	.189	.190
Coarse Mass	1.191	1.136	1.141

Table 7. CALPOST Control File Inputs

Variable	Description	Value
	Input Group 1	
ASPEC	Species to Process	VISIB
ILAYER	Layer/deposition code	1
A,B	Scaling factors	0,0
LBACK	Add background concentrations?	F
BTZONE	Base time zone	7
LVSO4	Species to be included in extinction	T
LVNO3		T
LVOC		F
LVPMC		T
LVPMF		T
LVEC		F
LVBK	Include background?	T
SPECPMC	Species name for particulates	PM10
SPECPMF		PM25
EETMC	Extinction efficiencies	0.6
EETMF		1.0
EETMCBK		0.6
EESO4		3.0
EENO3		3.0
EEOC		4.0
EESOIL		1.0
EEEC		10.0
MVISBK	Visibility calculation method	6
RHFAC	Monthly RH adjustment factors	Table 5
BKSO4	Background concentrations	Table 6
BKNO3		Table 6
BKPMC		Table 6
BK OC		Table 6
BKSOIL		Table 6
BKEC		Table 6
BEXTRAY	Extinction due to Rayleigh scattering	10.0

7.0 REPORTING

A report on the BART visibility analysis should be submitted that clearly compares impacts for post-control emissions to those for baseline emissions. Data for baseline and BART scenarios should include both the 98th percentile values and the number of days with delta-deciview values exceeding 0.5. Results should be given for each model year.

Table 8 is an example of a recommended format for presentation of model input and model results. The example is for baseline conditions; similar tables should be provided for each control scenario (SO₂, NO_x, and PM10) and for the combination of all BART controls. Your report tables need not follow the exact format shown in Table 8; but the same information should be provided in a concise and clear form. If additional scenarios were modeled or you wish to present supplemental information, they should be provided in an appendix or separate from the specified final results.

Table 8. Example Format for Presentation of Model Input and Results

Baseline Conditions Model Input Data												
Source (Unit) Description And ID	SO ₂ Emission Rate (lb/day)	NO _x Emission Rate (lb/day)	PM _{2.5} Emission Rate (lb/day)	PM _{10-2.5} Emission Rate (lb/day)	SO ₄ Emission Rate (lb/day)	NH ₃ Emission Rate (lb/day)	Location Easting (m)	Location Northing (m)	Stack Height (m)	Stack Diameter (m)	Exit Velocity (m/s)	Exit Gas Temp (deg K)
							UTM (m)	UTM (m)				

Baseline Visibility Modeling Results						
Name of Facility	Class I Area	2001		2002		2003
		98 th Percentile Value (dv)	No. of days exceeding 0.5 dv	98 th Percentile Value (dv)	No. of days exceeding 0.5 dv	98 th Percentile Value (dv)

APPENDIX C

Just-Noticeable Differences in Atmospheric Haze
Dr. Ronald Henry

Just-Noticeable Differences in Atmospheric Haze

Ronald C. Henry

Department of Civil and Environmental Engineering, University of Southern California, Los Angeles

ABSTRACT

This article examines the only available experimental data taken in the natural environment on the ability of an observer to perceive small, incremental changes in the colorfulness of objects seen through atmospheric haze and estimates an appropriate just-noticeable difference (JND) from these data. This experimentally determined threshold of perception is compared to changes in the deciview scale. Based on these experimental results, the deciview scale is found to not be uniform over a wide range of visibility conditions, as has been previously claimed. In addition, a 1-deciview change never produces a perceptible change in haze, as defined by a 95% probability of producing a measurable change in the colorfulness of an object seen through the haze.

INTRODUCTION

Section 169A of the Clean Air Act sets a national goal of protecting visibility in national parks and other pristine areas. Under regulations promulgated in 1980, the U.S. Environmental Protection Agency (EPA) has taken specific regulatory action to protect visibility in the Grand Canyon National Park by reducing emissions of sulfur dioxide from the Navajo Electric Generating Station near the eastern end of the Grand Canyon and from the Mohave Power Plant at the western end. However, current concerns about visibility degradation stem from regional haze that is difficult or impossible to attribute to individual sources of air pollution. This issue is addressed by regional haze regulations that set a goal of making reasonable

IMPLICATIONS

Current regulations use the deciview to quantify a perceptible change in regional haze. Based on the results of this article, changes in atmospheric extinction required to meet regional haze regulations calculated using deciviews would probably be too small, sometimes much too small. In addition, these regulations require that progress be assessed over five-year intervals. In this way, the burden of reducing emissions is spread evenly over many years. However, since deciviews are not uniform in perception, it may be that the actual improvement in visibility will not be uniform.

progress toward improving regional visibility in five-year increments, leading to the attainment of "natural conditions" by 2064.¹ Progress is to be measured by an innovative visibility metric for regulatory purposes known as the deciview,² used instead of visual range or other visibility metrics because it "expresses uniform changes in haziness in terms of common increments across the entire range of visibility conditions, from pristine to extremely hazy conditions."¹ One goal of this article is to assess this and other claims about the deciview scale in light of actual measurements of the perception of haziness. Since the deciview scale is meant to quantify small, just-noticeable differences (JNDs) in visibility, a review of the basic concepts of thresholds and JNDs is given.

Perceptual Threshold Concepts

For all the senses, thresholds are necessary—otherwise we would be constantly distracted by small, inconsequential changes in the environment. A background of random noise, some from the environment and some produced inside our own sensory organs, would make it next to impossible to form a stable view of the world. Our vision would be like the grainy, speckled images produced by night vision cameras. On a more basic scientific level, the study of thresholds of the senses has led to a deeper understanding of sensory physiology and how our vision and other senses function. For this reason, virtually all studies of thresholds of vision have been carried out under controlled laboratory conditions.

Since laboratory conditions seldom mimic the natural environment, thresholds so determined are generally not useful in predicting perception in the complex natural world. As an example of the drastic effect that experimental conditions can have on perception, consider an experiment to determine the ability of an observer to perceive the difference in the length of two strings—or to put it another way, to determine the threshold for perception of the difference in the length of two strings, or the JND. If the two strings are widely separated when presented to the observer, the threshold will be much greater than if the two strings are presented side by side. The visual equivalent of this is the use of a split image to determine the ability to distinguish color. If two colors are seen as two halves of a disk, the JND is very small, but if one

color is presented as a full disk, followed a few seconds later by the other color, the JND will be much larger. The topic of the background on which the colors are seen is also important (e.g., if it is black or a complex scene). In general, many conditions influence thresholds; for this reason, the results of laboratory experiments should be applied with great caution to the natural environment. Thus, this article will report and analyze data taken in a unique experiment in the natural environment with a goal of determining a JND in atmospheric haze.

In the above discussion, the terms "threshold" and "JND" have been freely used, but not defined. The naïve definition of a threshold or JND is clear: It is the smallest amount, or change in, a physical stimulus that is detectable. Ideally, a 1-JND change in a stimulus such as contrast or color would always result in the observer seeing a change, and anything less would not. Of course, the senses do not work in this simple on-off manner. In actuality, as the change in the physical stimulus increases, the probability that the observer will detect the change increases as well. Thus, thresholds and JNDs have always been defined by a probability of detection. Furthermore, the sensitivity of people's senses varies from person to person and during a person's life. Even if each person had a single, idealized threshold, the response of the general population would be best described by a probability of detection.

Repeated matching by the method of adjustments is one of the oldest methods of determining a JND. Palmagne³ described this and other methods to quantify perception. Briefly, the observer is shown a target color and a variable test color and is asked to adjust the test color until it matches the target. Taking random starting points, the matching procedure is repeated as often as is practical. Since the observer has judged the matching color to be the same as the target color, the variability in the matches is a measure of a JND around the target. The standard deviation of the matches is one measure of this variability that is often used; another is the difference between the 75th and the 25th percentile of the match distribution. The method of adjustments has been replaced in laboratory studies by methods that give less control to the observer and more to the researcher and therefore improve the reproducibility of the results (unfortunately, these methods are impractical for field studies). However, JNDs are still defined by some measure related to the probability of detection. The final determination of the value of a JND or threshold is really dependent on how the measurements are made and how the data are interpreted. For the experimental data used in this article, the method of adjustments was used and a JND related to the standard deviation of repeated matches was defined.

Atmospheric Visibility Concepts

In the classical theory of atmospheric visibility, the threshold of contrast perception, that is, the threshold for perception of a large, dark object on the horizon, is assumed to be 2%.⁴ This number is somewhat arbitrary. The Federal Aviation Administration (FAA) has taken the more conservative value of 5.5% as a contrast threshold for the definition of visual range, presumably because approaching aircraft seen from a cockpit are usually neither large nor dark. The common formula for visual range, using the 2% threshold, is

$$V_R = \frac{-\ln(0.02)}{b_{ext}} = \frac{3.9}{b_{ext}} \quad (1)$$

where b_{ext} is the extinction coefficient of the atmosphere, which is assumed to be homogeneous. The extinction coefficient in the denominator of the formula can be thought of as the fraction of light that is lost as it traverses 1 m of air. For completely clear air, b_{ext} has a value of about $10 \times 10^{-6} \text{ m}^{-1}$ or 10 Mm^{-1} , or a visual range of about 390 km. More typically, particles in the air usually increase the extinction coefficient to 150–300 Mm^{-1} or more. Typical visual ranges are about 10 km in the eastern United States and 50 km or more in the western United States. Closely related to b_{ext} and visual range is the more general concept of optical depth. For a target at a distance x , this is defined as $x b_{ext}$. It is dimensionless; if b_{ext} is held constant it represents distance, and if the distance is constant, it represents changes in b_{ext} . From eq 1, the visual range corresponds to an optical depth of 3.9, and a distance of about one quarter of the visual range is equivalent to an optical depth of 1.

Despite lacking a firm psychophysical or experimental basis, the visual range defined by the 2% threshold has stood the test of time. However, while visual range has proven to be a good surrogate for atmospheric visibility for the aviation community, it is of limited value in addressing the concerns of the air quality community. Unlike aviation, where poor visibility is of greatest interest, the air quality community is primarily concerned with relatively small changes in good visibility. Pitchford and Malm² have proposed the deciview as a visibility indicator more suited to air quality regulations. If the extinction coefficient is given in Mm^{-1} , then deciview is defined as

$$v = 10 \ln(b_{ext} / 10) \quad (2)$$

Current regional haze visibility regulations state that:

- (1) A 1-deciview change in haziness is a small, but noticeable, change in haziness under most circumstances when viewing scenes in Class I areas.
- (2) Deciview units are uniform in perception over a wide range of visibility conditions; that is, a 1-deciview change is just perceptible regardless of the visibility conditions.¹

The next section describes a color matching experiment in the Great Smoky Mountains National Park. The results of this experiment are used to estimate a just-noticeable change in haze based on color perception. The validity of the claims for deciviews will be evaluated by comparison to experimental estimates of JNDs.

EXPERIMENTAL DATA

During summer 1995, a group of researchers from universities, government agencies, and private companies conducted the SouthEast Aerosol and Visibility Study (SEAVS) in the Great Smoky Mountains National Park. The SEAVS focused largely on aerosol composition,^{5,6} airborne particle size distribution,^{7,8} and the role of water in the aerosol.⁹⁻¹¹ However, the SEAVS had a number of other aspects, including a study of the perception of color through atmospheric haze.¹² The methods and primary results of the color perception study are described below.

The perceived colors of natural targets were quantified by color matching using a specially constructed visual colorimeter.¹³ An observer looked at some scene element, such as a barn or green field, with one eye. The observer looked with the other eye in the visual colorimeter at a color spot, which the observer adjusted to match the color of the target. The perceived color was recorded as the amount of red, green, and blue light in the color match. At the same time, the spectrum of the light coming from the target was measured by a telespectroradiometer. A color appearance model was applied to produce measures of the perceived color as recorded by the visual colorimeter and as calculated from the spectrum.¹⁴

Of most interest here are the hue and colorfulness. The hue is what most people call the color—red, green, blue, yellow, and so on. It is quantified as a mixture of pure red, green, blue, or yellow lights. The colorfulness is the degree to which the hue is expressed; it is similar to the concept of saturation. A deep red color would have a colorfulness of about 100, while a colorfulness of 10 or less is almost achromatic (i.e., white or gray).

Two observers (Mahadev and Urquito) made color matches of a set of natural targets during the SEAVS. These observers were both males in their 20s with normal color vision. Each had received extensive training in color matching using the visual colorimeter. The scattering coefficient of the atmosphere was measured by a nearby nephelometer; particle absorption was small and its contribution to the extinction coefficient ignored. The full details of the experiment are found in Mahadev.¹⁵

The perception study found that viewing through a semitransparent atmosphere affected the perception of hue and colorfulness in a highly nonlinear way. The eye appeared to split the light coming from the target into two parts, the haze and the target. The result was that as

the haze increased, the hue of the target as seen by the observer remained constant. However, because the increasing haze scattered more light into the sight path, the hue calculated from the spectrum became bluer. To the observer, the main effect of haze was to decrease the perceived colorfulness. Furthermore, the decrease in colorfulness seemed to be exponential with optical depth (optical depth is the dimensionless product of the extinction coefficient and distance):

$$M(\tau) = M_0 \exp(-\tau) \quad (3)$$

where $M(\tau)$ is the colorfulness of the object at optical depth τ and M_0 is the colorfulness at zero optical depth (i.e., no haze). M_0 is also known as the inherent colorfulness. The colorfulness of the horizon was assumed to be small enough to be taken as zero—the horizon was perceived to be white. This result implies that a JND in colorfulness can be taken to be a JND in haze.

JND in Colorfulness

Estimates of JNDs in colorfulness were based on sets of repeated color matches made during periods when the observing conditions (cloud cover, haze level, and lighting) were judged to be constant or nearly so. Observer Urquito made six sets of repeated matches.¹⁵ Figure 1 is a plot of all the repeated observations of the colorfulness of the red barn roof made by this observer versus optical depth. The exponential fit given by eq 1 is fairly good ($R^2 = 0.68$). The error bars in the figure are twice the standard deviation given in Table 1. They show that one set




Figure 1. Colorfulness vs. optical depth for observer Urquito for repeated observations of the red barn roof. The line is an exponential fit as in eq 1, and the error bars are two times the standard deviation given in Table 2.

Table 1. Repeated measurements of the red barn roof by observer Mahadev.

Date	Time	Scattering Coefficient (Mm) ⁻¹	Visual Range (km)	Colorfulness		Spectra Hue		Perceived Hue	
				Spectra	Perceived	% Red	% Blue	% Red	% Blue
7/29/95	10:20 a.m.	37	105.7	38.0	42.2	53	47	97	3
7/29/95	10:46 a.m.	39	100.3	38.9	45.6	40	60	92	8
7/29/95	10:54 a.m.	39	100.3	39.9	45.4	38	62	99	1
7/29/95	11:03 a.m.	42	93.1	35.6	46.3	52	48	92	8
7/29/95	11:12 a.m.	42	93.1	37.5	44.9	53	47	93	7
7/25/95	11:49 a.m.	65	60.2	31.2	41.1	50	50	88	12
7/25/95	12:01 p.m.	65	60.2	30.8	45.1	42	58	84	16
7/25/95	12:12 p.m.	65	60.2	30.4	44.1	53	47	91	9
7/25/95	12:19 p.m.	65	60.2	29.4	43.0	54	46	91	9
7/25/95	12:24 p.m.	65	60.2	29.2	48.4	47	53	93	7
8/11/95	9:46 a.m.	157	24.9	37.6	29.2	19	81	97	3
8/11/95	9:57 a.m.	157	24.9	37.2	28.8	22	78	98	2
8/11/95	10:07 a.m.	157	24.9	37.5	29.2	23	77	98	2
8/11/95	10:16 a.m.	161	24.3	36.3	34.9	24	76	98	2
8/11/95	10:21 a.m.	161	24.3	36.7	29.5	23	77	98	2
8/14/95	10:12 a.m.	311	12.6	44.4	18.2	9	91	91	9
8/14/95	10:18 a.m.	312	12.5	44.0	18.4	8	92	97	3
8/14/95	10:30 a.m.	313	12.5	44.8	17.6	7	93	95	5
8/14/95	10:34 a.m.	313	12.5	44.7	18.1	7	93	94	6
8/14/95	10:38 a.m.	313	12.5	44.3	18.3	8	92	94	6
8/18/95	11:00 a.m.	595	6.6	35.3	9.7	2	98	81	19
8/18/95	10:46 a.m.	616	6.4	35.4	6.8	2	98	98	2
8/18/95	10:50 a.m.	616	6.4	35.2	9.4	2	98	91	9
8/18/95	10:53 a.m.	616	6.4	35.0	7.3	2	98	99	1
8/18/95	10:57 a.m.	616	6.4	35.7	10.0	2	98	97	3

of repeated measurements had colorfulness values that deviated much more than 2 sigma from the exponential line. However, the spread of these values about the mean was about the same as other observations for the same optical depth. This shows that the variability in the colorfulness numbers is not affected by systematic observer bias in the average colorfulness, and that the variability will be used to define the JND. The observations of the same target by the other observer are discussed in detail below.

Table 1 gives the results of five sets of repeated matches by observer Mahadev for the roof of a red barn about 3.5 km distant. Table 1 is sorted by the extinction coefficient so that one can easily see that the perceived hue did not change with increasing haze, but that the hue derived from the spectrum changed from red to blue. Colorfulness had the opposite behavior; the perceived values decreased with increasing haze and the values from the spectrum stayed about the same. Two-way

analysis of variance was applied to estimate the random error in the sets of repeated measurements in Table 1. This analysis was repeated for both observers' matches of five additional natural targets. The results are given in Table 2. The standard deviation for both observers was 2.05, as calculated from the average of the variances. Although viewing conditions were chosen to be constant, some of this variability was due to small changes in atmospheric conditions.

Based on these results, one can define the JND in colorfulness in many ways. One appropriate definition for this application is based on the following thought experiment. An observer matches a target with the visual colorimeter and determines the colorfulness to be C_1 . The extinction coefficient of the atmosphere is decreased, so the colorfulness of the target is increased by an amount ΔC . The observer matches the

target again to get the new colorfulness C_2 . A JND is defined as the value of ΔC that gives a 95% probability that $C_2 - C_1 > 0$. Assume that C_1 and C_2 are normal random variables with standard deviation s and means C_0 and $C_0 + \Delta C$, respectively (statistical analysis of the SEAVS color matching data confirms that this is a good assumption). Then $C_2 - C_1$ is a normal random variable with mean ΔC and standard deviation $2^{1/2}\sigma$. The value of ΔC needed to ensure a 95% probability that $C_1 - C_2 > 0$ is given by $2^{1/2}\sigma F(0.95)$, where $F(0.95)$ is the inverse of the cumulative standard normal distribution and is equal to 1.645. Thus, the colorfulness JND is taken to be $2^{1/2}\sigma F(0.95) = 2.326\sigma$. From Table 2, using the data for both observers gives $\sigma = 2.05$, and a 1 colorfulness JND is 4.8. This value of σ includes the effects of small random variations in natural illumination, which should be included for this application because they are inevitably present, but makes the value of a colorfulness JND a bit larger than it would be otherwise.

Table 2. Standard deviations of colorfulness for repeated matches of natural targets.

Target	Observer		Distance (km)
	M	U	
White silo	0.91	1.33	3.54
Red roof	1.93	2.41	3.54
Near green meadow	2.93	2.15	3.86
Green hills	2.15	3.46	5.15
Far green meadow	1.45	1.64	10.46
Horizon sky	1.53	1.19	
Average	1.92	2.17	
Number of observations	55	60	

Deciviews and Colorfulness JNDs

Relationships between colorfulness, deciviews, and optical depth are derived below; these will be applied to test the validity of the properties of deciviews given in the regional haze regulations.

From eqs 2 and 3, an expression for deciviews v as a function of colorfulness M is derived:

$$v = 10 \ln \left(-\frac{1}{10x} \ln \left(\frac{M}{M_0} \right) \right) \quad (4)$$

For a given optical depth and inherent colorfulness, the equations above were used to calculate the change in deciviews needed to give a 1-JND increase in colorfulness, using 4.8 as a JND. Figure 2 is a plot of the results as a function of optical depth for objects with three levels of inherent colorfulness. These levels of inherent colorfulness represent a reasonable range for natural targets.¹² As might be expected, more colorful objects are more sensitive to changes in atmospheric haze. Perhaps unexpectedly, the figure shows that landscape features at a distance corresponding to an optical depth of 1–2 are the most sensitive to changes in extinction as measured by deciviews. This range corresponds to one quarter to one half of the visual range. Landscape features outside this range are much less sensitive to changes in haze. If the deciview scale were perceptually uniform, as claimed in the regional haze rules, then the lines in the figure would be horizontal, or at least approximately so. However, the change in deciviews needed to produce a 1-JND change in colorfulness varied a great deal with optical depth and inherent colorfulness. The figure also shows that a 1-JND change in colorfulness always requires more than a 1-deciview change, sometimes much more.

DISCUSSION AND CONCLUSIONS

Regional atmospheric haze affects visibility by producing a visible haze layer that limits the visual range, reduces




Figure 2. Change in deciviews needed to produce a just-noticeable increase in colorfulness for objects with an inherent colorfulness of 25, 50, and 75. The horizontal dashed dotted line represents what would be expected if a 1-deciview change were actually a uniform measure of haze perception.

contrast, and decreases the colorfulness of objects seen through the haze. Of these three effects of haze, the decrease in colorfulness may be the most important and sensitive visual cue. Visual range is not often useful for judging the effects of small changes in extinction. For example, a change in visual range from 50 to 60 km will not be noticed if the most distant landscape feature is at 25 km. The effect of haze on contrast is a better candidate as an indicator of change in haze; however, perceived contrast, like perceived hue, is affected in a nonlinear fashion by the semitransparent nature of haze and is not a sensitive indicator of changes in atmospheric haze.¹⁶ Experimental data have shown that colorfulness is a sensitive measure of changes in haze, so this article has used it to define just-noticeable changes in atmospheric haze.

A just-noticeable decrease in atmospheric haze is defined as a decrease in extinction that would produce a 95% probability of a measurable increase in colorfulness of an object seen through the haze. From the experimental evidence from the two young male observers, a JND in colorfulness was 4.8. For the population in general, this number is certainly too low, since all visual functions decline with age. Thus, the conclusions below about the deciview scale based on this number are understated for the general population.

Analysis of the experimental data showed that for a JND in atmospheric haze as defined above:

- (1) The deciview scale is not uniform in perception over a wide range of visibility conditions. In fact, the change in deciviews needed to be noticeable

varies greatly depending on the optical distance of the landscape feature and its inherent colorfulness.

(2) A 1-deciview change is never noticeable.

What are the implications of these results for measuring progress toward reducing regional haze using the deciview metric? This is difficult to judge because the current proposals are very complex, using particulate measurements and relative humidity to estimate the extinction coefficient and average deciviews for the 20% most-impaired and 20% least-impaired days. The goal is to show no change on the least-impaired days and improvement on the most-impaired days, leading to natural conditions by 2064.¹⁷

The results of this article highlight a possible flaw in this regulatory scheme based on the deciview metric. An unstated assumption is that the nature of the scenic vista can be ignored—that is, a given deciview change will affect the perception of all landscape features in all scenes in the same way. Figure 2 shows that this is approximately true only if all the important landscape features have nearly the same inherent colorfulness and are at distances that correspond to an optical depth of between 1 and 2, or about one quarter to one half of the visual range. In this limited case, the deciview is indeed a uniform metric. However, most scenic vistas do not fit these restrictions and, by Figure 2, will require greater decreases in extinction as measured by deciviews to show a perceptible change. The result is that the emission reductions required by the proposed regulatory analysis are likely to produce much smaller improvements in perceived effects of regional haze than expected. The EPA guidance documents provide an example of an eastern scenic vista with a baseline of 27 deciviews and natural conditions of 11.¹⁷ The decrease in extinction to reach natural conditions by 2064 is 0.35 deciview/yr, or 1.75 deciviews in five years. This five-year reduction should, according to the regulations, result in a noticeable change in regional haze. However, the results herein predict that there would very likely be no noticeable difference in any actual scenic vista in the region as a result of the required emission reductions.

Regional haze rules also call for a uniform rate of improvement in visibility (measured in deciviews) that is needed to go from current conditions to natural conditions by 2064. Since the deciview scale is not uniform in perception over a wide range of visibility conditions, this requirement is also flawed and will not result in uniform improvement in perceived visibility.

ACKNOWLEDGMENTS

The funding for this project was provided by the Electric Power Research Institute under Contract EP-P5419/C2683. The author would like to thank Dr. Naresh Kumar for his support and discussions leading to this work, and Drs.

Shudeish Mahadev and Santiago Urquito for their careful and diligent work as the observers in the field study.

REFERENCES

1. *Fed. Regist.* 1999, 64 (126), 35713-35774.
2. Pitchford, M.; Malm, W. Development and Applications of a Standard Visual Index; *Atmos. Environ.* 1994, 28, 1049-1054.
3. Falmagne, J.C. *Elements of Psychophysical Theory*; Oxford University Press: New York, 1985.
4. Middleton, W.B.K. *Vision through the Atmosphere*; University of Toronto Press: Toronto, Ontario, 1952; p 122.
5. Andrews, E.; Saxena, P.; Musarra, S.; Hildemann, L.M.; Koutrakis, P.; McMurry, P.H.; Olmez, I.; White, W.H. Concentration and Composition of Atmospheric Aerosols from the 1995 SEAVS Experiment and a Review of the Closure between Chemical and Gravimetric Measurements; *J. Air & Waste Manage. Assoc.* 2000, 50, 648-664.
6. Blando, J.D.; Porcja, R.J.; Li, T.H.; Bowman, D.; Lloy, P.J.; Turpin, B.J. Secondary Formation and the Smoky Mountain Organic Aerosol: An Examination of Aerosol Polarity and Functional Group Composition during SEAVS; *Environ. Sci. Technol.* 1998, 32, 604-613.
7. Dick, W.D.; Ziemann, P.J.; Huang, P.F.; McMurry, P.H. Optical Shape Fraction Measurements of Submicrometer Laboratory and Atmospheric Aerosols; *Measure. Sci. Technol.* 1998, 9, 183-196.
8. Ames, R.B.; Hand, J.L.; Kreidenweis, S.M.; Day, D.E.; Malm, W.C. Optical Measurements of Aerosol Size Distributions in Great Smoky Mountains National Park: Dry Aerosol Characterization; *J. Air & Waste Manage. Assoc.* 2000, 50, 665-676.
9. Hand, J.L.; Ames, R.B.; Kreidenweis, S.M.; Day, D.E.; Malm, W.C. Estimates of Particle Hygroscopicity during the Southeastern Aerosol and Visibility Study; *J. Air & Waste Manage. Assoc.* 2000, 50, 677-685.
10. Malm, W.C.; Day, D.E.; Kreidenweis, S.M. Light Scattering Characteristics of Aerosols as a Function of Relative Humidity: Part I—A Comparison of Measured Scattering and Aerosol Concentrations Using the Theoretical Models; *J. Air & Waste Manage. Assoc.* 2000, 50, 686-700.
11. Malm, W.C.; Day, D.E.; Kreidenweis, S.M. Light Scattering Characteristics of Aerosols at Ambient and as a Function of Relative Humidity: Part II—A Comparison of Measured Scattering and Aerosol Concentrations Using Statistical Models; *J. Air & Waste Manage. Assoc.* 2000, 50, 701-709.
12. Henry, R.C.; Mahadev, S.; Urquito, S.; Chitwood, D. Color Perception through Atmospheric Haze; *J. Opt. Soc. Am., A. Optics, Imaging Sci. & Vision* 2000, 17, 831-835.
13. Henry, R.C.; Shibata, T.; Chitwood, D. Construction and Operation of a Video-Based Visual Colorimeter for Atmospheric Research; *Atmos. Environ.* 1994, 28A, 1065-1069.
14. Mahadev, S.; Henry, R.C. Application of a Color Appearance Model to Vision through Atmospheric Haze; *Color Resh. & Appl.* 1999, 24, 112-120.
15. Mahadev, S. Quantifying the Color Appearance of Objects Viewed through Atmospheric Haze. Ph.D. Dissertation, University of Southern California, Los Angeles, CA, 1998.
16. Henry, R.C. Psychophysics, Visibility, and Perceived Transparency; *Atmos. Environ.* 1987, 21, 159-164.
17. U.S. Environmental Protection Agency. *Draft Guidance for Tracking Progress under the Regional Haze Rule*; U.S. Environmental Protection Agency, Office of Air Quality Planning and Standards: Research Triangle Park, NC, September 27, 2001.

About the Author

Dr. Ronald C. Henry is professor of Civil and Environmental Engineering at the University of Southern California, Department of Civil and Environmental Engineering, 3620 South Vermont Ave., Los Angeles, CA 90089-2531; e-mail: rhenry@usc.edu.

Final Report

BART Analysis for Jim Bridger Unit 2

Prepared For:

PacifiCorp
1407 West North Temple
Salt Lake City, Utah 84116

January 12, 2007

Prepared By:

CH2MHILL
215 South State Street, Suite 1000
Salt Lake City, Utah 84111

Final Report



BART Analysis for Jim Bridger Unit 2

Prepared For:

PacifiCorp
1407 West North Temple
Salt Lake City, Utah 84116

January 12, 2007

Prepared By:

CH2MHILL
215 South State Street, Suite 1000
Salt Lake City, Utah 84111

Executive Summary

Background

In response to the Regional Haze Rule and Best Available Retrofit Technology (BART) regulations and guidelines, CH2M HILL was requested to perform a BART analysis for PacifiCorp's Jim Bridger Unit 2 (hereafter referred to as Jim Bridger 2). A BART analysis has been conducted for the following criteria pollutants: oxides of nitrogen (NO_x), sulfur dioxide (SO₂), and particulate matter less than 10 microns in aerodynamic diameter (PM₁₀). The Jim Bridger Station consists of four 530 megawatt (MW) units with a total generating capacity of 2,120 megawatts (MW). Because the total generating capacity of the Jim Bridger Station exceeds 750 MW, presumptive BART limits apply to Jim Bridger 2, based on the United States Environmental Protection Agency's (EPA) guidelines. BART emissions limits must be achieved within five years after the State Implementation Plan (SIP) is approved by the EPA. A compliance date of 2014 was assumed for this analysis.

In completing the BART analysis, technology alternatives were investigated and potential reductions in NO_x, SO₂, and PM₁₀ emissions rates were identified. The following technology alternatives were investigated, listed below by pollutant:

NO_x emission controls:

- Low NO_x burners with over-fire air
- Rotating opposed fire air
- Low NO_x burners with selective non-catalytic reduction system (SNCR)
- Low NO_x burners with selective catalytic reduction (SCR) system

SO₂ emission controls:

- Optimize current operation of existing wet sodium flue gas desulfurization (FGD) system
- Upgrade wet sodium FGD system to achieve an SO₂ emission rate of 0.10 lb/MMBtu
- New dry FGD system

PM₁₀ emission controls:

- Sulfur trioxide (SO₃) injection flue gas conditioning system on existing electrostatic precipitator
- Polishing fabric filter

BART Engineering Analysis

The specific steps in a BART engineering analysis are identified in the Code of Federal Regulations (CFR) at 40 CFR 51 Appendix Y, Section IV. The evaluation must include:

1. The identification of available, technically feasible, retrofit control options

2. Consideration of any pollution control equipment in use at the source (which affects the availability of options and their impacts)
3. The costs of compliance with the control options
4. The remaining useful life of the facility
5. The energy and non-air quality environmental impacts of compliance
6. The degree of visibility improvement which may reasonably be anticipated from the use of BART

These steps are incorporated into the BART analysis as follows:

Step 1 – Identify All Available Retrofit Control Technologies

Step 2 – Eliminate Technically Infeasible Options

- The identification of available, technically feasible, retrofit control options
- Consideration of any pollution control equipment in use at the source (which affects the applicability of options and their impacts)

Step 3 – Evaluate Control Effectiveness of Remaining Control Technologies

Step 4 – Evaluate Impacts and Document the Results

- The costs of compliance with the control options
- The remaining useful life of the facility
- The energy and non-air quality environmental impacts of compliance

Step 5 – Evaluate Visibility Impacts

- The degree of visibility improvement which may reasonably be anticipated from the use of BART

Separate analyses have been conducted for NO_x, SO₂, and PM₁₀ emissions. All costs included in the BART analyses are in 2006 dollars, and costs have not been escalated to the assumed 2014 BART implementation date.

Coal Characteristics

The main source of coal burned at Jim Bridger 2 will be the Bridger Underground Mine. Secondary sources are the Bridger Surface Mine, the Bridger Highwall Mine, the Black Butte Mine, and the Leucite Hills Mine. These coals are ranked as subbituminous, but are closer in characteristics to bituminous coal in many of the parameters influencing NO_x formation. These coals have higher nitrogen content than coals from the Powder River Basin (PRB), which represent the bulk of subbituminous coal use in the U.S. This BART analysis has considered the higher nitrogen content and different combustion characteristics of PRB coals, as compared to those coals used at Jim Bridger 2, and has evaluated the effect of these qualities on NO_x formation and achievable emission rates.

Recommendations

NO_x Emission Control

The BART presumptive NO_x limit assigned by EPA for tangentially-fired boilers burning subbituminous coal is 0.15 lb/MMBtu. However, as documented in this analysis, the characteristics of the Jim Bridger coals are more closely aligned with bituminous coals, with a presumptive BART NO_x limit of 0.28 lb/MMBtu.

CH2M HILL recommends the existing low-NO_x burners with over-fire air (LNB w/OFA) as BART for Jim Bridger 2, based on the projected significant reduction in NO_x emissions, reasonable control costs, and the advantages of no additional power requirements or non-air quality environmental impacts. NO_x reductions have been realized at Jim Bridger 2. CH2M HILL recommends that the unit be permitted at a rate of 0.26 lb/MMBtu.

SO₂ Emission Control

CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 2, based on the significant reduction in SO₂ emissions, reasonable control costs, and the advantages of minimal additional power requirements and minimal non-air quality environmental impacts. This upgrade approach will meet the BART presumptive SO₂ limit of 0.15 lb/MMBtu.

PM₁₀ Emission Control

CH2M HILL recommends finalizing the permitting of the flue gas conditioning system to enhance the performance of the existing electrostatic precipitator (ESP) as BART for Jim Bridger 2, based on the significant reduction in PM₁₀ emissions, reasonable control costs, and the advantages of minimal additional power requirements and no non-air quality environmental impacts.

Control Scenario 1

These BART selections, which include maintaining the existing low NO_x burners with over-fire air, upgrading the existing FGD system, and operating the existing electrostatic precipitator with an SO₃ flue gas conditioning system, are identified as Scenario 1 throughout this report.

BART Modeling Analysis

CH2M HILL used the CALPUFF modeling system to assess the visibility impacts of emissions from Jim Bridger 2 at Class I areas. The Class I areas potentially affected are located more than 50 kilometers, but less than 300 kilometers, from the Jim Bridger Plant.

The Class I areas include the following wilderness areas (WA):

- Bridger WA
- Fitzpatrick WA
- Mt. Zirkel WA

Because Jim Bridger 2 will simultaneously control NO_x, SO₂, and PM₁₀ emissions, four post control atmospheric dispersion modeling scenarios were developed to cover the range of effectiveness for combining the individual NO_x, SO₂ and PM₁₀ control technologies under evaluation. These modeling scenarios, and the controls assumed, are as follows:

- **Scenario 1:** Existing LNB w/OFA, upgraded wet FGD system, and flue gas conditioning for enhanced ESP performance. As indicated previously, this scenario represents CH2M HILL's preliminary BART recommendation.
- **Scenario 2:** Existing LNB w/OFA, upgraded wet FGD system, and new polishing fabric filter.
- **Scenario 3:** Existing LNB w/OFA and SCR, upgraded wet FGD system, and flue gas conditioning for enhanced ESP performance.
- **Scenario 4:** Existing LNB w/OFA and SCR, upgraded wet FGD system, and new polishing fabric filter.

Visibility improvements for all emission control scenarios were analyzed, and the results were compared utilizing a Least-Cost Envelope, as outlined in the draft EPA 1990 New Source Review Workshop Manual (NSR Manual).

Least-Cost Envelope Analysis

EPA has adopted the Least-Cost Envelope Analysis Methodology as an accepted methodology for selecting the most reasonable, cost-effective controls. Incremental cost-effectiveness comparisons focus on annualized cost and emission reduction differences between dominant alternatives. The dominant set of control alternatives is determined by generating what is called the envelope of least-cost alternatives. This is a graphical plot of total annualized costs for a total emissions reductions for all control alternatives identified in the BART analysis.

To evaluate the impacts of the modeled control scenarios on the three Class I areas, the total annualized cost, cost per deciview (dV) reduction, and cost per reduction in number of days above 0.5 dV were analyzed. This report provides a comparison of the average incremental costs between relevant scenarios for the three Class I areas; the total annualized cost versus number of days above 0.5 dV, and the total annualized cost versus 98th percentile delta-deciview (Δ dV) reduction.

Results of the Least-Cost Envelope Analysis validate the selection of Scenario 1, based on incremental cost and visibility improvements. Scenario 2 (LNB w/OFA, upgraded wet FGD, and polishing fabric filter) is eliminated, because it is to the left of the curve formed by the "dominant" control alternative scenario, which indicates a scenario with lower improvement and/or higher costs. Scenario 3 (LNB w/OFA and SCR, upgraded wet FGD, and flue gas conditioning for enhanced ESP performance) is not selected due to very high incremental costs, on the basis of both cost per day of improvement and cost per dV reduction. While Scenario 4 (LNB w/OFA and SCR, upgraded wet FGD, and polishing fabric filter) provides some potential visibility advantage over Scenario 1, the projected improvement is less than half a dV, and the projected costs are excessive. Therefore, Scenario 1 represents BART for Jim Bridger 2.

Just-Noticeable Differences in Atmospheric Haze

Studies have been conducted that demonstrate only dV differences of approximately 1.5 to 2.0 dV or more are perceptible by the human eye. Deciview changes of less than 1.5 cannot be distinguished by the average person. Therefore, the modeling analysis results indicate that only minimal, if any, observable visibility improvements at the Class I areas studied would be expected under any of the control scenarios. Thus, the results indicate that only minimal discernable visibility improvements may result, even though PacifiCorp will be spending many millions of dollars at this single unit, and over a billion dollars when considering its entire fleet of coal-fired power plants..

Contents

Acronyms and Abbreviations	iv
1.0 Introduction	1-1
2.0 Present Unit Operation.....	2-1
3.0 BART Engineering Analysis	3-1
3.1 Applicability.....	3-1
3.2 BART Process.....	3-1
3.2.1 BART NO _x Analysis.....	3-2
3.2.2 BART SO ₂ Analysis.....	3-13
3.2.3 BART PM ₁₀ Analysis.....	3-15
4.0 BART Modeling Analysis.....	4-1
4.1 Model Selection	4-1
4.2 CALMET Methodology.....	4-1
4.2.1 Dimensions of the Modeling Domain.....	4-1
4.2.2 CALMET Input Data	4-3
4.2.3 Validation of CALMET Wind Field.....	4-6
4.3 CALPUFF Modeling Approach.....	4-6
4.3.1 Background Ozone and Ammonia.....	4-6
4.3.2 Stack Parameters	4-7
4.3.3 Emission Rates	4-7
4.3.4 Post Control Scenarios	4-7
4.3.5 Modeling Process	4-10
4.3.6 Receptor Grids	4-10
4.4 CALPOST	4-10
4.5 Presentation of Modeling Results	4-11
4.5.1 Degree of Visibility Change for Baseline vs. Preferred Scenario.....	4-11
5.0 Preliminary Assessment and Recommendations	5-1
5.1 Least-Cost Envelope Analysis	5-1
5.1.1 Analysis Methodology	5-1
5.1.2 Analysis Results.....	5-8
5.2 Recommendations	5-8
5.2.1 NO _x Emission Control	5-8
5.2.2 SO ₂ Emission Control	5-8
5.2.3 PM ₁₀ Emission Control	5-8
5.3 Just-Noticeable Differences in Atmospheric Haze	5-9
6.0 References	6-1

Tables

2-1	Unit Operation and Study Assumptions.....	2-1
2-2	Coal Sources and Characteristics	2-3
3-1	Coal Characteristics Comparison.....	3-4
3-2	NO _x Control Technology Projected Emission Rates	3-7
3-3	NO _x Control Cost Comparison	3-11
3-4	SO ₂ Control Technology Emission Rates	3-13
3-5	SO ₂ Control Cost Comparison (Incremental to Existing Wet FGD System).....	3-15
3-6	PM ₁₀ Control Technology Emission Rates	3-17
3-7	PM ₁₀ Control Cost Comparison	3-17
4-1	User-Specified CALMET Options.....	4-3
4-2	BART Model Input Data.....	4-8
4-3	Average Natural Levels of Aerosol Components	4-11
4-4	Costs and Visibility Modeling Results for Baseline Vs. Post-Control Scenarios at Class I Areas	4-12
5-1	Control Scenario Results for the Bridger Class 1 Wilderness Area	5-2
5-2	Control Scenario Results for the Fitzpatrick Class I Wilderness Area	5-3
5-3	Control Scenario Results for the Mt. Zirkel Class I Wilderness Area.....	5-3
5-4	Bridger Class I Wilderness Area Incremental Analysis Data	5-4
5-5	Fitzpatrick Class I Wilderness Area Incremental Analysis Data.....	5-4
5-6	Mt. Zirkel Class I Wilderness Area Incremental Analysis Data.....	5-4

Figures

3-1	Illustration of the Effect of Agglomeration on the Speed of Coal Combustion ..	3-3
3-2	Plot of Typical Nitrogen Content of Various Coals and Applicable Presumptive BART NO _x Limits	3-5
3-3	Plot of Typical Oxygen Content of Various Coals and Applicable Presumptive BART NO _x Limits	3-5
3-4	First Year Control Cost for NO _x Air Pollution Control Options.....	3-12
3-5	First Year Control Cost for PM Air Pollution Control Options.....	3-19
4-1	Extent of Modeling Domain.....	4-2
4-2	Surface and Upper Air Station Locations	4-5
5-1	Least Cost Envelope Bridger Class I WA Days Reduction	5-5
5-2	Least Cost Envelope Bridger WA Class I Area 98 th Percentile Reduction	5-5
5-3	Least Cost Envelope Fitzpatrick Class I WA Days Reduction.....	5-6
5-4	Least Cost Envelope Fitzpatrick Class I WA 98 th Percentile Reduction	5-6
5-5	Least Cost Envelope Mt. Zirkel Class I WA Days Reduction.....	5-7
5-6	Least Cost Envelope Mt. Zirkel Class I WA 98 th Percentile Reduction.....	5-7

Appendices

A	Economic Analysis
B	2006 Wyoming BART Protocol
C	Just-Noticeable Differences in Atmospheric Haze - Ronald C. Henry Report

Acronyms and Abbreviations

BACT	Best Available Control Technology
BART	Best Available Retrofit Technology
CALDESK	Program to display data and results
CALMET	Meteorological data preprocessing program for CALPUFF
CALPOST	Post-processing program for calculating visibility impacts
CALPUFF	Gaussian puff dispersion model
COHPAC	Compact Hybrid Particulate Collector
dV	deciview
Δ dV	delta deciview, change in deciview
DEQ	Department of Environmental Quality
ESP	electrostatic precipitator
EPA	United States Environmental Protection Agency
Fuel NO _x	oxidation of fuel bound nitrogen
FGC	flue gas conditioning
FGD	flue gas desulfurization
<i>f</i> (RH)	relative humidity factors
ID	internal diameter
kW	kilowatts
kW-Hr	kilowatt-hour
LAER	lowest achievable emission rate
lb/MMBtu	pounds per million British Thermal Units
LNB	low-NO _x burner
LOI	loss on ignition
MMBtu	Million British Thermal Units
MM5	Mesoscale Meteorological Model, Version 5
MW	megawatts
N ₂	nitrogen
NO	nitric oxide
NO _x	oxides of nitrogen
NWS	National Weather Service
OFA	over-fire air
PM ₁₀	particulate matter less than 10 microns in aerodynamic diameter

PRB	Powder River Basin
ROFA	Rotating Opposed Fire Air
S&L	Sargent & Lundy
SCR	selective catalytic reduction system
SIP	State Implementation Plan
SNCR	selective non-catalytic reduction system
SO ₂	sulfur dioxide
SO ₃	sulfur trioxide
Thermal NO _x	high temperature fixation of atmospheric nitrogen in combustion air
USGS	U.S. Geological Survey
WA	Wilderness Area
WDEQ-AQD	Wyoming Department of Environmental Quality – Air Quality Division

1.0 Introduction

Best Available Retrofit Technology (BART) guidelines were established as a result of United States Environmental Protection Agency (EPA) regulations intended to reduce the occurrence of regional haze in national parks and other Class I protected air quality areas in the United States¹. These guidelines provide guidance for states when determining which facilities must install additional controls, and the type of controls that must be used. Facilities eligible for BART installation were built between 1962 and 1977, and have the potential to emit more than 250 tons/year of visibility-impairing pollutants.

The Wyoming Department of Environmental Quality (DEQ) BART regulations state that each source subject to BART must submit a BART application for a construction permit by December 15, 2006. PacifiCorp received an extension from the Wyoming DEQ to submit the BART report for Jim Bridger Unit 2 by January 12, 2007. This report to the Wyoming DEQ must include a BART analysis, and a proposal and justification for BART at the source.

The State of Wyoming has identified those eligible in-state facilities that are required to reduce emissions under BART, and will set BART emissions limits for those facilities. This information will be included in the State of Wyoming State Implementation Plan (SIP), which the State has estimated will be formally submitted to the EPA by early 2008. The EPA BART guidelines also state that the BART emission limits must be fully implemented within five years of EPA's approval of the SIP.

There are five basic elements related to BART, when addressing the issue of emissions for the identified facilities:

- Any existing pollution control technology in use at the source
- The cost of the controls
- The remaining useful life of the source
- The energy and non-air environmental impacts of compliance
- The degree of improvement in visibility which may reasonably be anticipated from the use of such technology

This report documents the BART analysis that was performed on Jim Bridger 2 by CH2M HILL for PacifiCorp. The analysis was performed for the pollutants NO_x, SO₂, and particulate matter less than 10 microns in aerodynamic diameter (PM₁₀), because they are the primary criteria pollutants that affect visibility.

Section 2.0 of this report provides a description of the present unit operation, including a discussion of coal sources and characteristics. The BART Engineering Analysis is provided in Section 3.0, by pollutant type. Section 4.0 provides the methodology and results of the BART

¹ 40 CFR Part 51: Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations; Final Rule. 70 Federal Register, 39103-39172, July 6, 2005.

Modeling Analysis, followed by recommendations in Section 5.0. References are provided in Section 6.0. Appendices provide more detail on the Economic Analysis, the 2006 Wyoming BART Protocol, and a paper by Dr. Ronald Henry, titled, *Just Noticeable Differences in Atmospheric Haze*.

2.0 Present Unit Operation

The Jim Bridger Station consists of four units with a total generating capacity of 2,120 megawatts (MW). Jim Bridger 2 is a nominal 530 net MW unit located approximately 35 miles northeast of Rock Springs, Wyoming. Unit 2 is equipped with a tangentially fired pulverized coal boiler. LNB TFS 2000 low NOX burners with overfire air were installed in 2005. The unit was constructed with a Flakt wire frame electrostatic precipitator (ESP). The unit contains a Babcock & Wilcox wet sodium flue gas desulfurization (FGD) system with three absorber towers installed in 1986. An Emerson Ovation distributed control system (DCS) was installed in 2005.

Jim Bridger 2 was placed in service in 1975. Its current economic depreciation life is through 2040; however, this analysis is based on a 20 year life for BART control technologies. Assuming a BART implementation date of 2014, this will result in an approximate remaining useful life for Jim Bridger 2 of 20 years from the installation date of any new or modified BART-related equipment. This report does not attempt to quantify any additional life extension costs needed to allow the unit and these control devices at Jim Bridger 2 to operate until 2040.

Table 2-1 lists additional unit information and study assumptions for this analysis.

TABLE 2-1
Unit Operation and Study Assumptions
Jim Bridger 2

General Plant Data	
Site Elevation feet above MSL	6669
Stack Height feet	500
Stack Exit ID feet /Exit Area sq. ft.	24 /452.4
Stack Exit Temperature °F	140
Stack Exit Velocity ft/sec	84.0
Stack Flow ACFM	2,281,182
Latitude deg: min : sec	41:44:16.42 north
Longitude deg: min : sec	108:47:10.59 west
Annual Unit Capacity Factor (%)	90
Net Unit Output (MW)	530
Net Unit Heat Rate (Btu/kW-Hr)(100% load)	10,400 (as measured by fuel throughput)
Boiler Heat Input (MMBtu/Hr)(100% load)	6,000 (as measured by CEM)
Type of Boiler	Tangentially fired
Boiler Fuel	Coal
Coal Sources	Bridger Mine, Black Butte Mine, Leucite Hills Mine
Coal Heating Value (Btu/lb)*	9,660
Coal Sulfur Content (wt. %)*	0.58
Coal Ash Content (wt. %)*	10.3

TABLE 2-1
Unit Operation and Study Assumptions
Jim Bridger 2

Coal Moisture Content (wt. %)*	19.3
Coal Nitrogen Content (wt. %)*	0.98
Current NO _x Controls	Low NO _x burners
NO _x Emission Rate (lb/MMBtu)	0.24
Current SO ₂ Controls	Sodium based wet scrubber
SO ₂ Emission Rate (lb/MMBtu)	0.3
Current PM ₁₀ Controls	Electrostatic Precipitator
PM ₁₀ Emission Rate (lb/MMBtu)**	0.074

* Coal characteristics based on Bridger Underground Mine (primary coal source)

** Based on maximum historic emission rate from 1999 – 2001, prior to installation of the SO₃ injection system.

The BART presumptive NO_x limit for tangential-fired boilers burning subbituminous coal is 0.15 lb/MMBtu and the BART presumptive NO_x limit for burning bituminous coal is 0.28 lb/MMBtu. The main sources of coal burned at Jim Bridger 2 are the Bridger Mine, and secondarily the Black Butte Mine and Leucite Hills Mine. These coals are ranked as subbituminous, but are closer in characteristics to bituminous coal in many of the parameters influencing NO_x formation. These coals have higher nitrogen content than coals from the Powder River Basin (PRB), which represent the bulk of subbituminous coal used in the U.S. This BART analysis has considered the higher nitrogen content and different combustion characteristics of PRB coals, as compared to those coals used at Jim Bridger 2, and has evaluated the effect of these qualities on NO_x formation and achievable emission rates. Coal sources and characteristics are summarized in Table 2-2. The primary source of coal will be the Bridger Underground Mine, and data on coal from this source were used in the modeling analysis. For the coal analysis that is presented in Section 3.2.1, the data from all the coal sources were used.

TABLE 2-2
Coal Sources and Characteristics
Jim Bridger 2

Mines	Moist. %	Ash %	Volatile Matter %	Fixed Carbon %	Btu/lb	Sulfur %	MAF (Btu/lb)	Ultimate Analysis (% dry basis)						
								Hydrogen	Carbon	Sulfur	Nitrogen	Oxygen	Ash	
Bridger Mine Underground	19.3	10.3	32.2	38.3	9660	0.58	13712	4.66	69.2	0.72	1.22	11.8	12.4	
Max	Not enough data yet to run statistical analysis for variability													
Min	Not enough data yet to run statistical analysis for variability													
Bridger Mine Surface	19.1	10.6	32.3	38.0	9390	0.57	13340	4.38	37.4	0.71	1.26	13.2	13.0	
Max	20.5	12.5	35.5	41.9	9800	0.72	13500	4.69	4.0	0.90	1.43	14.8	15.8	
Min	17.5	9.0	31.0	36.0	9000	0.49	13100	4.00	64.3	0.60	1.14	11.7	11.2	
Bridger Mine Highwall	18.0	9.5	33.0	39.5	9700	0.58	13500	No samples of separate highwall coal						
Max	Not enough data yet to run statistical analysis for variability													
Min	Not enough data yet to run statistical analysis for variability													
Black Butte Mine	20.0	9.2	33.3	35.6	9450	0.45	13330	4.43	68.7	0.56	1.47	13.4	11.5	
Max	21.1	10.8	35.4	41.9	10275	0.62	13500	4.66	70.5	0.78	1.69	14.8	13.6	
Min	18.0	7.6	29.9	36.8	9180	0.33	13140	4.21	66.1	0.41	1.25	11.6	9.7	
Leucite Hills Mine (through 2009)	19.4	11.5	30.7	38.3	9080	0.64	13140	4.20	66.0	0.81	1.48	13.2	14.4	
Max	23.0	15.0	33.0	43.0	10250	0.90	13800	4.70	70.0	1.20	1.64	17.1	19.0	
Min	17.0	8.0	28.3	33.6	8000	0.40	12300	3.70	61.0	0.50	1.32	10.5	10.0	

3.0 BART Engineering Analysis

This section presents the required BART engineering analysis.

3.1 Applicability

In compliance with regional haze requirements, the State of Wyoming must prepare and submit visibility SIPs to the EPA for Class I areas. The State has estimated that the formal submittal of the SIPs will occur by early 2008. The first phase of the regional haze program is the implementation of BART emission controls on all BART eligible units, within five years after EPA approval of the SIP.

3.2 BART Process

The specific steps in a BART engineering analysis are identified in the Code of Federal Regulations (CFR) at 40 CFR 51 Appendix Y, Section IV. The evaluation must include:

1. The identification of available, technically feasible, retrofit control options,
2. Consideration of any pollution control equipment in use at the source (which affects the availability of options and their impacts),
3. The costs of compliance with the control options,
4. The remaining useful life of the facility,
5. The energy and non-air quality environmental impacts of compliance, and
6. The degree of visibility improvement which may reasonably be anticipated from the use of BART.

These steps are incorporated into the BART analysis as follows:

Step 1 – Identify All Available Retrofit Control Technologies

Step 2 – Eliminate Technically Infeasible Options

- The identification of available, technically feasible, retrofit control options
- Consideration of any pollution control equipment in use at the source (which affects the applicability of options and their impacts)

Step 3 – Evaluate Control Effectiveness of Remaining Control Technologies

Step 4 – Evaluate Impacts and Document the Results

- The costs of compliance with the control options
- The remaining useful life of the facility
- The energy and non-air quality environmental impacts of compliance

Step 5 – Evaluate Visibility Impacts

- The degree of visibility improvement which may reasonably be anticipated from the use of BART

In order to minimize costs in the BART analysis, consideration was made of any pollution control equipment in use at the source, the costs of compliance associated with the control options, and the energy and non-air quality environmental impacts of compliance using these existing control devices. In some cases, enhancing the performance of the existing control equipment was considered. Other scenarios with new control equipment were also developed.

Separate analyses have been conducted for NO_x, SO₂, and PM₁₀ emissions. All costs included in the BART analyses are in 2006 dollars, and costs have not been escalated to the assumed 2014 BART implementation date.

3.2.1 BART NO_x Analysis

NO_x formation in coal-fired boilers is a complex process that is dependent on a number of variables, including operating conditions, equipment design, and coal characteristics.

3.2.1.1 Formation of NO_x

During coal combustion, NO_x is formed in three different ways. The dominant source of NO_x formation is the oxidation of fuel-bound nitrogen (fuel NO_x). During combustion, part of the fuel-bound nitrogen is released from the coal with the volatile matter, and part is retained in the solid portion (char). The nitrogen chemically bound in the coal is partially oxidized to nitrogen oxides (NO and NO₂) and partially reduced to molecular nitrogen (N₂). A smaller part of NO_x formation is due to high temperature fixation of atmospheric nitrogen in the combustion air (thermal NO_x). A very small amount of NO_x is called “prompt” NO_x. Prompt NO_x results from an interaction of hydrocarbon radicals, nitrogen, and oxygen.

In a conventional pulverized coal burner, air is introduced with turbulence to promote good mixing of fuel and air, which provides stable combustion. However, not all of the oxygen in the air is used for combustion. Some of the oxygen combines with the fuel nitrogen to form NO_x.

Coal characteristics directly and significantly affect NO_x emissions from coal combustion. Coal ranking is a means of classifying coals according to their degree of metamorphism in the natural series, from lignite to subbituminous to bituminous and on to anthracite. Lower rank coals, such as the subbituminous coals from the PRB, produce lower NO_x emissions than higher rank bituminous coals, due to their higher reactivity and lower nitrogen content. The fixed carbon to volatile matter ratio (fuel ratio), coal oxygen content, and rank are good relative indices of the reactivity of a coal. Lower rank coals release more organically bound nitrogen earlier in the combustion process than do higher rank bituminous coals. When used with low NO_x burners, subbituminous coals create a longer time for the kinetics to promote more stable molecular nitrogen, and hence result in lower NO_x emissions.

Coals from the PRB are classified as subbituminous C and demonstrate the high reactivity and low NO_x production characteristics described above. Based on data from the Energy Information Administration (EIA), PRB coals currently represent 88 percent of total U.S. subbituminous production and 73 percent of western coal production. Most references to “western” coal and subbituminous coal infer PRB origin and characteristics. Emissions

standards differentiating between bituminous and subbituminous coals are presumed to use PRB coal as the basis for the subbituminous standards, due to their dominant market presence and unique characteristics.

There are a number of western coals that are classified as subbituminous, however, they border on being ranked as bituminous and do not display many of the qualities of PRB coals, including most of the low NO_x forming characteristics. Coals from the Bridger, Black Butte, and Leucite Hills mines fall into this category.

As defined by the American Society for Testing and Materials, the only distinguishing characteristic that classifies the coals used at Jim Bridger 2 as subbituminous rather than bituminous – that is, they are “agglomerating” as compared to “non-agglomerating”. Agglomerating as applied to coal is “the property of softening when it is heated to above about 400°C in a non-oxidizing atmosphere, and then appearing as a coherent mass after cooling to room temperature.” Because the agglomerating property of coals is the result of particles transforming into a plastic or semi-liquid state when heated, it reflects a change in surface area of the particle. Thus, with the application of heat, agglomerating coals would tend to develop a non-porous surface, while the surface of non-agglomerating coals would become even more porous with combustion. As shown by Figure 3-1, the increased porosity provides more particle surface area, resulting in more favorable combustion conditions. This non-agglomerating property assists in making subbituminous coals more amenable to controlling NO_x by allowing less air to be introduced during the initial ignition portion of the combustion process. The coals from the Bridger, Black Butte and Leucite Hills mines just barely fall into the category of non-agglomerating coals. While each of these coals is considered non-agglomerating, they either do not exhibit those properties of non-agglomerating coals or exhibit them to only a minor degree. The conditions during combustion of typical non-agglomerating coals that make it easier to control NO_x emissions do not exist during combustion of the Bridger blends of coals.

FIGURE 3-1
Illustration of the Effect of Agglomeration on the Speed of Coal Combustion
Jim Bridger 2




Table 3-1 shows key characteristics of a typical PRB coal, compared to coals from the Bridger Mine, Black Butte, and Leucite Hills, as well as coal from Twentymile, which is a representative western bituminous coal.

TABLE 3-1
Coal Characteristics Comparison
Jim Bridger 2

Parameter	Typical PRB	Bridger Mine	Black Butte	Leucite Hills	Twentymile
Nitrogen (% dry)	1.10	1.26	1.47	1.48	1.85
Oxygen (% dry)	16.2	13.2	13.4	13.2	7.19
Coal rank	Sub C	Sub B	Sub B	Sub B	Bitum. high volatility B

As shown in Table 3-1, although Bridger, Black Butte, and Leucite Hills are classified as subbituminous, they all exhibit higher nitrogen content and lower oxygen content than the PRB coal. The higher nitrogen content is an indication that more nitrogen is available to the combustion process and higher NO_x emissions are likely. Oxygen content can be correlated to the reactivity of the coal, with more reactive coals generally containing higher levels of oxygen. More reactive coals tend to produce lower NO_x emissions, and they are also more conducive to reduction of NO_x emissions through the use of combustion control measures, such as low NO_x burners and over-fire air (OFA). These characteristics indicate that higher NO_x formation is likely with coal from the Bridger, Black Butte, and Leucite Hills mines, rather than with PRB coal. The Bridger, Black Butte, and Leucite Hills coals all contain quality characteristics that fall between a typical PRB coal and Twentymile. Twentymile is a clearly bituminous coal that produces higher NO_x, as has been demonstrated at power plants burning this fuel.

Figures 3-2 and 3-3 graphically illustrate the relationship of nitrogen and oxygen content to the BART presumptive NO_x limits for the coals listed in Table 3-1. Each chart identifies the presumptive BART limit associated with a typical bituminous and subbituminous coal, and demonstrates how the Jim Bridger coal falls between these two general coal classifications.

The Bridger blend data point represents a combination of coals from the Bridger Mine, Black Butte, and Leucite Hills that has been used at Jim Bridger 2, and indicates the average NO_x emission rate achieved during the years 2003-2005. The Jim Bridger 2 data point represents the NO_x emission rate achieved after installation of Alstom's current state of the art TFS2000 LNB and OFA System. The long-term sustainable emission rate for this system is expected to be 0.24 lb/MMBtu.

Figures 3-2 and 3-3 both demonstrate that for the Jim Bridger units with the TFS2000 low NO_x emission system installed and burning a combination of the Bridger, Black Butte, and Leucite Hill coals, the likely NO_x emission rate will be closer to the bituminous end (0.28) of the BART presumptive NO_x limit range, rather than the BART presumptive NO_x limit of 0.15 lb/MMBtu for subbituminous coal. All these factors are consistent with the observed sustainable rate of 0.24 lb/MMBtu.

FIGURE 3-2
 Plot of Typical Nitrogen Content of Various Coals and Applicable Presumptive BART NO_x Limits
 Jim Bridger 2





FIGURE 3-3
 Plot of Typical Oxygen Content of Various Coals and Applicable Presumptive BART NO_x Limits
 Jim Bridger 2



Coal quality characteristics also impact the design and operation of the boiler and associated auxiliary equipment. Minor changes in quality can sometimes be accommodated through operational adjustments or changes to equipment. It is important to note, however, that consistent variations in quality or assumptions of “average” quality for performance projections can be problematic. This is particularly troublesome when dealing with performance issues that are very sensitive to both coal quality and combustion conditions, such as NO_x formation. There is significant variability in the quality of coals burned at Jim Bridger 2. In addition to

burning coal from Black Butte and Leucite Hills, Jim Bridger 2 burns coal supplied from the Bridger Mine consisting of three sources: underground, surface, and highwall operations. Each of these coal sources has different quality characteristics, as well as inherent variability in the composition of coal within the mine.

Several of the coal quality characteristics and their effect on NO_x formation have been previously discussed. There are some additional considerations that illustrate the complexity of achieving and maintaining consistent low NO_x emissions with pulverized coal on a shorter term, such as a 30-day rolling average basis.

Good combustion is based on the “three Ts”: time, temperature, and turbulence. These parameters, along with a “design” coal, are taken into consideration when designing a boiler and associated firing equipment such as fans, burners, and pulverizers. If a performance requirement such as NO_x emission limits is subsequently changed, conflicts with and between other performance issues can result.

Jim Bridger 2 is located at an altitude of 6,669 feet above sea level. At this elevation, atmospheric pressure is lower (11.5 pounds per square inch) as compared with sea level pressure of 14.7 pounds per square inch. This lower pressure means that less oxygen is available for combustion for each volume of air. In order to provide adequate oxygen to meet the requirements for efficient combustion, larger volumes of air are required. When adjusting air flows and distribution to reduce NO_x emissions, using low NO_x burners and overfire air, original boiler design restrictions again limit the modifications that can be made and still achieve satisfactory combustion performance.

Another significant factor in controlling NO_x emissions is the fineness of the coal entering the burners. Fineness is influenced by the grindability index (Hardgrove) of the coal. Finer coal particles promote release of volatiles and assist char burnout due to more surface area exposed to air. NO_x reduction with high volatile coals is improved with greater fineness and with proper air staging. The lower rank subbituminous coals such as PRB coals are quite friable and easy to grind. Coals with lower Hardgrove Grindability Index values, such as those used at Jim Bridger 2, are more difficult to grind and can contribute to higher NO_x levels. In addition, coal fineness can deteriorate over time periods between pulverizer maintenance and service, as pulverizer grinding surfaces undergo wear.

In summary, when all the factors of agglomeration versus non-agglomeration, nitrogen and oxygen content of the coals, and the grindability index are taken into account, this analysis demonstrates that for the coal used at Jim Bridger 2, the more applicable presumptive BART limit for NO_x emissions is 0.28 lb/MMBtu. The BART analysis for NO_x emissions from Jim Bridger 2 is further described below.

3.2.1.2 Step 1: Identify All Available Retrofit Control Technologies

The first step of the BART process is to evaluate NO_x control technologies with practical potential for application to Jim Bridger 2, including those control technologies identified as Best Available Control Technology (BACT) or lowest achievable emission rate (LAER) by permitting agencies across the United States. A broad range of information sources have been reviewed in an effort to identify potentially applicable emission control technologies. NO_x

emissions at Jim Bridger 2 are currently controlled through the use of good combustion practices and OFA.

The following potential NO_x control technology options were considered:

- New/modified low-NO_x burners (LNB) with advanced OFA
- rotating opposed fire air (ROFA)
- LNB with OFA and conventional selective non-catalytic reduction system (SNCR)
- LNB with OFA and selective catalytic reduction system (SCR)

3.2.1.3 Step 2: Eliminate Technically Infeasible Options

For Jim Bridger 2, a tangential-fired configuration burning subbituminous coal, technical feasibility will primarily be determined by physical constraints, boiler configuration, and the ability to achieve the regulatory presumptive limit (used as a guide) of 0.28 lb NO_x/MMBtu. Jim Bridger 2 has an uncontrolled NO_x emission rate of 0.45 lb/MMBtu.

For this BART analysis, information pertaining to LNBS, OFA, SNCR, and SCR were based on the Multi-Pollutant Control Report dated October, 2002 (S&L Study). The cost estimates for SCR and SNCR were updated by Sargent & Lundy (S&L) in October 2006. PacifiCorp provided additional emissions data and costs developed by boiler vendors for LNBS and OFA. Also, CH2M HILL solicited a proposal from Mobotec for their ROFA technology.

With SNCR, an amine-based reagent such as ammonia, or more commonly urea, is injected into the furnace within a temperature range of 1,600° F to 2,100° F, where it reduces NO_x to nitrogen and water. NO_x reductions of up to 40 to 60 percent have been achieved, although 15 to 30 percent is more realistic for most applications. SNCR is typically applied on smaller units.

Table 3-2 summarizes the control technology options evaluated in this BART analysis, along with projected NO_x emission rates. All of the evaluated technologies are projected to meet the applicable presumptive BART limit of 0.28 lb/MMBtu.

TABLE 3-2
NO_x Control Technology Projected Emission Rates
Jim Bridger 2

Technology	Projected Emission Rate (lb/MMBtu)
Presumptive BART Limit	0.28
LNB w/OFA	0.24
ROFA	0.22
LNB w/OFA & SNCR	0.20
LNB w/OFA & SCR	0.07

3.2.1.4 Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

Preliminary vendor proposals, such as those used to support portions of this BART analysis, may be technically feasible and provide expected or guaranteed emission rates; however, they include inherent uncertainties. These proposals are usually prepared in a limited time frame, may be based on incomplete information, may contain over-optimistic conclusions, and are non-binding. Therefore, emission rate values obtained in such preliminary proposals must be qualified, and it must be recognized that contractual guarantees are established only after more detailed analysis has been completed. The following subsections describe the control technologies and the control effectiveness evaluated in this BART analysis.

LNBs with OFA System. The mechanism used to lower NO_x with low NO_x burners is to stage the combustion process and provide a fuel rich condition initially; this is so oxygen needed for combustion is not diverted to combine with nitrogen and form NO_x. Fuel-rich conditions favor the conversion of fuel nitrogen to N₂ instead of NO_x. Additional air (or OFA) is then introduced downstream in a lower temperature zone to burn out the char.

Both LNBs and OFA are considered to be a capital cost, combustion technology retrofit. For LNB retrofits to units configured with tangential-firing such as Jim Bridger 2, it is generally necessary to increase the burner spacing; this prevents interaction of the flames from adjacent burners and reduces burner zone heat flux. These modifications usually require boiler waterwall tube replacement. However, Jim Bridger 2 has already been modified with the installation of a TFS-2000 LNB w/OFA system.

Information provided to CH2M HILL by PacifiCorp, based on the S&L Study and data from boiler vendors, indicates that the existing TFS-2000 LNB w/and OFA system at Jim Bridger 2 could be more finely tuned to result in an expected NO_x emission rate of 0.24 lb/MMBtu. PacifiCorp has indicated that this rate corresponds to a vendor guarantee, not a vendor prediction, and they believe that this emission rate can be sustained as an average between overhauls. This emission rate represents a significant reduction from the current NO_x emission rate, and is below the more applicable presumptive NO_x emission rate of 0.28 lb/MMBtu.

ROFA. Mobotec markets ROFA as an improved second generation OFA system. Mobotec states that "the flue gas volume of the furnace is set in rotation by asymmetrically placed air nozzles. Rotation is reported to prevent laminar flow, so that the entire volume of the furnace can be used more effectively for the combustion process. In addition, the swirling action reduces the maximum temperature of the flames and increases heat absorption. The combustion air is also mixed more effectively". A typical ROFA installation would have a booster fan(s) to supply the high velocity air to the ROFA boxes, and Mobotec would propose two 4,000 to 4,300 Hp fans for Jim Bridger 2.

Mobotec proposes to achieve a NO_x emission rate of 0.18 lb/MMBtu using ROFA technology. An operating margin of 0.04 lb/MMBtu was added to the expected rate due to Mobotec's limited ROFA experience with western subbituminous coals. Under the Mobotec proposal, which is primarily based on ROFA equipment, the operation of existing LNB and OFA ports would be analyzed. While a typical installation does not require modification to the existing LNB system and the existing OFA ports are not used, results of computational fluid dynamics modeling would determine the quantity and location of new ROFA ports. The Mobotec proposal includes bent tube assemblies for OFA port installation.

Mobotec would not provide installation services, because they believe that the Owner can more cost effectively contract for these services. However, they would provide one onsite construction supervisor during installation and startup.

SNCR. Selective non-catalytic reduction is generally utilized to achieve modest NO_x reductions on smaller units. With SNCR, an amine-based reagent such as ammonia, or more commonly urea, is injected into the furnace within a temperature range of 1,600°F to 2,100°F, where it reduces NO_x to nitrogen and water. NO_x reductions of up to 60 percent have been achieved, although 20 to 40 percent is more realistic for most applications.

Reagent utilization, which is a measure of the efficiency with which the reagent reduces NO_x, can range from 20 to 60 percent, depending on the amount of reduction, unit size, operating conditions, and allowable ammonia slip. With low reagent utilization, low temperatures, or inadequate mixing, ammonia slip occurs, allowing unreacted ammonia to create problems downstream. The ammonia may render fly ash unsaleable, react with sulfur to foul heat exchange surfaces, and/or create a visible stack plume. Reagent utilization can have a significant impact on economics, with higher levels of NO_x reduction generally resulting in lower reagent utilization and higher operating cost.

Reductions from higher baseline concentrations (inlet NO_x) are lower in cost per ton, but result in higher operating costs, due to greater reagent consumption. Unit 2 has already had combustion modifications including LNBs and advanced OFA, capable of achieving a projected NO_x emission rate of 0.24 lb/MMBtu. At a further reduction of 15 percent in NO_x emission rates for SNCR would result in a projected emission rate of 0.20 lb/MMBtu.

SCR. SCR works on the same chemical principle as SNCR, but SCR uses a catalyst to promote the chemical reaction. Ammonia is injected into the flue-gas stream, where it reduces NO_x to nitrogen and water. Unlike the high temperatures required for SNCR, in SCR the reaction takes place on the surface of a vanadium/titanium-based catalyst at a temperature range between 580° F to 750° F. Due to the catalyst, the SCR process is more efficient than SNCR and results in lower NO_x emissions. The most common type of SCR is the high-dust configuration, where the catalyst is located downstream from the boiler economizer, and upstream of the air heater and any particulate control equipment. In this location, the SCR is exposed to the full concentration of fly ash in the flue gas that is leaving the boiler. The high-dust configuration is assumed for Jim Bridger 2.

In a full-scale SCR, the flue ducts are routed to a separate large reactor containing the catalyst. With in-duct SCR, the catalyst is located in the existing gas duct, which may be expanded in the area of the catalyst to reduce flue gas flow velocity and increase flue gas residence time. Due to the higher removal rate, a full-scale SCR was used as the basis for analysis at Jim Bridger 2.

S&L prepared the design conditions and cost estimates for SCR at Jim Bridger 2. Unit 2 has already had combustion modifications including LNBs and advanced OFA, capable of achieving a projected NO_x emission rate of 0.24 lb/MMBtu. The S&L design basis for LNB w/OFA and SCR results in a projected NO_x emission rate of 0.07 lb/MMBtu. Additional catalyst surface was included in the SCR design to accommodate the characteristics of the coal used at Jim Bridger 2.

Level of Confidence for Vendor Post-Control Emissions Estimates. In order to determine the level of NO_x emissions needed to consistently achieve compliance with an established goal, a review of typical NO_x emissions from coal-fired generating units was completed. As a result of this review, it was noted that NO_x emissions can vary significantly around an average emissions level. Variations may result for many reasons, including coal characteristics, unit load, boiler operation including excess air, boiler slagging, burner equipment condition, coal mill fineness, and so forth.

The steps utilized for determining a level of confidence for the vendor expected values are as follows:

1. Establish expected NO_x emissions value from vendor.
2. Evaluate vendor experience and historical basis for meeting expected values.
3. Review and evaluate unit physical and operational characteristics and restrictions. The fewer variations there are in operations, coal supply, etc., the more predictable and less variant the NO_x emissions are.
4. For each technology expected value, there is a corresponding potential for actual NO_x emissions to vary from this expected value. From the vendor information presented, along with anticipated unit operational data, an adjustment to the expected value can be made.

3.2.1.5 Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

Energy Impacts. Installation of LNBS and modification to the existing OFA systems are not expected to significantly impact the boiler efficiency or forced draft fan power usage. Therefore, these technologies will not have energy impacts.

The Mobotec ROFA system would require installation and operation of two 4,000 to 4,300 Hp ROFA fans (6,410 kW total). The SNCR system would require approximately 530 kW of additional power.

SCR retrofit impacts the existing flue gas fan systems, due to the additional pressure drop associated with the catalyst, which is typically a 6- to 8-inch water gage increase. Total additional power requirements for SCR installation at Jim Bridger 2 are estimated at approximately 3,250 kW, based on the S&L Study.

Environmental Impacts. Mobotec has predicted that CO emissions, and unburned carbon in the ash, commonly referred to as LOI (loss on ignition), would be the same or lower than prior levels for the ROFA system.

SNCR and SCR installation could impact the salability and disposal of fly ash due to ammonia levels, and could potentially create a visible stack plume, which may negate other visibility improvements. Other environmental impacts involve the storage of ammonia, especially if anhydrous ammonia is used, and the transportation of the ammonia to the power plant site.

Economic Impacts. Costs and schedules for the LNBs and OFA, SNCR, and SCR were furnished to CH2M HILL by PacifiCorp, developed using S&L's internal proprietary database, and supplemented (as needed) by vendor-obtained price quotes. The relative accuracy of these cost estimates is stated by S&L to be in the range of ± 20 percent. Cost for the ROFA system was obtained from Mobotec.

A comparison of the technologies on the basis of costs, design control efficiencies, and tons of NO_x removed is summarized in Table 3-3, and the first year control costs are presented in Figure 3-4. The complete Economic Analysis is contained in Appendix A.

TABLE 3-3
NO_x Control Cost Comparison
Jim Bridger 2


Factor	LNB w/OFA (Existing)	ROFA	SNCR	SCR
Total Installed Capital Costs	\$0	\$20.5 Million	13.4 Million	\$120.9 Million
Total First Year Fixed & Variable O&M Costs	\$0	\$2.6 Million	\$1.0 Million	\$3.2 Million
Total First Year Annualized Cost	\$0	\$4.6 Million	\$2.3 Million	\$14.7 Million
Power Consumption (MW)	0	6.4	0.5	3.3
Annual Power Usage (1000 MW-Hr/Yr)	0	50.6	4.2	25.6
NO _x Design Control Efficiency	0.0%	8.3%	16.7%	70.8%
NO _x Removed per Year (Tons)	0	473	946	4,021
First Year Average Control Cost (\$/Ton of NO _x Removed)	\$0/ton	\$9,695/ton	\$2,389/ton	\$3,654/ton
Incremental Control Cost (\$/Ton of NO _x Removed)	\$0/ton	\$9,695/ton	\$2,389/ton	\$4,044/ton

Preliminary BART Selection. CH2M HILL recommends selection of the existing low-NO_x burners with OFA as BART for Jim Bridger 2, based on the projected significant reduction in NO_x emissions, reasonable control costs, and the advantages of no additional power requirements or non-air quality environmental impacts. LNB w/OFA does not meet the EPA presumptive limit of 0.15 lb/MMBtu for subbituminous coal, but it does meet an emission rate that falls between the presumptive limit of 0.28 lb/MMBtu for bituminous coal and the limit of 0.15 lb/MMBtu for subbituminous coal. As discussed in the section on coal quality, the recommended technology and the achieved emission rate are deemed appropriate as BART for NO_x emissions from the coals combusted at Jim Bridger 2.

3.2.1.6 Step 5: Evaluate Visibility Impacts

Please see Section 4.0, BART Modeling Analysis.

FIGURE 3-4
 First Year Control Cost for NOx Air Pollution Control Options
 Jim Bridger 2



3.2.2 BART SO₂ Analysis

SO₂ forms in the boiler during the combustion process, and is primarily dependent on coal sulfur content. The BART analysis for SO₂ emissions on Jim Bridger 2 is described below.

3.2.2.1 Step 1: Identify All Available Retrofit Control Technologies

A broad range of information sources were reviewed, in an effort to identify potentially applicable emission control technologies for SO₂ at Jim Bridger 2. This included control technologies identified as BACT or LAER by permitting agencies across the United States.

The following potential SO₂ control technology options were considered:

- Optimize current operation of existing wet sodium FGD system
- Upgrade wet sodium FGD system to meet SO₂ emission rate of 0.10 lb/MMBtu
- New dry FGD system

3.2.2.2 Step 2: Eliminate Technically Infeasible Options

Technical feasibility will primarily be based on the regulatory presumptive limit (used as a guideline) of 95 percent reduction in SO₂ emissions, or 0.15 lb/MMBtu. Based on the coal that Jim Bridger 2 currently burns, the unit would be required to achieve an 87.5 percent SO₂ removal efficiency to meet the presumptive limit of 0.15 lb/MMBtu.

Table 3-4 summarizes the control technology options evaluated in this BART analysis, along with projected SO₂ emission rates. Only one technology option can meet the applicable presumptive BART limit of 0.15 lb/MMBtu.

TABLE 3-4
SO₂ Control Technology Emission Rates
Jim Bridger 2

Technology	Projected Emission Rate (lb/MMBtu)
Presumptive BART Limit	0.15
Upgrade Existing Wet Sodium System	0.10
Optimize Existing Wet Sodium System	0.20
New Dry FGD System	0.21

Wet Sodium FGD System. Wet sodium FGD systems operate by treating the flue gas in large scrubber vessels with a soda ash solution. The scrubber mixes the flue gas and alkaline reagent using a series of spray nozzles to distribute the reagent across the scrubber vessel. The sodium in the reagent reacts with the SO₂ in the flue gas to form sodium sulfite and sodium bisulfite, which are removed from the scrubber and disposed.

The wet sodium FGD system at Jim Bridger 2 currently achieves approximately 78 percent SO₂ removal to achieve an SO₂ outlet emission rate of 0.27 lb/MMBtu. Optimizing the existing wet FGD system is projected to achieve an SO₂ outlet emission rate of 0.20 lb/MMBtu (83.3 percent SO₂ removal). Optimization would be accomplished by partially closing the

bypass damper to reduce the routine bypass flue gas flow used to reheat the treated flue gas from the scrubber, relocating the opacity monitor, and modifying the system to minimize scaling problems.

Upgrading the wet FGD system is projected to achieve an SO₂ outlet emission rate of 0.10 lb/MMBtu (91.7 percent SO₂ removal). Upgrading the system would involve closing the bypass damper to eliminate the routine bypass flue gas flow used to reheat the treated flue gas from the scrubber, relocating the opacity monitor, adding new fans, adding a stack liner and drains for wet operation, and using a refined soda ash reagent. It is considered to be technically infeasible for the present wet FGD system to achieve a 95 percent SO₂ removal rate (0.06 lb/MMBtu) on a continuous basis since this high level of removal must be incorporated into the original design of the scrubber.

Optimizing the existing wet sodium scrubbing FGD system is projected to achieve an outlet emission rate of 0.20 lb/MMBtu, which would not meet the presumptive limit of 0.15 lb SO₂/MMBtu. Therefore, this option is eliminated as technically infeasible for this analysis. An upgraded wet sodium scrubbing FGD system is projected to achieve an outlet emission rate of 0.10 lb/MMBtu (91.7 percent SO₂ removal), which would meet the presumptive limit of 0.15 lb SO₂/MMBtu for Jim Bridger 2.

New Dry FGD System. The lime spray dryer typically injects lime slurry in the top of the absorber vessel with a rapidly rotating atomizer wheel. The rapid speed of the atomizer wheel causes the lime slurry to separate into very fine droplets that intermix with the flue gas. The SO₂ in the flue gas reacts with the calcium in the lime slurry to form dry calcium sulfate particles. At Jim Bridger 2 this dry particulate matter would be captured downstream in the existing ESP, along with the fly ash. A lime spray dryer system typically produces a dry waste product suitable for landfill disposal.

The dry FGD system with the existing ESP is projected to achieve 82.5 percent SO₂ removal at Jim Bridger 2. This would result in a controlled SO₂ emission rate of 0.21 lb/MMBtu, based on an uncontrolled SO₂ emission rate of 1.20 lb/MMBtu. Therefore, this option cannot meet the presumptive limit of 0.15 lb SO₂/MMBtu, and is eliminated from further analysis as technically infeasible.

3.2.2.3 Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

When evaluating the control effectiveness of SO₂ reduction technologies, each option can be compared against benchmarks of performance. One such benchmark is the presumptive BART emission limit, because Jim Bridger 2 is required to meet this limit. As indicated previously, the presumptive limit for SO₂ on a BART-eligible coal burning unit is 95 percent removal, or 0.15 lb/MMBtu.

The projected emission rate for an upgraded wet sodium FGD system for Bridger 2 would be 0.10 lb/MMBtu. This option would meet the presumptive SO₂ limit of 0.15 lb/MMBtu.

3.2.2.4 Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

Energy Impacts. Upgrading the existing wet sodium FGD system would require an additional 530 kW of power.

Environmental Impacts. There will be incremental additions to scrubber waste disposal and makeup water requirements, and a reduction of the stack gas temperature from 140°F to 120°F, due to elimination of reheating by the bypassed flue gas.

Economic Impacts. A summary of the costs and amount of SO₂ removed for the upgraded wet sodium FGD system is provided in Table 3-5. The complete Economic Analysis is contained in Appendix A.

TABLE 3-5
SO₂ Control Cost Comparison (Incremental to Existing Wet FGD System)
Jim Bridger 2

Factor	Upgraded Wet FGD
Total Installed Capital Costs	\$13.0 Million
Total First Year Fixed & Variable O&M Costs	\$1.3 Million
Total First Year Annualized Cost	\$2.5 Million
Additional Power Consumption (MW)	0.5
Additional Annual Power Usage (1000 MW-Hr/Yr)	4.2
Incremental SO ₂ Design Control Efficiency	62.5% (91.7% based on Uncontrolled SO ₂)
Incremental Tons SO ₂ Removed per Year	3,950
First Year Average Control Cost (\$/Ton of SO ₂ Removed)	632
Incremental Control Cost (\$/Ton of SO ₂ Removed)	632

Preliminary BART Selection. CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 2, based on significant reduction in SO₂ emissions (meeting presumptive limit of 0.15 lb/MMBtu), reasonable control costs, and the advantages of minimal additional power requirements and environmental impacts.

3.2.2.5 Step 5: Evaluate Visibility Impacts

Please see Section 4.0, BART Modeling Analysis.

3.2.3 BART PM₁₀ Analysis

Jim Bridger 2 is currently equipped with an electrostatic precipitator (ESP). ESPs remove particulate matter from the flue gas stream by charging fly ash particles with a very high direct current voltage, and attracting these charged particles to grounded collection plates. A layer of collected particulate matter forms on the collecting plates and is removed by periodically rapping the plates. The collected ash particles drop into hoppers below the precipitator and are removed periodically by the fly ash-handling system. Historically, the ESP at Jim Bridger 2 has controlled PM₁₀ emissions to levels below 0.074 lb/MMBtu.

The BART analysis for PM₁₀ emissions at Jim Bridger 2 is described below. For the modeling analysis in Section 4.0, PM₁₀ was used as an indicator for PM, and PM₁₀ includes PM_{2.5} as a subset.

3.2.3.1 Step 1: Identify All Available Retrofit Control Technologies

Two retrofit control technologies have been identified for additional PM control:

- Flue gas conditioning
- Polishing fabric filter (baghouse) downstream of Existing ESP

Another available control technology is replacing the existing ESP with a new fabric filter. However, because the environmental benefits that would be achieved by a replacement fabric filter are also achieved by installing a polishing fabric filter downstream of the existing ESP at lower costs, installation of a full fabric filter was not considered in the analysis.

3.2.3.2 Step 2: Eliminate Technically Infeasible Options

Flue Gas Conditioning. If the fly ash from coal has high resistivity, such as fly ash from subbituminous coal, the ash is not collected effectively in an ESP. This is because the high resistivity makes the particles less willing to accept an electrical charge. Adding flue gas conditioning (FGC), which is typically accomplished by injection of sulfur trioxide (SO₃), will lower the resistivity of the particles so that they will accept more charge and allow the ESP to collect the ash more effectively. Flue gas conditioning systems can account for large improvements in collection efficiency for small ESPs.

Polishing Fabric Filter. A polishing fabric filter could be added downstream of the existing ESP at Jim Bridger 2. One such technology is licensed by the Electric Power Research Institute, and referred to as a COHPAC (Compact Hybrid Particulate Collector). The COHPAC collects the ash that is not collected by the ESP, thus acting as a polishing device. The ESP needs to be kept in service for the COHPAC fabric filter to operate effectively.

The COHPAC fabric filter is about one-half to two-thirds the size of a full size fabric filter, because the COHPAC has a higher air-to-cloth ratio (7 to 9:1), compared to a full size pulse jet fabric filter (3.5 to 4:1).

3.2.3.3 Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

The existing ESP at Jim Bridger 2 is achieving a controlled PM emission rate of 0.074 lb/MMBtu. Utilizing flue gas conditioning upstream of the existing ESP is projected to reduce PM emissions to approximately 0.030 lb/MMBtu. Adding a COHPAC fabric filter downstream of the existing ESP is projected to reduce PM emissions to approximately 0.015 lb/MMBtu.

The PM₁₀ control technology emission rates are summarized in Table 3-6.

TABLE 3-6
PM₁₀ Control Technology Emission Rates
Jim Bridger 2

Control Technology	Short-Term Expected PM ₁₀ Emission Rate (Lb/MMBtu)
Flue Gas Conditioning	0.030
Polishing Fabric Filter	0.015

3.2.3.4 Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

Energy Impacts. Energy is required to overcome the additional pressure drop from the COHPAC fabric filter and associated ductwork. Therefore, a COHPAC retrofit will require an ID fan upgrade and upgrade of the auxiliary power supply system.

A COHPAC fabric filter at Jim Bridger 2 would require approximately 3.4 MW of power, equating to an annual power usage of approximately 26.5 million kW-Hr.

There is only a small power requirement of approximately 50 kW associated with flue gas conditioning.

Environmental Impacts. There are no negative environmental impacts from the addition of a COHPAC polishing fabric filter or flue gas conditioning system.

Economic Impacts. A summary of the costs and PM removed for COHPAC and flue gas conditioning is recorded in Table 3-7, and the first-year control costs for flue gas conditioning and fabric filters are shown in Figure 3-5. The complete Economic Analysis is contained in Appendix A.

TABLE 3-7
PM₁₀ Control Cost Comparison
Jim Bridger 2

Factor	Flue Gas Conditioning	Polishing Fabric Filter
Total Installed Capital Costs	\$0	\$48.4 Million
Total First Year Fixed & Variable O&M Costs	\$0.2 Million	\$1.8 Million
Total First Year Annualized Cost	\$0.2 Million	\$ 6.4 Million
Additional Power Consumption (MW)	0.05	3.4
Additional Annual Power Usage (Million kW-Hr/Yr)	0.4	26.5
Incremental PM Design Control Efficiency	59.5%	79.7%
Incremental Tons PM Removed per Year	1,041	1,395

TABLE 3-7
PM₁₀ Control Cost Comparison
Jim Bridger 2


Factor	Flue Gas Conditioning	Polishing Fabric Filter
First Year Average Control Cost (\$/Ton of PM Removed)	169	4,556
Incremental Control Cost (\$/Ton of SO ₂ PM Removed)	169	17,426

Preliminary BART Selection. CH2M HILL recommends selection of flue gas conditioning upstream of the existing ESP as BART for Jim Bridger 2, based on the significant reduction in PM emissions, reasonable control costs, and advantages of minimal additional power requirements and no environmental impacts.

3.2.3.5 Step 5: Evaluate Visibility Impacts

Please see Section 4.0, BART Modeling Analysis.

FIGURE 3-5
First Year Control Cost for PM Air Pollution Control Options
Jim Bridger 2



4.0 BART Modeling Analysis

4.1 Model Selection

CH2M HILL used the CALPUFF modeling system to assess the visibility impacts of emissions from Jim Bridger 2 at nearby Class I areas. The Class I areas potentially affected are located more than 50 kilometers but less than 300 kilometers from the Jim Bridger 2 facility. The Class I areas include the following wilderness areas (WA):

- Bridger WA
- Fitzpatrick WA
- Mt. Zirkel WA

The CALPUFF modeling system includes the CALMET meteorological model, a Gaussian puff dispersion model (CALPUFF) with algorithms for chemical transformation and deposition, and a post processor capable of calculating concentrations, visibility impacts, and deposition (CALPOST). The CALPUFF modeling system was applied in a full, refined mode. Version numbers of the various programs in the CALPUFF system used by CH2M HILL were as follows:

- CALMET Version 5.53a, Level 040716
- CALPUFF Version 5.711a, Level 040716
- CALPOST Version 5.51, Level 030709

4.2 CALMET Methodology

4.2.1 Dimensions of the Modeling Domain

CH2M HILL used the CALMET model to generate a three-dimensional wind field and other meteorological parameters suitable for use by the CALPUFF model. A modeling domain was established to encompass the Jim Bridger 2 facility and allow for a 50-km buffer around the Class I areas that were within 300 km of the facility. Grid resolution was 4 km. Figure 4-1 shows the extent of the modeling domain. Except when specifically instructed otherwise by the Wyoming Department of Environmental Quality – Air Quality Division (WDEQ-AQD), CH2M HILL followed the methodology spelled out in the WDEQ-AQD BART Modeling Protocol, a copy of which is included in this report as Appendix B.

CH2M HILL used the Lambert Conformal Conic map projection for the analysis due to the large extent of the domain. The latitude of the projection origin and the longitude of the central meridian were chosen at the approximate center of the domain. Standard parallels were drawn to represent 1/6 and 5/6 of the north-south extent of the domain to minimize distortion in the north-south direction.




Figure 4-1
 Jim Bridger Source-Specific
 Class I Areas to be Addressed



CH2MHILL

S:\C\B\GIS\PROJECTS\HUNTER\MAPFILES\JIM_BRIDGER_CLASS1\MXD 11/9/2006 MSLAYDEN

The default technical options listed in TRC Companies, Inc.'s (TRC) current example CALMET.inp file were used for CALMET. Vertical resolution of the wind field included ten layers, with vertical face heights as follows (in meters):

- 0, 20, 40, 100, 140, 320, 580, 1020, 1480, 2220, 3500

Other user-specified model options were set to values established by WDEQ-AQD, which appear in Table 3 of Appendix B. Table 4-1 lists the key user-specified options used for this analysis.

TABLE 4-1
User-Specified CALMET Options
Jim Bridger 2

CALMET Input Parameter	Value
CALMET Input Group 2	
Map projection (PMAP)	Lambert Conformal
Grid spacing (DGRIDKM)	4
Number vertical layers (NZ)	10
Top of lowest layer (m)	20
Top of highest layer (m)	3500
CALMET Input Group 4	
Observation mode (NOOBS)	0
CALMET Input Group 5	
Prog. Wind data (IPROG)	14
(RMAX1)	30
(RMAX2)	50
Terrain influence (TERRAD)	15
(R1)	5
(R2)	25
CALMET Input Group 6	
Max mixing ht (ZIMAX)	3500

4.2.2 CALMET Input Data

CH2M HILL ran the CALMET model to produce three years of analysis: 2001, 2002, and 2003. WDEQ-AQD provided 12-km resolution Mesoscale Meteorological Model, Version 5 (MM5) meteorological data fields that covered the entire modeling domain for each study year.

These three data sets were chosen because they are current and have been evaluated for quality. The MM5 data were used as input to CALMET as the "initial guess" wind field. The initial guess wind field was adjusted by CALMET for local terrain and land use effects to generate a

Step 1 wind field, and further refined using local surface observations to create a final Step 2 wind field.

Surface data for 2001-2003 were obtained from the National Climatic Data Center. CH2M HILL processed the data from the National Weather Service's Automated Surface Observing System (ASOS) network for all stations that are in the domain. The surface data were obtained in abbreviated DATSAV3 format. A conversion routine available from the TRC website was used to convert the DATSAV3 files to CD-144 format for input into the SMERGE preprocessor and CALMET.

Land use and terrain data were obtained from the U.S. Geological Survey (USGS). Land use data were obtained in Composite Theme Grid format from the USGS, and the Level I USGS land use categories were mapped into the 14 primary CALMET land use categories. Surface properties such as albedo, Bowen ratio, roughness length, and leaf area index were computed from the land use values. Terrain data were taken from USGS 1-degree Digital Elevation Model data, which primarily derive from USGS 1:250,000 scale topographic maps. Missing land use data were filled with values that were assumed appropriate for the missing area.

Precipitation data were obtained from the National Climatic Data Center. All available data in fixed-length, TD-3240 format were obtained for the modeling domain. The list of available stations that have collected complete data varies by year, but CH2M HILL processed all available stations/data within the domain for each year. Precipitation data were prepared with the PXTRACT/PMERGE processors in preparation for use within CALMET.

Upper-air data were prepared for the CALMET model with the READ62 preprocessor for the following stations:

- Denver, Colorado
- Salt Lake City, Utah
- Riverton, Wyoming
- Rapid City, South Dakota

Figure 4-2 shows the locations of surface and upper air stations within the MM5 modeling domain.





Figure 4-2
 Surface and Upper Air Stations Used in the
 Jim Bridger BART Analysis



CH2MHILL

4.2.3 Validation of CALMET Wind Field

CH2M HILL used the CALDESK data display and analysis system (v2.97, Enviromodeling Ltd.) to view plots of wind vectors and other meteorological parameters to evaluate the CALMET wind fields. The CALDESK displays were compared to observed weather conditions, as depicted in surface and upper-air weather maps from the National Oceanic and Atmospheric Administration Central Library U.S. Daily Weather Maps Project (http://docs.lib.noaa.gov/rescue/dwm/data_rescue_daily_weather_maps.html).

4.3 CALPUFF Modeling Approach

For the BART control technology visibility improvement modeling, CH2M HILL followed WDEQ-AQD guidance provided in the document titled *BART Air Modeling Protocol - Individual Source Visibility Assessments for BART Control Analyses* (September, 2006).

A modeling protocol titled *Modeling Protocol for BART Control Technology Improvement Modeling Analysis* (CH2M HILL, August, 2006) was submitted to WDEQ-AQD for review. In the protocol, CH2M HILL described how the general CALMET/CALPUFF approach recommended by the WDEQ-AQD would be used to model Jim Bridger 2.

CH2M HILL drove the CALPUFF model with the meteorological output from CALMET over the modeling domain described earlier. The CALPUFF model was used to predict visibility impacts for the pre-control (baseline) scenario for comparison to the predicted impacts for post-control scenarios for Jim Bridger 2.

4.3.1 Background Ozone and Ammonia

Hourly values of background ozone concentrations were used by CALPUFF for the calculation of SO₂ and NO_x transformation with the MESOPUFF II chemical transformation scheme. CH2M HILL obtained hourly ozone data from the following stations located within the modeling domain for 2001, 2002, and 2003:

- Rocky Mountain National Park, Colorado
- Craters of the Moon National Park, Idaho
- Highland, Utah
- Thunder Basin National Grasslands, Wyoming
- Yellowstone National Park, Wyoming
- Centennial, Wyoming
- Pinedale, Wyoming

For periods of missing hourly ozone data, the chemical transformation relied on a monthly default value of 44 parts per billion. Background ammonia was set to 2 parts per billion. Both of these background values were taken from the WDEQ-AQD document *BART Air Modeling Protocol - Individual Source Visibility Assessments for BART Control Analyses* (September, 2006).

4.3.2 Stack Parameters

The stack parameters used for the baseline modeling reflect those that are in place under the current permit for Jim Bridger 2, except for the NO_x emission rate where 0.24 lb/MMBtu (achieved with the new LNB w/OFA system) was used in lieu of the permit limit of 0.45 lb/MMBtu. Post-control stack parameters reflect the anticipated changes associated with installation of the control technology alternatives that are being evaluated. The maximum heat input rate of 6,000 MMBtu/hr was used to calculate a maximum emission rate. Measured velocities and stack flow rates were used in the modeling to represent a worst-case situation.

4.3.3 Emission Rates

Pre-control emission rates for Jim Bridger 2 reflect peak 24-hour average emissions that may occur under the source's current permit. The emission rates reflect actual emissions under normal operating conditions, as described by the EPA in the *Regional Haze Regulations and Guidelines for Best Available Retrofit Technology Determinations; Final Rule* (40 CFR Part 51; July 6, 2005, pg 39129).

CH2M HILL used available continuous emission monitoring data to determine peak 24-hour emission rates. Data reflected operations from the most recent 3 to 5 year period, unless a more recent period was more representative. Allowable short-term (24-hour or shorter period) emissions or short-term emission limits were used if continuous emission monitoring data were not available.

Emissions were modeled for the following pollutants:

- SO₂
- NO_x
- Coarse particulate (PM_{2.5}<diameeter<PM₁₀)
- Fine particulate (diameeter<PM_{2.5})
- Sulfates

Post-control emission rates reflect the effects of the emissions control scenario under consideration. Modeled pollutants were the same as those listed for the pre-control scenario.

4.3.4 Post Control Scenarios

Four post control modeling scenarios were developed to cover the range of effectiveness for the combination of the individual NO_x, SO₂ and PM control technologies being evaluated. The selection of each control device was made based on the engineering analyses performed in Section 3 for reasonable technologies that would meet or exceed the presumptive BART levels for each pollutant.

- **Scenario 1:** Existing LNB w/OFA, upgraded wet FGD system, and flue gas conditioning for enhanced ESP performance. As indicated previously, this scenario represents CH2M HILL's preliminary BART recommendation.
- **Scenario 2:** Existing LNB w/OFA, upgraded wet FGD system, and new polishing fabric filter.

- **Scenario 3:** Existing LNB w/OFA and SCR, upgraded wet FGD system, and flue gas conditioning for enhanced ESP performance.
- **Scenario 4:** Existing LNB w/OFA and SCR, upgraded wet FGD system, and new polishing fabric filter.

The ROFA and SNCR options for NO_x control were not included in the modeling scenarios, because their control effectiveness is between the existing LNB w/OFA option and the SCR option. Modeling of NO_x, SO₂, and PM controls alone was not performed because any final BART solution will include a combination of control technologies for NO_x, SO₂, and PM.

Table 4-2 presents the stack parameters and emission rates used for the Jim Bridger 2 analysis for baseline and post-control modeling. In accordance with the WDEQ BART modeling protocol, elemental carbon stack emissions and organic aerosol emissions were not modeled.

TABLE 4-2
BART Model Input Data
Jim Bridger 2

	Baseline	Post Control Scenario 1	Post Control Scenario 2	Post Control Scenario 3	Post Control Scenario 4
	Current Operations with wet FGD and ESP	LNB with OFA, Wet FGD, ESP	LNB with OFA, Wet FGD, New Fabric Filter	LNB with OFA and SCR, Wet FGD, ESP	LNB with OFA and SCR, Wet FGD, Fabric Filter
Heat Input (MMBtu/hr)	6,000	6,000	6,000	6,000	6,000
SO ₂ Stack Emissions (lb/MMBTU)	0.3	0.10	0.10	0.10	0.10
SO ₂ Stack Emissions (lb/hr)	1,600	600	600	600	600
NO _x Stack Emissions (lb/MMBTU) ⁽¹⁾	0.45	0.24	0.24	0.07	0.07
NO _x Stack Emissions (lb/hr)	2,700	1,440	1,440	420	420
PM ₁₀ Stack Emissions (lb/MMBTU)	0.074	0.030	0.015	0.030	0.015
PM ₁₀ Stack Emissions (lb/hr)	444	180	90.0	180	90
PM ₁₀ -PM _{2.5} Stack Emissions (lb/hr) ⁽²⁾	191	77.4	51.3	77.4	51.3
PM _{2.5} -PM ₀ Stack Emissions (lb/hr) ⁽²⁾	253	103	38.7	103	38.7
HF Stack Emissions (lb/MMBTU)	0.00055	0.00055	0.00055	0.00055	0.00055
HF Stack Emissions (lb/hr)	3.3	3.3	3.3	3.3	3.3
HCl Stack Emissions (lb/MMBTU)	0.00075	0.00075	0.00075	0.00075	0.00075
HCl Stack Emissions (lb/hr)	4.5	4.5	4.5	4.5	4.5
H ₂ SO ₄ Stack Emissions (lb/MMBtu)	0.0092	0.0092	0.0092	0.0158	0.0158
H ₂ SO ₄ Stack Emissions (lb/hr)	55.2	55.20	55.20	94.80	94.80
H ₂ SO ₄ as SO ₄ Stack Emissions (lb/hr)	54.1	54.07	54.07	92.87	92.87
(NH ₄) ₂ SO ₄ Stack Emissions (lb/MMBtu)				0.00117	0.00117

TABLE 4-2
BART Model Input Data
Jim Bridger 2

	Baseline	Post Control Scenario 1	Post Control Scenario 2	Post Control Scenario 3	Post Control Scenario 4
	Current Operations with wet FGD and ESP	LNB with OFA, Wet FGD, ESP	LNB with OFA, Wet FGD, New Fabric Filter	LNB with OFA and SCR, Wet FGD, ESP	LNB with OFA and SCR, Wet FGD, Fabric Filter
(NH ₄) ₂ SO ₄ Stack Emissions (lb/hr)				7.02	7.02
(NH ₄) ₂ SO ₄ as SO ₄ Stack Emissions (lb/hr)				5.10	5.10
(NH ₄)HSO ₄ Stack Emissions (lb/MMBtu)				0.00204	0.00204
(NH ₄)HSO ₄ as SO ₄ Stack Emissions (lb/hr)				12.2	12.2
(NH ₄)HSO ₄ as SO ₄ Stack Emissions (lb/hr)				10.22	10.22
Total Filterable PM ₁₀ (lb/hr) (incl. PM _{2.5})	452	188	97.8	187.8	97.8
Total Sulfate (as SO ₄) (lb/hr)	54.1	54.1	54.1	108.2	108.2
Stack Conditions					
Stack Height (feet)	500	500	500	500	500
Stack Height (m)	152	152	152	152	152
Stack Exit Diameter (feet)	24.00	24.00	24.00	24.00	24.00
Stack Exit Diameter (m)	7.32	7.32	7.32	7.32	7.32
Stack Exit Temperature (deg. F)	140	120	140	140	140
Stack Exit Temperature (K)	333.2	322.0	333.2	333.2	333.2
Stack Exit Flow (acfm)	2,281,182	2,208,010	2,437,627	2,437,627	2,437,627
Stack Exit Area (ft ²)	452	452	452	452	452
Stack Exit Velocity (fps) ⁽³⁾	84.04	81.24	89.81	89.81	89.81
Stack Exit Velocity (m/s)	25.62	24.76	27.37	27.37	27.37

Notes:

(1) Uncontrolled emissions were modeled as the baseline condition even though LNB with OFA has been installed.

(2) Based on AP-42, Table 1.1-6, as percent of PM₁₀

	ESP	Baghouse
PM ₁₀ -PM _{2.5} Stack Emissions (lb/hr)	43	57
PM _{2.5} -PM ₀ Stack Emissions (lb/hr)	57	43

(3) Scenarios 2, 3, and 4 were not remodeled at the lower, correct velocity of 81.24 fps due to lack of time and the fact that the conclusions to select Scenario 1 would not have changed.

4.3.5 Modeling Process

The CALPUFF modeling for the control technology options for Jim Bridger 2 followed this sequence:

- Model pre-control (baseline) emissions
- Model preferred post-control scenario (if applicable)
- Determine degree of visibility improvement
- Model other control scenarios
- Determine degree of visibility improvement
- Factor visibility results into BART “5-step” evaluation

4.3.6 Receptor Grids

Discrete receptors for the CALPUFF modeling were placed at uniform receptor spacing along the boundary and in the interior of each area of concern. Class I area receptors were taken from the National Park Service (NPS) database for Class I area modeling receptors. The TRC COORDS program was used to convert all latitude/longitude coordinates to Lambert Conformal Conic coordinates, including receptors, meteorological stations, and source locations.

4.4 CALPOST

The CALPOST processor was used to determine 24-hour average visibility results with output specified in deciview (dV) units. Calculations of light extinction were made for each pollutant modeled. The sum of all extinction values were used to calculate the delta-dV (Δ dV) change relative to natural background. Default light extinction coefficients for each pollutant, as shown below, were used.

- | | |
|---------------------------------|------|
| • Ammonium sulfate | 3.0 |
| • Ammonium nitrate | 3.0 |
| • PM coarse (PM ₁₀) | 0.6 |
| • PM fine (PM _{2.5}) | 1.0 |
| • Organic carbon | 4.0 |
| • Elemental carbon | 10.0 |

CALPOST visibility Method 6 was used to determine the visibility impacts. Monthly relative humidity factors [f (RH)] were used in the light extinction calculations to account for the hygroscopic characteristics of nitrate and sulfate particles. Table 5 of the Wyoming BART Air Modeling Protocol (Appendix B) lists the monthly f (RH) factors for the Class I areas. These values were used for the particular Class I area being modeled.

The natural background conditions as a reference for determining the Δ dV change represented the 20 percent best natural visibility days. The EPA BART guidance document provided dV values for the 10 percent best days for each Class I area, but did not provide individual species concentration data for the 20 percent best days. Species concentrations corresponding to the 20 percent best days were calculated for each Class I area by scaling back the annual average species concentrations given in Table 2-1 of *Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule*. A separate scaling factor was derived for each Class

I area such that, when multiplied by the Guidance table annual concentrations, the 20 percent best days dV value for that area would be calculated. This procedure was taken from *Protocol for BART-Related Visibility Improvement Modeling Analysis in North Dakota* (North Dakota Department of Health; October 26, 2005). The Wyoming BART Air Modeling Protocol did provide natural background concentrations of aerosol components to use in the BART analysis. Table 4-3 lists the annual average species concentrations from the BART protocol.

TABLE 4-3
Average Natural Levels of Aerosol Components
Jim Bridger 2

Aerosol Component	Average Natural Concentration (micrograms per cubic meter) for Mt. Zirkel Class I Wilderness Area	Average Natural Concentration (micrograms per cubic meter) for Fitzpatrick and Bridger Class I Wilderness Areas
Ammonium Sulfate	0.046	0.045
Ammonium Nitrate	0.038	0.038
Organic Carbon	0.179	0.178
Elemental Carbon	0.008	0.008
Soil	0.190	0.189
Coarse Mass	1.141	1.136

Note: Taken from Table 6 of the Wyoming BART Air Modeling Protocol

4.5 Presentation of Modeling Results

This section presents the results of the CALPUFF visibility improvement modeling analysis for Jim Bridger 2.

4.5.1 Degree of Visibility Change for Baseline vs. Preferred Scenario

CH2M HILL modeled Jim Bridger 2 for the baseline conditions and post-control Scenario 1. The post-control scenario included emission rates for NO_x, SO₂, and PM₁₀ that would be achieved if BART technology were installed on Unit 2.

Baseline (and post-control) 98th percentile results were greater than 0.5 ΔdV for the Bridger WA, Fitzpatrick WA, and Mt. Zirkel WA. The 98th percentile results for each Class I area are presented in Table 4-4.

TABLE 4-4
Costs and Visibility Modeling Results for Baseline Vs. Post-Control Scenarios at Class 1 Areas
Jim Bridger 2

Scenario	First Year Cost	Class / Area	Highest Delta- (dV)	98th Percentile Delta (dV)	No. of Days Above 0.5 dV	Cost per dV Reduction	Cost per Reduction In No. of Days Above 0.5 dV	Incremental Cost per dV Reduction	Incremental Cost per Reduction In No. of Days Above 0.5 dV
Baseline - Current Operation with Wet FGD and ESP									
		Bridger WA	2.827	0.814	20	-	-	-	-
		Fitzpatrick WA	2.573	0.487	7	-	-	-	-
		ML Zirkel WA	2.375	1.49	35	-	-	-	-
Scenario 1 - Existing LNB w/IOFA, upgraded wet FGD system, and FGC for enhanced ESP performance									
	\$2,494,828	Bridger WA	1.559	0.424	7	\$6,396,955	\$191,910	\$373,973,666	NA
	\$2,494,828	Fitzpatrick WA	1.604	0.269	3	\$11,444,165	\$623,707	\$109,612,971	NA
	\$2,494,828	ML Zirkel WA	1.376	0.87	21	\$4,023,916	\$178,202	\$30,644,305	\$641,173
Scenario 2 - Existing LNB w/IOFA, upgraded wet FGD system, and new polishing fabric filter.									
	\$8,852,380	Bridger WA	1.557	0.406	7	\$21,697,010	\$690,852	\$8,335,250,973	NA
	\$8,852,380	Fitzpatrick WA	1.386	0.252	3	\$37,669,703	\$2,213,085	\$373,973,666	NA
	\$8,852,380	ML Zirkel WA	1.311	0.812	21	\$13,056,608	\$632,313	\$109,612,971	NA
Scenario 3 - Existing LNB w/IOFA and SCR, upgraded wet FGD system, and FGC for enhanced ESP performance									
	\$17,187,631	Bridger WA	1.022	0.406	3	\$42,023,548	\$1,011,037	\$8,335,250,973	\$2,083,813
	\$17,187,631	Fitzpatrick WA	0.796	0.163	2	\$53,046,245	\$3,437,526	\$93,654,505	\$8,335,251
	\$17,187,631	ML Zirkel WA	0.896	0.54	8	\$18,092,243	\$636,579	\$30,644,305	\$641,173
Scenario 4 - Existing LNB w/IOFA and SCR, upgraded wet FGD system, and new polishing fabric filter.									
	\$23,545,184	Bridger WA	0.985	0.394	3	\$56,059,991	\$1,365,011	\$577,959,300	NA
	\$23,545,184	Fitzpatrick WA	0.775	0.157	2	\$71,349,041	\$4,709,037	\$1,059,592,050	NA
	\$23,545,184	ML Zirkel WA	0.87	0.524	8	\$24,373,895	\$872,044	\$397,347,019	NA
Baseline - Current Operation with Wet FGD and ESP									
		Bridger WA	4.434	1.664	31	-	-	-	-
		Fitzpatrick WA	2.07	0.842	13	-	-	-	-
		ML Zirkel WA	3.499	1.843	48	-	-	-	-
Scenario 1 - Existing LNB w/IOFA, upgraded wet FGD system, and FGC for enhanced ESP performance									
	\$2,494,828	Bridger WA	2.62	0.865	14	\$3,202,603.3	\$146,754.6	\$635,755,230.3	\$6,357,552.3
	\$2,494,828	Fitzpatrick WA	1.158	0.418	7	\$5,864,028.2	\$415,204.7	\$529,796,025.2	\$6,357,552.3
	\$2,494,828	ML Zirkel WA	1.932	0.592	17	\$2,831,813.8	\$90,478.3	\$2,119,184,100.9	\$6,357,552.3
Scenario 2 - Existing LNB w/IOFA, upgraded wet FGD system, and new polishing fabric filter.									
	\$8,852,380	Bridger WA	2.49	0.875	13	\$11,219,748.8	\$491,788.9	\$26,941,843.7	\$2,083,812.7
	\$8,852,380	Fitzpatrick WA	1.077	0.406	6	\$20,303,624.4	\$1,294,625.7	\$53,080,770.5	\$1,667,050.2
	\$8,852,380	ML Zirkel WA	1.666	0.965	18	\$10,082,437.5	\$295,078.3	\$21,708,392.7	\$1,041,906.4
Scenario 3 - Existing LNB w/IOFA and SCR, upgraded wet FGD system, and FGC for enhanced ESP performance									
	\$17,187,631	Bridger WA	1.415	0.387	9	\$15,968,803.4	\$781,256.0	\$489,042,484.8	NA
	\$17,187,631	Fitzpatrick WA	0.59	0.249	1	\$28,984,201.0	\$1,432,302.6	\$2,119,184,100.9	NA
	\$17,187,631	ML Zirkel WA	1.11	0.581	10	\$13,619,359.1	\$452,306.1	\$21,708,392.7	\$1,041,906.4
Scenario 4 - Existing LNB w/IOFA and SCR, upgraded wet FGD system, and new polishing fabric filter.									
	\$23,545,184	Bridger WA	1.39	0.574	9	\$21,601,055.8	\$1,070,235.6	\$489,042,484.8	NA
	\$23,545,184	Fitzpatrick WA	0.58	0.246	1	\$39,505,341.5	\$1,962,086.6	\$2,119,184,100.9	NA
	\$23,545,184	ML Zirkel WA	1.092	0.572	10	\$18,524,928.0	\$619,610.1	\$708,394,700.3	NA

TABLE 4-4
Costs and Visibility Modeling Results for Baseline Vs. Post-Control Scenarios at Class I Areas
Jim Bridger 2

Scenario	First Year Cost	Class I Area	Highest Delta- (dV)	98th Percentile Delta- (dV)	No. of Days Above 0.5 dV	Cost per dV Reduction	Cost per Reduction in No. of Days 0.5 dV	Incremental Cost per dV Reduction	Incremental Cost per Reduction in No. of Days Above 0.5 dV
Baseline - Current Operation with Wet FGD and ESP		Bridger WA	2.032	0.306	17	-	-	-	-
		Fitzpatrick WA	2.134	0.467	7	-	-	-	-
		Mt. Zirkel WA	2.293	1.81	45	-	-	-	-
Scenario 1 - Existing LNB w/OFA, upgraded wet FGD system, and FGC for enhanced ESP performance	\$2,494,828	Bridger WA	1.161	0.469	7	\$5,982,801	\$249,483	\$6,357,552	\$6,357,552
	\$2,494,828	Fitzpatrick WA	1.209	0.238	3	\$10,894,445	\$623,707	\$10,894,445	\$6,357,552
	\$2,494,828	Mt. Zirkel WA	1.22	0.939	19	\$6,386,995	\$95,955	\$6,386,995	\$6,357,552
Scenario 2 - Existing LNB w/OFA, upgraded wet FGD system, and new polishing fabric filter.	\$9,852,390	Bridger WA	1.154	0.454	6	\$19,584,912	\$904,762	\$18,184,352	\$6,357,552
	\$9,852,390	Fitzpatrick WA	1.18	0.237	3	\$38,488,610	\$2,213,095	\$36,957,552	\$6,357,552
	\$9,852,390	Mt. Zirkel WA	1.235	0.899	18	\$12,450,605	\$327,966	\$12,450,605	\$6,357,552
Scenario 3 - Existing LNB w/OFA and SCR, upgraded wet FGD system, and FGC for enhanced ESP performance	\$17,187,631	Bridger WA	0.991	0.317	3	\$29,181,098	\$1,227,688	\$80,841,248	\$2,778,417
	\$17,187,631	Fitzpatrick WA	0.739	0.16	2	\$55,985,769	\$3,437,526	\$108,250,013	\$6,357,552
	\$17,187,631	Mt. Zirkel WA	0.758	0.548	8	\$16,164,210	\$464,531	\$23,747,154	\$833,525
Scenario 4 - Existing LNB w/OFA and SCR, upgraded wet FGD system, and new polishing fabric filter.	\$23,545,184	Bridger WA	0.949	0.305	3	\$39,176,678	\$1,681,799	\$529,798,025	NA
	\$23,545,184	Fitzpatrick WA	0.72	0.156	2	\$75,707,986	\$4,709,037	\$1,589,388,076	NA
	\$23,545,184	Mt. Zirkel WA	0.734	0.537	8	\$21,943,321	\$636,596	\$77,959,300	NA
Scenario 1		Bridger WA				\$3,469,322	\$135,066		
		Fitzpatrick WA				\$6,548,345	\$386,347		
		Mt. Zirkel WA				\$3,295,113	\$92,378		
Scenario 2		Bridger WA				\$15,898,498	\$923,249	\$1,233,493,911	\$6,357,552
		Fitzpatrick WA				\$29,646,467	\$1,782,755	\$1,539,049,021	\$6,357,552
		Mt. Zirkel WA				\$11,104,855	\$376,314	\$435,584,149	\$6,357,552
Scenario 3		Bridger WA				\$27,290,647	\$986,978	\$2,792,091,793	\$2,315,347
		Fitzpatrick WA				\$44,183,187	\$2,668,813	\$84,506,513	\$6,112,517
		Mt. Zirkel WA				\$15,492,053	\$487,679	\$25,219,145	\$938,868
Scenario 4		Bridger WA				\$37,014,839	\$1,367,250	\$526,094,348	NA
		Fitzpatrick WA				\$60,378,985	\$3,697,077	\$1,570,959,226	NA
		Mt. Zirkel WA				\$21,203,594	\$875,576	\$554,067,269	NA

Sample Calculations: Cost per dV Reduction for Scenario 1 for 2001:
 = \$2,494,828 / (0.814 - 0.424) = \$6,396,995
 Sample Calculations: Cost per Reduction in No. of Days Above 0.5 dV for 2001:
 = \$2,494,828 / (20 - 7) = \$181,910.

5.0 Preliminary Assessment and Recommendations

As a result of the completed technical and economic evaluations, and consideration of the modeling analysis for Jim Bridger 2, the preliminary recommended BART controls for NO_x, SO₂, and PM are as follows:

- Existing LNBs and OFA system for NO_x control
- Upgrade the existing wet sodium FGD for SO₂ control
- Add flue gas conditioning upstream of the existing ESP for PM control

The above recommendations were identified as Scenario 1 for the modeling analysis described in Section 4.0. Visibility improvements for all emission control scenarios were analyzed, and the results are compared below, utilizing a Least-Cost Envelope, as outlined in the draft EPA 1990 *New Source Review Workshop Manual (NSR Manual)*. The purpose of this analysis is to use an objective, EPA-approved methodology to evaluate and make the final recommendation of BART control technology.

5.1 Least-Cost Envelope Analysis

For the control scenarios modeled in Section 4, Tables 5-1 through 5-3 list the total annualized cost, cost per dV reduction, and cost per reduction in number of days above 0.5 dV for each of the three Class I areas. A comparison of the incremental results between selected scenarios is provided in Tables 5-4 through 5-6. Figures 5-1 to 5-6 show the total annualized cost versus number of days above 0.5 dV, and the total annualized cost versus 98th percentile Δ dV reduction, for the three Class I areas.

5.1.1 Analysis Methodology

Page B-41 of the New Source Review (NSR) Manual, EPA states that "Incremental cost-effectiveness comparisons should focus on annualized cost and emission reduction differences between dominant alternatives. Dominant set of control alternatives are determined by generating what is called the envelope of least-cost alternatives. This is a graphical plot of total annualized costs for a total emissions reductions for all control alternatives identified in the BACT analysis..."

An analysis of incremental cost effectiveness has been conducted. This analysis was performed in the following way. First, the control option scenarios are ranked in ascending order of annualized total costs, as shown in Tables 5-1 through 5-3. The incremental cost effectiveness data, expressed per day and per dV, represents a comparison of the different scenarios, and is summarized in Tables 5-4 through 5-6 for each of the three wilderness areas. Then the most reasonable smooth curve of least-cost control option scenarios is plotted for each analysis. Figures 5-1 through 5-6 present the two analyses (cost per dV reduction and cost per reduction in number of days above 0.5 dV) for each of the three Class I areas impacted by the operation of Jim Bridger 2.

In Figure 5-1, the four scenarios are compared as a graph of total annualized cost versus number of days above 0.5 dV. EPA states that "In calculating incremental costs, the analysis should only be conducted for control options that are dominant among all possible options". In Figure 5-1, the dominant set of control options, Scenarios 1 and 3, represent the least-cost envelope depicted by the curvilinear line connecting them. Scenarios 2 and 4 are inferior options and should not be considered in the derivation of incremental cost effectiveness. Scenarios 2 and 4 represent inferior controls, because Scenario 1 provides approximately same amount of visibility impact reduction for less cost than Scenario 2; and similarly, Scenario 3 will provides approximately the same amount of visibility impact reduction for less cost than Scenario 4. The incremental cost effectiveness is determined by the difference in total annual costs between two contiguous scenarios divided by the difference in emissions reduction.

TABLE 5-1
Control Scenario Results for the Bridger Class 1 Wilderness Area
Jim Bridger 2

Scenario	Controls	98th Percentile dV Reduction	Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet FGD, ESP	0.0	0.0	\$0.0	\$0.0	\$0.0
1	Existing LNB w/OFA, upgraded wet FGD system, and FGC for enhanced ESP performance	0.5	13.3	\$2.5	\$5.2	\$0.2
2	LNB w/OFA, upgraded wet FGD system, and new polishing fabric filter.	0.6	14.0	\$8.9	\$17.5	\$0.7
3	LNB w/OFA and SCR, upgraded wet FGD system, FGC for enhanced ESP performance	0.7	17.7	\$17.2	\$29.1	\$1.0
4	LNB w/OFA and SCR, upgraded wet FGD system, new polishing fabric filter.	0.7	17.7	\$23.6	\$39.0	\$1.4

TABLE 5-2
Control Scenario Results for the Fitzpatrick Class I Wilderness Area
Jim Bridger 2

Scenario	Controls	98th Percentile dV Reduction	Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet FGD and ESP	0.0	0.0	\$0.0	\$0.0	\$0.0
1	Existing LNB w/OFA, upgraded wet FGD system, and FGC for enhanced ESP performance	0.3	4.7	\$2.5	\$9.4	\$0.6
2	LNB w/OFA, upgraded wet FGD system, and new polishing fabric filter.	0.3	5.0	\$89	\$32.2	\$1.9
3	LNB w/OFA and SCR, upgraded wet FGD system, FGC for enhanced ESP performance	0.4	7.3	\$17.2	\$46.0	\$2.8
4	LNB w/OFA and SCR, upgraded wet FGD system, new polishing fabric filter.	0.4	7.3	\$23.6	\$62.2	\$3.8

TABLE 5-3
Control Scenario Results for the Mt. Zirkel Class I Wilderness Area
Jim Bridger 2

Scenario	Controls	98th Percentile dV Reduction	Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet FGD and ESP	0.0	0.0	\$0.0	\$0.0	\$0.0
1	Existing LNB w/OFA, upgraded wet FGD system, and FGC for enhanced ESP performance	0.7	2367	\$2.5	\$4.4	\$0.1
2	LNB w/OFA, upgraded wet FGD system, and new polishing fabric filter.	0.8	23.7	\$8.9	\$11.9	\$0.4
3	LNB w/OFA and SCR, upgraded wet FGD system, FGC for enhanced ESP performance	1.1	34.0	\$17.2	\$16.0	\$0.5
4	LNB w/OFA and SCR, upgraded wet FGD system, new polishing fabric filter.	1.1	34.0	\$23.6	\$21.6	\$0.7

TABLE 5-4
Bridger Class I Wilderness Area Incremental Analysis Data
Jim Bridger 2

Options Compared	Incremental Reduction in Days Above 0.5 dV (Days)	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	13.3	0.5	\$0.2	\$4.7
Scenario 1 and Scenario 3	4.3	0.2	\$3.4	\$90.1
Scenario 4 and Scenario 3	0.0	0.01	N/A	\$530

TABLE 5-5
Fitzpatrick Class I Wilderness Area Incremental Analysis Data
Jim Bridger 2

Options Compared	Incremental Reduction in Days Above 0.5 dV (Days)	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	4.7	0.3	\$0.5	\$8.6
Scenario 1 and Scenario 3	267	0.1	\$5.5	\$125
Scenario 4 and Scenario 3	0.0	0.004	N/A	\$1,467

TABLE 5-6
Mt. Zirkel Class I Wilderness Area Incremental Analysis Data
Jim Bridger 2

Options Compared	Incremental Reduction in Days Above 0.5 dV (Days)	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	23.7	0.7	\$0.1	\$3.5
Scenario 1 and Scenario 3	10.3	0.4	\$1.4	\$40.0
Scenario 4 and Scenario 3	0.0	0.01	N/A	\$530

FIGURE 5-1
Least Cost Envelope Bridger Class I WA Days Reduction
Jim Bridger 2




FIGURE 5-2
Least Cost Envelope Bridger WA Class I Area 98th Percentile Reduction
Jim Bridger 2




FIGURE 5-3
Least Cost Envelope Fitzpatrick Class I WA Days Reduction
Jim Bridger 2




FIGURE 5-4
Least Cost Envelope Fitzpatrick Class I WA 98th Percentile Reduction
Jim Bridger 2




FIGURE 5-5
 Least Cost Envelope Mt. Zirkel Class I WA Days Reduction
 Jim Bridger 2





FIGURE 5-6
 Least Cost Envelope Mt. Zirkel Class I WA 98th Percentile Reduction
 Jim Bridger 2



5.1.2 Analysis Results

Results of the Least Cost Analysis, shown in Tables 5-1 through 5-6 and Figures 5-1 through 5-4 on the preceding pages, confirm the selection of Scenario 1, based on incremental cost and visibility improvements. Scenario 2 is eliminated because it is to the left of the curve formed by the “dominant” control alternative scenarios, which indicates a scenario with lower improvement and/or higher costs. Scenario 3 is not selected due to very high incremental costs for both a cost per day of improvement and a cost per dV reduction. While Scenario 4 provides some potential visibility advantage over Scenario 1, the projected improvement is less than half a dV, and the projected costs are excessive.

Analysis of the results for the Jim Bridger Class 1WA in Tables 5-1 and 5-4 and Figures 5-1 and 5-2 illustrates the conclusions stated above. The greatest reduction in 98th percentile dV and number of days above 0.5 dV is between the Baseline and Scenario 1. The incremental cost effectiveness for Scenario 1 compared to the Baseline for the Bridger WA, for example, is reasonable at \$190,000/day and \$4.72 Million/dV. However, the incremental cost effectiveness for Scenario 3 compared to Scenario 1 is excessive at \$3.39 Million/day and \$90.14 Million/dV. The same conclusions are reached for each of the three wilderness areas studied. Therefore, Scenario 1 represents BART for Jim Bridger 2.

5.2 Recommendations

5.2.1 NO_x Emission Control

The BART presumptive NO_x limit assigned by EPA for tangentially-fired boilers burning subbituminous coal is 0.15 lb/MMBtu. However, as documented in Section 3.2.1.1, the characteristics of the Jim Bridger coals are more closely aligned with bituminous coals, with a presumptive BART NO_x limit of 0.28 lb/MMBtu.

CH2M HILL recommends the existing low-NO_x burners with over-fire air (LNB w/OFA) as BART for Jim Bridger 2, based on the projected significant reduction in NO_x emissions, reasonable control costs, and the advantages of no additional power requirements or non-air quality environmental impacts. NO_x reductions have been realized at Jim Bridger 2. CH2M HILL recommends that the unit be permitted at a rate of 0.26 lb/MMBtu.

5.2.2 SO₂ Emission Control

CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 2, based on the significant reduction in SO₂ emissions, reasonable control costs, and the advantages of minimal additional power requirements and minimal non-air quality environmental impacts. This upgrade approach will meet the BART presumptive SO₂ limit of 0.15 lb/MMBtu.

5.2.3 PM₁₀ Emission Control

CH2M HILL recommends finalizing the permitting of the flue gas conditioning system to enhance the performance of the existing electrostatic precipitator (ESP) as BART for Jim Bridger 2, based on the significant reduction in PM₁₀ emissions, reasonable control costs, and

the advantages of minimal additional power requirements and no non-air quality environmental impacts.

5.3 Just-Noticeable Differences in Atmospheric Haze

Conclusions reached in the reference document "Just-Noticeable Differences in Atmospheric Haze" by Dr. Ronald Henry of the University of Southern California (Appendix C), state that only dV differences of approximately 1.5 to 2.0 dV, or more are perceptible by the human eye. Deciview changes of less than 1.5 cannot be distinguished by the average person. Therefore, the modeling analysis results indicate that only minimal, if any, observable visibility improvements at the Class I areas studied would be expected under any of the scenarios. Thus the results indicate that even though many millions of dollars will be spent, only minimal, if any, visibility improvements may result.

Finally, it should be noted that none of the data were corrected for natural obscuration. Water in various forms (fog, clouds, snow, or rain) or other naturally caused aerosols may obscure the atmosphere and reduce visibility. During the period of 2001 through 2003, there were several mega-wildfires that lasted for many days, with a significant impact on background visibility in these Class I areas. If natural obscuration lessens the achievable reduction in visibility impacts modeled for BART controls at the Jim Bridger 2 facility, the overall effect would be to increase the costs per dV reduction that are presented in this report.

6.0 References

BART Air Modeling Protocol - Individual Source Visibility Assessments for BART Control Analyses. September, 2006.

Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule.

Multi-Pollutant Control Report. October, 2002, updated October 2006

Protocol for BART-Related Visibility Improvement Modeling Analysis in North Dakota. North Dakota Department of Health. October 26, 2005.

Regional Haze Regulations and Guidelines for Best Available Retrofit Technology Determinations; Final Rule (40 CFR Part 51; July 6, 2005, pg 39129)

S&L Study Multi-Pollutant Control Report. October, 2002, updated October 2006

United States Environmental Protection Agency, 1990. *New Source Review Workshop Manual - Prevention of Significant Deterioration and Nonattainment Area Permitting*. October 1990.

Appendices

APPENDIX A
Economic Analysis

PacifiCorp BART Analysis Report Tables

Jim Bridger Unit 2

TABLE 3-1 NO _x Control Technology Emission Rate Ranking Jim Bridger Unit 2	
Technology	Projected Emission Rate (lb/MMBtu)
Exist. LNB w/OFA	0.24
ROFA	0.22
SNCr	0.20
SCR	0.07

TABLE 3-2

NO _x Control Cost Comparison Jim Bridger Unit 2		Exist. LNB w/OFA		ROFA		SNCr		SCR	
Factor		\$	Million	\$	Million	\$	Million	\$	Million
Total Installed Capital Costs			-	20.5	Million		13.4		120.9
Total First Year Fixed & Variable O&M Costs			-	2.6	Million		1.0		3.2
Total First Year Annualized Cost			-	4.6	Million		2.3		14.7
Power Consumption (MW)			-	6.41			0.53		3.25
Annual Power Usage (Million kW-Hr/Yr)			-	50.6			4.2		25.6
NO _x Design Control Efficiency			0.0%	8.3%			16.7%		70.8%
Tons NO _x Removed per Year			0	473			946		4,021
First Year Average Control Cost (\$/Ton of NO _x Removed)			#DIV/0!	9,695			2,389		3,654
Incremental Control Cost (\$/Ton of NO _x Removed)			#DIV/0!	9,695			2,389		4,044

TABLE 3-3

SO ₂ Control Technology Emission Rate Ranking Jim Bridger Unit 2	
Control Technology	Short-Term Expected SO ₂ Emission Rate (Lb/MMBtu)
N/A	N/A
N/A	N/A
Upgraded Wet FGD	0.10

PacifiCorp BART Analysis Report Tables

Jim Bridger Unit 2


SO ₂ Control Cost Comparison Jim Bridger Unit 2	Factor	N/A	N/A	Upgraded Wet FGD
Total Installed Capital Costs				13.0 Million
Total First Year Fixed & Variable O&M Costs				1.3 Million
Total First Year Annualized Cost				2.5 Million
Power Consumption (MW)				0.53
Annual Power Usage (Million kW-Hr/Yr)				4.2
SO ₂ Design Control Efficiency				62.5%
Tons SO ₂ Removed per Year				3,950
First Year Average Control Cost (\$/Ton of SO ₂ Removed)				632
Incremental Control Cost (\$/Ton of SO ₂ Removed)				632


TABLE 3-5

PM ₁₀ Control Technology Emission Ranking Jim Bridger Unit 2	Control Technology	Short-Term Expected PM ₁₀ Emission Rate (Lb/MIMEtu)
Flue Gas Conditioning		0.030
Fabric Filter		0.015

TABLE 3-6


PM ₁₀ Control Cost Jim Bridger Unit 2	Factor	Flue Gas Conditioning	Fabric Filter
Total Installed Capital Costs		\$ - Million	\$ 48.4 Million
Total First Year Fixed & Variable Operations & Maintenance Costs		\$ 0.2 Million	\$ 1.8 Million
Total First Year Annualized Cost		\$ 0.2 Million	\$ 6.4 Million
Power Consumption (MW)		0.05	3.37
Annual Power Usage (Million kW-Hr/Yr)		0.4	26.5
PM Design Control Efficiency		59.46%	79.73%
Tons PM Removed per Year		1,041	1,395
First Year Average Control Cost (\$/Ton of PM Removed)		169	4,556
Incremental Control Cost (\$/Ton of SO ₂ Removed)		169	17,426





Upgraded Wet FGD
Air Pollution Control Option

■ First Year Average Control Cost ■ First Year Incremental Control Cost



PacifiCorp BART Analysis Scenarios

4 Jim Bridger Unit 2

Select Unit:

Index No.	Name of Unit
1	Dave Johnston Unit 3
2	Dave Johnston Unit 4
3	Jim Bridger Unit 1
4	Jim Bridger Unit 2
5	Jim Bridger Unit 3
6	Jim Bridger Unit 4
7	Naughton Unit 1
8	Naughton Unit 2
9	Naughton Unit 3
10	Wyodak Unit 1

Scenario	Dave Johnston		Naughton		Myodak	
	DJ Unit 3	DJ Unit 4	NTN Unit 1	NTN Unit 2	WDK Unit 1	JB Unit 4
Baseline - Current Operation with ESP	First Year Cost	Scenario - Current Operation with Venturi Scrubber	Scenario - Current Operation with ESP	Scenario - Current Operation with FGD, ESP	Scenario - Current Operation with FGD, Fabric Filter	Scenario - Current Operation with Dry FGD, Fabric Filter
Scenario 1 - LNB with OFA, Dry FGD, Existing ESP	N/A	Scenario 1 - LNB with OFA, Dry FGD, Fabric Filter	Scenario 1 - LNB with OFA, Dry FGD, ESP	Scenario 1 - LNB with OFA, Dry FGD, ESP	Scenario 1 - LNB with OFA, Wet FGD, New Fabric Filter	Scenario 1 - LNB with OFA, Dry FGD, Fabric Filter
Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	Scenario 2 - LNB with OFA and SCR, Dry FGD
Scenario 3 - LNB with OFA and SCR, Dry FGD, Existing ESP, New Stack	N/A	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	Scenario 3 - LNB with OFA and SCR, Wet FGD, Fabric Filter
Scenario 4 - LNB with OFA and SCR, Wet FGD, Existing ESP, New Stack	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	Scenario 4 - LNB with OFA and SCR, Wet FGD, ESP, New Stack	Scenario 4 - LNB with OFA and SCR, Wet FGD, ESP, New Stack	Scenario 4 - LNB with OFA and SCR, Wet FGD, ESP, New Stack	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter
First Year Cost		First Year Cost	First Year Cost	First Year Cost	First Year Cost	First Year Cost
Baseline - Current Operation with Wet FGD and ESP	Scenario - Current Operation with Wet FGD and ESP	Scenario - Current Operation with Wet FGD and ESP	Scenario - Current Operation with Wet FGD and ESP	Scenario - Current Operation with Wet FGD and ESP	Scenario - Current Operation with Wet FGD and ESP	Scenario - Current Operation with Wet FGD and ESP
Scenario 1 - LNB with OFA, Wet FGD, ESP	Scenario 1 - LNB with OFA, Wet FGD, ESP	Scenario 1 - LNB with OFA, Wet FGD, ESP	Scenario 1 - LNB with OFA, Wet FGD, ESP	Scenario 1 - LNB with OFA, Wet FGD, ESP	Scenario 1 - LNB with OFA, Wet FGD, ESP	Scenario 1 - LNB with OFA, Wet FGD, ESP
Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	Scenario 2 - LNB with OFA and SCR, Dry FGD
Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	Scenario 3 - LNB with OFA and SCR, Wet FGD, Fabric Filter
Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter
First Year Cost	First Year Cost	First Year Cost	First Year Cost	First Year Cost	First Year Cost	First Year Cost

ECONOMIC ANALYSIS SUMMARY

Jim Bridger Unit 2 Tangential-Fired PC Boiler Design:

Parameter	NOx Control				SO2 Control			PM Control		
	Current Operation	Exist. LNB w/OFA	ROFA	SNCR	SCR	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter		
Case	1	2	3	4	5	6	7	8	9	10
NOx Emission Control System	LNB - TFS 2000	Exist. LNB w/OFA	ROFA	SNCR	SCR	LNB - TFS 2000	LNB - TFS 2000	LNB - TFS 2000	LNB - TFS 2000	LNB - TFS 2000
SO2 Emission Control System	Wet FGD	Wet FGD	Wet FGD	Wet FGD	Wet FGD	Wet FGD	Wet FGD	Wet FGD	Wet FGD	Wet FGD
PM Emission Control System	ESP	ESP	ESP	ESP	ESP	ESP	Flue Gas Conditioning	Fabric Filter	Fabric Filter	Fabric Filter
TOTAL INSTALLED CAPITAL COST (\$)	0	0	20,628,122	13,427,239	120,375,484	12,989,900	0	46,386,333	0	0
FIRST YEAR O&M COST (\$)	0	0	0	0	0	0	0	0	0	0
Operating Labor (\$)	0	0	42,000	95,000	182,000	25,550	0	0	0	51,089
Maintenance Material (\$)	0	0	83,000	142,500	243,000	17,033	10,000	0	10,000	76,649
Maintenance Labor (\$)	0	0	0	0	0	0	0	0	0	0
Administrative Labor (\$)	0	0	105,000	237,500	405,000	42,583	10,000	127,749	0	0
TOTAL FIXED O&M COST	0	0	105,000	237,500	405,000	42,583	10,000	127,749	0	0
Makeup Water Cost	0	0	0	0	0	30,503	0	0	0	0
Reagent Cost	0	0	0	536,432	912,848	533,206	145,854	0	0	0
SCR Catalyst / FF Bag Cost	0	0	0	0	594,000	0	0	300,040	0	0
Waste Disposal Cost	0	0	0	0	0	442,958	0	0	0	0
Electric Power Cost	0	0	2,528,012	208,926	1,292,333	208,826	18,710	1,326,877	0	0
TOTAL VARIABLE O&M COST	0	0	2,528,012	208,926	1,292,333	208,826	18,710	1,326,877	0	0
TOTAL FIRST YEAR O&M COST	0	0	2,528,012	208,926	1,292,333	208,826	18,710	1,326,877	0	0
FIRST YEAR DEBT SERVICE (\$)	0	0	1,952,798	1,277,304	11,498,623	1,236,652	0	4,602,887	0	0
TOTAL FIRST YEAR COST (\$)	0	0	4,885,808	2,260,162	14,652,803	2,494,928	175,564	6,957,652	0	0
Power Consumption (MW)	0.0	0.0	6.4	0.5	3.3	0.5	0.1	3.4	0	0
Annual Power Usage (Million kWh/yr)	0.0	0.0	50.6	4.2	25.6	4.2	0.4	26.5	0	0
CONTROL COST (\$/Ton Removed)	0.0%	0.0%	8.3%	16.7%	70.8%	0.0%	0.0%	0.0%	0.0%	0.0%
NOx Removal Rate (%)	0	0	473	946	4,021	0	0	0	0	0
NOx Removed (Tons/Yr)	0	0	9,695	2,389	3,654	0	0	0	0	0
First Year Average Control Cost (\$/Ton NOx Removed)	0	0	2,389	2,389	4,044	0	0	0	0	0
Incremental Control Cost (\$/Ton NOx Removed)	0	0	3-2	4-2	5-4	0	0	0	0	0
SO2 Removal Rate (%)	77.8%	0.0%	0.0%	0.0%	0.0%	62.5%	0.0%	0.0%	0.0%	0.0%
SO2 Removed (Tons/Yr)	0	0	0	0	0	3,950	0	0	0	0
First Year Average Control Cost (\$/Ton SO2 Rem.)	0	0	0	0	0	632	0	0	0	0
Incremental Control Cost (\$/Ton SO2 Removed)	Base	0	0	0	0	8-1	0	0	0	0
PM Removal Rate (%)	99.13%	0.00%	0.00%	0.00%	0.00%	0.00%	59.46%	79.73%	0	0
PM Removed (Tons/Yr)	0	0	0	0	0	0	1,041	1,395	0	0
First Year Average Control Cost (\$/Ton PM Rem.)	0	0	0	0	0	0	169	4,556	0	0
Incremental Control Cost (\$/Ton PM Removed)	Base	0	0	0	0	0	169	17,426	0	0
PRESENT WORTH COST (\$)	0	0	52,697,883	25,435,659	159,901,524	28,372,107	2,145,015	69,824,582	0	0

INPUT CALCULATIONS

Parameter	Tangential-Fired PC										Comments
	Current Operation	NOx Control			SO2 Control			PM Control			
	1	2	3	4	5	8	9	10			
Case	1	2	3	4	5	8	9	10			
NOx Emission Control System	LNB - TFS 2000 Wet FGD	Exist. LNB w/OFA Wet FGD	ROFA Wet FGD	SNCR Wet FGD	SCR Wet FGD	LNB - TFS 2000 Upgraded Wet FGD	LNB - TFS 2000 Wet FGD	LNB - TFS 2000 Wet FGD			
SO2 Emission Control System	ESP	ESP	ESP	ESP	ESP	ESP	Flue Gas Conditioning	Fabric Filter			
PM Emission Control System	ESP	ESP	ESP	ESP	ESP	ESP	Flue Gas Conditioning	Fabric Filter			
Unit Design and Coal Characteristics											
Type of Unit	PC	PC	PC	PC	PC	PC	PC	PC	PC	PC	
Net Power Output (kW)	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000	
Net Plant Heat Rate (Btu/kWh)	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	
Boiler Fuel	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	
Coal Heating Value (Btu/Lb)	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	
Coal Sulfur Content (wt %)	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	
Coal Ash Content (wt %)	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	
Boiler Heat Input, each (MMBtu/Hr)	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	
Coal Flow Rate (Lb/Hr)	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	
Coal Flow Rate (MMBtu/Yr)	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	
	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	
Emissions											
Uncontrolled SO2 (Lb/Hr)	7,210	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	
(Lb/MMBtu)	1.20	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	
(Lb Moles/Hr)	112.54	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	
(Tons/Yr)	28,421	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	
SO2 Removal Rate (%)	77.8%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	
(Lb/Hr)	6,608	0	0	0	0	0	0	0	0	0	
(Ton/Yr)	22,106	0	0	0	0	0	0	0	0	0	
SO2 Emission Rate (Lb/Hr)	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	
(Lb/MMBtu)	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	
(Ton/Yr)	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	
Uncontrolled NOx (Lb/Hr)	1,440	1,440	1,440	1,440	1,440	1,440	1,440	1,440	1,440	1,440	
(Lb/MMBtu)	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	
(Lb Moles/Hr)	47.98	47.98	47.98	47.98	47.98	47.98	47.98	47.98	47.98	47.98	
(Tons/Yr)	5,676	5,676	5,676	5,676	5,676	5,676	5,676	5,676	5,676	5,676	
NOx Removal Rate (%)	0.0%	0.0%	0.0%	16.7%	70.8%	0%	0%	0%	0%	0%	
(Lb/Hr)	0	0	0	240	1,020	0	0	0	0	0	
(Lb Moles/Hr)	0	0	0	800	3,399	0	0	0	0	0	
(Ton/Yr)	0	0	0	946	4,021	0	0	0	0	0	
NOx Emission Rate (Lb/Hr)	1,440	1,440	1,320	1,200	420	1,440	1,440	1,440	1,440	1,440	
(Lb/MMBtu)	0.24	0.24	0.22	0.20	0.07	0.24	0.24	0.24	0.24	0.24	
(Ton/Yr)	5,676	5,676	5,203	4,730	1,656	5,676	5,676	5,676	5,676	5,676	
Uncontrolled Fly Ash (Lb/Hr)	51,177	444	444	444	444	444	444	444	444	444	
(Lb/MMBtu)	8.530	0.074	0.074	0.074	0.074	0.074	0.074	0.074	0.074	0.074	
(Lb Moles/Hr)	1,705.3	14.8	14.8	14.8	14.8	14.8	14.8	14.8	14.8	14.8	
(Tons/Yr)	201,739	1,750	1,750	1,750	1,750	1,750	1,750	1,750	1,750	1,750	
Fly Ash Removal Rate (%)	99.13%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
(Lb/Hr)	50,733	0	0	0	0	0	0	0	0	0	
(Ton/Yr)	189,988	0	0	0	0	0	0	0	0	0	
Fly Ash Emission Rate (Lb/Hr)	444	444	444	444	444	444	444	444	444	444	
(Lb/MMBtu)	0.074	0.074	0.074	0.074	0.074	0.074	0.074	0.074	0.074	0.074	
(Ton/Yr)	1,750	1,750	1,750	1,750	1,750	1,750	1,750	1,750	1,750	1,750	

Parameter	Current Operation		NOx Control				SO2 Control		PM Control			Comments
	1	2	ROFA	SNCR	SCR	8	9	10	Flue Gas Conditioning	Fabric Filter		
Case												
General Plant Data												
Annual Operation (Hours/Year)	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	
Annual On-Site Power Plant Capacity Factor	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	
Economic Factors												
Interest Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	
Discount Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	
Plant Economic Life (Years)	20	20	20	20	20	20	20	20	20	20	20	
Installed Capital Costs												
NOx Emission Control System (\$2006)	0	0	20,528,122	13,427,239	120,875,494	12,959,500	0	0	0	0	0	
SO2 Emission Control System (\$2006)	0	0	0	0	0	12,959,500	0	0	0	0	0	
PM Emission Control System (\$2006)	0	0	0	0	0	0	0	0	0	0	0	
Total Emission Control Systems (\$2006)	0	0	20,528,122	13,427,239	120,875,494	12,959,500	0	0	0	0	0	
NOx Emission Control System (\$/KW)	0	0	39	25	226	0	0	0	0	0	0	
SO2 Emission Control System (\$/KW)	0	0	0	0	0	25	0	0	0	0	0	
PM Emission Control System (\$/KW)	0	0	0	0	0	0	0	0	0	0	0	
Total Emission Control Systems (\$/KW)	0	0	39	25	226	25	0	0	0	0	0	
Total Fixed Operation & Maintenance Costs												
Operating Labor (\$)	0	0	0	0	0	0	0	0	0	0	0	
Maintenance Material (\$)	0	0	42,000	95,000	162,000	25,500	0	0	0	0	0	
Maintenance Labor (\$)	0	0	63,000	142,500	243,000	17,033	0	0	0	0	0	
Administrative Labor (\$)	0	0	0	0	0	0	0	0	0	0	0	
Total Fixed O&M Cost (\$)	0	0	105,000	237,500	405,000	42,533	0	0	0	0	0	
Annual Fixed O&M Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Water Cost												
Wakeup Water Usage (Gpm)	0	0	0	0	0	53	0	0	0	0	0	
Unit Price (\$/1000 Gallons)	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	
First Year Water Cost (\$)	0	0	0	0	0	30,503	0	0	0	0	0	
Annual Water Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Reagent Cost												
Unit Cost (\$/Ton)	None	None	None	Urea	Anhydrous NH3	Soda Ash	Elemental Sulfur	None	None	None	None	
(\$/Lb)	0.00	0.00	0.00	370	400	80.00	370	0.00	0.00	0.00	0.00	
Molar Stoichiometry	0.00	0.00	0.00	0.46	1.00	1.02	0.185	0.00	0.00	0.00	0.00	
Reagent Purity (Wt.%)	0.00	0.00	0.00	100%	100%	100%	100%	0.00	0.00	0.00	0.00	
Reagent Usage (Lb/Hr)	0	0	0	366	579	1,891	100	0	0	0	0	
First Year Reagent Cost (\$)	0	0	0	536,432	912,848	533,206	145,854	0	0	0	0	
Annual Reagent Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
SCR Catalyst / FF Bag Replacement Cost												
Annual SCR Catalyst / No. FF Bags	0	0	0	0	198	0	0	0	0	0	0	
SCR Catalyst / Bag Cost (\$/Yr)	3,000	3,000	3,000	3,000	3,000	104	3,000	104	3,000	104	3,000	
First Year SCR Catalyst / Bag Replac. Cost (\$)	0	0	0	0	594,000	0	0	0	0	0	0	
Annual SCR Catalyst / Bag Cost Esc. Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
FGD Waste Disposal Cost												
FGD Solid Waste Disposal Rate, Dry (Lb/Hr)	0	0	0	0	0	4,618	0	0	0	0	0	
FGD Waste Disposal Unit Cost (\$/Dry Ton)	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	
First Year FGD Waste Disposal Cost (\$)	0	0	0	0	0	442,958	0	0	0	0	0	
Annual Waste Disposal Cost Esc. Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Auxiliary Power Cost												
Auxiliary Power Requirement (% of Plant Output)	0.00%	0.00%	1.21%	0.10%	0.61%	0.10%	0.01%	0.64%	0.01%	0.64%	0.64%	
Unit Cost (\$2006/MW-Hr)	0.00	0.00	6.41	0.53	3.25	0.53	0.05	3.37	0.05	3.37	3.37	
First Year Auxiliary Power Cost (\$)	60.00	60.00	50.00	50.00	50.00	50.00	50.00	50.00	50.00	50.00	50.00	
Annual Power Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	

Input Tables

Table 1 - Cases

Index No.	Name of Unit Case →	NOx Control			SO2 Control			PM Control			
		1	2	3	4	5	6	7	8	9	10
1	Dave Johnston Unit 3	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Dry FGD w/Fabric Filter	Wet FGD w/ESPP	N/A	N/A	Fabric Filter
2	Dave Johnston Unit 4	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Wet FGD w/Fabric Filter	Wet FGD w/Fabric Filter	Fabric Filter	Fabric Filter	Fabric Filter
3	Jim Bridger Unit 1	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Wet FGD w/Fabric Filter	Wet FGD w/Fabric Filter	Fluor Gas Conditioning	Fluor Gas Conditioning	Fabric Filter
4	Jim Bridger Unit 2	Current Operation	Excl. LNB w/OFA	ROFA	SNCR	SNCR	Wet FGD w/Fabric Filter	Wet FGD w/Fabric Filter	Fluor Gas Conditioning	Fluor Gas Conditioning	Fabric Filter
5	Jim Bridger Unit 3	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Wet FGD w/Fabric Filter	Wet FGD w/Fabric Filter	Fluor Gas Conditioning	Fluor Gas Conditioning	Fabric Filter
6	Jim Bridger Unit 4	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Wet FGD w/Fabric Filter	Wet FGD w/Fabric Filter	Fluor Gas Conditioning	Fluor Gas Conditioning	Fabric Filter
7	Naughton Unit 1	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Wet FGD w/ESPP	Wet FGD w/ESPP	Fluor Gas Conditioning	Fluor Gas Conditioning	Fabric Filter
8	Naughton Unit 2	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Wet FGD w/ESPP	Wet FGD w/ESPP	Fluor Gas Conditioning	Fluor Gas Conditioning	Fabric Filter
9	Naughton Unit 3	Current Operation	Edat. LNB w/OFA	ROFA	SNCR	SNCR	Wet FGD w/ESPP	Wet FGD w/ESPP	Fluor Gas Conditioning	Fluor Gas Conditioning	Fabric Filter
10	Wyodak Unit 1	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Wet FGD	Wet FGD	Fluor Gas Conditioning	Fluor Gas Conditioning	Fabric Filter

Table 2 - Unit Design and Coal Characteristics

Index No.	Name of Unit	Current Emission Control Systems			Unit Design			Coal Quality			
		NOx	SO2	PM	Boiler Design	Net Power Output (kW)	Net Plant Heat Rate (Btu/kWhr)	Coal	Heating Value, HHV (Btu/Lb)	Sulfur Content (Wt.%)	Ash Content (Wt.%)
1	Dave Johnston Unit 3	None	None	ESP	3-Cell Burner, Opposed Wall-Fired PC	250,000	11,200	Dry Fork PRB	7,784	0.47%	5.01%
2	Dave Johnston Unit 4	Windbox Mods. LNCFS-1 & Windbox Mods.	Line Added to Venturi Scrubber	Venturi Scrubber	Tangential-Fired PC	360,000	11,390	Dry Fork PRB	7,784	0.47%	5.01%
3	Jim Bridger Unit 1	None	Wet FGD	ESP	Tangential-Fired PC	530,000	11,320	Bridger Mine Underground	9,660	0.58%	10.30%
4	Jim Bridger Unit 2	LNB - TFS 2000 LNCFS-1 & Windbox Mods.	Wet FGD	ESP	Tangential-Fired PC	530,000	11,320	Bridger Mine Underground	9,660	0.58%	10.30%
5	Jim Bridger Unit 3	LNCFS-1 & Windbox Mods.	Wet FGD	ESP	Tangential-Fired PC	530,000	11,320	Bridger Mine Underground	9,660	0.58%	10.30%
6	Jim Bridger Unit 4	None	Wet FGD	ESP	Tangential-Fired PC	530,000	11,320	Bridger Mine Underground	9,660	0.58%	10.30%
7	Naughton Unit 1	None	None	ESP	Tangential-Fired PC	173,000	10,684	Kemmerer Mine	9,970	0.60%	4.64%
8	Naughton Unit 2	None	None	ESP	Tangential-Fired PC	226,000	10,574	Kemmerer Mine	9,970	0.60%	4.64%
9	Naughton Unit 3	LNCFS II LNB	Wet FGD	ESP	Tangential-Fired PC	356,000	10,336	Kemmerer Mine	9,970	0.50%	4.64%
10	Wyodak Unit 1	LNB	Dry FGD	ESP	Opposed Wall-Fired PC	335,000	12,087	Clovis Point Mine	7,977	0.85%	7.46%

Table 3 - Emissions

Index No.	Name of Unit	Current Emission Rates (Lb/MMBtu)		NOx Control Emission Rates (Lb/MMBtu)					SO2 Control Emission Rates (Lb/MMBtu)					PM Emission Rates (Lb/MMBtu)									
		Controlled	Controlled NOx	Case 2	Case 3	Case 4	Case 5	Case 6	Case 7	Case 8	Case 9	Case 10	Case 1	Case 2	Case 3	Case 4	Case 5	Case 6	Case 7	Case 8	Case 9	Case 10	
1	Dave Johnston Unit 3	1.20	0.70	0.27	0.21	0.20	0.07	0.21	0.15	0.15	0.10	0.21	0.15	0.15	0.10	0.07	0.21	0.15	0.15	0.10	N/A	N/A	0.015
2	Dave Johnston Unit 4	0.33	0.48	0.15	0.19	0.12	0.07	0.15	0.12	0.12	0.10	0.07	0.12	0.12	0.10	0.07	0.15	N/A	N/A	0.10	N/A	N/A	0.015
3	Jim Bridger Unit 1	0.27	0.45	0.24	0.22	0.20	0.07	0.24	0.20	0.20	0.10	0.07	0.20	0.20	0.10	0.07	N/A	N/A	N/A	0.10	0.030	0.030	0.015
4	Jim Bridger Unit 2	0.27	0.45	0.24	0.22	0.20	0.07	0.24	0.20	0.20	0.10	0.07	0.20	0.20	0.10	0.07	N/A	N/A	N/A	0.10	0.030	0.030	0.015
5	Jim Bridger Unit 3	0.17	0.45	0.24	0.22	0.20	0.07	0.24	0.20	0.20	0.10	0.07	0.20	0.20	0.10	0.07	N/A	N/A	N/A	0.10	0.030	0.030	0.015
6	Jim Bridger Unit 4	1.20	0.58	0.24	0.28	0.18	0.07	0.24	0.28	0.18	0.15	0.07	0.24	0.28	0.18	0.07	0.18	0.18	0.15	0.10	0.040	0.040	0.015
7	Naughton Unit 1	1.20	0.54	0.24	0.28	0.18	0.07	0.24	0.28	0.18	0.15	0.07	0.24	0.28	0.18	0.07	0.18	0.18	0.15	0.10	0.040	0.040	0.015
8	Naughton Unit 2	0.50	0.45	0.35	0.30	0.25	0.07	0.35	0.30	0.25	0.18	0.07	0.35	0.30	0.25	0.07	0.25	N/A	N/A	0.10	0.040	0.040	0.015
9	Naughton Unit 3	0.50	0.50	0.23	0.22	0.18	0.07	0.23	0.22	0.18	0.15	0.07	0.23	0.22	0.18	0.07	0.25	N/A	N/A	0.10	0.025	0.025	0.015
10	Wyodak Unit 1	0.50	0.50	0.23	0.22	0.18	0.07	0.23	0.22	0.18	0.15	0.07	0.23	0.22	0.18	0.07	0.25	N/A	N/A	0.10	0.025	0.025	0.015

Table 4 - Case 1 O&M Costs (Current Operation)

Index No.	Name of Unit	Annual Fixed O&M Costs					Variable Operating Requirements						
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Reagent	Makeup Water Use (Gpm)	Reagent Molar Stoich.	Aux. Power Usage (MW)				
1	Dave Johnston Unit 3	\$ -	\$ -	\$ -	\$ -	\$ -	-	-	-	-	-	-	-
2	Dave Johnston Unit 4	\$ -	\$ -	\$ -	\$ -	\$ -	-	-	-	-	-	-	-
3	Jim Bridger Unit 1	\$ -	\$ -	\$ -	\$ -	\$ -	-	-	-	-	-	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	\$ -	-	-	-	-	-	-	-
5	Jim Bridger Unit 3	\$ -	\$ -	\$ -	\$ -	\$ -	-	-	-	-	-	-	-
6	Jim Bridger Unit 4	\$ -	\$ -	\$ -	\$ -	\$ -	-	-	-	-	-	-	-
7	Naughton Unit 1	\$ -	\$ -	\$ -	\$ -	\$ -	-	-	-	-	-	-	-
8	Naughton Unit 2	\$ -	\$ -	\$ -	\$ -	\$ -	-	-	-	-	-	-	-
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	\$ -	-	-	-	-	-	-	-
10	Wyodak Unit 1	\$ -	\$ -	\$ -	\$ -	\$ -	-	-	-	-	-	-	-

Table 5 - Case 2 O&M Costs (LNB w/IOFA)

Index No.	Name of Unit	Annual Fixed O&M Costs					Variable Operating Requirements						
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Reagent	Makeup Water Use (Gpm)	Reagent Molar Stoich.	Aux. Power Usage (MW)				
1	Dave Johnston Unit 3	\$ -	\$ 40,000	\$ 60,000	\$ -	\$ -	-	-	-	-	-	-	-
2	Dave Johnston Unit 4	\$ -	\$ 36,000	\$ 54,000	\$ -	\$ -	-	-	-	-	-	-	-
3	Jim Bridger Unit 1	\$ -	\$ 28,000	\$ 42,000	\$ -	\$ -	-	-	-	-	-	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	\$ -	-	-	-	-	-	-	-
5	Jim Bridger Unit 3	\$ -	\$ 28,000	\$ 42,000	\$ -	\$ -	-	-	-	-	-	-	-
6	Jim Bridger Unit 4	\$ -	\$ 28,000	\$ 42,000	\$ -	\$ -	-	-	-	-	-	-	-
7	Naughton Unit 1	\$ -	\$ 32,000	\$ 48,000	\$ -	\$ -	-	-	-	-	-	-	-
8	Naughton Unit 2	\$ -	\$ -	\$ -	\$ -	\$ -	-	-	-	-	-	-	-
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	\$ -	-	-	-	-	-	-	-
10	Wyodak Unit 1	\$ -	\$ 24,000	\$ 36,000	\$ -	\$ -	-	-	-	-	-	-	-

Table 6 - Case 3 O&M Costs (Mobotec ROFA)

Index No.	Name of Unit	Annual Fixed O&M Costs					Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor		Reagent	Stoich.	Aux. Power Usage (MW)	Reagent Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ 60,000	\$ 90,000	\$ -	-	None	-	2.76	-	-
2	Dave Johnston Unit 4	\$ -	\$ 54,000	\$ 81,000	\$ -	-	None	-	4.33	-	-
3	Jim Bridger Unit 1	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41	-	-
4	Jim Bridger Unit 2	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41	-	-
5	Jim Bridger Unit 3	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41	-	-
6	Jim Bridger Unit 4	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41	-	-
7	Naughton Unit 1	\$ -	\$ 48,000	\$ 72,000	\$ -	-	None	-	1.42	-	-
8	Naughton Unit 2	\$ -	\$ 48,000	\$ 72,000	\$ -	-	None	-	2.61	-	-
9	Naughton Unit 3	\$ -	\$ 48,000	\$ 72,000	\$ -	-	None	-	4.47	-	-
10	Wyodak Unit 1	\$ -	\$ 36,000	\$ 54,000	\$ -	-	None	-	5.22	-	-

Table 7 - Case 4 O&M Costs (LNB w/OFA & SNCR)

Index No.	Name of Unit	Annual Fixed O&M Costs					Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor		Reagent	Stoich.	Aux. Power Usage (MW)	Reagent Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ 95,000	\$ 147,000	\$ -	-	Urea	0.41	0.23	-	-
2	Dave Johnston Unit 4	\$ -	\$ 105,000	\$ 157,500	\$ -	-	Urea	0.45	0.33	-	-
3	Jim Bridger Unit 1	\$ -	\$ 123,000	\$ 184,500	\$ -	-	Urea	0.46	0.53	-	-
4	Jim Bridger Unit 2	\$ -	\$ 95,000	\$ 142,500	\$ -	-	Urea	0.45	0.53	-	-
5	Jim Bridger Unit 3	\$ -	\$ 122,000	\$ 183,000	\$ -	-	Urea	0.45	0.52	-	-
6	Jim Bridger Unit 4	\$ -	\$ 123,000	\$ 184,500	\$ -	-	Urea	0.45	0.53	-	-
7	Naughton Unit 1	\$ -	\$ 83,000	\$ 124,500	\$ -	-	Urea	0.45	0.16	-	-
8	Naughton Unit 2	\$ -	\$ 93,000	\$ 139,500	\$ -	-	Urea	0.51	0.22	-	-
9	Naughton Unit 3	\$ -	\$ 75,000	\$ 112,500	\$ -	-	Urea	0.45	0.33	-	-
10	Wyodak Unit 1	\$ -	\$ 93,000	\$ 139,500	\$ -	-	Urea	0.45	0.34	-	-

Table 8 - Case 5 O&M Costs (LNB w/OFA & SCR)

Index No.	Name of Unit	Annual Fixed O&M Costs					Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor		Reagent	Stoich.	Aux. Power Usage (MW)	Catalyst Replace. (m³)	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ 155,000	\$ 232,500	\$ -	-	Anhydrous NH3	1.00	128	1.57	-
2	Dave Johnston Unit 4	\$ -	\$ 165,000	\$ 249,000	\$ -	-	Anhydrous NH3	1.00	123	2.29	-
3	Jim Bridger Unit 1	\$ -	\$ 190,000	\$ 285,000	\$ -	-	Anhydrous NH3	1.00	198	3.28	-
4	Jim Bridger Unit 2	\$ -	\$ 162,000	\$ 243,000	\$ -	-	Anhydrous NH3	1.00	198	3.25	-
5	Jim Bridger Unit 3	\$ -	\$ 190,000	\$ 285,000	\$ -	-	Anhydrous NH3	1.00	200	3.22	-
6	Jim Bridger Unit 4	\$ -	\$ 190,000	\$ 285,000	\$ -	-	Anhydrous NH3	1.00	214	3.36	-
7	Naughton Unit 1	\$ -	\$ 132,000	\$ 198,000	\$ -	-	Anhydrous NH3	1.00	67	0.98	-
8	Naughton Unit 2	\$ -	\$ 160,000	\$ 240,000	\$ -	-	Anhydrous NH3	1.00	101	1.34	-
9	Naughton Unit 3	\$ -	\$ 156,000	\$ 234,000	\$ -	-	Anhydrous NH3	1.00	167	1.99	-
10	Wyodak Unit 1	\$ -	\$ 181,000	\$ 271,500	\$ -	-	Anhydrous NH3	1.00	160	2.42	-

Table 9 - Case 6 O&M Costs (Dry FGD)

Index No.	Name of Unit	Annual Fixed O&M Costs					Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Admn. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Stoich.	Annual FF Bag Replace.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 506,128	\$ 714,175	\$ 476,928	\$ -	\$ -	173	Lime	1.15	-	2.49
2	Dave Johnston Unit 4	\$ -	\$ -	\$ -	\$ -	\$ -	-	Lime	-	-	-
3	Jim Bridger Unit 1	\$ -	\$ -	\$ -	\$ -	\$ -	-	Lime	-	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	\$ -	-	Lime	-	-	-
5	Jim Bridger Unit 3	\$ -	\$ -	\$ -	\$ -	\$ -	-	Lime	-	-	-
6	Jim Bridger Unit 4	\$ -	\$ -	\$ -	\$ -	\$ -	-	Lime	-	-	-
7	Naughton Unit 1	\$ 506,128	\$ 587,643	\$ 391,762	\$ -	\$ -	120	Lime	1.40	-	1.64
8	Naughton Unit 2	\$ 506,128	\$ 860,174	\$ 573,044	\$ -	\$ -	165	Lime	1.40	-	2.25
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	\$ -	-	Lime	-	-	-
10	Wyodak Unit 1	\$ -	\$ 21,900	\$ 14,600	\$ -	\$ -	25	Lime	1.10	-	0.11

Table 10 - Case 7 O&M Costs (Dry FGD w/Fabric Filter)

Index No.	Name of Unit	Annual Fixed O&M Costs					Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Admn. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Stoich.	Annual FF Bag Replace.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 506,128	\$ 714,175	\$ 476,928	\$ -	\$ -	173	Lime	1.15	1,457	3.88
2	Dave Johnston Unit 4	\$ 506,128	\$ 1,102,286	\$ 734,858	\$ -	\$ -	248	Lime	1.10	1,798	4.54
3	Jim Bridger Unit 1	\$ -	\$ -	\$ -	\$ -	\$ -	-	Lime	-	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	\$ -	-	Lime	-	-	-
5	Jim Bridger Unit 3	\$ -	\$ -	\$ -	\$ -	\$ -	-	Lime	-	-	-
6	Jim Bridger Unit 4	\$ -	\$ -	\$ -	\$ -	\$ -	-	Lime	-	-	-
7	Naughton Unit 1	\$ 506,128	\$ 632,660	\$ 455,286	\$ -	\$ -	120	Lime	1.15	865	2.66
8	Naughton Unit 2	\$ 506,128	\$ 905,190	\$ 640,568	\$ -	\$ -	165	Lime	1.15	1,193	3.63
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	\$ -	-	Lime	-	-	-
10	Wyodak Unit 1	\$ -	\$ -	\$ -	\$ -	\$ -	-	Lime	-	-	-

Table 11 - Case 8 O&M Costs (Wet FGD)

Index No.	Name of Unit	Annual Fixed O&M Costs					Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Admn. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Stoich.	Annual FF Bag Replace.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 809,804	\$ 1,182,587	\$ 782,391	\$ -	\$ -	230	Lime	1.02	-	3.45
2	Dave Johnston Unit 4	\$ 809,804	\$ 1,430,764	\$ 953,856	\$ -	\$ -	330	Lime	1.02	1,798	6.29
3	Jim Bridger Unit 1	\$ -	\$ 25,560	\$ 17,033	\$ -	\$ -	53	Soda Ash	1.02	-	0.53
4	Jim Bridger Unit 2	\$ -	\$ 25,560	\$ 17,033	\$ -	\$ -	52	Soda Ash	1.02	-	0.52
5	Jim Bridger Unit 3	\$ -	\$ 25,560	\$ 17,033	\$ -	\$ -	27	Soda Ash	1.02	-	0.53
6	Jim Bridger Unit 4	\$ -	\$ 25,560	\$ 17,033	\$ -	\$ -	160	Lime	1.05	-	2.40
7	Naughton Unit 1	\$ 809,804	\$ 963,589	\$ 642,393	\$ -	\$ -	220	Lime	1.05	-	3.30
8	Naughton Unit 2	\$ 809,804	\$ 1,226,386	\$ 817,591	\$ -	\$ -	86	Soda Ash	1.02	-	0.33
9	Naughton Unit 3	\$ -	\$ 21,900	\$ 14,600	\$ -	\$ -	82	Lime	1.02	-	1.75
10	Wyodak Unit 1	\$ 303,677	\$ 328,496	\$ 219,998	\$ -	\$ -	-	-	-	-	-

Table 12 - Case 9 O&M Costs (Flue Gas Conditioning)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements					
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Usage (Lb/Hr)	Annual FF Bag Replace.	Aux. Power Usage (MW)	
1	Dave Johnston Unit 3	\$ -	\$ -	\$ -	\$ -	-	None	-	-	-	
2	Dave Johnston Unit 4	\$ -	\$ -	\$ -	\$ -	-	None	-	-	-	
3	Jim Bridger Unit 1	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	100	-	0.05	
4	Jim Bridger Unit 2	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	100	-	0.05	
5	Jim Bridger Unit 3	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	100	-	0.05	
6	Jim Bridger Unit 4	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	33	-	0.05	
7	Naughton Unit 1	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	43	-	0.05	
8	Naughton Unit 2	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	67	-	0.05	
9	Naughton Unit 3	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	63	-	0.05	
10	Wyodak Unit 1	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	63	-	0.05	

Table 13 - Case 10 O&M Costs (Fabric Filter)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements					
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Annual FF Bag Replace.	Aux. Power Usage (MW)	
1	Dave Johnston Unit 3	\$ -	\$ 45,016	\$ 67,524	\$ -	-	None	-	1,457	1.38	
2	Dave Johnston Unit 4	\$ -	\$ 68,133	\$ 102,199	\$ -	-	None	-	1,798	2.35	
3	Jim Bridger Unit 1	\$ -	\$ 51,099	\$ 76,649	\$ -	-	None	-	2,865	3.39	
4	Jim Bridger Unit 2	\$ -	\$ 51,099	\$ 76,649	\$ -	-	None	-	2,865	3.37	
5	Jim Bridger Unit 3	\$ -	\$ 51,099	\$ 76,649	\$ -	-	None	-	2,827	3.33	
6	Jim Bridger Unit 4	\$ -	\$ 51,099	\$ 76,649	\$ -	-	None	-	2,865	3.39	
7	Naughton Unit 1	\$ -	\$ 45,016	\$ 67,524	\$ -	-	None	-	865	1.01	
8	Naughton Unit 2	\$ -	\$ 45,016	\$ 67,524	\$ -	-	None	-	1,193	1.38	
9	Naughton Unit 3	\$ -	\$ 48,666	\$ 72,999	\$ -	-	None	-	1,799	2.06	
10	Wyodak Unit 1	\$ -	\$ 48,666	\$ 72,999	\$ -	-	None	-	1,798	2.06	

Table 14 - Major Materials Design and Supply Costs

Index No.	Name of Unit (Case ->)	NOx Control			SO2 Control			PM Control	
		2	3	4	6	7	8	9	10
1	Dave Johnston Unit 3	\$ 3,221,912	\$ 3,556,617	\$ 5,773,000	\$ 83,871,000	\$ 142,077,000	\$ 108,865,669	\$ -	\$ 18,359,000
2	Dave Johnston Unit 4	\$ 2,673,501	\$ 4,343,492	\$ 7,171,085	\$ -	\$ 137,267,000	\$ 178,174,384	\$ -	\$ 30,853,500
3	Jim Bridger Unit 1	\$ 2,981,962	\$ 6,056,955	\$ 9,528,000	\$ -	\$ -	\$ 8,010,093	\$ -	\$ 29,814,000
4	Jim Bridger Unit 2	\$ -	\$ 6,056,955	\$ 9,528,000	\$ -	\$ -	\$ 8,010,093	\$ -	\$ 29,814,000
5	Jim Bridger Unit 3	\$ 2,981,962	\$ 6,056,955	\$ 9,528,000	\$ -	\$ -	\$ 8,010,093	\$ -	\$ 29,814,000
6	Jim Bridger Unit 4	\$ 2,981,962	\$ 6,056,955	\$ 9,528,000	\$ -	\$ -	\$ 8,010,093	\$ -	\$ 29,814,000
7	Naughton Unit 1	\$ 2,502,123	\$ 2,675,792	\$ 7,257,000	\$ 26,619,000	\$ 44,000,000	\$ 44,000,000	\$ 800,000	\$ 18,462,000
8	Naughton Unit 2	\$ 2,570,674	\$ 3,123,633	\$ 8,784,000	\$ 39,262,000	\$ 57,621,000	\$ 56,000,000	\$ 800,000	\$ 20,105,000
9	Naughton Unit 3	\$ -	\$ 4,351,377	\$ 11,203,578	\$ 47,834,000	\$ -	\$ 2,963,000	\$ 800,000	\$ -
10	Wyodak Unit 1	\$ 3,187,636	\$ 4,500,245	\$ 7,234,860	\$ 996,100	\$ -	\$ 178,174,384	\$ 1,247,061	\$ 20,105,000

CAPITAL COST

Jim Bridger Unit 2

Parameter	NOX Control			SO2 Control			PM Control		
	ROFA Wet FGD ESP	SNCR Wet FGD ESP	SCR Wet FGD ESP	N/A	N/A	Wet FGD ESP	Wet FGD ESP	Wet FGD ESP	Fabric Filter
NOX Emission Control System									
SO2 Emission Control System									
PM Emission Control System									
CAPITAL COST COMPONENT									
LNB w/OFA or ROFA									
Major Materials Design and Supply	Vendor	Vendor	Vendor	Vendor	Vendor	Vendor	Vendor	Vendor	Vendor
Contingency	85.3%	85.3%	85.3%	85.3%	85.3%	85.3%	85.3%	85.3%	85.3%
Labor Premium	51.7%	51.7%	51.7%	51.7%	51.7%	51.7%	51.7%	51.7%	51.7%
EPC Premium	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
Boiler Reinforcement (Allowance)	13.2%	13.2%	13.2%	13.2%	13.2%	13.2%	13.2%	13.2%	13.2%
Escalation	16.4%	16.4%	16.4%	16.4%	16.4%	16.4%	16.4%	16.4%	16.4%
Surcharge	12.2%	12.2%	12.2%	12.2%	12.2%	12.2%	12.2%	12.2%	12.2%
AFUDC									
Subtotal	\$18,711,036	\$18,711,036	\$18,711,036	\$18,711,036	\$18,711,036	\$18,711,036	\$18,711,036	\$18,711,036	\$18,711,036
Total Capital Cost for LNB w/OFA or ROFA	\$20,224,122	\$20,224,122	\$20,224,122	\$20,224,122	\$20,224,122	\$20,224,122	\$20,224,122	\$20,224,122	\$20,224,122
SNCR or SCR									
Major Materials Design and Supply	Vendor	Vendor	Vendor	Vendor	Vendor	Vendor	Vendor	Vendor	Vendor
Contingency	20.0%	20.0%	20.0%	20.0%	20.0%	20.0%	20.0%	20.0%	20.0%
Labor Premium	5.6%	5.6%	5.6%	5.6%	5.6%	5.6%	5.6%	5.6%	5.6%
EPC Premium	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
Boiler Reinforcement (Allowance)	1.1%	1.1%	1.1%	1.1%	1.1%	1.1%	1.1%	1.1%	1.1%
Escalation	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
Surcharge	2.6%	2.6%	2.6%	2.6%	2.6%	2.6%	2.6%	2.6%	2.6%
AFUDC	11.4%	11.4%	11.4%	11.4%	11.4%	11.4%	11.4%	11.4%	11.4%
Contingency on Adders									
Surcharge and AFUDC									
Total Capital Cost for SNCR or SCR	\$122,000	\$122,000	\$122,000	\$122,000	\$122,000	\$122,000	\$122,000	\$122,000	\$122,000
Dry or Wet FGD, FGC or Fabric Filter									
Major Materials Design and Supply	Vendor	Vendor	Vendor	Vendor	Vendor	Vendor	Vendor	Vendor	Vendor
Contingency	20.0%	20.0%	20.0%	20.0%	20.0%	20.0%	20.0%	20.0%	20.0%
Labor Premium	6.6%	6.6%	6.6%	6.6%	6.6%	6.6%	6.6%	6.6%	6.6%
EPC Premium	8.4%	8.4%	8.4%	8.4%	8.4%	8.4%	8.4%	8.4%	8.4%
Boiler Reinforcement (Allowance)	2.9%	2.9%	2.9%	2.9%	2.9%	2.9%	2.9%	2.9%	2.9%
Sales Tax	1.1%	1.1%	1.1%	1.1%	1.1%	1.1%	1.1%	1.1%	1.1%
Escalation	10.1%	10.1%	10.1%	10.1%	10.1%	10.1%	10.1%	10.1%	10.1%
Surcharge	2.8%	2.8%	2.8%	2.8%	2.8%	2.8%	2.8%	2.8%	2.8%
AFUDC	11.4%	11.4%	11.4%	11.4%	11.4%	11.4%	11.4%	11.4%	11.4%
Contingency on Adders									
Surcharge and AFUDC									
Total Capital Cost for Dry/Wet FGD, FGC or FF	\$29,814,000	\$29,814,000	\$29,814,000	\$29,814,000	\$29,814,000	\$29,814,000	\$29,814,000	\$29,814,000	\$29,814,000

16 of 21

10/2007 4:31 PM

APP A_Prop JB2 BART Economic Analysis_01-11-07.xls / G08

Jim Bridger Unit 2												Exist. LNB w/OFA											
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)												
0	2013	-	-	-	-	-	-	-	-	-	-												
1	2014	-	-	-	-	-	-	-	-	-	-												
2	2015	-	-	-	-	-	-	-	-	-	-												
3	2016	-	-	-	-	-	-	-	-	-	-												
4	2017	-	-	-	-	-	-	-	-	-	-												
5	2018	-	-	-	-	-	-	-	-	-	-												
6	2019	-	-	-	-	-	-	-	-	-	-												
7	2020	-	-	-	-	-	-	-	-	-	-												
8	2021	-	-	-	-	-	-	-	-	-	-												
9	2022	-	-	-	-	-	-	-	-	-	-												
10	2023	-	-	-	-	-	-	-	-	-	-												
11	2024	-	-	-	-	-	-	-	-	-	-												
12	2025	-	-	-	-	-	-	-	-	-	-												
13	2026	-	-	-	-	-	-	-	-	-	-												
14	2027	-	-	-	-	-	-	-	-	-	-												
15	2028	-	-	-	-	-	-	-	-	-	-												
16	2029	-	-	-	-	-	-	-	-	-	-												
17	2030	-	-	-	-	-	-	-	-	-	-												
18	2031	-	-	-	-	-	-	-	-	-	-												
19	2032	-	-	-	-	-	-	-	-	-	-												
20	2033	-	-	-	-	-	-	-	-	-	-												
Present Worth (% of PV)		-	0.0%	-	0.0%	-	0.0%	-	0.0%	-	0.0%												

Jim Bridger Unit 2												ROFA											
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)												
0	2013	105,000	-	-	-	-	2,528,012	2,528,012	1,952,798	4,580,808	9,695												
1	2014	107,100	-	-	-	-	2,578,573	2,578,573	1,952,798	4,638,468	9,606												
2	2015	109,242	-	-	-	-	2,630,144	2,630,144	1,952,798	4,692,182	9,520												
3	2016	111,427	-	-	-	-	2,682,747	2,682,747	1,952,798	4,746,970	10,036												
4	2017	113,655	-	-	-	-	2,736,402	2,736,402	1,952,798	4,802,653	10,154												
5	2018	115,928	-	-	-	-	2,791,130	2,791,130	1,952,798	4,859,654	10,274												
6	2019	118,247	-	-	-	-	2,846,953	2,846,953	1,952,798	4,917,995	10,397												
7	2020	120,612	-	-	-	-	2,903,892	2,903,892	1,952,798	4,977,298	10,523												
8	2021	123,024	-	-	-	-	2,961,970	2,961,970	1,952,798	5,037,789	10,651												
9	2022	125,486	-	-	-	-	3,021,209	3,021,209	1,952,798	5,098,488	10,781												
10	2023	127,994	-	-	-	-	3,081,633	3,081,633	1,952,798	5,162,423	10,914												
11	2024	130,554	-	-	-	-	3,143,265	3,143,265	1,952,798	5,226,616	11,050												
12	2025	133,165	-	-	-	-	3,206,131	3,206,131	1,952,798	5,292,092	11,188												
13	2026	135,829	-	-	-	-	3,270,254	3,270,254	1,952,798	5,358,876	11,329												
14	2027	138,548	-	-	-	-	3,335,659	3,335,659	1,952,798	5,427,000	11,473												
15	2028	141,316	-	-	-	-	3,402,372	3,402,372	1,952,798	5,496,484	11,620												
16	2029	144,142	-	-	-	-	3,470,419	3,470,419	1,952,798	5,567,358	11,770												
17	2030	147,025	-	-	-	-	3,539,828	3,539,828	1,952,798	5,639,649	11,923												
18	2031	149,966	-	-	-	-	3,610,624	3,610,624	1,952,798	5,713,386	12,079												
19	2032	152,965	-	-	-	-	3,682,937	3,682,937	1,952,798	5,788,598	12,238												
20	2033	156,024	-	-	-	-	3,756,786	3,756,786	1,952,798	5,865,188	12,400												
Present Worth (% of PV)		1,282,875	0.0%	-	0.0%	-	30,896,886	30,896,886	20,526,122	62,687,893	5,571												
		2.4%					58.6%	58.6%	39.0%	100.0%													

SNCR												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst/FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)	
0	2013											
1	2014	237,500	-	536,432	-	-	208,928	745,358	1,277,304	2,260,162	2,389	
2	2015	242,250	-	547,161	-	-	213,105	760,266	1,277,304	2,279,820	2,410	
3	2016	247,095	-	558,104	-	-	217,357	775,471	1,277,304	2,299,870	2,431	
4	2017	252,037	-	569,266	-	-	221,714	790,980	1,277,304	2,320,321	2,453	
5	2018	257,078	-	580,652	-	-	226,148	806,800	1,277,304	2,341,182	2,475	
6	2019	262,219	-	592,285	-	-	230,671	822,936	1,277,304	2,362,459	2,497	
7	2020	267,464	-	604,110	-	-	235,385	839,395	1,277,304	2,384,162	2,520	
8	2021	272,813	-	616,192	-	-	239,990	856,183	1,277,304	2,406,299	2,544	
9	2022	278,269	-	628,516	-	-	244,790	873,306	1,277,304	2,428,879	2,567	
10	2023	283,834	-	641,086	-	-	249,698	890,772	1,277,304	2,451,911	2,592	
11	2024	289,511	-	653,908	-	-	254,680	908,588	1,277,304	2,475,403	2,617	
12	2025	295,301	-	666,886	-	-	259,773	926,760	1,277,304	2,499,365	2,642	
13	2026	301,207	-	680,326	-	-	264,989	945,295	1,277,304	2,523,806	2,668	
14	2027	307,232	-	693,833	-	-	270,268	964,201	1,277,304	2,548,736	2,694	
15	2028	313,376	-	707,611	-	-	275,673	983,485	1,277,304	2,574,165	2,721	
16	2029	319,644	-	721,657	-	-	281,187	1,003,154	1,277,304	2,600,102	2,748	
17	2030	326,037	-	736,407	-	-	286,811	1,023,217	1,277,304	2,626,558	2,776	
18	2031	332,557	-	751,135	-	-	292,547	1,043,682	1,277,304	2,653,543	2,805	
19	2032	339,208	-	765,158	-	-	298,398	1,064,553	1,277,304	2,681,068	2,834	
20	2033	345,993	-	779,461	-	-	304,366	1,085,843	1,277,304	2,709,143	2,864	
Present Worth (% of PW)		2,901,740	0.0%	6,554,053	0.0%	-	2,852,627	9,105,660	13,427,238	25,435,659	1,344	
		11.4%		25.8%			10.0%	35.8%	52.8%	100.0%		


SCR												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst/FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)	
0	2013											
1	2014	405,000	-	912,848	594,000	-	1,282,333	2,769,181	11,498,623	14,692,803	3,654	
2	2015	413,100	-	931,105	605,990	-	1,307,979	2,844,564	11,498,623	14,756,687	3,670	
3	2016	421,392	-	949,727	617,998	-	1,334,139	2,901,664	11,498,623	14,821,846	3,687	
4	2017	429,789	-	968,722	630,358	-	1,360,822	2,959,901	11,498,623	14,888,313	3,703	
5	2018	438,365	-	988,086	642,665	-	1,388,038	3,019,099	11,498,623	14,956,106	3,720	
6	2019	447,153	-	1,007,858	655,824	-	1,415,799	3,079,481	11,498,623	15,025,256	3,737	
7	2020	456,096	-	1,028,015	669,940	-	1,444,115	3,141,070	11,498,623	15,095,789	3,755	
8	2021	465,218	-	1,048,575	682,319	-	1,472,987	3,203,892	11,498,623	15,167,732	3,773	
9	2022	474,522	-	1,068,547	695,988	-	1,502,457	3,267,970	11,498,623	15,241,114	3,791	
10	2023	484,012	-	1,090,838	709,985	-	1,532,506	3,333,329	11,498,623	15,315,964	3,809	
11	2024	493,693	-	1,112,757	724,083	-	1,563,156	3,399,596	11,498,623	15,392,311	3,828	
12	2025	503,567	-	1,135,012	738,564	-	1,594,419	3,467,996	11,498,623	15,470,185	3,846	
13	2026	513,638	-	1,157,712	753,336	-	1,626,308	3,537,555	11,498,623	15,549,616	3,868	
14	2027	523,911	-	1,180,865	768,402	-	1,658,834	3,608,103	11,498,623	15,630,656	3,888	
15	2028	534,389	-	1,204,484	783,770	-	1,692,011	3,680,165	11,498,623	15,713,276	3,908	
16	2029	545,077	-	1,228,573	799,446	-	1,725,951	3,753,670	11,498,623	15,797,969	3,929	
17	2030	555,978	-	1,253,145	815,456	-	1,760,588	3,828,947	11,498,623	15,883,940	3,951	
18	2031	567,098	-	1,278,208	831,743	-	1,796,975	3,905,526	11,498,623	15,971,247	3,972	
19	2032	578,440	-	1,303,772	848,378	-	1,834,487	3,983,637	11,498,623	16,060,659	3,995	
20	2033	590,009	-	1,329,847	865,346	-	1,883,116	4,063,309	11,498,623	16,151,941	4,017	
Present Worth (% of PW)		4,948,231	0.0%	11,153,043	7,257,405	0.0%	15,667,352	34,077,600	120,875,494	155,901,524	1,989	
		3.1%		7.0%	4.5%		8.8%	21.3%	75.6%	100.0%		

Jim Bridger Unit 2												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton SO2 Removed)	
0	2013											
1	2014	42,583	30,503	533,206	-	442,958	208,926	1,215,593	1,236,652	2,494,828	632	
2	2015	43,435	31,113	543,870	-	451,818	213,105	1,239,005	1,236,652	2,519,991	638	
3	2016	44,303	31,735	554,747	-	460,854	217,367	1,264,703	1,236,652	2,545,658	645	
4	2017	45,189	32,370	565,942	-	470,071	221,714	1,289,997	1,236,652	2,571,838	651	
5	2018	46,093	33,017	577,159	-	479,472	226,148	1,316,797	1,236,652	2,598,542	658	
6	2019	47,015	33,678	588,702	-	489,082	230,671	1,342,113	1,236,652	2,625,780	665	
7	2020	47,955	34,351	600,476	-	498,843	235,285	1,366,955	1,236,652	2,653,582	672	
8	2021	48,914	35,038	612,468	-	508,820	239,990	1,392,334	1,236,652	2,681,901	679	
9	2022	49,893	35,739	624,735	-	519,096	244,790	1,417,761	1,236,652	2,710,806	686	
10	2023	50,890	36,454	637,290	-	529,376	249,696	1,443,246	1,236,652	2,740,289	694	
11	2024	51,908	37,183	650,975	-	539,964	254,690	1,468,786	1,236,652	2,770,361	701	
12	2025	52,946	37,925	664,874	-	550,763	259,773	1,494,379	1,236,652	2,801,006	709	
13	2026	54,005	38,685	679,224	-	561,778	264,969	1,520,524	1,236,652	2,832,323	717	
14	2027	55,085	39,469	694,058	-	573,014	270,268	1,547,288	1,236,652	2,864,237	725	
15	2028	56,187	40,248	709,394	-	584,474	275,673	1,574,669	1,236,652	2,896,788	733	
16	2029	57,311	41,063	725,255	-	596,164	281,167	1,602,188	1,236,652	2,929,991	742	
17	2030	58,457	41,874	731,977	-	608,087	286,811	1,630,848	1,236,652	2,963,858	750	
18	2031	59,626	42,711	746,617	-	620,249	292,547	1,702,123	1,236,652	2,998,402	759	
19	2032	60,819	43,566	761,548	-	632,654	298,398	1,736,166	1,236,652	3,033,637	768	
20	2033	62,035	44,437	776,780	-	645,307	304,356	1,770,889	1,236,652	3,069,577	777	
Present Worth (% of PW)		520,271	372,679	6,514,528	-	5,412,000	2,552,627	14,851,935	12,998,900	28,372,107	359	
		1.8%	1.3%	23.0%	0.0%	19.1%	9.0%	52.3%	45.9%	100.0%		


Flue Gas Conditioning												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton PM Removed)	
0	2013											
1	2014	10,000	-	145,854	-	-	19,710	165,564	-	175,564	169	
2	2015	10,200	-	148,771	-	-	20,104	168,875	-	179,075	172	
3	2016	10,404	-	151,747	-	-	20,506	172,253	-	182,657	176	
4	2017	10,612	-	154,781	-	-	20,916	175,698	-	186,310	179	
5	2018	10,824	-	157,877	-	-	21,335	179,212	-	190,036	183	
6	2019	11,041	-	161,035	-	-	21,761	182,796	-	193,837	186	
7	2020	11,262	-	164,255	-	-	22,197	186,452	-	197,714	190	
8	2021	11,487	-	167,540	-	-	22,641	190,181	-	201,666	194	
9	2022	11,717	-	170,881	-	-	23,092	193,985	-	205,701	198	
10	2023	11,951	-	174,369	-	-	23,555	197,864	-	209,815	202	
11	2024	12,190	-	177,955	-	-	24,026	201,822	-	214,012	206	
12	2025	12,434	-	181,351	-	-	24,507	205,859	-	218,292	210	
13	2026	12,682	-	184,978	-	-	24,997	209,975	-	222,698	214	
14	2027	12,938	-	188,678	-	-	25,497	214,175	-	227,111	218	
15	2028	13,185	-	192,451	-	-	26,007	218,468	-	231,663	223	
16	2029	13,459	-	196,300	-	-	26,527	222,827	-	236,288	227	
17	2030	13,728	-	200,226	-	-	27,058	227,284	-	241,012	232	
18	2031	14,002	-	204,231	-	-	27,599	231,830	-	245,832	236	
19	2032	14,282	-	208,315	-	-	28,151	236,466	-	250,749	241	
20	2033	14,568	-	212,482	-	-	28,714	241,195	-	255,764	246	
Present Worth (% of PW)		122,179	-	1,762,023	-	0.0%	240,814	2,022,637	-	2,145,015	103	
		5.7%	0.0%	83.1%	0.0%	0.0%	11.2%	94.3%	0.0%	100.0%		

Fabric Filter												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton PM Removed)	
0	2013											
1	2014	127,749	-	-	300,040	-	1,326,877	1,626,917	4,602,887	6,357,552	4,556	
2	2015	130,304	-	-	300,041	-	1,353,416	1,659,456	4,602,887	6,352,646	4,581	
3	2016	132,810	-	-	312,162	-	1,380,483	1,692,646	4,602,887	6,428,441	4,607	
4	2017	135,568	-	-	319,405	-	1,408,093	1,726,498	4,602,887	6,464,852	4,633	
5	2018	138,279	-	-	324,773	-	1,436,255	1,761,027	4,602,887	6,502,183	4,660	
6	2019	141,045	-	-	331,268	-	1,464,980	1,796,248	4,602,887	6,540,179	4,687	
7	2020	143,866	-	-	337,894	-	1,494,279	1,832,173	4,602,887	6,578,925	4,715	
8	2021	146,743	-	-	344,652	-	1,524,165	1,868,616	4,602,887	6,618,446	4,743	
9	2022	149,578	-	-	351,545	-	1,554,648	1,906,193	4,602,887	6,658,757	4,772	
10	2023	152,571	-	-	358,578	-	1,585,741	1,944,317	4,602,887	6,699,875	4,801	
11	2024	155,725	-	-	365,747	-	1,617,456	1,983,203	4,602,887	6,741,814	4,832	
12	2025	158,839	-	-	373,062	-	1,649,805	2,022,857	4,602,887	6,784,593	4,862	
13	2026	162,016	-	-	380,523	-	1,682,801	2,063,324	4,602,887	6,828,227	4,893	
14	2027	165,256	-	-	388,134	-	1,716,457	2,104,591	4,602,887	6,872,734	4,925	
15	2028	168,562	-	-	395,896	-	1,750,766	2,146,683	4,602,887	6,918,131	4,958	
16	2029	171,933	-	-	403,814	-	1,785,802	2,189,616	4,602,887	6,964,436	4,991	
17	2030	175,371	-	-	411,891	-	1,821,518	2,233,409	4,602,887	7,011,687	5,025	
18	2031	178,879	-	-	420,128	-	1,857,948	2,278,077	4,602,887	7,059,842	5,059	
19	2032	182,456	-	-	428,531	-	1,895,107	2,323,539	4,602,887	7,108,981	5,093	
20	2033	186,106	-	-	437,102	-	1,933,010	2,370,111	4,602,887	7,159,103	5,133	
Present Worth (% of PW)		1,560,813	0.0%	0.0%	3,653,845	0.0%	16,241,591	19,877,438	48,395,333	69,624,562	2,502	
		2.2%			5.3%		23.2%	26.5%	69.3%	100.0%		

First Year Cost for Air Pollution Control Options



Present Worth Cost for Air Pollution Control Options



Air Pollution Control Options

APPENDIX B
2006 Wyoming BART Protocol

BART Air Modeling Protocol
Individual Source Visibility Assessments
for BART Control Analyses

September, 2006

State of Wyoming
Department of Environmental Quality
Air Quality Division
Cheyenne, WY 82002

Table of Contents

1.0	INTRODUCTION	3
2.0	OVERVIEW	4
3.0	EMISSIONS DATA FOR MODELING	7
3.1	Baseline Modeling	7
3.2	Post-Control Modeling.....	8
4.0	METEOROLOGICAL DATA.....	9
5.0	CALPUFF MODEL APPLICATION.....	12
6.0	POST PROCESSING	15
7.0	REPORTING	19

1.0 INTRODUCTION

The U.S. EPA has issued final amendments to the Regional Haze Regulations, along with Guidelines for Best Available Retrofit Technology (BART) Determinations.⁽¹⁾ The guidelines address the methodology for determining which facilities must apply BART (sources subject-to-BART) and the evaluation of control options.

The State of Wyoming used air quality modeling in accordance with the EPA Guidelines to determine the Wyoming sources which are subject-to-BART. This Protocol defines the specific methodology to be used by those sources for determining the improvement in visibility to be achieved by BART controls.

The methodology presented in this Protocol is consistent with EPA guidance and the Air Quality Division (AQD) determination of subject-to-BART sources. It is intended that all Wyoming sources that must conduct BART analyses will use this Protocol for their evaluation of control technology visibility improvement. Any deviations from the procedures described herein must be approved by the Division prior to implementation.

⁽¹⁾ 40 CFR Part 51: Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations; Final Rule. 70 Federal Register, 39103-39172, July 6, 2005.

2.0 OVERVIEW

Wyoming AQD determined that eight facilities (sources) in the state are subject-to-BART. The sources are listed in Table 1. Division modeling indicated that each of these sources causes or contributes to visibility impairment in one or more Class I areas. Each source must conduct a BART analysis to define Best Available Retrofit Technology (BART) applicable to that source, and quantify the improvement in Class I visibility associated with BART controls. This Protocol sets out the procedures for quantifying visibility improvement. Other aspects of the full BART analysis are not addressed here.

There are many Class I areas within and surrounding Wyoming (See Figure 1). On the basis of distance from subject-to-BART sources, topography, meteorology, and prior modeling, the AQD has determined that only five Class I areas need be addressed in BART individual source analyses. These are Badlands and Wind Cave National Parks in South Dakota, Mt. Zirkel Wilderness Area in Colorado, and Bridger and Fitzpatrick Wilderness Areas in Wyoming. Sources in eastern Wyoming have been shown to have greatest visibility impacts at the two South Dakota Class I areas, and western Wyoming sources have maximum impacts at Bridger and Fitzpatrick Wilderness Areas, and Mt. Zirkel. Visibility improvement at these highest impact areas will provide the best measure of the effectiveness of BART controls.

Each facility should carry out modeling with the CALPUFF modeling system for the Class I areas specified in Table 2. The AQD will provide meteorological input for CALMET for the years 2001, 2002, and 2003. The model domain covered by the AQD meteorological data is centered in southwest Wyoming, and extends roughly from Twin Falls, ID in the west to the Missouri River in the east, and from Denver in the south to Helena, MT in the north. The domain is shown, along with Class I areas, in Figure 1.

Sources may wish to utilize a smaller domain for CALPUFF modeling. Smaller domains are acceptable if they provide adequate additional area beyond the specific source and Class I areas being addressed. Figure 1 includes a "southwest Wyoming" domain which represents the minimum acceptable area for sources impacting the Bridger and Fitzpatrick Wilderness Areas, and the Mt. Zirkel Wilderness Area, and a "northeast Wyoming" domain as a minimum area for Badlands and Wind Cave National Parks modeling.

The CALPUFF model should be used with each of the three years of meteorological data to calculate visibility impacts for a baseline (existing emissions) case, and for cases reflecting BART controls. The control scenarios are to include individual scenarios for proposed BART controls for each pollutant (SO₂, NO_x, and particulate matter), and a combined scenario representing application of all proposed BART controls. If desired, additional modeling may be performed for controls that are not selected as BART. This might be done, for example, to provide data useful in identifying the control technologies that represent BART. However, visibility modeling is required only for the proposed BART controls.

Table 1. Wyoming Sources Subject-to-BART

Basin Electric	Laramie River Power Plant	Boilers #1,2,3
FMC Corporation	Granger Soda Ash Plant	Boilers #1,2
FMC Corporation	Green River Sodium Plant	Three boilers
General Chemical Co.	Green River Soda Ash	Two boilers
PacifiCorp	Dave Johnson Power Plant	Boilers #3,4
PacifiCorp	Jim Bridger Power Plant	Boilers #1-4
PacifiCorp	Naughton Power Plant	Boilers #1,2,3
PacifiCorp	Wyodak Power Plant	Boiler

Results of visibility modeling will be presented as a comparison between baseline impacts and those calculated for the BART control scenarios. Quantitative measures of impact will be the 98th percentile deciview change (Δdv) relative to the 20% best days natural background, and the number of days with deciview change exceeding 0.5 (EPA Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations, 70 FR 39103). Results should be presented for each year.

Table 2. Source-Specific Class I Areas to be Addressed

Source	Class I Areas to be Evaluated
Basin Electric Laramie River	Wind Cave NP, Badlands NP
FMC Corporation Granger Soda Ash	Bridger WA, Fitzpatrick WA
FMC Corporation Sodium Products	Bridger WA, Fitzpatrick WA
General Chemical Green River Soda Ash	Bridger WA, Fitzpatrick WA
Pacificorp Dave Johnston	Wind Cave NP, Badlands NP
Pacificorp Jim Bridger	Bridger WA, Fitzpatrick WA, Mt. Zirkel WA
Pacificorp Naughton Plant	Bridger WA, Fitzpatrick WA
Pacificorp Wyodak	Wind Cave NP, Badlands NP

3.0 EMISSIONS DATA FOR MODELING

CALPUFF model input requires source (stack) – specific emission rates for each pollutant, and stack parameters (height, diameter, exit gas temperature, and exit gas velocity). Per EPA BART guidance, these parameters must be representative of maximum actual 24-hour average emitting conditions for baseline (existing) operation, and maximum proposed 24-hour average emissions for future (BART) operations.

3.1 Baseline Modeling

Sources are required to utilize representative baseline emission conditions if data are available; baseline emissions must be documented. Possible sources of emission data are stack tests, CEM data, fuel consumption data, etc. Remember that emissions should represent maximum 24-hour rates. EPA BART guidance states that you should “Use the 24-hour average actual emission rate from the highest emitting day of the meteorological period modeled (for the pre-control scenario).” Thus, baseline conditions should reference data from 2001 through 2003 (or 2004).

As a minimum, modeled emissions must include:

SO ₂	sulfur dioxide
NO _x	oxides of nitrogen
PM _{2.5}	particles with diameter less than 2.5µm
PM _{10-2.5}	particles with diameters greater than 2.5µm but less than or equal to 10 µm

If the fraction of PM₁₀ in the PM_{2.5} (fine) and PM_{10-2.5} (coarse) categories cannot be determined all particulate matter should be assumed to be PM_{2.5}.

In addition, direct emissions of sulfate (SO₄) should be included where possible. Sulfate can be emitted as sulfuric acid (H₂SO₄), sulfur trioxide (SO₃), or as sulfate compounds; emissions should be quantified as the equivalent mass of SO₄.

When test or engineering data are not available to specify SO₄ emissions or the relative fractions of fine and coarse particles, use can be made of speciation profiles available from Federal Land Managers at the website <http://ww2.nature.nps.gov/air/permits/ect/index.cfm>. Profiles are available for a number of source type and control technology combinations. The FLM speciation factors are acceptable if data are available for the appropriate source type.

Emissions of VOC (volatile organic compounds), condensable organics measured in stack tests, and elemental carbon components of PM₁₀ do not need to be included for BART modeling. The only other pollutant noted in EPA BART guidance is ammonia (NH₃). Though ammonia is not believed to be a significant contributor to visibility

impairment in most cases in Wyoming, it could be important for sources with significant ammonia emissions – for example from some NO_x control systems. Sources that are expected to emit ammonia (in pre-or post-control configurations) should include ammonia emissions in their model input.

If quantitative baseline emissions data are unavailable and sources believe that the maximum 24-hour emission rates estimated by the Division (presented in the Subject-to-BART final report) are representative of baseline conditions for their facility, they may be used for baseline modeling. However, emissions of sulfate and ammonia (if applicable) should be included based on the best available test information or speciation factors from current literature.

3.2 Post-Control Modeling

All pollutants described above should be included for each post-control scenario. Post-control emissions (maximum 24-hour average) will generally be the baseline emissions multiplied by a control factor appropriate to the BART control. However, some proposed controls may simply increase the efficiency of existing controls; others may result in an increase in emissions of one pollutant while controlling another. These factors must all be considered in defining emission rates for post-control modeling. Any changes in stack parameters resulting from control application must also be included.

The required visibility assessment will include the effect of each proposed BART control. For example, if a source proposes to add a scrubber for SO₂ control, low NO_x burners for NO_x control, and a baghouse for particulate control, four sets of visibility results should be developed:

- Use of SO₂ control alone
- Use of NO_x control alone
- Use of particulate control alone
- Use of proposed combination of all three controls

All pollutants should be modeled in each CALPUFF model run, but the modeled emissions should reflect only the specific controls or combination of controls addressed in that run.

Additional modeling could be necessary in situations where a facility is comprised of more than one subject-to-BART source, and different BART controls are applicable to different sources. Excessive modeling to address multiple control combinations is not necessary; however, visibility modeling should quantify the effect of BART controls on all affected sources for each pollutant, and of all facility BART controls combined.

4.0 METEOROLOGICAL DATA

Wyoming AQD will provide MM5 meteorological data fields for years 2001, 2002, and 2003 that can be utilized as input to CALMET. The MM5 output will have 12 kilometer resolution and cover the full domain shown in Figure 1.

Mesoscale meteorological data (MM5) were developed and evaluated as part of the AQD's southwest Wyoming NO₂ increment analysis. Three years of MM5 data at 36 km resolution were used to initialize 12 km MM5 simulations. The 12km MM5 modeling used identical physics options to the original 36 km runs. CALMM5 was then used as a preprocessor to produce CALMET – ready MM5 data input files. Quality assurance was performed by comparing the original MM5 output on the 36km national RPO grid to the 12 km MM5 output and observations.

The CALMET model (version 5.53a, level 040716) should be used to prepare meteorological input for CALPUFF. The user may select a domain smaller than the MM5 domain for CALMET and CALPUFF modeling if desired. Figure 1 shows minimum domain areas for modeling of western and eastern Wyoming BART sources. Four kilometer resolution should be specified for CALMET output.

CALMET processing should use the AQD MM5 data, and appropriate surface, upper air, and precipitation data. Figure 2 shows the locations of surface and upper air stations within the MM5 model domain. The MM5 data are used as the initial guess wind field; this wind field is then adjusted by CALMET for terrain and land use to generate a step 1 wind field, and refined using surface and upper air data to create the final step 2 wind field.

Surface, upper air, and precipitation data can be obtained from the National Climatic Data Center. Land use and terrain data are available from the U.S. Geological Survey. Data can be formatted for use in CALMET with standard conversion and processing programs available with the CALMET/CALPUFF software.

Table 3 provides a listing of applicable CALMET input variables for BART meteorological processing. The table includes inputs that are specific to Wyoming BART modeling. Inputs not shown in Table 3 are not relevant to the present application, are dependent on the specific model domain of the user, use model default values, or are obvious from the context.

Table 3. CALMET Control File Inputs

Variable	Description	Value
	Input Group 1	
IBYR	Year	2001
		2002
		2003
IBTZ	Base time zone	7
IRTYPE	Run type	1
LCALGRD	Compute data fields for CALGRID	T
	Input Group 2	
PMAP	Map projection	LCC
DGRIDKM	Grid spacing (km)	4
NZ	Number of layers	10
ZFACE	Cell face heights (m)	0
		20
		40
		100
		140
		320
		580
		1020
		1480
		2220
		3500
	Input Group 4	
NOOBS	No observation Mode	0
	Input Group 5	
IWFCOD	Model selection variable	1
IFRADJ	Froude number adjustment	1
IKINE	Kinematic effects	0
IOBR	Use O'Brien procedure	0
ISLOPE	Slope flow effects	1
IEXTRP	Extrapolate surface wind observations	-4
ICALM	Extrapolate calm surface winds	0
BIAS	Biases for weights of surface and upper air stations	All 0
RMIN2	Minimum distance for extrapolation	-1
I PROG	Use gridded prognostic model output	14
ISTEPPG	Time Step (hours)	1
LVARY	Use varying radius of influence	F

Table 3. CALMET Control File Inputs (continued)

Variable	Description	Value
RMAX 1	Maximum radius of influence (km)	30
RMAX 2	Maximum radius of influence (km)	50
RMIN	Minimum radius of influence (km)	0.1
TERRAD	Radius of influence for terrain (km)	15
R1	Relative weighting of first guess wind field and observations (km)	5
R2	Relative weighting aloft (km)	25
IDIOPT 1	Surface temperature	0
IDIOPT 2	Upper air lapse rate	0
ZUPT	Lapse rate depth (m)	200
IDIOPT 3	Average wind components	0
IUPWND	Upper air station	-1
ZUPWND (1)	Bottom and top of layer for domain	1, 1000
ZUPWND (2)	scale winds (m)	1, 1000
IDIOPT4	Surface wind components	0
IDIOPT5	Upper air wind components	0
Input Group 6		
IAVEZI	Spatial averaging	1
MNMDAV	Max search radius	1
HAFANG	Half angle for averaging (deg)	30
ILEVZI	Layer of winds in averaging	1
ZIMAX	Maximum overland mixing height (m)	3500
ITPROG	3D temperature source	1
IRAD	Interpolation type	1
TRADKM	Radius of influence – temperature (km)	500
NUMTS	Maximum number of Stations	5
IAVET	Spatial averaging of temperatures	1
NFLAGP	Precipitation interpolation	2

5.0 CALPUFF MODEL APPLICATION

The CALPUFF model (version 5.711a, level 040716) will be used to calculate pollutant concentrations at receptors in each Class I area. Application of CALPUFF should, in general, follow the guidance presented in the Interagency Workgroup on Air Quality Modeling (IWAQM) Phase 2 report (EPA - 454/R98-019) and the EPA Regional Haze Regulations and Guidelines for BART Determinations (70 FR 39103).

Appropriate CALPUFF control file inputs are in Table 4. Note should be taken of the basis for several of the recommended CALPUFF inputs.

- Building downwash effects need not be included. Because of the transport distances involved and the fact that most sources have tall stacks, building downwash is unlikely to have a significant effect on model-predicted concentrations
- Puff splitting is not required. The additional computation time necessary for puff splitting is not justified for purposes of BART analyses.
- Hourly ozone files should be used to define background ozone concentration. Data are available from the following sites within the model domain.
 - Rocky Mountain NP, CO
 - Craters of the Moon NP, ID
 - AIRS - Highland UT
 - Mountain Thunder, WY
 - Yellowstone NP, WY
 - Centennial, WY
 - Pinedale, WY

The background ozone concentration shown in Table 4 is used only when hourly data are missing.

- A constant background ammonia concentration of 2.0 ppb is specified. This value is based upon monitoring data from nearby states and IWAQM guidance. Experience suggests that 2.0 ppb is conservative in that it is unlikely to significantly limit nitrate formation in the model computations.
- MESOPUFF II chemical transformation rates should be used.
- The species to be modeled should be the seven identified in CALPUFF: SO₂, SO₄, NO_x, HNO₃, NO₃, PM_{2.5}, and PM_{10-2.5}. If ammonia (NH₃) is emitted it should be added to the species list. In most cases, all pollutants modeled will also be emitted, except for HNO₃ and NO₃.

Concentration calculations should be made for receptors covering the areas of the Class I areas being addressed. Receptors in each Class I area will be those designated by the Federal Land Managers and available from the National Park Service website.

Table 4. CALPUFF Control File Inputs

Variable	Description	Value
	Input Group 1	
METRUN	Control parameter for running all periods in met file	1
IBYR	Starting year	2001 2002 2003
XBTZ	Base time zone	7
NSPEC	Number of chemical species modeled	7 (or 8)
NSE	Number of species emitted	5 (or 6)
METFM	Meteorological data format	1
	Input Group 2	
MGAUSS	Vertical distribution in near field	1
MCTADJ	Terrain adjustment method	3
MCTSG	Subgrid scale complex terrain	0
MSLUG	Elongated puffs	0
MTRANS	Transitional plume rise	1
MTIP	Stack tip downwash	1
MSHEAR	Vertical wind shear	0
MSPLIT	Puff splitting allowed?	0
MCHEM	Chemical mechanism	1
MAQCHEM	Aqueous phase transformation	0
MWET	Wet removal	1
MDRY	Dry deposition	1
MDISP	Dispersion Coefficients	3
MROUGH	Adjust sigma for roughness	0
MPARTL	Partial plume penetration of inversions	1
MPDF	PDF for convective conditions	0
	Input Group 4	
PMAP	Map projection	LCC
DGRIDKM	Grid spacing	4

Table 4. CALPUFF Control File Inputs (continued)

ZFACE	Cell face heights (m)	0
		20
		40
		100
		140
		320
		580
		1020
		1480
		2220
		3500
	Input Group 6	
NHILL	Number of terrain features Input Group 7	0
Dry Gas Depo	Chemical parameters for dry gas deposition	Defaults
	Input Group 8	
Dry Part. Depo	Size parameters for dry particle deposition SO ₄ , NO ₃ , PM25 PM10	Defaults 6.5, 1.0
	Input Group 11	
MOZ	Ozone Input option	1
BCKO3	Background ozone – all months (ppb)	44.0
BCKNH3	Background ammonia – all months (ppb)	2.0
	Input Group 12	
XMAXZI	Maximum mixing height (m)	3500
XMINZI	Minimum mixing height (m)	50

6.0 POST PROCESSING

Visibility impacts are calculated from the CALPUFF concentration results using CALPOST. CALPOST version 5.51, level 030709 should be used; the output from CALPOST will provide the highest deciview impact on each day from all receptors within each Class I area modeled.

For some CALPUFF applications such as deposition calculations, the POSTUTIL program is used prior to CALPOST. POSTUTIL is also used to repartition total nitrate by accounting for ammonia limiting. The ammonia limiting calculation in POSTUTIL should not be applied for Wyoming BART modeling. If you believe that ammonia limiting is appropriate for a specific BART analysis, justification should be discussed with the Division prior to its used.

Visibility calculations by CALPOST for BART purposes use Method 6. This method requires input of monthly relative humidity factors, $f(RH)$, for each Class I area. The EPA guidance document provides appropriate data for each area. Table 5 lists monthly $f(RH)$ factors to use for the Wyoming, Colorado, and South Dakota areas to be addressed in BART modeling. The factors shown in Table 5 include averages for the adjacent Class I areas, and are within 0.2 units of the Guideline table values for the individual Class I areas.

Natural background conditions as a reference for determination of the delta-dv change due to a source should be representative of the 20% best natural visibility days. EPA BART guidance provides the 20% best days deciview values for each Class I area on an annual basis, but does not provide species concentration data for the 20% best background conditions. These concentrations are needed for input to CALPOST.

Annual species concentrations corresponding to the 20% best days were calculated for each Class I area to be addressed, by scaling back the annual average concentrations given in Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule (Table 2-1). A separate scaling factor was derived for each Class I area such that, when multiplied by the Guidance table annual concentrations, the 20% best days deciview value for that area would be calculated. The scaled aerosol concentrations were averaged for the Bridger and Fitzpatrick WAs, and for Wind Cave and Badlands NPs, because of their geographical proximity and similar annual background visibility. The 20% best days aerosol concentrations to be used for each month for Wyoming BART evaluations are listed in Table 6.

Table 7 is a list of inputs for CALPOST. These inputs should be used for all BART visibility calculations. Output from CALPOST should be configured to provide a ranked list of the highest delta-deciview values in each Class I area. The 98th percentile delta-deciview value and the number of values exceeding 0.5 can then be determined directly from the CALPOST output.

Table 5. Monthly f(RH) Factors for Class I Areas

Month	Wind Cave NP Badlands NP	Bridger WA Fitzpatrick WA	Mt. Zirkel WA
January	2.65	2.50	2.20
February	2.65	2.30	2.20
March	2.65	2.30	2.00
April	2.55	2.10	2.10
May	2.70	2.10	2.20
June	2.60	1.80	1.80
July	2.30	1.50	1.70
August	2.30	1.50	1.80
September	2.20	1.80	2.00
October	2.25	2.00	1.90
November	2.75	2.50	2.10
December	2.65	2.40	2.10

Table 6. Natural Background Concentrations of Aerosol Components for 20% Best Days for BART Analyses ($\mu\text{g}/\text{m}^3$)

Aerosol Component	Wind Cave NP Badlands NP	Fitzpatrick WA Bridger WA	Mt. Zirkel WA
Ammonium Sulfate	.047	.045	.046
Ammonium Nitrate	.040	.038	.038
Organic Carbon	.186	.178	.179
Elemental Carbon	.008	.008	.008
Soil	.198	.189	.190
Coarse Mass	1.191	1.136	1.141

Table 7. CALPOST Control File Inputs

Variable	Description	Value
	Input Group 1	
ASPEC	Species to Process	VISIB
ILAYER	Layer/deposition code	1
A,B	Scaling factors	0,0
LBACK	Add background concentrations?	F
BTZONE	Base time zone	7
LVSO4	Species to be included in extinction	T
LVNO3		T
LVOC		F
LVPMC		T
LVPMF		T
LVEC		F
LVBK	Include background?	T
SPECPMC	Species name for particulates	PM10
SPECPMF		PM25
EEPMC	Extinction efficiencies	0.6
EEPMF		1.0
EEPMCBK		0.6
EESO4		3.0
EENO3		3.0
EEOC		4.0
EESOIL		1.0
EEEC		10.0
MVISBK	Visibility calculation method	6
RHFAC	Monthly RH adjustment factors	Table 5
BKSO4	Background concentrations	Table 6
BKNO3		Table 6
BKPMC		Table 6
BK OC		Table 6
BKSOIL		Table 6
BKEC		Table 6
BEXTRAY	Extinction due to Rayleigh scattering	10.0

7.0 REPORTING

A report on the BART visibility analysis should be submitted that clearly compares impacts for post-control emissions to those for baseline emissions. Data for baseline and BART scenarios should include both the 98th percentile values and the number of days with delta-deciview values exceeding 0.5. Results should be given for each model year.

Table 8 is an example of a recommended format for presentation of model input and model results. The example is for baseline conditions; similar tables should be provided for each control scenario (SO₂, NO_x, and PM10) and for the combination of all BART controls. Your report tables need not follow the exact format shown in Table 8; but the same information should be provided in a concise and clear form. If additional scenarios were modeled or you wish to present supplemental information, they should be provided in an appendix or separate from the specified final results.

Table 8. Example Format for Presentation of Model Input and Results

Baseline Conditions Model Input Data												
Source (Unit) Description And ID	SO ₂ Emission Rate (lb/day)	NO _x Emission Rate (lb/day)	PM _{2.5} Emission Rate (lb/day)	PM _{10-2.5} Emission Rate (lb/day)	SO ₄ Emission Rate (lb/day)	NH ₃ Emission Rate (lb/day)	Location Easting (m)	Location Northing (m)	Stack Height (m)	Stack Diameter (m)	Exit Velocity (m/s)	Exit Gas Temp (deg K)
							UTM (m)	UTM (m)				

Baseline Visibility Modeling Results							
Name of Facility	Class I Area	2001		2002		2003	
		98 th Percentile Value (dv)	No. of days exceeding 0.5 dv	98 th Percentile Value (dv)	No. of days exceeding 0.5 dv	98 th Percentile Value (dv)	No. of days exceeding 0.5 dv

APPENDIX C
Just-Noticeable Differences in Atmospheric Haze
Dr. Ronald Henry

Just-Noticeable Differences in Atmospheric Haze

Ronald C. Henry

Department of Civil and Environmental Engineering, University of Southern California, Los Angeles

ABSTRACT

This article examines the only available experimental data taken in the natural environment on the ability of an observer to perceive small, incremental changes in the colorfulness of objects seen through atmospheric haze and estimates an appropriate just-noticeable difference (JND) from these data. This experimentally determined threshold of perception is compared to changes in the deciview scale. Based on these experimental results, the deciview scale is found to not be uniform over a wide range of visibility conditions, as has been previously claimed. In addition, a 1-deciview change never produces a perceptible change in haze, as defined by a 95% probability of producing a measurable change in the colorfulness of an object seen through the haze.

INTRODUCTION

Section 169A of the Clean Air Act sets a national goal of protecting visibility in national parks and other pristine areas. Under regulations promulgated in 1980, the U.S. Environmental Protection Agency (EPA) has taken specific regulatory action to protect visibility in the Grand Canyon National Park by reducing emissions of sulfur dioxide from the Navajo Electric Generating Station near the eastern end of the Grand Canyon and from the Mohave Power Plant at the western end. However, current concerns about visibility degradation stem from regional haze that is difficult or impossible to attribute to individual sources of air pollution. This issue is addressed by regional haze regulations that set a goal of making reasonable

IMPLICATIONS

Current regulations use the deciview to quantify a perceptible change in regional haze. Based on the results of this article, changes in atmospheric extinction required to meet regional haze regulations calculated using deciviews would probably be too small, sometimes much too small. In addition, these regulations require that progress be assessed over five-year intervals. In this way, the burden of reducing emissions is spread evenly over many years. However, since deciviews are not uniform in perception, it may be that the actual improvement in visibility will not be uniform.

progress toward improving regional visibility in five-year increments, leading to the attainment of "natural conditions" by 2064.¹ Progress is to be measured by an innovative visibility metric for regulatory purposes known as the deciview,² used instead of visual range or other visibility metrics because it "expresses uniform changes in haziness in terms of common increments across the entire range of visibility conditions, from pristine to extremely hazy conditions."¹ One goal of this article is to assess this and other claims about the deciview scale in light of actual measurements of the perception of haziness. Since the deciview scale is meant to quantify small, just-noticeable differences (JNDs) in visibility, a review of the basic concepts of thresholds and JNDs is given.

Perceptual Threshold Concepts

For all the senses, thresholds are necessary—otherwise we would be constantly distracted by small, inconsequential changes in the environment. A background of random noise, some from the environment and some produced inside our own sensory organs, would make it next to impossible to form a stable view of the world. Our vision would be like the grainy, speckled images produced by night vision cameras. On a more basic scientific level, the study of thresholds of the senses has led to a deeper understanding of sensory physiology and how our vision and other senses function. For this reason, virtually all studies of thresholds of vision have been carried out under controlled laboratory conditions.

Since laboratory conditions seldom mimic the natural environment, thresholds so determined are generally not useful in predicting perception in the complex natural world. As an example of the drastic effect that experimental conditions can have on perception, consider an experiment to determine the ability of an observer to perceive the difference in the length of two strings—or to put it another way, to determine the threshold for perception of the difference in the length of two strings, or the JND. If the two strings are widely separated when presented to the observer, the threshold will be much greater than if the two strings are presented side by side. The visual equivalent of this is the use of a split image to determine the ability to distinguish color. If two colors are seen as two halves of a disk, the JND is very small, but if one

color is presented as a full disk, followed a few seconds later by the other color, the JND will be much larger. The topic of the background on which the colors are seen is also important (e.g., if it is black or a complex scene). In general, many conditions influence thresholds; for this reason, the results of laboratory experiments should be applied with great caution to the natural environment. Thus, this article will report and analyze data taken in a unique experiment in the natural environment with a goal of determining a JND in atmospheric haze.

In the above discussion, the terms "threshold" and "JND" have been freely used, but not defined. The naïve definition of a threshold or JND is clear: It is the smallest amount, or change in, a physical stimulus that is detectable. Ideally, a 1-JND change in a stimulus such as contrast or color would always result in the observer seeing a change, and anything less would not. Of course, the senses do not work in this simple on-off manner. In actuality, as the change in the physical stimulus increases, the probability that the observer will detect the change increases as well. Thus, thresholds and JNDs have always been defined by a probability of detection. Furthermore, the sensitivity of people's senses varies from person to person and during a person's life. Even if each person had a single, idealized threshold, the response of the general population would be best described by a probability of detection.

Repeated matching by the method of adjustments is one of the oldest methods of determining a JND. Falmagne³ described this and other methods to quantify perception. Briefly, the observer is shown a target color and a variable test color and is asked to adjust the test color until it matches the target. Taking random starting points, the matching procedure is repeated as often as is practical. Since the observer has judged the matching color to be the same as the target color, the variability in the matches is a measure of a JND around the target. The standard deviation of the matches is one measure of this variability that is often used; another is the difference between the 75th and the 25th percentile of the match distribution. The method of adjustments has been replaced in laboratory studies by methods that give less control to the observer and more to the researcher and therefore improve the reproducibility of the results (unfortunately, these methods are impractical for field studies). However, JNDs are still defined by some measure related to the probability of detection. The final determination of the value of a JND or threshold is really dependent on how the measurements are made and how the data are interpreted. For the experimental data used in this article, the method of adjustments was used and a JND related to the standard deviation of repeated matches was defined.

Atmospheric Visibility Concepts

In the classical theory of atmospheric visibility, the threshold of contrast perception, that is, the threshold for perception of a large, dark object on the horizon, is assumed to be 2%.⁴ This number is somewhat arbitrary. The Federal Aviation Administration (FAA) has taken the more conservative value of 5.5% as a contrast threshold for the definition of visual range, presumably because approaching aircraft seen from a cockpit are usually neither large nor dark. The common formula for visual range, using the 2% threshold, is

$$V_R = \frac{-\ln(0.02)}{b_{ext}} = \frac{3.9}{b_{ext}} \quad (1)$$

where b_{ext} is the extinction coefficient of the atmosphere, which is assumed to be homogeneous. The extinction coefficient in the denominator of the formula can be thought of as the fraction of light that is lost as it traverses 1 m of air. For completely clear air, b_{ext} has a value of about $10 \times 10^{-6} \text{ m}^{-1}$ or 10 Mm^{-1} , or a visual range of about 390 km. More typically, particles in the air usually increase the extinction coefficient to 150–300 Mm^{-1} or more. Typical visual ranges are about 10 km in the eastern United States and 50 km or more in the western United States. Closely related to b_{ext} and visual range is the more general concept of optical depth. For a target at a distance x , this is defined as xb_{ext} . It is dimensionless; if b_{ext} is held constant it represents distance, and if the distance is constant, it represents changes in b_{ext} . From eq 1, the visual range corresponds to an optical depth of 3.9, and a distance of about one quarter of the visual range is equivalent to an optical depth of 1.

Despite lacking a firm psychophysical or experimental basis, the visual range defined by the 2% threshold has stood the test of time. However, while visual range has proven to be a good surrogate for atmospheric visibility for the aviation community, it is of limited value in addressing the concerns of the air quality community. Unlike aviation, where poor visibility is of greatest interest, the air quality community is primarily concerned with relatively small changes in good visibility. Pitchford and Malm² have proposed the deciview as a visibility indicator more suited to air quality regulations. If the extinction coefficient is given in Mm^{-1} , then deciview is defined as

$$v = 10 \ln(b_{ext} / 10) \quad (2)$$

Current regional haze visibility regulations state that:

- (1) A 1-deciview change in haziness is a small, but noticeable, change in haziness under most circumstances when viewing scenes in Class I areas.
- (2) Deciview units are uniform in perception over a wide range of visibility conditions; that is, a 1-deciview change is just perceptible regardless of the visibility conditions.¹

The next section describes a color matching experiment in the Great Smoky Mountains National Park. The results of this experiment are used to estimate a just-noticeable change in haze based on color perception. The validity of the claims for deciviews will be evaluated by comparison to experimental estimates of JNDs.

EXPERIMENTAL DATA

During summer 1995, a group of researchers from universities, government agencies, and private companies conducted the SouthEast Aerosol and Visibility Study (SEAVS) in the Great Smoky Mountains National Park. The SEAVS focused largely on aerosol composition,^{5,6} airborne particle size distribution,^{7,8} and the role of water in the aerosol.⁹⁻¹¹ However, the SEAVS had a number of other aspects, including a study of the perception of color through atmospheric haze.¹² The methods and primary results of the color perception study are described below.

The perceived colors of natural targets were quantified by color matching using a specially constructed visual colorimeter.¹³ An observer looked at some scene element, such as a barn or green field, with one eye. The observer looked with the other eye in the visual colorimeter at a color spot, which the observer adjusted to match the color of the target. The perceived color was recorded as the amount of red, green, and blue light in the color match. At the same time, the spectrum of the light coming from the target was measured by a telespectoradiometer. A color appearance model was applied to produce measures of the perceived color as recorded by the visual colorimeter and as calculated from the spectrum.¹⁴

Of most interest here are the hue and colorfulness. The hue is what most people call the color—red, green, blue, yellow, and so on. It is quantified as a mixture of pure red, green, blue, or yellow lights. The colorfulness is the degree to which the hue is expressed; it is similar to the concept of saturation. A deep red color would have a colorfulness of about 100, while a colorfulness of 10 or less is almost achromatic (i.e., white or gray).

Two observers (Mahadev and Urquito) made color matches of a set of natural targets during the SEAVS. These observers were both males in their 20s with normal color vision. Each had received extensive training in color matching using the visual colorimeter. The scattering coefficient of the atmosphere was measured by a nearby nephelometer; particle absorption was small and its contribution to the extinction coefficient ignored. The full details of the experiment are found in Mahadev.¹⁵

The perception study found that viewing through a semitransparent atmosphere affected the perception of hue and colorfulness in a highly nonlinear way. The eye appeared to split the light coming from the target into two parts, the haze and the target. The result was that as

the haze increased, the hue of the target as seen by the observer remained constant. However, because the increasing haze scattered more light into the sight path, the hue calculated from the spectrum became bluer. To the observer, the main effect of haze was to decrease the perceived colorfulness. Furthermore, the decrease in colorfulness seemed to be exponential with optical depth (optical depth is the dimensionless product of the extinction coefficient and distance):

$$M(\tau) = M_0 \exp(-\tau) \quad (3)$$

where $M(\tau)$ is the colorfulness of the object at optical depth τ and M_0 is the colorfulness at zero optical depth (i.e., no haze). M_0 is also known as the inherent colorfulness. The colorfulness of the horizon was assumed to be small enough to be taken as zero—the horizon was perceived to be white. This result implies that a JND in colorfulness can be taken to be a JND in haze.

JND in Colorfulness

Estimates of JNDs in colorfulness were based on sets of repeated color matches made during periods when the observing conditions (cloud cover, haze level, and lighting) were judged to be constant or nearly so. Observer Urquito made six sets of repeated matches.¹⁵ Figure 1 is a plot of all the repeated observations of the colorfulness of the red barn roof made by this observer versus optical depth. The exponential fit given by eq 1 is fairly good ($R^2 = 0.68$). The error bars in the figure are twice the standard deviation given in Table 1. They show that one set




Figure 1. Colorfulness vs. optical depth for observer Urquito for repeated observations of the red barn roof. The line is an exponential fit as in eq 1, and the error bars are two times the standard deviation given in Table 2.

Table 1. Repeated measurements of the red barn roof by observer Mahadev.

Date	Time	Scattering Coefficient (Mm) ⁻¹	Visual Range (km)	Colorfulness		Spectra Hue		Perceived Hue	
				Spectra	Perceived	% Red	% Blue	% Red	% Blue
7/29/95	10:20 a.m.	37	105.7	38.0	42.2	53	47	97	3
7/29/95	10:46 a.m.	39	100.3	38.9	45.6	40	60	92	8
7/29/95	10:54 a.m.	39	100.3	39.9	45.4	38	62	99	1
7/29/95	11:03 a.m.	42	93.1	35.6	46.3	52	48	92	8
7/29/95	11:12 a.m.	42	93.1	37.5	44.9	53	47	93	7
7/25/95	11:49 a.m.	65	60.2	31.2	41.1	50	50	88	12
7/25/95	12:01 p.m.	65	60.2	30.8	45.1	42	58	84	16
7/25/95	12:12 p.m.	65	60.2	30.4	44.1	53	47	91	9
7/25/95	12:19 p.m.	65	60.2	29.4	43.0	54	46	91	9
7/25/95	12:24 p.m.	65	60.2	29.2	48.4	47	53	93	7
8/11/95	9:46 a.m.	157	24.9	37.6	29.2	19	81	97	3
8/11/95	9:57 a.m.	157	24.9	37.2	28.8	22	78	98	2
8/11/95	10:07 a.m.	157	24.9	37.5	29.2	23	77	98	2
8/11/95	10:16 a.m.	161	24.3	36.3	34.9	24	76	98	2
8/11/95	10:21 a.m.	161	24.3	36.7	29.5	23	77	98	2
8/14/95	10:12 a.m.	311	12.6	44.4	18.2	9	91	91	9
8/14/95	10:18 a.m.	312	12.5	44.0	18.4	8	92	97	3
8/14/95	10:30 a.m.	313	12.5	44.8	17.6	7	93	95	5
8/14/95	10:34 a.m.	313	12.5	44.7	18.1	7	93	94	6
8/14/95	10:38 a.m.	313	12.5	44.3	18.3	8	92	94	6
8/18/95	11:00 a.m.	595	6.6	35.3	9.7	2	98	81	19
8/18/95	10:46 a.m.	616	6.4	35.4	6.8	2	98	98	2
8/18/95	10:50 a.m.	616	6.4	35.2	9.4	2	98	91	9
8/18/95	10:53 a.m.	616	6.4	35.0	7.3	2	98	99	1
8/18/95	10:57 a.m.	616	6.4	35.7	10.0	2	98	97	3

of repeated measurements had colorfulness values that deviated much more than 2 sigma from the exponential line. However, the spread of these values about the mean was about the same as other observations for the same optical depth. This shows that the variability in the colorfulness numbers is not affected by systematic observer bias in the average colorfulness, and that the variability will be used to define the JND. The observations of the same target by the other observer are discussed in detail below.

Table 1 gives the results of five sets of repeated matches by observer Mahadev for the roof of a red barn about 3.5 km distant. Table 1 is sorted by the extinction coefficient so that one can easily see that the perceived hue did not change with increasing haze, but that the hue derived from the spectrum changed from red to blue. Colorfulness had the opposite behavior; the perceived values decreased with increasing haze and the values from the spectrum stayed about the same. Two-way

analysis of variance was applied to estimate the random error in the sets of repeated measurements in Table 1. This analysis was repeated for both observers' matches of five additional natural targets. The results are given in Table 2. The standard deviation for both observers was 2.05, as calculated from the average of the variances. Although viewing conditions were chosen to be constant, some of this variability was due to small changes in atmospheric conditions.

Based on these results, one can define the JND in colorfulness in many ways. One appropriate definition for this application is based on the following thought experiment. An observer matches a target with the visual colorimeter and determines the colorfulness to be C_1 . The extinction coefficient of the atmosphere is decreased, so the colorfulness of the target is increased by an amount ΔC .

The observer matches the target again to get the new colorfulness C_2 . A JND is defined as the value of ΔC that gives a 95% probability that $C_2 - C_1 > 0$. Assume that C_1 and C_2 are normal random variables with standard deviation s and means C_0 and $C_0 + \Delta C$, respectively (statistical analysis of the SBAVS color matching data confirms that this is a good assumption). Then $C_2 - C_1$ is a normal random variable with mean ΔC and standard deviation $2^{1/2}\sigma$. The value of ΔC needed to ensure a 95% probability that $C_1 - C_2 > 0$ is given by $2^{1/2}\sigma F(0.95)$, where $F(0.95)$ is the inverse of the cumulative standard normal distribution and is equal to 1.645. Thus, the colorfulness JND is taken to be $2^{1/2}\sigma F(0.95) = 2.326\sigma$. From Table 2, using the data for both observers gives $\sigma = 2.05$, and a 1 colorfulness JND is 4.8. This value of σ includes the effects of small random variations in natural illumination, which should be included for this application because they are inevitably present, but makes the value of a colorfulness JND a bit larger than it would be otherwise.

Table 2. Standard deviations of colorfulness for repeated matches of natural targets.

Target	Observer		Distance (km)
	M	U	
White silo	0.91	1.33	3.54
Red roof	1.93	2.41	3.54
Near green meadow	2.93	2.15	3.86
Green hills	2.15	3.46	5.15
Far green meadow	1.45	1.64	10.46
Horizon sky	1.53	1.19	
Average	1.92	2.17	
Number of observations	55	60	

Deciviews and Colorfulness JNDs

Relationships between colorfulness, deciviews, and optical depth are derived below; these will be applied to test the validity of the properties of deciviews given in the regional haze regulations.

From eqs 2 and 3, an expression for deciviews v as a function of colorfulness M is derived:

$$v = 10 \ln \left(-\frac{1}{10x} \ln \left(\frac{M}{M_0} \right) \right) \quad (4)$$

For a given optical depth and inherent colorfulness, the equations above were used to calculate the change in deciviews needed to give a 1-JND increase in colorfulness, using 4.8 as a JND. Figure 2 is a plot of the results as a function of optical depth for objects with three levels of inherent colorfulness. These levels of inherent colorfulness represent a reasonable range for natural targets.¹² As might be expected, more colorful objects are more sensitive to changes in atmospheric haze. Perhaps unexpectedly, the figure shows that landscape features at a distance corresponding to an optical depth of 1–2 are the most sensitive to changes in extinction as measured by deciviews. This range corresponds to one quarter to one half of the visual range. Landscape features outside this range are much less sensitive to changes in haze. If the deciview scale were perceptually uniform, as claimed in the regional haze rules, then the lines in the figure would be horizontal, or at least approximately so. However, the change in deciviews needed to produce a 1-JND change in colorfulness varied a great deal with optical depth and inherent colorfulness. The figure also shows that a 1-JND change in colorfulness always requires more than a 1-deciview change, sometimes much more.

DISCUSSION AND CONCLUSIONS

Regional atmospheric haze affects visibility by producing a visible haze layer that limits the visual range, reduces




Figure 2. Change in deciviews needed to produce a just-noticeable increase in colorfulness for objects with an inherent colorfulness of 25, 50, and 75. The horizontal dashed dotted line represents what would be expected if a 1-deciview change were actually a uniform measure of haze perception.

contrast, and decreases the colorfulness of objects seen through the haze. Of these three effects of haze, the decrease in colorfulness may be the most important and sensitive visual cue. Visual range is not often useful for judging the effects of small changes in extinction. For example, a change in visual range from 50 to 60 km will not be noticed if the most distant landscape feature is at 25 km. The effect of haze on contrast is a better candidate as an indicator of change in haze; however, perceived contrast, like perceived hue, is affected in a nonlinear fashion by the semitransparent nature of haze and is not a sensitive indicator of changes in atmospheric haze.¹⁶ Experimental data have shown that colorfulness is a sensitive measure of changes in haze, so this article has used it to define just-noticeable changes in atmospheric haze.

A just-noticeable decrease in atmospheric haze is defined as a decrease in extinction that would produce a 95% probability of a measurable increase in colorfulness of an object seen through the haze. From the experimental evidence from the two young male observers, a JND in colorfulness was 4.8. For the population in general, this number is certainly too low, since all visual functions decline with age. Thus, the conclusions below about the deciview scale based on this number are understated for the general population.

Analysis of the experimental data showed that for a JND in atmospheric haze as defined above:

- (1) The deciview scale is not uniform in perception over a wide range of visibility conditions. In fact, the change in deciviews needed to be noticeable

varies greatly depending on the optical distance of the landscape feature and its inherent colorfulness.

(2) A 1-deciview change is never noticeable.

What are the implications of these results for measuring progress toward reducing regional haze using the deciview metric? This is difficult to judge because the current proposals are very complex, using particulate measurements and relative humidity to estimate the extinction coefficient and average deciviews for the 20% most-impaired and 20% least-impaired days. The goal is to show no change on the least-impaired days and improvement on the most-impaired days, leading to natural conditions by 2064.¹⁷

The results of this article highlight a possible flaw in this regulatory scheme based on the deciview metric. An unstated assumption is that the nature of the scenic vista can be ignored—that is, a given deciview change will affect the perception of all landscape features in all scenes in the same way. Figure 2 shows that this is approximately true only if all the important landscape features have nearly the same inherent colorfulness and are at distances that correspond to an optical depth of between 1 and 2, or about one quarter to one half of the visual range. In this limited case, the deciview is indeed a uniform metric. However, most scenic vistas do not fit these restrictions and, by Figure 2, will require greater decreases in extinction as measured by deciviews to show a perceptible change. The result is that the emission reductions required by the proposed regulatory analysis are likely to produce much smaller improvements in perceived effects of regional haze than expected. The EPA guidance documents provide an example of an eastern scenic vista with a baseline of 27 deciviews and natural conditions of 11.¹⁷ The decrease in extinction to reach natural conditions by 2064 is 0.35 deciview/yr, or 1.75 deciviews in five years. This five-year reduction should, according to the regulations, result in a noticeable change in regional haze. However, the results herein predict that there would very likely be no noticeable difference in any actual scenic vista in the region as a result of the required emission reductions.

Regional haze rules also call for a uniform rate of improvement in visibility (measured in deciviews) that is needed to go from current conditions to natural conditions by 2064. Since the deciview scale is not uniform in perception over a wide range of visibility conditions, this requirement is also flawed and will not result in uniform improvement in perceived visibility.

ACKNOWLEDGMENTS

The funding for this project was provided by the Electric Power Research Institute under Contract EP-P5419/C2683. The author would like to thank Dr. Naresh Kumar for his support and discussions leading to this work, and Drs.

Shudeish Mahadev and Santiago Urquito for their careful and diligent work as the observers in the field study.

REFERENCES

1. *Fed. Regist.* 1999, 64 (126), 35713-35774.
2. Pitchford, M.; Malm, W. Development and Applications of a Standard Visual Index; *Atmos. Environ.* 1994, 28, 1049-1054.
3. Falmagne, J.C. *Elements of Psychophysical Theory*; Oxford University Press: New York, 1985.
4. Middleton, W.E.K. *Vision through the Atmosphere*; University of Toronto Press: Toronto, Ontario, 1952; p 122.
5. Andrews, E.; Saxena, P.; Musarra, S.; Hildemann, L.M.; Kouttrakis, P.; McMurry, P.H.; Olmez, I.; White, W.H. Concentration and Composition of Atmospheric Aerosols from the 1995 SEAVS Experiment and a Review of the Closure between Chemical and Gravimetric Measurements; *J. Air & Waste Manage. Assoc.* 2000, 50, 648-664.
6. Blando, J.D.; Porcja, R.J.; Li, T.H.; Bowman, D.; Lloy, P.J.; Turpin, B.J. Secondary Formation and the Smoky Mountain Organic Aerosol: An Examination of Aerosol Polarity and Functional Group Composition during SEAVS; *Environ. Sci. Technol.* 1998, 32, 604-613.
7. Dick, W.D.; Ziemann, P.J.; Huang, P.E.; McMurry, P.H. Optical Shape Fraction Measurements of Submicrometer Laboratory and Atmospheric Aerosols; *Measure. Sci. Technol.* 1998, 9, 183-196.
8. Ames, R.B.; Hand, J.L.; Kreidenweis, S.M.; Day, D.E.; Malm, W.C. Optical Measurements of Aerosol Size Distributions in Great Smoky Mountains National Park: Dry Aerosol Characterization; *J. Air & Waste Manage. Assoc.* 2000, 50, 665-676.
9. Hand, J.L.; Ames, R.B.; Kreidenweis, S.M.; Day, D.E.; Malm, W.C. Estimates of Particle Hygroscopicity during the Southeastern Aerosol and Visibility Study; *J. Air & Waste Manage. Assoc.* 2000, 50, 677-685.
10. Malm, W.C.; Day, D.E.; Kreidenweis, S.M. Light Scattering Characteristics of Aerosols as a Function of Relative Humidity: Part I—A Comparison of Measured Scattering and Aerosol Concentrations Using the Theoretical Models; *J. Air & Waste Manage. Assoc.* 2000, 50, 686-700.
11. Malm, W.C.; Day, D.E.; Kreidenweis, S.M. Light Scattering Characteristics of Aerosols at Ambient and as a Function of Relative Humidity: Part II—A Comparison of Measured Scattering and Aerosol Concentrations Using Statistical Models; *J. Air & Waste Manage. Assoc.* 2000, 50, 701-709.
12. Henry, R.C.; Mahadev, S.; Urquito, S.; Chitwood, D. Color Perception through Atmospheric Haze; *J. Opt. Soc. Am., A. Optics, Imaging Sci. & Vision* 2000, 17, 831-835.
13. Henry, R.C.; Shibata, T.; Chitwood, D. Construction and Operation of a Video-Based Visual Colorimeter for Atmospheric Research; *Atmos. Environ.* 1994, 28A, 1065-1069.
14. Mahadev, S.; Henry, R.C. Application of a Color Appearance Model to Vision through Atmospheric Haze; *Color Resh. & Appl.* 1999, 24, 112-120.
15. Mahadev, S. Quantifying the Color Appearance of Objects Viewed through Atmospheric Haze. Ph.D. Dissertation, University of Southern California, Los Angeles, CA, 1998.
16. Henry, R.C. Psychophysics, Visibility, and Perceived Transparency; *Atmos. Environ.* 1987, 21, 159-164.
17. U.S. Environmental Protection Agency. *Draft Guidance for Tracking Progress under the Regional Haze Rule*; U.S. Environmental Protection Agency, Office of Air Quality Planning and Standards: Research Triangle Park, NC, September-27, 2001.

About the Author

Dr. Ronald C. Henry is professor of Civil and Environmental Engineering at the University of Southern California, Department of Civil and Environmental Engineering, 3620 South Vermont Ave., Los Angeles, CA 90089-2531; e-mail: rhenry@usc.edu.

Final Report

BART Analysis for Jim Bridger Unit 3

Prepared For:

PacifiCorp
1407 West North Temple
Salt Lake City, Utah 84116

January 12, 2007

Prepared By:

CH2MHILL
215 South State Street, Suite 1000
Salt Lake City, Utah 84111

Final Report



BART Analysis for Jim Bridger Unit 3

Prepared For:

PacifiCorp
1407 West North Temple
Salt Lake City, Utah 84116

January 12, 2007

Prepared By:

CH2MHILL
215 South State Street, Suite 1000
Salt Lake City, Utah 84111

Executive Summary

Background

In response to the Regional Haze Rule and Best Available Retrofit Technology (BART) regulations and guidelines, CH2M HILL was requested to perform a BART analysis for PacifiCorp's Jim Bridger Unit 3 (hereafter referred to as Jim Bridger 3). A BART analysis has been conducted for the following criteria pollutants: oxides of nitrogen (NO_x), sulfur dioxide (SO₂), and particulate matter less than 10 microns in aerodynamic diameter (PM₁₀). The Jim Bridger Station consists of four 530 megawatt (MW) units with a total generating capacity of 2,120 MW. Because the total generating capacity of the Jim Bridger Station exceeds 750 MW, presumptive BART limits apply to Jim Bridger 3, based on the United States Environmental Protection Agency's (EPA) guidelines. BART emissions limits must be achieved within five years after the State Implementation Plan (SIP) is approved by the EPA. A compliance date of 2014 was assumed for this analysis.

In completing the BART analysis, technology alternatives were investigated and potential reductions in NO_x, SO₂, and PM₁₀ emissions rates were identified. The following technology alternatives were investigated, listed below by pollutant:

NO_x emission controls:

- Low NO_x burners with over-fire air
- Rotating opposed fire air
- Low NO_x burners with selective non-catalytic reduction system (SNCR)
- Low NO_x burners with selective catalytic reduction (SCR) system

SO₂ emission controls:

- Optimize current operation of existing wet sodium flue gas desulfurization (FGD) system
- Upgrade wet sodium FGD system to achieve an SO₂ emission rate of 0.10 lb/MMBtu
- New dry FGD system

PM₁₀ emission controls:

- Sulfur trioxide (SO₃) injection flue gas conditioning system on existing electrostatic precipitator
- Polishing fabric filter

BART Engineering Analysis

The specific steps in a BART engineering analysis are identified in the Code of Federal Regulations (CFR) at 40 CFR 51 Appendix Y, Section IV. The evaluation must include:

1. The identification of available, technically feasible, retrofit control options

2. Consideration of any pollution control equipment in use at the source (which affects the availability of options and their impacts)
3. The costs of compliance with the control options
4. The remaining useful life of the facility
5. The energy and non-air quality environmental impacts of compliance
6. The degree of visibility improvement which may reasonably be anticipated from the use of BART

These steps are incorporated into the BART analysis as follows:

Step 1 – Identify All Available Retrofit Control Technologies

Step 2 – Eliminate Technically Infeasible Options

- The identification of available, technically feasible, retrofit control options
- Consideration of any pollution control equipment in use at the source (which affects the applicability of options and their impacts)

Step 3 – Evaluate Control Effectiveness of Remaining Control Technologies

Step 4 – Evaluate Impacts and Document the Results

- The costs of compliance with the control options
- The remaining useful life of the facility
- The energy and non-air quality environmental impacts of compliance

Step 5 – Evaluate Visibility Impacts

- The degree of visibility improvement which may reasonably be anticipated from the use of BART

Separate analyses have been conducted for NO_x, SO₂, and PM₁₀ emissions. All costs included in the BART analyses are in 2006 dollars, and costs have not been escalated to the assumed 2014 BART implementation date.

Coal Characteristics

The main source of coal burned at Jim Bridger 3 will be the Bridger Underground Mine. Secondary sources are the Bridger Surface Mine, the Bridger Highwall Mine, the Black Butte Mine, and the Leucite Hills Mine. These coals are ranked as subbituminous, but are closer in characteristics to bituminous coal in many of the parameters influencing NO_x formation. These coals have higher nitrogen content than coals from the Powder River Basin (PRB), which represent the bulk of subbituminous coal use in the U.S. This BART analysis has considered the higher nitrogen content and different combustion characteristics of PRB coals, as compared to those coals used at Jim Bridger 3, and has evaluated the effect of these qualities on NO_x formation and achievable emission rates.

Recommendations

NO_x Emission Control

The BART presumptive NO_x limit assigned by EPA for tangentially-fired boilers burning subbituminous coal is 0.15 lb/MMBtu. However, as documented in this analysis, the characteristics of the Jim Bridger coals are more closely aligned with bituminous coals, with a presumptive BART NO_x limit of 0.28 lb/MMBtu.

CH2M HILL recommends low-NO_x burners with over-fire air (LNB w/OFA) as BART for Jim Bridger 3, based on the projected significant reduction in NO_x emissions, reasonable control costs, and the advantages of no additional power requirements or non-air quality environmental impacts. NO_x reductions are expected to be similar to those realized at Jim Bridger 2. CH2M HILL recommends that the unit be permitted at a rate of 0.26 lb/MMBtu.

SO₂ Emission Control

CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 3, based on the significant reduction in SO₂ emissions, reasonable control costs, and the advantages of minimal additional power requirements and minimal non-air quality environmental impacts. This upgrade approach will meet the BART presumptive SO₂ limit of 0.15 lb/MMBtu.

PM₁₀ Emission Control

CH2M HILL recommends finalizing the permitting of the flue gas conditioning system to enhance the performance of the existing electrostatic precipitator (ESP) as BART for Jim Bridger 3, based on the significant reduction in PM₁₀ emissions, reasonable control costs, and the advantages of minimal additional power requirements and no non-air quality environmental impacts.

Control Scenario 1

These BART selections, which include installing low NO_x burners with over-fire air, upgrading the existing FGD system, and operating the existing electrostatic precipitator with an SO₃ flue gas conditioning system, are identified as Scenario 1 throughout this report.

BART Modeling Analysis

CH2M HILL used the CALPUFF modeling system to assess the visibility impacts of emissions from Jim Bridger 3 at Class I areas. The Class I areas potentially affected are located more than 50 kilometers, but less than 300 kilometers, from the Jim Bridger Plant.

The Class I areas include the following wilderness areas (WA):

- Bridger WA
- Fitzpatrick WA
- Mt. Zirkel WA

Because Jim Bridger 3 will simultaneously control NO_x, SO₂, and PM₁₀ emissions, four post control atmospheric dispersion modeling scenarios were developed to cover the range of effectiveness for combining the individual NO_x, SO₂ and PM₁₀ control technologies under evaluation. These modeling scenarios, and the controls assumed, are as follows:

- **Scenario 1:** New LNB w/OFA modifications, upgraded wet FGD system, and flue gas conditioning for enhanced ESP performance. As indicated previously, this scenario represents CH2M HILL HILL's preliminary BART recommendation.
- **Scenario 2:** New LNB w/OFA modifications, upgraded wet FGD system, and new polishing fabric filter.
- **Scenario 3:** New LNB w/OFA modifications and SCR, upgraded wet FGD system, and flue gas conditioning for enhanced ESP performance.
- **Scenario 4:** New LNB w/OFA modifications and SCR, upgraded wet FGD system, and new polishing fabric filter.

Visibility improvements for all emission control scenarios were analyzed, and the results were compared utilizing a Least-Cost Envelope, as outlined in the draft EPA 1990 New Source Review Workshop Manual (NSR Manual).

Least-Cost Envelope Analysis

EPA has adopted the Least-Cost Envelope Analysis Methodology as an accepted methodology for selecting the most reasonable, cost-effective controls. Incremental cost-effectiveness comparisons focus on annualized cost and emission reduction differences between dominant alternatives. The dominant set of control alternatives is determined by generating what is called the envelope of least-cost alternatives. This is a graphical plot of total annualized costs for a total emissions reductions for all control alternatives identified in the BART analysis.

To evaluate the impacts of the modeled control scenarios on the three Class I areas, the total annualized cost, cost per deciview (dV) reduction, and cost per reduction in number of days above 0.5 dV were analyzed. This report provides a comparison of the average incremental costs between relevant scenarios for the three Class I areas; the total annualized cost versus number of days above 0.5 dV, and the total annualized cost versus 98th percentile delta-deciview (Δ dV) reduction.

Results of the Least-Cost Envelope Analysis validate the selection of Scenario 1, based on incremental cost and visibility improvements. Scenario 2 (LNB w/OFA, upgraded wet FGD, and polishing fabric filter) is eliminated, because it is to the left of the curve formed by the "dominant" control alternative scenario, which indicates a scenario with lower improvement and/or higher costs. Scenario 3 (LNB w/OFA and SCR, upgraded wet FGD, and flue gas conditioning for enhanced ESP performance) is not selected due to very high incremental costs, on the basis of both a cost per day of improvement and cost per dV reduction. While Scenario 4 (LNB w/OFA and SCR, upgraded wet FGD, and polishing fabric filter) provides some potential visibility advantage over Scenario 1, the projected improvement is less than

half a dV, and the projected costs are excessive. Therefore, Scenario 1 represents BART for Jim Bridger 3.

Just-Noticeable Differences in Atmospheric Haze

Studies have been conducted that demonstrate only dV differences of approximately 1.5 to 2.0 dV or more are perceptible by the human eye. Deciview changes of less than 1.5 cannot be distinguished by the average person. Therefore, the modeling analysis results indicate that only minimal, if any, observable visibility improvements at the Class I areas studied would be expected under any of the control scenarios. Thus, the results indicate that only minimal discernable visibility improvements may result, even though PacifiCorp will be spending many millions of dollars at this single unit, and over a billion dollars when considering its entire fleet of coal-fired power plants.

Contents

Acronyms and Abbreviations	iv
1.0 Introduction	1-1
2.0 Present Unit Operation.....	2-1
3.0 BART Engineering Analysis	3-1
3.1 Applicability	3-1
3.2 BART Process.....	3-1
3.2.1 BART NO _x Analysis.....	3-2
3.2.2 BART SO ₂ Analysis	3-14
3.2.3 BART PM ₁₀ Analysis	3-16
4.0 BART Modeling Analysis.....	4-1
4.1 Model Selection	4-1
4.2 CALMET Methodology.....	4-1
4.2.1 Dimensions of the Modeling Domain.....	4-1
4.2.2 CALMET Input Data	4-3
4.2.3 Validation of CALMET Wind Field.....	4-6
4.3 CALPUFF Modeling Approach.....	4-6
4.3.1 Background Ozone and Ammonia.....	4-6
4.3.2 Stack Parameters	4-7
4.3.3 Emission Rates.....	4-7
4.3.4 Post Control Scenarios.....	4-7
4.3.5 Modeling Process.....	4-10
4.3.6 Receptor Grids	4-10
4.4 CALPOST.....	4-10
Presentation of Modeling Results	4-11
Degree of Visibility Change for Baseline vs. Preferred Scenario	4-11
5.0 Preliminary Assessment and Recommendations	5-1
5.1 Least-Cost Envelope Analysis	5-1
5.1.1 Analysis Methodology	5-1
5.1.2 Analysis Results.....	5-8
5.2 Recommendations.....	5-8
5.2.1 NO _x Emission Control	5-8
5.2.2 SO ₂ Emission Control.....	5-8
5.2.3 PM ₁₀ Emission Control.....	5-8
5.3 Just-Noticeable Differences in Atmospheric Haze.....	5-9
6.0 References	6-1

Tables

2-1	Unit Operation and Study Assumptions	2-1
2-2	Coal Sources and Characteristics	2-3
3-1	Coal Characteristics Comparison	3-4
3-2	NO _x Control Technology Projected Emission Rates	3-8
3-3	NO _x Control Cost Comparison	3-11
3-4	SO ₂ Control Technology Emission Rates	3-14
3-5	SO ₂ Control Cost Comparison (Incremental to Existing FGD System)	3-16
3-6	PM ₁₀ Control Technology Emission Rates	3-18
3-7	PM ₁₀ Control Cost Comparison (Incremental to Existing ESP)	3-18
4-1	User-Specified CALMET Options	4-3
4-2	BART Model Input Data	4-8
4-3	Average Natural Levels of Aerosol Components	4-11
4-4	Costs and Visibility Modeling Results for Baseline Vs. Post-Control Scenarios at Class I Areas	4-12
5-1	Control Scenario Results for the Bridger Class 1 Wilderness Area	5-2
5-2	Control Scenario Results for the Fitzpatrick Class 1 Wilderness Area	5-3
5-3	Control Scenario Results for the Mt. Zirkel Class 1 Wilderness Area	5-3
5-4	Bridger Class I Wilderness Area Incremental Analysis Data	5-4
5-5	Fitzpatrick Class I Wilderness Area Incremental Analysis Data	5-4
5-6	Mt. Zirkel Class I Wilderness Area Incremental Analysis Data	5-4

Figures

3-1	Illustration of the Effect of Agglomeration on the Speed of Coal Combustion	3-3
3-2	Plot of Typical Nitrogen Content of Various Coals and Applicable Presumptive BART NO _x Limits	3-5
3-3	Plot of Typical Oxygen Content of Various Coals and Applicable Presumptive BART NO _x Limits	3-5
3-4	First Year Control Cost for NO _x Air Pollution Control Options	3-13
3-5	First Year Control Cost for PM Air Pollution Control Options	3-20
4-1	Extent of Modeling Domain	4-2
4-2	Surface and Upper Air Station Locations	4-5
5-1	Least Cost Envelope Bridger Class I WA Days Reduction	5-5
5-2	Least Cost Envelope Bridger Class I WA 98 th Percentile Reduction	5-5
5-3	Least Cost Envelope Fitzpatrick Class I WA Days Reduction	5-6
5-4	Least Cost Envelope Fitzpatrick Class I WA 98 th Percentile Reduction	5-6
5-5	Least Cost Envelope Mt. Zirkel Class I WA Days Reduction	5-7
5-6	Least Cost Envelope Mt. Zirkel Class I WA 98 th Percentile Reduction	5-7

Appendices

A	Economic Analysis
B	2006 Wyoming BART Protocol
C	Just-Noticeable Differences in Atmospheric Haze - Ronald C. Henry Report

Acronyms and Abbreviations

BACT	Best Available Control Technology
BART	Best Available Retrofit Technology
CALDESK	Program to display data and results
CALMET	Meteorological data preprocessing program for CALPUFF
CALPOST	Post-processing program for calculating visibility impacts
CALPUFF	Gaussian puff dispersion model
COHPAC	Compact Hybrid Particulate Collector
dV	deciview
DEQ	Department of Environmental Quality
ESP	electrostatic precipitator
EPA	United States Environmental Protection Agency
Fuel NO _x	oxidation of fuel bound oxides of nitrogen
FGC	flue gas conditioning
FGD	flue gas desulfurization
<i>f</i> (RH)	relative humidity factors
ID	internal diameter
kW	kilowatts
kW-Hr	kilowatt-hour
LAER	lowest achievable emission rate
LNB	Low-NO _x burner
LOI	loss on ignition
MMBtu	Million British Thermal Units
MM5	Mesoscale Meteorological Model, Version 5
MW	megawatts
N ₂	nitrogen
NO	nitric oxide
NO _x	nitrogen oxides
NWS	National Weather Service
OFA	over fire air
PM ₁₀	particulate matter less than 10 microns in aerodynamic diameter
PRB	Powder River Basin
ROFA	Rotating Opposed Fire Air

S&L	Sargent & Lundy
SCR	selective catalytic reduction system
SIP	State Implementation Plan
SNCR	selective non-catalytic reduction system
SO ₂	sulfur dioxide
SO ₃	sulfur trioxide
Thermal NO _x	high temperature fixation of atmospheric nitrogen in combustion air
USGS	U.S. Geological Survey
WA	Wilderness Area
WDEQ-AQD	Wyoming Department of Environmental Quality – Air Quality Division

1.0 Introduction

Best Available Retrofit Technology (BART) guidelines were established as a result of United States Environmental Protection Agency (EPA) regulations intended to reduce the occurrence of regional haze in national parks and other Class I protected air quality areas in the United States¹. These guidelines provide guidance for states when determining which facilities must install additional controls, and the type of controls that must be used. Facilities eligible for BART installation were built between 1962 and 1977, and have the potential to emit more than 250 tons/year of visibility-impairing pollutants.

The Wyoming Department of Environmental Quality (DEQ) BART regulations state that each source subject to BART must submit a BART application for a construction permit by December 15, 2006. PacifiCorp received an extension from the Wyoming DEQ to submit the BART report for Jim Bridger Unit 3 by January 12, 2007. This report to the Wyoming DEQ must include a BART analysis, and a proposal and justification for BART at the source.

The State of Wyoming has identified those eligible in-state facilities that are required to reduce emissions under BART, and will set BART emissions limits for those facilities. This information will be included in the State of Wyoming State Implementation Plan (SIP), which the State has estimated will be formally submitted to the EPA by early 2008. The EPA BART guidelines also state that the BART emission limits must be fully implemented within five years of EPA's approval of the SIP.

There are five basic elements related to BART, when addressing the issue of emissions for the identified facilities:

- Any existing pollution control technology in use at the source
- The cost of the controls
- The remaining useful life of the source
- The energy and non-air environmental impacts of compliance
- The degree of improvement in visibility which may reasonably be anticipated from the use of such technology

This report documents the BART analysis that was performed on Jim Bridger 3 by CH2M HILL for PacifiCorp. The analysis was performed for the pollutants NO_x, SO₂, and particulate matter less than 10 microns in aerodynamic diameter (PM₁₀), because they are the primary criteria pollutants that affect visibility.

Section 2.0 of this report provides a description of the present unit operation, including a discussion of coal sources and characteristics. The BART Engineering Analysis is provided in Section 3.0, by pollutant type. Section 4.0 provides the methodology and results of the BART Modeling Analysis, followed by recommendations in Section 5.0. References are

¹ 40 CFR Part 51: Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations; Final Rule. 70 Federal Register, 39103-39172, July 6, 2005.

provided in Section 6.0. Appendices provide more detail on the Economic Analysis, the 2006 Wyoming BART Protocol, and a paper by Dr. Ronald Henry, titled, *Just Noticeable Differences in Atmospheric Haze*.

2.0 Present Unit Operation

The Jim Bridger Station consists of four units with a total generating capacity of 2,120 megawatts (MW). Jim Bridger 3 is a nominal 530 net MW unit located approximately 35 miles northeast of Rock Springs, Wyoming. Unit 3 is equipped with a tangentially fired pulverized coal boiler with low NO_x burners manufactured by Combustion Engineering. The unit was constructed with a Flakt wire frame electrostatic precipitator (ESP). The unit contains a Babcock & Wilcox wet sodium flue-gas desulfurization (FGD) system with three absorber towers installed in 1988. An Emerson Ovation distributed control system (DCS) was installed in 2003.

Jim Bridger 3 was placed in service in 1976. Its current economic depreciation life is through 2040; however, this analysis is based on a 20 year life for BART control technologies. Assuming a BART implementation date of 2014, this will result in an approximate remaining useful life for Jim Bridger 3 of 20 years from the installation date of any new or modified BART-related equipment. This report does not attempt to quantify any additional life extension costs needed to allow the unit and these control devices at Jim Bridger 3 to operate until 2040.

Table 2-1 lists additional unit information and study assumptions for this analysis.

TABLE 2-1
Unit Operation and Study Assumptions
Jim Bridger 3

General Plant Data	
Site Elevation feet above MSL	6669
Stack Height feet	500
Stack Exit ID feet /Exit Area sq. ft.	24 /452.4
Stack Exit Temperature °F	140
Stack Exit Velocity ft/sec	84.04
Stack Flow ACFM	2,281,182
Latitude deg: min : sec	41:44:18.54 north
Longitude deg: min : sec	108:47:12.82 west
Annual Unit Capacity Factor (%)	90
Net Unit Output (MW)	530
Net Unit Heat Rate (Btu/kW-Hr)(100% load)	10,400 (as measured by fuel throughput)
Boiler Heat Input (MMBtu/Hr)(100% load)	6,000 (as measured by CEM)
Type of Boiler	Tangentially fired
Boiler Fuel	Coal
Coal Sources	Bridger Mine, Black Butte Mine, Leucite Hills Mine
Coal Heating Value (Btu/lb)*	9,660
Coal Sulfur Content (wt. %)*	0.58

TABLE 2-1
Unit Operation and Study Assumptions
Jim Bridger 3

Coal Ash Content (wt. %)*	10.3
Coal Moisture Content (wt. %)*	19.3
Coal Nitrogen Content (wt. %)*	0.98
Current NO _x Controls	Low NO _x burners
NO _x Emission Rate (lb/MMBtu)	0.45
Current SO ₂ Controls	Sodium based wet scrubber
SO ₂ Emission Rate (lb/MMBtu)	0.3
Current PM ₁₀ Controls	Electrostatic Precipitator
PM ₁₀ Emission Rate (lb/MMBtu)**	0.057

* Coal characteristics based on Bridger Underground Mine (primary coal source)

** Based on maximum historic emission rate from 1999 – 2001, prior to installation of the SO₃ injection system.

The BART presumptive NO_x limit for tangential-fired boilers burning subbituminous coal is 0.15 lb/MMBtu and the BART presumptive NO_x limit for burning bituminous coal is 0.28 lb/MMBtu. The main sources of coal burned at Jim Bridger 3 are the Bridger Mine and secondarily the Black Butte Mine and Leucite Hills Mine. These coals are ranked as subbituminous, but are closer in characteristics to bituminous coal in many of the parameters influencing NO_x formation. These coals have higher nitrogen content than coals from the Powder River Basin (PRB), which represent the bulk of subbituminous coal use in the U.S. This BART analysis has considered the higher nitrogen content and the different combustion characteristics of PRB coals, as compared to those coals used at Jim Bridger 3, and has evaluated the effect of these qualities on NO_x formation and achievable emission rates. Coal sources and characteristics are summarized in Table 2-2. The primary source of coal will be the Bridger Underground Mine, and data on coal from this source were used in the modeling analysis. For the coal analysis that is presented in Section 3.2.1, the data from all the coal sources were used.

TABLE 2-2
Coal Sources and Characteristics
Jim Bridger 3

Mines	Moist. %	Ash %	Volatile Matter %	Fixed Carbon %	Btu/lb	Sulfur %	MAF (Btu/lb)	Ultimate Analysis (% dry basis)						
								Hydrogen	Carbon	Sulfur	Nitrogen	Oxygen	Ash	
Bridger Mine Underground	19.3	10.3	32.2	38.3	9660	0.58	13712	4.66	69.2	0.72	1.22	11.8	12.4	
Max	Not enough data yet to run statistical analysis for variability													
Min	Not enough data yet to run statistical analysis for variability													
Bridger Mine Surface	19.1	10.6	32.3	38.0	9390	0.57	13340	4.38	37.4	0.71	1.26	13.2	13.0	
Max	20.5	12.5	35.5	41.9	9800	0.72	13500	4.69	4.0	0.90	1.43	14.8	15.8	
Min	17.5	9.0	31.0	36.0	9000	0.49	13100	4.00	64.3	0.60	1.14	11.7	11.2	
Bridger Mine Highwall	18.0	9.5	33.0	39.5	9700	0.58	13500	No samples of separate highwall coal						
Max	Not enough data yet to run statistical analysis for variability													
Min	Not enough data yet to run statistical analysis for variability													
Black Butte Mine	20.0	9.2	33.3	35.6	9450	0.45	13330	4.43	68.7	0.56	1.47	13.4	11.5	
Max	21.1	10.8	35.4	41.9	10275	0.62	13500	4.66	70.5	0.78	1.69	14.8	13.6	
Min	18.0	7.6	29.9	36.8	9180	0.33	13140	4.21	66.1	0.41	1.25	11.6	9.7	
Leucite Hills Mine (through 2009)	19.4	11.5	30.7	38.3	9080	0.64	13140	4.20	66.0	0.81	1.48	13.2	14.4	
Max	23.0	15.0	33.0	43.0	10250	0.90	13800	4.70	70.0	1.20	1.64	17.1	19.0	
Min	17.0	8.0	28.3	33.6	8000	0.40	12300	3.70	61.0	0.50	1.32	10.5	10.0	

3.0 BART Engineering Analysis

This section presents the required BART engineering analysis.

3.1 Applicability

In compliance with regional haze requirements, the State of Wyoming must prepare and submit visibility SIPs to the EPA for Class I areas. The State has estimated that the formal submittal of the SIPs will occur by early 2008. The first phase of the regional haze program is the implementation of BART emission controls on all BART eligible units, within five years after EPA approval of the SIP.

3.2 BART Process

The specific steps in a BART engineering analysis are identified in the Code of Federal Regulations (CFR) at 40 CFR 51 Appendix Y, Section IV. The evaluation must include:

1. The identification of available, technically feasible, retrofit control options
2. Consideration of any pollution control equipment in use at the source (which affects the availability of options and their impacts)
3. The costs of compliance with the control options
4. The remaining useful life of the facility
5. The energy and non-air quality environmental impacts of compliance, and
6. The degree of visibility improvement which may reasonably be anticipated from the use of BART

These steps are incorporated into the BART analysis as follows:

Step 1 – Identify All Available Retrofit Control Technologies

Step 2 – Eliminate Technically Infeasible Options

- The identification of available, technically feasible, retrofit control options
- Consideration of any pollution control equipment in use at the source (which affects the applicability of options and their impacts)

Step 3 – Evaluate Control Effectiveness of Remaining Control Technologies

Step 4 – Evaluate Impacts and Document the Results

- The costs of compliance with the control options
- The remaining useful life of the facility
- The energy and non-air quality environmental impacts of compliance

Step 5 – Evaluate Visibility Impacts

- The degree of visibility improvement which may reasonably be anticipated from the use of BART

In order to minimize costs in the BART analysis, consideration was made of any pollution control equipment in use at the source, the costs of compliance associated with the control options, and the energy and non-air quality environmental impacts of compliance using these existing control devices. In some cases, enhancing the performance of the existing control equipment was considered. Other scenarios with new control equipment were also developed.

All costs included in the BART analysis are in 2006 dollars (not escalated to 2014 BART implementation date).

3.2.1 BART NO_x Analysis

NO_x formation in coal-fired boilers is a complex process that is dependent on a number of variables, including operating conditions, equipment design, and coal characteristics.

3.2.1.1 Formation of NO_x

During coal combustion, NO_x is formed in three different ways. The dominant source of NO_x formation is the oxidation of fuel-bound nitrogen (fuel NO_x). During combustion, part of the fuel-bound nitrogen is released from the coal with the volatile matter, and part is retained in the solid portion (char). The nitrogen chemically bound in the coal is partially oxidized to nitrogen oxides (NO and NO₂) and partially reduced to molecular nitrogen (N₂). A smaller part of NO_x formation is due to high temperature fixation of atmospheric nitrogen in the combustion air (thermal NO_x). A very small amount of NO_x is called “prompt” NO_x. Prompt NO_x results from an interaction of hydrocarbon radicals, nitrogen, and oxygen.

In a conventional pulverized coal burner, air is introduced with turbulence to promote good mixing of fuel and air, which provides stable combustion. However, not all of the oxygen in the air is used for combustion. Some of the oxygen combines with the fuel nitrogen to form NO_x.

Coal characteristics directly and significantly affect NO_x emissions from coal combustion. Coal ranking is a means of classifying coals according to their degree of metamorphism in the natural series, from lignite to subbituminous to bituminous and on to anthracite. Lower rank coals, such as the subbituminous coals from the PRB, produce lower NO_x emissions than higher rank bituminous coals, due to their higher reactivity and lower nitrogen content. The fixed carbon to volatile matter ratio (fuel ratio), coal oxygen content, and rank are good relative indices of the reactivity of a coal. Lower rank coals release more organically bound nitrogen earlier in the combustion process than do higher rank bituminous coals. When used with low NO_x burners, subbituminous coals create a longer time for the kinetics to promote more stable molecular nitrogen, and hence result in lower NO_x emissions.

Coals from the PRB are classified as subbituminous C and demonstrate the high reactivity and low NO_x production characteristics described above. Based on data from the Energy Information Administration (EIA), PRB coals currently represent 88 percent of total U.S. subbituminous production and 73 percent of western coal production. Most references to “western” coal and subbituminous coal infer PRB origin and characteristics. Emissions standards differentiating between bituminous and subbituminous coals are presumed to use

PRB coal as the basis for the subbituminous standards, due to their dominant market presence and unique characteristics.

There are a number of western coals that are classified as subbituminous, however, they border on being ranked as bituminous and do not display many of the qualities of PRB coals, including most of the low NO_x forming characteristics. Coals from the Bridger, Black Butte, and Leucite Hills mines fall into this category.

As defined by the American Society for Testing and Materials, the only distinguishing characteristic that classifies the coals used at Jim Bridger 3 as subbituminous rather than bituminous – that is, they are “agglomerating” as compared to “non-agglomerating”. Agglomerating as applied to coal is “the property of softening when it is heated to above about 400°C in a non-oxidizing atmosphere, and then appearing as a coherent mass after cooling to room temperature.” Because the agglomerating property of coals is the result of particles transforming into a plastic or semi-liquid state when heated, it reflects a change in surface area of the particle. Thus, with the application of heat, agglomerating coals would tend to develop a non-porous surface while the surface of non-agglomerating coals would become even more porous with combustion. As shown by Figure 3-1, the increased porosity provides more particle surface area resulting in more favorable combustion conditions. This non-agglomerating property assists in making subbituminous coals more amenable to controlling NO_x by allowing less air to be introduced during the initial ignition portion of the combustion process. The coals from the Bridger, Black Butte and Leucite Hills mines just barely fall into the category of non-agglomerating coals. While each of these coals is considered non-agglomerating, they either do not exhibit those properties of non-agglomerating coals or exhibit them to only a minor degree. The conditions during combustion of typical non-agglomerating coals that make it easier to control NO_x emissions do not exist for the Bridger blends of coals.

FIGURE 3-1
Illustration of the Effect of Agglomeration on the Speed of Coal Combustion
Jim Bridger 3




Table 3-1 shows key characteristics of a typical PRB coal compared to coals from the Bridger Mine, Black Butte, and Leucite Hills, as well as Twentymile, which is a representative western bituminous coal.

TABLE 3-1
Coal Characteristics Comparison
Jim Bridger 3

Parameter	Typical PRB	Bridger Mine	Black Butte	Leucite Hills	Twentymile
Nitrogen (% dry)	1.10	1.26	1.47	1.48	1.85
Oxygen (% dry)	16.2	13.2	13.4	13.2	7.19
Coal rank	Sub C	Sub B	Sub B	Sub B	Bitum. high volatility B

As shown in Table 3-1, although Bridger, Black Butte, and Leucite Hills are classified as subbituminous, they all exhibit higher nitrogen content and lower oxygen content than the PRB coal. The higher nitrogen content is an indication that more nitrogen is available to the combustion process and higher NO_x emissions are likely. Oxygen content can be correlated to the reactivity of the coal, with more reactive coals generally containing higher levels of oxygen. More reactive coals tend to produce lower NO_x emissions, and they are also more conducive to reduction of NO_x emissions through the use of combustion control measures, such as low NO_x burners and over-fire air (OFA). These characteristics indicate that higher NO_x formation is likely with coal from the Bridger, Black Butte, and Leucite Hills mines, rather than with PRB coal. The Bridger, Black Butte, and Leucite Hills coals all contain quality characteristics that fall between a typical PRB coal and Twentymile. Twentymile is a clearly bituminous coal that produces higher NO_x, as has been demonstrated at power plants burning this fuel.

Figures 3-2 and 3-3 graphically illustrate the relationship of nitrogen and oxygen content to the BART presumptive NO_x limits for the coals listed in Table 3-1. Each chart identifies the presumptive BART limit associated with a typical bituminous and subbituminous coal, and demonstrates how the Jim Bridger coal falls between these two general coal classifications.

The Bridger blend data point represents a combination of coals from the Bridger Mine, Black Butte, and Leucite Hills that has been used at Jim Bridger 3, and indicates the average NO_x emission rate achieved during the years 2003-2005. The Jim Bridger 2 data point consists of the same blend of coals as Jim Bridger 3, and represents the NO_x emission rate achieved after installation of Alstom's current state of the art TFS2000 LNB and OFA system. The long-term sustainable emission rate for this system is expected to be 0.24 lb/MMBtu. All four units at Jim Bridger consist of identical boilers; while there may be some differences in performance among them, installation of the TFS2000 firing system at Jim Bridger 3 would likely result in performance and NO_x emission rates comparable to those at Jim Bridger 2.

Figures 3-2 and 3-3 both demonstrate that for the Jim Bridger units with the TFS2000 low NO_x emission system installed and burning a combination of the Bridger, Black Butte, and Leucite Hill coals, the likely NO_x emission rate will be closer to the bituminous end (0.28) of the BART presumptive NO_x limit range, rather than the BART presumptive NO_x limit of

0.15 lb/MMBtu for subbituminous coal. All these factors are consistent with the observed sustainable rate of 0.24 lb/MMBtu.

FIGURE 3-2
 Plot of Typical Nitrogen Content of Various Coals and Applicable Presumptive BART NO_x Limits
 Jim Bridger 3





FIGURE 3-3
 Plot of Typical Oxygen Content of Various Coals and Applicable Presumptive BART NO_x Limits
 Jim Bridger 3



Coal quality characteristics also impact the design and operation of the boiler and associated auxiliary equipment. Minor changes in quality can sometimes be accommodated through operational adjustments or changes to equipment. It is important to note, however, that consistent variations in quality or assumptions of “average” quality for performance projections can be problematic. This is particularly troublesome when dealing with performance issues that are very sensitive to both coal quality and combustion conditions, such as NO_x formation. There is significant variability in the quality of coals burned at Jim Bridger 3. In addition to burning coal from Black Butte and Leucite Hills, Jim Bridger 3 burns coal supplied from the Bridger Mine consisting of three sources: underground, surface, and highwall operations. Each of these coal sources has different quality characteristics, as well as inherent variability in composition of the coal within the mine.

Several of the coal quality characteristics and their effect on NO_x formation have been previously discussed. There are some additional considerations that illustrate the complexity of achieving and maintaining consistent low NO_x emissions with pulverized coal on a shorter term, such as a 30-day rolling average basis.

Good combustion is based on the “three Ts”: time, temperature and turbulence. These parameters along with a “design” coal are taken into consideration when designing a boiler and associated firing equipment such as fans, burners, and pulverizers. If a performance requirement such as NO_x emission limits is subsequently changed, conflicts with and between other performance issues can result.

Jim Bridger 3 is located at an altitude of 6,669 feet above sea level. At this elevation, atmospheric pressure is lower (11.5 pounds per square inch) as compared with sea level pressure of 14.7 pounds per square inch. This lower pressure means that less oxygen is available for combustion for each volume of air. In order to provide adequate oxygen to meet the requirements for efficient combustion, larger volumes of air are required. When adjusting air flows and distribution to reduce NO_x emissions using low NO_x burners and overfire air, original boiler design restrictions again limit the modifications that can be made and still achieve satisfactory combustion performance.

Another significant factor in controlling NO_x emissions is the fineness of the coal entering the burners. Fineness is influenced by the grindability index (Hardgrove) of the coal. Finer coal particles promote release of volatiles and assist char burnout due to more surface area exposed to air. NO_x reduction with high volatile coals is improved with greater fineness and with proper air staging. The lower rank subbituminous coals such as PRB coals are quite friable and easy to grind. Coals with lower Hardgrove Grindability Index values, such as those used at Jim Bridger 3, are more difficult to grind and can contribute to higher NO_x levels. In addition, coal fineness can deteriorate over time periods between pulverizer maintenance and service as pulverizer grinding surfaces wear.

In summary, when all the factors of agglomeration versus non-agglomeration, nitrogen and oxygen content of the coals, and the grindability index are taken into account, this analysis demonstrates that, for the coal used at Jim Bridger 3, the more applicable presumptive BART limit for NO_x emissions is 0.28 lb/MMBtu. The BART analysis for NO_x emissions from Jim Bridger 3 is further described below.

3.2.1.2 Step 1: Identify All Available Retrofit Control Technologies

The first step of the BART process is to evaluate NO_x control technologies with practical potential for application to Jim Bridger 3, including those control technologies identified as Best Available Control Technology (BACT) or lowest achievable emission rate (LAER) by permitting agencies across the United States. A broad range of information sources have been reviewed in an effort to identify potentially applicable emission control technologies. NO_x emissions at Jim Bridger 3 are currently controlled through the use of good combustion practices and OFA.

The following potential NO_x control technology options were considered:

- New/modified low-NO_x burners (LNB) with advanced OFA
- Rotating Opposed Fire Air (ROFA)
- Conventional selective non-catalytic reduction system (SNCR)
- Selective catalytic reduction system (SCR)

3.2.1.3 Step 2: Eliminate Technically Infeasible Options

For Jim Bridger 3, a tangential-fired configuration burning subbituminous coal, technical feasibility will primarily be determined by physical constraints, boiler configuration, and on the ability to achieve the regulatory presumptive limit (used as a guide) of 0.28 lb NO_x/MMBtu. Jim Bridger 3 has an uncontrolled NO_x emission rate of 0.45 lb/MMBtu.

For this BART analysis, information pertaining to LNBs, OFA, SNCR, and SCR were based on the Multi-Pollutant Control Report dated October, 2002 (S&L Study). The cost estimates for SCR and SNCR were updated by Sargent & Lundy (S&L) in October 2006. PacifiCorp provided additional emissions data and costs developed by boiler vendors for LNBs and OFA. Also, CH2M HILL solicited a proposal from Mobotec for their ROFA technology.

With SNCR, an amine-based reagent such as ammonia, or more commonly urea, is injected into the furnace within a temperature range of 1,600° F to 2,100° F, where it reduces NO_x to nitrogen and water. NO_x reductions of up to 40 to 60 percent have been achieved, although 15 to 30 percent is more realistic for most applications. SNCR is typically applied on smaller units. Adequate reagent distribution in the furnaces of large units can be problematic.

Table 3-2 summarizes the control technology options evaluated in this BART analysis, along with projected NO_x emission rates. All technologies can meet the applicable presumptive BART limit of 0.28 lb/MMBTU.

TABLE 3-2
 NO_x Control Technology Projected Emission Rates
 Jim Bridger 3

Technology	Projected Emission Rate (lb/MMBtu)
Presumptive BART Limit	0.28
LNB w/OFA	0.24
ROFA	0.22
LNB w/OFA & SNCR	0.20
LNB w/OFA & SCR	0.07

3.2.1.4 Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

Preliminary vendor proposals, such as those used to support portions of this BART analysis, may be technically feasible and provide expected or guaranteed emission rates; however, they include inherent uncertainties. These proposals are usually prepared in a limited time frame, may be based on incomplete information, may contain over-optimistic conclusions, and are non-binding. Therefore, emission rate values obtained in such preliminary proposals must be qualified, and it must be recognized that contractual guarantees are established only after more detailed analysis has been completed. The following subsections describe the control technologies and the control-effectiveness evaluated in this BART analysis.

New LNBs with OFA System. The mechanism used to lower NO_x with low NO_x burners is to stage the combustion process and provide a fuel rich condition initially; this is so oxygen needed for combustion is not diverted to combine with nitrogen and form NO_x. Fuel-rich conditions favor the conversion of fuel nitrogen to N₂ instead of NO_x. Additional air (or OFA) is then introduced downstream in a lower temperature zone to burn out the char.

Both LNBs and OFA are considered to be a capital cost, combustion technology retrofit. For LNB retrofits to units configured with tangential-firing such as Jim Bridger 3, it is generally necessary to increase the burner spacing; this prevents interaction of the flames from adjacent burners and reduces burner zone heat flux. These modifications usually require boiler waterwall tube replacement.

Information provided to CH2M HILL by PacifiCorp – based on the S&L Study and data from boiler vendors – indicates that new LNB and OFA retrofit at Jim Bridger 3 would result in an expected NO_x emission rate of 0.24 lb/MMBtu. PacifiCorp has indicated that this rate corresponds to a vendor guarantee, not a vendor prediction, and they believe that this emission rate can be sustained as an average between overhauls. This emission rate represents a significant reduction from the current NO_x emission rate, and is below the more applicable, presumptive NO_x emission rate of 0.28 lb/MMBtu.

ROFA. Mobotec markets ROFA as an improved second generation OFA system. Mobotec states that “the flue gas volume of the furnace is set in rotation by asymmetrically placed air nozzles. Rotation is reported to prevent laminar flow, so that the entire volume of the furnace can be

used more effectively for the combustion process. In addition, the swirling action reduces the maximum temperature of the flames and increases heat absorption. The combustion air is also mixed more effectively". A typical ROFA installation would have a booster fan(s) to supply the high velocity air to the ROFA boxes, and Mobotec would propose two 4,000 to 4,300 Hp fans for Jim Bridger 3.

Mobotec proposes to achieve a NO_x emission rate of 0.18 lb/MMBtu using ROFA technology. An operating margin of 0.04 lb/MMBtu was added to the expected rate due to Mobotec's limited ROFA experience with western subbituminous coals. Under the Mobotec proposal, which is primarily based on ROFA equipment, the operation of existing LNB and OFA ports would be analyzed. While a typical installation does not require modification to the existing LNB system and the existing OFA ports are not used, results of computational fluid dynamics modeling would determine the quantity and location of new ROFA ports. The Mobotec proposal includes bent tube assemblies for OFA port installation.

Mobotec would not provide installation services, because they believe that the Owner can more cost effectively contract for these services. However, they would provide one onsite construction supervisor during installation and startup.

SNCR. Selective non-catalytic reduction is generally utilized to achieve modest NO_x reductions on smaller units. With SNCR, an amine-based reagent such as ammonia – or more commonly urea – is injected into the furnace within a temperature range of 1,600°F to 2,100°F, where it reduces NO_x to nitrogen and water. NO_x reductions of up to 60 percent have been achieved, although 20 to 40 percent is more realistic for most applications.

Reagent utilization, which is a measure of the efficiency with which the reagent reduces NO_x , can range from 20 to 60 percent, depending on the amount of reduction, unit size, operating conditions, and allowable ammonia slip. With low reagent utilization, low temperatures, or inadequate mixing, ammonia slip occurs, allowing unreacted ammonia to create problems downstream. The ammonia may render fly ash unsaleable, react with sulfur to foul heat exchange surfaces, and/or create a visible stack plume. Reagent utilization can have a significant impact on economics, with higher levels of NO_x reduction generally resulting in lower reagent utilization and higher operating cost.

Reductions from higher baseline concentrations (inlet NO_x) are lower in cost per ton, but result in higher operating costs, due to greater reagent consumption. To reduce reagent costs, S&L has assumed that combustion modifications including LNBs and advanced OFA, capable of achieving a projected NO_x emission rate of 0.24 lb/MMBtu. At a further reduction of 15 percent in NO_x emission rates for SNCR would result in a projected emission rate of 0.20 lb/MMBtu.

SCR. SCR works on the same chemical principle as SNCR but SCR uses a catalyst to promote the chemical reaction. Ammonia is injected into the flue-gas stream, where it reduces NO_x to nitrogen and water. Unlike the high temperatures required for SNCR, in SCR the reaction takes place on the surface of a vanadium/titanium-based catalyst at a temperature range between 580° F to 750° F. Due to the catalyst, the SCR process is more efficient than SNCR and results in lower NO_x emissions. The most common type of SCR is the high-dust configuration, where the catalyst is located downstream from the boiler economizer and upstream of the air heater and any particulate control equipment. In this location, the SCR is exposed to the full

concentration of fly ash in the flue gas that is leaving the boiler. The high-dust configuration is assumed for Jim Bridger 3. In a full-scale SCR, the flue ducts are routed to a separate large reactor containing the catalyst. With in-duct SCR, the catalyst is located in the existing gas duct, which may be expanded in the area of the catalyst to reduce flue gas flow velocity and increase flue gas residence time. Due to the higher removal rate, a full-scale SCR was used as the basis for analysis at Jim Bridger 3.

S&L prepared the design conditions and cost estimates for SCR at Jim Bridger 3. As with SNCR, it is generally more cost effective to reduce NO_x emission levels as much as possible through combustion modifications, in order to minimize the catalyst surface area and ammonia requirements of the SCR. The S&L design basis for LNB w/OFA and SCR results in a projected NO_x emission rate of 0.07 lb/MMBtu. Additional catalyst surface was included in the SCR design to accommodate the characteristics of the coal used at Jim Bridger 3.

Level of Confidence for Vendor Post-Control Emissions Estimates. In order to determine the level of NO_x emissions needed to consistently achieve compliance with an established goal, a review of typical NO_x emissions from coal-fired generating units was completed. As a result of this review, it was noted that NO_x emissions can vary significantly around an average emissions level. Variations may result for many reasons, including coal characteristics, unit load, boiler operation including excess air, boiler slagging, burner equipment condition, coal mill fineness, and so forth.

The steps utilized for determining a level of confidence for the vendor expected value are as follows:

1. Establish expected NO_x emissions value from vendor.
2. Evaluate vendor experience and historical basis for meeting expected values.
3. Review and evaluate unit physical and operational characteristics and restrictions. The fewer variations there are in operations, coal supply, etc., the more predictable and less variant the NO_x emissions are.
4. For each technology expected value, there is a corresponding potential for actual NO_x emissions to vary from this expected value. From the vendor information presented, along with anticipated unit operational data, an adjustment to the expected value can be made.

3.2.1.5 Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

Energy Impacts. Installation of LNBs and modification to the existing OFA systems are not expected to significantly impact the boiler efficiency or forced draft fan power usage. Therefore, these technologies will not have energy impacts.

The Mobotec ROFA system would require installation and operation of two 4,000 to 4,300 Hp ROFA fans (6,410 kW total). The SNCR system would require approximately 520 kW of additional power.

SCR retrofit impacts the existing flue gas fan systems, due to the additional pressure drop associated with the catalyst, which is typically a 6- to 8-inch water gage increase. Total additional power requirements for SCR installation at Jim Bridger 3 are estimated at approximately 3,220 kW, based on the S&L Study.

Environmental Impacts. Mobotec has predicted that CO emissions, and unburned carbon in the ash, commonly referred to as LOI (loss on ignition), would be the same or lower than prior levels for the ROFA system.

SNCR and SCR installation could impact the salability and disposal of fly ash due to ammonia levels, and could potentially create a visible stack plume, which may negate other visibility improvements. Other environmental impacts involve the storage of ammonia, especially if anhydrous ammonia is used, and the transportation of the ammonia to the power plant site.

Economic Impacts. Costs and schedules for the LNBs and OFA, SNCR, and SCR were furnished to CH2M HILL by PacifiCorp, developed using S&L's internal proprietary database, and supplemented (as needed) by vendor-obtained price quotes. The relative accuracy of these cost estimates is stated by S&L to be in the range of ± 20 percent. Cost for the ROFA system was obtained from Mobotec.

A comparison of the technologies on the basis of costs, design control efficiencies, and tons of NO_x removed is summarized in Table 3-3, and the first year control costs are presented in Figure 3-4. The complete Economic Analysis is contained in Appendix A.

TABLE 3-3
NO_x Control Cost Comparison
Jim Bridger 3

Factor	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR
Total Installed Capital Costs	\$8.7 Million	\$20.5 Million	22.0 Million	\$129.6 Million
Total First Year Fixed & Variable O&M Costs	\$0.1 Million	\$2.6 Million	\$1.5 Million	\$3.3 Million
Total First Year Annualized Cost	\$0.9 Million	\$4.6 Million	\$3.6 Million	\$15.6 Million
Power Consumption (MW)	0	6.4	0.5	3.3
Annual Power Usage (1000 MW-Hr/Yr)	0	50.6	4.1	25.4
NO _x Design Control Efficiency	46.7%	51.1%	55.6%	84.4%
NO _x Removed per Year (Tons)	4,967	5,440	5,913	8,987
First Year Average Control Cost (\$/Ton of NO _x Removed)	\$181/ton	\$843/ton	\$610/ton	\$1,734/ton
Incremental Control Cost (\$/Ton of NO _x Removed)	\$181/ton	\$7,797/ton	\$2,863/ton	\$3,896/ton


Preliminary BART Selection. CH2M HILL recommends selection of low-NO_x burners with OFA as BART for Jim Bridger 3 based on its significant reduction in NO_x emissions, reasonable control cost, and no additional power requirements or environmental impacts. LNB w/OFA does not meet the EPA presumptive limit of 0.15 lb/MMBtu for subbituminous coal, but it does

meet an emission rate that falls between the presumptive limit of 0.28 lb/MMBtu for bituminous coal and the limit of 0.15 lb/MMBtu for subbituminous coal. As discussed in the section on coal quality, the recommended technology and the achieved emission rate are deemed appropriate as BART for NO_x emissions from the coals combusted at Jim Bridger 3.

3.2.1.6 Step 5: Evaluate Visibility Impacts

Please see Section 4.0, BART Modeling Analysis.

FIGURE 3-4
 First Year Control Cost for NO_x Air Pollution Control Options
 Jim Bridger 3



3.2.2 BART SO₂ Analysis

SO₂ forms in the boiler during the combustion process, and is primarily dependent on coal sulfur content. The BART analysis for SO₂ emissions on Jim Bridger 3 is described below.

3.2.2.1 Step 1: Identify All Available Retrofit Control Technologies

A broad range of information sources were reviewed, in an effort to identify potentially applicable emission control technologies for SO₂ at Jim Bridger 3. This included control technologies identified as BACT or LAER by permitting agencies across the United States.

The following potential SO₂ control technology options were considered:

- Optimize current operation of existing wet sodium FGD system
- Upgrade wet sodium FGD system to meet SO₂ emission rate of 0.10 lb/MMBtu
- New dry FGD system

3.2.2.2 Step 2: Eliminate Technically Infeasible Options

Technical feasibility will primarily be based on the regulatory presumptive limit (used as a guideline) of 95 percent reduction in SO₂ emissions, or 0.15 lb/MMBtu. Based on the coal that Jim Bridger 3 currently burns, the unit would be required to achieve an 87.5 percent SO₂ removal efficiency to meet the presumptive limit of 0.15 lb/MMBtu.

Table 3-4 summarizes the control technology options evaluated in this BART analysis, along with projected SO₂ emission rates. Only one technology option can meet the applicable presumptive BART limit of 0.15 lb/MMBtu.

TABLE 3-4
SO₂ Control Technology Emission Rates
Jim Bridger 3

Technology	Projected Emission Rate (lb/MMBtu)
Presumptive BART Limit	0.15
Upgrade Existing Wet Sodium System	0.10
Optimize Existing Wet Sodium System	0.20
New Dry FGD System	0.21

Wet Sodium FGD System. Wet sodium FGD systems operate by treating the flue gas in large scrubber vessels with a soda ash solution. The scrubber mixes the flue gas and alkaline reagent using a series of spray nozzles to distribute the reagent across the scrubber vessel. The sodium in the reagent reacts with the SO₂ in the flue gas to form sodium sulfite and sodium bisulfite, which are removed from the scrubber and disposed.

The wet sodium FGD system at Jim Bridger 3 currently achieves approximately 78 percent SO₂ removal to achieve an SO₂ outlet emission rate of 0.27 lb/MMBtu. Optimizing the existing wet FGD system would achieve an SO₂ outlet emission rate of 0.20 lb/MMBtu (83.3 percent SO₂

removal) by partially closing the bypass damper to reduce routine bypass flue gas flow used to reheat the treated flue gas from the scrubber, relocating the opacity monitor, and modifying the system to minimize scaling problems.

Upgrading the wet FGD system would achieve an SO₂ outlet emission rate of 0.10 lb/MMBtu (91.7 percent SO₂ removal) by closing the bypass damper to eliminate routine bypass flue gas flow used to reheat the treated flue gas from the scrubber, relocating the opacity monitor, adding new fans, adding a stack liner and drains for wet operation, and using a refined soda ash reagent. It is considered to be technically infeasible for the present wet FGD system to achieve 95 percent SO₂ removal (0.06 lb/MMBtu) on a continuous basis since this high level of removal must be incorporated into the original design of the scrubber.

Optimizing the existing wet sodium scrubbing FGD system is projected to achieve an outlet emission rate of 0.20 lb/MMBtu which would not meet the presumptive limit of 0.15 lb SO₂/MMBtu. Therefore, this option is eliminated as technically infeasible for this analysis. An upgraded wet sodium scrubbing FGD system is projected to achieve an outlet emission rate of 0.10 lb/MMBtu (91.7 percent SO₂ removal) which would meet the presumptive limit of 0.15 lb SO₂/MMBtu for Jim Bridger 3.

New Dry FGD System. The lime spray dryer typically injects lime slurry in the top of the absorber vessel with a rapidly rotating atomizer wheel. The rapid speed of the atomizer wheel causes the lime slurry to separate into very fine droplets that intermix with the flue gas. The SO₂ in the flue gas reacts with the calcium in the lime slurry to form dry calcium sulfate particles. At Jim Bridger 3 this dry particulate matter would be captured downstream in the existing ESP, along with the fly ash. A lime spray dryer system typically produces a dry waste product suitable for landfill disposal.

The dry FGD system with the existing ESP is projected to achieve 82.5 percent SO₂ removal at Jim Bridger 3. This would result in a controlled SO₂ emission rate of 0.21 lb/MMBtu, based on an uncontrolled SO₂ emission rate of 1.20 lb/MMBtu. Therefore, this option cannot meet the presumptive limit of 0.15 lb SO₂/MMBtu, and is eliminated from further analysis as technically infeasible.

3.2.2.3 Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

When evaluating the control effectiveness of SO₂ reduction technologies, each option can be compared against benchmarks of performance. One such benchmark is the presumptive BART emission limit because Jim Bridger 3 is required to meet this limit. As indicated previously, the presumptive limit for SO₂ on a BART-eligible coal burning unit is 95 percent removal, or 0.15 lb/MMBtu.

The projected emission rate for an upgraded wet sodium FGD system for Jim Bridger 3 would be 0.10 lb/MMBtu. This option would meet the presumptive SO₂ limit of 0.15 lb/MMBtu.

3.2.2.4 Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

Energy Impacts. Upgrading the existing wet sodium FGD system would require an additional 520 kW of power.

Environmental Impacts. There will be incremental additions to scrubber waste disposal and makeup water requirements, and a reduction of the stack gas temperature from 140°F to 120°F due to elimination of the bypassed flue gas which had provided approximately 20°F of reheat.

Economic Impacts. A summary of the costs and amount of SO₂ removed for the upgraded wet sodium FGD system is provided in Table 3-5. The complete Economic Analysis is contained in Appendix A.

TABLE 3-5
SO₂ Control Cost Comparison (Incremental to Existing FGD System)
Jim Bridger 3

Factor	Upgraded Wet FGD
Total Installed Capital Costs	\$13.0 Million
Total First Year Fixed & Variable O&M Costs	\$1.3 Million
Total First Year Annualized Cost	\$2.5 Million
Additional Power Consumption (MW)	0.5
Additional Annual Power Usage (1000 MW-Hr/Yr)	4.1
Incremental SO ₂ Design Control Efficiency	62.5% (91.7% based on Uncontrolled SO ₂)
Incremental Tons SO ₂ Removed per Year	3,950
First Year Average Control Cost (\$/Ton of SO ₂ Removed)	632
Incremental Control Cost (\$/Ton of SO ₂ Removed)	632

Preliminary BART Selection. CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 3 based on its significant reduction in SO₂ emissions (meeting presumptive limit of 0.15 lb/MMBtu), reasonable control costs, and the advantages of minimal additional power requirements and environmental impacts.

3.2.2.5 Step 5: Evaluate Visibility Impacts

Please see Section 4.0, BART Modeling Analysis.

3.2.3 BART PM₁₀ Analysis

Jim Bridger 3 is currently equipped with an electrostatic precipitator (ESP). ESPs remove particulate matter from the flue gas stream by charging fly ash particles with a very high direct current voltage, and attracting these charged particles to grounded collection plates. A layer of collected particulate matter forms on the collecting plates and is removed by periodically rapping the plates. The collected ash particles drop into hoppers below the precipitator and are removed periodically by the fly ash-handling system. Historically, the ESP at Jim Bridger 3 has controlled PM₁₀ emissions to levels below 0.057 lb/MMBtu.

The BART analysis for PM₁₀ emissions at Jim Bridger 3 is described below. For the modeling analysis in Section 4.0, PM₁₀ was used as an indicator for PM, and PM₁₀ includes PM_{2.5} as a subset.

3.2.3.1 Step 1: Identify All Available Retrofit Control Technologies

Two retrofit control technologies have been identified for additional PM control:

- Flue gas conditioning
- Polishing fabric filter (baghouse) downstream of Existing ESP

Another available control technology is replacing the existing ESP with a new fabric filter. However, because the environmental benefits that would be achieved by a replacement fabric filter are also achieved by installing a polishing fabric filter downstream of the existing ESP at lower costs, installation of a full fabric filter was not considered in the analysis.

3.2.3.2 Step 2: Eliminate Technically Infeasible Options

Flue Gas Conditioning. If the fly ash from coal has high resistivity, such as fly ash from subbituminous coal, the ash is not collected effectively in an ESP. This is because the high resistivity makes the particles less willing to accept an electrical charge. Adding flue gas conditioning (FGC), which is typically accomplished by injection of sulfur trioxide (SO₃), will lower the resistivity of the particles so that they will accept more charge and allow the ESP to collect the ash more effectively. Flue gas conditioning systems can account for large improvements in collection efficiency for small ESPs.

Polishing Fabric Filter. A polishing fabric filter could be added downstream of the existing ESP at Jim Bridger 3. One such technology is licensed by the Electric Power Research Institute, and referred to as a COHPAC (Compact Hybrid Particulate Collector). The COHPAC collects the ash that is not collected by the ESP, thus acting as a polishing device. The ESP needs to be kept in service for the COHPAC fabric filter to operate effectively.

The COHPAC fabric filter is about one-half to two-thirds the size of a full size fabric filter, because the COHPAC has a higher air-to-cloth ratio (7 to 9:1), compared to a full size pulse jet fabric filter (3.5 to 4:1).

3.2.3.3 Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

The existing ESP at Jim Bridger 3 is achieving a controlled PM emission rate of 0.057 lb/MMBtu. Utilizing flue conditioning upstream of the existing ESP is projected to reduce PM emissions to approximately 0.030 lb/MMBtu. Adding a COHPAC fabric filter downstream of the existing ESP is projected to reduce PM emissions to approximately 0.015 lb/MMBtu.

The PM₁₀ control technology emission rates are summarized in Table 3-6.

TABLE 3-6
PM₁₀ Control Technology Emission Rates
Jim Bridger 3

Control Technology	Short-Term Expected PM ₁₀ Emission Rate (Lb/MMBtu)
Flue Gas Conditioning	0.030
Polishing Fabric Filter	0.015

3.2.3.4 Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

Energy Impacts. Energy is required to overcome the additional pressure drop from the COHPAC fabric filter and associated ductwork. Therefore, a COHPAC retrofit will require an ID fan upgrade and upgrade of the auxiliary power supply system.

A COHPAC fabric filter at Jim Bridger 3 would require approximately 3.3 MW of power, equating to an annual power usage of approximately 26.3 million kW-Hr.

There is only a small power requirement of approximately 50 kW associated with flue gas conditioning.

Environmental Impacts. There are no negative environmental impacts from the addition of a COHPAC polishing fabric filter or flue gas conditioning system.

Economic Impacts. A summary of the costs and PM removed for COHPAC and flue gas conditionings are recorded in Table 3-7, and the first-year control costs for flue gas conditioning and fabric filters are shown in Figure 3-5. The complete Economic Analysis is contained in Appendix A.

TABLE 3-7
PM₁₀ Control Cost Comparison (Incremental to Existing ESP)
Jim Bridger 3

Factor	Flue Gas Conditioning	Polishing Fabric Filter
Total Installed Capital Costs	\$0	\$48.4 Million
Total First Year Fixed & Variable O&M Costs	\$0.2 Million	\$1.7 Million
Total First Year Annualized Cost	\$0.2 Million	\$ 6.3 Million
Additional Power Consumption (MW)	0.05	3.43
Additional Annual Power Usage (Million kW-Hr/Yr)	0.4	26.3
Incremental PM Design Control Efficiency	47.4%	73.7%
Incremental Tons PM Removed per Year	639	993

TABLE 3-7
 PM₁₀ Control Cost Comparison (Incremental to Existing ESP)
 Jim Bridger 3


Factor	Flue Gas Conditioning	Polishing Fabric Filter
First Year Average Control Cost (\$/Ton of PM Removed)	275	6,381
Incremental Control Cost (\$/Ton of PM Removed)	275	17,371

Preliminary BART Selection. CH2M HILL recommends selection of flue gas conditioning upstream of the existing ESP as BART for Jim Bridger 3 based on the significant reduction in PM emissions, reasonable control costs, and advantages of minimal additional power requirements and no environmental impacts.

3.2.3.5 Step 5: Evaluate Visibility Impacts

Please see Section 4.0, BART Modeling Analysis.

FIGURE 3-5
First Year Control Cost for PM Air Pollution Control Options
Jim Bridger 3



4.0 BART Modeling Analysis

4.1 Model Selection

CH2M HILL used the CALPUFF modeling system to assess the visibility impacts of emissions from Jim Bridger 3 at nearby Class I areas. The Class I areas potentially affected are located more than 50 kilometers but less than 300 kilometers from the Jim Bridger 3 facility. The Class I areas include the following wilderness areas (WA):

- Bridger WA
- Fitzpatrick WA
- Mt. Zirkel WA

The CALPUFF modeling system includes the CALMET meteorological model, a Gaussian puff dispersion model (CALPUFF) with algorithms for chemical transformation and deposition, and a post processor capable of calculating concentrations, visibility impacts, and deposition (CALPOST). The CALPUFF modeling system was applied in a full, refined mode. Version numbers of the various programs in the CALPUFF system used by CH2M HILL were as follows:

- CALMET Version 5.53a, Level 040716
- CALPUFF Version 5.711a, Level 040716
- CALPOST Version 5.51, Level 030709

4.2 CALMET Methodology

4.2.1 Dimensions of the Modeling Domain

CH2M HILL used the CALMET model to generate a three-dimensional wind field and other meteorological parameters suitable for use by the CALPUFF model. A modeling domain was established to encompass the Jim Bridger 3 facility and allow for a 50-km buffer around the Class I areas that were within 300 km of the facility. Grid resolution was 4 km. Figure 4-1 shows the extent of the modeling domain. Except when specifically instructed otherwise by the Wyoming Department of Environmental Quality – Air Quality Division (WDEQ-AQD), CH2M HILL followed the methodology spelled out in the WDEQ-AQD BART Modeling Protocol, a copy of which is included in this report as Appendix B.

CH2M HILL used the Lambert Conformal Conic map projection for the analysis due to the large extent of the domain. The latitude of the projection origin and the longitude of the central meridian were chosen at the approximate center of the domain. Standard parallels were drawn to represent 1/6 and 5/6 of the north-south extent of the domain to minimize distortion in the north-south direction.

FIGURE 4-1
Extent of Modeling Domain
Jim Bridger 3




Figure 4-1
Jim Bridger Source-Specific
Class I Areas to be Addressed



CH2MHILL

SLG 151630201.PROJECT3\1\NR\BART\UNIT3\JIM BRIDGER CLASSIWD 11\20\04\10.1.KXDEN

The default technical options listed in TRC Companies, Inc.'s (TRC) current example CALMET.inp file were used for CALMET. Vertical resolution of the wind field included ten layers, with vertical face heights as follows (in meters):

- 0, 20, 40, 100, 140, 320, 580, 1020, 1480, 2220, 3500

Other user-specified model options were set to values established by WDEQ-AQD which appear in Table 3 of Appendix B. Table 4-1 lists the key user-specified options used for this analysis.

TABLE 4-1
User-Specified CALMET Options
Jim Bridger 3

CALMET Input Parameter	Value
CALMET Input Group 2	
Map projection (PMAP)	Lambert Conformal
Grid spacing (DGRIDKM)	4
Number vertical layers (NZ)	10
Top of lowest layer (m)	20
Top of highest layer (m)	3500
CALMET Input Group 4	
Observation mode (NOOBS)	0
CALMET Input Group 5	
Prog. Wind data (IPROG)	14
(RMAX1)	30
(RMAX2)	50
Terrain influence (TERRAD)	15
(R1)	5
(R2)	25
CALMET Input Group 6	
Max mixing ht (ZIMAX)	3500

4.2.2 CALMET Input Data

CH2M HILL ran the CALMET model to produce three years of analysis: 2001, 2002, and 2003. WDEQ-AQD provided 12-km resolution Mesoscale Meteorological Model, Version 5 (MM5) meteorological data fields that covered the entire modeling domain for each study year.

These three data sets were chosen because they are current and have been evaluated for quality. The MM5 data were used as input to CALMET as the "initial guess" wind field. The initial guess wind field was adjusted by CALMET for local terrain and land use effects to generate a

Step 1 wind field, and further refined using local surface observations to create a final Step 2 wind field.

Surface data for 2001-2003 were obtained from the National Climatic Data Center. CH2M HILL processed the data from the National Weather Service's Automated Surface Observing System (ASOS) network for all stations that are in the domain. The surface data were obtained in abbreviated DATSAV3 format. A conversion routine available from the TRC website was used to convert the DATSAV3 files to CD-144 format for input into the SMERGE preprocessor and CALMET.

Land use and terrain data were obtained from the U.S. Geological Survey (USGS). Land use data were obtained in Composite Theme Grid format from the USGS, and the Level I USGS land use categories were mapped into the 14 primary CALMET land use categories. Surface properties such as albedo, Bowen ratio, roughness length, and leaf area index were computed from the land use values. Terrain data were taken from USGS 1-degree Digital Elevation Model data, which primarily derive from USGS 1:250,000 scale topographic maps. Missing land use data were filled with values that were assumed appropriate for the missing area.

Precipitation data were obtained from the National Climatic Data Center. All available data in fixed-length, TD-3240 format were obtained for the modeling domain. The list of available stations that have collected complete data varies by year, but CH2M HILL processed all available stations/data within the domain for each year. Precipitation data were prepared with the PXTRACT/PMERGE processors in preparation for use within CALMET.

Upper-air data were prepared for the CALMET model with the READ62 preprocessor for the following stations:

- Denver, Colorado
- Salt Lake City, Utah
- Riverton, Wyoming
- Rapid City, South Dakota

Figure 4-2 shows the locations of surface and upper air stations within the MM5 modeling domain.

FIGURE 4-2
Surface and Upper Air Station Locations
Jim Bridger 3




Figure 4-2
Surface and Upper Air Stations Used in the
Jim Bridger BART Analysis

PACIFICORP

CH2MHILL

4.2.3 Validation of CALMET Wind Field

CH2M HILL used the CALDESK data display and analysis system (v2.97, Enviromodeling Ltd.) to view plots of wind vectors and other meteorological parameters to evaluate the CALMET wind fields. The CALDESK displays were compared to observed weather conditions, as depicted in surface and upper-air weather maps from the National Oceanic and Atmospheric Administration Central Library U.S. Daily Weather Maps Project (http://docs.lib.noaa.gov/rescue/dwm/data_rescue_daily_weather_maps.html).

4.3 CALPUFF Modeling Approach

For the BART control technology visibility improvement modeling, CH2M HILL followed WDEQ-AQD guidance provided in the document titled *BART Air Modeling Protocol - Individual Source Visibility Assessments for BART Control Analyses* (September, 2006).

A modeling protocol titled *Modeling Protocol for BART Control Technology Improvement Modeling Analysis* (CH2M HILL, August, 2006) was submitted to WDEQ-AQD for review. In the protocol, CH2M HILL described how the general CALMET/CALPUFF approach recommended by the WDEQ-AQD would be used to model Jim Bridger 3.

CH2M HILL drove the CALPUFF model with the meteorological output from CALMET over the modeling domain described earlier. The CALPUFF model was used to predict visibility impacts for the pre-control (baseline) scenario for comparison to the predicted impacts for post-control scenarios for Jim Bridger 3.

4.3.1 Background Ozone and Ammonia

Hourly values of background ozone concentrations were used by CALPUFF for the calculation of SO₂ and NO_x transformation with the MESOPUFF II chemical transformation scheme. CH2M HILL obtained hourly ozone data from the following stations located within the modeling domain for 2001, 2002, and 2003:

- Rocky Mountain National Park, Colorado
- Craters of the Moon National Park, Idaho
- Highland, Utah
- Thunder Basin National Grasslands, Wyoming
- Yellowstone National Park, Wyoming
- Centennial, Wyoming
- Pinedale, Wyoming

For periods of missing hourly ozone data, the chemical transformation relied on a monthly default value of 44 parts per billion. Background ammonia was set to 2 parts per billion. Both of these background values were taken from the WDEQ-AQD document *BART Air Modeling Protocol - Individual Source Visibility Assessments for BART Control Analyses* (September, 2006).

4.3.2 Stack Parameters

The stack parameters used for the baseline modeling reflect those that are in place under the current permit for Jim Bridger 3. Post-control stack parameters reflect the anticipated changes associated with installation of the control technology alternatives that are being evaluated. The maximum heat input rate of 6,000 MMBtu/hr was used to calculate a maximum emission rate. Measured velocities and stack flow rates were used in the modeling to represent a worst-case situation.

4.3.3 Emission Rates

Pre-control emission rates for Jim Bridger 3 reflect peak 24-hour average emissions that may occur under the source's current permit. The emission rates reflect actual emissions under normal operating conditions, as described by the EPA in the *Regional Haze Regulations and Guidelines for Best Available Retrofit Technology Determinations; Final Rule* (40 CFR Part 51; July 6, 2005, pg 39129).

CH2M HILL used available continuous emission monitoring data to determine peak 24-hour emission rates. Data reflected operations from the most recent 3 to 5 year period unless a more recent period was more representative. Allowable short-term (24-hour or shorter period) emissions or short-term emission limits were used if continuous emission monitoring data were not available.

Emissions were modeled for the following pollutants:

- SO₂
- NO_x
- Coarse particulate (PM_{2.5}<diameter<PM₁₀)
- Fine particulate (diameter<PM_{2.5})
- Sulfates

Post-control emission rates reflect the effects of the emissions control scenario under consideration. Modeled pollutants were the same as those listed for the pre-control scenario.

4.3.4 Post Control Scenarios

Four post control modeling scenarios were developed to cover the range of effectiveness for the combination of the individual NO_x, SO₂ and PM control technologies being evaluated. The selection of each control device was made based on the engineering analyses performed in Section 3 for reasonable technologies that would meet or exceed the presumptive BART levels for each pollutant.

- **Scenario 1:** New LNB w/OFA Modifications, upgraded wet FGD system and flue gas conditioning for enhanced ESP performance. As indicated previously, this scenario represents CH2M HILL's preliminary BART recommendation.
- **Scenario 2:** New LNB w/OFA modifications, upgraded wet FGD system and new polishing fabric filter
- **Scenario 3:** New LNB w/OFA modifications and SCR, upgraded wet FGD system and flue gas conditioning for enhanced ESP performance.

- **Scenario 4:** New LNB w/OFA modifications and SCR, upgraded wet FGD system and new polishing fabric filter.

The ROFA option and LNB w/OFA & SCR option for NO_x control were not included in the modeling scenarios because their control effectiveness is between the LNB w/OFA option and the SCR option. Modeling of NO_x, SO₂ and PM controls alone was not performed because any final BART solution will include a combination of control technologies for NO_x, SO₂ and PM.

Table 4-2 presents the stack parameters and emission rates used for the Jim Bridger 3 analysis for baseline and post-control modeling. In accordance with the WDEQ BART modeling protocol, elemental carbon stack emissions and organic aerosol emissions were not modeled.

TABLE 4-2
BART Model Input Data
Jim Bridger 3

	Baseline	Post Control Scenario 1	Post Control Scenario 2	Post Control Scenario 3	Post Control Scenario 4
	Current Operations with wet FGD and ESP	LNB with OFA, Upgrade Wet FGD & FGC for Enhanced ESP Performance	LNB with OFA, Upgrade Wet FGD, New Fabric Filter	LNB with OFA and SCR, Upgrade Wet FGD & FGC for Enhanced ESP Performance	LNB with OFA and SCR, Upgrade Wet FGD, New Fabric Filter
Heat Input (MMBtu/hr)	6,000	6,000	6,000	6,000	6,000
SO ₂ Stack Emissions (lb/MMBTU)	0.3	0.10	0.10	0.10	0.10
SO ₂ Stack Emissions (lb/hr)	1,600	600	600	600	600
NO _x Stack Emissions (lb/MMBTU)	0.45	0.24	0.24	0.07	0.07
NO _x Stack Emissions (lb/hr)	2,700	1,440	1,440	420	420
PM ₁₀ Stack Emissions (lb/MMBTU)	0.057	0.030	0.015	0.030	0.015
PM ₁₀ Stack Emissions (lb/hr)	342	180	90.0	180	90
PM ₁₀ -PM _{2.5} Stack Emissions (lb/hr) ⁽¹⁾	147	77.4	51.3	77.4	51.3
PM _{2.5} -PM ₀ Stack Emissions (lb/hr) ⁽¹⁾	195	103	38.7	103	38.7
HF Stack Emissions (lb/MMBTU)	0.00055	0.00055	0.00055	0.00055	0.00055
HF Stack Emissions (lb/hr)	3.3	3.3	3.3	3.3	3.3
HCl Stack Emissions (lb/MMBTU)	0.00075	0.00075	0.00075	0.00075	0.00075
HCl Stack Emissions (lb/hr)	4.5	4.5	4.5	4.5	4.5
H ₂ SO ₄ Stack Emissions (lb/MMBTU)	0.0092	0.0092	0.0092	0.0158	0.0158
H ₂ SO ₄ Stack Emissions (lb/hr)	55.2	55.20	55.20	94.80	94.80
H ₂ SO ₄ as SO ₄ Stack Emissions (lb/hr)	54.1	54.07	54.07	92.87	92.87
(NH ₄) ₂ SO ₄ Stack Emissions (lb/MMBTU)				0.00117	0.00117

TABLE 4-2
BART Model Input Data
Jim Bridger 3

	Baseline	Post Control Scenario 1	Post Control Scenario 2	Post Control Scenario 3	Post Control Scenario 4
	Current Operations with wet FGD and ESP	LNB with OFA, Upgrade Wet FGD & FGC for Enhanced ESP Performance	LNB with OFA, Upgrade Wet FGD, New Fabric Filter	LNB with OFA and SCR, Upgrade Wet FGD & FGC for Enhanced ESP Performance	LNB with OFA and SCR, Upgrade Wet FGD, New Fabric Filter
(NH ₄) ₂ SO ₄ Stack Emissions (lb/hr)				7.02	7.02
(NH ₄) ₂ SO ₄ as SO ₄ Stack Emissions (lb/hr)				5.10	5.10
(NH ₄)HSO ₄ Stack Emissions (lb/MMBtu)				0.00204	0.00204
(NH ₄)HSO ₄ as SO ₄ Stack Emissions (lb/hr)				12.2	12.2
(NH ₄)HSO ₄ as SO ₄ Stack Emissions (lb/hr)				10.22	10.22
Total Filterable PM ₁₀ (lb/hr) (Incl. PM _{2.5})	350	188	97.8	187.8	97.8
Total Sulfate (as SO ₄) (lb/hr)	54.1	54.1	54.1	108.2	108.2
Stack Conditions					
Stack Height (feet)	500	500	500	500	500
Stack Height (m)	152	152	152	152	152
Stack Exit Diameter (feet)	24.00	24.00	24.00	24.00	24.00
Stack Exit Diameter (m)	7.32	7.32	7.32	7.32	7.32
Stack Exit Temperature (degF)	140	120	140	140	140
Stack Exit Temperature (K)	333.2	322.0	333.2	333.2	333.2
Stack Exit Flow (acfm)	2,281,182	2,208,010	2,437,627	2,437,627	2,437,627
Stack Exit Area (ft ²)	452	452	452	452	452
Stack Exit Velocity (fps)	84.04	81.24	89.81	89.81	89.81
Stack Exit Velocity (m/s)	25.62	24.76	27.37	27.37	27.37

Notes:

(1) Based on AP-42, Table 1.1-6, as percent of PM₁₀. See factors below.

	ESP	Baghouse
PM ₁₀ -PM _{2.5} Stack Emissions (lb/hr)	43	57
PM _{2.5} -PM ₀ Stack Emissions (lb/hr)	57	43

(2) Scenarios 2, 3, and 4 were not remodeled at the lower, correct velocity of 81.24 fps due to lack of time and the fact that the conclusions to select Scenario 1 would not have changed.

4.3.5 Modeling Process

The CALPUFF modeling for the control technology options for Jim Bridger 3 followed this sequence:

- Model pre-control (baseline) emissions
- Model preferred post-control scenario (if applicable)
- Determine degree of visibility improvement
- Model other control scenarios
- Determine degree of visibility improvement
- Factor visibility results into BART “5-step” evaluation

4.3.6 Receptor Grids

Discrete receptors for the CALPUFF modeling were placed at uniform receptor spacing along the boundary and in the interior of each area of concern. Class I area receptors were taken from the National Park Service (NPS) database for Class I area modeling receptors. The TRC COORDS program was used to convert all latitude/longitude coordinates to Lambert Conformal Conic coordinates, including receptors, meteorological stations, and source locations.

4.4 CALPOST

The CALPOST processor was used to determine 24-hour average visibility results with output specified in deciview (dV) units. Calculations of light extinction were made for each pollutant modeled. The sum of all extinction values were used to calculate the delta-dV (Δ dV) change relative to natural background. Default light extinction coefficients for each pollutant, as shown below, were used.

- Ammonium sulfate 3.0
- Ammonium nitrate 3.0
- PM coarse (PM₁₀) 0.6
- PM fine (PM_{2.5}) 1.0
- Organic carbon 4.0
- Elemental carbon 10.0

CALPOST visibility Method 6 was used to determine the visibility impacts. Monthly relative humidity factors [f (RH)] were used in the light extinction calculations to account for the hygroscopic characteristics of nitrate and sulfate particles. Table 5 of the Wyoming BART Air Modeling Protocol (Appendix B) lists the monthly f (RH) factors for the Class I areas. These values were used for the particular Class I area being modeled.

The natural background conditions as a reference for determining the Δ dV change represented the 20 percent best natural visibility days. The EPA BART guidance document provided dV values for the 10 percent best days for each Class I area, but did not provide individual species concentration data for the 20 percent best days. Species concentrations corresponding to the 20 percent best days were calculated for each Class I area by scaling back the annual average species concentrations given in Table 2-1 of *Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule*. A separate scaling

factor was derived for each Class I area such that, when multiplied by the Guidance table annual concentrations, the 20 percent best days dV value for that area would be calculated. This procedure was taken from *Protocol for BART-Related Visibility Improvement Modeling Analysis in North Dakota* (North Dakota Department of Health; October 26, 2005). The Wyoming BART Air Modeling Protocol did provide natural background concentrations of aerosol components to use in the BART analysis. Table 4-3 lists the annual average species concentrations from the BART protocol.

TABLE 4-3
Average Natural Levels of Aerosol Components
Jim Bridger 3

Aerosol Component	Average Natural Concentration (micrograms per cubic meter) for Mt. Zirkel Class I Wilderness Area	Average Natural Concentration (micrograms per cubic meter) for Fitzpatrick and Bridger Class I Wilderness Areas
Ammonium Sulfate	0.046	0.045
Ammonium Nitrate	0.038	0.038
Organic Carbon	0.179	0.178
Elemental Carbon	0.008	0.008
Soil	0.190	0.189
Coarse Mass	1.141	1.136

Note: Taken from Table 6 of the Wyoming BART Air Modeling Protocol

Presentation of Modeling Results

This section presents the results of the CALPUFF visibility improvement modeling analysis for Jim Bridger 3.

Degree of Visibility Change for Baseline vs. Preferred Scenario

CH2M HILL modeled Jim Bridger 3 for the baseline conditions and post-control Scenario 1. The post-control scenario included emission rates for NO_x, SO₂, and PM₁₀ that would be achieved if BART technology were installed on Unit 3.

Baseline (and post-control) 98th percentile results were greater than 0.5 ΔdV for the Bridger WA, Fitzpatrick WA, and Mt. Zirkel WA. The 98th percentile results for each Class I area are presented in Table 4-4.

TABLE 4.4
Costs and Visibility Modeling Results for Baseline Vs. Post-Control Scenarios at Class I Areas
Jim Bridger 3

Scenario	Class I Area	Highest Delta- (dV)	98th Percentile Delta- (dV)	No. of Days Above 0.5 dV	Cost per dV Reduction	Cost per Reduction in No. of Days Above 0.5 dV	Incremental Cost per dV Reduction	Incremental Cost per Reduction in No. of Days Above 0.5 dV
Baseline - Current Operation with Wet FGD and ESP								
	Bridger WA	2,794	0.805	20	-	-	-	-
	Fitzpatrick WA	2,542	0.48	7	-	-	-	-
	Mt. Zirkel WA	2,291	1.454	35	-	-	-	-
Scenario 1 - LNB w/OFA, upgraded wet FGD system, FGC for enhanced ESP performance.								
	Bridger WA	1,553	0.422	7	\$8,845,751	\$260,609	\$422,541,167	NA
	Fitzpatrick WA	1,624	0.265	3	\$15,757,779	\$465,981	\$528,176,459	NA
	Mt. Zirkel WA	1,382	0.871	21	\$5,811,188	\$241,994	\$99,033,086	NA
Scenario 2 - LNB w/OFA, upgraded wet FGD system, and new polishing fabric filter.								
	Bridger WA	1,584	0.407	7	\$24,437,287	\$748,157	\$422,541,167	NA
	Fitzpatrick WA	1,382	0.253	3	\$42,845,991	\$2,451,510	\$528,176,459	NA
	Mt. Zirkel WA	1,31	0.807	21	\$15,032,519	\$694,717	\$99,033,086	NA
Scenario 3 - LNB w/OFA and SCR, upgraded wet FGD system, FGC for enhanced ESP performance								
	Bridger WA	1,021	0.405	3	\$45,186,279	\$1,063,183	\$4,174,035,666	\$2,067,018
	Fitzpatrick WA	0.8	0.163	2	\$7,016,124	\$3,514,822	\$2,795,349	\$8,946,071
	Mt. Zirkel WA	0.896	0.537	8	\$19,710,046	\$669,412	\$30,918,783	\$642,159
Scenario 4 - LNB w/OFA and SCR, upgraded wet FGD system, new polishing fabric filter.								
	Bridger WA	0.985	0.394	3	\$59,397,151	\$1,436,013	\$576,192,500	NA
	Fitzpatrick WA	0.779	0.158	2	\$75,814,378	\$4,882,446	\$1,267,623,301	NA
	Mt. Zirkel WA	0.87	0.521	8	\$26,165,304	\$904,157	\$396,132,344	NA
Baseline - Current Operation with Wet FGD and ESP								
	Bridger WA	4,381	1.57	30	-	-	-	-
	Fitzpatrick WA	2,051	0.833	13	-	-	-	-
	Mt. Zirkel WA	3,46	1.817	47	-	-	-	-
Scenario 1 - LNB w/OFA, upgraded wet FGD system, FGC for enhanced ESP performance.								
	Bridger WA	2,625	0.918	14	\$4,505,216	\$211,745	\$147,398,081	\$6,335,118
	Fitzpatrick WA	1,159	0.418	7	\$8,163,669	\$664,664	\$528,176,459	\$6,335,118
	Mt. Zirkel WA	1,828	0.966	17	\$3,895,192	\$112,931	\$2,112,705,834	\$6,335,118
Scenario 2 - LNB w/OFA, upgraded wet FGD system, and new polishing fabric filter.								
	Bridger WA	2,49	0.875	13	\$12,234,013	\$572,120	\$147,398,081	\$6,335,118
	Fitzpatrick WA	1,086	0.406	6	\$22,777,611	\$1,389,434	\$528,176,459	\$6,335,118
	Mt. Zirkel WA	1,862	0.966	18	\$11,428,954	\$335,381	\$2,112,705,834	\$6,335,118
Scenario 3 - LNB w/OFA and SCR, upgraded wet FGD system, FGC for enhanced ESP performance								
	Bridger WA	1,416	0.586	9	\$16,823,782	\$660,672	\$29,921,403	\$2,087,018
	Fitzpatrick WA	0.895	0.249	1	\$30,846,821	\$1,506,176	\$53,172,429	\$1,668,614
	Mt. Zirkel WA	1,108	0.578	10	\$14,587,661	\$489,489	\$21,515,648	\$1,043,509
Scenario 4 - LNB w/OFA and SCR, upgraded wet FGD system, new polishing fabric filter.								
	Bridger WA	1,39	0.583	9	\$22,458,362	\$1,162,487	\$487,547,500	NA
	Fitzpatrick WA	0.895	0.248	1	\$41,586,124	\$2,094,352	\$2,112,705,834	NA
	Mt. Zirkel WA	1,088	0.57	10	\$19,576,167	\$659,790	\$792,264,688	NA

TABLE 4-4
Costs and Visibility Modeling Results for Baseline Vs. Post-Control Scenarios at Class I Areas
Jim Bridger 3

Scenario	Class I Area	Highest Delta- (dV)	98th Percentile Delta- (dV)	No. of Days Above 0.5 dV	Cost per dV Reduction	Cost per Reduction in No. of Days Above 0.5 dV	Incremental Cost per dV Reduction	Incremental Cost per Reduction in No. of Days Above 0.5 dV
Baseline - Current Operation with Wet FGD and ESP	Bridger WA	1.995	0.896	17	-	-	-	-
	Fitzpatrick WA	2.085	0.457	7	-	-	-	-
Scenario 1 - LNB w/OFA, upgraded wet FGD system, FGC for enhanced ESP performance.	Mt. Zirkel WA	2.27	1.544	44	-	-	-	-
	Bridger WA	1.147	0.492	7	\$8,385,947	\$338,792	\$154,588,232	\$6,338,118
Scenario 2 - LNB w/OFA, upgraded wet FGD system, and new polishing fabric filter.	Fitzpatrick WA	1.195	0.229	3	\$14,659,308	\$448,981	\$2,782,850	NA
	Mt. Zirkel WA	1.218	0.937	18	\$10,392,400	\$155,517	\$109,843,044	\$8,348,071
Scenario 3 - LNB w/OFA and SCR, upgraded wet FGD system, FGC for enhanced ESP performance	Bridger WA	1.155	0.45	6	\$21,807,265	\$884,185	\$154,588,232	\$6,338,118
	Fitzpatrick WA	1.178	0.232	3	\$43,228,845	\$2,431,510	\$154,588,232	NA
Scenario 4 - LNB w/OFA and SCR, upgraded wet FGD system, new polishing fabric filter.	Mt. Zirkel WA	1.235	0.896	18	\$15,009,321	\$374,078	\$154,588,232	\$6,338,118
	Bridger WA	0.991	0.319	3	\$31,324,283	\$1,291,008	\$63,725,736	\$2,782,850
Scenario 1	Fitzpatrick WA	0.738	0.156	2	\$60,046,882	\$3,614,822	\$109,843,044	\$8,348,071
	Mt. Zirkel WA	0.789	0.544	8	\$16,074,111	\$92,069	\$23,716,112	\$934,807
Scenario 2	Bridger WA	0.949	0.306	3	\$41,376,659	\$1,743,731	\$487,547,500	NA
	Fitzpatrick WA	0.719	0.152	2	\$80,040,085	\$4,882,448	\$1,584,529,376	NA
Scenario 3	Bridger WA	0.738	0.533	8	\$24,146,616	\$978,117	\$76,192,500	NA
	Fitzpatrick WA	0.738	0.533	8	\$24,146,616	\$978,117	\$76,192,500	NA
Scenario 4	Bridger WA	0.738	0.533	8	\$24,146,616	\$978,117	\$76,192,500	NA
	Fitzpatrick WA	0.738	0.533	8	\$24,146,616	\$978,117	\$76,192,500	NA
Scenario 1	Bridger WA	0.738	0.533	8	\$7,245,638	\$270,382	\$240,282,269	\$6,338,118
	Fitzpatrick WA	0.738	0.533	8	\$12,926,819	\$752,872	\$1,056,352,817	\$6,338,118
Scenario 2	Mt. Zirkel WA	0.738	0.533	8	\$6,732,827	\$163,481	\$788,775,717	\$6,338,118
	Bridger WA	0.738	0.533	8	\$18,492,855	\$734,821	\$1,422,560,942	\$6,338,118
Scenario 3	Fitzpatrick WA	0.738	0.533	8	\$36,283,482	\$2,084,151	\$85,257,274	\$6,121,819
	Mt. Zirkel WA	0.738	0.533	8	\$15,823,588	\$468,089	\$17,447,410	\$840,158
Scenario 4	Bridger WA	0.738	0.533	8	\$31,112,781	\$1,071,621	\$517,095,834	NA
	Fitzpatrick WA	0.738	0.533	8	\$49,337,278	\$2,811,840	\$1,654,952,803	NA
Scenario 4	Mt. Zirkel WA	0.738	0.533	8	\$17,457,272	\$593,320	\$588,196,511	NA
	Bridger WA	0.738	0.533	8	\$41,077,387	\$1,447,410	\$1,654,952,803	NA
Scenario 4	Fitzpatrick WA	0.738	0.533	8	\$65,814,188	\$3,933,081	\$1,654,952,803	NA
	Mt. Zirkel WA	0.738	0.533	8	\$23,286,229	\$747,355	\$588,196,511	NA

Sample Calculations: Cost per dV Reduction for Scenario 1 for 2001:
 $= \$3,387,923 / (0.896 - 0.492) = \$8,845,751$
 Sample Calculations: Cost per Reduction in No. of Days Above 0.5 dV for 2001:
 $= \$3,387,923 / (20 - 7) = \$260,608$

5.0 Preliminary Assessment and Recommendations

As a result of the completed technical and economic evaluations, and consideration of the modeling analysis for Jim Bridger 3, the preliminary recommended BART controls for NO_x, SO₂, and PM are as follows:

- New LNBs and modifications to the OFA system for NO_x control
- Upgrade wet sodium FGD for SO₂ control
- Add flue gas conditioning upstream of existing ESPs for PM control

The above recommendations were identified as Scenario 1 for the modeling analysis described in Section 4.0. Visibility improvements for all emission control scenarios were analyzed, and the results are compared below, utilizing a Least-Cost Envelope, as outlined in the draft EPA 1990 *New Source Review Workshop Manual (NSR Manual)*. The purpose of this analysis is to use an objective, EPA-approved methodology to evaluate and make the final recommendation of BART control technology.

5.1 Least-Cost Envelope Analysis

For the control scenarios modeled in Section 4, Tables 5-1 through 5-3 list the total annualized cost, cost per dV reduction, and cost per reduction in number of days above 0.5 dV for each of the three Class I areas. A comparison of the incremental results between selected scenarios is provided in Tables 5-4 through 5-6. Figures 5-1 to 5-6 show the total annualized cost versus number of days above 0.5 dV, and the total annualized cost versus 98th percentile ΔdV reduction, for the three Class I areas.

5.1.1 Analysis Methodology

Page B-41 of the New Source Review (NSR) Manual, EPA states that “Incremental cost-effectiveness comparisons should focus on annualized cost and emission reduction differences between dominant alternatives. Dominant set of control alternatives are determined by generating what is called the envelope of least-cost alternatives. This is a graphical plot of total annualized costs for a total emissions reductions for all control alternatives identified in the BACT analysis...”

An analysis of incremental cost effectiveness has been conducted. This analysis was performed in the following way. First, the control option scenarios are ranked in ascending order of annualized total costs, as shown in Tables 5-1 through 5-3. The incremental cost effectiveness data, expressed per day and per dV, represents a comparison of the different scenarios, and is summarized in Tables 5-4 through 5-6 for each of the three wilderness areas. Then the most reasonable smooth curve of least-cost control option scenarios is plotted for each analysis. Figures 5-1 through 5-6 present the two analyses (cost per dV reduction and cost per reduction in number of days above 0.5 dV) for each of the three Class I areas impacted by the operation of Jim Bridger 3.

In Figure 5-1, the four scenarios are compared as a graph of total annualized cost versus number of days above 0.5 dV. EPA states that "In calculating incremental costs, the analysis should only be conducted for control options that are dominant among all possible options". In Figure 5-1, the dominant set of control options, Scenarios 1 and 3, represent the least-cost envelope depicted by the curvilinear line connecting them. Scenarios 2 and 4 are inferior options and should not be considered in the derivation of incremental cost effectiveness. Scenarios 2 and 4 represent inferior controls, because Scenario 1 provides approximately same amount of visibility impact reduction for less cost than Scenario 2; and similarly, Scenario 3 will provides approximately the same amount of visibility impact reduction for less cost than Scenario 4. The incremental cost effectiveness is determined by the difference in total annual costs between two contiguous scenarios divided by the difference in emissions reduction.

TABLE 5-1
Control Scenario Results for the Bridger Class 1 Wilderness Area
Jim Bridger 3

Scenario	Controls	98th Percentile dV Reduction	Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet FGD, ESP	0.0	0.0	\$0.0	\$0.0	\$0.0
1	LNB w/OFA, upgraded wet FGD system, FGC for enhanced ESP performance.	0.5	13.0	\$3.4	\$7.3	\$0.3
2	LNB w/OFA, upgraded wet FGD system, and new polishing fabric filter.	0.6	13.67	\$9.7	\$19.5	\$0.7
3	LNB w/OFA and SCR, upgraded wet FGD system, FGC for enhanced ESP performance	0.7	17.3	\$18.1	\$31.1	\$1.07
4	LNB w/OFA and SCR, upgraded wet FGD system, new polishing fabric filter.	0.7	17.3	\$24.4	\$41.1	\$1.45

TABLE 5-2
Control Scenario Results for the Fitzpatrick Class 1 Wilderness Area
Jim Bridger 3

Scenario	Controls	98th Percentile dV Reduction	Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet FGD, ESP	0.0	0.0	\$0.0	\$0.0	\$0.0
1	LNB w/OFA, upgraded wet FGD system, FGC for enhanced ESP performance.	0.3	4.7	\$3.4	\$12.9	\$0.8
2	LNB w/OFA, upgraded wet FGD system, and new polishing fabric filter.	0.3	5.0	\$9.7	\$36.3	\$2.1
3	LNB w/OFA and SCR, upgraded wet FGD system, FGC for enhanced ESP performance	0.4	7.3	\$18.0	\$49.3	\$2.9
4	LNB w/OFA and SCR, upgraded wet FGD system, new polishing fabric filter.	0.4	7.3	\$24.4	\$65.8	\$3.9

TABLE 5-3
Control Scenario Results for the Mt. Zirkel Class 1 Wilderness Area
Jim Bridger 3

Scenario	Controls	98th Percentile dV Reduction	Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet FGD, ESP	0.0	0.0	\$0.0	\$0.0	\$0.0
1	LNB w/OFA, upgraded wet FGD system, FGC for enhanced ESP performance.	0.7	23.0	\$3.4	\$6.7	\$0.2
2	LNB w/OFA, upgraded wet FGD system, and new polishing fabric filter.	0.7	23.0	\$9.7	\$13.8	\$0.5
3	LNB w/OFA and SCR, upgraded wet FGD system, FGC for enhanced ESP performance	1.1	33.3	\$18.1	\$17.5	\$0.6
4	LNB w/OFA and SCR, upgraded wet FGD system, new polishing fabric filter.	1.1	33.3	\$24.4	\$23.3	\$0.8

TABLE 5-4
Bridger Class I Wilderness Area Incremental Analysis Data
Jim Bridger 3

Options Compared	Incremental Reduction in Days Above 0.5 dV (Days)	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	13.0	0.5	\$0.3	\$6.6
Scenario 1 and Scenario 3	4.3	0.2	\$3.4	\$86.1
Scenario 3 and Scenario 4	0.0	0.01	N/A	\$514.

TABLE 5-5
Fitzpatrick Class I Wilderness Area Incremental Analysis Data
Jim Bridger 3

Options Compared	Incremental Reduction in Days Above 0.5 dV (Days)	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	4.7	0.3	\$0.7	\$12.0
Scenario 1 and Scenario 3	2.7	0.1	\$5.5	\$128.
Scenario 3 and Scenario 4	0.0	0.004	N/A	\$1,585.

TABLE 5-6
Mt. Zirkel Class I Wilderness Area Incremental Analysis Data
Jim Bridger 3

Options Compared	Incremental Reduction in Days Above 0.5 dV (Days)	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	23.0	0.7	\$0.2	\$5.0
Scenario 1 and Scenario 3	10.3	0.4	\$1.4	\$39.4
Scenario 3 and Scenario 4	0.0	0.01	N/A	\$543.

FIGURE 5-1
 Least Cost Envelope Bridger Class I WA Days Reduction
 Jim Bridger 3




FIGURE 5-2
 Least Cost Envelope Bridger Class I WA 98th Percentile Reduction
 Jim Bridger 3




FIGURE 5-3
 Least Cost Envelope Fitzpatrick Class I WA Days Reduction
 Jim Bridger 3




FIGURE 5-4
 Least Cost Envelope Fitzpatrick Class I WA 98th Percentile Reduction
 Jim Bridger 3




FIGURE 5-5
Least Cost Envelope Mt. Zirkel Class I WA Days Reduction
Jim Bridger 3





FIGURE 5-6
Least Cost Envelope Mt. Zirkel Class I WA 98th Percentile Reduction
Jim Bridger 3



5.1.2 Analysis Results

Results of the Least Cost Analysis, shown in Tables 5-1 through 5-6 and Figures 5-1 through 5-4 on the preceding pages, confirm the selection of Scenario 1, based on incremental cost and visibility improvements. Scenario 2 is eliminated because it is to the left of the curve formed by the “dominant” control alternative scenarios, which indicates a scenario with lower improvement and/or higher costs. Scenario 3 is not selected due to very high incremental costs for both a cost per day of improvement and a cost per dV reduction. While Scenario 4 provides some potential visibility advantage over Scenario 1, the projected improvement is less than half a dV, and the projected costs are excessive.

Analysis of the results for the Jim Bridger Class 1 WA in Tables 5-1 and 5-4 and Figures 5-1 and 5-2 illustrates the conclusions stated above. The greatest reduction in 98th percentile dV and number of days above 0.5 dV is between the Baseline and Scenario 1. The incremental cost effectiveness for Scenario 1 compared to the Baseline for the Bridger WA, for example, is reasonable at \$260,000/day and \$6.60 Million/dV. However, the incremental cost effectiveness for Scenario 3 compared to Scenario 1, again for the Bridger WA, is excessive at \$3.39 Million/day and \$88.05 Million/dV. The same conclusions are reached for each of the three wilderness areas studied. Therefore, Scenario 1 represents BART for Jim Bridger 3.

5.2 Recommendations

5.2.1 NO_x Emission Control

The BART presumptive NO_x limit assigned by EPA for tangentially-fired boilers burning subbituminous coal is 0.15 lb/MMBtu. However, as documented in Section 3.2.1.1, the characteristics of the Jim Bridger coals are more closely aligned with bituminous coals, and have been assigned a presumptive BART NO_x limit of 0.28 lb/MMBtu.

CH2M HILL recommends low-NO_x burners with over-fire air (LNB w/OFA) as BART for Jim Bridger 3, based on the projected significant reduction in NO_x emissions, reasonable control costs, and the advantages of no additional power requirements or non-air quality environmental impacts. NO_x reductions are expected to be similar to those realized at Jim Bridger 2. CH2M HILL recommends that the unit be permitted at a rate of 0.26 lb/MMBtu.

5.2.2 SO₂ Emission Control

CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 3, based on the significant reduction in SO₂ emissions, reasonable control costs, and the advantages of minimal additional power requirements and minimal non-air quality environmental impacts. This upgrade approach will meet the BART presumptive SO₂ limit of 0.15 lb/MMBtu.

5.2.3 PM₁₀ Emission Control

CH2M HILL recommends finalizing the permitting of the flue gas conditioning system to enhance the performance of the existing electrostatic precipitator (ESP) as BART for Jim Bridger 3, based on the significant reduction in PM₁₀ emissions, reasonable control costs, and

the advantages of minimal additional power requirements and no non-air quality environmental impacts.

5.3 Just-Noticeable Differences in Atmospheric Haze

Conclusions reached in the reference document "Just-Noticeable Differences in Atmospheric Haze" by Dr. Ronald Henry of the University of Southern California (Appendix C), state that only dV differences of approximately 1.5 to 2.0 dV, or more are perceptible by the human eye. Deciview changes of less than 1.5 cannot be distinguished by the average person. Therefore, the modeling analysis results indicate that only minimal, if any, observable visibility improvements at the Class I areas studied would be expected under any of the scenarios. Thus the results indicate that even though many millions of dollars will be spent, only minimal if any visibility improvements may result.

Finally, it should be noted that none of the data were corrected for natural obscuration. Water in various forms (fog, clouds, snow, or rain) or other naturally caused aerosols may obscure the atmosphere and reduce visibility. During the period of 2001 through 2003, there were several mega-wildfires that lasted for many days, with a significant impact on background visibility in these Class 1 areas. If natural obscuration lessens the achievable reduction in visibility impacts modeled for BART controls at the Jim Bridger 3 facility, the overall effect would be to increase the costs per dV reduction that are presented in this report

6.0 References

BART Air Modeling Protocol - Individual Source Visibility Assessments for BART Control Analyses. September, 2006.

Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule.

Multi-Pollutant Control Report. October, 2002, updated October 2006

Protocol for BART-Related Visibility Improvement Modeling Analysis in North Dakota. North Dakota Department of Health. October 26, 2005.

Regional Haze Regulations and Guidelines for Best Available Retrofit Technology Determinations; Final Rule (40 CFR Part 51; July 6, 2005, pg 39129)

S&L Study Multi-Pollutant Control Report. October, 2002, updated October 2006

United States Environmental Protection Agency, 1990. *New Source Review Workshop Manual - Prevention of Significant Deterioration and Nonattainment Area Permitting.* October 1990.

Appendices

APPENDIX A
Economic Analysis

PacifiCorp BART Analysis Report Tables

Jim Bridger Unit 3

TABLE 3-1
NO_x Control Technology Emission Rate Ranking
Jim Bridger Unit 3

Technology	Projected Emission Rate (lb/MMBtu)
LNB w/OFA	0.24
ROFA	0.22
LNB w/OFA & SNCR	0.20
LNB w/OFA & SCR	0.07

TABLE 3-2
NO_x Control Cost Comparison
Jim Bridger Unit 3

Factor	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR
Total Installed Capital Costs	\$ 8.7 Million	\$ 20.5 Million	\$ 22.0 Million	\$ 129.6 Million
Total First Year Fixed & Variable O&M Costs	\$ 0.1 Million	\$ 2.6 Million	\$ 1.5 Million	\$ 3.3 Million
Total First Year Annualized Cost	\$ 0.9 Million	\$ 4.6 Million	\$ 3.6 Million	\$ 15.6 Million
Power Consumption (MW)	-	6.41	0.52	3.22
Annual Power Usage (Million kW-Hr/Yr)	-	50.6	4.1	25.4
NO _x Design Control Efficiency	46.7%	51.1%	55.6%	84.4%
Tons NO _x Removed per Year	4,967	5,440	5,913	8,987
First Year Average Control Cost (\$/Ton of NO _x Removed)	181	843	610	1,734
Incremental Control Cost (\$/Ton of NO _x Removed)	181	7,797	2,863	3,896

TABLE 3-3
SO₂ Control Technology Emission Rate Ranking
Jim Bridger Unit 3

Control Technology	Short-Term Expected SO ₂ Emission Rate (lb/MMBtu)
N/A	N/A
N/A	N/A
Upgraded Wet FGD	0.10

PacifiCorp BART Analysis Report Tables

Jim Bridger Unit 3

TABLE 3-4:
SO₂ Control Cost Comparison
Jim Bridger Unit 3


Factor	N/A	N/A	Upgraded Wet FGD
Total Installed Capital Costs			13.0 Million
Total First Year Fixed & Variable O&M Costs			1.3 Million
Total First Year Annualized Cost			2.5 Million
Power Consumption (MW)			0.52
Annual Power Usage (Million kW-Hr/Yr)			4.1
SO ₂ Design Control Efficiency			62.5%
Tons SO ₂ Removed per Year			3,950
First Year Average Control Cost (\$/Ton of SO ₂ Removed)			631
Incremental Control Cost (\$/Ton of SO ₂ Removed)			631


TABLE 3-5:
PM₁₀ Control Technology Emission Ranking
Jim Bridger Unit 3


Control Technology	Short-Term Expected PM ₁₀ Emission Rate (Lb/MMBtu)
Flue Gas Conditioning	0.030
Fabric Filter	0.015

TABLE 3-6:
PM₁₀ Control Cost
Jim Bridger Unit 3

Factor	Flue Gas Conditioning	Fabric Filter
Total Installed Capital Costs	\$ - Million	\$ 48.4 Million
Total First Year Fixed & Variable Operations & Maintenance Costs	\$ 0.2 Million	\$ 1.7 Million
Total First Year Annualized Cost	\$ 0.2 Million	\$ 6.3 Million
Power Consumption (MW)	0.05	3.33
Annual Power Usage (Million kW-Hr/Yr)	0.4	26.3
PM Design Control Efficiency	47.37%	73.68%
Tons PM Removed per Year	639	993
First Year Average Control Cost (\$/Ton of PM Removed)	275	6,381
Incremental Control Cost (\$/Ton of SO ₂ Removed)	275	17,371







PacifiCorp BART Analysis Scenarios

Select Unit:		5	Jim Bridger Unit 3
Index No.	Name of Unit		
1	Dave Johnston Unit 3		
2	Dave Johnston Unit 4		
3	Jim Bridger Unit 1		
4	Jim Bridger Unit 2		
5	Jim Bridger Unit 3		
6	Jim Bridger Unit 4		
7	Naughton Unit 1		
8	Naughton Unit 2		
9	Naughton Unit 3		
10	Wyodak Unit 1		

Dave Johnston			
DJ Unit 3		DJ Unit 4	
Scenario	First Year Cost	Scenario	First Year Cost
Baseline - Current Operation with ESP	N/A	Baseline - Current Operation with Venturi Scrubber	N/A
Scenario 1 - LNB with OFA, Dry FGD, Existing ESP	N/A	Scenario 1 - LNB with OFA, Dry FGD, Fabric Filter	N/A
Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	N/A
Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	N/A	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	N/A
Scenario 4 - LNB with OFA and SCR, Wet FGD, Existing ESP, New Stack	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A

Naughton					
NTN Unit 1		NTN Unit 2		NTN Unit 3	
Scenario	First Year Cost	Scenario	First Year Cost	Scenario	First Year Cost
Baseline - Current Operation with ESP	N/A	Baseline - Current Operation with ESP	N/A	Baseline - Current Operation with FGD and ESP	N/A
Scenario 1 - LNB with OFA, Dry FGD, ESP	N/A	Scenario 1 - LNB with OFA, Dry FGD, ESP	N/A	Scenario 1 - LNB with OFA, Wet FGD, ESP	N/A
Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	N/A
Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	N/A	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	N/A	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	N/A
Scenario 4 - LNB with OFA and SCR, Wet FGD, ESP, New Stack	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, ESP, New Stack	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, ESP, New Stack	N/A

Jim Bridger									
JB Unit 1		JB Unit 2		JB Unit 3		JB Unit 4		WYD Unit 1	
Scenario	First Year Cost	Scenario	First Year Cost	Scenario	First Year Cost	Scenario	First Year Cost	Scenario	First Year Cost
Baseline - Current Operation with Wet FGD and ESP	N/A	Baseline - Current Operation with Wet FGD and ESP	N/A	Baseline - Current Operation with Wet FGD and ESP	N/A	Baseline - Current Operation with Wet FGD and ESP	N/A	Baseline - Current Operation with Dry FGD, Fabric Filter	N/A
Scenario 1 - LNB with OFA, Wet FGD, ESP	N/A	Scenario 1 - LNB with OFA, Wet FGD, ESP	N/A	Scenario 1 - LNB with OFA, Wet FGD, ESP	\$ 3,357,923	Scenario 1 - LNB with OFA, Wet FGD, ESP	\$ 3,357,923	Scenario 1 - LNB with OFA, Dry FGD, Fabric Filter	N/A
Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	\$ 9,726,040	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	\$ 9,726,040	Scenario 2 - LNB with OFA and SCR, Dry FGD, Fabric Filter	N/A
Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	N/A	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	N/A	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	\$ 18,074,111	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	\$ 18,074,111	Scenario 3 - LNB with OFA and SCR, Wet FGD, Fabric Filter, New Stack	N/A
Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	\$ 24,412,229	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	\$ 24,412,229	Scenario 4 - N/A	N/A

ECONOMIC ANALYSIS SUMMARY

Jim Bridger Unit 3

Boiler Design:

Tangential-Fired PC

Parameter	NOx Control				SO2 Control			PM Control	
	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	Upgraded Wet FGD	Flue Gas Conditioning	Flue Gas Conditioning	Fabric Filter	
CASE									
NOx Emission Control System	1	2	3	4	5	6	7	8	
SO2 Emission Control System	LNCFS-1 & Windbox Mods.	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	Upgraded Wet FGD	LNCFS-1 & Windbox Mods.	LNCFS-1 & Windbox Mods.	
PM Emission Control System	Wet FGD ESP	Wet FGD ESP	Wet FGD ESP	Wet FGD ESP	Wet FGD ESP	Wet FGD ESP	Wet FGD ESP	Wet FGD ESP	
TOTAL INSTALLED CAPITAL COST (\$)	0	8,700,001	20,528,122	21,973,632	129,576,495	12,999,900	0	48,386,333	
FIRST YEAR O&M COST (\$)									
Operating Labor (\$)	0	0	0	0	0	0	0	0	
Maintenance Material (\$)	0	28,000	42,000	122,000	190,000	25,650	0	51,089	
Maintenance Labor (\$)	0	42,000	63,000	183,000	285,000	17,033	10,000	76,849	
Administrative Labor (\$)	0	0	0	0	0	0	0	0	
TOTAL FIXED O&M COST	0	70,000	105,000	305,000	475,000	42,683	10,000	127,938	
Makeup Water Cost	0	0	0	0	0	28,927	0	0	
Reagent Cost	0	0	0	1,805,811	912,848	533,206	145,854	0	
SCR Catalyst / FF Bag Cost	0	0	0	0	600,000	0	0	294,008	
Waste Disposal Cost	0	0	0	0	0	442,958	18,710	0	
Electric Power Cost	0	0	2,528,012	2,049,884	1,269,718	204,984	19,710	1,313,474	
TOTAL VARIABLE O&M COST	0	0	2,528,012	1,210,795	2,782,566	1,211,075	165,564	1,607,482	
TOTAL FIRST YEAR O&M COST	0	70,000	2,633,012	1,815,795	3,267,566	1,253,658	175,564	1,735,231	
FIRST YEAR DEBT SERVICE (\$)	0	827,612	1,952,796	2,050,304	12,326,235	1,236,652	0	4,602,887	
TOTAL FIRST YEAR COST (\$)	0	8,977,612	23,480,918	24,023,936	141,802,731	14,236,564	0	53,615,118	
Power Consumption (MW)	0.0	0.0	5.4	0.5	3.2	0.6	0.1	3.3	
Annual Power Usage (Million kWh-Hr/Yr)	0.0	0.0	50.6	4.1	25.4	4.1	0.4	26.3	
CONTROL COST (\$/Ton Removed)									
NOx Removal Rate (%)	0.0%	46.7%	51.1%	65.6%	84.4%	0.0%	0.0%	0.0%	
NOx Removed (Tons/Yr)	0	4,967	5,440	5,913	8,887	0	0	0	
First Year Average Control Cost (\$/Ton NOx Rem.)	0	181	843	610	1,734	0	0	0	
Incremental Control Cost (\$/Ton NOx Removed)	0	181	7,797	2,863	3,896	0	0	0	
			3-2	4-2	5-4				
SO2 Removal Rate (%)	77.8%	0.0%	0.0%	0.0%	0.0%	62.5%	0.0%	0.0%	
SO2 Removed (Tons/Yr)	0	0	0	0	0	3,950	0	0	
First Year Average Control Cost (\$/Ton SO2 Rem.)	0	0	0	0	0	631	0	0	
Incremental Control Cost (\$/Ton SO2 Removed)	Base	0	0	0	0	631	0	0	
						8-1			
PM Removal Rate (%)	99.33%	0.00%	0.00%	0.00%	0.00%	0.00%	47.37%	73.68%	
PM Removed (Tons/Yr)	0	0	0	0	0	0	639	993	
First Year Average Control Cost (\$/Ton PM Rem.)	0	0	0	0	0	0	275	6,381	
Incremental Control Cost (\$/Ton PM Removed)	Base	0	0	0	0	0	275	17,371	
							9-1	10-9	
PRESENT WORTH COST (\$)	0	9,565,250	52,697,853	40,493,391	169,375,961	28,316,912	2,145,016	69,587,730	

INPUT CALCULATIONS

Boiler Design: Tangent-Fired PC
Jim Bridger Unit 3

Parameter	NOx Control				SO2 Control			PM Control			Comments
	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter		
Case	1	2	3	4	5	8	9	10			
NOx Emission Control System	LNCFS-1 & Windbox Mod.	LNB w/OFA Wet FGD	ROFA Wet FGD	LNB w/OFA & SNCR Wet FGD	LNB w/OFA & SNCR Wet FGD	LNB w/OFA & SNCR Wet FGD	LNCFS-1 & Windbox Mod. Wet FGD	LNCFS-1 & Windbox Mod. Wet FGD			
SO2 Emission Control System	Wet FGD	Wet FGD	Wet FGD	Wet FGD	Wet FGD	Wet FGD	Wet FGD	Wet FGD			
PM Emission Control System	ESP	ESP	ESP	ESP	ESP	ESP	Conditioning	Fabric Filter			
Unit Design and Coal Characteristics											
Type of Unit	PC	PC	PC	PC	PC	PC	PC	PC			
Net Power Output (kW)	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000			
Net Plant Heat Rate (Btu/kW-Hr)	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320			
Boiler Fuel	Bridger Mine	Bridger Mine	Bridger Mine	Bridger Mine	Bridger Mine	Bridger Mine	Bridger Mine	Bridger Mine			
Coal Heating Value (Btu/Lb)	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660			
Coal Sulfur Content (wt.%)	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%			
Coal Ash Content (wt.%)	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%			
Boiler Heat Input, each (MMBtu/Hr)	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000			
Coal Flow Rate (Lb/Hr)	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077			
(Ton/Yr)	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284			
(MMBtu/Yr)	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846			
Emissions											
Uncontrolled SO2 (Lb/Hr)	7,210	1,602	1,602	1,602	1,602	1,602	1,602	1,602			
(Lb/MMBtu)	1.20	0.27	0.27	0.27	0.27	0.27	0.27	0.27			
(Lb Moles/Hr)	112.84	25.00	25.00	25.00	25.00	25.00	25.00	25.00			
(Tons/Yr)	28,421	6,315	6,315	6,315	6,315	6,315	6,315	6,315			
SO2 Removal Rate (%)	77.8%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%			
(Lb/Hr)	5,608	0	0	0	0	0	0	0			
(Ton/Yr)	22,106	0	0	0	0	0	0	0			
SO2 Emission Rate (Lb/Hr)	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602			
(Lb/MMBtu)	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27			
(Ton/Yr)	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315			
Uncontrolled NOx (Lb/Hr)	2,700	2,700	2,700	2,700	2,700	2,700	2,700	2,700			
(Lb/MMBtu)	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45			
(Lb Moles/Hr)	89.96	89.96	89.96	89.96	89.96	89.96	89.96	89.96			
(Tons/Yr)	10,643	10,643	10,643	10,643	10,643	10,643	10,643	10,643			
NOx Removal Rate (%)	0.0%	46.7%	51.1%	55.6%	84.4%	84.4%	0.0%	0.0%			
(Lb/Hr)	0	1,260	1,380	1,500	2,280	2,280	0	0			
(Lb Moles/Hr)	0.00	41.98	46.98	50.98	75.97	75.97	0.00	0.00			
(Ton/Yr)	0	4,967	5,440	5,913	8,987	8,987	0	0			
NOx Emission Rate (Lb/Hr)	2,700	1,440	1,320	1,200	420	2,700	2,700	2,700			
(Lb/MMBtu)	0.45	0.27	0.22	0.20	0.07	0.45	0.45	0.45			
(Ton/Yr)	10,643	5,876	5,203	4,730	1,656	10,643	10,643	10,643			
Uncontrolled Fly Ash (Lb/Hr)	54,177	342	342	342	342	342	342	342			
(Lb/MMBtu)	8.520	0.057	0.057	0.057	0.057	0.057	0.057	0.057			
(Lb Moles/Hr)	4,705.3	11.4	11.4	11.4	11.4	11.4	11.4	11.4			
(Tons/Yr)	201,739	1,348	1,348	1,348	1,348	1,348	1,348	1,348			
Fly Ash Removal Rate (%)	99.33%	0.00%	0.00%	0.00%	0.00%	0.00%	47.37%	73.68%			
(Lb/Hr)	200,391	0	0	0	0	0	162	252			
(Ton/Yr)	200,391	0	0	0	0	0	639	953			
Fly Ash Emission Rate (Lb/Hr)	342	342	342	342	342	342	342	342			
(Lb/MMBtu)	0.057	0.057	0.057	0.057	0.057	0.057	0.057	0.057			
(Ton/Yr)	1,348	1,348	1,348	1,348	1,348	1,348	1,348	1,348			

Parameter	Current Operation	NOx Control				SO2 Control		PM Control		Comments
		LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter		
Case	1	2	3	4	5	6	7	8	9	10
General Plant Data										
Annual Operation (Hours/Year)	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884
Annual On-Site Power Plant Capacity Factor	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90
Economic Factors										
Interest Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%
Discount Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%
Plant Economic Life (Years)	20	20	20	20	20	20	20	20	20	20
Installed Capital Costs										
NOx Emission Control System (\$2006)	0	8,700,001	20,528,122	21,973,632	129,575,495	0	0	0	0	0
SO2 Emission Control System (\$2006)	0	0	0	0	0	12,999,900	0	0	0	0
PM Emission Control System (\$2006)	0	0	0	0	0	0	0	0	0	48,386,333
Total Emission Control Systems (\$2006)	0	8,700,001	20,528,122	21,973,632	129,575,495	12,999,900	0	0	0	48,386,333
NOx Emission Control System (\$/KW)	0	16	35	41	244	0	0	0	0	0
SO2 Emission Control System (\$/KW)	0	0	0	0	0	25	0	0	0	0
PM Emission Control System (\$/KW)	0	0	0	0	0	0	0	0	0	91
Total Emission Control Systems (\$/KW)	0	16	35	41	244	25	0	0	0	91
Total Fixed Operating & Maintenance Costs										
Operating Labor (\$)	0	0	0	0	0	0	0	0	0	0
Maintenance Material (\$)	0	28,000	42,000	122,000	190,000	25,550	0	0	0	51,099
Maintenance Labor (\$)	0	42,000	63,000	183,000	285,000	17,033	10,000	0	10,000	76,649
Administrative Labor (\$)	0	0	0	0	0	0	0	0	0	0
Total Fixed O&M Cost (\$)	0	70,000	105,000	305,000	475,000	42,583	10,000	0	10,000	127,749
Annual Fixed O&M Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%
Water Costs										
Makeup Water Usage (Gpm)	0	0	0	0	0	52	0	0	0	0
Unit Price (\$/1000 Gallons)	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22
First Year Water Cost (\$)	0	0	0	0	0	29,927	0	0	0	0
Annual Water Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%
Reagent Costs										
Unit Cost (\$/Ton)	None	None	None	Urea	Anhydrous NH3	Soda Ash	Elemental Sulfur	None	None	None
(\$/Lb)	0.00	0.00	0.00	370	400	80.00	370	0.00	0.00	0.00
Molar Stoichiometry	0.00	0.00	0.00	0.185	0.200	0.040	0.186	0.000	0.000	0.000
Reagent Purity (Wt. %)	100%	100%	100%	0.45	1.00	1.02	1.00	0.00	0.00	0.00
Reagent Usage (Lb/Hr)	0	0	0	690	579	1,691	100%	100%	100%	90%
First Year Reagent Cost (\$)	0	0	0	1,005,811	912,848	533,206	145,864	0	0	0
Annual Reagent Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%
SCR Catalyst / FF Bag Replacement Cost										
Annual SCR Catalyst (m3) / No. FF Bags	0	0	0	0	200	0	0	0	0	2,827
SCR Catalyst (\$/m3) / Bag Cost (\$/ea.)	3,000	3,000	3,000	3,000	3,000	104	3,000	104	3,000	104
First Year SCR Catalyst / Bag Replac. Cost (\$)	0	0	0	0	600,000	0	0	0	0	294,008
Annual SCR Catalyst / Bag Cost Esc. Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%
FGD Waste Disposal Cost										
FGD Solid Waste Disposal Rate, Dry (Lb/Hr)	0	0	0	0	0	4,618	0	0	0	0
FGD Waste Disposal Unit Cost (\$/Dry Ton)	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33
First Year FGD Waste Disposal Cost (\$)	0	0	0	0	0	442,568	0	0	0	0
Annual Waste Disposal Cost Esc. Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%
Auxiliary Power Cost										
Auxiliary Power Requirement (% of Plant Output)	0.00%	0.00%	1.21%	0.10%	0.61%	0.10%	0.07%	0.07%	0.07%	0.53%
(MW)	0.00	0.00	6.41	0.52	3.22	0.52	0.06	0.06	0.06	3.33
Unit Cost (\$2006/MW-Hr)	50.00	50.00	50.00	50.00	50.00	50.00	50.00	50.00	50.00	50.00
First Year Auxiliary Power Cost (\$)	0	0	2,528,012	204,984	1,269,718	204,984	204,984	204,984	204,984	1,313,474
Annual Power Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%

Input Tables

Table 1 - Cases

Index No.	Name of Unit Case ->	Existing			NOx Control			SO2 Control			PM Control		
		1	2	3	4	5	6	7	8	9	10		
1	Dave Johnston Unit 3	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Dry FGD w/ESP	Dry FGD w/Fabric Filter	Wet FGD w/ESP	N/A	Fabric Filter		
2	Dave Johnston Unit 4	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	N/A	Dry FGD w/Fabric Filter	Wet FGD w/Fabric Filter	N/A	Fabric Filter		
3	Jim Bridger Unit 1	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	N/A	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter		
4	Jim Bridger Unit 2	Current Operation	Esst. LNB w/OFA	ROFA	SNCR	SNCR	N/A	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter		
5	Jim Bridger Unit 3	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	N/A	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter		
6	Jim Bridger Unit 4	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	N/A	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter		
7	Naughton Unit 1	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Dry FGD w/ESP	Dry FGD w/Fabric Filter	Wet FGD w/ESP	Flue Gas Conditioning	Fabric Filter		
8	Naughton Unit 2	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Dry FGD w/ESP	Dry FGD w/Fabric Filter	Wet FGD w/ESP	Flue Gas Conditioning	Fabric Filter		
9	Naughton Unit 3	Current Operation	Esst. LNB w/OFA	ROFA	SNCR	SNCR	N/A	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter		
10	Wyodak Unit 1	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Upgraded Dry FGD	N/A	Wet FGD	Conditioning	Fabric Filter		

Table 2 - Unit Design and Coal Characteristics

Index No.	Name of Unit	Current Emission Control Systems			Unit Design			Coal Quality			
		NOx	SO2	PM	Boiler Design	Net Power Output (KW)	Net Plant Heat Rate (Btu/KW-Hr)	Coal	Heating Value, HHV (Btu/Lb)	Sulfur Content (WT%)	Ash Content (WT%)
1	Dave Johnston Unit 3	None	None	ESP	3-Coil Burner, Opposed Wall-Fired PC	250,000	11,200	Dry Fork PRB	7,784	0.47%	5.01%
2	Dave Johnston Unit 4	Windbox Mod. LNCFS-1 & Windbox Mod.	Lime Added to Venturi Scrubber	Venturi Scrubber	Tangential-Fired PC	360,000	11,390	Dry Fork PRB Underground	7,784	0.47%	5.01%
3	Jim Bridger Unit 1	Windbox Mod.	Wet FGD	ESP	Tangential-Fired PC	530,000	11,220	Bridger Mine Underground	9,660	0.58%	10.30%
4	Jim Bridger Unit 2	LNB - TFS 2000 LNCFS-1 & Windbox Mod.	Wet FGD	ESP	Tangential-Fired PC	530,000	11,320	Bridger Mine Underground	9,660	0.58%	10.30%
5	Jim Bridger Unit 3	LNCFS-1 & Windbox Mod.	Wet FGD	ESP	Tangential-Fired PC	530,000	11,320	Bridger Mine Underground	9,660	0.58%	10.30%
6	Jim Bridger Unit 4	Windbox Mod.	Wet FGD	ESP	Tangential-Fired PC	530,000	11,320	Bridger Mine Underground	9,660	0.58%	10.30%
7	Naughton Unit 1	None	None	ESP	Tangential-Fired PC	173,000	10,694	Kemmerer Mine	9,970	0.60%	4.64%
8	Naughton Unit 2	None	None	ESP	Tangential-Fired PC	226,000	10,574	Kemmerer Mine	9,970	0.60%	4.64%
9	Naughton Unit 3	LNCFS II LNB	Wet FGD	ESP	Tangential-Fired PC	356,000	10,336	Kemmerer Mine	9,970	0.60%	4.64%
10	Wyodak Unit 1	LNB	Dry FGD	ESP	Opposed Wall-Fired PC	335,000	12,087	Cheyle Point Mine	7,977	0.65%	7.46%

Table 3 - Emissions

Index No.	Name of Unit	Current Emission Rates (Lb/MMBtu)		NOx Control Emission Rates (Lb/MMBtu)		SO2 Control Emission Rates (Lb/MMBtu)		PM Emission Rates (Lb/MMBtu)				
		Controlled	Controlled NOx	Case 2	Case 3	Case 4	Case 5	Case 6	Case 7	Case 8	Case 9	Case 10
1	Dave Johnston Unit 3	1.20	0.70	0.27	0.21	0.20	0.07	0.21	0.15	0.10	N/A	0.015
2	Dave Johnston Unit 4	0.33	0.48	0.15	0.19	0.12	0.07	N/A	0.15	0.10	N/A	0.015
3	Jim Bridger Unit 1	0.27	0.45	0.24	0.22	0.20	0.07	N/A	N/A	0.10	0.030	0.015
4	Jim Bridger Unit 2	0.27	0.24	0.24	0.22	0.20	0.07	N/A	N/A	0.10	0.030	0.015
5	Jim Bridger Unit 3	0.27	0.45	0.24	0.22	0.20	0.07	N/A	N/A	0.10	0.030	0.015
6	Jim Bridger Unit 4	0.17	0.45	0.24	0.22	0.20	0.07	N/A	N/A	0.10	0.030	0.015
7	Naughton Unit 1	1.20	0.58	0.24	0.28	0.18	0.07	0.18	0.15	0.10	0.040	0.015
8	Naughton Unit 2	1.20	0.54	0.24	0.28	0.18	0.07	0.18	0.15	0.10	0.040	0.015
9	Naughton Unit 3	0.50	0.45	0.35	0.30	0.25	0.07	N/A	N/A	0.10	0.040	0.015
10	Wyodak Unit 1	0.50	0.60	0.23	0.22	0.18	0.07	0.25	N/A	0.10	0.025	0.015

Table 4 - Case 1 O&M Costs (Current Operation)

Index No.	Name of Unit	Annual Fixed O&M Costs					Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Aux. Power Usage (MWh)	
1	Dave Johnston Unit 3	\$ -	\$ -	\$ -	\$ -	-	None	-	-	-
2	Dave Johnston Unit 4	\$ -	\$ -	\$ -	\$ -	-	None	-	-	-
3	Jim Bridger Unit 1	\$ -	\$ -	\$ -	\$ -	-	None	-	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	-	None	-	-	-
5	Jim Bridger Unit 3	\$ -	\$ -	\$ -	\$ -	-	None	-	-	-
6	Jim Bridger Unit 4	\$ -	\$ -	\$ -	\$ -	-	None	-	-	-
7	Naughton Unit 1	\$ -	\$ -	\$ -	\$ -	-	None	-	-	-
8	Naughton Unit 2	\$ -	\$ -	\$ -	\$ -	-	None	-	-	-
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	-	None	-	-	-
10	Wyodak Unit 1	\$ -	\$ -	\$ -	\$ -	-	None	-	-	-

Table 5 - Case 2 O&M Costs (LNB w/OFA)

Index No.	Name of Unit	Annual Fixed O&M Costs					Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Aux. Power Usage (MWh)	
1	Dave Johnston Unit 3	\$ -	\$ 40,000	\$ 60,000	\$ -	-	None	-	-	-
2	Dave Johnston Unit 4	\$ -	\$ 35,000	\$ 54,000	\$ -	-	None	-	-	-
3	Jim Bridger Unit 1	\$ -	\$ 28,000	\$ 42,000	\$ -	-	None	-	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	-	None	-	-	-
5	Jim Bridger Unit 3	\$ -	\$ 28,000	\$ 42,000	\$ -	-	None	-	-	-
6	Jim Bridger Unit 4	\$ -	\$ 28,000	\$ 42,000	\$ -	-	None	-	-	-
7	Naughton Unit 1	\$ -	\$ 32,000	\$ 48,000	\$ -	-	None	-	-	-
8	Naughton Unit 2	\$ -	\$ 32,000	\$ 48,000	\$ -	-	None	-	-	-
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	-	None	-	-	-
10	Wyodak Unit 1	\$ -	\$ 24,000	\$ 36,000	\$ -	-	None	-	-	-

Table 6 - Case 3 O&M Costs (Mobotec ROFA)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent Stoich.	Reagent Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ 60,000	\$ 90,000	\$ -	-	None	-	2.76
2	Dave Johnston Unit 4	\$ -	\$ 54,000	\$ 81,000	\$ -	-	None	-	4.33
3	Jim Bridger Unit 1	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41
4	Jim Bridger Unit 2	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41
5	Jim Bridger Unit 3	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41
6	Jim Bridger Unit 4	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41
7	Naughton Unit 1	\$ -	\$ 48,000	\$ 72,000	\$ -	-	None	-	1.42
8	Naughton Unit 2	\$ -	\$ 48,000	\$ 72,000	\$ -	-	None	-	2.81
9	Naughton Unit 3	\$ -	\$ 48,000	\$ 72,000	\$ -	-	None	-	4.47
10	Wyodak Unit 1	\$ -	\$ 36,000	\$ 54,000	\$ -	-	None	-	5.22

Table 7 - Case 4 O&M Costs (LNB w/OFA & SNCR)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent Stoich.	Reagent Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ 98,000	\$ 147,000	\$ -	-	Urea	0.41	0.23
2	Dave Johnston Unit 4	\$ -	\$ 105,000	\$ 157,500	\$ -	-	Urea	0.45	0.33
3	Jim Bridger Unit 1	\$ -	\$ 123,000	\$ 184,500	\$ -	-	Urea	0.45	0.53
4	Jim Bridger Unit 2	\$ -	\$ 95,000	\$ 142,500	\$ -	-	Urea	0.45	0.53
5	Jim Bridger Unit 3	\$ -	\$ 122,000	\$ 183,000	\$ -	-	Urea	0.45	0.52
6	Jim Bridger Unit 4	\$ -	\$ 123,000	\$ 184,500	\$ -	-	Urea	0.45	0.53
7	Naughton Unit 1	\$ -	\$ 83,000	\$ 124,500	\$ -	-	Urea	0.45	0.16
8	Naughton Unit 2	\$ -	\$ 93,000	\$ 139,500	\$ -	-	Urea	0.51	0.22
9	Naughton Unit 3	\$ -	\$ 75,000	\$ 112,500	\$ -	-	Urea	0.45	0.33
10	Wyodak Unit 1	\$ -	\$ 93,000	\$ 139,500	\$ -	-	Urea	0.45	0.34

Table 8 - Case 5 O&M Costs (LNB w/OFA & SCR)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent Stoich.	Reagent Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ 155,000	\$ 232,500	\$ -	-	Anhydrous NH3	1.00	1.57
2	Dave Johnston Unit 4	\$ -	\$ 166,000	\$ 249,000	\$ -	-	Anhydrous NH3	1.00	123
3	Jim Bridger Unit 1	\$ -	\$ 180,000	\$ 285,000	\$ -	-	Anhydrous NH3	1.00	198
4	Jim Bridger Unit 2	\$ -	\$ 162,000	\$ 243,000	\$ -	-	Anhydrous NH3	1.00	3.28
5	Jim Bridger Unit 3	\$ -	\$ 190,000	\$ 285,000	\$ -	-	Anhydrous NH3	1.00	198
6	Jim Bridger Unit 4	\$ -	\$ 190,000	\$ 285,000	\$ -	-	Anhydrous NH3	1.00	3.22
7	Naughton Unit 1	\$ -	\$ 132,000	\$ 198,000	\$ -	-	Anhydrous NH3	1.00	214
8	Naughton Unit 2	\$ -	\$ 160,000	\$ 240,000	\$ -	-	Anhydrous NH3	1.00	67
9	Naughton Unit 3	\$ -	\$ 156,000	\$ 234,000	\$ -	-	Anhydrous NH3	1.00	101
10	Wyodak Unit 1	\$ -	\$ 181,000	\$ 271,500	\$ -	-	Anhydrous NH3	1.00	167

Table 9 - Case 6 O&M Costs (Dry FGD)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Annual FF Bag Replace.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 506,128	\$ 714,175	\$ 476,928	\$ -	173	Lime	1.15	-	2.48
2	Dave Johnston Unit 4	-	-	-	-	-	Lime	-	-	-
3	Jim Bridger Unit 1	-	-	-	-	-	Lime	-	-	-
4	Jim Bridger Unit 2	-	-	-	-	-	Lime	-	-	-
5	Jim Bridger Unit 3	-	-	-	-	-	Lime	-	-	-
6	Jim Bridger Unit 4	-	-	-	-	-	Lime	-	-	-
7	Naughton Unit 1	\$ 606,128	\$ 587,643	\$ 391,762	\$ -	120	Lime	1.40	-	1.64
8	Naughton Unit 2	\$ 506,128	\$ 860,174	\$ 573,044	\$ -	165	Lime	1.40	-	2.25
9	Naughton Unit 3	-	-	-	-	-	Lime	-	-	-
10	Wyodak Unit 1	-	\$ 21,900	\$ 14,600	\$ -	25	Lime	1.10	-	0.11

Table 10 - Case 7 O&M Costs (Dry FGD w/Fabric Filter)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Annual FF Bag Replace.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 506,128	\$ 714,175	\$ 476,928	\$ -	173	Lime	1.15	1,457	3.88
2	Dave Johnston Unit 4	\$ 506,128	\$ 1,102,288	\$ 734,858	\$ -	248	Lime	1.10	1,798	4.54
3	Jim Bridger Unit 1	-	-	-	-	-	Lime	-	-	-
4	Jim Bridger Unit 2	-	-	-	-	-	Lime	-	-	-
5	Jim Bridger Unit 3	-	-	-	-	-	Lime	-	-	-
6	Jim Bridger Unit 4	-	-	-	-	-	Lime	-	-	-
7	Naughton Unit 1	\$ 606,128	\$ 632,660	\$ 459,286	\$ -	120	Lime	1.15	865	2.66
8	Naughton Unit 2	\$ 506,128	\$ 905,190	\$ 640,568	\$ -	165	Lime	1.15	1,193	3.63
9	Naughton Unit 3	-	-	-	-	-	Lime	-	-	-
10	Wyodak Unit 1	-	-	-	-	-	Lime	-	-	-

Table 11 - Case 8 O&M Costs (Wet FGD)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Annual FF Bag Replace.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 809,804	\$ 1,182,587	\$ 788,391	\$ -	230	Lime	1.02	-	3.45
2	Dave Johnston Unit 4	\$ 809,804	\$ 1,430,784	\$ 953,856	\$ -	330	Lime	1.02	1,798	6.29
3	Jim Bridger Unit 1	-	\$ 25,550	\$ 17,033	\$ -	53	Soda Ash	1.02	-	0.53
4	Jim Bridger Unit 2	-	\$ 25,550	\$ 17,033	\$ -	53	Soda Ash	1.02	-	0.53
5	Jim Bridger Unit 3	-	\$ 25,550	\$ 17,033	\$ -	52	Soda Ash	1.02	-	0.52
6	Jim Bridger Unit 4	-	\$ 25,550	\$ 17,033	\$ -	27	Soda Ash	1.02	-	0.52
7	Naughton Unit 1	\$ 809,804	\$ 963,589	\$ 642,393	\$ -	160	Lime	1.05	-	2.40
8	Naughton Unit 2	\$ 809,804	\$ 1,226,386	\$ 817,591	\$ -	220	Lime	1.05	-	3.30
9	Naughton Unit 3	-	\$ 21,900	\$ 14,600	\$ -	86	Soda Ash	1.02	-	0.33
10	Wyodak Unit 1	\$ 303,677	\$ 328,496	\$ 218,998	\$ -	82	Lime	1.02	-	1.75

Table 12 - Case 9 O&M Costs (Flue Gas Conditioning)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements					
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (gpm)	Reagent	Reagent Usage (Lb/hr)	Annual FF Bag Replace.	Aux. Power Usage (MW)	
1	Dave Johnston Unit 3	\$ -	\$ -	\$ -	\$ -	-	None	-	-	-	-
2	Dave Johnston Unit 4	\$ -	\$ -	\$ -	\$ -	-	None	-	-	-	-
3	Jim Bridger Unit 1	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	100	-	-	0.05
4	Jim Bridger Unit 2	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	100	-	-	0.05
5	Jim Bridger Unit 3	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	100	-	-	0.05
6	Jim Bridger Unit 4	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	33	-	-	0.05
7	Naughton Unit 1	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	43	-	-	0.05
8	Naughton Unit 2	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	67	-	-	0.05
9	Naughton Unit 3	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	83	-	-	0.05
10	Wyodak Unit 1	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	83	-	-	0.05

Table 13 - Case 10 O&M Costs (Fabric Filter)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements					
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (gpm)	Reagent	Reagent Molar Stoich.	Annual FF Bag Replace.	Aux. Power Usage (MW)	
1	Dave Johnston Unit 3	\$ -	\$ 45,016	\$ 67,524	\$ -	-	None	-	1,457	1.38	
2	Dave Johnston Unit 4	\$ -	\$ 68,133	\$ 102,199	\$ -	-	None	-	1,798	2.35	
3	Jim Bridger Unit 1	\$ -	\$ 51,099	\$ 76,649	\$ -	-	None	-	2,885	3.39	
4	Jim Bridger Unit 2	\$ -	\$ 51,099	\$ 76,649	\$ -	-	None	-	2,885	3.37	
5	Jim Bridger Unit 3	\$ -	\$ 51,099	\$ 76,649	\$ -	-	None	-	2,827	3.33	
6	Jim Bridger Unit 4	\$ -	\$ 51,099	\$ 76,649	\$ -	-	None	-	2,885	3.39	
7	Naughton Unit 1	\$ -	\$ 45,016	\$ 67,524	\$ -	-	None	-	865	1.01	
8	Naughton Unit 2	\$ -	\$ 45,016	\$ 67,524	\$ -	-	None	-	1,493	1.58	
9	Naughton Unit 3	\$ -	\$ 45,066	\$ 72,999	\$ -	-	None	-	1,798	2.06	
10	Wyodak Unit 1	\$ -	\$ 45,066	\$ 72,999	\$ -	-	None	-	1,798	2.06	

Table 14 - Major Materials Design and Supply Costs

Index No.	Name of Unit Case ->	SO2 Control										PM Control		
		2	3	4	5	6	7	8	9	10	11	12	13	14
1	Dave Johnston Unit 3	\$ 3,221,912	\$ 3,556,617	\$ 5,773,000	\$ 49,355,000	\$ 83,871,000	\$ 142,077,000	\$ 198,855,569	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 18,359,000
2	Dave Johnston Unit 4	\$ 2,673,501	\$ 4,343,192	\$ 7,171,085	\$ 65,200,000	\$ -	\$ 137,267,000	\$ 176,174,384	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 30,853,500
3	Jim Bridger Unit 1	\$ 2,981,982	\$ 6,056,955	\$ 9,528,000	\$ 80,923,000	\$ -	\$ -	\$ 6,010,093	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 29,814,000
4	Jim Bridger Unit 2	\$ -	\$ 6,056,955	\$ 9,528,000	\$ 80,923,000	\$ -	\$ -	\$ 6,010,093	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 29,814,000
5	Jim Bridger Unit 3	\$ 2,981,982	\$ 6,056,955	\$ 9,528,000	\$ 80,923,000	\$ -	\$ -	\$ 6,010,093	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 29,814,000
6	Jim Bridger Unit 4	\$ 2,981,982	\$ 6,056,955	\$ 9,528,000	\$ 80,923,000	\$ -	\$ -	\$ 6,010,093	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 29,814,000
7	Naughton Unit 1	\$ 2,502,123	\$ 2,675,792	\$ 7,257,000	\$ 37,292,000	\$ 26,619,000	\$ 42,301,000	\$ 44,000,000	\$ 800,000	\$ 800,000	\$ 15,482,000	\$ -	\$ -	\$ 15,482,000
8	Naughton Unit 2	\$ 2,570,674	\$ 3,123,533	\$ 8,784,000	\$ 47,934,000	\$ 39,262,000	\$ 57,621,000	\$ 56,000,000	\$ 800,000	\$ 800,000	\$ 18,359,000	\$ -	\$ -	\$ 18,359,000
9	Naughton Unit 3	\$ -	\$ 4,351,377	\$ 11,203,578	\$ 67,373,000	\$ 996,100	\$ -	\$ 2,563,000	\$ 800,000	\$ 800,000	\$ 20,106,000	\$ -	\$ -	\$ 20,106,000
10	Wyodak Unit 1	\$ 3,187,636	\$ 4,500,245	\$ 7,234,860	\$ 72,479,000	\$ 996,100	\$ -	\$ 178,174,384	\$ 1,247,081	\$ -	\$ -	\$ -	\$ -	\$ 20,106,000

CAPITAL COST

Jim Bridger Unit 3

Parameter	NOx Control			SO2 Control			PM Control		
	LNB WFOFA	ROFA	LNB WFOFA & SNCR	LNB WFOFA & SCR	N/A	7	8	9	10
NOx Emission Control System	LNB WFOFA W/F FGD ESP	ROFA W/F FGD ESP	LNB WFOFA & SNCR W/F FGD ESP	LNB WFOFA & SCR W/F FGD ESP	N/A	LNFPS-1 & Wetbox Mod. ESP	Upgraded Wet FGD	LNFPS-1 & Wetbox Mod. W/F FGD	Fabric Filter W/F FGD
CAPITAL COST COMPONENT									
LNB WFOFA or ROFA	LNB WFOFA	ROFA	LNB WFOFA	LNB WFOFA	N/A	LNFPS-1 & Wetbox Mod.	Upgraded Wet FGD	LNFPS-1 & Wetbox Mod.	Fabric Filter
Major Materials Design and Supply	Vendor	Vendor	Vendor	Vendor	Vendor	Vendor	Vendor	Vendor	Vendor
Contingency	85.3%	85.3%	85.3%	85.3%	85.3%	85.3%	85.3%	85.3%	85.3%
Labor Premium	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
EPIC Premium	13.2%	13.2%	13.2%	13.2%	13.2%	13.2%	13.2%	13.2%	13.2%
Boiler Relocament (Allowance)	16.2%	16.2%	16.2%	16.2%	16.2%	16.2%	16.2%	16.2%	16.2%
Swes Tax	18.2%	18.2%	18.2%	18.2%	18.2%	18.2%	18.2%	18.2%	18.2%
Escalator	12.2%	12.2%	12.2%	12.2%	12.2%	12.2%	12.2%	12.2%	12.2%
Contingency on Adders	12.8%	12.8%	12.8%	12.8%	12.8%	12.8%	12.8%	12.8%	12.8%
Surcharge and AFUDC	12.8%	12.8%	12.8%	12.8%	12.8%	12.8%	12.8%	12.8%	12.8%
Total Capital Cost for LNB WFOFA or ROFA	\$1,700,001	\$20,629,122	\$7,700,001	\$7,700,001	\$7,700,001	\$7,700,001	\$7,700,001	\$7,700,001	\$7,700,001
SNCR or SCR									
Major Materials Design and Supply	Vendor	Vendor	Vendor	Vendor	Vendor	Vendor	Vendor	Vendor	Vendor
Contingency	20.0%	20.0%	20.0%	20.0%	20.0%	20.0%	20.0%	20.0%	20.0%
Labor Premium	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
EPIC Premium	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
Boiler Relocament (Allowance)	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
Swes Tax	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
Escalator	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
Contingency on Adders	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
Surcharge and AFUDC	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
Total Capital Cost for SNCR or SCR	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Dry or Wet FGD, FGD or Fabric Filter									
Major Materials Design and Supply	Vendor	Vendor	Vendor	Vendor	Vendor	Vendor	Vendor	Vendor	Vendor
Contingency	20.0%	20.0%	20.0%	20.0%	20.0%	20.0%	20.0%	20.0%	20.0%
Labor Premium	5.6%	5.6%	5.6%	5.6%	5.6%	5.6%	5.6%	5.6%	5.6%
EPIC Premium	8.4%	8.4%	8.4%	8.4%	8.4%	8.4%	8.4%	8.4%	8.4%
Boiler Relocament (Allowance)	2.8%	2.8%	2.8%	2.8%	2.8%	2.8%	2.8%	2.8%	2.8%
Swes Tax	10.1%	10.1%	10.1%	10.1%	10.1%	10.1%	10.1%	10.1%	10.1%
Escalator	2.8%	2.8%	2.8%	2.8%	2.8%	2.8%	2.8%	2.8%	2.8%
Contingency on Adders	11.4%	11.4%	11.4%	11.4%	11.4%	11.4%	11.4%	11.4%	11.4%
Surcharge and AFUDC	11.4%	11.4%	11.4%	11.4%	11.4%	11.4%	11.4%	11.4%	11.4%
Total Capital Cost for Dry/Wet FGD, FGD or FF	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Total Capital Cost	\$1,700,001	\$20,629,122	\$7,700,001	\$7,700,001	\$7,700,001	\$7,700,001	\$7,700,001	\$7,700,001	\$7,700,001

11/10/07 4:31 PM

15/21

App_A_Prop_303 BART Elements Analyt_01-11-07.dwg / 038

Jim Bridger Unit 3												
LNB w/OFA												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)	
0	2013											
1	2014	70,000							827,612	827,612	181	
2	2015	71,400							827,612	899,012	181	
3	2016	72,828							827,612	900,440	181	
4	2017	74,285							827,612	901,887	182	
5	2018	75,770							827,612	903,382	182	
6	2019	77,288							827,612	904,896	182	
7	2020	78,831							827,612	906,443	183	
8	2021	80,408							827,612	908,020	183	
9	2022	82,016							827,612	909,628	183	
10	2023	83,656							827,612	911,269	183	
11	2024	85,330							827,612	912,942	184	
12	2025	87,038							827,612	914,648	184	
13	2026	88,777							827,612	916,389	185	
14	2027	90,552							827,612	918,165	185	
15	2028	92,364							827,612	919,976	185	
16	2029	94,211							827,612	921,823	186	
17	2030	96,095							827,612	923,707	186	
18	2031	98,017							827,612	925,628	186	
19	2032	99,977							827,612	927,589	187	
20	2033	101,977							827,612	929,589	187	
Present Worth (% of PW)		855,250	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	8,700,001	9,555,250	100.0%	

Jim Bridger Unit 3												
ROFA												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)	
0	2013											
1	2014	105,000					2,528,012	2,528,012	1,952,796	4,480,808	843	
2	2015	107,100					2,578,573	2,578,573	1,952,796	4,538,469	853	
3	2016	109,242					2,630,144	2,630,144	1,952,796	4,592,182	863	
4	2017	111,427					2,682,747	2,682,747	1,952,796	4,746,970	873	
5	2018	113,655					2,736,402	2,736,402	1,952,796	4,802,853	883	
6	2019	115,928					2,791,130	2,791,130	1,952,796	4,859,854	893	
7	2020	118,247					2,846,953	2,846,953	1,952,796	4,917,995	904	
8	2021	120,612					2,903,892	2,903,892	1,952,796	4,977,299	915	
9	2022	123,024					2,961,970	2,961,970	1,952,796	5,037,769	926	
10	2023	125,485					3,021,209	3,021,209	1,952,796	5,099,489	937	
11	2024	127,994					3,081,633	3,081,633	1,952,796	5,162,423	949	
12	2025	130,554					3,143,266	3,143,266	1,952,796	5,226,616	961	
13	2026	133,165					3,206,131	3,206,131	1,952,796	5,292,092	973	
14	2027	135,829					3,270,254	3,270,254	1,952,796	5,358,878	985	
15	2028	138,545					3,335,659	3,335,659	1,952,796	5,427,000	998	
16	2029	141,316					3,402,372	3,402,372	1,952,796	5,496,484	1,010	
17	2030	144,142					3,470,419	3,470,419	1,952,796	5,567,358	1,023	
18	2031	147,025					3,539,828	3,539,828	1,952,796	5,639,649	1,037	
19	2032	149,966					3,610,624	3,610,624	1,952,796	5,713,386	1,050	
20	2033	152,965					3,682,837	3,682,837	1,952,796	5,789,598	1,064	
Present Worth (% of PW)		1,282,875	0.0%	0.0%	0.0%	0.0%	30,886,866	30,886,866	270,528,123	52,697,883	100.0%	

LNB w/OFA & SNCR												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)	
0	2013											
1	2014	305,000	-	1,005,811	-	-	204,884	1,210,795	2,090,304	3,605,099	610	
2	2015	311,100	-	1,025,927	-	-	209,084	1,235,011	2,090,304	3,636,415	615	
3	2016	317,322	-	1,046,146	-	-	213,265	1,259,711	2,090,304	3,667,337	620	
4	2017	323,668	-	1,067,375	-	-	217,531	1,284,905	2,090,304	3,698,677	625	
5	2018	330,142	-	1,088,722	-	-	221,881	1,310,603	2,090,304	3,731,049	631	
6	2019	336,745	-	1,110,496	-	-	226,319	1,336,815	2,090,304	3,763,684	637	
7	2020	343,480	-	1,132,706	-	-	230,845	1,363,552	2,090,304	3,797,335	642	
8	2021	350,349	-	1,155,381	-	-	235,462	1,390,823	2,090,304	3,831,476	648	
9	2022	357,356	-	1,178,468	-	-	240,171	1,418,639	2,090,304	3,866,299	654	
10	2023	364,503	-	1,202,037	-	-	244,975	1,447,012	2,090,304	3,901,819	660	
11	2024	371,793	-	1,226,078	-	-	249,874	1,475,952	2,090,304	3,938,048	666	
12	2025	379,229	-	1,250,599	-	-	254,872	1,505,471	2,090,304	3,975,004	672	
13	2026	386,814	-	1,275,611	-	-	259,968	1,535,581	2,090,304	4,012,698	679	
14	2027	394,550	-	1,301,124	-	-	265,169	1,565,292	2,090,304	4,051,146	685	
15	2028	402,441	-	1,327,146	-	-	270,472	1,595,618	2,090,304	4,090,363	692	
16	2029	410,480	-	1,353,689	-	-	275,881	1,625,570	2,090,304	4,130,364	699	
17	2030	418,700	-	1,380,763	-	-	281,399	1,655,162	2,090,304	4,171,165	705	
18	2031	427,074	-	1,408,378	-	-	287,027	1,685,405	2,090,304	4,212,783	713	
19	2032	435,615	-	1,436,546	-	-	292,768	1,728,313	2,090,304	4,255,232	720	
20	2033	444,327	-	1,465,276	-	-	298,623	1,763,898	2,090,304	4,298,531	727	
Present Worth (% of PW)		3,726,445	0.0%	12,288,849	0.0%	-	2,504,464	14,793,314	21,973,632	40,493,391	342	
		9.2%		30.3%			6.2%	36.5%	54.3%	100.0%		


LNB w/OFA & SCR												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)	
0	2013											
1	2014	475,000	-	912,648	600,000	-	1,269,718	2,762,566	12,326,235	15,565,801	1,734	
2	2015	484,500	-	931,105	612,000	-	1,286,113	2,836,218	12,326,235	15,546,952	1,741	
3	2016	494,180	-	949,727	624,240	-	1,321,015	2,894,962	12,326,235	15,715,407	1,749	
4	2017	504,074	-	968,722	636,725	-	1,347,435	2,952,862	12,326,235	15,783,190	1,756	
5	2018	514,155	-	988,098	649,459	-	1,374,384	3,011,939	12,326,235	15,852,329	1,764	
6	2019	524,438	-	1,007,858	662,448	-	1,401,871	3,072,178	12,326,235	15,922,851	1,772	
7	2020	534,927	-	1,028,015	675,697	-	1,429,909	3,133,622	12,326,235	15,994,783	1,780	
8	2021	545,626	-	1,048,575	689,211	-	1,458,507	3,195,294	12,326,235	16,068,154	1,788	
9	2022	556,538	-	1,069,547	702,986	-	1,487,677	3,260,220	12,326,235	16,142,993	1,796	
10	2023	567,669	-	1,090,938	717,056	-	1,517,451	3,325,424	12,326,235	16,219,328	1,805	
11	2024	579,022	-	1,112,757	731,397	-	1,547,779	3,391,933	12,326,235	16,297,190	1,813	
12	2025	590,603	-	1,135,012	746,025	-	1,578,735	3,459,771	12,326,235	16,376,608	1,822	
13	2026	602,415	-	1,157,712	760,945	-	1,610,310	3,528,867	12,326,235	16,457,616	1,831	
14	2027	614,463	-	1,180,865	776,164	-	1,642,516	3,599,546	12,326,235	16,540,244	1,840	
15	2028	626,752	-	1,204,484	791,687	-	1,675,366	3,671,537	12,326,235	16,624,524	1,850	
16	2029	639,287	-	1,228,573	807,521	-	1,708,874	3,744,968	12,326,235	16,710,490	1,859	
17	2030	652,073	-	1,253,145	823,671	-	1,743,051	3,819,887	12,326,235	16,798,175	1,869	
18	2031	665,115	-	1,278,208	840,145	-	1,777,912	3,896,264	12,326,235	16,887,614	1,879	
19	2032	678,417	-	1,303,772	856,948	-	1,813,470	3,974,190	12,326,235	16,978,842	1,889	
20	2033	691,985	-	1,329,847	874,087	-	1,849,740	4,053,674	12,326,235	17,071,894	1,900	
Present Worth (% of PW)		5,503,490	0.0%	11,153,043	7,330,712	-	15,613,231	33,656,966	129,576,495	169,375,961	942	
		3.4%		6.6%	4.3%		9.2%	20.1%	76.5%	100.0%		

Jim Bridger Unit 3												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton SO2 Removed)	
0	2013											
1	2014	42,563	29,927	533,206	-	442,959	204,984	1,211,075	1,236,652	2,490,310	631	
2	2015	43,435	30,526	543,870	-	451,818	209,094	1,235,297	1,236,652	2,515,384	637	
3	2016	44,303	31,136	554,747	-	460,854	213,265	1,260,003	1,236,652	2,540,958	643	
4	2017	45,189	31,759	565,842	-	470,071	217,531	1,285,203	1,236,652	2,567,044	650	
5	2018	46,093	32,384	577,159	-	479,472	221,881	1,310,907	1,236,652	2,593,652	657	
6	2019	47,015	33,042	588,702	-	489,062	226,319	1,337,125	1,236,652	2,620,792	664	
7	2020	48,914	33,703	600,476	-	498,843	230,845	1,363,868	1,236,652	2,648,475	671	
8	2021	48,914	34,377	612,498	-	508,820	235,462	1,391,145	1,236,652	2,676,711	678	
9	2022	49,890	35,065	624,735	-	518,995	240,171	1,418,968	1,236,652	2,705,513	685	
10	2023	50,890	35,766	637,230	-	529,376	244,975	1,447,347	1,236,652	2,734,890	692	
11	2024	51,908	36,481	649,974	-	539,964	249,874	1,476,234	1,236,652	2,764,855	700	
12	2025	52,946	37,211	662,974	-	550,763	254,872	1,506,220	1,236,652	2,795,419	708	
13	2026	54,002	37,955	676,234	-	561,776	259,969	1,536,586	1,236,652	2,826,584	716	
14	2027	55,085	38,714	689,768	-	573,014	265,169	1,566,865	1,236,652	2,858,393	724	
15	2028	56,187	39,488	703,554	-	584,474	270,472	1,597,988	1,236,652	2,890,928	732	
16	2029	57,311	40,278	717,625	-	596,164	275,891	1,629,948	1,236,652	2,923,911	740	
17	2030	58,457	41,084	731,977	-	608,087	281,369	1,662,547	1,236,652	2,957,666	749	
18	2031	59,626	41,905	746,617	-	620,249	287,027	1,695,798	1,236,652	2,992,076	758	
19	2032	60,819	42,744	761,548	-	632,654	292,768	1,729,714	1,236,652	3,027,165	766	
20	2033	62,035	43,588	776,780	-	645,307	298,623	1,764,308	1,236,652	3,062,955	776	
Present Worth		520,271	365,648	6,514,628	0.0%	5,472,000	2,504,464	14,796,741	12,989,900	29,316,912	359	
(% of PW)		1.8%	1.3%	23.0%		18.1%	8.8%	52.3%	45.9%	100.0%		


Flue Gas Conditioning												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton PM Removed)	
0	2013											
1	2014	10,000	-	145,854	-	-	19,710	165,564	-	175,564	275	
2	2015	10,200	-	148,771	-	-	20,104	168,875	-	179,075	280	
3	2016	10,404	-	151,747	-	-	20,506	172,253	-	182,657	286	
4	2017	10,612	-	154,781	-	-	20,916	175,698	-	186,310	292	
5	2018	10,824	-	157,877	-	-	21,335	179,212	-	190,036	298	
6	2019	11,041	-	161,035	-	-	21,761	182,796	-	193,837	304	
7	2020	11,262	-	164,255	-	-	22,197	186,452	-	197,714	310	
8	2021	11,487	-	167,540	-	-	22,641	190,181	-	201,668	316	
9	2022	11,717	-	170,891	-	-	23,093	193,985	-	205,701	322	
10	2023	11,951	-	174,309	-	-	23,555	197,864	-	209,815	329	
11	2024	12,190	-	177,795	-	-	24,026	201,822	-	214,012	335	
12	2025	12,434	-	181,351	-	-	24,507	205,858	-	218,262	342	
13	2026	12,682	-	184,978	-	-	24,997	209,975	-	222,669	349	
14	2027	12,936	-	188,676	-	-	25,497	214,176	-	227,111	356	
15	2028	13,195	-	192,451	-	-	26,007	218,468	-	231,663	363	
16	2029	13,459	-	196,300	-	-	26,527	222,827	-	236,286	370	
17	2030	13,728	-	200,226	-	-	27,058	227,284	-	241,012	377	
18	2031	14,002	-	204,231	-	-	27,599	231,830	-	245,852	385	
19	2032	14,282	-	208,315	-	-	28,151	236,466	-	250,749	393	
20	2033	14,568	-	212,482	-	-	28,714	241,195	-	255,764	401	
Present Worth		122,179	-	1,782,023	0.0%	-	240,814	2,022,837	-	2,145,015	168	
(% of PW)		5.7%	0.0%	83.1%		0.0%	11.2%	94.3%	0.0%	100.0%		

Fabric Filter												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst/FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton PM Removed)	
0	2013											
1	2014	127,749	-	-	294,008	-	1,313,474	1,607,482	4,602,887	6,338,118	6,381	
2	2015	130,304	-	-	295,888	-	1,339,744	1,639,832	4,602,887	6,372,822	6,416	
3	2016	132,910	-	-	305,886	-	1,365,539	1,672,425	4,602,887	6,408,221	6,461	
4	2017	135,568	-	-	312,004	-	1,393,870	1,705,873	4,602,887	6,444,328	6,468	
5	2018	138,279	-	-	318,244	-	1,421,747	1,739,991	4,602,887	6,481,155	6,525	
6	2019	141,045	-	-	324,609	-	1,450,182	1,774,790	4,602,887	6,518,722	6,583	
7	2020	143,865	-	-	331,101	-	1,478,166	1,810,286	4,602,887	6,557,038	6,601	
8	2021	146,743	-	-	337,723	-	1,506,949	1,846,462	4,602,887	6,596,121	6,640	
9	2022	149,678	-	-	344,477	-	1,536,949	1,883,422	4,602,887	6,635,988	6,681	
10	2023	152,671	-	-	351,357	-	1,568,723	1,921,090	4,602,887	6,676,848	6,722	
11	2024	155,725	-	-	358,394	-	1,601,118	1,959,512	4,602,887	6,718,123	6,763	
12	2025	158,839	-	-	365,582	-	1,633,140	1,998,702	4,602,887	6,760,428	6,806	
13	2026	162,016	-	-	372,873	-	1,665,803	2,038,678	4,602,887	6,803,579	6,849	
14	2027	165,256	-	-	380,331	-	1,699,119	2,079,450	4,602,887	6,847,593	6,894	
15	2028	168,562	-	-	387,937	-	1,733,102	2,121,039	4,602,887	6,892,467	6,939	
16	2029	171,933	-	-	395,686	-	1,767,764	2,163,460	4,602,887	6,938,279	6,985	
17	2030	175,371	-	-	403,610	-	1,803,118	2,206,729	4,602,887	6,984,967	7,032	
18	2031	178,879	-	-	411,682	-	1,839,181	2,250,863	4,602,887	7,032,629	7,080	
19	2032	182,456	-	-	419,916	-	1,875,965	2,295,881	4,602,887	7,081,224	7,128	
20	2033	186,105	-	-	428,314	-	1,913,484	2,341,788	4,602,887	7,130,790	7,179	
Present Worth (% of PW)		1,560,813	0.0%	0.0%	3,552,147	0.0%	18,047,838	19,639,984	48,386,333	69,567,130	100.0%	
		2.2%			5.2%		23.1%	28.2%	69.5%			

Present Worth Cost for Air Pollution Control Options



Present Worth Cost for Air Pollution Control Options



APPENDIX B
2006 Wyoming BART Protocol

BART Air Modeling Protocol
Individual Source Visibility Assessments
for BART Control Analyses

September, 2006

State of Wyoming
Department of Environmental Quality
Air Quality Division
Cheyenne, WY 82002

Table of Contents

1.0	INTRODUCTION	3
2.0	OVERVIEW	4
3.0	EMISSIONS DATA FOR MODELING	7
3.1	Baseline Modeling	7
3.2	Post-Control Modeling.....	8
4.0	METEOROLOGICAL DATA.....	9
5.0	CALPUFF MODEL APPLICATION.....	12
6.0	POST PROCESSING	15
7.0	REPORTING	19

1.0 INTRODUCTION

The U.S. EPA has issued final amendments to the Regional Haze Regulations, along with Guidelines for Best Available Retrofit Technology (BART) Determinations.⁽¹⁾ The guidelines address the methodology for determining which facilities must apply BART (sources subject-to-BART) and the evaluation of control options.

The State of Wyoming used air quality modeling in accordance with the EPA Guidelines to determine the Wyoming sources which are subject-to-BART. This Protocol defines the specific methodology to be used by those sources for determining the improvement in visibility to be achieved by BART controls.

The methodology presented in this Protocol is consistent with EPA guidance and the Air Quality Division (AQD) determination of subject-to-BART sources. It is intended that all Wyoming sources that must conduct BART analyses will use this Protocol for their evaluation of control technology visibility improvement. Any deviations from the procedures described herein must be approved by the Division prior to implementation.

⁽¹⁾ 40 CFR Part 51: Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations; Final Rule. 70 Federal Register, 39103-39172, July 6, 2005.

2.0 OVERVIEW

Wyoming AQD determined that eight facilities (sources) in the state are subject-to-BART. The sources are listed in Table 1. Division modeling indicated that each of these sources causes or contributes to visibility impairment in one or more Class I areas. Each source must conduct a BART analysis to define Best Available Retrofit Technology (BART) applicable to that source, and quantify the improvement in Class I visibility associated with BART controls. This Protocol sets out the procedures for quantifying visibility improvement. Other aspects of the full BART analysis are not addressed here.

There are many Class I areas within and surrounding Wyoming (See Figure 1). On the basis of distance from subject-to-BART sources, topography, meteorology, and prior modeling, the AQD has determined that only five Class I areas need be addressed in BART individual source analyses. These are Badlands and Wind Cave National Parks in South Dakota, Mt. Zirkel Wilderness Area in Colorado, and Bridger and Fitzpatrick Wilderness Areas in Wyoming. Sources in eastern Wyoming have been shown to have greatest visibility impacts at the two South Dakota Class I areas, and western Wyoming sources have maximum impacts at Bridger and Fitzpatrick Wilderness Areas, and Mt. Zirkel. Visibility improvement at these highest impact areas will provide the best measure of the effectiveness of BART controls.

Each facility should carry out modeling with the CALPUFF modeling system for the Class I areas specified in Table 2. The AQD will provide meteorological input for CALMET for the years 2001, 2002, and 2003. The model domain covered by the AQD meteorological data is centered in southwest Wyoming, and extends roughly from Twin Falls, ID in the west to the Missouri River in the east, and from Denver in the south to Helena, MT in the north. The domain is shown, along with Class I areas, in Figure 1.

Sources may wish to utilize a smaller domain for CALPUFF modeling. Smaller domains are acceptable if they provide adequate additional area beyond the specific source and Class I areas being addressed. Figure 1 includes a "southwest Wyoming" domain which represents the minimum acceptable area for sources impacting the Bridger and Fitzpatrick Wilderness Areas, and the Mt. Zirkel Wilderness Area, and a "northeast Wyoming" domain as a minimum area for Badlands and Wind Cave National Parks modeling.

The CALPUFF model should be used with each of the three years of meteorological data to calculate visibility impacts for a baseline (existing emissions) case, and for cases reflecting BART controls. The control scenarios are to include individual scenarios for proposed BART controls for each pollutant (SO₂, NO_x, and particulate matter), and a combined scenario representing application of all proposed BART controls. If desired, additional modeling may be performed for controls that are not selected as BART. This might be done, for example, to provide data useful in identifying the control technologies that represent BART. However, visibility modeling is required only for the proposed BART controls.

Table 1. Wyoming Sources Subject-to-BART

Basin Electric	Laramie River Power Plant	Boilers #1,2,3
FMC Corporation	Granger Soda Ash Plant	Boilers #1,2
FMC Corporation	Green River Sodium Plant	Three boilers
General Chemical Co.	Green River Soda Ash	Two boilers
PacifiCorp	Dave Johnson Power Plant	Boilers #3,4
PacifiCorp	Jim Bridger Power Plant	Boilers #1-4
PacifiCorp	Naughton Power Plant	Boilers #1,2,3
PacifiCorp	Wyodak Power Plant	Boiler

Results of visibility modeling will be presented as a comparison between baseline impacts and those calculated for the BART control scenarios. Quantitative measures of impact will be the 98th percentile deciview change (Δdv) relative to the 20% best days natural background, and the number of days with deciview change exceeding 0.5 (EPA Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations, 70 FR 39103). Results should be presented for each year.

Table 2. Source-Specific Class I Areas to be Addressed

Source	Class I Areas to be Evaluated
Basin Electric Laramie River	Wind Cave NP, Badlands NP
FMC Corporation Granger Soda Ash	Bridger WA, Fitzpatrick WA
FMC Corporation Sodium Products	Bridger WA, Fitzpatrick WA
General Chemical Green River Soda Ash	Bridger WA, Fitzpatrick WA
Pacificorp Dave Johnston	Wind Cave NP, Badlands NP
Pacificorp Jim Bridger	Bridger WA, Fitzpatrick WA, Mt. Zirkel WA
Pacificorp Naughton Plant	Bridger WA, Fitzpatrick WA
Pacificorp Wyodak	Wind Cave NP, Badlands NP

3.0 EMISSIONS DATA FOR MODELING

CALPUFF model input requires source (stack) – specific emission rates for each pollutant, and stack parameters (height, diameter, exit gas temperature, and exit gas velocity). Per EPA BART guidance, these parameters must be representative of maximum actual 24-hour average emitting conditions for baseline (existing) operation, and maximum proposed 24-hour average emissions for future (BART) operations.

3.1 Baseline Modeling

Sources are required to utilize representative baseline emission conditions if data are available; baseline emissions must be documented. Possible sources of emission data are stack tests, CEM data, fuel consumption data, etc. Remember that emissions should represent maximum 24-hour rates. EPA BART guidance states that you should “Use the 24-hour average actual emission rate from the highest emitting day of the meteorological period modeled (for the pre-control scenario).” Thus, baseline conditions should reference data from 2001 through 2003 (or 2004).

As a minimum, modeled emissions must include:

SO ₂	sulfur dioxide
NO _x	oxides of nitrogen
PM _{2.5}	particles with diameter less than 2.5µm
PM _{10-2.5}	particles with diameters greater than 2.5µm but less than or equal to 10 µm

If the fraction of PM₁₀ in the PM_{2.5} (fine) and PM_{10-2.5} (coarse) categories cannot be determined all particulate matter should be assumed to be PM_{2.5}.

In addition, direct emissions of sulfate (SO₄) should be included where possible. Sulfate can be emitted as sulfuric acid (H₂SO₄), sulfur trioxide (SO₃), or as sulfate compounds; emissions should be quantified as the equivalent mass of SO₄.

When test or engineering data are not available to specify SO₄ emissions or the relative fractions of fine and coarse particles, use can be made of speciation profiles available from Federal Land Managers at the website <http://ww2.nature.nps.gov/air/permits/ect/index.cfm>. Profiles are available for a number of source type and control technology combinations. The FLM speciation factors are acceptable if data are available for the appropriate source type.

Emissions of VOC (volatile organic compounds), condensable organics measured in stack tests, and elemental carbon components of PM₁₀ do not need to be included for BART modeling. The only other pollutant noted in EPA BART guidance is ammonia (NH₃). Though ammonia is not believed to be a significant contributor to visibility

impairment in most cases in Wyoming, it could be important for sources with significant ammonia emissions – for example from some NO_x control systems. Sources that are expected to emit ammonia (in pre-or post-control configurations) should include ammonia emissions in their model input.

If quantitative baseline emissions data are unavailable and sources believe that the maximum 24-hour emission rates estimated by the Division (presented in the Subject-to-BART final report) are representative of baseline conditions for their facility, they may be used for baseline modeling. However, emissions of sulfate and ammonia (if applicable) should be included based on the best available test information or speciation factors from current literature.

3.2 Post-Control Modeling

All pollutants described above should be included for each post-control scenario. Post-control emissions (maximum 24-hour average) will generally be the baseline emissions multiplied by a control factor appropriate to the BART control. However, some proposed controls may simply increase the efficiency of existing controls; others may result in an increase in emissions of one pollutant while controlling another. These factors must all be considered in defining emission rates for post-control modeling. Any changes in stack parameters resulting from control application must also be included.

The required visibility assessment will include the effect of each proposed BART control. For example, if a source proposes to add a scrubber for SO₂ control, low NO_x burners for NO_x control, and a baghouse for particulate control, four sets of visibility results should be developed:

- Use of SO₂ control alone
- Use of NO_x control alone
- Use of particulate control alone
- Use of proposed combination of all three controls

All pollutants should be modeled in each CALPUFF model run, but the modeled emissions should reflect only the specific controls or combination of controls addressed in that run.

Additional modeling could be necessary in situations where a facility is comprised of more than one subject-to-BART source, and different BART controls are applicable to different sources. Excessive modeling to address multiple control combinations is not necessary; however, visibility modeling should quantify the effect of BART controls on all affected sources for each pollutant, and of all facility BART controls combined.

4.0 METEOROLOGICAL DATA

Wyoming AQD will provide MM5 meteorological data fields for years 2001, 2002, and 2003 that can be utilized as input to CALMET. The MM5 output will have 12 kilometer resolution and cover the full domain shown in Figure 1.

Mesoscale meteorological data (MM5) were developed and evaluated as part of the AQD's southwest Wyoming NO₂ increment analysis. Three years of MM5 data at 36 km resolution were used to initialize 12 km MM5 simulations. The 12km MM5 modeling used identical physics options to the original 36 km runs. CALMM5 was then used as a preprocessor to produce CALMET – ready MM5 data input files. Quality assurance was performed by comparing the original MM5 output on the 36km national RPO grid to the 12 km MM5 output and observations.

The CALMET model (version 5.53a, level 040716) should be used to prepare meteorological input for CALPUFF. The user may select a domain smaller than the MM5 domain for CALMET and CALPUFF modeling if desired. Figure 1 shows minimum domain areas for modeling of western and eastern Wyoming BART sources. Four kilometer resolution should be specified for CALMET output.

CALMET processing should use the AQD MM5 data, and appropriate surface, upper air, and precipitation data. Figure 2 shows the locations of surface and upper air stations within the MM5 model domain. The MM5 data are used as the initial guess wind field; this wind field is then adjusted by CALMET for terrain and land use to generate a step 1 wind field, and refined using surface and upper air data to create the final step 2 wind field.

Surface, upper air, and precipitation data can be obtained from the National Climatic Data Center. Land use and terrain data are available from the U.S. Geological Survey. Data can be formatted for use in CALMET with standard conversion and processing programs available with the CALMET/CALPUFF software.

Table 3 provides a listing of applicable CALMET input variables for BART meteorological processing. The table includes inputs that are specific to Wyoming BART modeling. Inputs not shown in Table 3 are not relevant to the present application, are dependent on the specific model domain of the user, use model default values, or are obvious from the context.

Table 3. CALMBT Control File Inputs

Variable	Description	Value
	Input Group 1	
IBYR	Year	2001
		2002
		2003
IBTZ	Base time zone	7
IRTYPE	Run type	1
LCALGRD	Compute data fields for CALGRID	T
	Input Group 2	
PMAP	Map projection	LCC
DGRIDKM	Grid spacing (km)	4
NZ	Number of layers	10
ZFACE	Cell face heights (m)	0
		20
		40
		100
		140
		320
		580
		1020
		1480
		2220
		3500
	Input Group 4	
NOOBS	No observation Mode	0
	Input Group 5	
IWFCOD	Model selection variable	1
IFRADJ	Froude number adjustment	1
IKINE	Kinematic effects	0
IOBR	Use O'Brien procedure	0
ISLOPE	Slope flow effects	1
IEXTRP	Extrapolate surface wind observations	-4
ICALM	Extrapolate calm surface winds	0
BIAS	Biases for weights of surface and upper air stations	All 0
RMIN2	Minimum distance for extrapolation	-1
I PROG	Use gridded prognostic model output	14
ISTEPPG	Time Step (hours)	1
LVARY	Use varying radius of influence	F

Table 3. CALMET Control File Inputs (continued)

Variable	Description	Value
RMAX 1	Maximum radius of influence (km)	30
RMAX 2	Maximum radius of influence (km)	50
RMIN	Minimum radius of influence (km)	0.1
TERRAD	Radius of influence for terrain (km)	15
R1	Relative weighting of first guess wind field and observations (km)	5
R2	Relative weighting aloft (km)	25
IDIOPT 1	Surface temperature	0
IDIOPT 2	Upper air lapse rate	0
ZUPT	Lapse rate depth (m)	200
IDIOPT 3	Average wind components	0
IUPWND	Upper air station	-1
ZUPWND (1)	Bottom and top of layer for domain	1, 1000
ZUPWND (2)	scale winds (m)	1, 1000
IDIOPT4	Surface wind components	0
IDIOPT5	Upper air wind components	0
	Input Group 6	
IAVEZI	Spatial averaging	1
MNMDAV	Max search radius	1
HAFANG	Half angle for averaging (deg)	30
ILEVZI	Layer of winds in averaging	1
ZIMAX	Maximum overland mixing height (m)	3500
ITPROG	3D temperature source	1
IRAD	Interpolation type	1
TRADKM	Radius of influence – temperature (km)	500
NUMTS	Maximum number of Stations	5
IAVET	Spatial averaging of temperatures	1
NFLAGP	Precipitation interpolation	2

5.0 CALPUFF MODEL APPLICATION

The CALPUFF model (version 5.711a, level 040716) will be used to calculate pollutant concentrations at receptors in each Class I area. Application of CALPUFF should, in general, follow the guidance presented in the Interagency Workgroup on Air Quality Modeling (IWAQM) Phase 2 report (EPA - 454/R98-019) and the EPA Regional Haze Regulations and Guidelines for BART Determinations (70 FR 39103).

Appropriate CALPUFF control file inputs are in Table 4. Note should be taken of the basis for several of the recommended CALPUFF inputs.

- Building downwash effects need not be included. Because of the transport distances involved and the fact that most sources have tall stacks, building downwash is unlikely to have a significant effect on model-predicted concentrations
- Puff splitting is not required. The additional computation time necessary for puff splitting is not justified for purposes of BART analyses.
- Hourly ozone files should be used to define background ozone concentration. Data are available from the following sites within the model domain.
 - Rocky Mountain NP, CO
 - Craters of the Moon NP, ID
 - AIRS - Highland UT
 - Mountain Thunder, WY
 - Yellowstone NP, WY
 - Centennial, WY
 - Pinedale, WY

The background ozone concentration shown in Table 4 is used only when hourly data are missing.

- A constant background ammonia concentration of 2.0 ppb is specified. This value is based upon monitoring data from nearby states and IWAQM guidance. Experience suggests that 2.0 ppb is conservative in that it is unlikely to significantly limit nitrate formation in the model computations.
- MESOPUFF II chemical transformation rates should be used.
- The species to be modeled should be the seven identified in CALPUFF: SO₂, SO₄, NO_x, HNO₃, NO₃, PM_{2.5}, and PM_{10-2.5}. If ammonia (NH₃) is emitted it should be added to the species list. In most cases, all pollutants modeled will also be emitted, except for HNO₃ and NO₃.

Concentration calculations should be made for receptors covering the areas of the Class I areas being addressed. Receptors in each Class I area will be those designated by the Federal Land Managers and available from the National Park Service website.

Table 4. CALPUFF Control File Inputs

Variable	Description	Value
	Input Group 1	
MBTRUN	Control parameter for running all periods in met file	1
IBYR	Starting year	2001 2002 2003
XBTZ	Base time zone	7
NSPEC	Number of chemical species modeled	7 (or 8)
NSE	Number of species emitted	5 (or 6)
METFM	Meteorological data format	1
	Input Group 2	
MGAUSS	Vertical distribution in near field	1
MCTADJ	Terrain adjustment method	3
MCTSG	Subgrid scale complex terrain	0
MSLUG	Elongated puffs	0
MTRANS	Transitional plume rise	1
MTIP	Stack tip downwash	1
MSHEAR	Vertical wind shear	0
MSPLIT	Puff splitting allowed?	0
MCHEM	Chemical mechanism	1
MAQCHEM	Aqueous phase transformation	0
MWET	Wet removal	1
MDRY	Dry deposition	1
MDISP	Dispersion Coefficients	3
MROUGH	Adjust sigma for roughness	0
MPARTL	Partial plume penetration of inversions	1
MPDF	PDF for convective conditions	0
	Input Group 4	
PMAP	Map projection	LCC
DGRIDKM	Grid spacing	4

Table 4. CALPUFF Control File Inputs (continued)

ZFACE	Cell face heights (m)	0
		20
		40
		100
		140
		320
		580
		1020
		1480
		2220
		3500
	Input Group 6	
NHILL	Number of terrain features Input Group 7	0
Dry Gas Depo	Chemical parameters for dry gas deposition	Defaults
	Input Group 8	
Dry Part. Depo	Size parameters for dry particle deposition SO ₄ , NO ₃ , PM25 PM10	Defaults 6.5, 1.0
	Input Group 11	
MOZ	Ozone Input option	1
BCKO3	Background ozone -- all months (ppb)	44.0
BCKNH3	Background ammonia -- all months (ppb)	2.0
	Input Group 12	
XMAXZI	Maximum mixing height (m)	3500
XMINZI	Minimum mixing height (m)	50

6.0 POST PROCESSING

Visibility impacts are calculated from the CALPUFF concentration results using CALPOST. CALPOST version 5.51, level 030709 should be used; the output from CALPOST will provide the highest deciview impact on each day from all receptors within each Class I area modeled.

For some CALPUFF applications such as deposition calculations, the POSTUTIL program is used prior to CALPOST. POSTUTIL is also used to repartition total nitrate by accounting for ammonia limiting. The ammonia limiting calculation in POSTUTIL should not be applied for Wyoming BART modeling. If you believe that ammonia limiting is appropriate for a specific BART analysis, justification should be discussed with the Division prior to its used.

Visibility calculations by CALPOST for BART purposes use Method 6. This method requires input of monthly relative humidity factors, $f(RH)$, for each Class I area. The EPA guidance document provides appropriate data for each area. Table 5 lists monthly $f(RH)$ factors to use for the Wyoming, Colorado, and South Dakota areas to be addressed in BART modeling. The factors shown in Table 5 include averages for the adjacent Class I areas, and are within 0.2 units of the Guideline table values for the individual Class I areas.

Natural background conditions as a reference for determination of the delta-dv change due to a source should be representative of the 20% best natural visibility days. EPA BART guidance provides the 20% best days deciview values for each Class I area on an annual basis, but does not provide species concentration data for the 20% best background conditions. These concentrations are needed for input to CALPOST.

Annual species concentrations corresponding to the 20% best days were calculated for each Class I area to be addressed, by scaling back the annual average concentrations given in Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule (Table 2-1). A separate scaling factor was derived for each Class I area such that, when multiplied by the Guidance table annual concentrations, the 20% best days deciview value for that area would be calculated. The scaled aerosol concentrations were averaged for the Bridger and Fitzpatrick WAs, and for Wind Cave and Badlands NPs, because of their geographical proximity and similar annual background visibility. The 20% best days aerosol concentrations to be used for each month for Wyoming BART evaluations are listed in Table 6.

Table 7 is a list of inputs for CALPOST. These inputs should be used for all BART visibility calculations. Output from CALPOST should be configured to provide a ranked list of the highest delta-deciview values in each Class I area. The 98th percentile delta-deciview value and the number of values exceeding 0.5 can then be determined directly from the CALPOST output.

Table 5. Monthly f(RH) Factors for Class I Areas

Month	Wind Cave NP Badlands NP	Bridger WA Fitzpatrick WA	Mt. Zirkel WA
January	2.65	2.50	2.20
February	2.65	2.30	2.20
March	2.65	2.30	2.00
April	2.55	2.10	2.10
May	2.70	2.10	2.20
June	2.60	1.80	1.80
July	2.30	1.50	1.70
August	2.30	1.50	1.80
September	2.20	1.80	2.00
October	2.25	2.00	1.90
November	2.75	2.50	2.10
December	2.65	2.40	2.10

Table 6. Natural Background Concentrations of Aerosol Components for 20% Best Days for BART Analyses ($\mu\text{g}/\text{m}^3$)

Aerosol Component	Wind Cave NP Badlands NP	Fitzpatrick WA Bridger WA	Mt. Zirkel WA
Ammonium Sulfate	.047	.045	.046
Ammonium Nitrate	.040	.038	.038
Organic Carbon	.186	.178	.179
Elemental Carbon	.008	.008	.008
Soil	.198	.189	.190
Coarse Mass	1.191	1.136	1.141

Table 7. CALPOST Control File Inputs

Variable	Description	Value
	Input Group 1	
ASPEC	Species to Process	VISIB
ILAYER	Layer/deposition code	1
A,B	Scaling factors	0,0
LBACK	Add background concentrations?	F
BTZONE	Base time zone	7
LVSO4	Species to be included in extinction	T
LVNO3		T
LVOC		F
LVPMC		T
LVPMF		T
LVEC		F
LVBK	Include background?	T
SPECPMC	Species name for particulates	PM10
SPECPMF		PM25
EEPMC	Extinction efficiencies	0.6
EEPMF		1.0
EEPMCBK		0.6
EESO4		3.0
EENO3		3.0
EEOC		4.0
EESOIL		1.0
EEEC		10.0
MVISBK	Visibility calculation method	6
RHFAC	Monthly RH adjustment factors	Table 5
BKSO4	Background concentrations	Table 6
BKNO3		Table 6
BKPMC		Table 6
BK OC		Table 6
BKSOIL		Table 6
BKEC		Table 6
BEXTRAY	Extinction due to Rayleigh scattering	10.0

7.0 REPORTING

A report on the BART visibility analysis should be submitted that clearly compares impacts for post-control emissions to those for baseline emissions. Data for baseline and BART scenarios should include both the 98th percentile values and the number of days with delta-deciview values exceeding 0.5. Results should be given for each model year.

Table 8 is an example of a recommended format for presentation of model input and model results. The example is for baseline conditions; similar tables should be provided for each control scenario (SO₂, NO_x, and PM10) and for the combination of all BART controls. Your report tables need not follow the exact format shown in Table 8; but the same information should be provided in a concise and clear form. If additional scenarios were modeled or you wish to present supplemental information, they should be provided in an appendix or separate from the specified final results.

Table 8. Example Format for Presentation of Model Input and Results

Baseline Conditions Model Input Data												
Source (Unit) Description And ID	SO ₂ Emission Rate (lb/day)	NO _x Emission Rate (lb/day)	PM _{2.5} Emission Rate (lb/day)	PM _{10-2.5} Emission Rate (lb/day)	SO ₄ Emission Rate (lb/day)	NH ₃ Emission Rate (lb/day)	Location Easting UTM (m)	Location Northing UTM (m)	Stack Height (m)	Stack Diameter (m)	Exit Velocity (m/s)	Exit Gas Temp (deg K)

Baseline Visibility Modeling Results

Name of Facility	Class I Area	2001		2002		2003	
		98 th Percentile Value (dv)	No. of days exceeding 0.5 dv	98 th Percentile Value (dv)	No. of days exceeding 0.5 dv	98 th Percentile Value (dv)	No. of days exceeding 0.5 dv

APPENDIX C
Just-Noticeable Differences in Atmospheric Haze
Dr. Ronald Henry

Just-Noticeable Differences in Atmospheric Haze

Ronald C. Henry

Department of Civil and Environmental Engineering, University of Southern California, Los Angeles

ABSTRACT

This article examines the only available experimental data taken in the natural environment on the ability of an observer to perceive small, incremental changes in the colorfulness of objects seen through atmospheric haze and estimates an appropriate just-noticeable difference (JND) from these data. This experimentally determined threshold of perception is compared to changes in the deciview scale. Based on these experimental results, the deciview scale is found to not be uniform over a wide range of visibility conditions, as has been previously claimed. In addition, a 1-deciview change never produces a perceptible change in haze, as defined by a 95% probability of producing a measurable change in the colorfulness of an object seen through the haze.

INTRODUCTION

Section 169A of the Clean Air Act sets a national goal of protecting visibility in national parks and other pristine areas. Under regulations promulgated in 1980, the U.S. Environmental Protection Agency (EPA) has taken specific regulatory action to protect visibility in the Grand Canyon National Park by reducing emissions of sulfur dioxide from the Navajo Electric Generating Station near the eastern end of the Grand Canyon and from the Mohave Power Plant at the western end. However, current concerns about visibility degradation stem from regional haze that is difficult or impossible to attribute to individual sources of air pollution. This issue is addressed by regional haze regulations that set a goal of making reasonable

progress toward improving regional visibility in five-year increments, leading to the attainment of "natural conditions" by 2064.¹ Progress is to be measured by an innovative visibility metric for regulatory purposes known as the deciview,² used instead of visual range or other visibility metrics because it "expresses uniform changes in haziness in terms of common increments across the entire range of visibility conditions, from pristine to extremely hazy conditions."¹ One goal of this article is to assess this and other claims about the deciview scale in light of actual measurements of the perception of haziness. Since the deciview scale is meant to quantify small, just-noticeable differences (JNDs) in visibility, a review of the basic concepts of thresholds and JNDs is given.

Perceptual Threshold Concepts

For all the senses, thresholds are necessary—otherwise we would be constantly distracted by small, inconsequential changes in the environment. A background of random noise, some from the environment and some produced inside our own sensory organs, would make it next to impossible to form a stable view of the world. Our vision would be like the grainy, speckled images produced by night vision cameras. On a more basic scientific level, the study of thresholds of the senses has led to a deeper understanding of sensory physiology and how our vision and other senses function. For this reason, virtually all studies of thresholds of vision have been carried out under controlled laboratory conditions.

Since laboratory conditions seldom mimic the natural environment, thresholds so determined are generally not useful in predicting perception in the complex natural world. As an example of the drastic effect that experimental conditions can have on perception, consider an experiment to determine the ability of an observer to perceive the difference in the length of two strings—or to put it another way, to determine the threshold for perception of the difference in the length of two strings, or the JND. If the two strings are widely separated when presented to the observer, the threshold will be much greater than if the two strings are presented side by side. The visual equivalent of this is the use of a split image to determine the ability to distinguish color. If two colors are seen as two halves of a disk, the JND is very small, but if one

IMPLICATIONS

Current regulations use the deciview to quantify a perceptible change in regional haze. Based on the results of this article, changes in atmospheric extinction required to meet regional haze regulations calculated using deciviews would probably be too small, sometimes much too small. In addition, these regulations require that progress be assessed over five-year intervals. In this way, the burden of reducing emissions is spread evenly over many years. However, since deciviews are not uniform in perception, it may be that the actual improvement in visibility will not be uniform.

color is presented as a full disk, followed a few seconds later by the other color, the JND will be much larger. The topic of the background on which the colors are seen is also important (e.g., if it is black or a complex scene). In general, many conditions influence thresholds; for this reason, the results of laboratory experiments should be applied with great caution to the natural environment. Thus, this article will report and analyze data taken in a unique experiment in the natural environment with a goal of determining a JND in atmospheric haze.

In the above discussion, the terms "threshold" and "JND" have been freely used, but not defined. The naïve definition of a threshold or JND is clear: It is the smallest amount, or change in, a physical stimulus that is detectable. Ideally, a 1-JND change in a stimulus such as contrast or color would always result in the observer seeing a change, and anything less would not. Of course, the senses do not work in this simple on-off manner. In actuality, as the change in the physical stimulus increases, the probability that the observer will detect the change increases as well. Thus, thresholds and JNDs have always been defined by a probability of detection. Furthermore, the sensitivity of people's senses varies from person to person and during a person's life. Even if each person had a single, idealized threshold, the response of the general population would be best described by a probability of detection.

Repeated matching by the method of adjustments is one of the oldest methods of determining a JND. Falmagne³ described this and other methods to quantify perception. Briefly, the observer is shown a target color and a variable test color and is asked to adjust the test color until it matches the target. Taking random starting points, the matching procedure is repeated as often as is practical. Since the observer has judged the matching color to be the same as the target color, the variability in the matches is a measure of a JND around the target. The standard deviation of the matches is one measure of this variability that is often used; another is the difference between the 75th and the 25th percentile of the match distribution. The method of adjustments has been replaced in laboratory studies by methods that give less control to the observer and more to the researcher and therefore improve the reproducibility of the results (unfortunately, these methods are impractical for field studies). However, JNDs are still defined by some measure related to the probability of detection. The final determination of the value of a JND or threshold is really dependent on how the measurements are made and how the data are interpreted. For the experimental data used in this article, the method of adjustments was used and a JND related to the standard deviation of repeated matches was defined.

Atmospheric Visibility Concepts

In the classical theory of atmospheric visibility, the threshold of contrast perception, that is, the threshold for perception of a large, dark object on the horizon, is assumed to be 2%.⁴ This number is somewhat arbitrary. The Federal Aviation Administration (FAA) has taken the more conservative value of 5.5% as a contrast threshold for the definition of visual range, presumably because approaching aircraft seen from a cockpit are usually neither large nor dark. The common formula for visual range, using the 2% threshold, is

$$V_R = \frac{-\ln(0.02)}{b_{ext}} = \frac{3.9}{b_{ext}} \quad (1)$$

where b_{ext} is the extinction coefficient of the atmosphere, which is assumed to be homogeneous. The extinction coefficient in the denominator of the formula can be thought of as the fraction of light that is lost as it traverses 1 m of air. For completely clear air, b_{ext} has a value of about $10 \times 10^{-6} \text{ m}^{-1}$ or 10 Mm^{-1} , or a visual range of about 390 km. More typically, particles in the air usually increase the extinction coefficient to 150–300 Mm^{-1} or more. Typical visual ranges are about 10 km in the eastern United States and 50 km or more in the western United States. Closely related to b_{ext} and visual range is the more general concept of optical depth. For a target at a distance x , this is defined as xb_{ext} . It is dimensionless; if b_{ext} is held constant it represents distance, and if the distance is constant, it represents changes in b_{ext} . From eq 1, the visual range corresponds to an optical depth of 3.9, and a distance of about one quarter of the visual range is equivalent to an optical depth of 1.

Despite lacking a firm psychophysical or experimental basis, the visual range defined by the 2% threshold has stood the test of time. However, while visual range has proven to be a good surrogate for atmospheric visibility for the aviation community, it is of limited value in addressing the concerns of the air quality community. Unlike aviation, where poor visibility is of greatest interest, the air quality community is primarily concerned with relatively small changes in good visibility. Pitchford and Malm² have proposed the deciview as a visibility indicator more suited to air quality regulations. If the extinction coefficient is given in Mm^{-1} , then deciview is defined as

$$v = 10 \ln(b_{ext} / 10) \quad (2)$$

Current regional haze visibility regulations state that:

- (1) A 1-deciview change in haziness is a small, but noticeable, change in haziness under most circumstances when viewing scenes in Class I areas.
- (2) Deciview units are uniform in perception over a wide range of visibility conditions; that is, a 1-deciview change is just perceptible regardless of the visibility conditions.¹

The next section describes a color matching experiment in the Great Smoky Mountains National Park. The results of this experiment are used to estimate a just-noticeable change in haze based on color perception. The validity of the claims for deciviews will be evaluated by comparison to experimental estimates of JNDs.

EXPERIMENTAL DATA

During summer 1995, a group of researchers from universities, government agencies, and private companies conducted the SouthEast Aerosol and Visibility Study (SEAVS) in the Great Smoky Mountains National Park. The SEAVS focused largely on aerosol composition,^{5,6} airborne particle size distribution,^{7,8} and the role of water in the aerosol.⁹⁻¹¹ However, the SEAVS had a number of other aspects, including a study of the perception of color through atmospheric haze.¹² The methods and primary results of the color perception study are described below.

The perceived colors of natural targets were quantified by color matching using a specially constructed visual colorimeter.¹³ An observer looked at some scene element, such as a barn or green field, with one eye. The observer looked with the other eye in the visual colorimeter at a color spot, which the observer adjusted to match the color of the target. The perceived color was recorded as the amount of red, green, and blue light in the color match. At the same time, the spectrum of the light coming from the target was measured by a telespectroradiometer. A color appearance model was applied to produce measures of the perceived color as recorded by the visual colorimeter and as calculated from the spectrum.¹⁴

Of most interest here are the hue and colorfulness. The hue is what most people call the color—red, green, blue, yellow, and so on. It is quantified as a mixture of pure red, green, blue, or yellow lights. The colorfulness is the degree to which the hue is expressed; it is similar to the concept of saturation. A deep red color would have a colorfulness of about 100, while a colorfulness of 10 or less is almost achromatic (i.e., white or gray).

Two observers (Mahadev and Urquito) made color matches of a set of natural targets during the SEAVS. These observers were both males in their 20s with normal color vision. Each had received extensive training in color matching using the visual colorimeter. The scattering coefficient of the atmosphere was measured by a nearby nephelometer; particle absorption was small and its contribution to the extinction coefficient ignored. The full details of the experiment are found in Mahadev.¹⁵

The perception study found that viewing through a semitransparent atmosphere affected the perception of hue and colorfulness in a highly nonlinear way. The eye appeared to split the light coming from the target into two parts, the haze and the target. The result was that as

the haze increased, the hue of the target as seen by the observer remained constant. However, because the increasing haze scattered more light into the sight path, the hue calculated from the spectrum became bluer. To the observer, the main effect of haze was to decrease the perceived colorfulness. Furthermore, the decrease in colorfulness seemed to be exponential with optical depth (optical depth is the dimensionless product of the extinction coefficient and distance):

$$M(\tau) = M_0 \exp(-\tau) \quad (3)$$

where $M(\tau)$ is the colorfulness of the object at optical depth τ and M_0 is the colorfulness at zero optical depth (i.e., no haze). M_0 is also known as the inherent colorfulness. The colorfulness of the horizon was assumed to be small enough to be taken as zero—the horizon was perceived to be white. This result implies that a JND in colorfulness can be taken to be a JND in haze.

JND in Colorfulness

Estimates of JNDs in colorfulness were based on sets of repeated color matches made during periods when the observing conditions (cloud cover, haze level, and lighting) were judged to be constant or nearly so. Observer Urquito made six sets of repeated matches.¹⁵ Figure 1 is a plot of all the repeated observations of the colorfulness of the red barn roof made by this observer versus optical depth. The exponential fit given by eq 1 is fairly good ($R^2 = 0.68$). The error bars in the figure are twice the standard deviation given in Table 1. They show that one set




Figure 1. Colorfulness vs. optical depth for observer Urquito for repeated observations of the red barn roof. The line is an exponential fit as in eq 1, and the error bars are two times the standard deviation given in Table 2.

Table 1. Repeated measurements of the red barn roof by observer Mahadev.

Date	Time	Scattering Coefficient (Mm) ⁻¹	Visual Range (km)	Colorfulness		Spectra Hue		Perceived Hue	
				Spectra	Perceived	% Red	% Blue	% Red	% Blue
7/29/95	10:20 a.m.	37	105.7	38.0	42.2	53	47	97	3
7/29/95	10:46 a.m.	39	100.3	38.9	45.6	40	60	92	8
7/29/95	10:54 a.m.	39	100.3	39.9	45.4	38	62	99	1
7/29/95	11:03 a.m.	42	93.1	35.6	46.3	52	48	92	8
7/29/95	11:12 a.m.	42	93.1	37.5	44.9	53	47	93	7
7/25/95	11:49 a.m.	65	60.2	31.2	41.1	50	50	88	12
7/25/95	12:01 p.m.	65	60.2	30.8	45.1	42	58	84	16
7/25/95	12:12 p.m.	65	60.2	30.4	44.1	53	47	91	9
7/25/95	12:19 p.m.	65	60.2	29.4	43.0	54	46	91	9
7/25/95	12:24 p.m.	65	60.2	29.2	48.4	47	53	93	7
8/11/95	9:46 a.m.	157	24.9	37.6	29.2	19	81	97	3
8/11/95	9:57 a.m.	157	24.9	37.2	28.8	22	78	98	2
8/11/95	10:07 a.m.	157	24.9	37.5	29.2	23	77	98	2
8/11/95	10:16 a.m.	161	24.3	36.3	34.9	24	76	98	2
8/11/95	10:21 a.m.	161	24.3	36.7	29.5	23	77	98	2
8/14/95	10:12 a.m.	311	12.6	44.4	18.2	9	91	91	9
8/14/95	10:18 a.m.	312	12.5	44.0	18.4	8	92	97	3
8/14/95	10:30 a.m.	313	12.5	44.8	17.6	7	93	95	5
8/14/95	10:34 a.m.	313	12.5	44.7	18.1	7	93	94	6
8/14/95	10:38 a.m.	313	12.5	44.3	18.3	8	92	94	6
8/18/95	11:00 a.m.	595	6.6	35.3	9.7	2	98	81	19
8/18/95	10:46 a.m.	616	6.4	35.4	6.8	2	98	98	2
8/18/95	10:50 a.m.	616	6.4	35.2	9.4	2	98	91	9
8/18/95	10:53 a.m.	616	6.4	35.0	7.3	2	98	99	1
8/18/95	10:57 a.m.	616	6.4	35.7	10.0	2	98	97	3

of repeated measurements had colorfulness values that deviated much more than 2 sigma from the exponential line. However, the spread of these values about the mean was about the same as other observations for the same optical depth. This shows that the variability in the colorfulness numbers is not affected by systematic observer bias in the average colorfulness, and that the variability will be used to define the JND. The observations of the same target by the other observer are discussed in detail below.

Table 1 gives the results of five sets of repeated matches by observer Mahadev for the roof of a red barn about 3.5 km distant. Table 1 is sorted by the extinction coefficient so that one can easily see that the perceived hue did not change with increasing haze, but that the hue derived from the spectrum changed from red to blue. Colorfulness had the opposite behavior; the perceived values decreased with increasing haze and the values from the spectrum stayed about the same. Two-way

analysis of variance was applied to estimate the random error in the sets of repeated measurements in Table 1. This analysis was repeated for both observers' matches of five additional natural targets. The results are given in Table 2. The standard deviation for both observers was 2.05, as calculated from the average of the variances. Although viewing conditions were chosen to be constant, some of this variability was due to small changes in atmospheric conditions.

Based on these results, one can define the JND in colorfulness in many ways. One appropriate definition for this application is based on the following thought experiment. An observer matches a target with the visual colorimeter and determines the colorfulness to be C_1 . The extinction coefficient of the atmosphere is decreased, so the colorfulness of the target is increased by an amount ΔC .

The observer matches the target again to get the new colorfulness C_2 . A JND is defined as the value of ΔC that gives a 95% probability that $C_2 - C_1 > 0$. Assume that C_1 and C_2 are normal random variables with standard deviation s and means C_0 and $C_0 + \Delta C$, respectively (statistical analysis of the SEAVS color matching data confirms that this is a good assumption). Then $C_2 - C_1$ is a normal random variable with mean ΔC and standard deviation $2^{1/2}\sigma$. The value of ΔC needed to ensure a 95% probability that $C_1 - C_2 > 0$ is given by $2^{1/2}\sigma F(0.95)$, where $F(0.95)$ is the inverse of the cumulative standard normal distribution and is equal to 1.645. Thus, the colorfulness JND is taken to be $2^{1/2}\sigma F(0.95) = 2.326\sigma$. From Table 2, using the data for both observers gives $\sigma = 2.05$, and a 1 colorfulness JND is 4.8. This value of σ includes the effects of small random variations in natural illumination, which should be included for this application because they are inevitably present, but makes the value of a colorfulness JND a bit larger than it would be otherwise.

Table 2. Standard deviations of colorfulness for repeated matches of natural targets.

Target	Observer		Distance (km)
	M	U	
White silo	0.91	1.33	3.54
Red roof	1.93	2.41	3.54
Near green meadow	2.93	2.15	3.86
Green hills	2.15	3.46	5.15
Far green meadow	1.45	1.64	10.46
Horizon sky	1.53	1.19	
Average	1.92	2.17	
Number of observations	55	60	

Deciviews and Colorfulness JNDs

Relationships between colorfulness, deciviews, and optical depth are derived below; these will be applied to test the validity of the properties of deciviews given in the regional haze regulations.

From eqs 2 and 3, an expression for deciviews v as a function of colorfulness M is derived:

$$v = 10 \ln \left(-\frac{1}{10x} \ln \left(\frac{M}{M_0} \right) \right) \quad (4)$$

For a given optical depth and inherent colorfulness, the equations above were used to calculate the change in deciviews needed to give a 1-JND increase in colorfulness, using 4.8 as a JND. Figure 2 is a plot of the results as a function of optical depth for objects with three levels of inherent colorfulness. These levels of inherent colorfulness represent a reasonable range for natural targets.¹² As might be expected, more colorful objects are more sensitive to changes in atmospheric haze. Perhaps unexpectedly, the figure shows that landscape features at a distance corresponding to an optical depth of 1–2 are the most sensitive to changes in extinction as measured by deciviews. This range corresponds to one quarter to one half of the visual range. Landscape features outside this range are much less sensitive to changes in haze. If the deciview scale were perceptually uniform, as claimed in the regional haze rules, then the lines in the figure would be horizontal, or at least approximately so. However, the change in deciviews needed to produce a 1-JND change in colorfulness varied a great deal with optical depth and inherent colorfulness. The figure also shows that a 1-JND change in colorfulness always requires more than a 1-deciview change, sometimes much more.

DISCUSSION AND CONCLUSIONS

Regional atmospheric haze affects visibility by producing a visible haze layer that limits the visual range, reduces




Figure 2. Change in deciviews needed to produce a just-noticeable increase in colorfulness for objects with an inherent colorfulness of 25, 50, and 75. The horizontal dashed dotted line represents what would be expected if a 1-deciview change were actually a uniform measure of haze perception.

contrast, and decreases the colorfulness of objects seen through the haze. Of these three effects of haze, the decrease in colorfulness may be the most important and sensitive visual cue. Visual range is not often useful for judging the effects of small changes in extinction. For example, a change in visual range from 50 to 60 km will not be noticed if the most distant landscape feature is at 25 km. The effect of haze on contrast is a better candidate as an indicator of change in haze; however, perceived contrast, like perceived hue, is affected in a nonlinear fashion by the semitransparent nature of haze and is not a sensitive indicator of changes in atmospheric haze.¹⁶ Experimental data have shown that colorfulness is a sensitive measure of changes in haze, so this article has used it to define just-noticeable changes in atmospheric haze.

A just-noticeable decrease in atmospheric haze is defined as a decrease in extinction that would produce a 95% probability of a measurable increase in colorfulness of an object seen through the haze. From the experimental evidence from the two young male observers, a JND in colorfulness was 4.8. For the population in general, this number is certainly too low, since all visual functions decline with age. Thus, the conclusions below about the deciview scale based on this number are understated for the general population.

Analysis of the experimental data showed that for a JND in atmospheric haze as defined above:

- (1) The deciview scale is not uniform in perception over a wide range of visibility conditions. In fact, the change in deciviews needed to be noticeable

varies greatly depending on the optical distance of the landscape feature and its inherent colorfulness.

(2) A 1-deciview change is never noticeable.

What are the implications of these results for measuring progress toward reducing regional haze using the deciview metric? This is difficult to judge because the current proposals are very complex, using particulate measurements and relative humidity to estimate the extinction coefficient and average deciviews for the 20% most-impaired and 20% least-impaired days. The goal is to show no change on the least-impaired days and improvement on the most-impaired days, leading to natural conditions by 2064.¹⁷

The results of this article highlight a possible flaw in this regulatory scheme based on the deciview metric. An unstated assumption is that the nature of the scenic vista can be ignored—that is, a given deciview change will affect the perception of all landscape features in all scenes in the same way. Figure 2 shows that this is approximately true only if all the important landscape features have nearly the same inherent colorfulness and are at distances that correspond to an optical depth of between 1 and 2, or about one quarter to one half of the visual range. In this limited case, the deciview is indeed a uniform metric. However, most scenic vistas do not fit these restrictions and, by Figure 2, will require greater decreases in extinction as measured by deciviews to show a perceptible change. The result is that the emission reductions required by the proposed regulatory analysis are likely to produce much smaller improvements in perceived effects of regional haze than expected. The EPA guidance documents provide an example of an eastern scenic vista with a baseline of 27 deciviews and natural conditions of 11.¹⁷ The decrease in extinction to reach natural conditions by 2064 is 0.35 deciview/yr, or 1.75 deciviews in five years. This five-year reduction should, according to the regulations, result in a noticeable change in regional haze. However, the results herein predict that there would very likely be no noticeable difference in any actual scenic vista in the region as a result of the required emission reductions.

Regional haze rules also call for a uniform rate of improvement in visibility (measured in deciviews) that is needed to go from current conditions to natural conditions by 2064. Since the deciview scale is not uniform in perception over a wide range of visibility conditions, this requirement is also flawed and will not result in uniform improvement in perceived visibility.

ACKNOWLEDGMENTS

The funding for this project was provided by the Electric Power Research Institute under Contract EP-P5419/C2683. The author would like to thank Dr. Naresh Kumar for his support and discussions leading to this work, and Drs.

Shudeish Mahadev and Santiago Urquito for their careful and diligent work as the observers in the field study.

REFERENCES

1. *Fed. Regist.* 1999, 64 (126), 35713-35774.
2. Pitchford, M.; Malm, W. Development and Applications of a Standard Visual Index; *Atmos. Environ.* 1994, 28, 1049-1054.
3. Falmagne, J.C. *Elements of Psychophysical Theory*; Oxford University Press: New York, 1985.
4. Middleton, W.E.K. *Vision through the Atmosphere*; University of Toronto Press: Toronto, Ontario, 1952; p 122.
5. Andrews, E.; Saxena, P.; Musarra, S.; Hildemann, L.M.; Koutrakis, P.; McMurry, P.H.; Olmez, I.; White, W.H. Concentration and Composition of Atmospheric Aerosols from the 1995 SEAVS Experiment and a Review of the Closure between Chemical and Gravimetric Measurements; *J. Air & Waste Manage. Assoc.* 2000, 50, 648-664.
6. Blando, J.D.; Porcja, R.J.; Li, T.H.; Bowman, D.; Lloy, P.J.; Turpin, B.J. Secondary Formation and the Smoky Mountain Organic Aerosol: An Examination of Aerosol Polarity and Functional Group Composition during SEAVS; *Environ. Sci. Technol.* 1998, 32, 604-613.
7. Dick, W.D.; Ziemann, P.J.; Huang, P.E.; McMurry, P.H. Optical Shape Fraction Measurements of Submicrometer Laboratory and Atmospheric Aerosols; *Measura. Sci. Technol.* 1998, 9, 183-196.
8. Ames, R.B.; Hand, J.L.; Kreidenweis, S.M.; Day, D.E.; Malm, W.C. Optical Measurements of Aerosol Size Distributions in Great Smoky Mountains National Park: Dry Aerosol Characterization; *J. Air & Waste Manage. Assoc.* 2000, 50, 665-676.
9. Hand, J.L.; Ames, R.B.; Kreidenweis, S.M.; Day, D.E.; Malm, W.C. Estimates of Particle Hygroscopicity during the Southeastern Aerosol and Visibility Study; *J. Air & Waste Manage. Assoc.* 2000, 50, 677-685.
10. Malm, W.C.; Day, D.E.; Kreidenweis, S.M. Light Scattering Characteristics of Aerosols as a Function of Relative Humidity: Part I—A Comparison of Measured Scattering and Aerosol Concentrations Using the Theoretical Models; *J. Air & Waste Manage. Assoc.* 2000, 50, 686-700.
11. Malm, W.C.; Day, D.E.; Kreidenweis, S.M. Light Scattering Characteristics of Aerosols at Ambient and as a Function of Relative Humidity: Part II—A Comparison of Measured Scattering and Aerosol Concentrations Using Statistical Models; *J. Air & Waste Manage. Assoc.* 2000, 50, 701-709.
12. Henry, R.C.; Mahadev, S.; Urquito, S.; Chitwood, D. Color Perception through Atmospheric Haze; *J. Opt. Soc. Am., A. Optics, Imaging Sci. & Vision* 2000, 17, 831-835.
13. Henry, R.C.; Shibata, T.; Chitwood, D. Construction and Operation of a Video-Based Visual Colorimeter for Atmospheric Research; *Atmos. Environ.* 1994, 28A, 1065-1069.
14. Mahadev, S.; Henry, R.C. Application of a Color Appearance Model to Vision through Atmospheric Haze; *Color Resh. & Appl.* 1999, 24, 112-120.
15. Mahadev, S. Quantifying the Color Appearance of Objects Viewed through Atmospheric Haze. Ph.D. Dissertation, University of Southern California, Los Angeles, CA, 1998.
16. Henry, R.C. Psychophysics, Visibility, and Perceived Transparency; *Atmos. Environ.* 1987, 21, 159-164.
17. U.S. Environmental Protection Agency. *Draft Guidance for Tracking Progress under the Regional Haze Rule*; U.S. Environmental Protection Agency, Office of Air Quality Planning and Standards: Research Triangle Park, NC, September 27, 2001.

About the Author

Dr. Ronald C. Henry is professor of Civil and Environmental Engineering at the University of Southern California, Department of Civil and Environmental Engineering, 3620 South Vermont Ave., Los Angeles, CA 90089-2531; e-mail: rhenry@usc.edu.

Final Report

BART Analysis for Jim Bridger Unit 4

Prepared For:

PacifiCorp

1407 West North Temple
Salt Lake City, Utah 84116

January 12, 2007

Prepared By:

CH2MHILL

215 South State Street, Suite 1000
Salt Lake City, Utah 84111

Final Report



BART Analysis for Jim Bridger Unit 4

Prepared For:

PacifiCorp
1407 West North Temple
Salt Lake City, Utah 84116

January 12, 2007

Prepared By:

CH2MHILL
215 South State Street, Suite 1000
Salt Lake City, Utah 84111

Executive Summary

Background

In response to the Regional Haze Rule and Best Available Retrofit Technology (BART) regulations and guidelines, CH2M HILL was requested to perform a BART analysis for PacifiCorp's Jim Bridger Unit 4 (hereafter referred to as Jim Bridger 4). A BART analysis has been conducted for the following criteria pollutants: oxides of nitrogen (NO_x), sulfur dioxide (SO₂), and particulate matter less than 10 microns in aerodynamic diameter (PM₁₀). The Jim Bridger Station consists of four 530 megawatt (MW) units with a total generating capacity of 2,120 MW. Because the total generating capacity of the Jim Bridger Station exceeds 750 MW, presumptive BART limits apply to Jim Bridger 4, based on the United States Environmental Protection Agency's (EPA) guidelines. BART emissions limits must be achieved within five years after the State Implementation Plan (SIP) is approved by the EPA. A compliance date of 2014 was assumed for this analysis.

In completing the BART analysis, technology alternatives were investigated and potential reductions in NO_x, SO₂, and PM₁₀ emissions rates were identified. The following technology alternatives were investigated, listed below by pollutant:

NO_x emission controls:

- Low NO_x burners with over-fire air
- Rotating opposed fire air
- Low NO_x burners with selective non-catalytic reduction system (SNCR)
- Low NO_x burners with selective catalytic reduction (SCR) system

SO₂ emission controls:

- Optimize current operation of existing wet sodium flue gas desulfurization (FGD) system
- Upgrade wet sodium FGD system to achieve an SO₂ emission rate of 0.10 lb/MMBtu
- New dry FGD system

PM₁₀ emission controls:

- Sulfur trioxide (SO₃) injection flue gas conditioning system on existing electrostatic precipitator
- Polishing fabric filter

BART Engineering Analysis

The specific steps in a BART engineering analysis are identified in the Code of Federal Regulations (CFR) at 40 CFR 51 Appendix Y, Section IV. The evaluation must include:

1. The identification of available, technically feasible, retrofit control options

2. Consideration of any pollution control equipment in use at the source (which affects the availability of options and their impacts)
3. The costs of compliance with the control options
4. The remaining useful life of the facility
5. The energy and non-air quality environmental impacts of compliance
6. The degree of visibility improvement which may reasonably be anticipated from the use of BART

These steps are incorporated into the BART analysis as follows:

Step 1 – Identify All Available Retrofit Control Technologies

Step 2 – Eliminate Technically Infeasible Options

- The identification of available, technically feasible, retrofit control options
- Consideration of any pollution control equipment in use at the source (which affects the applicability of options and their impacts)

Step 3 – Evaluate Control Effectiveness of Remaining Control Technologies

Step 4 – Evaluate Impacts and Document the Results

- The costs of compliance with the control options
- The remaining useful life of the facility
- The energy and non-air quality environmental impacts of compliance

Step 5 – Evaluate Visibility Impacts

- The degree of visibility improvement which may reasonably be anticipated from the use of BART

Separate analyses have been conducted for NO_x, SO₂, and PM₁₀ emissions. All costs included in the BART analyses are in 2006 dollars, and costs have not been escalated to the assumed 2014 BART implementation date.

Coal Characteristics

The main source of coal burned at Jim Bridger 4 will be the Bridger Underground Mine. Secondary sources are the Bridger Surface Mine, the Bridger Highwall Mine, the Black Butte Mine, and the Leucite Hills Mine. These coals are ranked as subbituminous, but are closer in characteristics to bituminous coal in many of the parameters influencing NO_x formation. These coals have higher nitrogen content than coals from the Powder River Basin (PRB), which represent the bulk of subbituminous coal use in the U.S. This BART analysis has considered the higher nitrogen content and different combustion characteristics of PRB coals, as compared to those coals used at Jim Bridger 4, and has evaluated the effect of these qualities on NO_x formation and achievable emission rates.

Recommendations

NO_x Emission Control

The BART presumptive NO_x limit assigned by EPA for tangentially-fired boilers burning subbituminous coal is 0.15 lb/MMBtu. However, as documented in this analysis, the characteristics of the Jim Bridger coals are more closely aligned with bituminous coals, and have been assigned a presumptive BART NO_x limit of 0.28 lb/MMBtu.

CH2M HILL recommends low-NO_x burners with over-fire air (LNB w/OFA) as BART for Jim Bridger 4, based on the projected significant reduction in NO_x emissions, reasonable control costs, and the advantages of no additional power requirements or non-air quality environmental impacts. NO_x reductions are expected to be similar to those realized at Jim Bridger 2. CH2M HILL recommends that the unit be permitted at a rate of 0.26 lb/MMBtu.

SO₂ Emission Control

CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 4, based on the significant reduction in SO₂ emissions, reasonable control costs, and the advantages of minimal additional power requirements and minimal non-air quality environmental impacts. This upgrade approach will meet the BART presumptive SO₂ limit of 0.15 lb/MMBtu.

PM₁₀ Emission Control

CH2M HILL recommends finalizing the permitting of the flue gas conditioning system to enhance the performance of the existing electrostatic precipitator (ESP) as BART for Jim Bridger 4, based on the significant reduction in PM₁₀ emissions, reasonable control costs, and the advantages of minimal additional power requirements and no non-air quality environmental impacts.

Control Scenario 1

These BART selections, which include installing low NO_x burners with over-fire air, upgrading the existing FGD system, and operating the existing electrostatic precipitator with an SO₃ flue gas conditioning system, are identified as Scenario 1 throughout this report.

BART Modeling Analysis

CH2M HILL used the CALPUFF modeling system to assess the visibility impacts of emissions from Jim Bridger 4 at Class I areas. The Class I areas potentially affected are located more than 50 kilometers, but less than 300 kilometers, from the Jim Bridger Plant.

The Class I areas include the following wilderness areas (WA):

- Bridger WA
- Fitzpatrick WA
- Mt. Zirkel WA

Because Jim Bridger 4 will simultaneously control NO_x, SO₂, and PM₁₀ emissions, four post control atmospheric dispersion modeling scenarios were developed to cover the range of effectiveness for combining the individual NO_x, SO₂ and PM₁₀ control technologies under evaluation. These modeling scenarios, and the controls assumed, are as follows:

- **Scenario 1:** New LNB w/OFA modifications, upgraded wet FGD system, and flue gas conditioning for enhanced ESP performance. As indicated previously, this scenario represents CH2M HILL's preliminary BART recommendation.
- **Scenario 2:** New LNB w/OFA modifications, upgraded wet FGD system, and new polishing fabric filter.
- **Scenario 3:** New LNB w/OFA modifications and SCR, upgraded wet FGD system, and flue gas conditioning for enhanced ESP performance.
- **Scenario 4:** New LNB w/OFA modifications and SCR, upgraded wet FGD system, and new polishing fabric filter.

Visibility improvements for all emission control scenarios were analyzed, and the results were compared utilizing a Least-Cost Envelope, as outlined in the draft EPA 1990 New Source Review Workshop Manual (NSR Manual).

Least-Cost Envelope Analysis

EPA has adopted the Least-Cost Envelope Analysis Methodology as an accepted methodology for selecting the most reasonable, cost-effective controls. Incremental cost-effectiveness comparisons focus on annualized cost and emission reduction differences between dominant alternatives. The dominant set of control alternatives is determined by generating what is called the envelope of least-cost alternatives. This is a graphical plot of total annualized costs for a total emissions reductions for all control alternatives identified in the BART analysis.

To evaluate the impacts of the modeled control scenarios on the three Class 1 areas, the total annualized cost, cost per deciview (dV) reduction, and cost per reduction in number of days above 0.5 dV were analyzed. This report provides a comparison of the average incremental costs between relevant scenarios for the three Class 1 areas; the total annualized cost versus number of days above 0.5 dV, and the total annualized cost versus 98th percentile delta-deciview (Δ dV) reduction.

Results of the Least-Cost Envelope Analysis validate the selection of Scenario 1, based on incremental cost and visibility improvements. Scenario 2 (LNB w/OFA, upgraded wet FGD, and polishing fabric filter) is eliminated, because it is to the left of the curve formed by the "dominant" control alternative scenario, which indicates a scenario with lower improvement and/or higher costs. Scenario 3 (LNB w/OFA and SCR, upgraded wet FGD, and flue gas conditioning for enhanced ESP performance) is not selected due to very high incremental costs, on the basis of both a cost per day of improvement and cost per dV reduction. While Scenario 4 (LNB w/OFA and SCR, upgraded wet FGD, and polishing fabric filter) provides some potential visibility advantage over Scenario 1, the projected improvement is less than

half a dV, and the projected costs are excessive. Therefore, Scenario 1 represents BART for Jim Bridger 4.

Just-Noticeable Differences in Atmospheric Haze

Studies have been conducted that demonstrate only dV differences of approximately 1.5 to 2.0 dV or more are perceptible by the human eye. Deciview changes of less than 1.5 cannot be distinguished by the average person. Therefore, the modeling analysis results indicate that only minimal, if any, observable visibility improvements at the Class I areas studied would be expected under any of the control scenarios. Thus, the results indicate that only minimal discernable visibility improvements may result, even though PacifiCorp will be spending many millions of dollars at this single unit, and over a billion dollars when considering its entire fleet of coal-fired power plants.

Contents

Acronyms and Abbreviations	iv
1.0 Introduction.....	1-1
2.0 Present Unit Operation.....	2-1
3.0 BART Engineering Analysis	3-1
3.1 Applicability	3-1
3.2 BART Process.....	3-1
3.2.1 BART NO _x Analysis.....	3-2
3.2.2 BART SO ₂ Analysis	3-13
3.2.3 BART PM ₁₀ Analysis	3-15
4.0 BART Modeling Analysis.....	4-1
4.1 Model Selection	4-1
4.2 CALMET Methodology.....	4-1
4.2.1 Dimensions of the Modeling Domain.....	4-1
4.2.2 CALMET Input Data	4-3
4.2.3 Validation of CALMET Wind Field.....	4-6
4.3 CALPUFF Modeling Approach.....	4-6
4.3.1 Background Ozone and Ammonia.....	4-6
4.3.2 Stack Parameters.....	4-7
4.3.3 Emission Rates.....	4-7
4.3.4 Post Control Scenarios.....	4-7
4.3.5 Modeling Process.....	4-10
4.3.6 Receptor Grids	4-10
4.4 CALPOST.....	4-10
4.5 Presentation of Modeling Results	4-12
4.5.1 Degree of Visibility Change for Baseline vs. Preferred Scenario.....	4-12
5.0 Preliminary Assessment and Recommendations	5-1
5.1 Least-Cost Envelope Analysis	5-1
5.1.1 Analysis Methodology	5-1
5.1.2 Analysis Results.....	5-8
5.2 Recommendations.....	5-8
5.2.1 NO _x Emission Control	5-8
5.2.2 SO ₂ Emission Control.....	5-8
5.2.3 PM ₁₀ Emission Control.....	5-8
5.3 Just-Noticeable Differences in Atmospheric Haze.....	5-9
6.0 References	6-1

Tables

2-1	Unit Operation and Study Assumptions	2-1
2-2	Coal Sources and Characteristics.....	2-3
3-1	Coal Characteristics Comparison.....	3-4
3-2	NO _x Control Technology Projected Emission Rates	3-7
3-3	NO _x Control Cost Comparison	3-11
3-4	SO ₂ Control Technology Emission Rates	3-13
3-5	SO ₂ Control Cost Comparison (Incremental to Existing FGD System).....	3-15
3-6	PM ₁₀ Control Technology Emission Rates.....	3-16
3-7	PM ₁₀ Control Cost Comparison (Incremental to Existing ESP).....	3-17
4-1	User-Specified CALMET Options	4-3
4-2	BART Model Input Data	4-8
4-3	Average Natural Levels of Aerosol Components	4-11
4-4	Costs and Visibility Modeling Results for Baseline Vs. Post-Control Scenarios at Class I Areas.....	4-13
5-1	Control Scenario Results for the Bridger Class 1 Wilderness Area	5-2
5-2	Control Scenario Results for the Fitzpatrick Class 1 Wilderness Area	5-3
5-3	Control Scenario Results for the Mt. Zirkel Class 1 Wilderness Area	5-3
5-4	Bridger Class I Wilderness Area Incremental Analysis Data.....	5-4
5-5	Fitzpatrick Class I Wilderness Area Incremental Analysis Data.....	5-4
5-6	Mt. Zirkel Class I Wilderness Area Incremental Analysis Data.....	5-4

Figures

3-1	Illustration of the Effect of Agglomeration on the Speed of Coal Combustion.....	3-3
3-2	Plot of Typical Nitrogen Content of Various Coals and Applicable Presumptive BART NO _x Limits	3-5
3-3	Plot of Typical Oxygen Content of Various Coals and Applicable Presumptive BART NO _x Limits	3-5
3-4	First Year Control Cost for NO _x Air Pollution Control Options.....	3-12
3-5	First Year Control Cost for PM Air Pollution Control Options.....	3-19
4-1	Extent of Modeling Domain	4-2
4-2	Surface and Upper Air Station Locations	4-5
5-1	Least Cost Envelope Bridger Class I WA Days Reduction.....	5-5
5-2	Least Cost Envelope Bridger Class I WA 98 th Percentile Reduction	5-5
5-3	Least Cost Envelope Fitzpatrick Class I WA Days Reduction.....	5-6
5-4	Least Cost Envelope Fitzpatrick Class I WA 98 th Percentile Reduction.....	5-6
5-5	Least Cost Envelope Mt. Zirkel Class I WA Days Reduction.....	5-7
5-6	Least Cost Envelope Mt. Zirkel Class I WA 98 th Percentile Reduction.....	5-7

Appendices

A	Economic Analysis
B	2006 Wyoming BART Protocol
C	Just-Noticeable Differences in Atmospheric Haze - Ronald C. Henry Report

Acronyms and Abbreviations

BACT	Best Available Control Technology
BART	Best Available Retrofit Technology
CALDESK	Program to display data and results
CALMET	Meteorological data preprocessing program for CALPUFF
CALPOST	Post-processing program for calculating visibility impacts
CALPUFF	Gaussian puff dispersion model
COHPAC	Compact Hybrid Particulate Collector
dV	deciview
DEQ	Department of Environmental Quality
ESP	electrostatic precipitator
EPA	United States Environmental Protection Agency
Fuel NO _x	oxidation of fuel bound oxides of nitrogen
FGC	flue gas conditioning
FGD	flue gas desulfurization
<i>f</i> (RH)	relative humidity factors
ID	internal diameter
kW	kilowatts
kW-Hr	kilowatt-hour
LAER	lowest achievable emission rate
LNB	Low-NO _x burner
LOI	loss on ignition
MMBtu	Million British Thermal Units
MM5	Mesoscale Meteorological Model, Version 5
MW	megawatts
N ₂	nitrogen
NO	nitric oxide
NO _x	nitrogen oxides
NWS	National Weather Service
OFA	over fire air
PM ₁₀	particulate matter less than 10 microns in aerodynamic diameter
PRB	Powder River Basin
ROFA	Rotating Opposed Fire Air

S&L	Sargent & Lundy
SCR	selective catalytic reduction system
SIP	State Implementation Plan
SNCR	selective non-catalytic reduction system
SO ₂	sulfur dioxide
SO ₃	sulfur trioxide
Thermal NO _x	high temperature fixation of atmospheric nitrogen in combustion air
USGS	U.S. Geological Survey
WA	Wilderness Area
WDEQ-AQD	Wyoming Department of Environmental Quality – Air Quality Division

1.0 Introduction

Best Available Retrofit Technology (BART) guidelines were established as a result of United States Environmental Protection Agency (EPA) regulations intended to reduce the occurrence of regional haze in national parks and other Class I protected air quality areas in the United States¹. These guidelines provide guidance for states when determining which facilities must install additional controls, and the type of controls that must be used. Facilities eligible for BART installation were built between 1962 and 1977, and have the potential to emit more than 250 tons/year of visibility-impairing pollutants.

The Wyoming Department of Environmental Quality (DEQ) BART regulations state that each source subject to BART must submit a BART application for a construction permit by December 15, 2006. PacifiCorp received an extension from the Wyoming DEQ to submit the BART report for Jim Bridger Unit 4 by January 12, 2007. This report to the Wyoming DEQ must include a BART analysis, and a proposal and justification for BART at the source.

The State of Wyoming has identified those eligible in-state facilities that are required to reduce emissions under BART, and will set BART emissions limits for those facilities. This information will be included in the State of Wyoming State Implementation Plan (SIP), which the State has estimated will be formally submitted to the EPA by early 2008. The EPA BART guidelines also state that the BART emission limits must be fully implemented within five years of EPA's approval of the SIP.

There are five basic elements related to BART, when addressing the issue of emissions for the identified facilities:

- Any existing pollution control technology in use at the source
- The cost of the controls
- The remaining useful life of the source
- The energy and non-air environmental impacts of compliance
- The degree of improvement in visibility which may reasonably be anticipated from the use of such technology

This report documents the BART analysis that was performed on Jim Bridger 4 by CH2M HILL for PacifiCorp. The analysis was performed for the pollutants NO_x, SO₂, and particulate matter less than 10 microns in aerodynamic diameter (PM₁₀), because they are the primary criteria pollutants that affect visibility.

Section 2.0 of this report provides a description of the present unit operation, including a discussion of coal sources and characteristics. The BART Engineering Analysis is provided in Section 3.0, by pollutant type. Section 4.0 provides the methodology and results of the BART Modeling Analysis, followed by recommendations in Section 5.0. References are

¹ 40 CFR Part 51: Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations; Final Rule. 70 Federal Register, 39103-39172, July 6, 2005.

provided in Section 6.0. Appendices provide more detail on the Economic Analysis, the 2006 Wyoming BART Protocol, and a paper by Dr. Ronald Henry, titled, *Just Noticeable Differences in Atmospheric Haze*.

2.0 Present Unit Operation

The Jim Bridger Station consists of four units with a total generating capacity of 2,120 megawatts (MW). Jim Bridger 4 is a nominal 530 net MW unit located approximately 35 miles northeast of Rock Springs, Wyoming. Unit 4 is equipped with a tangentially fired pulverized coal boiler with low NO_x burners manufactured by Combustion Engineering. The unit was constructed with a Flakt wire frame electrostatic precipitator (ESP). The unit contains a Babcock & Wilcox wet sodium flue gas desulfurization (FGD) system with three absorber towers installed in 1982. An Emerson Ovation distributed control system (DCS) was installed in 2004.

Jim Bridger 4 was placed in service in 1979. Its current economic depreciation life is through 2040; however, this analysis is based on a 20 year life for BART control technologies. Assuming a BART implementation date of 2014, this will result in an approximate remaining useful life for Jim Bridger 4 of 20 years from the installation date of any new or modified BART-related equipment. This report does not attempt to quantify any additional life extension costs needed to allow the unit and these control devices at Jim Bridger 4 to operate until 2040.

Table 2-1 lists additional unit information and study assumptions for this analysis.

TABLE 2-1
Unit Operation and Study Assumptions
Jim Bridger 4

General Plant Data	
Site Elevation feet above MSL	6669
Stack Height feet	500
Stack Exit ID feet /Exit Area sq. ft.	31 /755
Stack Exit Temperature °F	120
Stack Exit Velocity ft/sec	42.4
Stack Flow ACFM	1,920,610
Latitude deg: min : sec	41:44:20.82 north
Longitude deg: min : sec	108:47:15.17 west
Annual Unit Capacity Factor (%)	90
Net Unit Output (MW)	530
Net Unit Heat Rate (Btu/kW-Hr)(100% load)	10,400 (as measured by fuel throughput)
Boiler Heat Input (MMBtu/Hr)(100% load)	6,000 (as measured by CEM)
Type of Boiler	Tangentially fired
Boiler Fuel	Coal
Coal Sources	Bridger Mine, Black Butte Mine, Leucite Hills Mine
Coal Heating Value (Btu/lb)*	9,660
Coal Sulfur Content (wt. %)*	0.58

TABLE 2-1
Unit Operation and Study Assumptions
Jim Bridger 4

Coal Ash Content (wt. %)*	10.3
Coal Moisture Content (wt. %)*	19.3
Coal Nitrogen Content (wt. %)*	0.98
Current NO _x Controls	Low NO _x burners
NO _x Emission Rate (lb/MMBtu)	0.45
Current SO ₂ Controls	Sodium based wet scrubber
SO ₂ Emission Rate (lb/MMBtu)	0.2
Current PM ₁₀ Controls	Electrostatic Precipitator
PM ₁₀ Emission Rate (lb/MMBtu)**	0.030

* Coal characteristics based on Bridger Underground Mine (primary coal source)

** Based on maximum historic emission rate from 1999 – 2001, prior to installation of the SO₃ injection system.

The BART presumptive NO_x limit for tangential-fired boilers burning subbituminous coal is 0.15 lb/MMBtu and the BART presumptive NO_x limit for burning bituminous coal is 0.28 lb/MMBtu. The main sources of coal burned at Jim Bridger 4 are the Bridger Mine and secondarily the Black Butte Mine and Leucite Hills Mine. These coals are ranked as subbituminous, but are closer in characteristics to bituminous coal in many of the parameters influencing NO_x formation. These coals have higher nitrogen content than coals from the Powder River Basin (PRB), which represent the bulk of subbituminous coal use in the U.S. This BART analysis has considered the higher nitrogen content and different combustion characteristics of PRB coals, as compared to those coals used at Jim Bridger 4, and has evaluated the effect of these qualities on NO_x formation and achievable emission rates. Coal sources and characteristics are summarized in Table 2-2. The primary source of coal will be the Bridger Underground Mine, and data on coal from this source were used in the modeling analysis. For the coal analysis that is presented in Section 3.2.1, the data from all the coal sources were used.

TABLE 2-2
Coal Sources and Characteristics
Jim Bridger 4

Mines	Ultimate Analysis (% dry basis)												
	Moist. %	Ash %	Volatile Matter %	Fixed Carbon %	Btu/lb	Sulfur %	MAF (Btu/lb)	Hydrogen	Carbon	Sulfur	Nitrogen	Oxygen	Ash
Bridger Mine Underground	19.3	10.3	32.2	38.3	9660	0.58	13712	4.66	69.2	0.72	1.22	11.8	12.4
Max	Not enough data yet to run statistical analysis for variability												
Min	Not enough data yet to run statistical analysis for variability												
Bridger Mine Surface	19.1	10.6	32.3	38.0	9390	0.57	13340	4.38	37.4	0.71	1.26	13.2	13.0
Max	20.5	12.5	35.5	41.9	9800	0.72	13500	4.69	4.0	0.90	1.43	14.8	15.8
Min	17.5	9.0	31.0	36.0	9000	0.49	13100	4.00	64.3	0.60	1.14	11.7	11.2
Bridger Mine Highwall	18.0	9.5	33.0	39.5	9700	0.68	13500		No samples of separate highwall coal				
Max	Not enough data yet to run statistical analysis for variability												
Min	Not enough data yet to run statistical analysis for variability												
Black Butte Mine	20.0	9.2	33.3	35.6	9450	0.45	13330	4.43	68.7	0.56	1.47	13.4	11.5
Max	21.1	10.8	35.4	41.9	10275	0.62	13500	4.66	70.5	0.78	1.69	14.8	13.6
Min	18.0	7.6	29.9	36.8	9180	0.33	13140	4.21	66.1	0.41	1.25	11.6	9.7
Leucite Hills Mine (through 2009)	19.4	11.5	30.7	38.3	9080	0.64	13140	4.20	66.0	0.81	1.48	13.2	14.4
Max	23.0	15.0	33.0	43.0	10250	0.90	13800	4.70	70.0	1.20	1.64	17.1	19.0
Min	17.0	8.0	28.3	33.6	8000	0.40	12300	3.70	61.0	0.50	1.32	10.5	10.0

3.0 BART Engineering Analysis

This section presents the required BART engineering analysis.

3.1 Applicability

In compliance with regional haze requirements, the State of Wyoming must prepare and submit visibility SIPs to the EPA for Class I areas. The State has estimated that the formal submittal of the SIPs will occur by early 2008. The first phase of the regional haze program is the implementation of BART emission controls on all BART eligible units, within five years after EPA approval of the SIP.

3.2 BART Process

The specific steps in a BART engineering analysis are identified in the Code of Federal Regulations (CFR) at 40 CFR 51 Appendix Y, Section IV. The evaluation must include:

1. The identification of available, technically feasible, retrofit control options
2. Consideration of any pollution control equipment in use at the source (which affects the availability of options and their impacts)
3. The costs of compliance with the control options
4. The remaining useful life of the facility
5. The energy and non-air quality environmental impacts of compliance, and
6. The degree of visibility improvement which may reasonably be anticipated from the use of BART

These steps are incorporated into the BART analysis as follows:

Step 1 – Identify All Available Retrofit Control Technologies

Step 2 – Eliminate Technically Infeasible Options

- The identification of available, technically feasible, retrofit control options
- Consideration of any pollution control equipment in use at the source (which affects the applicability of options and their impacts)

Step 3 – Evaluate Control Effectiveness of Remaining Control Technologies

Step 4 – Evaluate Impacts and Document the Results

- The costs of compliance with the control options
- The remaining useful life of the facility
- The energy and non-air quality environmental impacts of compliance

Step 5 – Evaluate Visibility Impacts

- The degree of visibility improvement which may reasonably be anticipated from the use of BART

In order to minimize costs in the BART analysis, consideration was made of any pollution control equipment in use at the source, the costs of compliance associated with the control options, and the energy and non-air quality environmental impacts of compliance using these existing control devices. In some cases, enhancing the performance of the existing control equipment was considered. Other scenarios with new control equipment were also developed.

All costs included in the BART analysis are in 2006 dollars (not escalated to 2014 BART implementation date).

3.2.1 BART NO_x Analysis

NO_x formation in coal-fired boilers is a complex process that is dependent on a number of variables, including operating conditions, equipment design, and coal characteristics.

3.2.1.1 Formation of NO_x

During coal combustion, NO_x is formed in three different ways. The dominant source of NO_x formation is the oxidation of fuel-bound nitrogen (fuel NO_x). During combustion, part of the fuel-bound nitrogen is released from the coal with the volatile matter, and part is retained in the solid portion (char). The nitrogen chemically bound in the coal is partially oxidized to nitrogen oxides (NO and NO₂) and partially reduced to molecular nitrogen (N₂). A smaller part of NO_x formation is due to high temperature fixation of atmospheric nitrogen in the combustion air (thermal NO_x). A very small amount of NO_x is called “prompt” NO_x. Prompt NO_x results from an interaction of hydrocarbon radicals, nitrogen, and oxygen.

In a conventional pulverized coal burner, air is introduced with turbulence to promote good mixing of fuel and air, which provides stable combustion. However, not all of the oxygen in the air is used for combustion. Some of the oxygen combines with the fuel nitrogen to form NO_x.

Coal characteristics directly and significantly affect NO_x emissions from coal combustion. Coal ranking is a means of classifying coals according to their degree of metamorphism in the natural series, from lignite to subbituminous to bituminous and on to anthracite. Lower rank coals, such as the subbituminous coals from the PRB, produce lower NO_x emissions than higher rank bituminous coals, due to their higher reactivity and lower nitrogen content. The fixed carbon to volatile matter ratio (fuel ratio), coal oxygen content, and rank are good relative indices of the reactivity of a coal. Lower rank coals release more organically bound nitrogen earlier in the combustion process than do higher rank bituminous coals. When used with low NO_x burners, subbituminous coals create a longer time for the kinetics to promote more stable molecular nitrogen, and hence result in lower NO_x emissions.

Coals from the PRB are classified as subbituminous C and demonstrate the high reactivity and low NO_x production characteristics described above. Based on data from the Energy Information Administration (EIA), PRB coals currently represent 88 percent of total U.S. subbituminous production and 73 percent of western coal production. Most references to “western” coal and subbituminous coal infer PRB origin and characteristics. Emissions standards differentiating between bituminous and subbituminous coals are presumed to use

PRB coal as the basis for the subbituminous standards, due to their dominant market presence and unique characteristics.

There are a number of western coals that are classified as subbituminous, however, they border on being ranked as bituminous and do not display many of the qualities of PRB coals, including most of the low NO_x forming characteristics. Coals from the Bridger, Black Butte, and Leucite Hills mines fall into this category.

As defined by the American Society for Testing and Materials, the only distinguishing characteristic that classifies the coals used at Jim Bridger 4 as subbituminous rather than bituminous – that is, they are “agglomerating” as compared to “non-agglomerating”. Agglomerating as applied to coal is “the property of softening when it is heated to above about 400° C in a non-oxidizing atmosphere, and then appearing as a coherent mass after cooling to room temperature.” Because the agglomerating property of coals is the result of particles transforming into a plastic or semi-liquid state when heated, it reflects a change in surface area of the particle. Thus, with the application of heat, agglomerating coals would tend to develop a non-porous surface, while the surface of non-agglomerating coals would become even more porous with combustion. As shown by Figure 3-1, the increased porosity provides more particle surface area, resulting in more favorable combustion conditions. This non-agglomerating property assists in making subbituminous coals more amenable to controlling NO_x, by allowing less air to be introduced during the initial ignition portion of the combustion process. The coals from the Bridger, Black Butte and Leucite Hills mines just barely fall into the category of non-agglomerating coals. While each of these coals is considered non-agglomerating, they either do not exhibit those properties of non-agglomerating coals or exhibit them to only a minor degree. The conditions during combustion of typical non-agglomerating coals that make it easier to control NO_x emissions do not exist for the Bridger blends of coals.

FIGURE 3-1
Illustration of the Effect of Agglomeration on the Speed of Coal Combustion
Jim Bridger 4




Table 3-1 shows key characteristics of a typical PRB coal compared to coals from the Bridger Mine, Black Butte, and Leucite Hills, as well as Twentymile, which is a representative western bituminous coal.

TABLE 3-1
Coal Characteristics Comparison
Jim Bridger 4

Parameter	Typical PRB	Bridger Mine	Black Butte	Leucite Hills	Twentymile
Nitrogen (% dry)	1.10	1.26	1.47	1.48	1.85
Oxygen (% dry)	16.2	13.2	13.4	13.2	7.19
Coal rank	Sub C	Sub B	Sub B	Sub B	Bitum. high volatility B

As shown in Table 3-1, although Bridger, Black Butte, and Leucite Hills are classified as subbituminous, they all exhibit higher nitrogen content and lower oxygen content than the PRB coal. The higher nitrogen content is an indication that more nitrogen is available to the combustion process and higher NO_x emissions are likely. Oxygen content can be correlated to the reactivity of the coal, with more reactive coals generally containing higher levels of oxygen. More reactive coals tend to produce lower NO_x emissions, and they are also more conducive to reduction of NO_x emissions through the use of combustion control measures, such as low NO_x burners and over-fire air (OFA). These characteristics indicate that higher NO_x formation is likely with coal from the Bridger, Black Butte, and Leucite Hills mines, rather than with PRB coal. The Bridger, Black Butte, and Leucite Hills coals all contain quality characteristics that fall between a typical PRB coal and Twentymile. Twentymile is a clearly bituminous coal that produces higher NO_x, as has been demonstrated at power plants burning this fuel.

Figures 3-2 and 3-3 graphically illustrate the relationship of nitrogen and oxygen content to the BART presumptive NO_x limits for the coals listed in Table 3-1. Each chart identifies the presumptive BART limit associated with a typical bituminous and subbituminous coal, and demonstrates how the Jim Bridger coal falls between these two general coal classifications.

The Bridger blend data point represents a combination of coals from the Bridger Mine, Black Butte, and Leucite Hills that has been used at Jim Bridger 4, and indicates the average NO_x emission rate achieved during the years 2003-2005. The Jim Bridger 2 data point consists of the same blend of coals as Jim Bridger 4, and represents the NO_x emission rate achieved after installation of Alstom's current state of the art TFS2000 LNB and OFA system. The long-term sustainable emission rate for this system is expected to be 0.24 lb/MMBtu. All four units at Jim Bridger consist of identical boilers; while there may be some differences in performance among them, installation of the TFS2000 firing system at Jim Bridger 4 would likely result in performance and NO_x emission rates comparable to those at Jim Bridger 2.

Figures 3-2 and 3-3 both demonstrate that for the Jim Bridger units with the TFS2000 low NO_x emission system installed and burning a combination of the Bridger, Black Butte, and Leucite Hill coals, the likely NO_x emission rate will be closer to the bituminous end (0.28) of the BART presumptive NO_x limit range, rather than the BART presumptive NO_x limit of

0.15 lb/MMBtu for subbituminous coal. All these factors are consistent with the observed sustainable rate of 0.24 lb/MMBtu.

FIGURE 3-2
Plot of Typical Nitrogen Content of Various Coals and Applicable Presumptive BART NO_x Limits
Jim Bridger 4





FIGURE 3-3
Plot of Typical Oxygen Content of Various Coals and Applicable Presumptive BART NO_x Limits
Jim Bridger 4



Coal quality characteristics also impact the design and operation of the boiler and associated auxiliary equipment. Minor changes in quality can sometimes be accommodated through operational adjustments or changes to equipment. It is important to note, however, that consistent variations in quality or assumptions of "average" quality for performance projections can be problematic. This is particularly troublesome when dealing with performance issues that are very sensitive to both coal quality and combustion conditions, such as NO_x formation. There is significant variability in the quality of coals burned at Jim Bridger 4. In addition to burning coal from Black Butte and Leucite Hills, Jim Bridger 4 burns coal supplied from the Bridger Mine consisting of three sources: underground, surface, and highwall operations. Each of these coal sources has different quality characteristics, as well as inherent variability in composition of the coal within the mine.

Several of the coal quality characteristics and their effect on NO_x formation have been previously discussed. There are some additional considerations that illustrate the complexity of achieving and maintaining consistent low NO_x emissions with pulverized coal on a shorter term, such as a 30-day rolling average basis.

Good combustion is based on the "three Ts": time, temperature, and turbulence. These parameters, along with a "design" coal, are taken into consideration when designing a boiler and associated firing equipment such as fans, burners, and pulverizers. If a performance requirement such as NO_x emission limits is subsequently changed, conflicts with and between other performance issues can result.

Jim Bridger 4 is located at an altitude of 6,669 feet above sea level. At this elevation, atmospheric pressure is lower (11.5 pounds per square inch) as compared with sea level pressure of 14.7 pounds per square inch. This lower pressure means that less oxygen is available for combustion for each volume of air. In order to provide adequate oxygen to meet the requirements for efficient combustion, larger volumes of air are required. When adjusting air flows and distribution to reduce NO_x emissions, using low NO_x burners and overfire air, original boiler design restrictions again limit the modifications that can be made and still achieve satisfactory combustion performance.

Another significant factor in controlling NO_x emissions is the fineness of the coal entering the burners. Fineness is influenced by the grindability index (Hardgrove) of the coal. Finer coal particles promote release of volatiles and assist char burnout due to more surface area exposed to air. NO_x reduction with high volatile coals is improved with greater fineness and with proper air staging. The lower rank subbituminous coals such as PRB coals are quite friable and easy to grind. Coals with lower Hardgrove Grindability Index values, such as those used at Jim Bridger 4, are more difficult to grind and can contribute to higher NO_x levels. In addition, coal fineness can deteriorate over time periods between pulverizer maintenance and service as pulverizer grinding surfaces wear.

In summary, when all the factors of agglomeration versus non-agglomeration, nitrogen and oxygen content of the coals, and the grindability index are taken into account, this analysis demonstrates that, for the coal used at Jim Bridger 4, the more applicable presumptive BART limit for NO_x emissions is 0.28 lb/MMBtu. The BART analysis for NO_x emissions from Jim Bridger 4 is further described below.

3.2.1.2 Step 1: Identify All Available Retrofit Control Technologies

The first step of the BART process is to evaluate NO_x control technologies with practical potential for application to Jim Bridger 4, including those control technologies identified as Best Available Control Technology (BACT) or lowest achievable emission rate (LAER) by permitting agencies across the United States. Broad-ranging information sources were reviewed in an effort to identify potentially applicable emission control technologies. NO_x emissions at Jim Bridger 4 are currently controlled through good combustion practices and OFA.

The following potential NO_x control technology options were considered:

- New/modified low-NO_x burners (LNB) with advanced OFA
- Rotating opposed fire air (ROFA)
- LNB with OFA and conventional selective non-catalytic reduction system (SNCR)
- LNB with OFA and selective catalytic reduction system (SCR)

3.2.1.3 Step 2: Eliminate Technically Infeasible Options

For Jim Bridger 4, a tangential-fired configuration burning subbituminous coal, technical feasibility will primarily be determined by physical constraints, boiler configuration, and the ability to achieve the regulatory presumptive limit (used as a guide) of 0.28 lb NO_x/MMBtu. Jim Bridger 4 has an uncontrolled NO_x emission rate of 0.45 lb/MMBtu.

For this BART analysis, information pertaining to LNBS, OFA, SNCR, and SCR were based on the Multi-Pollutant Control Report dated October, 2002 (S&L Study). The cost estimates for SCR and SNCR were updated by Sargent & Lundy (S&L) in October 2006. PacifiCorp provided additional emissions data and costs developed by boiler vendors for LNBS and OFA. Also, CH2M HILL solicited a proposal from Mobotec for their ROFA technology.

With SNCR, an amine-based reagent such as ammonia, or more commonly urea, is injected into the furnace within a temperature range of 1,600° F to 2,100° F, where it reduces NO_x to nitrogen and water. NO_x reductions of up to 40 to 60 percent have been achieved, although 15 to 30 percent is more realistic for most applications. SNCR is typically applied on smaller units. Adequate reagent distribution in the furnaces of large units can be problematic.

Table 3-2 summarizes the control technology options evaluated in this BART analysis, along with projected NO_x emission rates. All technologies can meet the applicable presumptive BART limit of 0.28 lb/MMBTU.

TABLE 3-2
NO_x Control Technology Projected Emission Rates
Jim Bridger 4

Technology	Projected Emission Rate (lb/MMBtu)
Presumptive BART Limit	0.28
LNB w/OFA	0.24
ROFA	0.22
LNB w/OFA & SNCR	0.20
LNB w/OFA & SCR	0.07

3.2.1.4 Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

Preliminary vendor proposals, such as those used to support portions of this BART analysis, may be technically feasible and provide expected or guaranteed emission rates; however, they include inherent uncertainties. These proposals are usually prepared in a limited time frame, may be based on incomplete information, may contain over-optimistic conclusions, and are non-binding. Therefore, emission rate values obtained in such preliminary proposals must be qualified, and it must be recognized that contractual guarantees are established only after more detailed analysis has been completed. The following subsections describe the control technologies and the control effectiveness evaluated in this BART analysis.

New LNBS with OFA System. The mechanism used to lower NO_x with low NO_x burners is to stage the combustion process and provide a fuel rich condition initially; this so oxygen needed for combustion is not diverted to combine with nitrogen and form NO_x . Fuel-rich conditions favor the conversion of fuel nitrogen to N_2 instead of NO_x . Additional air (or OFA) is then introduced downstream in a lower temperature zone to burn out the char.

Both LNBS and OFA are considered to be a capital cost, combustion technology retrofit. For LNB retrofits to units configured with tangential-firing such as Jim Bridger 4, it is generally necessary to increase the burner spacing; this prevents interaction of the flames from adjacent burners and reduces burner zone heat flux. These modifications usually require boiler waterwall tube replacement.

Information provided to CH2M HILL by PacifiCorp – based on the S&L Study and data from boiler vendors – indicates that new LNB and OFA retrofit at Jim Bridger 4 would result in an expected NO_x emission rate of 0.24 lb/MMBtu. PacifiCorp has indicated that this rate corresponds to a vendor guarantee, not a vendor prediction, and they believe that this emission rate can be sustained as an average between overhauls. This emission rate represents a significant reduction from the current NO_x emission rate, and is below the more applicable presumptive NO_x emission rate of 0.28 lb/MMBtu.

ROFA. Mobotec markets ROFA as an improved second generation OFA system. Mobotec states that “the flue gas volume of the furnace is set in rotation by asymmetrically placed air nozzles. Rotation is reported to prevent laminar flow, so that the entire volume of the furnace can be used more effectively for the combustion process. In addition, the swirling action reduces the maximum temperature of the flames and increases heat absorption. The combustion air is also mixed more effectively”. A typical ROFA installation would have a booster fan(s) to supply the high velocity air to the ROFA boxes, and Mobotec would propose two 4,000 to 4,300 Hp fans for Jim Bridger 4.

Mobotec proposes to achieve a NO_x emission rate of 0.18 lb/MMBtu using ROFA technology. An operating margin of 0.04 lb/MMBtu was added to the expected rate due to Mobotec’s limited ROFA experience with western subbituminous coals. Under the Mobotec proposal, which is primarily based on ROFA equipment, the operation of existing LNB and OFA ports would be analyzed. While a typical installation does not require modification to the existing LNB system and the existing OFA ports are not used, results of computational fluid dynamics modeling would determine the quantity and location of new ROFA ports. The Mobotec proposal includes bent tube assemblies for OFA port installation.

Mobotec would not provide installation services, because they believe that the Owner can more cost effectively contract for these services. However, they would provide one onsite construction supervisor during installation and startup.

SNCR. Selective non-catalytic reduction is generally utilized to achieve modest NO_x reductions on smaller units. With SNCR, an amine-based reagent such as ammonia – or more commonly urea – is injected into the furnace within a temperature range of 1,600°F to 2,100°F, where it reduces NO_x to nitrogen and water. NO_x reductions of up to 60 percent have been achieved, although 20 to 40 percent is more realistic for most applications.

Reagent utilization, which is a measure of the efficiency with which the reagent reduces NO_x, can range from 20 to 60 percent, depending on the amount of reduction, unit size, operating conditions, and allowable ammonia slip. With low reagent utilization, low temperatures, or inadequate mixing, ammonia slip occurs, allowing unreacted ammonia to create problems downstream. The ammonia may render fly ash unsaleable, react with sulfur to foul heat exchange surfaces, and/or create a visible stack plume. Reagent utilization can have a significant impact on economics, with higher levels of NO_x reduction generally resulting in lower reagent utilization and higher operating cost.

Reductions from higher baseline concentrations (inlet NO_x) are lower in cost per ton, but result in higher operating costs, due to greater reagent consumption. To reduce reagent costs, S&L has assumed that combustion modifications including LNBs and advanced OFA, capable of achieving a projected NO_x emission rate of 0.24 lb/MMBtu. At a further reduction of 15 percent in NO_x emission rates for SNCR would result in a projected emission rate of 0.20 lb/MMBtu.

SCR. SCR works on the same chemical principle as SNCR, but SCR uses a catalyst to promote the chemical reaction. Ammonia is injected into the flue-gas stream, where it reduces NO_x to nitrogen and water. Unlike the high temperatures required for SNCR, in SCR the reaction takes place on the surface of a vanadium/titanium-based catalyst at a temperature range between 580° F to 750° F. Due to the catalyst, the SCR process is more efficient than SNCR and results in lower NO_x emissions. The most common type of SCR is the high-dust configuration, where the catalyst is located downstream from the boiler economizer and upstream of the air heater and any particulate control equipment. In this location, the SCR is exposed to the full concentration of fly ash in the flue gas that is leaving the boiler. The high-dust configuration is assumed for Jim Bridger 4. In a full-scale SCR, the flue ducts are routed to a separate large reactor containing the catalyst. With in-duct SCR, the catalyst is located in the existing gas duct, which may be expanded in the area of the catalyst to reduce flue gas flow velocity and increase flue gas residence time. Due to the higher removal rate, a full-scale SCR was used as the basis for analysis at Jim Bridger 4.

S&L prepared the design conditions and cost estimates for SCR at Jim Bridger 4. As with SNCR, it is generally more cost effective to reduce NO_x emission levels as much as possible through combustion modifications, in order to minimize the catalyst surface area and ammonia requirements of the SCR. The S&L design basis for LNB w/OFA and SCR results in a projected NO_x emission rate of 0.07 lb/MMBtu. Additional catalyst surface was included in the SCR design to accommodate the characteristics of the coal used at Jim Bridger 4.

Level of Confidence for Vendor Post-Control Emissions Estimates. In order to determine the level of NO_x emissions needed to consistently achieve compliance with an established goal, a review of typical NO_x emissions from coal-fired generating units was completed. As a result of this review, it was noted that NO_x emissions can vary significantly around an average emissions level. Variations may result for many reasons, including coal characteristics, unit load, boiler operation including excess air, boiler slagging, burner equipment condition, coal mill fineness, and so forth.

The steps utilized for determining a level of confidence for the vendor expected values are as follows:

1. Establish expected NO_x emissions value from vendor.
2. Evaluate vendor experience and historical basis for meeting expected values.
3. Review and evaluate unit physical and operational characteristics and restrictions. The fewer variations there are in operations, coal supply, etc., the more predictable and less variant the NO_x emissions are.
4. For each technology expected value, there is a corresponding potential for actual NO_x emissions to vary from this expected value. From the vendor information presented, along with anticipated unit operational data, an adjustment to the expected value can be made.

3.2.1.5 Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

Energy Impacts. Installation of LNBs and modification to the existing OFA systems are not expected to significantly impact the boiler efficiency or forced draft fan power usage. Therefore, these technologies will not have energy impacts.

The Mobotec ROFA system would require installation and operation of two 4,000 to 4,300 Hp ROFA fans (6,410 kW total). The SNCR system would require approximately 530 kW of additional power.

SCR retrofit impacts the existing flue gas fan systems, due to the additional pressure drop associated with the catalyst, which is typically a 6- to 8-inch water gage increase. Total additional power requirements for SCR installation at Jim Bridger 4 are estimated at approximately 3,360 kW, based on the S&L Study.

Environmental Impacts. Mobotec has predicted that CO emissions, and unburned carbon in the ash, commonly referred to as LOI (loss on ignition), would be the same or lower than prior levels for the ROFA system.

SNCR and SCR installation could impact the salability and disposal of fly ash due to ammonia levels, and could potentially create a visible stack plume, which may negate other visibility improvements. Other environmental impacts involve the storage of ammonia, especially if anhydrous ammonia is used, and the transportation of the ammonia to the power plant site.

Economic Impacts. Costs and schedules for the LNBs and OFA, SNCR, and SCR were furnished to CH2M HILL by PacifiCorp, developed using S&L's internal proprietary database, and supplemented (as needed) by vendor-obtained price quotes. The relative accuracy of these cost estimates is stated by S&L to be in the range of ± 20 percent. Cost for the ROFA system was obtained from Mobotec.

A comparison of the technologies on the basis of costs, design control efficiencies, and tons of NO_x removed is summarized in Table 3-3, and the first year control costs are presented in Figure 3-4. The complete Economic Analysis is contained in Appendix A.

TABLE 3-3
NO_x Control Cost Comparison
Jim Bridger 4


Factor	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR
Total Installed Capital Costs	\$8.7 Million	\$20.5 Million	22.1 Million	\$147.6 Million
Total First Year Fixed & Variable O&M Costs	\$0.1 Million	\$2.6 Million	\$1.5 Million	\$3.4 Million
Total First Year Annualized Cost	\$0.9 Million	\$4.6 Million	\$3.6 Million	\$17.4 Million
Power Consumption (MW)	0	6.4	0.5	3.4
Annual Power Usage (1000 MW-Hr/Yr)	0	50.6	4.2	26.5
NO _x Design Control Efficiency	46.7%	51.1%	55.6%	84.4%
NO _x Removed per Year (Tons)	4,967	5,440	5,913	8,987
First Year Average Control Cost (\$/Ton of NO _x Removed)	\$181/ton	\$843/ton	\$613/ton	\$1,936/ton
Incremental Control Cost (\$/Ton of NO _x Removed)	\$181/ton	\$7,797/ton	\$2,885/ton	\$4,479/ton

Preliminary BART Selection. CH2M HILL recommends selection of low-NO_x burners with OFA as BART for Jim Bridger 4 based on its significant reduction in NO_x emissions, reasonable control cost, and no additional power requirements or environmental impacts. LNB w/OFA does not meet the EPA presumptive limit of 0.15 lb/MMBtu for subbituminous coal, but it does meet an emission rate that falls between the presumptive limit of 0.28 lb/MMBtu for bituminous coal and the limit of 0.15 lb/MMBtu for subbituminous coal. As discussed in the section on coal quality, the recommended technology and the achieved emission rate are deemed appropriate as BART for NO_x emissions from the coals combusted at Jim Bridger 4.

3.2.1.6 Step 5: Evaluate Visibility Impacts

Please see Section 4.0, BART Modeling Analysis.

FIGURE 3-4
 First Year Control Cost for NO_x Air Pollution Control Options
 Jim Bridger 4



3.2.2 BART SO₂ Analysis

SO₂ forms in the boiler during the combustion process, and is primarily dependent on coal sulfur content. The BART analysis for SO₂ emissions on Jim Bridger 4 is described below.

3.2.2.1 Step 1: Identify All Available Retrofit Control Technologies

A broad range of information sources were reviewed, in an effort to identify potentially applicable emission control technologies for SO₂ at Jim Bridger 4. This included control technologies identified as BACT or LAER by permitting agencies across the United States.

The following potential SO₂ control technology options were considered:

- Optimize current operation of existing wet sodium FGD system
- Upgrade wet sodium FGD system to meet SO₂ emission rate of 0.10 lb/MMBtu
- New dry FGD system

3.2.2.2 Step 2: Eliminate Technically Infeasible Options

Technical feasibility will primarily be based on the regulatory presumptive limit (used as a guideline) of 95 percent reduction in SO₂ emissions, or 0.15 lb/MMBtu. Based on the coal that Jim Bridger 4 currently burns, the unit would be required to achieve an 87.5 percent SO₂ removal efficiency to meet the presumptive limit of 0.15 lb/MMBtu.

Table 3-4 summarizes the control technology options evaluated in this BART analysis, along with projected SO₂ emission rates. Only one technology option can meet the applicable presumptive BART limit of 0.15 lb/MMB.

TABLE 3-4
SO₂ Control Technology Emission Rates
Jim Bridger 4

Technology	Projected Emission Rate (lb/MMBtu)
Presumptive BART Limit	0.15
Upgrade Existing Wet Sodium System	0.10
Optimize Existing Wet Sodium System	0.17
New Dry FGD System	0.21

Wet Sodium FGD System Wet sodium FGD systems operate by treating the flue gas in large scrubber vessels with a soda ash solution. The scrubber mixes the flue gas and alkaline reagent using a series of spray nozzles to distribute the reagent across the scrubber vessel. The sodium in the reagent reacts with the SO₂ in the flue gas to form sodium sulfite and sodium bisulfite, which are removed from the scrubber and disposed.

The wet sodium FGD system at Jim Bridger 4 currently achieves approximately 86 percent SO₂ removal to achieve an SO₂ outlet emission rate of 0.17 lb/MMBtu. Upgrading the wet FGD system would achieve an SO₂ outlet emission rate of 0.10 lb/MMBtu (91.7 percent SO₂

removal) by closing the bypass damper to eliminate routine bypass flue gas flow used to reheat the treated flue gas from the scrubber, relocating the opacity monitor, adding new fans, adding a stack liner and drains for wet operation, and using a refined soda ash reagent. It is considered to be technically infeasible for the present wet FGD system to achieve 95 percent SO₂ removal (0.06 lb/MMBtu) on a continuous basis since this high level of removal must be incorporated into the original design of the scrubber.

The wet FGD system is achieving an outlet SO₂ emission rate of 0.17 lb SO₂/MMBtu. It is not expected that any significant additional SO₂ reduction would occur with optimization of the wet sodium scrubbing FGD system. This option would not meet the presumptive limit of 0.15 lb SO₂/MMBtu. Therefore, this option is eliminated as technically infeasible for this analysis. An upgraded wet sodium scrubbing FGD system is projected to achieve an outlet emission rate of 0.10 lb/MMBtu (91.7 percent SO₂ removal) which would meet the presumptive limit of 0.15 lb SO₂/MMBtu for Jim Bridger 4.

New Dry FGD System. The lime spray dryer typically injects lime slurry in the top of the absorber vessel with a rapidly rotating atomizer wheel. The rapid speed of the atomizer wheel causes the lime slurry to separate into very fine droplets that intermix with the flue gas. The SO₂ in the flue gas reacts with the calcium in the lime slurry to form dry calcium sulfate particles. At Jim Bridger 4 this dry particulate matter would be captured downstream in the existing ESP, along with the fly ash. A lime spray dryer system typically produces a dry waste product suitable for landfill disposal.

The dry FGD system with the existing ESP is projected to achieve 82.5 percent SO₂ removal at Jim Bridger 4. This would result in a controlled SO₂ emission rate of 0.21 lb/MMBtu, based on an uncontrolled SO₂ emission rate of 1.20 lb/MMBtu. Therefore, this option cannot meet the presumptive limit of 0.15 lb SO₂/MMBtu, and is eliminated from further analysis as technically infeasible.

3.2.2.3 Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

When evaluating the control effectiveness of SO₂ reduction technologies, each option can be compared against benchmarks of performance. One such benchmark is the presumptive BART emission limit because Jim Bridger 4 is required to meet this limit. As indicated previously, the presumptive limit for SO₂ on a BART-eligible coal burning unit is 95 percent removal, or 0.15 lb/MMBtu.

The projected emission rate for an upgraded wet sodium FGD system for Jim Bridger 4 would be 0.10 lb/MMBtu. This option would meet the presumptive SO₂ limit of 0.15 lb/MMBtu.

3.2.2.4 Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

Energy Impacts. Upgrading the existing wet sodium FGD system would require an additional 520 kW of power.

Environmental Impacts. There will be incremental additions to scrubber waste disposal and makeup water requirements.

Economic Impacts. A summary of the costs and amount of SO₂ removed for the upgraded wet sodium FGD system is provided in Table 3-5. The complete Economic Analysis is contained in Appendix A.

TABLE 3-5
SO₂ Control Cost Comparison (Incremental to Existing FGD System)
Jim Bridger 4

Factor	Upgraded Wet FGD
Total Installed Capital Costs	\$5.8 Million
Total First Year Fixed & Variable O&M Costs	\$0.7 Million
Total First Year Annualized Cost	\$1.2 Million
Additional Power Consumption (MW)	0.5
Additional Annual Power Usage (1000 MW-Hr/Yr)	4.2
Incremental SO ₂ Design Control Efficiency	40.1% (91.7% based on Uncontrolled SO ₂)
Incremental Tons SO ₂ Removed per Year	1,585
First Year Average Control Cost (\$/Ton of SO ₂ Removed)	761
Incremental Control Cost (\$/Ton of SO ₂ Removed)	761

Preliminary BART Selection. CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 4 based on its significant reduction in SO₂ emissions (meeting presumptive limit of 0.15 lb/MMBtu), reasonable control costs, and the advantages of minimal additional power requirements and environmental impacts.

3.2.2.5 Step 5: Evaluate Visibility Impacts

Please see Section 4.0, BART Modeling Analysis.

3.2.3 BART PM₁₀ Analysis

Jim Bridger 4 is currently equipped with an electrostatic precipitator (ESP). ESPs remove particulate matter from the flue gas stream by charging fly ash particles with a very high direct current voltage, and attracting these charged particles to grounded collection plates. A layer of collected particulate matter forms on the collecting plates and is removed by periodically rapping the plates. The collected ash particles drop into hoppers below the precipitator and are removed periodically by the fly ash-handling system. Historically, the ESP at Jim Bridger 4 has controlled PM₁₀ emissions to levels below 0.030 lb/MMBtu.

The BART analysis for PM₁₀ emissions at Jim Bridger 4 is described below. For the modeling analysis in Section 4.0, PM₁₀ was used as an indicator for PM, and PM₁₀ includes PM_{2.5} as a subset.

3.2.3.1 Step 1: Identify All Available Retrofit Control Technologies

Two retrofit control technologies have been identified for additional PM control:

- Flue gas conditioning
- Polishing fabric filter (baghouse) downstream of Existing ESP

Another available control technology is replacing the existing ESP with a new fabric filter. However, because the environmental benefits that would be achieved by a replacement fabric filter are also achieved by installing a polishing fabric filter downstream of the existing ESP at lower costs, installation of a full fabric filter was not considered in the analysis.

3.2.3.2 Step 2: Eliminate Technically Infeasible Options

Flue Gas Conditioning. If the fly ash from coal has high resistivity, such as fly ash from subbituminous coal, the ash is not collected effectively in an ESP. This is because the high resistivity makes the particles less willing to accept an electrical charge. Adding flue gas conditioning (FGC), which is typically accomplished by injection of sulfur trioxide (SO₃), will lower the resistivity of the particles so that they will accept more charge and allow the ESP to collect the ash more effectively. Flue gas conditioning systems can account for large improvements in collection efficiency for small ESPs.

Polishing Fabric Filter. A polishing fabric filter could be added downstream of the existing ESP at Jim Bridger 4. One such technology is licensed by the Electric Power Research Institute, and referred to as a COHPAC (Compact Hybrid Particulate Collector). The COHPAC collects the ash that is not collected by the ESP, thus acting as a polishing device. The ESP needs to be kept in service for the COHPAC fabric filter to operate effectively.

The COHPAC fabric filter is about one-half to two-thirds the size of a full size fabric filter, because the COHPAC has a higher air-to-cloth ratio (7 to 9:1), compared to a full size pulse jet fabric filter (3.5 to 4:1).

3.2.3.3 Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

The existing ESP at Jim Bridger 4 is achieving a controlled PM emission rate of 0.030 lb/MMBtu. Utilizing flue gas conditioning upstream of the existing ESP is projected to not reduce PM emissions, but it would help maintain long term operation at an emission level of 0.030 lb/MMBtu. Adding a COHPAC fabric filter downstream of the existing ESP is projected to reduce PM emissions to approximately 0.015 lb/MMBtu.

The PM₁₀ control technology emission rates are summarized in Table 3-6.

TABLE 3-6
PM₁₀ Control Technology Emission Rates
Jim Bridger 4

Control Technology	Short-Term Expected PM ₁₀ Emission Rate (Lb/MMBtu)
Flue Gas Conditioning	0.030
Polishing Fabric Filter	0.015

3.2.3.4 Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

Energy Impacts. Energy is required to overcome the additional pressure drop from the COHPAC fabric filter and associated ductwork. Therefore, a COHPAC retrofit will require an ID fan upgrade and upgrade of the auxiliary power supply system.

A COHPAC fabric filter at Jim Bridger 4 would require approximately 3.4 MW of power, equating to an annual power usage of approximately 26.7 million kW-Hr.

There is only a small power requirement of approximately 50 kW associated with flue gas conditioning.

Environmental Impacts. There are no negative environmental impacts from the addition of a COHPAC polishing fabric filter or flue gas conditioning system.

Economic Impacts. A summary of the costs and PM removed for COHPAC and flue gas conditionings are recorded in Table 3-7, and the first-year control costs for flue gas conditioning and fabric filters are shown in Figure 3-5. The complete Economic Analysis is contained in Appendix A.

TABLE 3-7
PM₁₀ Control Cost Comparison (Incremental to Existing ESP)
Jim Bridger 4


Factor	Flue Gas Conditioning	Polishing Fabric Filter
Total Installed Capital Costs	\$0	\$48.4 Million
Total First Year Fixed & Variable O&M Costs	\$0.2 Million	\$1.8 Million
Total First Year Annualized Cost	\$0.2 Million	\$ 6.4 Million
Additional Power Consumption (MW)	0.05	3.39
Additional Annual Power Usage (Million kW-Hr/Yr)	0.4	26.7
Incremental PM Design Control Efficiency	0.0%	50.0%
Incremental Tons PM Removed per Year	0	355
First Year Average Control Cost (\$/Ton of PM Removed)	N/A	17,946
Incremental Control Cost (\$/Ton of PM Removed)	N/A	17,452

Preliminary BART Selection. CH2M HILL recommends selection of flue gas conditioning upstream of the existing ESP as BART for Jim Bridger 4 based on the significant reduction in PM emissions, reasonable control costs, and advantages of minimal additional power requirements and no environmental impacts.

3.2.3.5 Step 5: Evaluate Visibility Impacts

Please see Section 4.0, BART Modeling Analysis.

FIGURE 3-5
First Year Control Cost for PM Air Pollution Control Options
Jim Bridger 4



4.0 BART Modeling Analysis

4.1 Model Selection

CH2M HILL used the CALPUFF modeling system to assess the visibility impacts of emissions from Jim Bridger 4 at nearby Class I areas. The Class I areas potentially affected are located more than 50 kilometers but less than 300 kilometers from the Jim Bridger 4 facility. The Class I areas include the following wilderness areas (WA):

- Bridger WA
- Fitzpatrick WA
- Mt. Zirkel WA

The CALPUFF modeling system includes the CALMET meteorological model, a Gaussian puff dispersion model (CALPUFF) with algorithms for chemical transformation and deposition, and a post processor capable of calculating concentrations, visibility impacts, and deposition (CALPOST). The CALPUFF modeling system was applied in a full, refined mode. Version numbers of the various programs in the CALPUFF system used by CH2M HILL were as follows:

- CALMET Version 5.53a, Level 040716
- CALPUFF Version 5.711a, Level 040716
- CALPOST Version 5.51, Level 030709


4.2 CALMET Methodology

4.2.1 Dimensions of the Modeling Domain

CH2M HILL used the CALMET model to generate a three-dimensional wind field and other meteorological parameters suitable for use by the CALPUFF model. A modeling domain was established to encompass the Jim Bridger 4 facility and allow for a 50-km buffer around the Class I areas that were within 300 km of the facility. Grid resolution was 4 km. Figure 4-1 shows the extent of the modeling domain. Except when specifically instructed otherwise by the Wyoming Department of Environmental Quality – Air Quality Division (WDEQ-AQD), CH2M HILL followed the methodology spelled out in the WDEQ-AQD BART Modeling Protocol, a copy of which is included in this report as Appendix B.

CH2M HILL used the Lambert Conformal Conic map projection for the analysis due to the large extent of the domain. The latitude of the projection origin and the longitude of the central meridian were chosen at the approximate center of the domain. Standard parallels were drawn to represent 1/6 and 5/6 of the north-south extent of the domain to minimize distortion in the north-south direction.

FIGURE 4-1
Extent of Modeling Domain
Jim Bridger 4



PACIFICORP

CH2MHILL

Figure 4-1
Jim Bridger Source-Specific
Class I Areas to be Addressed

SLC \USCORS\PROJECT\UNIT4\BART\FILES\DATA\FRONTIER_CO\USCORS\MAP\FIG4-1.MXD

The default technical options listed in TRC Companies, Inc.'s (TRC) current example CALMET.inp file were used for CALMET. Vertical resolution of the wind field included ten layers, with vertical face heights as follows (in meters):

- 0, 20, 40, 100, 140, 320, 580, 1020, 1480, 2220, 3500

Other user-specified model options were set to values established by WDEQ-AQD, which appear in Table 3 of Appendix B. Table 4-1 lists the key user-specified options used for this analysis.

TABLE 4-1
User-Specified CALMET Options
Jim Bridger 4

CALMET Input Parameter	Value
CALMET Input Group 2	
Map projection (PMAP)	Lambert Conformal
Grid spacing (DGRIDKM)	4
Number vertical layers (NZ)	10
Top of lowest layer (m)	20
Top of highest layer (m)	3500
CALMET Input Group 4	
Observation mode (NOOBS)	0
CALMET Input Group 5	
Prog. Wind data (IPROG)	14
(RMAX1)	30
(RMAX2)	50
Terrain influence (TERRAD)	15
(R1)	5
(R2)	25
CALMET Input Group 6	
Max mixing ht (ZIMAX)	3500

4.2.2 CALMET Input Data

CH2M HILL ran the CALMET model to produce three years of analysis: 2001, 2002, and 2003. WDEQ-AQD provided 12-km resolution Mesoscale Meteorological Model, Version 5 (MM5) meteorological data fields that covered the entire modeling domain for each study year.

These three data sets were chosen because they are current and have been evaluated for quality. The MM5 data were used as input to CALMET as the "initial guess" wind field. The initial guess wind field was adjusted by CALMET for local terrain and land use effects to generate a

Step 1 wind field, and further refined using local surface observations to create a final Step 2 wind field.

Surface data for 2001-2003 were obtained from the National Climatic Data Center. CH2M HILL processed the data from the National Weather Service's Automated Surface Observing System (ASOS) network for all stations that are in the domain. The surface data were obtained in abbreviated DATSAV3 format. A conversion routine available from the TRC website was used to convert the DATSAV3 files to CD-144 format for input into the SMERGE preprocessor and CALMET.

Land use and terrain data were obtained from the U.S. Geological Survey (USGS). Land use data were obtained in Composite Theme Grid format from the USGS, and the Level I USGS land use categories were mapped into the 14 primary CALMET land use categories. Surface properties such as albedo, Bowen ratio, roughness length, and leaf area index were computed from the land use values. Terrain data were taken from USGS 1-degree Digital Elevation Model data, which primarily derive from USGS 1:250,000 scale topographic maps. Missing land use data were filled with values that were assumed appropriate for the missing area.

Precipitation data were obtained from the National Climatic Data Center. All available data in fixed-length, TD-3240 format were obtained for the modeling domain. The list of available stations that have collected complete data varies by year, but CH2M HILL processed all available stations/data within the domain for each year. Precipitation data were prepared with the PXTRACT/PMERGE processors in preparation for use within CALMET.

Upper-air data were prepared for the CALMET model with the READ62 preprocessor for the following stations:

- Denver, Colorado
- Salt Lake City, Utah
- Riverton, Wyoming
- Rapid City, South Dakota

Figure 4-2 shows the locations of surface and upper air stations within the MM5 modeling domain.

FIGURE 4-2
Surface and Upper Air Station Locations
Jim Bridger 4




Figure 4-2
Surface and Upper Air Stations Used in the
Jim Bridger BART Analysis



FILE: W:\BART\BART_ANALYSIS\FILES\BORDER_ACS.MXD 1:428164.128281

CH2MHILL

4.2.3 Validation of CALMET Wind Field

CH2M HILL used the CALDESK data display and analysis system (v2.97, Enviromodeling Ltd.) to view plots of wind vectors and other meteorological parameters to evaluate the CALMET wind fields. The CALDESK displays were compared to observed weather conditions, as depicted in surface and upper-air weather maps from the National Oceanic and Atmospheric Administration Central Library U.S. Daily Weather Maps Project (http://docs.lib.noaa.gov/rescue/dwm/data_rescue_daily_weather_maps.html).

4.3 CALPUFF Modeling Approach

For the BART control technology visibility improvement modeling, CH2M HILL followed WDEQ-AQD guidance provided in the document titled *BART Air Modeling Protocol - Individual Source Visibility Assessments for BART Control Analyses* (September, 2006).

A modeling protocol titled *Modeling Protocol for BART Control Technology Improvement Modeling Analysis* (CH2M HILL, August, 2006) was submitted to WDEQ-AQD for review. In the protocol, CH2M HILL described how the general CALMET/CALPUFF approach recommended by the WDEQ-AQD would be used to model Jim Bridger 4.

CH2M HILL drove the CALPUFF model with the meteorological output from CALMET over the modeling domain described earlier. The CALPUFF model was used to predict visibility impacts for the pre-control (baseline) scenario for comparison to the predicted impacts for post-control scenarios for Jim Bridger 4.

4.3.1 Background Ozone and Ammonia

Hourly values of background ozone concentrations were used by CALPUFF for the calculation of SO₂ and NO_x transformation with the MESOPUFF II chemical transformation scheme. CH2M HILL obtained hourly ozone data from the following stations located within the modeling domain for 2001, 2002, and 2003:

- Rocky Mountain National Park, Colorado
- Craters of the Moon National Park, Idaho
- Highland, Utah
- Thunder Basin National Grasslands, Wyoming
- Yellowstone National Park, Wyoming
- Centennial, Wyoming
- Pinedale, Wyoming

For periods of missing hourly ozone data, the chemical transformation relied on a monthly default value of 44 parts per billion. Background ammonia was set to 2 parts per billion. Both of these background values were taken from the WDEQ-AQD document *BART Air Modeling Protocol - Individual Source Visibility Assessments for BART Control Analyses* (September, 2006).

4.3.2 Stack Parameters

The stack parameters used for the baseline modeling reflect those that are in place under the current permit for Jim Bridger 4. Post-control stack parameters reflect the anticipated changes associated with installation of the control technology alternatives that are being evaluated. The maximum heat input rate of 6,000 MMBtu/hr was used to calculate a maximum emission rate. Measured velocities and stack flow rates were used in the modeling to represent a worst-case situation.

4.3.3 Emission Rates

Pre-control emission rates for Jim Bridger 4 reflect peak 24-hour average emissions that may occur under the source's current permit. The emission rates reflect actual emissions under normal operating conditions, as described by the EPA in the *Regional Haze Regulations and Guidelines for Best Available Retrofit Technology Determinations; Final Rule* (40 CFR Part 51; July 6, 2005, pg 39129).

CH2M HILL used available continuous emission monitoring data to determine peak 24-hour emission rates. Data reflected operations from the most recent 3 to 5 year period, unless a more recent period was more representative. Allowable short-term (24-hour or shorter period) emissions or short-term emission limits were used if continuous emission monitoring data were not available.

Emissions were modeled for the following pollutants:

- SO₂
- NO_x
- Coarse particulate (PM_{2.5}<diameter<PM₁₀)
- Fine particulate (diameter<PM_{2.5})
- Sulfates

Post-control emission rates reflect the effects of the emissions control scenario under consideration. Modeled pollutants were the same as those listed for the pre-control scenario.

4.3.4 Post Control Scenarios

Four post control modeling scenarios were developed to cover the range of effectiveness for the combination of the individual NO_x, SO₂ and PM control technologies being evaluated. The selection of each control device was made based on the engineering analyses performed in Section 3 for reasonable technologies that would meet or exceed the presumptive BART levels for each pollutant.

- **Scenario 1:** New LNB w/OFA Modifications, upgraded wet FGD system and flue gas conditioning for enhanced ESP performance. As indicated previously, this scenario represents CH2M HILL's preliminary BART recommendation.
- **Scenario 2:** New LNB w/OFA modifications, upgraded wet FGD system and new polishing fabric filter
- **Scenario 3:** New LNB w/OFA modifications and SCR, upgraded wet FGD system and flue gas conditioning for enhanced ESP performance.

- **Scenario 4:** New LNB w/OFA modifications and SCR, upgraded wet FGD system and new polishing fabric filter.

The ROFA option and LNB w/OFA & SCR option for NO_x control were not included in the modeling scenarios because their control effectiveness is between the LNB w/OFA option and the SCR option. Modeling of NO_x, SO₂ and PM controls alone was not performed because any final BART solution will include a combination of control technologies for NO_x, SO₂ and PM.

Table 4-2 presents the stack parameters and emission rates used for the Jim Bridger 4 analysis for baseline and post-control modeling. In accordance with the WDEQ BART modeling protocol, elemental carbon stack emissions and organic aerosol emissions were not modeled.

TABLE 4-2
BART Model Input Data
Jim Bridger 4

	Baseline	Post Control Scenario 1	Post Control Scenario 2	Post Control Scenario 3	Post Control Scenario 4
	Current Operations with wet FGD and ESP	LNB with OFA, Upgrade Wet FGD & FGC for Enhanced ESP Performance	LNB with OFA, Upgrade Wet FGD, New Fabric Filter	LNB with OFA and SCR, Upgrade Wet FGD & FGC for Enhanced ESP Performance	LNB with OFA and SCR, Upgrade Wet FGD, New Fabric Filter
Heat Input (MMBtu/hr)	6,000	6,000	6,000	6,000	6,000
SO ₂ Stack Emissions (lb/MMBTU)	0.2	0.10	0.10	0.10	0.10
SO ₂ Stack Emissions (lb/hr)	1,002	600	600	600	600
NO _x Stack Emissions (lb/MMBTU)	0.45	0.24	0.24	0.07	0.07
NO _x Stack Emissions (lb/hr)	2,700	1,440	1,440	420	420
PM ₁₀ Stack Emissions (lb/MMBTU)	0.030	0.030	0.019	0.019	0.019
PM ₁₀ Stack Emissions (lb/hr)	180	180	114	114	114
PM ₁₀ -PM _{2.5} Stack Emissions (lb/hr)	77.4	77.4	65.0	65.0	65.0
PM _{2.5} -PM ₀ Stack Emissions (lb/hr)	102.6	102.6	49.0	49.0	49.0
HF Stack Emissions (lb/MMBTU)	0.00055	0.00055	0.00055	0.00055	0.00055
HF Stack Emissions (lb/hr)	3.3	3.3	3.3	3.3	3.3
HCl Stack Emissions (lb/MMBTU)	0.00075	0.00075	0.00075	0.00075	0.00075
HCl Stack Emissions (lb/hr)	4.5	4.5	4.5	4.5	4.5
H ₂ SO ₄ Stack Emissions (lb/MMBTU)	0.0092	0.0092	0.0092	0.0158	0.0158
H ₂ SO ₄ Stack Emissions (lb/hr)	55.2	55.20	55.20	94.80	94.80

TABLE 4-2
BART Model Input Data
Jim Bridger 4

	Baseline	Post Control Scenario 1	Post Control Scenario 2	Post Control Scenario 3	Post Control Scenario 4
	Current Operations with wet FGD and ESP	LNB with OFA, Upgrade Wet FGD & FGC for Enhanced ESP Performance	LNB with OFA, Upgrade Wet FGD, New Fabric Filter	LNB with OFA and SCR, Upgrade Wet FGD & FGC for Enhanced ESP Performance	LNB with OFA and SCR, Upgrade Wet FGD, New Fabric Filter
H ₂ SO ₄ as SO ₄ Stack Emissions (lb/hr)	54.1	54.07	54.07	92.87	92.87
(NH ₄) ₂ SO ₄ Stack Emissions (lb/MMBtu)				0.00117	0.00117
(NH ₄) ₂ SO ₄ Stack Emissions (lb/hr)				7.02	7.02
(NH ₄) ₂ SO ₄ as SO ₄ Stack Emissions (lb/hr)				5.10	5.10
(NH ₄)HSO ₄ Stack Emissions (lb/MMBtu)				0.00204	0.00204
(NH ₄)HSO ₄ as SO ₄ Stack Emissions (lb/hr)				12.2	12.2
(NH ₄)HSO ₄ as SO ₄ Stack Emissions (lb/hr)				10.22	10.22
Total Filterable PM ₁₀ (lb/hr) (incl. PM _{2.5})	122	122	121.8	121.8	121.8
Total Sulfate (as SO ₄) (lb/hr)	54.1	54.1	54.1	108	108
Total PM _{2.5} (lb/hr)	49.0	49.0	49.0	49.0	49.0
Stack Conditions					
Stack Height (feet)	500	500	500	500	500
Stack Height (m)	152	152	152	152	152
Stack Exit Diameter (feet)	31.00	31.00	31.00	31.00	31.00
Stack Exit Diameter (m)	9.45	9.45	9.45	9.45	9.45
Stack Exit Temperature (degF)	120	120	120	120	120
Stack Exit Temperature (K)	322.0	322.0	322.0	322.0	322.0
Stack Exit Flow (acfm)	1,920,610	1,920,610	2,374,592	2,374,592	2,374,592
Stack Exit Area (ft ²)	755	755	755	755	755
Stack Exit Velocity (fps)	42.4	42.4	52.44	52.44	52.44

TABLE 4-2
BART Model Input Data
Jim Bridger 4

Baseline	Post Control Scenario 1	Post Control Scenario 2	Post Control Scenario 3	Post Control Scenario 4
Current Operations with wet FGD and ESP	LNB with OFA, Upgrade Wet FGD & FGC for Enhanced ESP Performance	LNB with OFA, Upgrade Wet FGD, New Fabric Filter	LNB with OFA and SCR, Upgrade Wet FGD & FGC for Enhanced ESP Performance	LNB with OFA and SCR, Upgrade Wet FGD, New Fabric Filter

Notes:

(1) Based on AP-42, Table 1.1-6, as percent of PM₁₀. See factors below.

	ESP	Baghouse
PM ₁₀ -PM _{2.5} Stack Emissions (lb/hr)	43	57
PM _{2.5} -PM ₁₀ Stack Emissions (lb/hr)	57	43

(2) Scenarios 2, 3, and 4 were not remodeled at the lower, correct velocity of 42.4 fps due to lack of time and the fact that the conclusions to select Scenario 1 would not have changed.

4.3.5 Modeling Process

The CALPUFF modeling for the control technology options for Jim Bridger 4 followed this sequence:

- Model pre-control (baseline) emissions
- Model preferred post-control scenario (if applicable)
- Determine degree of visibility improvement
- Model other control scenarios
- Determine degree of visibility improvement
- Factor visibility results into BART "5-step" evaluation

4.3.6 Receptor Grids

Discrete receptors for the CALPUFF modeling were placed at uniform receptor spacing along the boundary and in the interior of each area of concern. Class I area receptors were taken from the National Park Service (NPS) database for Class I area modeling receptors. The TRC COORDS program was used to convert all latitude/longitude coordinates to Lambert Conformal Conic coordinates, including receptors, meteorological stations, and source locations.

4.4 CALPOST

The CALPOST processor was used to determine 24-hour average visibility results with output specified in deciview (dV) units. Calculations of light extinction were made for each pollutant modeled. The sum of all extinction values were used to calculate the delta-dV (Δ dV) change relative to natural background. Default light extinction coefficients for each pollutant, as follows, were used.

- Ammonium sulfate 3.0
- Ammonium nitrate 3.0
- PM coarse (PM₁₀) 0.6
- PM fine (PM_{2.5}) 1.0
- Organic carbon 4.0
- Elemental carbon 10.0

CALPOST visibility Method 6 was used to determine the visibility impacts. Monthly relative humidity factors [$f(RH)$] were used in the light extinction calculations to account for the hygroscopic characteristics of nitrate and sulfate particles. Table 5 of the Wyoming BART Air Modeling Protocol (Appendix B) lists the monthly $f(RH)$ factors for the Class I areas. These values were used for the particular Class I area being modeled.

The natural background conditions as a reference for determining the delta-dV (ΔdV) change represented the 20 percent best natural visibility days. The EPA BART guidance document provided dV values for the 10 percent best days for each Class I area, but did not provide individual species concentration data for the 20 percent best background conditions. Species concentrations corresponding to the 20 percent best days were calculated for each Class I area by scaling back the annual average species concentrations given in Table 2-1 of *Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule*. A separate scaling factor was derived for each Class I area such that, when multiplied by the Guidance table annual concentrations, the 20 percent best days dV value for that area would be calculated. This procedure was taken from *Protocol for BART-Related Visibility Improvement Modeling Analysis in North Dakota* (North Dakota Department of Health; October 26, 2005). However, the Wyoming BART Air Modeling Protocol provided natural background concentrations of aerosol components to use in the BART analysis. Table 4-3 lists the annual average species concentrations from the BART protocol.

TABLE 4-3
Average Natural Levels of Aerosol Components
Jim Bridger 4

Aerosol Component	Average Natural Concentration (micrograms per cubic meter) for Mt. Zirkel Class I Wilderness Area	Average Natural Concentration (micrograms per cubic meter) for Fitzpatrick and Bridger Class I Wilderness Areas
Ammonium-Sulfate	0.046	0.045
Ammonium Nitrate	0.038	0.038
Organic Carbon	0.179	0.178
Elemental Carbon	0.008	0.008
Soil	0.190	0.189
Coarse Mass	1.141	1.136

Note: Taken from Table 6 of the Wyoming BART Air Modeling Protocol

4.5 Presentation of Modeling Results

This section presents the results of the CALPUFF visibility improvement modeling analysis for Jim Bridger 4.

4.5.1 Degree of Visibility Change for Baseline vs. Preferred Scenario

CH2M HILL modeled Jim Bridger 4 for the baseline conditions and post-control Scenario 1. The post-control scenario included emission rates for NO_x, SO₂, and PM₁₀ that would be achieved if BART technology were installed on Unit 4.

Baseline (and post-control) 98th percentile results were greater than 0.5 ΔdV for the Bridger WA, Fitzpatrick WA, and Mt. Zirkel WA. The 98th percentile results for each Class I area are presented in Table 4-4.

TABLE 4-4
Costs and Visibility Modeling Results for Baseline Vs. Post-Control Scenarios at Class I Areas
Jim Bridger 4

Scenario	Class I Area	First Year Cost	Highest Delta- (dV)	98th Percentile Delta- (dV)	No. of Days Above 0.5 dV	Cost per dV Reduction	Cost per Reduction in No. of Days Above 0.5 dV	Incremental Cost per dV Reduction	Incremental Cost per Reduction in No. of Days Above 0.5 dV
Baseline - Current Operation with Wet FGD and ESP	Bridger WA		2.541	0.727	15	-	-	-	-
	Fitzpatrick WA		2.606	0.507	8	-	-	-	-
	Mt. Zirkel WA		2.135	1.356	29	-	-	-	-
Scenario 1 - LNB with OFA, upgrade wet FGD & FGC for enhanced ESP performance	Bridger WA	\$2,104,213	1.563	0.415	7	\$6,744,274	\$263,027	NA	NA
	Fitzpatrick WA	\$2,104,213	1.57	0.284	3	\$9,436,935	\$420,843	NA	NA
	Mt. Zirkel WA	\$2,104,213	1.311	0.804	20	\$3,811,981	\$233,801	NA	NA
Scenario 2 - LNB with OFA, Upgrade Wet FGD, new polishing fabric filter	Bridger WA	\$8,470,832	1.543	0.415	7	\$27,150,104	\$1,058,854	NA	NA
	Fitzpatrick WA	\$8,470,832	1.615	0.273	3	\$39,200,138	\$1,694,166	\$578,783,537	\$6,366,619
	Mt. Zirkel WA	\$8,470,832	1.36	0.831	21	\$16,134,619	\$1,058,854	\$235,800,700	\$2,533,130
Scenario 3 - LNB with OFA and SCR, upgrade wet FGD & FGC for enhanced ESP performance	Bridger WA	\$18,603,354	1.052	0.389	3	\$35,717,543	\$1,550,280	\$633,282,611	\$10,132,522
	Fitzpatrick WA	\$18,603,354	0.909	0.147	2	\$51,675,984	\$3,100,559	\$80,416,839	\$844,377
	Mt. Zirkel WA	\$18,603,354	0.889	0.537	6	\$22,714,718	\$830,168	NA	NA
Scenario 4 - LNB with OFA and SCR, upgrade wet FGD, new polishing fabric filter	Bridger WA	\$24,969,973	1.052	0.389	3	\$76,127,966	\$2,080,831	NA	NA
	Fitzpatrick WA	\$24,969,973	0.909	0.147	2	\$99,361,036	\$4,161,862	NA	NA
	Mt. Zirkel WA	\$24,969,973	0.889	0.537	9	\$30,488,367	\$1,246,489	NA	NA
Baseline - Current Operation with Wet FGD and ESP	Bridger WA		4.247	1.501	30	-	-	-	-
	Fitzpatrick WA		2.012	0.736	14	-	-	-	-
	Mt. Zirkel WA		3.134	1.612	37	-	-	-	-
Scenario 1 - LNB with OFA, upgrade wet FGD & FGC for enhanced ESP performance	Bridger WA	\$2,104,213	2.613	0.858	14	\$3,272,494	\$191,516	NA	NA
	Fitzpatrick WA	\$2,104,213	1.178	0.421	6	\$6,690,049	\$283,027	NA	NA
	Mt. Zirkel WA	\$2,104,213	1.87	0.837	17	\$3,117,353	\$105,211	NA	NA
Scenario 2 - LNB with OFA, Upgrade Wet FGD, new polishing fabric filter	Bridger WA	\$8,470,832	2.602	0.867	14	\$13,360,934	\$529,427	\$707,402,100	NA
	Fitzpatrick WA	\$8,470,832	1.15	0.419	6	\$26,721,868	\$1,058,854	\$3,183,309,451	NA
	Mt. Zirkel WA	\$8,470,832	1.863	0.965	17	\$13,092,477	\$423,542	\$227,379,247	NA
Scenario 3 - LNB with OFA and SCR, upgrade wet FGD & FGC for enhanced ESP performance	Bridger WA	\$18,603,354	1.455	0.657	9	\$22,041,889	\$885,874	\$48,250,104	\$2,026,504
	Fitzpatrick WA	\$18,603,354	0.62	0.254	1	\$38,596,170	\$1,431,027	\$61,409,223	\$2,026,504
	Mt. Zirkel WA	\$18,603,354	1.108	0.581	10	\$18,043,980	\$689,013	\$26,986,775	\$1,447,503
Scenario 4 - LNB with OFA and SCR, upgrade wet FGD, new polishing fabric filter	Bridger WA	\$24,969,973	1.455	0.657	9	\$29,585,276	\$1,189,046	NA	NA
	Fitzpatrick WA	\$24,969,973	0.62	0.254	1	\$51,804,523	\$1,820,767	NA	NA
	Mt. Zirkel WA	\$24,969,973	1.108	0.581	10	\$24,219,178	\$924,814	NA	NA

TABLE 4.4
Costs and Visibility Modeling Results for Baseline Vs. Post-Control Scenarios at Class I Areas
Jim Bridger 4

Scenario	First Year Cost	Class / Area	Highest Delta- (dV)	98th Percentile Delta- (dV)	No. of Days Above 0.5 dV	Cost per dV Reduction	Cost per Reduction In No. of Days Above 0.5 dV	Incremental Cost per dV Reduction	Incremental Cost per Reduction in No. of Days Above 0.5 dV
Baseline - Current Operation with Wet FGD and ESP		Bridger WA Fitzpatrick WA Mt. Zirkel WA	1.857 1.87 2.08	0.881 0.482 1.464	15 7 38	-- -- --	-- -- --	-- -- --	-- -- --
Scenario 1 - LNB with OFA, upgrade wet FGD & FGC for enhanced ESP performance	\$2,104,213 \$2,104,213 \$2,104,213	Bridger WA Fitzpatrick WA Mt. Zirkel WA	1.144 1.187 1.213	0.516 0.267 0.882	9 3 20	\$5,764,968 \$12,024,077 \$8,383,320	\$950,702 \$526,053 \$116,901	\$205,374,803 \$289,381,768 \$132,637,894	\$3,163,309 NA \$3,163,309
Scenario 2 - LNB with OFA, Upgrade Wet FGD, new polishing fabric filter	\$8,470,832 \$8,470,832 \$18,603,364	Bridger WA Fitzpatrick WA Mt. Zirkel WA	1.124 1.19 1.22	0.485 0.235 0.93	7 3 18	\$21,900,891 \$42,899,149 \$15,862,982	\$1,056,854 \$2,117,708 \$423,542	\$205,374,803 \$289,381,768 \$132,637,894	\$3,163,309 NA \$3,163,309
Scenario 3 - LNB with OFA and SCR, upgrade wet FGD & FGC for enhanced ESP performance	\$18,603,354 \$18,603,354 \$24,969,973	Bridger WA Fitzpatrick WA Mt. Zirkel WA	0.917 0.722 -0.789	0.337 0.148 0.525	3 2 8	\$34,187,342 \$65,504,765 \$18,811,879	\$1,550,280 \$3,720,671 \$620,112	\$68,462,985 \$118,485,768 \$25,018,572	\$2,533,130 \$10,132,522 \$1,015,252
Scenario 4 - LNB with OFA and SCR, upgrade wet FGD, new polishing fabric filter	\$24,969,973 \$24,969,973 \$24,969,973	Bridger WA Fitzpatrick WA Mt. Zirkel WA	0.917 0.722 0.789	0.337 0.148 0.525	3 2 8	\$45,900,686 \$87,922,440 \$26,592,090	\$2,080,831 \$4,993,995 \$832,332	NA NA NA	NA NA NA
Scenario 1		Bridger WA				\$5,260,579	\$248,414		
		Fitzpatrick WA				\$9,380,018	\$403,308		
		Mt. Zirkel WA				\$5,104,218	\$151,971		
Scenario 2		Bridger WA				\$20,694,009	\$882,378	\$456,386,462	\$3,163,309
		Fitzpatrick WA				\$35,307,052	\$1,623,576	\$1,350,494,919	NA
		Mt. Zirkel WA				\$15,030,126	\$635,312	\$188,605,847	\$4,774,964
Scenario 3		Bridger WA				\$37,662,258	\$1,328,811	\$249,996,566	\$2,364,255
		Fitzpatrick WA				\$51,925,641	\$2,750,752	\$86,097,277	\$7,430,516
		Mt. Zirkel WA				\$20,190,196	\$746,431	\$28,623,236	\$1,101,711
Scenario 4		Bridger WA				\$50,537,976	\$1,783,569	NA	NA
		Fitzpatrick WA				\$69,686,133	\$3,692,141	NA	NA
		Mt. Zirkel WA				\$27,089,879	\$1,001,882	NA	NA

Sample Calculations: Cost per dV Reduction for Scenario 1 for 2001:
 $= \$2,104,213 / (0.727 - 0.415) = \$5,744,274$
 Sample Calculations: Cost per Reduction in No. of Days Above 0.5 dV for 2001:
 $= \$2,104,213 / (15 - 7) = \$263,027$

5.0 Preliminary Assessment and Recommendations

As a result of the completed technical and economic evaluations, and consideration of the modeling analysis for Jim Bridger 4, the preliminary recommended BART controls for NO_x, SO₂, and PM are as follows:

- New LNBS and modifications to the OFA system for NO_x control
- Upgrade wet sodium FGD for SO₂ control
- Add flue gas conditioning upstream of existing ESPs for PM control

The above recommendations were identified as Scenario 1 for the modeling analysis described in Section 4.0. Visibility improvements for all emission control scenarios were analyzed, and the results are compared below, utilizing a Least-Cost Envelope, as outlined in the draft EPA 1990 *New Source Review Workshop Manual (NSR Manual)*. The purpose of this analysis is to use an objective, EPA-approved methodology to evaluate and make the final recommendation of BART control technology.

5.1 Least-Cost Envelope Analysis

For the control scenarios modeled in Section 4, Tables 5-1 through 5-3 list the total annualized cost, cost per dV reduction, and cost per reduction in number of days above 0.5 dV for each of the three Class 1 areas. A comparison of the incremental results between selected scenarios is provided in Tables 5-4 through 5-6. Figures 5-1 to 5-6 show the total annualized cost versus number of days above 0.5 dV, and the total annualized cost versus 98th percentile ΔdV reduction, for the three Class I areas.

5.1.1 Analysis Methodology

Page B-41 of the New Source Review (NSR) Manual, EPA states that “Incremental cost-effectiveness comparisons should focus on annualized cost and emission reduction differences between dominant alternatives. Dominant set of control alternatives are determined by generating what is called the envelope of least-cost alternatives. This is a graphical plot of total annualized costs for a total emissions reductions for all control alternatives identified in the BACT analysis...”

An analysis of incremental cost effectiveness has been conducted. This analysis was performed in the following way. First, the control option scenarios are ranked in ascending order of annualized total costs, as shown in Tables 5-1 through 5-3. The incremental cost effectiveness data, expressed per day and per dV, represents a comparison of the different scenarios, and is summarized in Tables 5-4 through 5-6 for each of the three wilderness areas. Then the most reasonable smooth curve of least-cost control option scenarios is plotted for each analysis. Figures 5-1 through 5-6 present the two analyses (cost per dV reduction and cost per reduction in number of days above 0.5 dV) for each of the three Class I areas impacted by the operation of Jim Bridger 4.

In Figure 5-1, the four scenarios are compared as a graph of total annualized cost versus number of days above 0.5 dV. EPA states that "In calculating incremental costs, the analysis should only be conducted for control options that are dominant among all possible options". In Figure 5-1, the dominant set of control options, Scenarios 1 and 3, represent the least-cost envelope depicted by the curvilinear line connecting them. Scenarios 2 and 4 are inferior options and should not be considered in the derivation of incremental cost effectiveness. Scenarios 2 and 4 represent inferior controls because Scenario 1 provides approximately same amount of visibility impact reduction for less cost than Scenario 2; and similarly, Scenario 3 will provides approximately the same amount of visibility impact reduction for less cost than Scenario 4. The incremental cost effectiveness is determined by the difference in total annual costs between two contiguous scenarios divided by the difference in emissions reduction.

TABLE 5-1
Control Scenario Results for the Bridger Class 1 Wilderness Area
Jim Bridger 4

Scenario	Controls	98th Percentile dV Reduction	Reduction in Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet FGD, ESP	0.0	0.0	\$0.0	\$0.0	\$0.0
1	LNB with OFA, upgrade wet FGD & FGC for enhanced ESP performance	0.4	10.0	\$2.1	\$5.3	\$0.3
2	LNB with OFA, Upgrade Wet FGD, new polishing fabric filter	0.5	10.7	\$8.5	\$20.6	\$0.9
3	LNB with OFA and SCR, upgrade wet FGD & FGC for enhanced ESP performance	0.6	15.0	\$18.6	\$37.7	\$1.3
4	LNB with OFA and SCR, upgrade wet FGD, new polishing fabric filter	0.6	15.0	\$25.0	\$50.5	\$1.8

TABLE 5-2
Control Scenario Results for the Fitzpatrick Class 1 Wilderness Area
Jim Bridger 4

Scenario	Controls	98th Percentile dV Reduction	Reduction in Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet FGD, ESP	0.0	0.0	\$0.0	\$0.0	\$0.0
1	LNB with OFA, upgrade wet FGD & FGC for enhanced ESP performance	0.2	4.7	\$2.1	\$8.7	\$0.4
2	LNB with OFA, Upgrade Wet FGD, new polishing fabric filter	0.2	18.0	\$8.4	\$35.0	\$0.5
3	LNB with OFA and SCR, upgrade wet FGD & FGC for enhanced ESP performance	0.4	4.7	\$18.4	\$50.6	\$4.0
4	LNB with OFA and SCR, upgrade wet FGD, new polishing fabric filter	0.4	12.7	\$24.7	\$67.8	\$2.0

TABLE 5-3
Control Scenario Results for the Mt. Zirkel Class 1 Wilderness Area
Jim Bridger 4

Scenario	Controls	98th Percentile dV Reduction	Reduction in Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet FGD, ESP	0.0	0.0	\$0.0	\$0.0	\$0.0
1	LNB with OFA, upgrade wet FGD & FGC for enhanced ESP performance	0.6	17.0	\$2.1	\$3.3	\$0.1
2	LNB with OFA, Upgrade Wet FGD, new polishing fabric filter	0.6	17.0	\$8.4	\$13.2	\$0.5
3	LNB with OFA and SCR, upgrade wet FGD & FGC for enhanced ESP performance	1.0	26.7	\$18.4	\$18.5	\$0.7
4	LNB with OFA and SCR, upgrade wet FGD, new polishing fabric filter	1.0	26.7	\$24.7	\$24.8	\$0.9

TABLE 5-4
Bridger Class I Wilderness Area Incremental Analysis Data
Jim Bridger 4

Options Compared	Incremental Reduction in Days Above 0.5 dV (Days)	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	10.0	0.4	\$0.2	\$4.8
Scenario 1 and Scenario 3	5.0	0.1	\$3.3	\$125.

TABLE 5-5
Fitzpatrick Class I Wilderness Area Incremental Analysis Data
Jim Bridger 4

Options Compared	Incremental Reduction in Days Above 0.5 dV (Days)	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	5.7	0.2	\$0.4	\$8.9
Scenario 1 and Scenario 3	2.3	0.1	\$7.1	\$120.

TABLE 5-6
Mt. Zirkel Class I Wilderness Area Incremental Analysis Data
Jim Bridger 4

Options Compared	Incremental Reduction in Days Above 0.5 dV (Days)	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	15.7	0.6	\$0.1	\$3.5
Scenario 1 and Scenario 3	10.0	0.3	\$1.7	\$50.5

FIGURE 5-1
Least Cost Envelope Bridger Class I WA Days Reduction
Jim Bridger 4




FIGURE 5-2
Least Cost Envelope Bridger Class I WA 98th Percentile Reduction
Jim Bridger 4




FIGURE 5-3
Least Cost Envelope Fitzpatrick Class I WA Days Reduction
Jim Bridger 4




FIGURE 5-4
Least Cost Envelope Fitzpatrick Class I WA 98th Percentile Reduction
Jim Bridger 4




FIGURE 5-5
 Least Cost Envelope Mt. Zirkel Class I WA Days Reduction
 Jim Bridger 4





FIGURE 5-6
 Least Cost Envelope Mt. Zirkel Class I WA 98th Percentile Reduction
 Jim Bridger 4



5.1.2 Analysis Results

Results of the Least Cost Analysis, shown in Tables 5-1 through 5-6 and Figures 5-1 through 5-4 on the preceding pages, confirm the selection of Scenario 1, based on incremental cost and visibility improvements. Scenario 2 is eliminated because it is to the left of the curve formed by the “dominant” control alternative scenarios, which indicates a scenario with lower improvement and/or higher costs. Scenario 3 is not selected due to very high incremental costs for both a cost per day of improvement and a cost per dV reduction. While Scenario 4 provides some potential visibility advantage over Scenario 1, the projected improvement is less than half a dV, and the projected costs are excessive.

Analysis of the results for the Jim Bridger Class 1 WA in Tables 5-1 and 5-4 and Figures 5-1 and 5-2 illustrates the conclusions stated above. The greatest reduction in 98th percentile dV and number of days above 0.5 dV is between the Baseline and Scenario 1. The incremental cost effectiveness for Scenario 1 compared to the Baseline for the Bridger WA, for example, is reasonable at \$210,000/day and \$4.78 Million/dV. However, the incremental cost effectiveness for Scenario 3 compared to Scenario 1, again for the Bridger WA, is excessive at \$3.30 Million/day and \$124.99 Million/dV. The same conclusions are reached for each of the three wilderness areas studied. Therefore, Scenario 1 represents BART for Jim Bridger 4.

5.2 Recommendations

5.2.1 NO_x Emission Control

The BART presumptive NO_x limit assigned by EPA for tangentially-fired boilers burning subbituminous coal is 0.15 lb/MMBtu. However, as documented in Section 3.2.1.1, the characteristics of the Jim Bridger coals are more closely aligned with bituminous coals, and have been assigned a presumptive BART NO_x limit of 0.28 lb/MMBtu.

CH2M HILL recommends low-NO_x burners with over-fire air (LNB w/OFA) as BART for Jim Bridger 4, based on the projected significant reduction in NO_x emissions, reasonable control costs, and the advantages of no additional power requirements or non-air quality environmental impacts. NO_x reductions are expected to be similar to those realized at Jim Bridger 2. CH2M HILL recommends that the unit be permitted at a rate of 0.26 lb/MMBtu.

5.2.2 SO₂ Emission Control

CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 4, based on the significant reduction in SO₂ emissions, reasonable control costs, and the advantages of minimal additional power requirements and minimal non-air quality environmental impacts. This upgrade approach will meet the BART presumptive SO₂ limit of 0.15 lb/MMBtu.

5.2.3 PM₁₀ Emission Control

CH2M HILL recommends finalizing the permitting of the flue gas conditioning system to enhance the performance of the existing electrostatic precipitator (ESP) as BART for Jim Bridger 4, based on the significant reduction in PM₁₀ emissions, reasonable control costs, and

the advantages of minimal additional power requirements and no non-air quality environmental impacts.

5.3 Just-Noticeable Differences in Atmospheric Haze

Conclusions reached in the reference document "Just-Noticeable Differences in Atmospheric Haze" by Dr. Ronald Henry of the University of Southern California (Appendix C), state that only dV differences of approximately 1.5 to 2.0 dV, or more are perceptible by the human eye. Deciview changes of less than 1.5 cannot be distinguished by the average person. Therefore, the modeling analysis results indicate that only minimal, if any, observable visibility improvements at the Class I areas studied would be expected under any of the scenarios. Thus the results indicate that even though many millions of dollars will be spent, only minimal if any visibility improvements may result.

Finally, it should be noted that none of the data were corrected for natural obscuration. Water in various forms (fog, clouds, snow, or rain) or other naturally caused aerosols may obscure the atmosphere and reduce visibility. During the period of 2001 through 2003, there were several mega-wildfires that lasted for many days, with a significant impact on background visibility in these Class I areas. If natural obscuration lessens the achievable reduction in visibility impacts modeled for BART controls at the Jim Bridger 4 facility, the overall effect would be to increase the costs per dV reduction that are presented in this report.

6.0 References

BART Air Modeling Protocol - Individual Source Visibility Assessments for BART Control Analyses. September, 2006.

Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule.

Multi-Pollutant Control Report. October, 2002, updated October 2006

Protocol for BART-Related Visibility Improvement Modeling Analysis in North Dakota. North Dakota Department of Health. October 26, 2005.

Regional Haze Regulations and Guidelines for Best Available Retrofit Technology Determinations; Final Rule (40 CFR Part 51; July 6, 2005, pg 39129)

S&L Study Multi-Pollutant Control Report. October, 2002, updated October 2006

United States Environmental Protection Agency, 1990. *New Source Review Workshop Manual - Prevention of Significant Deterioration and Nonattainment Area Permitting.* October 1990.

Appendices

APPENDIX A
Economic Analysis

PacifiCorp BART Analysis Report Tables

Jim Bridger Unit 4

TABLE 3-1
NO_x Control Technology Emission Rate Ranking
Jim Bridger Unit 4

Technology	Projected Emission Rate (lb/MMBtu)
LNB w/OFA	0.24
ROFA	0.22
LNB w/OFA & SNCR	0.20
LNB w/OFA & SCR	0.07

TABLE 3-2
NO_x Control Cost Comparison
Jim Bridger Unit 4

Factor	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR
Total Installed Capital Costs	\$ 8.7 Million	\$ 20.5 Million	\$ 22.1 Million	\$ 147.6 Million
Total First Year Fixed & Variable O&M Costs	\$ 0.1 Million	\$ 2.6 Million	\$ 1.5 Million	\$ 3.4 Million
Total First Year Annualized Cost	\$ 0.9 Million	\$ 4.6 Million	\$ 3.6 Million	\$ 17.4 Million
Power Consumption (MW)	-	6.41	0.53	3.36
Annual Power Usage (Million kW-Hr/Yr)	-	50.6	4.2	26.5
NO _x Design Control Efficiency	46.7%	51.1%	55.6%	84.4%
Tons NO _x Removed per Year	4,967	5,440	5,913	8,987
First Year Average Control Cost (\$/Ton of NO _x Removed)	181	843	613	1,936
Incremental Control Cost (\$/Ton of NO _x Removed)	181	7,797	2,885	4,479

TABLE 3-3
SO₂ Control Technology Emission Rate Ranking
Jim Bridger Unit 4

Control Technology	Short-Term Expected SO ₂ Emission Rate (Lb/MMBtu)
N/A	N/A
N/A	N/A
Upgraded Wet FGD	0.10

PacifiCorp BART Analysis Report Tables

Jim Bridger Unit 4

TABLE 3-4
SO₂ Control Cost Comparison
Jim Bridger Unit 4


Factor	N/A	N/A	Upgraded Wet FGD
Total Installed Capital Costs			5.8 Million
Total First Year Fixed & Variable O&M Costs			0.7 Million
Total First Year Annualized Cost			1.2 Million
Power Consumption (MW)			0.53
Annual Power Usage (Million kW-Hr/Yr)			4.2
SO ₂ Design Control Efficiency			40.1%
Tons SO ₂ Removed per Year			1,585
First Year Average Control Cost (\$/Ton of SO ₂ Removed)			761
Incremental Control Cost (\$/Ton of SO ₂ Removed)			761


TABLE 3-5
PM₁₀ Control Technology Emission Ranking
Jim Bridger Unit 4


Control Technology	Short-Term Expected PM ₁₀ Emission Rate (Lb/MMBtu)
Flue Gas Conditioning	0.030
Fabric Filter	0.015

TABLE 3-6
PM₁₀ Control Cost
Jim Bridger Unit 4

Factor	Flue Gas Conditioning	Fabric Filter
Total Installed Capital Costs	\$ - Million	\$ 48.4 Million
Total First Year Fixed & Variable Operations & Maintenance Costs	\$ 0.2 Million	\$ 1.8 Million
Total First Year Annualized Cost	\$ 0.2 Million	\$ 6.4 Million
Power Consumption (MW)	0.05	3.39
Annual Power Usage (Million kW-Hr/Yr)	0.4	26.7
PM Design Control Efficiency	0.00%	50.00%
Tons PM Removed per Year	0	355
First Year Average Control Cost (\$/Ton of PM Removed)	#DIV/0!	17,946
Incremental Control Cost (\$/Ton of SO ₂ Removed)	#DIV/0!	17,452







PacifiCorp BART Analysis Scenarios

Select Unit:		6	Jim Bridger Unit 4
Index No.	Name of Unit		
1	Dave Johnston Unit 3		
2	Dave Johnston Unit 4		
3	Jim Bridger Unit 1		
4	Jim Bridger Unit 2		
5	Jim Bridger Unit 3		
6	Jim Bridger Unit 4		
7	Naughton Unit 1		
8	Naughton Unit 2		
9	Naughton Unit 3		
10	Wyodak Unit 1		

Dave Johnston				Naughton					
DJ Unit 3		DJ Unit 4		NTN Unit 1		NTN Unit 2		NTN Unit 3	
Scenario	First Year Cost	Scenario	First Year Cost	Scenario	First Year Cost	Scenario	First Year Cost	Scenario	First Year Cost
Baseline - Current Operation with FGD, Existing ESP	N/A	Baseline - Current Operation with Venturi Scrubber	N/A	Baseline - Current Operation with ESP	N/A	Baseline - Current Operation with ESP	N/A	Baseline - Current Operation with Wet FGD and ESP	N/A
Scenario 1 - LNB with OFA, Dry FGD, Existing ESP	N/A	Scenario 1 - LNB with OFA, Dry FGD, Fabric Filter	N/A	Scenario 1 - LNB with OFA, Dry FGD, ESP	N/A	Scenario 1 - LNB with OFA, Dry FGD, ESP	N/A	Scenario 1 - LNB with OFA, Wet FGD, ESP	N/A
Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	N/A
Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	N/A	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	N/A	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	N/A	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	N/A	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	N/A
Scenario 4 - LNB with OFA and SCR, Wet FGD, Existing ESP, New Stack	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, ESP, New Stack	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, ESP, New Stack	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A
Jim Bridger				Wyodak					
JB Unit 1		JB Unit 2		JB Unit 3		JB Unit 4		WDK Unit 1	
Scenario	First Year Cost	Scenario	First Year Cost	Scenario	First Year Cost	Scenario	First Year Cost	Scenario	First Year Cost
Baseline - Current Operation with Wet FGD and ESP	N/A	Baseline - Current Operation with Wet FGD and ESP	N/A	Baseline - Current Operation with Wet FGD and ESP	N/A	Baseline - Current Operation with Wet FGD and ESP	N/A	Baseline - Current Operation with Dry FGD, Fabric Filter	N/A
Scenario 1 - LNB with OFA, Wet FGD, ESP	N/A	Scenario 1 - LNB with OFA, Wet FGD, ESP	N/A	Scenario 1 - LNB with OFA, Wet FGD, ESP	N/A	Scenario 1 - LNB with OFA, Wet FGD, ESP	\$ 2,104,213	Scenario 1 - LNB with OFA, Dry FGD, Fabric Filter	N/A
Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	\$ 2,104,213	Scenario 2 - LNB with OFA and SCR, Dry FGD, Fabric Filter	N/A
Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	N/A	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	N/A	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	N/A	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	\$ 8,470,832	Scenario 3 - LNB with OFA and SCR, Wet FGD, Fabric Filter, New Stack	N/A
Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	\$ 18,603,354	Scenario 4 - N/A	N/A
Scenario 5 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A	Scenario 5 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A	Scenario 5 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A	Scenario 5 - LNB with OFA and SCR, Wet FGD, Fabric Filter	\$ 18,603,354		
Scenario 6 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A	Scenario 6 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A	Scenario 6 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A	Scenario 6 - LNB with OFA and SCR, Wet FGD, Fabric Filter	\$ 24,565,973		
Scenario 7 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A	Scenario 7 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A	Scenario 7 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A	Scenario 7 - LNB with OFA and SCR, Wet FGD, Fabric Filter	\$ 24,565,973		

ECONOMIC ANALYSIS SUMMARY

Boiler Design: Tangential-Fired PC

Jim Bridger Unit 4

Parameter	NOx Control			SO2 Control		PM Control	
	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
Case	2	3	4	5	8	9	10
NOx Emission Control System	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	LNCFS-1 & Windbox Mods.	LNCFS-1 & Windbox Mods.	LNCFS-1 & Windbox Mods.
SO2 Emission Control System	Wet FGD ESP	Wet FGD ESP	Wet FGD ESP	Wet FGD ESP	Upgraded Wet FGD ESP	Wet FGD	Wet FGD
PM Emission Control System	Wet FGD ESP	Wet FGD ESP	Wet FGD ESP	Wet FGD ESP	Wet FGD	Flue Gas Conditioning	Fabric Filter
TOTAL INSTALLED CAPITAL COST (\$)	8,700,001	20,528,122	22,127,239	147,628,474	5,759,814	0	48,386,333
FIRST YEAR O&M COST (\$)	0	0	0	0	0	0	0
Operating Labor (\$)	0	0	0	0	0	0	0
Maintenance Material (\$)	28,000	42,000	123,000	190,000	25,550	0	51,099
Maintenance Labor (\$)	42,000	63,000	184,500	285,000	17,033	10,000	76,649
Administrative Labor (\$)	0	0	0	0	0	0	0
TOTAL FIXED O&M COST	70,000	105,000	307,500	475,000	42,583	10,000	127,749
Makeup Water Cost	0	0	0	0	15,539	0	0
Reagent Cost	0	0	1,005,811	912,848	213,921	145,854	0
SCR Catalyst / FF Bag Cost	0	0	0	642,000	0	0	300,040
Waste Disposal Cost	0	0	0	0	177,714	0	0
Electric Power Cost	0	2,528,012	208,926	1,323,329	208,926	19,710	1,335,944
TOTAL VARIABLE O&M COST	0	2,528,012	1,214,737	2,378,177	616,100	165,564	1,635,984
TOTAL FIRST YEAR O&M COST	70,000	2,633,012	1,522,237	3,353,177	659,683	175,564	1,763,732
FIRST YEAR DEBT SERVICE (\$)	0	1,952,796	2,104,916	14,043,575	547,919	0	4,602,887
TOTAL FIRST YEAR COST (\$)	8,700,001	22,480,918	24,232,155	161,671,652	6,307,733	0	53,989,220
Power Consumption (MW)	0.0	6.4	0.5	3.4	0.5	0.1	3.4
Annual Power Usage (Million kWh/Yr)	0.0	50.6	4.2	26.5	4.2	0.4	26.7
CONTROL COST (\$/Ton Removed)	0.0%	51.1%	55.6%	84.4%	0.0%	0.0%	0.0%
NOx Removal Rate (%)	46.7%	5,440	5,913	8,987	0	0	0
NOx Removed (Tons/Yr)	181	843	613	1,936	0	0	0
First Year Average Control Cost (\$/Ton NOx Rem.)	181	7,797	2,885	4,479	0	0	0
Incremental Control Cost (\$/Ton NOx Rem.)	2-1	3-2	4-2	5-4	0	0	0
SO2 Removal Rate (%)	86.1%	0.0%	0.0%	0.0%	40.1%	0.0%	0.0%
SO2 Removed (Tons/Yr)	0	0	0	0	4,685	0	0
First Year Average Control Cost (\$/Ton SO2 Rem.)	0	0	0	0	761	0	0
Incremental Control Cost (\$/Ton SO2 Rem.)	Base	0	0	0	761	0	0
PM Removal Rate (%)	95.65%	0.00%	0.00%	0.00%	0.00%	0.00%	50.00%
PM Removed (Tons/Yr)	0	0	0	0	0	0	355
First Year Average Control Cost (\$/Ton PM Rem.)	0	0	0	0	0	#DIV/0!	17,946
Incremental Control Cost (\$/Ton PM Rem.)	Base	0	0	0	0	#DIV/0!	17,452
PRESENT WORTH COST (\$)	0	52,697,883	40,725,706	188,697,104	13,807,503	2,145,015	69,935,356

INPUT CALCULATIONS

Boiler Design:

Tangential-Fired PC

Jim Bridger Unit 4

Parameter	Current Operation		NOx Control				SO2 Control		PM Control		Comments
	1	2	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	Upgraded Wet FGD	Wet FGD	Flue Gas Conditioning	Fabric Filter		
Case	LNCF-1 & Windbox Mods. Wet FGD	LNCF-1 & Windbox Mods. Wet FGD	ROFA Wet FGD	LNB w/OFA & SNCR Wet FGD	LNB w/OFA & SCR Wet FGD	LNCF-1 & Windbox Mods. Upgraded Wet FGD	LNCF-1 & Windbox Mods. Wet FGD	LNCF-1 & Windbox Mods. Wet FGD	LNCF-1 & Windbox Mods. Wet FGD		
Unit Design and Coal Characteristics	PC	PC	PC	PC	PC	PC	PC	PC	PC		
Type of Unit	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000		
Net Power Output (kW)	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320		
Net Plant Heat Rate (Btu/kWhr)	Bridger Mine	Bridger Mine	Bridger Mine	Bridger Mine	Bridger Mine	Bridger Mine	Bridger Mine	Bridger Mine	Bridger Mine		
Boiler Fuel	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660		
Coal Heating Value (Btu/Lb)	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%		
Coal Sulfur Content (wt.%)	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%		
Coal Ash Content (wt.%)	6.00%	6.00%	6.00%	6.00%	6.00%	6.00%	6.00%	6.00%	6.00%		
Boiler Heat Input, each (MMBtu/Hr)	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077		
Coal Flow Rate (Lb/Hr)	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284		
(Ton/Yr)	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846		
(MMBtu/Yr)											
Emissions											
Uncontrolled SO2 (Lb/Hr)	7,210	1,002	1,002	1,002	1,002	1,002	1,002	1,002	1,002		
(Lb/MMBtu)	1,20	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17		
(Lb Moles/Hr)	112,64	15,64	15,64	15,64	15,64	15,64	15,64	15,64	15,64		
(Tons/Yr)	20,421	3,950	3,950	3,950	3,950	3,950	3,950	3,950	3,950		
SO2 Removal Rate (%)	86.1%	0.0%	0.0%	0.0%	0.0%	40.1%	0.0%	0.0%	0.0%		
(Lb/Hr)	6,208	0	0	0	0	402	0	0	0		
(Ton/Yr)	24,471	0	0	0	0	1,585	0	0	0		
SO2 Emission Rate (Lb/Hr)	1,002	1,002	1,002	1,002	1,002	600	1,002	1,002	1,002		
(Lb/MMBtu)	0.17	0.17	0.17	0.17	0.17	0.10	0.17	0.17	0.17		
(Ton/Yr)	3,950	3,950	3,950	3,950	3,950	2,365	3,950	3,950	3,950		
Uncontrolled NOx (Lb/Hr)	2,700	2,700	2,700	2,700	2,700	2,700	2,700	2,700	2,700		
(Lb/MMBtu)	0.46	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45		
(Lb Moles/Hr)	89,96	89,96	89,96	89,96	89,96	89,96	89,96	89,96	89,96		
(Tons/Yr)	10,643	10,643	10,643	10,643	10,643	10,643	10,643	10,643	10,643		
NOx Removal Rate (%)	0.0%	46.7%	51.1%	55.6%	55.6%	0.0%	0.0%	0.0%	0.0%		
(Lb/Hr)	0	1,260	1,380	1,500	1,500	0	0	0	0		
(Lb Moles/Hr)	0	41,98	45,98	49,98	49,98	0	0	0	0		
(Ton/Yr)	0	4,967	5,440	5,913	5,913	0	0	0	0		
NOx Emission Rate (Lb/Hr)	2,700	1,440	1,320	1,200	1,200	2,700	2,700	2,700	2,700		
(Lb/MMBtu)	0.45	0.24	0.22	0.20	0.20	0.45	0.45	0.45	0.45		
(Ton/Yr)	10,643	5,676	5,203	4,730	4,730	10,643	10,643	10,643	10,643		
Uncontrolled Fly Ash (Lb/Hr)	61,177	180	180	180	180	180	180	180	180		
(Lb/MMBtu)	8,530	0.030	0.030	0.030	0.030	0.030	0.030	0.030	0.030		
(Lb Moles/Hr)	1,705.3	6.0	6.0	6.0	6.0	6.0	6.0	6.0	6.0		
(Tons/Yr)	201,739	710	710	710	710	710	710	710	710		
Fly Ash Removal Rate (%)	99.65%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%		
(Lb/Hr)	60,997	0	0	0	0	0	0	0	0		
(Ton/Yr)	201,029	0	0	0	0	0	0	0	0		
Fly Ash Emission Rate (Lb/Hr)	180	180	180	180	180	180	180	180	180		
(Lb/MMBtu)	0.030	0.030	0.030	0.030	0.030	0.030	0.030	0.030	0.030		
(Ton/Yr)	710	710	710	710	710	710	710	710	710		

Parameter	Current Operation		NOx Control				SO2 Control		PM Control			Comments
	1	2	ROFA	LNB w/OFA & SNCR	LNB w/OFA	LNB w/OFA	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter	9	10	
Case	1		3	4	5	8						
General Plant Data												
Annual Operations (Hours/Year)	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	
Annual On-Site Power Plant Capacity Factor	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	
Economic Factors												
Interest Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	
Discount Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	
Plant Economic Life (Years)	20	20	20	20	20	20	20	20	20	20	20	
Installed Capital Costs												
NOx Emission Control System (\$2006)	0	8,700,001	20,528,122	22,127,239	147,628,474	5,795,814	0	0	0	0	0	
SO2 Emission Control System (\$2006)	0	0	0	0	0	0	5,795,814	0	0	0	0	
PM Emission Control System (\$2006)	0	8,700,001	20,528,122	22,127,239	147,628,474	5,795,814	0	0	0	0	48,386,333	
Total Emission Control Systems (\$2006)	0	16	39	42	279	0	0	0	0	0	48,386,333	
NOx Emission Control System (\$/kW)	0	0	0	0	0	11	0	0	0	0	0	
SO2 Emission Control System (\$/kW)	0	0	0	0	0	0	0	0	0	0	0	
PM Emission Control System (\$/kW)	0	0	0	0	0	0	0	0	0	0	0	
Total Emission Control Systems (\$/kW)	0	16	39	42	279	11	0	0	0	0	0	
Total Fixed Operating & Maintenance Costs												
Operating Labor (\$)	0	0	0	0	0	0	0	0	0	0	0	
Maintenance Material (\$)	0	28,000	42,000	123,000	190,000	25,550	0	0	0	0	51,099	
Maintenance Labor (\$)	0	42,000	63,000	184,500	285,000	17,033	0	10,000	0	0	76,649	
Administrative Labor (\$)	0	0	0	0	0	0	0	0	0	0	0	
Total Fixed O&M Cost (\$)	0	70,000	105,000	307,500	475,000	42,583	0	10,000	0	0	127,749	
Annual Fixed O&M Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Water Cost												
Makeup Water Usage (Gpm)	0	0	0	0	0	0	0	0	0	0	0	
Unit Price (\$/1000 Gallons)	1.22	1.22	1.22	0.00	1.22	1.22	1.22	1.22	1.22	1.22	1.22	
First Year Water Cost (\$)	0	0	0	0	0	0	0	0	0	0	0	
Annual Water Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Reagent Cost												
Unit Cost (\$/Ton)	None	None	None	Urea	Anhydrous NH3	Soda Ash	Elemental Sulfur	None	None	None	None	
(\$/Lb)	0.00	0.00	0.00	370	400	80.00	370	0.00	0.00	0.00	0.00	
Molar Stoichiometry	0.000	0.000	0.000	0.185	0.200	0.040	0.185	0.000	0.000	0.000	0.000	
Reagent Purity (Wt.%)	0.00	0.00	0.00	0.45	1.00	1.02	1.00	0.00	0.00	0.00	0.00	
Reagent Usage (Lb/Hr)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
First Year Reagent Cost (\$)	0	0	0	690	578	678	100	0	0	0	0	
Annual Reagent Cost Escalation Rate (%)	2.00%	2.00%	2.00%	1,005,811	912,848	213,921	145,954	0	0	0	0	
SCR Catalyst / FF Bag Replacement Cost												
Annual SCR Catalyst (m3) / No. FF Bags	0	0	0	0	214	0	0	0	0	0	0	
SCR Catalyst (\$/m3) / Bag Cost (\$/ea.)	3,000	3,000	3,000	3,000	3,000	104	3,000	3,000	3,000	3,000	3,000	
First Year SCR Catalyst / Bag Replacem. Cost (\$)	0	0	0	0	642,000	0	0	0	0	0	0	
Annual SCR Catalyst / Bag Cost Esc. Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
FGD Waste Disposal Cost												
FGD Solid Waste Disposal Rate, Dry (Lb/Hr)	0	0	0	0	0	1,853	0	0	0	0	0	
FGD Waste Disposal Unit Cost (\$/Dry Ton)	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	
First Year FGD Waste Disposal Cost (\$)	0	0	0	0	0	177,714	0	0	0	0	0	
Annual Waste Disposal Cost Esc. Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Auxiliary Power Cost												
Auxiliary Power Requirement (% of Plant Output)	0.00%	0.00%	1.21%	0.10%	0.53%	0.10%	0.01%	0.01%	0.54%	0.01%	0.54%	
Unit Cost (\$2006/MW-Hr)	0.00	0.00	6.41	0.53	3.36	0.53	0.05	0.05	3.39	0.05	3.39	
First Year Auxiliary Power Cost (\$)	0	0	50,000	50,000	50,000	50,000	50,000	50,000	50,000	50,000	50,000	
Annual Power Cost Escalation Rate (%)	2.00%	2.00%	2,528,012	208,926	1,323,329	208,926	15,710	15,710	1,335,944	15,710	1,335,944	

Input Tables

Table 1 - Cases

Index No.	Name of Unit Case	SO2 Control										PM Control											
		Existing	1	2	3	4	5	6	7	8	9	10	1	2	3	4	5	6	7	8	9	10	
1	Dave Johnston Unit 3	Current Operation	LNB w/OFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Dry FGD w/ESP	Dry FGD w/Fabric Filter	Wet FGD w/ESP	Wet FGD w/Fabric Filter	Fabric Filter	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	Dave Johnston Unit 4	Current Operation	LNB w/OFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	LNB w/OFA & SNCR	N/A	Dry FGD w/Fabric Filter	Wet FGD w/ESP	Wet FGD w/Fabric Filter	Fabric Filter	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning
3	Jim Bridger Unit 1	Current Operation	LNB w/OFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	LNB w/OFA & SNCR	N/A	N/A	Wet FGD w/ESP	Wet FGD w/Fabric Filter	Fabric Filter	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning
4	Jim Bridger Unit 2	Current Operation	Exhst. LNB w/OFA	SNCR	SNCR	SNCR	N/A	N/A	Wet FGD w/ESP	Wet FGD w/Fabric Filter	Fabric Filter	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning
5	Jim Bridger Unit 3	Current Operation	LNB w/OFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	LNB w/OFA & SNCR	N/A	N/A	Wet FGD w/ESP	Wet FGD w/Fabric Filter	Fabric Filter	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning
6	Jim Bridger Unit 4	Current Operation	LNB w/OFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	LNB w/OFA & SNCR	N/A	N/A	Wet FGD w/ESP	Wet FGD w/Fabric Filter	Fabric Filter	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning
7	Naughton Unit 1	Current Operation	LNB w/OFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Dry FGD w/ESP	Dry FGD w/Fabric Filter	Wet FGD w/ESP	Wet FGD w/Fabric Filter	Fabric Filter	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning
8	Naughton Unit 2	Current Operation	LNB w/OFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Dry FGD w/ESP	Dry FGD w/Fabric Filter	Wet FGD w/ESP	Wet FGD w/Fabric Filter	Fabric Filter	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning
9	Naughton Unit 3	Current Operation	LNB w/OFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	LNB w/OFA & SNCR	N/A	N/A	Wet FGD w/ESP	Wet FGD w/Fabric Filter	Fabric Filter	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning
10	Wyodak Unit 1	Current Operation	LNB w/OFA	LNB w/OFA & SNCR	LNB w/OFA & SNCR	LNB w/OFA & SNCR	Upgraded Dry FGD	N/A	Wet FGD	Wet FGD	Fabric Filter	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning	Flue Gas Conditioning

Table 2 - Unit Design and Coal Characteristics

Index No.	Name of Unit	Current Emission Control Systems				Unit Design			Coal Quality			
		NOx	SO2	PM	None	Boiler Design	Net Power Output (MW)	Nat Plant Heat Rate (Btu/kWh-Hr)	Coal	Heating Value, HHV (Btu/lb)	Sulfur Content (Wt.%)	Ash Content (Wt.%)
1	Dave Johnston Unit 3	None	None	ESP	None	3-Coal Burner, Opposed Wall-Fired PC	250,000	11,200	Dry Fork PNB	7,784	0.47%	5.01%
2	Dave Johnston Unit 4	Windbox Mode, LINCFS-I & Windbox Mode	Lime Added to Venturi Scrubber	Venturi Scrubber	None	Tangential-Fired PC	360,000	11,390	Dry Fork PNB Underground	7,784	0.47%	5.01%
3	Jim Bridger Unit 1	None	Wet FGD	ESP	None	Tangential-Fired PC	530,000	11,320	Bridger Mine Underground	9,660	0.58%	10.30%
4	Jim Bridger Unit 2	LNB - TFS 2000	Wet FGD	ESP	None	Tangential-Fired PC	530,000	11,320	Bridger Mine Underground	9,660	0.58%	10.30%
5	Jim Bridger Unit 3	Windbox Mode, LINCFS-I & Windbox Mode	Wet FGD	ESP	None	Tangential-Fired PC	530,000	11,320	Bridger Mine Underground	9,660	0.58%	10.30%
6	Jim Bridger Unit 4	None	Wet FGD	ESP	None	Tangential-Fired PC	530,000	11,320	Bridger Mine Underground	9,660	0.58%	10.30%
7	Naughton Unit 1	None	None	ESP	None	Tangential-Fired PC	173,000	10,694	Kemmerer Mine	9,970	0.60%	4.64%
8	Naughton Unit 2	None	None	ESP	None	Tangential-Fired PC	226,000	10,574	Kemmerer Mine	9,970	0.60%	4.64%
9	Naughton Unit 3	LINCFS II LNB	Wet FGD	ESP	None	Tangential-Fired PC	356,000	10,336	Kemmerer Mine	9,970	0.60%	4.64%
10	Wyodak Unit 1	LNB	Dry FGD	ESP	None	Opposed Wall-Fired PC	335,000	12,067	Clewis Point Mine	7,977	0.65%	7.46%

Table 3 - Emissions

Index No.	Name of Unit	Current Emission Rates (Lb/MMBtu)		NOx Control Emission Rates (Lb/MMBtu)		SO2 Control Emission Rates (Lb/MMBtu)		PM Emission Rates (Lb/MMBtu)				
		Controlled	Controlled NOx	Case 2	Case 3	Case 4	Case 5	Case 6	Case 7	Case 8	Case 9	Case 10
1	Dave Johnston Unit 3	1.20	0.70	0.27	0.21	0.20	0.07	0.21	0.15	0.10	N/A	0.015
2	Dave Johnston Unit 4	0.33	0.48	0.15	0.19	0.12	0.07	N/A	0.15	0.10	N/A	0.015
3	Jim Bridger Unit 1	0.27	0.45	0.24	0.22	0.20	0.07	N/A	N/A	0.10	0.030	0.015
4	Jim Bridger Unit 2	0.27	0.24	0.24	0.22	0.20	0.07	N/A	N/A	0.10	0.030	0.015
5	Jim Bridger Unit 3	0.27	0.45	0.24	0.22	0.20	0.07	N/A	N/A	0.10	0.030	0.015
6	Jim Bridger Unit 4	0.17	0.45	0.24	0.22	0.20	0.07	N/A	N/A	0.10	0.030	0.015
7	Naughton Unit 1	1.20	0.59	0.24	0.28	0.18	0.18	0.18	0.15	0.10	0.040	0.015
8	Naughton Unit 2	1.20	0.64	0.24	0.24	0.18	0.07	0.18	0.15	0.10	0.040	0.015
9	Naughton Unit 3	0.50	0.45	0.35	0.30	0.25	0.07	N/A	N/A	0.10	0.040	0.015
10	Wyodak Unit 1	0.50	0.50	0.25	0.22	0.18	0.07	0.25	N/A	0.10	0.025	0.015

Table 4 - Case 1 O&M Costs (Current Operation)

Index No.	Name of Unit	Annual Fixed O&M Costs					Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Reagent	Reagent Molar Stoich.	Aux. Power Usage (MW)	Makeup Water Use (Gpm)	
1	Dave Johnston Unit 3	\$ -	\$ -	\$ -	\$ -	None	-	-	-	
2	Dave Johnston Unit 4	\$ -	\$ -	\$ -	\$ -	None	-	-	-	
3	Jim Bridger Unit 1	\$ -	\$ -	\$ -	\$ -	None	-	-	-	
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	None	-	-	-	
5	Jim Bridger Unit 3	\$ -	\$ -	\$ -	\$ -	None	-	-	-	
6	Jim Bridger Unit 4	\$ -	\$ -	\$ -	\$ -	None	-	-	-	
7	Naughton Unit 1	\$ -	\$ -	\$ -	\$ -	None	-	-	-	
8	Naughton Unit 2	\$ -	\$ -	\$ -	\$ -	None	-	-	-	
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	None	-	-	-	
10	Wyodak Unit 1	\$ -	\$ -	\$ -	\$ -	None	-	-	-	

Table 5 - Case 2 O&M Costs (LNB w/OFA)

Index No.	Name of Unit	Annual Fixed O&M Costs					Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Reagent	Reagent Molar Stoich.	Aux. Power Usage (MW)	Makeup Water Use (Gpm)	
1	Dave Johnston Unit 3	\$ -	\$ 40,000	\$ 60,000	\$ -	None	-	-	-	
2	Dave Johnston Unit 4	\$ -	\$ 36,000	\$ 54,000	\$ -	None	-	-	-	
3	Jim Bridger Unit 1	\$ -	\$ 28,000	\$ 42,000	\$ -	None	-	-	-	
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	None	-	-	-	
5	Jim Bridger Unit 3	\$ -	\$ 28,000	\$ 42,000	\$ -	None	-	-	-	
6	Jim Bridger Unit 4	\$ -	\$ 32,000	\$ 48,000	\$ -	None	-	-	-	
7	Naughton Unit 1	\$ -	\$ 32,000	\$ 48,000	\$ -	None	-	-	-	
8	Naughton Unit 2	\$ -	\$ -	\$ -	\$ -	None	-	-	-	
9	Naughton Unit 3	\$ -	\$ 24,000	\$ 36,000	\$ -	None	-	-	-	
10	Wyodak Unit 1	\$ -	\$ -	\$ -	\$ -	None	-	-	-	

Table 6 - Case 3 O&M Costs (Mobotec ROFA)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent Stoich.	Reagent Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ 60,000	\$ 90,000	\$ -	-	None	-	2.76
2	Dave Johnston Unit 4	\$ -	\$ 54,000	\$ 81,000	\$ -	-	None	-	4.33
3	Jim Bridger Unit 1	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41
4	Jim Bridger Unit 2	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41
5	Jim Bridger Unit 3	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41
6	Jim Bridger Unit 4	\$ -	\$ 42,000	\$ 63,000	\$ -	-	None	-	6.41
7	Naughton Unit 1	\$ -	\$ 48,000	\$ 72,000	\$ -	-	None	-	1.42
8	Naughton Unit 2	\$ -	\$ 48,000	\$ 72,000	\$ -	-	None	-	2.61
9	Naughton Unit 3	\$ -	\$ 48,000	\$ 72,000	\$ -	-	None	-	4.47
10	Wyodak Unit 1	\$ -	\$ 36,000	\$ 54,000	\$ -	-	None	-	5.22

Table 7 - Case 4 O&M Costs (LNB w/ROFA & SNCR)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent Stoich.	Reagent Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ 98,000	\$ 147,000	\$ -	-	Urea	0.41	0.23
2	Dave Johnston Unit 4	\$ -	\$ 105,000	\$ 157,500	\$ -	-	Urea	0.45	0.33
3	Jim Bridger Unit 1	\$ -	\$ 123,000	\$ 184,500	\$ -	-	Urea	0.45	0.53
4	Jim Bridger Unit 2	\$ -	\$ 95,000	\$ 142,500	\$ -	-	Urea	0.45	0.53
5	Jim Bridger Unit 3	\$ -	\$ 122,000	\$ 183,000	\$ -	-	Urea	0.45	0.52
6	Jim Bridger Unit 4	\$ -	\$ 123,000	\$ 184,500	\$ -	-	Urea	0.45	0.53
7	Naughton Unit 1	\$ -	\$ 83,000	\$ 124,500	\$ -	-	Urea	0.45	0.16
8	Naughton Unit 2	\$ -	\$ 93,000	\$ 139,500	\$ -	-	Urea	0.51	0.22
9	Naughton Unit 3	\$ -	\$ 75,000	\$ 112,500	\$ -	-	Urea	0.45	0.33
10	Wyodak Unit 1	\$ -	\$ 93,000	\$ 139,500	\$ -	-	Urea	0.45	0.34

Table 8 - Case 5 O&M Costs (LNB w/ROFA & SCR)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent Stoich.	Reagent Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ -	\$ 155,000	\$ 232,500	\$ -	-	Anhydrous NH3	1.00	1.57
2	Dave Johnston Unit 4	\$ -	\$ 165,000	\$ 249,000	\$ -	-	Anhydrous NH3	1.00	2.29
3	Jim Bridger Unit 1	\$ -	\$ 190,000	\$ 285,000	\$ -	-	Anhydrous NH3	1.00	3.28
4	Jim Bridger Unit 2	\$ -	\$ 162,000	\$ 243,000	\$ -	-	Anhydrous NH3	1.00	3.25
5	Jim Bridger Unit 3	\$ -	\$ 190,000	\$ 285,000	\$ -	-	Anhydrous NH3	1.00	3.22
6	Jim Bridger Unit 4	\$ -	\$ 190,000	\$ 285,000	\$ -	-	Anhydrous NH3	1.00	2.14
7	Naughton Unit 1	\$ -	\$ 132,000	\$ 198,000	\$ -	-	Anhydrous NH3	1.00	0.98
8	Naughton Unit 2	\$ -	\$ 160,000	\$ 240,000	\$ -	-	Anhydrous NH3	1.00	1.34
9	Naughton Unit 3	\$ -	\$ 155,000	\$ 234,000	\$ -	-	Anhydrous NH3	1.00	1.99
10	Wyodak Unit 1	\$ -	\$ 181,000	\$ 271,500	\$ -	-	Anhydrous NH3	1.00	2.42

Table 9 - Case 6 O&M Costs (Dry FGD)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (gpm)	Reagent	Reagent Stoich.	Annual FF Bag Replaces.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 506,128	\$ 714,175	\$ 476,928	\$ -	173	Line	1.15	-	2.49
2	Dave Johnston Unit 4	\$ -	\$ -	\$ -	\$ -	-	Line	-	-	-
3	Jim Bridger Unit 1	\$ -	\$ -	\$ -	\$ -	-	Line	-	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	-	Line	-	-	-
5	Jim Bridger Unit 3	\$ -	\$ -	\$ -	\$ -	-	Line	-	-	-
6	Jim Bridger Unit 4	\$ -	\$ -	\$ -	\$ -	-	Line	-	-	-
7	Naughton Unit 1	\$ 506,128	\$ 587,643	\$ 391,762	\$ -	120	Line	1.40	-	1.64
8	Naughton Unit 2	\$ 506,128	\$ 860,174	\$ 573,044	\$ -	165	Line	1.40	-	2.25
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	-	Line	-	-	-
10	Wyodak Unit 1	\$ -	\$ 21,900	\$ 14,600	\$ -	25	Line	1.10	-	0.11

Table 10 - Case 7 O&M Costs (Dry FGD w/Fabric Filter)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (gpm)	Reagent	Reagent Stoich.	Annual FF Bag Replaces.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 506,128	\$ 714,175	\$ 476,928	\$ -	173	Line	1.15	1,457	3.88
2	Dave Johnston Unit 4	\$ 506,128	\$ 1,102,288	\$ 734,859	\$ -	248	Line	1.10	1,798	4.54
3	Jim Bridger Unit 1	\$ -	\$ -	\$ -	\$ -	-	Line	-	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	-	Line	-	-	-
5	Jim Bridger Unit 3	\$ -	\$ -	\$ -	\$ -	-	Line	-	-	-
6	Jim Bridger Unit 4	\$ -	\$ -	\$ -	\$ -	-	Line	-	-	-
7	Naughton Unit 1	\$ 506,128	\$ 532,660	\$ 459,286	\$ -	120	Line	1.15	865	2.66
8	Naughton Unit 2	\$ 506,128	\$ 905,190	\$ 640,568	\$ -	165	Line	1.15	1,193	3.63
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	-	Line	-	-	-
10	Wyodak Unit 1	\$ -	\$ -	\$ -	\$ -	-	Line	-	-	-

Table 11 - Case 8 O&M Costs (Wet FGD)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements				
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (gpm)	Reagent	Reagent Stoich.	Annual FF Bag Replaces.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 809,804	\$ 1,182,587	\$ 785,391	\$ -	230	Line	1.02	-	3.45
2	Dave Johnston Unit 4	\$ 809,804	\$ 1,430,784	\$ 953,856	\$ -	330	Line	1.02	1,798	6.29
3	Jim Bridger Unit 1	\$ -	\$ 25,550	\$ 17,033	\$ -	53	Soda Ash	1.02	-	0.53
4	Jim Bridger Unit 2	\$ -	\$ 25,550	\$ 17,033	\$ -	53	Soda Ash	1.02	-	0.53
5	Jim Bridger Unit 3	\$ -	\$ 25,550	\$ 17,033	\$ -	52	Soda Ash	1.02	-	0.52
6	Jim Bridger Unit 4	\$ -	\$ 25,550	\$ 17,033	\$ -	27	Soda Ash	1.02	-	0.52
7	Naughton Unit 1	\$ 809,804	\$ 963,589	\$ 642,393	\$ -	160	Line	1.05	-	2.40
8	Naughton Unit 2	\$ 809,804	\$ 1,225,386	\$ 817,591	\$ -	220	Line	1.05	-	3.30
9	Naughton Unit 3	\$ -	\$ 21,900	\$ 14,600	\$ -	66	Soda Ash	1.02	-	0.33
10	Wyodak Unit 1	\$ 303,677	\$ 328,496	\$ 216,996	\$ -	82	Line	1.02	-	1.75

Table 12 - Case 9 O&M Costs (Flue Gas Conditioning)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements					
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Usage (Lb/Hr)	Annual FF Bag Replace.	Aux. Power Usage (MW)	
1	Dave Johnston Unit 3	\$ -	\$ -	\$ -	\$ -	-	None	-	-	-	
2	Dave Johnston Unit 4	\$ -	\$ -	\$ -	\$ -	-	None	-	-	-	
3	Jim Bridger Unit 1	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	100	-	0.05	
4	Jim Bridger Unit 2	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	100	-	0.05	
5	Jim Bridger Unit 3	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	100	-	0.05	
6	Jim Bridger Unit 4	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	100	-	0.05	
7	Naughton Unit 1	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	33	-	0.05	
8	Naughton Unit 2	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	43	-	0.05	
9	Naughton Unit 3	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	87	-	0.05	
10	Wyodak Unit 1	\$ -	\$ -	\$ 10,000	\$ -	-	Elemental Sulfur	83	-	0.05	

Table 13 - Case 10 O&M Costs (Fabric Filter)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements					
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoich.	Annual FF Bag Replace.	Aux. Power Usage (MW)	
1	Dave Johnston Unit 3	\$ -	\$ 45,016	\$ 67,524	\$ -	-	None	-	1,457	1.38	
2	Dave Johnston Unit 4	\$ -	\$ 65,153	\$ 102,199	\$ -	-	None	-	1,798	2.55	
3	Jim Bridger Unit 1	\$ -	\$ 51,099	\$ 76,649	\$ -	-	None	-	2,885	3.39	
4	Jim Bridger Unit 2	\$ -	\$ 51,099	\$ 76,649	\$ -	-	None	-	2,885	3.37	
5	Jim Bridger Unit 3	\$ -	\$ 51,099	\$ 76,649	\$ -	-	None	-	2,827	3.33	
6	Jim Bridger Unit 4	\$ -	\$ 51,099	\$ 76,649	\$ -	-	None	-	2,885	3.39	
7	Naughton Unit 1	\$ -	\$ 45,016	\$ 67,524	\$ -	-	None	-	865	1.01	
8	Naughton Unit 2	\$ -	\$ 45,016	\$ 67,524	\$ -	-	None	-	1,193	1.38	
9	Naughton Unit 3	\$ -	\$ 48,666	\$ 72,999	\$ -	-	None	-	1,799	2.06	
10	Wyodak Unit 1	\$ -	\$ 48,666	\$ 72,999	\$ -	-	None	-	1,798	2.06	

Table 14 - Major Materials Design and Supply Costs

Index No.	Name of Unit Case →	NOx Control			SO2 Control			PM Control	
		2	3	4	6	7	8	9	10
1	Dave Johnston Unit 3	\$ 3,221,912	\$ 3,556,617	\$ 5,773,000	\$ 83,871,000	\$ 142,077,000	\$ 108,665,669	\$ -	\$ 18,359,000
2	Dave Johnston Unit 4	\$ 2,673,501	\$ 4,343,192	\$ 7,171,085	\$ -	\$ 137,267,000	\$ 176,174,384	\$ -	\$ 30,853,530
3	Jim Bridger Unit 1	\$ 2,981,982	\$ 6,056,955	\$ 9,528,000	\$ 80,923,000	\$ -	\$ 8,010,033	\$ -	\$ 29,814,000
4	Jim Bridger Unit 2	\$ 2,981,982	\$ 6,056,955	\$ 9,419,000	\$ 80,923,000	\$ -	\$ 8,010,033	\$ -	\$ 29,814,000
5	Jim Bridger Unit 3	\$ 2,981,982	\$ 6,056,955	\$ 9,528,000	\$ 93,009,000	\$ -	\$ 3,549,000	\$ -	\$ 29,814,000
6	Jim Bridger Unit 4	\$ 2,981,982	\$ 6,056,955	\$ 9,528,000	\$ 37,232,000	\$ 42,301,000	\$ 44,000,000	\$ 800,000	\$ 15,482,000
7	Naughton Unit 1	\$ 2,502,123	\$ 2,675,792	\$ 7,257,000	\$ 47,834,000	\$ 57,621,000	\$ 56,000,000	\$ 800,000	\$ 18,359,000
8	Naughton Unit 2	\$ 2,570,674	\$ 4,351,377	\$ 11,203,578	\$ 67,373,000	\$ -	\$ 2,963,000	\$ 800,000	\$ 20,706,000
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ 72,479,000	\$ -	\$ -	\$ 1,247,061	\$ -
10	Wyodak Unit 1	\$ 3,187,636	\$ 4,500,245	\$ 7,234,860	\$ 986,100	\$ -	\$ 176,174,384	\$ -	\$ 20,706,000

CAPITAL COST

Jim Bridger Unit 4

Parameter	NOx Control			SO2 Control			PM Control		
	LNB w/OFA 2	ROFA 3	LNB w/OFA & SNCR 4	LNB w/OFA & SCR 5	N/A 6	N/A 7	Upgraded Wet FGD 8	Flue Gas Conditioning 9	Fabric Filter 10
Case	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	N/A	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
NOx Emission Control System	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	N/A	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
SO2 Emission Control System	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	N/A	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
PM Emission Control System	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	N/A	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
CAPITAL COST COMPONENT									
Major Materials Design and Supply	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	N/A	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
Construction	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	N/A	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
Balance of Plant	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	N/A	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
Electrical (allowance)	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	N/A	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
Construction Costs	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	N/A	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
Startups	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	N/A	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
AFUDC	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	N/A	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
Subtotal									
Contingency									
Total Capital Cost for LNB w/OFA or ROFA									
SNCR or SCR									
Major Materials Design and Supply									
Construction									
Labor Premium									
EPC Premium									
Boiler Reinforcement (Allowance)									
Sales Tax									
Excitation									
Agency on Address									
Startups and AFUDC									
Total Capital Cost for SNCR or SCR									
Dry or Wet FGD, FGC or Fabric Filter									
Major Materials Design and Supply									
Construction									
Labor Premium									
EPC Premium									
Boiler Reinforcement (Allowance)									
Sales Tax									
Excitation									
Contingency on Address									
Startups and AFUDC									
Total Capital Cost for Dry/Wet FGD, FGC or FF									

Jim Bridger Unit 4											
LNB w/OFA											
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)
0	2013										
1	2014	70,000	-	-	-	-	-	-	827,612	897,612	181
2	2015	71,400	-	-	-	-	-	-	827,612	899,012	181
3	2016	72,828	-	-	-	-	-	-	827,612	900,440	181
4	2017	74,285	-	-	-	-	-	-	827,612	901,897	182
5	2018	75,770	-	-	-	-	-	-	827,612	903,382	182
6	2019	77,286	-	-	-	-	-	-	827,612	904,888	182
7	2020	78,831	-	-	-	-	-	-	827,612	906,443	183
8	2021	80,408	-	-	-	-	-	-	827,612	908,020	183
9	2022	82,016	-	-	-	-	-	-	827,612	909,628	183
10	2023	83,656	-	-	-	-	-	-	827,612	911,269	183
11	2024	85,330	-	-	-	-	-	-	827,612	912,942	184
12	2025	87,036	-	-	-	-	-	-	827,612	914,648	184
13	2026	88,777	-	-	-	-	-	-	827,612	916,389	185
14	2027	90,552	-	-	-	-	-	-	827,612	918,165	185
15	2028	92,364	-	-	-	-	-	-	827,612	919,976	185
16	2029	94,211	-	-	-	-	-	-	827,612	923,823	188
17	2030	96,095	-	-	-	-	-	-	827,612	925,629	188
18	2031	98,017	-	-	-	-	-	-	827,612	927,589	187
19	2032	99,977	-	-	-	-	-	-	827,612	929,588	187
20	2033	101,977	-	-	-	-	-	-	827,612	931,626	187
Present Worth [% of PW]		855,250	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	8,700,001	9,555,250	100.0%


Jim Bridger Unit 4											
ROFA											
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)
0	2013										
1	2014	105,000	-	-	-	-	2,528,012	2,628,012	1,952,796	4,580,808	843
2	2015	107,100	-	-	-	-	2,578,573	2,678,573	1,952,796	4,638,468	853
3	2016	109,242	-	-	-	-	2,630,144	2,690,144	1,952,796	4,692,182	863
4	2017	111,427	-	-	-	-	2,682,747	2,742,747	1,952,796	4,746,970	873
5	2018	113,655	-	-	-	-	2,736,402	2,796,402	1,952,796	4,802,853	883
6	2019	115,928	-	-	-	-	2,791,130	2,851,130	1,952,796	4,859,854	893
7	2020	118,247	-	-	-	-	2,846,953	2,906,953	1,952,796	4,917,885	904
8	2021	120,612	-	-	-	-	2,903,892	2,963,892	1,952,796	4,977,289	915
9	2022	123,024	-	-	-	-	2,961,970	3,021,970	1,952,796	5,037,769	926
10	2023	125,485	-	-	-	-	3,021,209	3,081,633	1,952,796	5,099,489	937
11	2024	127,984	-	-	-	-	3,081,633	3,143,266	1,952,796	5,162,423	949
12	2025	130,554	-	-	-	-	3,143,266	3,206,131	1,952,796	5,226,616	961
13	2026	133,165	-	-	-	-	3,206,131	3,270,254	1,952,796	5,292,092	973
14	2027	135,829	-	-	-	-	3,270,254	3,335,659	1,952,796	5,358,878	985
15	2028	138,545	-	-	-	-	3,335,659	3,402,372	1,952,796	5,427,000	998
16	2029	141,316	-	-	-	-	3,402,372	3,470,419	1,952,796	5,496,484	1,010
17	2030	144,142	-	-	-	-	3,470,419	3,539,828	1,952,796	5,567,358	1,023
18	2031	147,025	-	-	-	-	3,539,828	3,610,624	1,952,796	5,639,649	1,037
19	2032	149,958	-	-	-	-	3,610,624	3,682,837	1,952,796	5,713,388	1,050
20	2033	152,958	-	-	-	-	3,682,837	3,756,588	1,952,796	5,788,598	1,064
Present Worth [% of PW]		1,282,875	0.0%	0.0%	0.0%	0.0%	30,865,895	30,865,895	20,528,122	52,697,883	100.0%

Jim Bridger Unit 4 Upgraded Wet FGD												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst/FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton SO2 Removed)	
0	2013											
1	2014	42,583	15,539	213,921	-	177,714	208,926	616,100	547,919	1,208,601	761	
2	2015	43,435	15,850	218,159	-	181,268	213,105	628,422	547,919	1,219,775	770	
3	2016	44,303	16,167	222,563	-	184,893	217,957	640,960	547,919	1,233,212	778	
4	2017	45,189	16,490	227,014	-	188,591	221,714	653,810	547,919	1,246,918	787	
5	2018	46,093	16,820	231,555	-	192,353	226,148	666,886	547,919	1,260,888	796	
6	2019	47,015	17,157	236,186	-	196,210	230,671	680,224	547,919	1,275,158	805	
7	2020	47,955	17,500	240,910	-	200,135	235,265	693,929	547,919	1,289,702	814	
8	2021	48,914	17,850	245,728	-	204,137	239,960	707,705	547,919	1,304,538	823	
9	2022	49,893	18,207	250,642	-	208,220	244,790	721,659	547,919	1,319,670	833	
10	2023	50,890	18,571	255,655	-	212,394	249,686	735,296	547,919	1,335,105	843	
11	2024	51,908	18,942	260,768	-	216,632	254,680	751,022	547,919	1,350,849	852	
12	2025	52,948	19,321	265,884	-	220,965	259,773	766,043	547,919	1,366,908	863	
13	2026	54,005	19,707	271,003	-	225,384	264,969	781,364	547,919	1,383,288	873	
14	2027	55,085	20,102	276,229	-	229,892	270,268	796,981	547,919	1,399,985	884	
15	2028	56,187	20,504	281,460	-	234,480	275,673	812,931	547,919	1,417,036	894	
16	2029	57,311	20,914	286,709	-	239,178	281,187	829,189	547,919	1,434,419	905	
17	2030	58,457	21,332	292,057	-	243,953	286,911	845,773	547,919	1,452,149	916	
18	2031	59,626	21,759	298,541	-	248,842	292,547	862,689	547,919	1,470,233	928	
19	2032	60,819	22,184	305,532	-	253,819	298,398	879,942	547,919	1,488,680	939	
20	2033	62,035	22,638	311,642	-	258,895	304,356	897,541	547,919	1,507,485	951	
Present Worth (% of PW)		520,271	189,856	2,613,653	-	2,171,282	2,552,627	7,527,418	5,759,814	13,807,503	436	
		3.9%	1.4%	18.5%	0.0%	15.7%	18.5%	54.5%	41.7%	100.0%		


Jim Bridger Unit 4 Flue Gas Conditioning												
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst/FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton PM Removed)	
0	2013											
1	2014	10,000	-	145,854	-	-	19,710	165,564	-	175,564	#DNV/01	
2	2015	10,200	-	146,771	-	-	20,104	166,875	-	179,075	#DNV/01	
3	2016	10,404	-	151,747	-	-	20,506	172,253	-	182,657	#DNV/01	
4	2017	10,612	-	157,877	-	-	20,916	178,693	-	186,310	#DNV/01	
5	2018	10,824	-	161,095	-	-	21,335	185,310	-	190,096	#DNV/01	
6	2019	11,041	-	164,255	-	-	21,761	192,016	-	193,937	#DNV/01	
7	2020	11,262	-	167,540	-	-	22,197	198,737	-	197,714	#DNV/01	
8	2021	11,487	-	170,891	-	-	22,641	205,532	-	201,668	#DNV/01	
9	2022	11,717	-	174,309	-	-	23,093	212,402	-	205,701	#DNV/01	
10	2023	11,951	-	177,795	-	-	23,555	219,346	-	209,815	#DNV/01	
11	2024	12,190	-	181,351	-	-	24,026	226,377	-	214,012	#DNV/01	
12	2025	12,434	-	184,978	-	-	24,507	233,485	-	218,292	#DNV/01	
13	2026	12,682	-	188,678	-	-	24,997	240,682	-	222,658	#DNV/01	
14	2027	12,936	-	192,451	-	-	25,497	247,949	-	227,111	#DNV/01	
15	2028	13,195	-	196,300	-	-	26,007	255,307	-	231,653	#DNV/01	
16	2029	13,459	-	200,226	-	-	26,527	262,753	-	236,286	#DNV/01	
17	2030	13,728	-	204,231	-	-	27,058	270,281	-	241,012	#DNV/01	
18	2031	14,002	-	208,315	-	-	27,599	277,914	-	245,832	#DNV/01	
19	2032	14,282	-	212,482	-	-	28,151	285,633	-	250,749	#DNV/01	
20	2033	14,568	-	216,723	-	-	28,714	293,437	-	255,764	#DNV/01	
Present Worth (% of PW)		122,179	0.0%	1,782,023	-	0.0%	240,814	2,022,837	0.0%	2,145,015	#DNV/01	
		5.7%	0.0%	83.1%	0.0%	0.0%	11.2%	94.3%	0.0%	100.0%		

Jim Bridger Unit 4		Fabric Filter										
Year	Date	TOTAL FIXED O&M COST	Water Cost	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton PM Removed)
0	2013	127,748	-	-	-	300,040	-	1,335,944	1,635,984	4,602,887	6,366,619	17,948
1	2014	130,304	-	-	-	308,041	-	1,362,663	1,665,703	4,602,887	6,401,894	18,048
2	2015	132,910	-	-	-	312,162	-	1,389,916	1,702,078	4,602,887	6,437,874	18,147
3	2016	135,568	-	-	-	318,405	-	1,417,714	1,736,119	4,602,887	6,474,573	18,251
4	2017	138,276	-	-	-	324,773	-	1,446,069	1,770,841	4,602,887	6,512,007	18,356
5	2018	141,045	-	-	-	331,268	-	1,474,980	1,806,258	4,602,887	6,550,190	18,464
6	2019	143,866	-	-	-	337,894	-	1,504,490	1,842,393	4,602,887	6,589,136	18,574
7	2020	146,743	-	-	-	344,652	-	1,534,579	1,879,231	4,602,887	6,628,861	18,686
8	2021	149,678	-	-	-	351,545	-	1,565,271	1,916,816	4,602,887	6,669,360	18,800
9	2022	152,671	-	-	-	358,576	-	1,596,577	1,955,162	4,602,887	6,710,710	18,916
10	2023	155,725	-	-	-	365,747	-	1,628,508	1,994,285	4,602,887	6,752,966	19,035
11	2024	158,839	-	-	-	373,062	-	1,661,078	2,034,140	4,602,887	6,795,966	19,155
12	2025	162,016	-	-	-	380,523	-	1,694,300	2,074,323	4,602,887	6,839,726	19,280
13	2026	165,256	-	-	-	388,134	-	1,728,168	2,116,319	4,602,887	6,884,462	19,408
14	2027	168,562	-	-	-	395,896	-	1,762,749	2,159,648	4,602,887	6,930,084	19,535
15	2028	171,933	-	-	-	403,814	-	1,798,004	2,201,818	4,602,887	6,976,538	19,666
16	2029	175,371	-	-	-	411,891	-	1,833,865	2,245,355	4,602,887	7,024,113	19,800
17	2030	178,879	-	-	-	420,128	-	1,870,644	2,290,772	4,602,887	7,072,538	19,936
18	2031	182,456	-	-	-	428,531	-	1,908,057	2,336,588	4,602,887	7,121,931	20,076
19	2032	186,106	-	-	-	437,102	-	1,946,218	2,383,319	4,602,887	7,172,312	20,218
20	2033	1,560,813	-	-	-	3,665,845	-	16,322,365	19,885,210	46,386,333	69,935,356	9,857
Present Worth (% of PW)		2.2%	0.0%	0.0%	0.0%	5.2%	0.0%	23.3%	28.6%	69.2%	100.0%	

First Year Cost for Air Pollution Control Options



Present Worth Cost for Air Pollution Control Options



APPENDIX B
2006 Wyoming BART Protocol

BART Air Modeling Protocol
Individual Source Visibility Assessments
for BART Control Analyses

September, 2006

State of Wyoming
Department of Environmental Quality
Air Quality Division
Cheyenne, WY 82002

Table of Contents

1.0	INTRODUCTION	3
2.0	OVERVIEW	4
3.0	EMISSIONS DATA FOR MODELING	7
3.1	Baseline Modeling	7
3.2	Post-Control Modeling.....	8
4.0	METEOROLOGICAL DATA.....	9
5.0	CALPUFF MODEL APPLICATION.....	12
6.0	POST PROCESSING	15
7.0	REPORTING	19

1.0 INTRODUCTION

The U.S. EPA has issued final amendments to the Regional Haze Regulations, along with Guidelines for Best Available Retrofit Technology (BART) Determinations.⁽¹⁾ The guidelines address the methodology for determining which facilities must apply BART (sources subject-to-BART) and the evaluation of control options.

The State of Wyoming used air quality modeling in accordance with the EPA Guidelines to determine the Wyoming sources which are subject-to-BART. This Protocol defines the specific methodology to be used by those sources for determining the improvement in visibility to be achieved by BART controls.

The methodology presented in this Protocol is consistent with EPA guidance and the Air Quality Division (AQD) determination of subject-to-BART sources. It is intended that all Wyoming sources that must conduct BART analyses will use this Protocol for their evaluation of control technology visibility improvement. Any deviations from the procedures described herein must be approved by the Division prior to implementation.

⁽¹⁾ 40 CFR Part 51: Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations; Final Rule. 70 Federal Register, 39103-39172, July 6, 2005.

2.0 OVERVIEW

Wyoming AQD determined that eight facilities (sources) in the state are subject-to-BART. The sources are listed in Table 1. Division modeling indicated that each of these sources causes or contributes to visibility impairment in one or more Class I areas. Each source must conduct a BART analysis to define Best Available Retrofit Technology (BART) applicable to that source, and quantify the improvement in Class I visibility associated with BART controls. This Protocol sets out the procedures for quantifying visibility improvement. Other aspects of the full BART analysis are not addressed here.

There are many Class I areas within and surrounding Wyoming (See Figure 1). On the basis of distance from subject-to-BART sources, topography, meteorology, and prior modeling, the AQD has determined that only five Class I areas need be addressed in BART individual source analyses. These are Badlands and Wind Cave National Parks in South Dakota, Mt. Zirkel Wilderness Area in Colorado, and Bridger and Fitzpatrick Wilderness Areas in Wyoming. Sources in eastern Wyoming have been shown to have greatest visibility impacts at the two South Dakota Class I areas, and western Wyoming sources have maximum impacts at Bridger and Fitzpatrick Wilderness Areas, and Mt. Zirkel. Visibility improvement at these highest impact areas will provide the best measure of the effectiveness of BART controls.

Each facility should carry out modeling with the CALPUFF modeling system for the Class I areas specified in Table 2. The AQD will provide meteorological input for CALMET for the years 2001, 2002, and 2003. The model domain covered by the AQD meteorological data is centered in southwest Wyoming, and extends roughly from Twin Falls, ID in the west to the Missouri River in the east, and from Denver in the south to Helena, MT in the north. The domain is shown, along with Class I areas, in Figure 1.

Sources may wish to utilize a smaller domain for CALPUFF modeling. Smaller domains are acceptable if they provide adequate additional area beyond the specific source and Class I areas being addressed. Figure 1 includes a "southwest Wyoming" domain which represents the minimum acceptable area for sources impacting the Bridger and Fitzpatrick Wilderness Areas, and the Mt. Zirkel Wilderness Area, and a "northeast Wyoming" domain as a minimum area for Badlands and Wind Cave National Parks modeling.

The CALPUFF model should be used with each of the three years of meteorological data to calculate visibility impacts for a baseline (existing emissions) case, and for cases reflecting BART controls. The control scenarios are to include individual scenarios for proposed BART controls for each pollutant (SO₂, NO_x, and particulate matter), and a combined scenario representing application of all proposed BART controls. If desired, additional modeling may be performed for controls that are not selected as BART. This might be done, for example, to provide data useful in identifying the control technologies that represent BART. However, visibility modeling is required only for the proposed BART controls.

Table 1. Wyoming Sources Subject-to-BART

Basin Electric	Laramie River Power Plant	Boilers #1,2,3
FMC Corporation	Granger Soda Ash Plant	Boilers #1,2
FMC Corporation	Green River Sodium Plant	Three boilers
General Chemical Co.	Green River Soda Ash	Two boilers
PacifiCorp	Dave Johnson Power Plant	Boilers #3,4
PacifiCorp	Jim Bridger Power Plant	Boilers #1-4
PacifiCorp	Naughton Power Plant	Boilers #1,2,3
PacifiCorp	Wyodak Power Plant	Boiler

Results of visibility modeling will be presented as a comparison between baseline impacts and those calculated for the BART control scenarios. Quantitative measures of impact will be the 98th percentile deciview change (Δdv) relative to the 20% best days natural background, and the number of days with deciview change exceeding 0.5 (EPA Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations, 70 FR 39103). Results should be presented for each year.

Table 2. Source-Specific Class I Areas to be Addressed

Source	Class I Areas to be Evaluated
Basin Electric Laramie River	Wind Cave NP, Badlands NP
FMC Corporation Granger Soda Ash	Bridger WA, Fitzpatrick WA
FMC Corporation Sodium Products	Bridger WA, Fitzpatrick WA
General Chemical Green River Soda Ash	Bridger WA, Fitzpatrick WA
Pacificorp Dave Johnston	Wind Cave NP, Badlands NP
Pacificorp Jim Bridger	Bridger WA, Fitzpatrick WA, Mt. Zirkel WA
Pacificorp Naughton Plant	Bridger WA, Fitzpatrick WA
Pacificorp Wyodak	Wind Cave NP, Badlands NP

3.0 EMISSIONS DATA FOR MODELING

CALPUFF model input requires source (stack) – specific emission rates for each pollutant, and stack parameters (height, diameter, exit gas temperature, and exit gas velocity). Per EPA BART guidance, these parameters must be representative of maximum actual 24-hour average emitting conditions for baseline (existing) operation, and maximum proposed 24-hour average emissions for future (BART) operations.

3.1 Baseline Modeling

Sources are required to utilize representative baseline emission conditions if data are available; baseline emissions must be documented. Possible sources of emission data are stack tests, CEM data, fuel consumption data, etc. Remember that emissions should represent maximum 24-hour rates. EPA BART guidance states that you should “Use the 24-hour average actual emission rate from the highest emitting day of the meteorological period modeled (for the pre-control scenario).” Thus, baseline conditions should reference data from 2001 through 2003 (or 2004).

As a minimum, modeled emissions must include:

SO ₂	sulfur dioxide
NO _x	oxides of nitrogen
PM _{2.5}	particles with diameter less than 2.5µm
PM _{10-2.5}	particles with diameters greater than 2.5µm but less than or equal to 10 µm

If the fraction of PM₁₀ in the PM_{2.5} (fine) and PM_{10-2.5} (coarse) categories cannot be determined all particulate matter should be assumed to be PM_{2.5}.

In addition, direct emissions of sulfate (SO₄) should be included where possible. Sulfate can be emitted as sulfuric acid (H₂SO₄), sulfur trioxide (SO₃), or as sulfate compounds; emissions should be quantified as the equivalent mass of SO₄.

When test or engineering data are not available to specify SO₄ emissions or the relative fractions of fine and coarse particles, use can be made of speciation profiles available from Federal Land Managers at the website <http://ww2.nature.nps.gov/air/permits/ect/index.cfm>. Profiles are available for a number of source type and control technology combinations. The FLM speciation factors are acceptable if data are available for the appropriate source type.

Emissions of VOC (volatile organic compounds), condensable organics measured in stack tests, and elemental carbon components of PM₁₀ do not need to be included for BART modeling. The only other pollutant noted in EPA BART guidance is ammonia (NH₃). Though ammonia is not believed to be a significant contributor to visibility

impairment in most cases in Wyoming, it could be important for sources with significant ammonia emissions – for example from some NO_x control systems. Sources that are expected to emit ammonia (in pre-or post-control configurations) should include ammonia emissions in their model input.

If quantitative baseline emissions data are unavailable and sources believe that the maximum 24-hour emission rates estimated by the Division (presented in the Subject-to-BART final report) are representative of baseline conditions for their facility, they may be used for baseline modeling. However, emissions of sulfate and ammonia (if applicable) should be included based on the best available test information or speciation factors from current literature.

3.2 Post-Control Modeling

All pollutants described above should be included for each post-control scenario. Post-control emissions (maximum 24-hour average) will generally be the baseline emissions multiplied by a control factor appropriate to the BART control. However, some proposed controls may simply increase the efficiency of existing controls; others may result in an increase in emissions of one pollutant while controlling another. These factors must all be considered in defining emission rates for post-control modeling. Any changes in stack parameters resulting from control application must also be included.

The required visibility assessment will include the effect of each proposed BART control. For example, if a source proposes to add a scrubber for SO₂ control, low NO_x burners for NO_x control, and a baghouse for particulate control, four sets of visibility results should be developed:

- Use of SO₂ control alone
- Use of NO_x control alone
- Use of particulate control alone
- Use of proposed combination of all three controls

All pollutants should be modeled in each CALPUFF model run, but the modeled emissions should reflect only the specific controls or combination of controls addressed in that run.

Additional modeling could be necessary in situations where a facility is comprised of more than one subject-to-BART source, and different BART controls are applicable to different sources. Excessive modeling to address multiple control combinations is not necessary; however, visibility modeling should quantify the effect of BART controls on all affected sources for each pollutant, and of all facility BART controls combined.

4.0 METEOROLOGICAL DATA

Wyoming AQD will provide MM5 meteorological data fields for years 2001, 2002, and 2003 that can be utilized as input to CALMET. The MM5 output will have 12 kilometer resolution and cover the full domain shown in Figure 1.

Mesoscale meteorological data (MM5) were developed and evaluated as part of the AQD's southwest Wyoming NO₂ increment analysis. Three years of MM5 data at 36 km resolution were used to initialize 12 km MM5 simulations. The 12km MM5 modeling used identical physics options to the original 36 km runs. CALMM5 was then used as a preprocessor to produce CALMET - ready MM5 data input files. Quality assurance was performed by comparing the original MM5 output on the 36km national RPO grid to the 12 km MM5 output and observations.

The CALMET model (version 5.53a, level 040716) should be used to prepare meteorological input for CALPUFF. The user may select a domain smaller than the MM5 domain for CALMET and CALPUFF modeling if desired. Figure 1 shows minimum domain areas for modeling of western and eastern Wyoming BART sources. Four kilometer resolution should be specified for CALMET output.

CALMET processing should use the AQD MM5 data, and appropriate surface, upper air, and precipitation data. Figure 2 shows the locations of surface and upper air stations within the MM5 model domain. The MM5 data are used as the initial guess wind field; this wind field is then adjusted by CALMET for terrain and land use to generate a step 1 wind field, and refined using surface and upper air data to create the final step 2 wind field.

Surface, upper air, and precipitation data can be obtained from the National Climatic Data Center. Land use and terrain data are available from the U.S. Geological Survey. Data can be formatted for use in CALMET with standard conversion and processing programs available with the CALMET/CALPUFF software.

Table 3 provides a listing of applicable CALMET input variables for BART meteorological processing. The table includes inputs that are specific to Wyoming BART modeling. Inputs not shown in Table 3 are not relevant to the present application, are dependent on the specific model domain of the user, use model default values, or are obvious from the context.

Table 3. CALMET Control File Inputs

Variable	Description	Value
	Input Group 1	
IBYR	Year	2001
		2002
		2003
IBTZ	Base time zone	7
IRTYPE	Run type	1
LCALGRD	Compute data fields for CALGRID	T
	Input Group 2	
PMAP	Map projection	LCC
DGRIDKM	Grid spacing (km)	4
NZ	Number of layers	10
ZFACE	Cell face heights (m)	0
		20
		40
		100
		140
		320
		580
		1020
		1480
		2220
		3500
	Input Group 4	
NOOBS	No observation Mode	0
	Input Group 5	
IWFCOD	Model selection variable	1
IFRADJ	Froude number adjustment	1
IKINE	Kinematic effects	0
IOBR	Use O'Brien procedure	0
ISLOPE	Slope flow effects	1
IEXTRP	Extrapolate surface wind observations	-4
ICALM	Extrapolate calm surface winds	0
BIAS	Biases for weights of surface and upper air stations	All 0
RMIN2	Minimum distance for extrapolation	-1
IPROG	Use gridded prognostic model output	14
ISTEPPG	Time Step (hours)	1
LVARY	Use varying radius of influence	F

Table 3. CALMET Control File Inputs (continued)

Variable	Description	Value
RMAX 1	Maximum radius of influence (km)	30
RMAX 2	Maximum radius of influence (km)	50
RMIN	Minimum radius of influence (km)	0.1
TERRAD	Radius of influence for terrain (km)	15
R1	Relative weighting of first guess wind field and observations (km)	5
R2	Relative weighting aloft (km)	25
IDIOPT 1	Surface temperature	0
IDIOPT 2	Upper air lapse rate	0
ZUPT	Lapse rate depth (m)	200
IDIOPT 3	Average wind components	0
IUPWND	Upper air station	-1
ZUPWND (1)	Bottom and top of layer for domain	1, 1000
ZUPWND (2)	scale winds (m)	1, 1000
IDIOPT4	Surface wind components	0
IDIOPT5	Upper air wind components	0
	Input Group 6	--
IAVEZI	Spatial averaging	1
MNMDAV	Max search radius	1
HAFANG	Half angle for averaging (deg)	30
ILEVZI	Layer of winds in averaging	1
ZIMAX	Maximum overland mixing height (m)	3500
ITPROG	3D temperature source	1
IRAD	Interpolation type	1
TRADKM	Radius of influence – temperature (km)	500
NUMTS	Maximum number of Stations	5
IAVET	Spatial averaging of temperatures	1
NFLAGP	Precipitation interpolation	2

5.0 CALPUFF MODEL APPLICATION

The CALPUFF model (version 5.711a, level 040716) will be used to calculate pollutant concentrations at receptors in each Class I area. Application of CALPUFF should, in general, follow the guidance presented in the Interagency Workgroup on Air Quality Modeling (IWAQM) Phase 2 report (EPA - 454/R98-019) and the EPA Regional Haze Regulations and Guidelines for BART Determinations (70 FR 39103).

Appropriate CALPUFF control file inputs are in Table 4. Note should be taken of the basis for several of the recommended CALPUFF inputs.

- Building downwash effects need not be included. Because of the transport distances involved and the fact that most sources have tall stacks, building downwash is unlikely to have a significant effect on model-predicted concentrations
- Puff splitting is not required. The additional computation time necessary for puff splitting is not justified for purposes of BART analyses.
- Hourly ozone files should be used to define background ozone concentration. Data are available from the following sites within the model domain.
 - Rocky Mountain NP, CO
 - Craters of the Moon NP, ID
 - AIRS - Highland UT
 - Mountain Thunder, WY
 - Yellowstone NP, WY
 - Centennial, WY
 - Pinedale, WY

The background ozone concentration shown in Table 4 is used only when hourly data are missing.

- A constant background ammonia concentration of 2.0 ppb is specified. This value is based upon monitoring data from nearby states and IWAQM guidance. Experience suggests that 2.0 ppb is conservative in that it is unlikely to significantly limit nitrate formation in the model computations.
- MESOPUFF II chemical transformation rates should be used.
- The species to be modeled should be the seven identified in CALPUFF: SO₂, SO₄, NO_x, HNO₃, NO₃, PM_{2.5}, and PM_{10-2.5}. If ammonia (NH₃) is emitted it should be added to the species list. In most cases, all pollutants modeled will also be emitted, except for HNO₃ and NO₃.

Concentration calculations should be made for receptors covering the areas of the Class I areas being addressed. Receptors in each Class I area will be those designated by the Federal Land Managers and available from the National Park Service website.

Table 4. CALPUFF Control File Inputs

Variable	Description	Value
	Input Group 1	
METRUN	Control parameter for running all periods in met file	1
IBYR	Starting year	2001 2002 2003
XBTZ	Base time zone	7
NSPEC	Number of chemical species modeled	7 (or 8)
NSE	Number of species emitted	5 (or 6)
METFM	Meteorological data format	1
	Input Group 2	
MGAUSS	Vertical distribution in near field	1
MCTADJ	Terrain adjustment method	3
MCTSG	Subgrid scale complex terrain	0
MSLUG	Elongated puffs	0
MTRANS	Transitional plume rise	1
MTIP	Stack tip downwash	1
MSHEAR	Vertical wind shear	0
MSPLIT	Puff splitting allowed?	0
MCHEM	Chemical mechanism	1
MAQCHEM	Aqueous phase transformation	0
MWET	Wet removal	1
MDRY	Dry deposition	1
MDISP	Dispersion Coefficients	3
MROUGH	Adjust sigma for roughness	0
MPARTL	Partial plume penetration of inversions	1
MPDF	PDF for convective conditions	0
	Input Group 4	
PMAP	Map projection	LCC
DGRIDKM	Grid spacing	4

Table 4. CALPUFF Control File Inputs (continued)

ZFACE	Cell face heights (m)	0
		20
		40
		100
		140
		320
		580
		1020
		1480
		2220
		3500
	Input Group 6	
NHILL	Number of terrain features	0
	Input Group 7	
Dry Gas Depo	Chemical parameters for dry gas deposition	Defaults
	Input Group 8	
Dry Part. Depo	Size parameters for dry particle deposition SO ₄ , NO ₃ , PM ₂₅ PM ₁₀	Defaults 6.5, 1.0
	Input Group 11	
MOZ	Ozone Input option	1
BCKO3	Background ozone -- all months (ppb)	44.0
BCKNH3	Background ammonia -- all months (ppb)	2.0
	Input Group 12	
XMAXZI	Maximum mixing height (m)	3500
XMINZI	Minimum mixing height (m)	50

6.0 POST PROCESSING

Visibility impacts are calculated from the CALPUFF concentration results using CALPOST. CALPOST version 5.51, level 030709 should be used; the output from CALPOST will provide the highest deciview impact on each day from all receptors within each Class I area modeled.

For some CALPUFF applications such as deposition calculations, the POSTUTIL program is used prior to CALPOST. POSTUTIL is also used to repartition total nitrate by accounting for ammonia limiting. The ammonia limiting calculation in POSTUTIL should not be applied for Wyoming BART modeling. If you believe that ammonia limiting is appropriate for a specific BART analysis, justification should be discussed with the Division prior to its used.

Visibility calculations by CALPOST for BART purposes use Method 6. This method requires input of monthly relative humidity factors, $f(RH)$, for each Class I area. The EPA guidance document provides appropriate data for each area. Table 5 lists monthly $f(RH)$ factors to use for the Wyoming, Colorado, and South Dakota areas to be addressed in BART modeling. The factors shown in Table 5 include averages for the adjacent Class I areas, and are within 0.2 units of the Guideline table values for the individual Class I areas.

Natural background conditions as a reference for determination of the delta-dv change due to a source should be representative of the 20% best natural visibility days. EPA BART guidance provides the 20% best days deciview values for each Class I area on an annual basis, but does not provide species concentration data for the 20% best background conditions. These concentrations are needed for input to CALPOST.

Annual species concentrations corresponding to the 20% best days were calculated for each Class I area to be addressed, by scaling back the annual average concentrations given in Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule (Table 2-1). A separate scaling factor was derived for each Class I area such that, when multiplied by the Guidance table annual concentrations, the 20% best days deciview value for that area would be calculated. The scaled aerosol concentrations were averaged for the Bridger and Fitzpatrick WAS, and for Wind Cave and Badlands NPs, because of their geographical proximity and similar annual background visibility. The 20% best days aerosol concentrations to be used for each month for Wyoming BART evaluations are listed in Table 6.

Table 7 is a list of inputs for CALPOST. These inputs should be used for all BART visibility calculations. Output from CALPOST should be configured to provide a ranked list of the highest delta-deciview values in each Class I area. The 98th percentile delta-deciview value and the number of values exceeding 0.5 can then be determined directly from the CALPOST output.

Table 5. Monthly f(RH) Factors for Class I Areas

Month	Wind Cave NP Badlands NP	Bridger WA Fitzpatrick WA	Mt. Zirkel WA
January	2.65	2.50	2.20
February	2.65	2.30	2.20
March	2.65	2.30	2.00
April	2.55	2.10	2.10
May	2.70	2.10	2.20
June	2.60	1.80	1.80
July	2.30	1.50	1.70
August	2.30	1.50	1.80
September	2.20	1.80	2.00
October	2.25	2.00	1.90
November	2.75	2.50	2.10
December	2.65	2.40	2.10

Table 6. Natural Background Concentrations of Aerosol Components for 20% Best Days for BART Analyses ($\mu\text{g}/\text{m}^3$)

Aerosol Component	Wind Cave NP Badlands NP	Fitzpatrick WA Bridger WA	Mt. Zirkel WA
Ammonium Sulfate	.047	.045	.046
Ammonium Nitrate	.040	.038	.038
Organic Carbon	.186	.178	.179
Elemental Carbon	.008	.008	.008
Soil	.198	.189	.190
Coarse Mass	1.191	1.136	1.141

Table 7. CALPOST Control File Inputs

Variable	Description	Value
	Input Group 1	
ASPEC	Species to Process	VISIB
ILAYER	Layer/deposition code	1
A,B	Scaling factors	0,0
LBACK	Add background concentrations?	F
BTZONE	Base time zone	7
LVSO4	Species to be included in extinction	T
LVNO3		T
LVOC		F
LVPMC		T
LVPMF		T
LVEC		F
LVBK	Include background?	T
SPECPMC	Species name for particulates	PM10
SPECPMF		PM25
EEPMC	Extinction efficiencies	0.6
EEPMF		1.0
EEPMCBK		0.6
EESO4		3.0
EENO3		3.0
EEOC		4.0
EESOIL		1.0
EEEC		10.0
MVISBK	Visibility calculation method	6
RHFAC	Monthly RH adjustment factors	Table 5
BKSO4	Background concentrations	Table 6
BKNO3		Table 6
BKPMC		Table 6
BK OC		Table 6
BKSOIL		Table 6
BKEC		Table 6
BEXTRAY	Extinction due to Rayleigh scattering	10.0

7.0 REPORTING

A report on the BART visibility analysis should be submitted that clearly compares impacts for post-control emissions to those for baseline emissions. Data for baseline and BART scenarios should include both the 98th percentile values and the number of days with delta-deciview values exceeding 0.5. Results should be given for each model year.

Table 8 is an example of a recommended format for presentation of model input and model results. The example is for baseline conditions; similar tables should be provided for each control scenario (SO₂, NO_x, and PM10) and for the combination of all BART controls. Your report tables need not follow the exact format shown in Table 8; but the same information should be provided in a concise and clear form. If additional scenarios were modeled or you wish to present supplemental information, they should be provided in an appendix or separate from the specified final results.

Table 8. Example Format for Presentation of Model Input and Results

Baseline Conditions Model Input Data												
Source (Unit) Description And ID	SO ₂ Emission Rate (lb/day)	NO _x Emission Rate (lb/day)	PM _{2.5} Emission Rate (lb/day)	PM _{10-2.5} Emission Rate (lb/day)	SO ₄ Emission Rate (lb/day)	NH ₃ Emission Rate (lb/day)	Location Easting UTM (m)	Location Northing UTM (m)	Stack Height (m)	Stack Diameter (m)	Exit Velocity (m/s)	Exit Gas Temp (deg K)

Baseline Visibility Modeling Results

Name of Facility	Class I Area	2001			2002			2003	
		98 th Percentile Value (dv)	No. of days exceeding 0.5 dv	98 th Percentile Value (dv)	No. of days exceeding 0.5 dv	98 th Percentile Value (dv)	No. of days exceeding 0.5 dv		

APPENDIX C
Just-Noticeable Differences in Atmospheric Haze
Dr. Ronald Henry

Just-Noticeable Differences in Atmospheric Haze

Ronald C. Henry

Department of Civil and Environmental Engineering, University of Southern California, Los Angeles

ABSTRACT

This article examines the only available experimental data taken in the natural environment on the ability of an observer to perceive small, incremental changes in the colorfulness of objects seen through atmospheric haze and estimates an appropriate just-noticeable difference (JND) from these data. This experimentally determined threshold of perception is compared to changes in the deciview scale. Based on these experimental results, the deciview scale is found to not be uniform over a wide range of visibility conditions, as has been previously claimed. In addition, a 1-deciview change never produces a perceptible change in haze, as defined by a 95% probability of producing a measurable change in the colorfulness of an object seen through the haze.

INTRODUCTION

Section 169A of the Clean Air Act sets a national goal of protecting visibility in national parks and other pristine areas. Under regulations promulgated in 1980, the U.S. Environmental Protection Agency (EPA) has taken specific regulatory action to protect visibility in the Grand Canyon National Park by reducing emissions of sulfur dioxide from the Navajo Electric Generating Station near the eastern end of the Grand Canyon and from the Mohave Power Plant at the western end. However, current concerns about visibility degradation stem from regional haze that is difficult or impossible to attribute to individual sources of air pollution. This issue is addressed by regional haze regulations that set a goal of making reasonable

progress toward improving regional visibility in five-year increments, leading to the attainment of "natural conditions" by 2064.¹ Progress is to be measured by an innovative visibility metric for regulatory purposes known as the deciview,² used instead of visual range or other visibility metrics because it "expresses uniform changes in haziness in terms of common increments across the entire range of visibility conditions, from pristine to extremely hazy conditions."¹ One goal of this article is to assess this and other claims about the deciview scale in light of actual measurements of the perception of haziness. Since the deciview scale is meant to quantify small, just-noticeable differences (JNDs) in visibility, a review of the basic concepts of thresholds and JNDs is given.

Perceptual Threshold Concepts

For all the senses, thresholds are necessary—otherwise we would be constantly distracted by small, inconsequential changes in the environment. A background of random noise, some from the environment and some produced inside our own sensory organs, would make it next to impossible to form a stable view of the world. Our vision would be like the grainy, speckled images produced by night vision cameras. On a more basic scientific level, the study of thresholds of the senses has led to a deeper understanding of sensory physiology and how our vision and other senses function. For this reason, virtually all studies of thresholds of vision have been carried out under controlled laboratory conditions.

Since laboratory conditions seldom mimic the natural environment, thresholds so determined are generally not useful in predicting perception in the complex natural world. As an example of the drastic effect that experimental conditions can have on perception, consider an experiment to determine the ability of an observer to perceive the difference in the length of two strings—or to put it another way, to determine the threshold for perception of the difference in the length of two strings, or the JND. If the two strings are widely separated when presented to the observer, the threshold will be much greater than if the two strings are presented side by side. The visual equivalent of this is the use of a split image to determine the ability to distinguish color. If two colors are seen as two halves of a disk, the JND is very small, but if one

IMPLICATIONS

Current regulations use the deciview to quantify a perceptible change in regional haze. Based on the results of this article, changes in atmospheric extinction required to meet regional haze regulations calculated using deciviews would probably be too small, sometimes much too small. In addition, these regulations require that progress be assessed over five-year intervals. In this way, the burden of reducing emissions is spread evenly over many years. However, since deciviews are not uniform in perception, it may be that the actual improvement in visibility will not be uniform.

color is presented as a full disk, followed a few seconds later by the other color, the JND will be much larger. The topic of the background on which the colors are seen is also important (e.g., if it is black or a complex scene): In general, many conditions influence thresholds; for this reason, the results of laboratory experiments should be applied with great caution to the natural environment. Thus, this article will report and analyze data taken in a unique experiment in the natural environment with a goal of determining a JND in atmospheric haze.

In the above discussion, the terms "threshold" and "JND" have been freely used, but not defined. The naïve definition of a threshold or JND is clear: It is the smallest amount, or change in, a physical stimulus that is detectable. Ideally, a 1-JND change in a stimulus such as contrast or color would always result in the observer seeing a change, and anything less would not. Of course, the senses do not work in this simple on-off manner. In actuality, as the change in the physical stimulus increases, the probability that the observer will detect the change increases as well. Thus, thresholds and JNDs have always been defined by a probability of detection. Furthermore, the sensitivity of people's senses varies from person to person and during a person's life. Even if each person had a single, idealized threshold, the response of the general population would be best described by a probability of detection.

Repeated matching by the method of adjustments is one of the oldest methods of determining a JND. Falmagne³ described this and other methods to quantify perception. Briefly, the observer is shown a target color and a variable test color and is asked to adjust the test color until it matches the target. Taking random starting points, the matching procedure is repeated as often as is practical. Since the observer has judged the matching color to be the same as the target color, the variability in the matches is a measure of a JND around the target. The standard deviation of the matches is one measure of this variability that is often used; another is the difference between the 75th and the 25th percentile of the match distribution. The method of adjustments has been replaced in laboratory studies by methods that give less control to the observer and more to the researcher and therefore improve the reproducibility of the results (unfortunately, these methods are impractical for field studies). However, JNDs are still defined by some measure related to the probability of detection. The final determination of the value of a JND or threshold is really dependent on how the measurements are made and how the data are interpreted. For the experimental data used in this article, the method of adjustments was used and a JND related to the standard deviation of repeated matches was defined.

Atmospheric Visibility Concepts

In the classical theory of atmospheric visibility, the threshold of contrast perception, that is, the threshold for perception of a large, dark object on the horizon, is assumed to be 2%.⁴ This number is somewhat arbitrary. The Federal Aviation Administration (FAA) has taken the more conservative value of 5.5% as a contrast threshold for the definition of visual range, presumably because approaching aircraft seen from a cockpit are usually neither large nor dark. The common formula for visual range, using the 2% threshold, is

$$V_R = \frac{-\ln(0.02)}{b_{ext}} = \frac{3.9}{b_{ext}} \quad (1)$$

where b_{ext} is the extinction coefficient of the atmosphere, which is assumed to be homogeneous. The extinction coefficient in the denominator of the formula can be thought of as the fraction of light that is lost as it traverses 1 m of air. For completely clear air, b_{ext} has a value of about $10 \times 10^{-6} \text{ m}^{-1}$ or 10 Mm^{-1} , or a visual range of about 390 km. More typically, particles in the air usually increase the extinction coefficient to 150–300 Mm^{-1} or more. Typical visual ranges are about 10 km in the eastern United States and 50 km or more in the western United States. Closely related to b_{ext} and visual range is the more general concept of optical depth. For a target at a distance x , this is defined as xb_{ext} . It is dimensionless; if b_{ext} is held constant it represents distance, and if the distance is constant, it represents changes in b_{ext} . From eq 1, the visual range corresponds to an optical depth of 3.9, and a distance of about one quarter of the visual range is equivalent to an optical depth of 1.

Despite lacking a firm psychophysical or experimental basis, the visual range defined by the 2% threshold has stood the test of time. However, while visual range has proven to be a good surrogate for atmospheric visibility for the aviation community, it is of limited value in addressing the concerns of the air quality community. Unlike aviation, where poor visibility is of greatest interest, the air quality community is primarily concerned with relatively small changes in good visibility. Pitchford and Malm² have proposed the deciview as a visibility indicator more suited to air quality regulations. If the extinction coefficient is given in Mm^{-1} , then deciview is defined as

$$v = 10 \ln(b_{ext} / 10) \quad (2)$$

Current regional haze visibility regulations state that:

- (1) A 1-deciview change in haziness is a small, but noticeable, change in haziness under most circumstances when viewing scenes in Class I areas.
- (2) Deciview units are uniform in perception over a wide range of visibility conditions; that is, a 1-deciview change is just perceptible regardless of the visibility conditions.¹

The next section describes a color matching experiment in the Great Smoky Mountains National Park. The results of this experiment are used to estimate a just-noticeable change in haze based on color perception. The validity of the claims for deciviews will be evaluated by comparison to experimental estimates of JNDs.

EXPERIMENTAL DATA

During summer 1995, a group of researchers from universities, government agencies, and private companies conducted the SouthEast Aerosol and Visibility Study (SEAVS) in the Great Smoky Mountains National Park. The SEAVS focused largely on aerosol composition,^{5,6} airborne particle size distribution,^{7,8} and the role of water in the aerosol.⁹⁻¹¹ However, the SEAVS had a number of other aspects, including a study of the perception of color through atmospheric haze.¹² The methods and primary results of the color perception study are described below.

The perceived colors of natural targets were quantified by color matching using a specially constructed visual colorimeter.¹³ An observer looked at some scene element, such as a barn or green field, with one eye. The observer looked with the other eye in the visual colorimeter at a color spot, which the observer adjusted to match the color of the target. The perceived color was recorded as the amount of red, green, and blue light in the color match. At the same time, the spectrum of the light coming from the target was measured by a telespectroradiometer. A color appearance model was applied to produce measures of the perceived color as recorded by the visual colorimeter and as calculated from the spectrum.¹⁴

Of most interest here are the hue and colorfulness. The hue is what most people call the color—red, green, blue, yellow, and so on. It is quantified as a mixture of pure red, green, blue, or yellow lights. The colorfulness is the degree to which the hue is expressed; it is similar to the concept of saturation. A deep red color would have a colorfulness of about 100, while a colorfulness of 10 or less is almost achromatic (i.e., white or gray).

Two observers (Mahadev and Urquito) made color matches of a set of natural targets during the SEAVS. These observers were both males in their 20s with normal color vision. Each had received extensive training in color matching using the visual colorimeter. The scattering coefficient of the atmosphere was measured by a nearby nephelometer; particle absorption was small and its contribution to the extinction coefficient ignored. The full details of the experiment are found in Mahadev.¹⁵

The perception study found that viewing through a semitransparent atmosphere affected the perception of hue and colorfulness in a highly nonlinear way. The eye appeared to split the light coming from the target into two parts, the haze and the target. The result was that as

the haze increased, the hue of the target as seen by the observer remained constant. However, because the increasing haze scattered more light into the sight path, the hue calculated from the spectrum became bluer. To the observer, the main effect of haze was to decrease the perceived colorfulness. Furthermore, the decrease in colorfulness seemed to be exponential with optical depth (optical depth is the dimensionless product of the extinction coefficient and distance):

$$M(\tau) = M_0 \exp(-\tau) \quad (3)$$

where $M(\tau)$ is the colorfulness of the object at optical depth τ and M_0 is the colorfulness at zero optical depth (i.e., no haze). M_0 is also known as the inherent colorfulness. The colorfulness of the horizon was assumed to be small enough to be taken as zero—the horizon was perceived to be white. This result implies that a JND in colorfulness can be taken to be a JND in haze.

JND in Colorfulness

Estimates of JNDs in colorfulness were based on sets of repeated color matches made during periods when the observing conditions (cloud cover, haze level, and lighting) were judged to be constant or nearly so. Observer Urquito made six sets of repeated matches.¹⁵ Figure 1 is a plot of all the repeated observations of the colorfulness of the red barn roof made by this observer versus optical depth. The exponential fit given by eq 1 is fairly good ($R^2 = 0.68$). The error bars in the figure are twice the standard deviation given in Table 1. They show that one set




Figure 1. Colorfulness vs. optical depth for observer Urquito for repeated observations of the red barn roof. The line is an exponential fit as in eq 1, and the error bars are two times the standard deviation given in Table 2.

Table 1. Repeated measurements of the red barn roof by observer Mahadev.

Date	Time	Scattering Coefficient (Mm) ⁻¹	Visual Range (km)	Colorfulness		Spectra Hue		Perceived Hue	
				Spectra	Perceived	% Red	% Blue	% Red	% Blue
7/29/95	10:20 a.m.	37	105.7	38.0	42.2	53	47	97	3
7/29/95	10:46 a.m.	39	100.3	38.9	45.6	40	60	92	8
7/29/95	10:54 a.m.	39	100.3	39.9	45.4	38	62	99	1
7/29/95	11:03 a.m.	42	93.1	35.6	46.3	52	48	92	8
7/29/95	11:12 a.m.	42	93.1	37.5	44.9	53	47	93	7
7/25/95	11:49 a.m.	65	60.2	31.2	41.1	50	50	88	12
7/25/95	12:01 p.m.	65	60.2	30.8	45.1	42	58	84	16
7/25/95	12:12 p.m.	65	60.2	30.4	44.1	53	47	91	9
7/25/95	12:19 p.m.	65	60.2	29.4	43.0	54	46	91	9
7/25/95	12:24 p.m.	65	60.2	29.2	48.4	47	53	93	7
8/11/95	9:46 a.m.	157	24.9	37.6	29.2	19	81	97	3
8/11/95	9:57 a.m.	157	24.9	37.2	28.8	22	78	98	2
8/11/95	10:07 a.m.	157	24.9	37.5	29.2	23	77	98	2
8/11/95	10:16 a.m.	161	24.3	36.3	34.9	24	76	98	2
8/11/95	10:21 a.m.	161	24.3	36.7	29.5	23	77	98	2
8/14/95	10:12 a.m.	311	12.6	44.4	18.2	9	91	91	9
8/14/95	10:18 a.m.	312	12.5	44.0	18.4	8	92	97	3
8/14/95	10:30 a.m.	313	12.5	44.8	17.6	7	93	95	5
8/14/95	10:34 a.m.	313	12.5	44.7	18.1	7	93	94	6
8/14/95	10:38 a.m.	313	12.5	44.3	18.3	8	92	94	6
8/18/95	11:00 a.m.	595	6.6	35.3	9.7	2	98	81	19
8/18/95	10:46 a.m.	616	6.4	35.4	6.8	2	98	98	2
8/18/95	10:50 a.m.	616	6.4	35.2	9.4	2	98	91	9
8/18/95	10:53 a.m.	616	6.4	35.0	7.3	2	98	99	1
8/18/95	10:57 a.m.	616	6.4	35.7	10.0	2	98	97	3

of repeated measurements had colorfulness values that deviated much more than 2 sigma from the exponential line. However, the spread of these values about the mean was about the same as other observations for the same optical depth. This shows that the variability in the colorfulness numbers is not affected by systematic observer bias in the average colorfulness, and that the variability will be used to define the JND. The observations of the same target by the other observer are discussed in detail below.

Table 1 gives the results of five sets of repeated matches by observer Mahadev for the roof of a red barn about 3.5 km distant. Table 1 is sorted by the extinction coefficient so that one can easily see that the perceived hue did not change with increasing haze, but that the hue derived from the spectrum changed from red to blue. Colorfulness had the opposite behavior; the perceived values decreased with increasing haze and the values from the spectrum stayed about the same. Two-way

analysis of variance was applied to estimate the random error in the sets of repeated measurements in Table 1. This analysis was repeated for both observers' matches of five additional natural targets. The results are given in Table 2. The standard deviation for both observers was 2.05, as calculated from the average of the variances. Although viewing conditions were chosen to be constant, some of this variability was due to small changes in atmospheric conditions.

Based on these results, one can define the JND in colorfulness in many ways. One appropriate definition for this application is based on the following thought experiment. An observer matches a target with the visual colorimeter and determines the colorfulness to be C_1 . The extinction coefficient of the atmosphere is decreased, so the colorfulness of the target is increased by an amount ΔC . The observer matches the

target again to get the new colorfulness C_2 . A JND is defined as the value of ΔC that gives a 95% probability that $C_2 - C_1 > 0$. Assume that C_1 and C_2 are normal random variables with standard deviation s and means C_0 and $C_0 + \Delta C$, respectively (statistical analysis of the SEAVS color matching data confirms that this is a good assumption). Then $C_2 - C_1$ is a normal random variable with mean ΔC and standard deviation $2^{1/2}\sigma$. The value of ΔC needed to ensure a 95% probability that $C_1 - C_2 > 0$ is given by $2^{1/2}\sigma F(0.95)$, where $F(0.95)$ is the inverse of the cumulative standard normal distribution and is equal to 1.645. Thus, the colorfulness JND is taken to be $2^{1/2}\sigma F(0.95) = 2.326\sigma$. From Table 2, using the data for both observers gives $\sigma = 2.05$, and a 1 colorfulness JND is 4.8. This value of σ includes the effects of small random variations in natural illumination, which should be included for this application because they are inevitably present, but makes the value of a colorfulness JND a bit larger than it would be otherwise.

Table 2. Standard deviations of colorfulness for repeated matches of natural targets.

Target	Observer		Distance (km)
	M	U	
White silo	0.91	1.33	3.54
Red roof	1.93	2.41	3.54
Near green meadow	2.93	2.15	3.86
Green hills	2.15	3.46	5.15
Far green meadow	1.45	1.64	10.46
Horizon sky	1.53	1.19	
Average	1.92	2.17	
Number of observations	55	60	

Deciviews and Colorfulness JNDs

Relationships between colorfulness, deciviews, and optical depth are derived below; these will be applied to test the validity of the properties of deciviews given in the regional haze regulations.

From eqs 2 and 3, an expression for deciviews v as a function of colorfulness M is derived:

$$v = 10 \ln \left(-\frac{1}{10x} \ln \left(\frac{M}{M_0} \right) \right) \quad (4)$$

For a given optical depth and inherent colorfulness, the equations above were used to calculate the change in deciviews needed to give a 1-JND increase in colorfulness, using 4.8 as a JND. Figure 2 is a plot of the results as a function of optical depth for objects with three levels of inherent colorfulness: These levels of inherent colorfulness represent a reasonable range for natural targets.¹² As might be expected, more colorful objects are more sensitive to changes in atmospheric haze. Perhaps unexpectedly, the figure shows that landscape features at a distance corresponding to an optical depth of 1–2 are the most sensitive to changes in extinction as measured by deciviews. This range corresponds to one quarter to one half of the visual range. Landscape features outside this range are much less sensitive to changes in haze. If the deciview scale were perceptually uniform, as claimed in the regional haze rules, then the lines in the figure would be horizontal, or at least approximately so. However, the change in deciviews needed to produce a 1-JND change in colorfulness varied a great deal with optical depth and inherent colorfulness. The figure also shows that a 1-JND change in colorfulness always requires more than a 1-deciview change, sometimes much more.

DISCUSSION AND CONCLUSIONS

Regional atmospheric haze affects visibility by producing a visible haze layer that limits the visual range, reduces




Figure 2. Change in deciviews needed to produce a just-noticeable increase in colorfulness for objects with an inherent colorfulness of 25, 50, and 75. The horizontal dashed dotted line represents what would be expected if a 1-deciview change were actually a uniform measure of haze perception.

contrast, and decreases the colorfulness of objects seen through the haze. Of these three effects of haze, the decrease in colorfulness may be the most important and sensitive visual cue. Visual range is not often useful for judging the effects of small changes in extinction. For example, a change in visual range from 50 to 60 km will not be noticed if the most distant landscape feature is at 25 km. The effect of haze on contrast is a better candidate as an indicator of change in haze; however, perceived contrast, like perceived hue, is affected in a nonlinear fashion by the semitransparent nature of haze and is not a sensitive indicator of changes in atmospheric haze.¹⁶ Experimental data have shown that colorfulness is a sensitive measure of changes in haze, so this article has used it to define just-noticeable changes in atmospheric haze.

A just-noticeable decrease in atmospheric haze is defined as a decrease in extinction that would produce a 95% probability of a measurable increase in colorfulness of an object seen through the haze. From the experimental evidence from the two young male observers, a JND in colorfulness was 4.8. For the population in general, this number is certainly too low, since all visual functions decline with age. Thus, the conclusions below about the deciview scale based on this number are understated for the general population.

Analysis of the experimental data showed that for a JND in atmospheric haze as defined above:

- (1) The deciview scale is not uniform in perception over a wide range of visibility conditions. In fact, the change in deciviews needed to be noticeable

varies greatly depending on the optical distance of the landscape feature and its inherent colorfulness.

(2) A 1-deciview change is never noticeable.

What are the implications of these results for measuring progress toward reducing regional haze using the deciview metric? This is difficult to judge because the current proposals are very complex, using particulate measurements and relative humidity to estimate the extinction coefficient and average deciviews for the 20% most-impaired and 20% least-impaired days. The goal is to show no change on the least-impaired days and improvement on the most-impaired days, leading to natural conditions by 2064.¹⁷

The results of this article highlight a possible flaw in this regulatory scheme based on the deciview metric. An unstated assumption is that the nature of the scenic vista can be ignored—that is, a given deciview change will affect the perception of all landscape features in all scenes in the same way. Figure 2 shows that this is approximately true only if all the important landscape features have nearly the same inherent colorfulness and are at distances that correspond to an optical depth of between 1 and 2, or about one quarter to one half of the visual range. In this limited case, the deciview is indeed a uniform metric. However, most scenic vistas do not fit these restrictions and, by Figure 2, will require greater decreases in extinction as measured by deciviews to show a perceptible change. The result is that the emission reductions required by the proposed regulatory analysis are likely to produce much smaller improvements in perceived effects of regional haze than expected. The EPA guidance documents provide an example of an eastern scenic vista with a baseline of 27 deciviews and natural conditions of 11.¹⁷ The decrease in extinction to reach natural conditions by 2064 is 0.35 deciview/yr, or 1.75 deciviews in five years. This five-year reduction should, according to the regulations, result in a noticeable change in regional haze. However, the results herein predict that there would very likely be no noticeable difference in any actual scenic vista in the region as a result of the required emission reductions.

Regional haze rules also call for a uniform rate of improvement in visibility (measured in deciviews) that is needed to go from current conditions to natural conditions by 2064. Since the deciview scale is not uniform in perception over a wide range of visibility conditions, this requirement is also flawed and will not result in uniform improvement in perceived visibility.

ACKNOWLEDGMENTS

The funding for this project was provided by the Electric Power Research Institute under Contract EP-P5419/C2683. The author would like to thank Dr. Naresh Kumar for his support and discussions leading to this work, and Drs.

Shudeish Mahadev and Santiago Urquito for their careful and diligent work as the observers in the field study.

REFERENCES

1. *Fed. Regist.* 1999, 64 (126), 35713-35774.
2. Pritchford, M.; Malm, W. Development and Applications of a Standard Visual Index; *Atmos. Environ.* 1994, 28, 1049-1054.
3. Palmagne, J.C. *Elements of Psychophysical Theory*; Oxford University Press: New York, 1985.
4. Middleton, W.E.K. *Vision through the Atmosphere*; University of Toronto Press: Toronto, Ontario, 1952; p 122.
5. Andrews, E.; Saxena, P.; Musarra, S.; Hildemann, L.M.; Koutrakis, P.; McMurry, P.H.; Olmez, I.; White, W.H. Concentration and Composition of Atmospheric Aerosols from the 1995 SEAVS Experiment and a Review of the Closure between Chemical and Gravimetric Measurements; *J. Air & Waste Manage. Assoc.* 2000, 50, 648-664.
6. Blando, J.D.; Porcja, R.J.; Li, T.H.; Bowman, D.; Lloy, P.J.; Turpin, B.J. Secondary Formation and the Smoky Mountain Organic Aerosol: An Examination of Aerosol Polarity and Functional Group Composition during SEAVS; *Environ. Sci. Technol.* 1998, 32, 604-613.
7. Dick, W.D.; Ziemann, P.J.; Huang, P.E.; McMurry, P.H. Optical Shape Fraction Measurements of Submicrometer Laboratory and Atmospheric Aerosols; *Measur. Sci. Technol.* 1998, 9, 183-196.
8. Ames, R.B.; Hand, J.L.; Kreidenweis, S.M.; Day, D.E.; Malm, W.C. Optical Measurements of Aerosol Size Distributions in Great Smoky Mountains National Park: Dry Aerosol Characterization; *J. Air & Waste Manage. Assoc.* 2000, 50, 665-676.
9. Hand, J.L.; Ames, R.B.; Kreidenweis, S.M.; Day, D.E.; Malm, W.C. Estimates of Particle Hygroscopicity during the Southeastern Aerosol and Visibility Study; *J. Air & Waste Manage. Assoc.* 2000, 50, 677-685.
10. Malm, W.C.; Day, D.E.; Kreidenweis, S.M. Light Scattering Characteristics of Aerosols as a Function of Relative Humidity: Part I—A Comparison of Measured Scattering and Aerosol Concentrations Using the Theoretical Models; *J. Air & Waste Manage. Assoc.* 2000, 50, 686-700.
11. Malm, W.C.; Day, D.E.; Kreidenweis, S.M. Light Scattering Characteristics of Aerosols at Ambient and as a Function of Relative Humidity: Part II—A Comparison of Measured Scattering and Aerosol Concentrations Using Statistical Models; *J. Air & Waste Manage. Assoc.* 2000, 50, 701-709.
12. Henry, R.C.; Mahadev, S.; Urquito, S.; Chitwood, D. Color Perception through Atmospheric Haze; *J. Opt. Soc. Am., A. Optics, Imaging Sci. & Vision* 2000, 17, 831-835.
13. Henry, R.C.; Shibata, T.; Chitwood, D. Construction and Operation of a Video-Based Visual Colorimeter for Atmospheric Research; *Atmos. Environ.* 1994, 28A, 1065-1069.
14. Mahadev, S.; Henry, R.C. Application of a Color Appearance Model to Vision through Atmospheric Haze; *Color Resh. & Appl.* 1999, 24, 112-120.
15. Mahadev, S. Quantifying the Color Appearance of Objects Viewed through Atmospheric Haze. Ph.D. Dissertation, University of Southern California, Los Angeles, CA, 1998.
16. Henry, R.C. Psychophysics, Visibility, and Perceived Transparency; *Atmos. Environ.* 1987, 21, 159-164.
17. U.S. Environmental Protection Agency. *Draft Guidance for Tracking Progress under the Regional Haze Rule*; U.S. Environmental Protection Agency, Office of Air Quality Planning and Standards: Research Triangle Park, NC, September 27, 2001.

About the Author

Dr. Ronald C. Henry is professor of Civil and Environmental Engineering at the University of Southern California, Department of Civil and Environmental Engineering, 3620 South Vermont Ave., Los Angeles, CA 90089-2531; e-mail: rhenry@usc.edu.

