

BEFORE THE ENVIRONMENTAL QUALITY COUNCIL  
STATE OF WYOMING

In the Matter of the Appeal )  
And Petition for Review of: )  
BART Permit No. MD-6040 )  
(Jim Bridger Power Plant); and ) Docket No. 10-2801  
BART Permit No. MD-6042 )  
(Naughton Power Plant). )

---

**RESPONSE TO PACIFICORP'S MOTION FOR PARTIAL SUMMARY  
JUDGMENT**

---

**PacifiCorp's Revised BART applications for JB Units 1-4, 12/07**

**EXHIBIT 5**

---

*Final Report*

## BART Analysis for Jim Bridger Unit 1



Prepared For:

**PaciCorp**

1407 West North Temple  
Salt Lake City, Utah 84116

December 2007

Prepared By:

**CH2MHILL**

215 South State Street, Suite 1000  
Salt Lake City, Utah 84111

---

*Final Report*

# **BART Analysis for Jim Bridger Unit 1**

Submitted to

**PacifiCorp**

December 2007

---

**CH2MHILL**

# Executive Summary

---

## Background

In response to the Regional Haze Rule and Best Available Retrofit Technology (BART) regulations and guidelines, CH2M HILL was requested to perform a BART analysis for PacifiCorp's Jim Bridger Unit 1 (hereafter referred to as Jim Bridger 1). A BART analysis has been conducted for the following criteria pollutants: nitrogen oxide ( $\text{NO}_x$ ), sulfur dioxide ( $\text{SO}_2$ ), and particulate matter less than 10 micrometers in aerodynamic diameter ( $\text{PM}_{10}$ ). The Jim Bridger Station consists of four 530-megawatt (MW) units with a total generating capacity of 2,120 MW. Because the total generating capacity of the Jim Bridger Station exceeds 750 MW, presumptive BART limits apply to Jim Bridger 1, based on the United States Environmental Protection Agency's (EPA) guidelines. Best Available Retrofit Technology emissions limits must be achieved within 5 years after the State Implementation Plan (SIP) is approved by the EPA. A compliance date of 2014 was assumed for this analysis.

In completing the BART analysis, technology alternatives were investigated and potential reductions in  $\text{NO}_x$ ,  $\text{SO}_2$ , and  $\text{PM}_{10}$  emissions rates were identified. The following technology alternatives were investigated, listed below by pollutant:

- $\text{NO}_x$  emission controls:
  - Low- $\text{NO}_x$  burners (LNBs) with over-fire air (OFA)
  - Rotating opposed fire air (ROFA)
  - LNBs with selective non-catalytic reduction (SNCR) system
  - LNBs with selective catalytic reduction (SCR) system
- $\text{SO}_2$  emission controls:
  - Optimize current operation of existing wet sodium flue gas desulfurization (FGD) system
  - Upgrade wet sodium FGD system to achieve an  $\text{SO}_2$  emission rate of 0.10 pound (lb) per million British thermal units (MMBtu)
  - New dry FGD system
- $\text{PM}_{10}$  emission controls:
  - Sulfur trioxide ( $\text{SO}_3$ ) injection flue gas conditioning system on existing electrostatic precipitator (ESP)
  - Polishing fabric filter

## BART Engineering Analysis

The specific steps in a BART engineering analysis are identified in the Code of Federal Regulations (CFR) at 40 CFR 51, Appendix Y, Section IV. The evaluation must include:

- The identification of available, technically feasible, retrofit control options
- Consideration of any pollution control equipment in use at the source (which affects the availability of options and their impacts)
- The costs of compliance with the control options
- The remaining useful life of the facility
- The energy and non-air quality environmental impacts of compliance
- The degree of visibility improvement that may reasonably be anticipated from the use of BART

The following steps are incorporated into the BART analysis:

- Step 1 – Identify All Available Retrofit Control Technologies
  - The identification of available, technically feasible, retrofit control options
  - Consideration of any pollution control equipment in use at the source (which affects the applicability of options and their impacts)
- Step 3 – Evaluate Control Effectiveness of Remaining Control Technologies
- Step 4 – Evaluate Impacts and Document the Results
  - The costs of compliance with the control options
  - The remaining useful life of the facility
  - The energy and non-air quality environmental impacts of compliance
- Step 5 – Evaluate Visibility Impacts
  - The degree of visibility improvement that may reasonably be anticipated from the use of BART

Separate analyses have been conducted for NO<sub>x</sub>, SO<sub>2</sub>, and PM<sub>10</sub> emissions. All costs included in the BART analyses are in 2006 dollars, and costs have not been escalated to the assumed 2014 BART implementation date.

## Coal Characteristics

The main source of coal burned at Jim Bridger 1 will be the Bridger Underground Mine. Secondary sources are the Bridger Surface Mine, the Bridger Highwall Mine; the Black Butte Mine, and the Leucite Hills Mine. These coals are ranked as sub-bituminous, but are closer in

characteristics to bituminous coal in many of the parameters influencing NO<sub>x</sub> formation. These coals have higher nitrogen content than coals from the Powder River Basin (PRB), which represent the bulk of sub-bituminous coal used in the U.S. This BART analysis has considered the higher nitrogen content and different combustion characteristics of PRB coals as compared to those coals used at Jim Bridger 1, and has evaluated the effect of these qualities on NO<sub>x</sub> formation and achievable emission rates.

## Recommendations

CH2M HILL recommends installing the following control devices, which include LNBs with OFA, upgrading the existing FGD system, and operating the existing ESP with an SO<sub>3</sub> flue gas conditioning system. This combination of control devices is identified as Scenario 1 throughout this report.

### NO<sub>x</sub> Emission Control

The BART presumptive NO<sub>x</sub> limit assigned by EPA for tangentially-fired boilers burning sub-bituminous coal is 0.15 lb per MMBtu. However, as documented in this analysis, the characteristics of the Jim Bridger coals are more closely aligned with bituminous coals, with a presumptive BART NO<sub>x</sub> limit of 0.28 lb per MMBtu.

CH2M HILL recommends the existing LNB with OFA as BART for Jim Bridger 1, based on the projected significant reduction in NO<sub>x</sub> emissions, reasonable control costs, and the advantages of no additional power requirements or non-air quality environmental impacts. Nitrogen oxide reductions are expected to be similar to those realized at Jim Bridger 2. CH2M HILL recommends that the unit be permitted at a rate of 0.26 lb per MMBtu.

### SO<sub>2</sub> Emission Control

CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 1, based on the significant reduction in SO<sub>2</sub> emissions, reasonable control costs, and the advantages of minimal additional power requirements and minimal non-air quality environmental impacts. This upgrade approach will meet the BART presumptive SO<sub>2</sub> limit of 0.15 lb per MMBtu.

### PM<sub>10</sub> Emission Control

CH2M HILL recommends finalizing the permitting of the flue gas conditioning system to enhance the performance of the existing ESP as BART for Jim Bridger 1, based on the significant reduction in PM<sub>10</sub> emissions, reasonable control costs, and the advantages of minimal additional power requirements and no non-air quality environmental impacts.

## BART Modeling Analysis

CH2M HILL used the CALPUFF modeling system to assess the visibility impacts of emissions from Jim Bridger 1 at Class I areas. The Class I areas potentially affected are located more than 50 kilometers, but less than 300 kilometers, from the Jim Bridger Plant.

The Class I areas include the following wilderness areas (WA):

- Bridger WA
- Fitzpatrick WA
- Mt. Zirkel WA

Because Jim Bridger 1 will simultaneously control NO<sub>x</sub>, SO<sub>2</sub>, and PM<sub>10</sub> emissions, four post-control atmospheric dispersion modeling scenarios were developed to cover the range of effectiveness for combining the individual NO<sub>x</sub>, SO<sub>2</sub>, and PM<sub>10</sub> control technologies under evaluation. These modeling scenarios, and the controls assumed, are as follows:

- Scenario 1: New LNB with OFA modifications, upgraded wet FGD system, and flue gas conditioning for enhanced ESP performance. As indicated previously, this scenario represents PacifiCorp's preliminary BART selection.
- Scenario 2: New LNB with OFA modifications, upgraded wet FGD system, and new polishing fabric filter.
- Scenario 3: New LNB with OFA modifications and SCR, upgraded wet FGD system, and flue gas conditioning for enhanced ESP performance.
- Scenario 4: New LNB with OFA modifications and SCR, upgraded wet FGD system, and new polishing fabric filter.

Visibility improvements for all emission control scenarios were analyzed, and the results were compared utilizing a least-cost envelope, as outlined in the *New Source Review Workshop Manual*<sup>1</sup>.

## Least-cost Envelope Analysis

EPA has adopted the Least-cost Envelope Analysis Methodology as an accepted methodology for selecting the most reasonable, cost-effective controls. Incremental cost-effectiveness comparisons focus on annualized cost and emission reduction differences between dominant alternatives. The dominant set of control alternatives is determined by generating what is called the envelope of least-cost alternatives. This is a graphical plot of total annualized costs for total emissions reductions for all control alternatives identified in the BART analysis.

To evaluate the impacts of the modeled control scenarios on the three Class I areas, the total annualized cost, cost per deciview (dV) reduction, and cost per reduction in number of days above 0.5 dV were analyzed. This report provides a comparison of the average incremental costs

<sup>1</sup> EPA, 1990. *New Source Review Workshop Manual*. Draft. Environmental Protection Agency, October, 1990.

between relevant scenarios for the three Class I areas; the total annualized cost versus number of days above 0.5 dV, and the total annualized cost versus 98<sup>th</sup> percentile delta-deciview ( $\Delta$ dV) reduction.

Results of the least-cost envelope analysis validate the selection of Scenario 1, based on incremental cost and visibility improvements. Scenario 2 (LNB with OFA, upgraded wet FGD, and polishing fabric filter) is eliminated, because it is to the left of the curve formed by the dominant control alternative scenario, which indicates a scenario with lower improvement and/or higher costs. Scenario 3 (LNB with OFA and SCR, upgraded wet FGD, and flue gas conditioning for enhanced ESP performance) is not selected due to very high incremental costs, on the basis of both a cost per day of improvement and cost per dV reduction. While Scenario 4 (LNB with OFA and SCR, upgraded wet FGD, and polishing fabric filter) provides some potential visibility advantage over Scenario 1, the projected improvement is less than 0.5 dV, and the projected costs are excessive. Therefore, Scenario 1 represents BART for Jim Bridger 1.

## Just-Noticeable Differences in Atmospheric Haze

Studies have been conducted that demonstrate only dV differences of approximately 1.5 to 2.0 dV or more are perceptible by the human eye. Deciview changes of less than 1.5 cannot be distinguished by the average person. Therefore, the modeling analysis results indicate that only minimal, if any, observable visibility improvements at the Class I areas studied would be expected under any of the control scenarios. Thus, the results indicate that even though PacifiCorp will be spending many millions of dollars at this single unit, and over \$1 billion when considering its entire coal fleet, only minimal discernable visibility improvements may result.

# Contents

---

<b>1.0</b>	<b>Introduction .....</b>	<b>1-1</b>
<b>2.0</b>	<b>Present Unit Operation.....</b>	<b>2-1</b>
<b>3.0</b>	<b>BART Engineering Analysis .....</b>	<b>3-1</b>
3.1	Applicability.....	3-1
3.2	BART Process.....	3-1
3.2.1	BART NO <sub>x</sub> Analysis.....	3-2
3.2.2	BART SO <sub>2</sub> Analysis.....	3-14
3.2.3	BART PM <sub>10</sub> Analysis.....	3-17
<b>4.0</b>	<b>BART Modeling Analysis.....</b>	<b>4-1</b>
4.1	Model Selection .....	4-1
4.2	CALMET Methodology.....	4-1
4.2.1	Dimensions of the Modeling Domain.....	4-1
4.2.2	CALMET Input Data.....	4-3
4.2.3	Validation of CALMET Wind Field.....	4-4
4.3	CALPUFF Modeling Approach.....	4-6
4.3.1	Background Ozone and Ammonia.....	4-6
4.3.2	Stack Parameters .....	4-6
4.3.3	Emission Rates .....	4-6
4.3.4	Post-control Scenarios.....	4-7
4.3.5	Modeling Process.....	4-9
4.3.6	Receptor Grids .....	4-9
4.4	CALPOST .....	4-9
4.5	Presentation of Modeling Results .....	4-10
4.5.1	Visibility Changes for Baseline vs. Preferred Scenario.....	4-10
<b>5.0</b>	<b>Preliminary Assessment and Recommendations .....</b>	<b>5-1</b>
5.1	Least-cost Envelope Analysis .....	5-1
5.1.1	Analysis Methodology .....	5-1
5.1.2	Analysis Results.....	5-9
5.2	Recommendations .....	5-9
5.2.1	NO <sub>x</sub> Emission Control .....	5-9
5.2.2	SO <sub>2</sub> Emission Control .....	5-9
5.2.3	PM <sub>10</sub> Emission Control .....	5-9
5.3	Just-Noticeable Differences in Atmospheric Haze .....	5-10
<b>6.0</b>	<b>References .....</b>	<b>6-1</b>

**Tables**

- 2-1 Unit Operation and Study Assumptions
- 2-2 Coal Sources and Characteristics
- 3-1 Coal Characteristics Comparison
- 3-2 NO<sub>x</sub> Control Technology Emission Rate Ranking
- 3-3 NO<sub>x</sub> Control Cost Comparison
- 3-4 SO<sub>2</sub> Control Technology Emission Rates
- 3-5 SO<sub>2</sub> Control Cost Comparison (Incremental to Existing FGD System)
- 3-6 PM<sub>10</sub> Control Technology Emission Rates
- 3-7 PM<sub>10</sub> Control Cost Comparison (Incremental to Existing ESP)
- 4-1 User-specified CALMET Options
- 4-2 BART Model Input Data
- 4-3 Average Natural Levels of Aerosol Components
- 4-4 Costs and Visibility Modeling Results for Baseline vs. Post-control Scenarios at Class I Areas
- 5-1 Control Scenario Results for the Bridger Class I Wilderness Area
- 5-2 Control Scenario Results for the Fitzpatrick Class I Wilderness Area
- 5-3 Control Scenario Results for the Mt. Zirkel Class I Wilderness Area
- 5-4 Bridger Class I Wilderness Area Incremental Analysis Data
- 5-5 Fitzpatrick Class I Wilderness Area Incremental Analysis Data
- 5-6 Mt. Zirkel Class I Wilderness Area Incremental Analysis Data

**Figures**

- 3-1 Illustration of the Effect of Agglomeration on the Speed of Coal Combustion
- 3-2 Plot of Typical Nitrogen Content of Various Coals and Applicable Presumptive BART NO<sub>x</sub> Limits
- 3-3 Plot of Typical Oxygen Content of Various Coals and Applicable Presumptive BART NO<sub>x</sub> Limits
- 3-4 First Year Control Cost for NO<sub>x</sub> Air Pollution Control Options
- 3-5 First Year Control Cost for PM<sub>10</sub> Air Pollution Control Options
- 4-1 Jim Bridger Source-Specific Areas to be Addressed
- 4-2 Surface and Upper Air Stations Used in the Jim Bridger BART Analysis
- 5-1 Least-cost Envelope Bridger Class I WA Days Reduction
- 5-2 Least-cost Envelope Bridger Class I WA 98<sup>th</sup> Percentile Reduction
- 5-3 Least-cost Envelope Fitzpatrick Class I WA Days Reduction
- 5-4 Least-cost Envelope Fitzpatrick Class I WA 98<sup>th</sup> Percentile Reduction
- 5-5 Least-cost Envelope Mt. Zirkel Class I WA Days Reduction
- 5-6 Least-cost Envelope Mt. Zirkel Class I WA 98<sup>th</sup> Percentile Reduction

**Appendices**

- A Economic Analysis
- B 2006 Wyoming BART Protocol

## **Acronyms and Abbreviations**

---

°F	Degrees Fahrenheit
°C	Degrees Celsius
BACT	Best Available Control Technology
BART	Best Available Retrofit Technology
CALDESK	Program to Display Data and Results
CALMET	Meteorological Data Preprocessing Program for CALPUFF
CALPOST	Post-processing Program for Calculating Visibility Impacts
CALPUFF	Gaussian Puff Dispersion Model
CFR	Code of Federal Regulations
CO	Carbon Monoxide
COHPAC	Compact Hybrid Particulate Collector
dV	Deciview
ΔdV	Delta Deciview, Change in Deciview
EIA	Energy Information Administration
ESP	Electrostatic Precipitator
EPA	United States Environmental Protection Agency
Fuel NO <sub>x</sub>	Oxidation of Fuel-bound Nitrogen
FGC	Flue Gas Conditioning
FGD	Flue Gas Desulfurization
f(RH)	Relative Humidity Factors
kW	Kilowatt
LAER	Lowest Achievable Emission Rate
lb	Pound(s)
LNB	Low-NO <sub>x</sub> Burner
LOI	Loss on Ignition
MMBtu	Million British Thermal Units
MM5	Mesoscale Meteorological Model, Version 5
MW	Megawatt
N <sub>2</sub>	Nitrogen
NO <sub>x</sub>	Nitrogen Oxide
NSR Manual	<i>New Source Review Workshop Manual</i> (EPA, 1990)
OFA	Over-fire Air

ACRONYMS AND ABBREVIATIONS (CONTINUED)

PM	Particulate Matter
PM <sub>10</sub>	Particulate Matter less than 10 Micrometers in Aerodynamic Diameter
PM <sub>2.5</sub>	Particulate Matter less than 2.5 Micrometers in Aerodynamic Diameter
PRB	Powder River Basin
ROFA	Rotating Opposed Fire Air
S&L	Sargent & Lundy
SCR	Selective Catalytic Reduction
SIP	State Implementation Plan
SNCR	Selective Non-catalytic Reduction
SO <sub>2</sub>	Sulfur Dioxide
SO <sub>3</sub>	Sulfur Trioxide
Thermal NO <sub>x</sub>	High Temperature Fixation of Atmospheric Nitrogen in Combustion Air
TRC	TRC Company, Inc.
USGS	U.S. Geological Survey
WA	Wilderness Area
WDEQ-AQD	Wyoming Department of Environmental Quality – Air Quality Division

## 1.0 Introduction

---

Best Available Retrofit Technology (BART) guidelines were established as a result of U.S. Environmental Protection Agency (EPA) regulations intended to reduce the occurrence of regional haze in national parks and other Class I protected air quality areas in the United States (40 Code of Federal Regulations [CFR] Part 51). These guidelines provide guidance for states when determining which facilities must install additional controls, and the type of controls that must be used. Facilities eligible for BART installation were built between 1962 and 1977, and have the potential to emit more than 250 tons per year of visibility-impairing pollutants.

The Wyoming Department of Environmental Quality (WDEQ) BART regulations state that each source subject to BART must submit a BART application for a construction permit by December 15, 2006. PacifiCorp received an extension from the WDEQ to submit the BART report for Jim Bridger Unit 1 (hereafter referred to as Jim Bridger 1) by January 12, 2007. The BART report that was submitted to WDEQ in January 2007 included a BART analysis, and a proposal and justification for BART at the source. This revised report—submitted in October 2007—incorporates editorial revisions and new model runs since the January 2007 version.

The State of Wyoming has identified those eligible, in-state facilities that are required to reduce emissions under BART, and will set BART emissions limits for those facilities. This information will be included in the State of Wyoming State Implementation Plan (SIP), which the State has estimated will be formally submitted to the EPA by early 2008. The EPA BART guidelines also state that the BART emission limits must be fully implemented within 5 years of EPA's approval of the SIP.

Five elements related to BART address the issue of emissions for the identified facilities:

- Any existing pollution control technology in-use at the source
- The cost of the controls
- The remaining useful life of the source
- The energy and non-air quality environmental impacts of compliance
- The degree of improvement in visibility that may reasonably be anticipated from the use of such technology

This report documents the BART analysis that was performed on Jim Bridger 1 by CH2M HILL for PacifiCorp. The analysis was performed for the pollutants nitrogen oxide ( $\text{NO}_x$ ), sulfur dioxide ( $\text{SO}_2$ ), and particulate matter less than 10 micrometers in aerodynamic diameter ( $\text{PM}_{10}$ ), because they are the primary criteria pollutants that affect visibility.

Section 2 of this report provides a description of the present unit operation, including a discussion of coal sources and characteristics. The BART Engineering Analysis is provided in Section 3, by pollutant type. Section 4 provides the methodology and results of the BART Modeling Analysis, followed by recommendations in Section 5 and references in Section 6. Appendices provide more detail on the economic analysis and the 2006 Wyoming BART Protocol.

## 2.0 Present Unit Operation

---

The Jim Bridger Station consists of four units with a total generating capacity of 2,120 megawatts (MW). Jim Bridger 1 is a nominal 530 net MW unit located approximately 35 miles northeast of Rock Springs, Wyoming. Unit 1 is equipped with a tangentially fired, pulverized-coal boiler with low- $\text{NO}_x$  burners (LNBs) manufactured by Combustion Engineering. The unit was constructed with a Flakt wire frame electrostatic precipitator (ESP). The unit contains a Babcock & Wilcox wet sodium flue gas desulfurization (FGD) system with three absorber towers installed in 1990. An Emerson Ovation distributed control system was installed in 2006.

Jim Bridger 1 was placed in service in 1974. Its current economic depreciation life is through 2040; however, this analysis is based on a 20-year life for BART control technologies. Assuming a BART implementation date of 2014, this will result in an approximate remaining useful life for Jim Bridger 1 of 20 years from the installation date of any new or modified BART-related equipment. This report does not attempt to quantify any additional life extension costs needed to allow the unit and these control devices at Jim Bridger 1 to operate until 2040.

Table 2-1 lists additional unit information and study assumptions for this analysis.

The BART presumptive  $\text{NO}_x$  limit for tangential-fired boilers burning sub-bituminous coal is 0.15 pound per million British thermal units (lb per MMBtu) and the BART presumptive  $\text{NO}_x$  limit for burning bituminous coal is 0.28 lb per MMBtu. The main sources of coal burned at Jim Bridger 1 are the Bridger Mine and secondarily the Black Butte Mine and Leucite Hills Mine. These coals are ranked as sub-bituminous, but are closer in characteristics to bituminous coal in many of the parameters influencing  $\text{NO}_x$  formation. These coals have higher nitrogen content than coals from the Powder River Basin (PRB), which represent the bulk of sub-bituminous coal used in the U.S. This BART analysis has considered the higher nitrogen content and the different combustion characteristics of PRB coals, as compared to those coals used at Jim Bridger 1, and has evaluated the effect of these qualities on  $\text{NO}_x$  formation and achievable emission rates. Coal sources and characteristics are summarized in Table 2-2. The primary source of coal will be the Bridger Underground Mine, and data on coal from this source were used in the modeling analysis. For the coal analysis that is presented in Section 3, the data from all the coal sources were used.

**TABLE 2-1**  
**Unit Operation and Study Assumptions**  
*Jim Bridger 1*

<b>General Plant Data</b>	
Site Elevation (feet above mean sea level)	6669
Stack Height (feet)	500
Stack Exit ID (feet) /Exit Area (square feet)	24 /452.4
Stack Exit Temperature (degrees Fahrenheit)	140
Stack Exit Velocity (feet per second)	84.0
Stack Flow (actual cubic feet per minute)	2,281,182
Latitude (degree: minute: second)	41:44:07 north
Longitude (degree: minute: second)	108:47:12 west
Annual Unit Capacity Factor (percentage)	90
Net Unit Output (megawatts)	530
Net Unit Heat Rate (British thermal units (Btu) per kilowatt-hour)(100% load)	10,400 (as measured by fuel throughput)
Boiler Heat Input (million Btu (MMBtu) per hour)(100% load)	6,000 (as measured by continuous emission monitoring)
Type of Boiler	Tangentially fired
Boiler Fuel	Coal
Coal Sources	Bridger Mine, Black Butte Mine, Leucite Hills Mine
Coal Heating Value (Btu per pound [lb]) <sup>(a)</sup>	9,660
Coal Sulfur Content (percentage by weight [wt. %]) <sup>(a)</sup>	0.58
Coal Ash Content (wt. %) <sup>(a)</sup>	10.3
Coal Moisture Content (wt. %) <sup>(a)</sup>	19.3
Coal Nitrogen Content (wt. %) <sup>(a)</sup>	0.98
Current Nitrogen Oxide (NO <sub>x</sub> ) Controls	Low-NO <sub>x</sub> burners
NO <sub>x</sub> Emission Rate (lb/MMBtu)	0.45
Current Sulfur Dioxide (SO <sub>2</sub> ) Controls	Sodium-based wet scrubber
SO <sub>2</sub> Emission Rate (lb/MMBtu)	0.267
Current PM <sub>10</sub> <sup>(b)</sup> Controls	Electrostatic Precipitator
PM <sub>10</sub> Emission Rate (lb/MMBtu) <sup>(c)</sup>	0.045

**NOTES:**

(a)Coal characteristics based on Bridger Underground Mine (primary coal source)

(b)PM<sub>10</sub> refers to particulate matter less than 10 micrometers in aerodynamic diameter(c)Based on maximum historic emission rate from 1999 to 2001, prior to installation of the sulfur trioxide (SO<sub>3</sub>) injection system.

**TABLE 2-2**  
Coal Sources and Characteristics  
*Jim Bridger 1*

								Ultimate Analysis (% dry basis)				
								Hydrogen	Carbon	Sulfur	Nitrogen	Oxygen
Mines	Moisture (%)	Volatile Matter (%)	Fixed Carbon (%)	British thermal units per pound (Btu/lb)	Moisture and Ash Free (Btu/lb)	Sulfur (%)	Hydrogen	Carbon	Sulfur	Nitrogen	Oxygen	Ash
<b>Bridger Mine Underground</b>	19.3	10.3	32.2	38.3	9860	0.58	13712	4.66	69.2	0.72	1.22	11.8
Maximum												12.4
Minimum												
<b>Bridger Mine Surface</b>	19.1	10.6	32.3	38.0	9390	0.57	13340	4.38	37.4	0.71	1.26	13.2
Maximum	20.5	12.5	35.5	41.9	9800	0.72	13500	4.69	4.0	0.90	1.43	14.8
Minimum	17.5	9.0	31.0	36.0	9000	0.49	13100	4.00	64.3	0.60	1.14	11.7
<b>Bridger Mine Highwall</b>	18.0	9.5	33.0	39.5	9700	0.58	13500					11.2
Maximum												
Minimum												
<b>Black Butte Mine</b>	20.0	9.2	33.3	35.6	9450	0.45	13330	4.43	68.7	0.56	1.47	13.4
Maximum	21.1	10.8	35.4	41.9	10275	0.62	13500	4.66	70.5	0.78	1.69	14.8
Minimum	18.0	7.6	29.9	36.8	9180	0.33	13140	4.24	66.1	0.41	1.25	11.6
<b>Leucite Hills Mine (through 2009)</b>	19.4	11.5	30.7	38.3	9080	0.64	13140	4.20	66.0	0.81	1.48	13.2
Maximum	23.0	15.0	33.0	43.0	10250	0.90	13800	4.70	70.0	1.20	1.64	17.1
Minimum	17.0	8.0	28.3	33.6	8000	0.40	12300	3.70	61.0	0.50	1.32	10.5
												10.0

## **3.0 BART Engineering Analysis**

---

This section presents the required BART engineering analysis.

### **3.1 Applicability**

In compliance with regional haze requirements, the State of Wyoming must prepare and submit visibility SIPs to the EPA for Class I areas. The State has estimated that the formal submittal of the SIPs will occur by early 2008. The first phase of the regional haze program is the implementation of BART emission controls on all BART eligible units, within 5 years after EPA approval of the SIP.

### **3.2 BART Process**

The specific steps in a BART engineering analysis are identified in 40 CFR 51, Appendix Y, Section IV. The evaluation must include:

- The identification of available, technically feasible, retrofit control options
- Consideration of any pollution control equipment in use at the source (which affects the availability of options and their impacts)
- The costs of compliance with the control options
- The remaining useful life of the facility
- The energy and non-air quality environmental impacts of compliance
- The degree of visibility improvement that may reasonably be anticipated from the use of BART

The following steps are incorporated into the BART analysis:

- Step 1 – Identify All Available Retrofit Control Technologies
- Step 2 – Eliminate Technically Infeasible Options
  - The identification of available, technically feasible, retrofit control options
  - Consideration of any pollution control equipment in use at the source (which affects the applicability of options and their impacts)
- Step 3 – Evaluate Control Effectiveness of Remaining Control Technologies

- Step 4 – Evaluate Impacts and Document the Results
  - The costs of compliance with the control options
  - The remaining useful life of the facility
  - The energy and non-air quality environmental impacts of compliance
- Step 5 – Evaluate Visibility Impacts
  - The degree of visibility improvement that may reasonably be anticipated from BART use

In order to minimize costs in the BART analysis, consideration was made of any pollution control equipment in use at the source, the costs of compliance associated with the control options, and the energy and non-air quality environmental impacts of compliance using these existing control devices. In some cases, enhancing the performance of the existing control equipment was considered. Other scenarios with new control equipment were also developed.

Separate analyses have been conducted for NO<sub>x</sub>, SO<sub>2</sub>, and PM<sub>10</sub> emissions. All costs included in the BART analysis are in 2006 dollars, and costs have not been escalated to the assumed 2014 BART implementation date.

### 3.2.1 BART NO<sub>x</sub> Analysis

Nitrogen oxide formation in coal-fired boilers is a complex process that is dependent on a number of variables, including operating conditions, equipment design, and coal characteristics.

#### Formation of NO<sub>x</sub>

During coal combustion, NO<sub>x</sub> is formed in three different ways. The dominant source of NO<sub>x</sub> formation is the oxidation of fuel-bound nitrogen (fuel NO<sub>x</sub>). During combustion, part of the fuel-bound nitrogen is released from the coal with the volatile matter, and part is retained in the solid portion (char). The nitrogen chemically bound in the coal is partially oxidized to nitrogen oxides (nitric oxide and nitrogen dioxide) and partially reduced to molecular nitrogen (N<sub>2</sub>). A smaller part of NO<sub>x</sub> formation is due to high temperature fixation of atmospheric nitrogen in the combustion air (thermal NO<sub>x</sub>). A very small amount of NO<sub>x</sub> is called prompt NO<sub>x</sub>. Prompt NO<sub>x</sub> results from an interaction of hydrocarbon radicals, nitrogen, and oxygen.

In a conventional pulverized coal burner, air is introduced with turbulence to promote good mixing of fuel and air, which provides stable combustion. However, not all of the oxygen in the air is used for combustion. Some of the oxygen combines with the fuel nitrogen to form NO<sub>x</sub>.

Coal characteristics directly and significantly affect NO<sub>x</sub> emissions from coal combustion. Coal ranking is a means of classifying coals according to their degree of metamorphism in the natural series, from lignite to sub-bituminous to bituminous and on to anthracite. Lower rank coals, such as the sub-bituminous coals from the PRB, produce lower NO<sub>x</sub> emissions than higher rank bituminous coals, due to their higher reactivity and lower nitrogen content. The fixed carbon to volatile matter ratio (fuel ratio), coal oxygen content, and rank are good relative indices of the reactivity of a coal. Lower rank coals release more organically bound nitrogen earlier in the combustion process than do higher rank bituminous coals. When used with LNBs, sub-bituminous coals create a longer time for the kinetics to promote more stable molecular nitrogen, and hence result in lower NO<sub>x</sub> emissions.

Coals from the PRB are classified as sub-bituminous C and demonstrate the high reactivity and low NO<sub>x</sub> production characteristics described above. Based on data from the Energy Information Administration (EIA), PRB coals currently represent 88 percent of total U.S. sub-bituminous production and 73 percent of western coal production (Energy Information Administration, 2006). Most references to western coal and sub-bituminous coal infer PRB origin and characteristics. Emissions standards differentiating between bituminous and sub-bituminous coals are presumed to use PRB coal as the basis for the sub-bituminous standards, due to its dominant market presence and unique characteristics.

There are a number of western coals that are classified as sub-bituminous, however, they border on being ranked as bituminous and do not display many of the qualities of PRB coals, including most of the low NO<sub>x</sub> forming characteristics. Coals from the Bridger, Black Butte, and Leucite Hills mines fall into this category.

As defined by the American Society for Testing and Materials, the only distinguishing characteristic that classifies the coals used at Jim Bridger 1 as sub-bituminous rather than bituminous – is that they are “agglomerating” as compared to “non-agglomerating.” Agglomerating as applied to coal is “the property of softening when it is heated to above about 400 degrees Celsius (°C) in a non-oxidizing atmosphere, and then appearing as a coherent mass after cooling to room temperature.” Because the agglomerating property of coals is the result of particles transforming into a plastic or semi-liquid state when heated, it reflects a change in surface area of the particle. Thus, with the application of heat, agglomerating coals would tend to develop a non-porous surface, while the surface of non-agglomerating coals would become even more porous with combustion. As shown in Figure 3-1, the increased porosity provides more particle surface area, resulting in more favorable combustion conditions. This non-agglomerating property assists in making sub-bituminous coals more amenable to controlling NO<sub>x</sub>, by allowing less air to be introduced during the initial ignition portion of the combustion process. The coals from the Bridger, Black Butte and Leucite Hills mines just barely fall into the category of non-agglomerating coals. While each of these coals is considered non-agglomerating, they either do not exhibit those properties of non-agglomerating coals or exhibit them to only a minor degree. The conditions during combustion of typical non-agglomerating coals that make it easier to control NO<sub>x</sub> emissions do not exist during combustion of the Bridger blends of coals.

**FIGURE 3-1**  
**Illustration of the Effect of Agglomeration on the Speed of Coal Combustion**  
*Jim Bridger 1*




Table 3-1 shows key characteristics of a typical PRB coal, compared to coals from the Bridger Mine, Black Butte, and Leucite Hills, as well as coal from Twentymile, which is a representative western bituminous coal.

**TABLE 3-1**  
**Coal Characteristics Comparison**  
*Jim Bridger 1*

Parameter	Typical Powder River Basin	Bridger Mine	Black Butte	Leucite Hills	Twentymile
Nitrogen (% dry)	1.10	1.26	1.47	1.48	1.85
Oxygen (% dry)	16.2	13.2	13.4	13.2	7.19
Coal rank	Sub C	Sub B	Sub B	Sub B	Bitum. high volatility B


As shown in Table 3-1, although Bridger, Black Butte, and Leucite Hills are classified as sub-bituminous, they all exhibit higher nitrogen content and lower oxygen content than the PRB coal. The higher nitrogen content is an indication that more nitrogen is available to the combustion process and higher NO<sub>x</sub> emissions are likely. Oxygen content can be correlated to the reactivity of the coal, with more reactive coals generally containing higher levels of oxygen. More reactive coals tend to produce lower NO<sub>x</sub> emissions, and they are also more conducive to reduction of NO<sub>x</sub> emissions through the use of combustion control measures, such as LNBs and over-fire air (OFA). These characteristics indicate that higher NO<sub>x</sub> formation is likely with coal from the Bridger, Black Butte, and Leucite Hills mines, rather than with PRB coal. The Bridger, Black Butte, and Leucite Hills coals all contain quality characteristics that fall between a typical PRB coal and Twentymile. Twentymile is a clearly bituminous coal that produces higher NO<sub>x</sub>, as has been demonstrated at power plants burning this fuel.

Figures 3-2 and 3-3 graphically illustrate the relationship of nitrogen and oxygen content to the BART presumptive NO<sub>x</sub> limits for the coals listed in Table 3-1. Each chart identifies the presumptive BART limit associated with a typical bituminous and sub-bituminous coal, and demonstrates how the Jim Bridger coal falls between these two general coal classifications.


The Bridger-blend-data-point represents a combination of coals from the Bridger-Mine, Black Butte, and Leucite Hills that has been used at Jim Bridger 1, and indicates the average NO<sub>x</sub> emission rate achieved during the years 2003 to 2005. The Jim Bridger 2 data point consists of the same blend of coals as Jim Bridger 1, and represents the NO<sub>x</sub> emission rate achieved after installation of Alstom's current state-of-the-art TFS2000 LNB and OFA system. The long-term sustainable emission rate for this system is expected to be 0.24 lb per MMBtu. All four units at Jim Bridger consist of identical boilers; while there may be some differences in performance among them, installation of the TFS2000 firing system at Jim Bridger 1 would likely result in performance and NO<sub>x</sub> emission rates comparable to those at Jim Bridger 2.

Figures 3-2 and 3-3 both demonstrate that for the Jim Bridger units with the TFS2000 low NO<sub>x</sub> emission system installed and burning a combination of the Bridger, Black Butte, and Leucite Hill coals, the likely NO<sub>x</sub> emission rate will be closer to the bituminous end (0.28) of the BART presumptive NO<sub>x</sub> limit range, rather than the BART presumptive NO<sub>x</sub> limit of 0.15 lb per MMBtu for sub-bituminous coal. All these factors are consistent with the observed sustainable rate of 0.24 lb per MMBtu.

**FIGURE 3-2**  
Plot of Typical Nitrogen Content of Various Coals and Applicable Presumptive BART NO<sub>x</sub> Limits  
*Jim Bridger 1*



**FIGURE 3-3**  
Plot of Typical Oxygen Content of Various Coals and Applicable Presumptive BART NO<sub>x</sub> Limits  
*Jim Bridger 1*



Coal quality characteristics also impact the design and operation of the boiler and associated auxiliary equipment. Minor changes in quality can sometimes be accommodated through operational adjustments or changes to equipment. It is important to note, however, that consistent variations in quality or assumptions of "average" quality for performance projections can be problematic. This is particularly troublesome when dealing with performance issues that are very sensitive to both coal quality and combustion conditions, such as NO<sub>x</sub> formation. There is significant variability in the quality of coals burned at Jim Bridger 1. In addition to burning coal from Black Butte and Leucite Hills, Jim Bridger 1 burns coal supplied from the Bridger Mine consisting of three sources: underground, surface, and highwall operations. Each of these coal sources has different quality characteristics, as well as inherent variability in composition of the coal within the mine.

Several of the coal quality characteristics and their effect on NO<sub>x</sub> formation have been previously discussed. There are some additional considerations that illustrate the complexity of achieving and maintaining consistent low NO<sub>x</sub> emissions with pulverized coal on a shorter term, such as a 30-day rolling average basis.

Good combustion is based on the "three Ts": time, temperature, and turbulence. These parameters along with a "design" coal are taken into consideration when designing a boiler and associated firing equipment such as fans, burners, and pulverizers. If a performance requirement, such as NO<sub>x</sub> emission limits, is subsequently changed, conflicts with other performance issues can result.

Jim Bridger 1 is located at an altitude of 6,669 feet above sea level. At this elevation, atmospheric pressure is lower (11.5 pounds per square inch) as compared with sea level pressure of 14.7 pounds per square inch. This lower pressure means that less oxygen is available for combustion for each volume of air. In order to provide adequate oxygen to meet the requirements for efficient combustion, larger volumes of air are required. When adjusting air flows and distribution to lower NO<sub>x</sub> using LNBs and OFA, original boiler design restrictions again limit the modifications that can be made and still achieve satisfactory combustion performance.

Another significant factor in controlling NO<sub>x</sub> emissions is the fineness of the coal entering the burners. Fineness is influenced by the grindability index (Hardgrove) of the coal. Finer coal particles promote release of volatiles and assist char burnout due to more surface area exposed to air. Nitrogen oxide reduction with high volatile coals is improved with greater fineness and with proper air staging. The lower rank sub-bituminous coals such as PRB coals are quite friable and easy to grind. Coals with lower Hardgrove Grindability Index values, such as those used at Jim Bridger 1, are more difficult to grind and can contribute to higher NO<sub>x</sub> levels. In addition, coal fineness can deteriorate over time periods between pulverizer maintenance and service as pulverizer grinding surfaces wear.

In summary, when all the factors of agglomeration versus non-agglomeration, nitrogen and oxygen content of the coals, and the grindability index are taken into account, this analysis demonstrates that, for the coal used at Jim Bridger 1, the more applicable presumptive BART limit is 0.28 lb per MMBtu. The BART analysis for NO<sub>x</sub> emissions from Jim Bridger 1 is further described below.

### Step 1: Identify All Available Retrofit Control Technologies

The first step of the BART process is to evaluate NO<sub>x</sub> control technologies with practical potential for application to Jim Bridger 1, including those control technologies identified as Best Available Control Technology (BACT) or lowest achievable emission rate (LAER) by permitting agencies across the United States. A broad range of information sources have been reviewed in an effort to identify potentially applicable emission control technologies. Jim Bridger 1 NO<sub>x</sub> emissions are currently controlled through the use of good combustion practices and OFA.

The following potential NO<sub>x</sub> control technology options were considered:

- New/modified LNBs with advanced OFA
- Rotating Opposed Fire Air (ROFA)
- Conventional selective non-catalytic reduction (SNCR) system
- Selective catalytic reduction (SCR) system

### Step 2: Eliminate Technically Infeasible Options

For Jim Bridger 1, a tangential-fired configuration burning sub-bituminous coal, technical feasibility will primarily be determined by physical constraints, boiler configuration, and on the ability to achieve the regulatory presumptive limit (used as a guide) of 0.28 lb per MMBtu of NO<sub>x</sub>. Jim Bridger 1 has an uncontrolled NO<sub>x</sub> emission rate of 0.45 lb per MMBtu.

For this BART analysis, information pertaining to LNBs, OFA, SNCR, and SCR were based on the *Multi-Pollutant Control Report* (Sargent and Lundy, 2002, hereafter referred to as the S&L Study). Updated cost estimates for SCR and SNCR were used (Sargent and Lundy, 2006). PacifiCorp provided additional emissions data and costs developed by boiler vendors for LNBs and OFA. Also, CH2M HILL solicited a proposal from Mobotec for their ROFA technology.

With SNCR, an amine-based reagent such as ammonia, or more commonly urea, is injected into the furnace within a temperature range of 1,600 degrees Fahrenheit (°F) to 2,100°F, where it reduces NO<sub>x</sub> to nitrogen and water. Nitrogen oxide reductions of up to 60 percent have been achieved, although 15 to 30 percent is more realistic for most applications. Selective non-catalytic reduction is typically applied on smaller units. Adequate reagent distribution in the furnaces of large units can be problematic.

Table 3-2 summarizes the control technology options evaluated in this BART analysis, along with projected NO<sub>x</sub> emission rates. All technologies can meet the applicable presumptive BART limit of 0.28 lb per MMBTU.

TABLE 3-2  
NO<sub>x</sub> Control Technology Emission Rate Ranking  
*Jim Bridger 1*

Technology	Projected Emission Rate (pounds per million British thermal units)
Presumptive Best Available Retrofit Technology (BART) Limit	0.28
Low-NO <sub>x</sub> Burners (LNBs) with Over-fire Air (OFA)	0.24
Rotating Opposed Fire Air (ROFA)	0.22
LNB with OFA and Selective Non-catalytic Reduction (SNCR)	0.20
LNB with OFA and Selective Catalytic Reduction (SCR)	0.07

### Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

Preliminary vendor proposals, such as those used to support portions of this BART analysis, may be technically feasible and provide expected or guaranteed emission rates; however, the proposals include inherent uncertainties. These proposals are usually prepared in a limited time frame, may be based on incomplete information, may contain over-optimistic conclusions, and are non-binding. Therefore, emission rate values obtained in such preliminary proposals must be qualified, and it must be recognized that contractual guarantees are established only after more detailed analysis has been completed. The following subsections describe the control technologies and the control effectiveness evaluated in this BART analysis.

**New LNBs with OFA System.** The mechanism used to lower NO<sub>x</sub> with LNBs is to stage the combustion process and provide a fuel-rich condition initially; this is so oxygen needed for combustion is not diverted to combine with nitrogen and form NO<sub>x</sub>. Fuel-rich conditions favor the conversion of fuel nitrogen to N<sub>2</sub> instead of NO<sub>x</sub>. Additional air (or OFA) is then introduced downstream in a lower temperature zone to burn out the char.

Both LNBs and OFA are considered to be a capital cost, combustion technology retrofit. For LNB retrofits to units configured with tangential-firing such as Jim Bridger 1, it is generally necessary to increase the burner spacing; this prevents interaction of the flames from adjacent burners and reduces burner zone heat flux. These modifications usually require boiler waterwall tube replacement.

Information provided to CH2M HILL by PacifiCorp—based on the S&L Study and data from boiler vendors—indicates that new LNB and OFA retrofit at Jim Bridger 1 would result in an expected NO<sub>x</sub> emission rate of 0.24 lb per MMBtu. PacifiCorp has indicated that this rate corresponds to a vendor guarantee, not a vendor prediction, and they believe that this emission rate can be sustained as an average between overhauls. This emission rate represents a significant reduction from the current NO<sub>x</sub> emission rate, and is below the more applicable presumptive NO<sub>x</sub> emission rate of 0.28 lb per MMBtu.

**ROFA.** Mobotec markets ROFA as an improved second generation OFA system. Mobotec states that “the flue-gas volume of the furnace is set in rotation by asymmetrically placed air nozzles. Rotation is reported to prevent laminar flow, so that the entire volume of the furnace can be used

more effectively for the combustion process. In addition, the swirling action reduces the maximum temperature of the flames and increases heat absorption. The combustion air is also mixed more effectively." A typical ROFA installation will have a booster fan(s) to supply the high velocity air to the ROFA boxes, and Mobotec would propose two 4,000 to 4,300 Hp fans for Jim Bridger 1.

Mobotec expects to achieve a NO<sub>x</sub> emission rate of 0.18 lb per MMBtu using ROFA technology. An operating margin of 0.04 lb per MMBtu was added to the expected rate due to Mobotec's limited ROFA experience with western sub-bituminous coals. Under the Mobotec proposal, primarily based on ROFA equipment, the operation of existing LNB and OFA ports will be analyzed. While a typical installation does not require modification to the existing LNB system, and the existing OFA ports are not used, results of computational fluid dynamics modeling will determine the quantity and location of new ROFA ports. The Mobotec proposal includes bent tube assemblies for OFA port installation. Mobotec does not provide installation services, because they believe that the Owner can more cost effectively contract for these services. However, they do provide one onsite construction supervisor during installation and startup.

**SNCR.** Selective non-catalytic reduction is generally utilized to achieve modest NO<sub>x</sub> reductions on smaller units. With SNCR, an amine-based reagent such as ammonia—or more commonly urea—is injected into the furnace within a temperature range of 1,600°F to 2,100°F, where it reduces NO<sub>x</sub> to nitrogen and water. Nitrogen oxide reductions of up to 60 percent have been achieved, although 20 to 40 percent is more realistic for most applications.

Reagent utilization, which is a measure of the efficiency with which the reagent reduces NO<sub>x</sub>, can range from 20 to 60 percent, depending on the amount of reduction, unit size, operating conditions, and allowable ammonia slip. With low reagent utilization, low temperatures, or inadequate mixing, ammonia slip occurs, allowing unreacted ammonia to create problems downstream. The ammonia may render fly ash unsaleable, react with sulfur to foul heat exchange surfaces, and/or create a visible stack plume. Reagent utilization can have a significant impact on economics, with higher levels of NO<sub>x</sub> reduction generally resulting in lower reagent utilization and higher operating cost.

Reductions from higher baseline concentrations (inlet NO<sub>x</sub>) are lower in cost per ton, but result in higher operating costs, due to greater reagent consumption. To reduce reagent costs, S&L has assumed that combustion modifications including LNBs and advanced OFA are capable of achieving a projected NO<sub>x</sub> emission rate of 0.24 lb per MMBtu. A further reduction of 15 percent in NO<sub>x</sub> emission rates for SNCR would result in a projected emission rate of 0.20 lb per MMBtu.

**SCR.** SCR works on the same chemical principle as SNCR but SCR uses a catalyst to promote the chemical reaction. Ammonia is injected into the flue-gas stream, where it reduces NO<sub>x</sub> to nitrogen and water. Unlike the high temperatures required for SNCR, in SCR the reaction takes place on the surface of a vanadium/titanium-based catalyst at a temperature range between 580° F to 750° F. Due to the catalyst, the SCR process is more efficient than SNCR and results in lower NO<sub>x</sub> emissions. The most common type of SCR is the high-dust configuration, where the catalyst is located downstream from the boiler economizer and upstream of the air heater and any particulate control equipment. In this location, the SCR is exposed to the full concentration of fly ash in the flue gas that is leaving the boiler. The high-dust configuration is assumed for Jim Bridger 1. In a full-scale SCR, the flue ducts are routed to a separate large reactor containing

the catalyst. With in-duct SCR, the catalyst is located in the existing gas duct, which may be expanded in the area of the catalyst to reduce flue gas flow velocity and increase flue gas residence time. Due to the higher removal rate, a full-scale SCR was used as the basis for analysis at Jim Bridger 1.

Sargent and Lundy prepared the design conditions and cost estimates for SCR at Jim Bridger 1. As with SNCR, it is generally more cost effective to reduce NO<sub>x</sub> emission levels as much as possible through combustion modifications, in order to minimize the catalyst surface area and ammonia requirements of the SCR. The S&L design basis for LNB with OFA and SCR results in a projected NO<sub>x</sub> emission rate of 0.07 lb per MMBtu. Additional catalyst surface was included in the SCR design to accommodate the characteristics of the coal used at Jim Bridger 1.

**Level of Confidence for Vendor Post-control Emissions Estimates.** In order to determine the level of NO<sub>x</sub> emissions needed to consistently achieve compliance with an established goal, a review of typical NO<sub>x</sub> emissions from coal-fired generating units was completed. As a result of this review, it was noted that NO<sub>x</sub> emissions can vary significantly around an average emissions level. This variance can be attributed to many reasons, including coal characteristics, unit load, boiler operation including excess air, boiler slagging, burner equipment condition, coal mill fineness, and so forth.

The steps utilized for determining a level of confidence for the vendor expected value are as follows:

- Establish expected NO<sub>x</sub> emissions value from vendor.
- Evaluate vendor experience and historical basis for meeting expected values.
- Review and evaluate unit physical and operational characteristics and restrictions. The fewer variations there are in operations, coal supply, etc., the more predictable and less variant the NO<sub>x</sub> emissions are.
- For each technology expected value, there is a corresponding potential for actual NO<sub>x</sub> emissions to vary from this expected value. From the vendor information presented, along with anticipated unit operational data, an adjustment to the expected value can be made.

#### Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

**Energy Impacts.** Installation of LNBs and modification to the existing OFA systems are not expected to significantly impact the boiler efficiency or forced draft fan power usage. Therefore, these technologies will not have energy impacts.

The Mobotec ROFA system requires installation and operation of two 4,000 to 4,300 horsepower ROFA fans (6,410 kilowatts [kW] total). The SNCR system would require approximately 530 kW of additional power.

Selective catalytic reduction retrofit impacts the existing flue gas fan systems, due to the additional pressure drop associated with the catalyst, which is typically a 6- to 8-inch water gage

increase. Total additional power requirements for SCR installation at Jim Bridger 1 are estimated at approximately 3,280 kW, based on the S&L Study.

**Environmental Impacts.** Mobotec has predicted that carbon monoxide (CO) emissions, and unburned carbon in the ash, commonly referred to as LOI (loss on ignition), would be the same or lower than prior levels for the ROFA system.

The installation of SNCR and SCR could impact the saleability and disposal of fly ash due to ammonia levels, and could potentially create a visible stack plume, which may negate other visibility improvements. Other environmental impacts involve the storage of ammonia, especially if anhydrous ammonia is used, and the transportation of the ammonia to the power plant site.


**Economic Impacts.** Costs and schedules for the LNBs and OFA, SNCR, and SCR were furnished to CH2M HILL by PacifiCorp, developed using S&L's internal proprietary database, and supplemented (as needed) by vendor-obtained price quotes. The relative accuracy of these cost estimates is stated by S&L to be in the range of plus or minus 20 percent. Cost for the ROFA system was obtained from Mobotec.

A comparison of the technologies on the basis of costs, design control efficiencies, and tons of NO<sub>x</sub> removed is summarized in Table 3-3; and the first year control costs are shown in Figure 3-4. The complete economic analysis is contained in Appendix A.

TABLE 3-3  
NO<sub>x</sub> Control Cost Comparison  
*Jim Bridger 1*

Factor	Low-NO <sub>x</sub> Burners (LNBs) with Over-fire Air (OFA)	Rotating Opposed Fire Air (ROFA)	LNB with OFA and Selective Non-catalytic Reduction (SNCR)	LNB with OFA and Selective Catalytic Reduction (SCR)
Total Installed Capital Costs	\$8.7 million	\$20.5 million	22.1 million	\$129.6 million
Total First Year Fixed and Variable Operation and Maintenance Costs	\$0.1 million	\$2.6 million	\$1.5 million	\$3.3 million
Total First Year Annualized Cost	\$0.9 million	\$4.6 million	\$3.6 million	\$15.6 million
Power Consumption (megawatts)	0	6.4	0.5	3.3
Annual Power Usage (1,000 megawatt-hours per year)	0	50.6	4.2	25.8
Nitrogen Oxide (NO <sub>x</sub> ) Design Control Efficiency	46.7%	51.1%	55.6%	84.4%
NO <sub>x</sub> Removed per Year (Tons)	4,967	5,440	5,913	8,987
First Year Average Control Cost (dollars per ton [\$/Ton] of NO <sub>x</sub> Removed)	\$181/ton	\$843/ton	\$613/ton	\$1,736/ton
Incremental Control Cost (\$/Ton of NO <sub>x</sub> Removed)	\$181/ton	\$7,797/ton	\$2,885/ton	\$3,894/ton

FIGURE 3-4  
First Year Control Cost for NO<sub>x</sub> Air Pollution Control Options  
*Jim Bridger 1*



**Preliminary BART Selection.** PacifiCorp selects LNBs with OFA as BART for Jim Bridger 1 based on its significant reduction in NO<sub>x</sub> emissions, reasonable control cost, and no additional power requirements or environmental impacts. This scenario does not meet the EPA presumptive limit of 0.15 lb per MMBtu for sub-bituminous coal, but it does meet an emission rate that falls between the bituminous coal presumptive limit of 0.28 lb per MMBtu and the 0.15 lb per MMBtu limit for sub-bituminous coal, which, as discussed in the section on coal quality, is appropriate for this unit.

**Step 5: Evaluate Visibility Impacts**

Please see Section 4, BART Modeling Analysis.

**3.2.2 BART SO<sub>2</sub> Analysis**

Sulfur dioxide forms in the boiler during the combustion process, and is primarily dependent on coal sulfur content. The BART analysis for SO<sub>2</sub> emissions on Jim Bridger 1 is described below.

**Step 1: Identify All Available Retrofit Control Technologies**

A broad range of information sources were reviewed, in an effort to identify potentially applicable emission control technologies for SO<sub>2</sub> at Jim Bridger 1; this included control technologies identified as BACT or LAER by permitting agencies across the United States.

The following potential SO<sub>2</sub> control technology options were considered:

- Optimize current operation of existing wet sodium FGD system
- Upgrade wet sodium FGD system to meet SO<sub>2</sub> emission rate of 0.10 lb per MMBtu
- New dry FGD system

**Step 2: Eliminate Technically Infeasible Options**

Technical feasibility will primarily be based on the regulatory presumptive limit (used as a guideline) of 95 percent reduction in SO<sub>2</sub> emissions, or 0.15 lb per MMBtu. Based on the coal that Jim Bridger 1 currently burns, the unit would be required to achieve an 87.5 percent SO<sub>2</sub> removal efficiency to meet the presumptive limit of 0.15 lb per MMBtu.

Table 3-4 summarizes the control technology options evaluated in this BART analysis, along with projected SO<sub>2</sub> emission rates. Only one technology option can meet the applicable presumptive BART limit of 0.15 lb per MMBtu.

TABLE 3-4  
SO<sub>2</sub> Control Technology Emission Rates  
*Jim Bridger 1*

Technology	Projected Emission Rate (pounds per million British thermal units)
Presumptive Best Available Retrofit Technology (BART) Limit	0.15
Upgrade Existing Wet Sodium System	0.10
Optimize Existing Wet Sodium System	0.20
New Dry Flue Gas Desulfurization System	0.21

**Wet Sodium FGD System.** Wet sodium FGD systems operate by treating the flue gas in large scrubber vessels with a soda ash solution. The scrubber mixes the flue gas and alkaline reagent using a series of spray nozzles to distribute the reagent across the scrubber vessel. The sodium in the reagent reacts with the SO<sub>2</sub> in the flue gas to form sodium sulfite and sodium bisulfite, which are removed from the scrubber and disposed.

The wet sodium FGD system at Jim Bridger 1 currently achieves approximately 78 percent SO<sub>2</sub> removal to achieve an SO<sub>2</sub> outlet emission rate of 0.27 lb per MMBtu. Optimizing the existing wet FGD system is projected to achieve an SO<sub>2</sub> outlet emission rate of 0.20 lb per MMBtu (83.3 percent SO<sub>2</sub> removal). Optimization would be accomplished by partially closing the bypass damper to reduce the routine bypass flue gas flow used to reheat the treated flue gas from the scrubber, relocating the opacity monitor, and modifying the system to minimize scaling problems.

Upgrading the wet FGD system would achieve an SO<sub>2</sub> outlet emission rate of 0.10 lb per MMBtu (91.7 percent SO<sub>2</sub> removal). Upgrading the system would involve closing the bypass damper to eliminate the routine bypass flue gas flow used to reheat the treated flue gas from the scrubber, relocating the opacity monitor, adding new fans, adding a stack liner and drains for wet operation, and using a refined soda ash reagent. It is considered to be technically infeasible for the present wet FGD system to achieve a 95 percent SO<sub>2</sub> removal (0.06 lb per MMBtu) on a continuous basis since this high level of removal must be incorporated into the original design of the scrubber.

Optimizing the existing wet sodium scrubbing FGD system is projected to achieve an outlet emission rate of 0.20 lb per MMBtu, which would not meet the presumptive limit of 0.15 lb per MMBtu of SO<sub>2</sub>. Therefore, this option is eliminated as technically infeasible for this analysis. An upgraded wet sodium scrubbing FGD system is projected to achieve an outlet emission rate of 0.10 lb per MMBtu (91.7 percent SO<sub>2</sub> removal), which would meet the presumptive limit of 0.15 lb per MMBtu of SO<sub>2</sub> for Jim Bridger 1.

**New Dry FGD System.** The lime spray dryer typically injects lime slurry in the top of the absorber vessel with a rapidly rotating atomizer wheel. The rapid speed of the atomizer wheel causes the lime slurry to separate into very fine droplets that intermix with the flue gas. The SO<sub>2</sub> in the flue gas reacts with the calcium in the lime slurry to form dry calcium sulfate particles. At Jim Bridger 1 this dry particulate matter would be captured downstream in the

existing ESP, along with the fly ash. A lime spray dryer system typically produces a dry waste product suitable for landfill disposal.

The dry FGD system with the existing ESP is projected to achieve 82.5 percent SO<sub>2</sub> removal at Jim Bridger 1. This would result in a controlled SO<sub>2</sub> emission rate of 0.21 lb per MMBtu, based on an uncontrolled SO<sub>2</sub> emission rate of 1.20 lb per MMBtu. Therefore, this option cannot meet the presumptive limit of 0.15 lb per MMBtu of SO<sub>2</sub>, and is eliminated from further analysis.

### **Step 3: Evaluate Control Effectiveness of Remaining Control Technologies**

When evaluating the control effectiveness of SO<sub>2</sub> reduction technologies, each option can be compared against benchmarks of performance. One such benchmark is the presumptive BART emission limit because Jim Bridger 1 is required to meet this limit. As indicated previously, the presumptive limit for SO<sub>2</sub> on a BART-eligible coal burning unit is 95 percent removal, or 0.15 lb per MMBtu.

The projected emission rate for an upgraded wet sodium FGD system for Jim Bridger 1 would be 0.10 lb per MMBtu. This option would meet the presumptive SO<sub>2</sub> limit of 0.15 lb per MMBtu.

### **Step 4: Evaluate Impacts and Document the Results**

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

**Energy Impacts.** Upgrading the existing wet sodium FGD system would require an additional 530 kW of power.

**Environmental Impacts.** There will be incremental additions to scrubber waste disposal and makeup water requirements, and a reduction of the stack gas temperature from 140°F to 120°F due to elimination of reheating by the bypassed flue gas.

**Economic Impacts.** A summary of the costs and amount of SO<sub>2</sub> removed for the upgraded wet sodium FGD system is provided in Table 3-5. The complete economic analysis is contained in Appendix A.

**Preliminary BART Selection.** CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 1, based on significant reduction in SO<sub>2</sub> emissions (meeting presumptive limit of 0.15 lb per MMBtu), reasonable control costs, and the advantages of minimal additional power requirements and environmental impacts.

### **Step 5: Evaluate Visibility Impacts**

Please see Section 4, BART Modeling Analysis.

**TABLE 3-5**  
**SO<sub>2</sub> Control Cost Comparison (Incremental to Existing FGD System)**  
*Jim Bridger 1*

Factor	Upgraded Wet FGD
Total Installed Capital Costs	\$13.0 million
Total First Year Fixed and Variable Operation and Maintenance Costs	\$1.3 million
Total First Year Annualized Cost	\$2.5 million
Additional Power Consumption (megawatts)	0.5
Additional Annual Power Usage (1,000 megawatt-hours per year)	4.2
Incremental Sulfur Dioxide (SO <sub>2</sub> ) Design Control Efficiency	62.5% (91.7% based on Uncontrolled SO <sub>2</sub> )
Incremental Tons SO <sub>2</sub> Removed per Year	3,950
First Year Average Control Cost (dollars per ton [\$/Ton] of SO <sub>2</sub> Removed)	632
Incremental Control Cost (\$/Ton of SO <sub>2</sub> Removed)	632

### 3.2.3 BART PM<sub>10</sub> Analysis

Jim Bridger 1 is currently equipped with an ESP. Electrostatic precipitators remove particulate matter (PM) from the flue gas stream by charging fly ash particles with a very high direct current voltage, and attracting these charged particles to grounded collection plates. A layer of collected PM forms on the collecting plates and is removed by periodically rapping the plates. The collected ash particles drop into hoppers below the precipitator and are removed periodically by the fly ash-handling system. Historically, the ESP at Jim Bridger 1 has controlled PM<sub>10</sub> emissions to levels below 0.045 lb per MMBtu.

The BART analysis for PM<sub>10</sub> emissions at Jim Bridger 1 is described below. For the modeling analysis in Section 4, PM<sub>10</sub> was used as an indicator for PM, and PM<sub>10</sub> includes particulate matter less than 2.5 micrometers in aerodynamic diameter (PM<sub>2.5</sub>) as a subset.

#### Step 1: Identify All Available Retrofit Control Technologies

Two retrofit control technologies have been identified for additional PM control:

- Flue gas conditioning
- Polishing fabric filter (baghouse) downstream of existing ESP

Another available control technology is replacing the existing ESP with a new fabric filter. However, because the environmental benefits that would be achieved by a replacement fabric filter are also achieved by installing a polishing fabric filter downstream of the existing ESP at lower costs, installation of a full-size fabric filter was not considered in the analysis.

### Step 2: Eliminate Technically Infeasible Options

**Flue Gas Conditioning.** If the fly ash from coal has high resistivity, such as fly ash from sub-bituminous coal, the ash is not collected effectively in an ESP. This is because the high resistivity makes the particles less willing to accept an electrical charge. Adding flue gas conditioning (FGC), which is typically accomplished by injection of sulfur trioxide ( $\text{SO}_3$ ), will lower the resistivity of the particles so that they will accept more charge and allow the ESP to collect the ash more effectively. Flue gas conditioning systems can account for large improvements in collection efficiency for small ESPs. Therefore, the technology is retained as technically feasible.

**Polishing Fabric Filter.** A polishing fabric filter could be added downstream of the existing ESP at Jim Bridger 1. One such technology is licensed by the Electric Power Research Institute, and referred to as a COHPAC (Compact Hybrid Particulate Collector). The COHPAC collects the ash that is not collected by the ESP, thus acting as a polishing device. The ESP needs to be kept in service for the COHPAC fabric filter to operate effectively.

The COHPAC fabric filter is about one-half to two-thirds the size of a full-size fabric filter, because the COHPAC has a higher air-to-cloth ratio (7 to 9:1), compared to a full-size pulse jet fabric filter (3.5 to 4:1). This technology is retained as technically feasible.

### Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

The existing ESP at Jim Bridger 1 is achieving a controlled PM emission rate of 0.045 lb per MMBtu. Utilizing flue conditioning upstream of the existing ESP is projected to reduce PM emissions to approximately 0.030 lb per MMBtu. Adding a COHPAC fabric filter downstream of the existing ESP is projected to reduce PM emissions to approximately 0.015 lb per MMBtu.

The  $\text{PM}_{10}$  control technology emission rates are summarized in Table 3-6.

TABLE 3-6  
 $\text{PM}_{10}$  Control Technology Emission Rates  
*Jim Bridger 1*

Control Technology	Short-Term Expected $\text{PM}_{10}^{(a)}$ Emission Rate (pounds per million British thermal units)
Flue Gas Conditioning	0.030
Polishing Fabric Filter	0.015

**NOTES:**

<sup>(a)</sup> $\text{PM}_{10}$  refers to particulate matter less than 10 micrometers in aerodynamic diameter

### Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

**Energy Impacts.** Energy is required to overcome the additional pressure drop from the COHPAC fabric filter and associated ductwork. Therefore, a COHPAC retrofit will require an internal-diameter fan upgrade and upgrade of the auxiliary power supply system.

A COHPAC fabric filter at Jim Bridger 1 would require approximately 3.4 MW of power, equating to an annual power usage of approximately 26.7 million kW hours.

There is only a small power requirement of approximately 50 kW associated with flue gas conditioning.

**Environmental Impacts.** There are no negative environmental impacts from the addition of either a COHPAC polishing fabric filter or FGC system.

**Economic Impacts.** A summary of the costs and PM removed for COHPAC and FGC is recorded in Table 3-7, and the first-year control costs for FGC and fabric filters are shown in Figure 3-5. The complete economic analysis is contained in Appendix A.

TABLE 3-7  
PM<sub>10</sub> Control Cost Comparison (Incremental to Existing ESP)  
*Jim Bridger 1*


Factor	Flue Gas Conditioning	Polishing Fabric Filter
Total Installed Capital Costs	\$0	\$48.4 million
Total First Year Fixed and Variable Operation and Maintenance Costs	\$0.2 million	\$1.8 million
Total First Year Annualized Cost	\$0.2 million	\$6.4 million
Additional Power Consumption (megawatts)	0.05	3.4
Additional Annual Power Usage (1,000 megawatt-hours per year)	0.4	26.7
Incremental Particulate Matter (PM) Design Control Efficiency	33.3%	66.7%
Incremental Tons PM Removed per Year	355	710
First Year Average Control Cost (dollars per ton [\$/Ton] of PM Removed)	495	8,973
Incremental Control Cost (\$/Ton of PM Removed)	495	17,452

**Preliminary BART Selection.** PacifiCorp selects FGC as BART for Jim Bridger 1 based on its significant reduction in PM emissions, reasonable control cost, minimum additional power requirements, and no environmental impacts.

#### Step 5: Evaluate Visibility Impacts

Please see Section 4, BART Modeling Analysis.

FIGURE 3-5  
First Year Control Cost for PM Air Pollution Control Options  
*Jim Bridger 1*



## **4.0 BART Modeling Analysis**

---

### **4.1 Model Selection**

CH2M HILL used the CALPUFF modeling system to assess the visibility impacts of emissions from Jim Bridger 1 at nearby Class I areas. The Class I areas potentially affected are located more than 50 kilometers, but less than 300 kilometers, from the Jim Bridger 1 facility. The Class I areas include the following wilderness areas (WA):

- Bridger WA
- Fitzpatrick WA
- Mt. Zirkel WA

The CALPUFF modeling system includes the CALMET meteorological model, a Gaussian puff dispersion model (CALPUFF) with algorithms for chemical transformation and deposition, and a post processor capable of calculating concentrations, visibility impacts, and deposition (CALPOST). The CALPUFF modeling system was applied in a full, refined mode. Version numbers of the various programs in the CALPUFF system used by CH2M HILL were as follows:

- CALMET Version 5.53a, Level 040716
- CALPUFF Version 5.711a, Level 040716
- CALPOST Version 5.51, Level 030709

### **4.2 CALMET Methodology**

#### **4.2.1 Dimensions of the Modeling Domain**

CH2M HILL used the CALMET model to generate a three-dimensional wind field and other meteorological parameters suitable for use by the CALPUFF model. A modeling domain was established to encompass the Jim Bridger 1 facility and allow for a 50-kilometer buffer around the Class I areas that were within 300 kilometers of the facility. Grid resolution was 4 kilometer. Figure 4-1 shows the extent of the modeling domain. Except when specifically instructed otherwise by the Wyoming Department of Environmental Quality-Air Quality Division (WDEQ-AQD), CH2M HILL followed the methodology spelled out in the WDEQ-AQD BART Modeling Protocol, a copy of which is included in this report as Appendix B.

CH2M HILL used the Lambert Conformal Conic map projection for the analysis due to the large extent of the domain. The latitude of the projection origin and the longitude of the central meridian were chosen at the approximate center of the domain. Standard parallels were drawn to represent one-sixth and five-sixths of the north-south extent of the domain to minimize distortion in the north-south direction.




Figure 4-1  
**Jim Bridger Source-Specific  
Class I Areas to be Addressed**



SLC\SLCDGIS\PROJECTS\HUNTERMAPS\JIM\_BRIDGER\_CLASSI.MXD 11/13/2008 MSLAYDEN

**CH2MHILL**

The default technical options listed in TRC Companies, Inc.'s (TRC) current example CALMET.inp file were used for CALMET. Vertical resolution of the wind field included ten layers, with vertical face heights as follows (in meters):

- 0, 20, 40, 100, 140, 320, 580, 1020, 1480, 2220, 3500

Other user-specified model options were set to values established by WDEQ-AQD, which appear in Table 3 of Appendix B. Table 4-1 lists the key user-specified options used for this analysis.

**TABLE 4-1**  
User-specified CALMET Options  
*Jim Bridger 1*

CALMET Input Parameter	Value
<b>CALMET Input Group 2</b>	
Map projection (PMAP)	Lambert Conformal
Grid spacing (DGRIDDKM)	4
Number vertical layers (NZ)	10
Top of lowest layer (m)	20
Top of highest layer (m)	3500
<b>CALMET Input Group 4</b>	
Observation mode (NOOBS)	0
<b>CALMET Input Group 5</b>	
Prog. Wind data (IPROG)	14
(RMAX1)	30
(RMAX2)	50
Terrain influence (TERRAD)	15
(R1)	5
(R2)	25
<b>CALMET Input Group 6</b>	
Max mixing ht (ZIMAX)	3500

#### 4.2.2 CALMET Input Data

CH2M HILL ran the CALMET model to produce 3 years of analysis: 2001, 2002, and 2003. WDEQ-AQD provided 12-kilometer resolution Mesoscale Meteorological Model, Version 5 (MM5) meteorological data fields that covered the entire modeling domain for each study year.

These three data sets were chosen because they are current and have been evaluated for quality. The MM5 data were used as input to CALMET as the "initial guess" wind field. The initial guess wind field was adjusted by CALMET for local terrain and land use effects to generate a

Step 1 wind field, and further refined using local surface observations to create a final Step 2 wind field.

Surface data for 2001 through 2003 were obtained from the National Climatic Data Center. CH2M HILL processed the data from the National Weather Service's Automated Surface Observing System network for all stations that are in the domain. The surface data were obtained in abbreviated DATSAV3 format. A conversion routine available from the TRC Web site was used to convert the DATSAV3 files to CD-144 format for input into the SMERGE preprocessor and CALMET.

Land use and terrain data were obtained from the U.S. Geological Survey (USGS). Land use data were obtained in Composite Thematic Grid format from the USGS, and the Level I USGS land use categories were mapped into the 14 primary CALMET land use categories. Surface properties such as albedo, Bowen ratio, roughness length, and leaf area index were computed from the land use values. Terrain data were taken from USGS 1-degree Digital Elevation Model data, which primarily derive from USGS 1:250,000 scale topographic maps. Missing land use data were filled with values that were assumed appropriate for the missing area.

Precipitation data were obtained from the National Climatic Data Center. All available data in fixed-length, TD-3240 format were obtained for the modeling domain. The list of available stations that have collected complete data varies by year, but CH2M HILL processed all available stations/data within the domain for each year. Precipitation data were prepared with the PRACT/PMERGE processors in preparation for use within CALMET.

Upper-air data were prepared for the CALMET model with the READ62 preprocessor for the following stations:

- Denver, Colorado
- Salt Lake City, Utah
- Riverton, Wyoming
- Rapid City, South Dakota

Figure 4-2 shows the locations of surface and upper air stations within the MM5 modeling domain.

#### 4.2.3 Validation of CALMET Wind Field

CH2M HILL used the CALDESK data display and analysis system (v2.97, Enviromodeling Ltd.) to view plots of wind vectors and other meteorological parameters to evaluate the CALMET wind fields. The CALDESK displays were compared to observed weather conditions, as depicted in surface and upper-air weather maps (National Oceanic and Atmospheric Administration, 2006).




Figure 4-2  
**Surface and Upper Air Stations Used in the Jim Bridger BART Analysis**

**PACIFICORP**

S.I.C. NSLCBIS/PROJECTS/HUNTERMAPFILE/JIM\_BRIDGER\_ASOS.MXD 11/9/2006 MSLAYDEN

## 4.3 CALPUFF Modeling Approach

For the BART control technology visibility improvement modeling, CH2M HILL followed WDEQ-AQD guidance provided (WDEQ-AQD, 2006).

CH2M HILL drove the CALPUFF model with the meteorological output from CALMET over the modeling domain described earlier. The CALPUFF model was used to predict visibility impacts for the pre-control (baseline) scenario for comparison to the predicted impacts for post-control scenarios for Jim Bridger 1.

### 4.3.1 Background Ozone and Ammonia

Hourly values of background ozone concentrations were used by CALPUFF for the calculation of SO<sub>2</sub> and NO<sub>x</sub> transformation with the MESOPUFF II chemical transformation scheme. CH2M HILL obtained hourly ozone data from the following stations located within the modeling domain for 2001, 2002, and 2003:

- Rocky Mountain National Park, Colorado
- Craters of the Moon National Park, Idaho
- Highland, Utah
- Thunder Basin National Grasslands, Wyoming
- Yellowstone National Park, Wyoming
- Centennial, Wyoming
- Pinedale, Wyoming

For periods of missing hourly ozone data, the chemical transformation relied on a monthly default value of 44 parts per billion. Background ammonia was set to 2 parts per billion. Both of these background values were taken from the guidance document (WDEQ-AQD, 2006).

### 4.3.2 Stack Parameters

The stack parameters used for the baseline modeling reflect those that are in place under the current permit for Jim Bridger 1. Post-control stack parameters reflect the anticipated changes associated with installation of the control technology alternatives that are being evaluated. The maximum heat input rate of 6,000 MMBtu per hour was used to calculate a maximum emission rate. Measured velocities and stack flow rates were used in the modeling to represent a worst-case situation.

### 4.3.3 Emission Rates

Pre-control emission rates for Jim Bridger 1 reflect peak 24-hour average emissions that may occur under the source's current permit. The emission rates reflect actual emissions under normal operating conditions, as described by the EPA in the *Regional Haze Regulations and Guidelines for Best Available Retrofit Technology Determinations; Final Rule* (40 CFR Part 51).

CH2M HILL used available continuous emission monitoring data to determine peak 24-hour emission rates. Data reflected operations from the most recent 3- to 5-year period, unless a more recent period was more representative. Allowable short-term (24-hour or shorter period)

emissions or short-term emission limits were used if continuous emission monitoring data were not available.

Emissions were modeled for the following pollutants:

- SO<sub>2</sub>
- NO<sub>x</sub>
- Coarse particulate (PM<sub>2.5</sub><diameter<PM<sub>10</sub>)
- Fine particulate (diameter<PM<sub>2.5</sub>)
- Sulfates

Post-control emission rates reflect the effects of the emissions control scenario under consideration. Modeled pollutants were the same as those listed for the pre-control scenario.

#### 4.3.4 Post-control Scenarios

Four post-control modeling scenarios were developed to cover the range of effectiveness for the combination of the individual NO<sub>x</sub>, SO<sub>2</sub>, and PM control technologies being evaluated. The selection of each control device was made based on the engineering analyses described in Section 3 for reasonable technologies that would meet or exceed the presumptive BART levels for each pollutant.

- Scenario 1: New LNB with OFA modifications, upgraded wet FGD system, and flue gas conditioning for enhanced ESP performance. As indicated previously, this scenario represents CH2M HILL's preliminary BART recommendation.
- Scenario 2: New LNB with OFA modifications, upgraded wet FGD system, and new polishing fabric filter
- Scenario 3: New LNB with OFA modifications and SCR, upgraded wet FGD system, and flue gas conditioning for enhanced ESP performance.
- Scenario 4: New LNB with OFA modifications and SCR, upgraded wet FGD system, and new polishing fabric filter.

The ROFA option and LNB with OFA and SCR option for NO<sub>x</sub> control were not included in the modeling scenarios because their control effectiveness is between the LNB with OFA option and the SCR option. Modeling of NO<sub>x</sub>, SO<sub>2</sub>, and PM controls alone was not performed because any final BART solution will include a combination of control technologies for NO<sub>x</sub>, SO<sub>2</sub>, and PM.

Table 4-2 presents the stack parameters and emission rates used for the Jim Bridger 1 analysis for baseline and post-control modeling. In accordance with the WDEQ BART modeling protocol, elemental carbon stack emissions and organic aerosol emissions were not modeled.

TABLE E-2  
BART Model Input Data  
Jim Bridger /

	Baseline	Post-control Scenario 1	Post-control Scenario 2	Post-control Scenario 3	Post-control Scenario 4
	Current Operations with Low-NO <sub>x</sub> Burner (LNB) with Over-fire Air (OFA), Upgrade Wet FGD, and Flue Gas Conditioning (FGC) for Enhanced ESP Performance	LNB with OFA and Selective Catalytic Reduction (SCR), Upgrade Wet FGD, and FGBC for Enhanced ESP Performance	LNB with OFA, Upgrade Wet FGD, New Fabric Filter	LNB with OFA and SCR, Upgrade Wet FGD, New Fabric Filter	LNB with OFA and SCR, Upgrade Wet FGD, New Fabric Filter
Sulfur Dioxide (SO <sub>2</sub> ) Stack Emissions pounds per hour (lb/hr)	1,802	600	600	600	600
Nitrogen Oxide (NO <sub>x</sub> ) Stack Emissions (lb/hr)	2,700	1,440	1,440	1,440	1,440
PM <sub>10</sub> Stack Emissions (lb/hr)	270	180	90.0	180	90.0
:Coarse Particulate (PM <sub>2.5</sub> -diameters<PM <sub>10</sub> ) Stack Emissions (lb/hr) <sup>a</sup>	118	77.4	51.3	77.4	51.3
Fine Particulate (diameters<PM <sub>2.5</sub> ) Stack Emissions (lb/hr) <sup>a</sup>	154	103	38.7	103	38.7
Sulfuric Acid (H <sub>2</sub> SO <sub>4</sub> ) Stack Emissions (lb/hr)	55.2	55.2	55.2	94.8	94.8
H <sub>2</sub> SO <sub>4</sub> as Sulfate (SO <sub>4</sub> ) Stack Emissions (lb/hr)	54.1	54.1	54.1	92.9	92.9
Ammonium Sulfate ((NH <sub>4</sub> ) <sub>2</sub> SO <sub>4</sub> ) Stack Emissions (lb/hr)				7.02	7.02
(NH <sub>4</sub> ) <sub>2</sub> SO <sub>4</sub> as SO <sub>4</sub> Stack Emissions (lb/hr)				5.10	5.10
(NH <sub>4</sub> ) <sub>2</sub> SO <sub>4</sub> Stack Emissions (lb/hr)				12.2	12.2
(NH <sub>4</sub> ) <sub>2</sub> SO <sub>4</sub> as SO <sub>4</sub> Stack Emissions (lb/hr)				10.2	10.2
Total Sulfate (SO <sub>4</sub> ) (lb/hr)	54.1	54.1	54.1	108	108
Stack Conditions					
Stack Height (meters)	152	152	152	152	152
Stack Exit Diameter (meters)	7.32	7.32	7.32	7.32	7.32
Stack Exit Temperature (Kelvin)	333	322	333	333	333
Stack Exit Velocity (meters per second) <sup>a</sup>	25.6	24.7	27.4	27.4	27.4

NOTES:

<sup>a</sup>Based on AP-42, Table 1-1-6, the coarse particulates are counted as a percentage of PM<sub>10</sub>. This equates to 43 percent ESP and 57 percent Baghouse. PM<sub>10</sub> and PM<sub>2.5</sub> refer to particulate matter less than 10 and 2.5 micrometers, respectively, in aerodynamic diameter.

<sup>b</sup>Based on AP-42, Table 1-1-6, the fine particulates are counted as a percentage of PM<sub>10</sub>. This equates to 57 percent ESP and 43 percent Baghouse.

<sup>c</sup>Scenarios 2, 3, and 4 were not remodeled at the lower, correct velocity of 81.24 feet per second due to lack of time and the fact that the conclusions to select Scenario 1 would not have changed.

Total Sulfate (SO<sub>4</sub>) (lb/hr) = H<sub>2</sub>SO<sub>4</sub> as Sulfate (SO<sub>4</sub>) Stack Emissions (lb/hr) + (NH<sub>4</sub>)<sub>2</sub>SO<sub>4</sub> as SO<sub>4</sub> Stack Emissions (lb/hr)

#### 4.3.5 Modeling Process

The CALPUFF modeling for the control technology options for Jim Bridger 1 followed this sequence:

- Model pre-control (baseline) emissions
- Model preferred post-control scenario (if applicable)
- Determine degree of visibility improvement
- Model other control scenarios
- Determine degree of visibility improvement
- Factor visibility results into the BART five-step evaluation

#### 4.3.6 Receptor Grids

Discrete receptors for the CALPUFF modeling were placed at uniform receptor spacing along the boundary and in the interior of each area of concern. Class I area receptors were taken from the National Park Service database for Class I area modeling receptors. The TRC COORDS program was used to convert all latitude/longitude coordinates to Lambert Conformal-Conic coordinates, including receptors, meteorological stations, and source locations.

### 4.4 CALPOST

The CALPOST processor was used to determine 24-hour average visibility results with output specified in deciview (dV) units. Calculations of light extinction were made for each pollutant modeled. The sum of all extinction values were used to calculate the delta-dV ( $\Delta dV$ ) change relative to natural background. The following default light extinction coefficients for each pollutant, as shown below, were used:

- Ammonium sulfate      3.0
- Ammonium nitrate      3.0
- PM coarse (PM<sub>10</sub>)      0.6
- PM fine (PM<sub>2.5</sub>)      1.0
- Organic carbon      4.0
- Elemental carbon      10.0

CALPOST visibility Method 6 was used to determine the visibility impacts. Monthly relative humidity factors [ $f(RH)$ ] were used in the light extinction calculations to account for the hygroscopic characteristics of nitrate and sulfate particles. Table 5 of the Wyoming BART Air Modeling Protocol (Appendix B) lists the monthly  $f(RH)$  factors for the Class I areas. These values were used for the particular Class I area being modeled.

The natural background conditions as a reference for determining the  $\Delta dV$  change represented the 20 percent best natural visibility days. The EPA BART guidance document provided dV values for the 10 percent best days for each Class I area, but did not provide individual species concentration data for the 20 percent best background conditions. Species concentrations corresponding to the 20 percent best days were calculated for each Class I area by scaling back the annual average species concentrations given in Table 2-1 of *Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule* (EPA, 2003). A

separate scaling factor was derived for each Class I area such that, when multiplied by the Guidance table annual concentrations, the 20 percent best days dV value for that area would be calculated. This procedure was taken from *Protocol for BART-Related Visibility Improvement Modeling Analysis in North Dakota* (North Dakota Department of Health, 2005). However, the Wyoming BART Air Modeling Protocol (see Appendix B) provided natural background concentrations of aerosol components to use in the BART analysis. Table 4-3 lists the annual average species concentrations from the BART protocol.

**TABLE 4-3**  
Average Natural Levels of Aerosol Components  
*Jim Bridger 1*

Aerosol Component	Average Natural Concentration (micrograms per cubic meter) for Mt. Zirkel Class I Wilderness Area	Average Natural Concentration (micrograms per cubic meter) for Fitzpatrick and Bridger Class I Wilderness Areas
Ammonium Sulfate	0.046	0.045
Ammonium Nitrate	0.038	0.038
Organic Carbon	0.179	0.178
Elemental Carbon	0.008	0.008
Soil	0.190	0.189
Coarse Mass	1.141	1.136

**NOTES:**

Data in this table was taken from Table 6 of the Wyoming BART Air Modeling Protocol

## 4.5 Presentation of Modeling Results

This section presents the results of the CALPUFF visibility improvement modeling analysis for Jim Bridger 1.

### 4.5.1 Visibility Changes for Baseline vs. Preferred Scenario

CH2M HILL modeled Jim Bridger 1 for the baseline and the post-control scenarios. The post-control scenario included emission rates for SO<sub>2</sub>, NO<sub>x</sub>, and PM<sub>10</sub> that would be achieved if BART state-of-the-art technology were installed on Unit 1.

Baseline (and post-control) 98<sup>th</sup> percentile results were greater than 0.5 ΔdV for the Bridger, WA, Fitzpatrick, WA, and Mt. Zirkel, WA. The 98<sup>th</sup> percentile results for each Class I area are presented in Table 4-4.

TABLE 4-4  
Costs and Visibility Modeling Results for Baseline vs. Post-Control Scenarios at Class Areas  
*Jim Bridger I*

Scenario	Total First Year Annualized Cost	Class I Area	Highest Data Decileview (Adv)	Modeling Results				Incremental Cost per Reduction in No. of Days Above 0.5 dV
				95 <sup>th</sup> Percentile (Adv)	Number (No.) of Days Above 0.5 dV	Cost per dV Reduction	Cost per Reduction in No. of Days Above 0.5 dV	
<b>2001</b>								
Baseline: Current Operation with Wet Flue Gas Desulfurization (FGD), Electrostatic Precipitator (ESP)		Bridger WA	2,504	0.746	14			
Scenario 1: Low-NO <sub>x</sub> Burners (LNBs) with Overfire Air (OFA), upgrade wet FGD, flue gas Conditioning (FGC) for enhanced ESP performance	\$3,392,440	Fitzpatrick WA	2,177	0.418	7			
Scenario 2: LNB with OFA, upgrade wet FGD, polishing fabric filter	\$3,392,440	Mt. Zirkel WA	1,956	1.236	27			
Scenario 3: LNB with OFA and Selective Catalytic Reduction (SCR), upgrade wet FGD, FGC for enhanced ESP performance	\$18,083,916	Bridger WA	1,364	0.384	7	\$9,371,381	\$464,634	
Scenario 4: LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	\$18,083,916	Fitzpatrick WA	1,388	0.221	3	\$17,220,508	\$84,110	
		Mt. Zirkel WA	1,167	0.736	16	\$784,880	\$308,404	
Baseline: Current Operation with Wet FGD, ESP		Bridger WA	1,953	0.372	6	\$26,065,741	\$1,218,882	\$50,551,575
Scenario 1: LNB with OFA, upgrade wet FGD, polishing fabric filter	\$9,759,059	Fitzpatrick WA	1,171	0.211	3	\$47,145,212	\$2,435,785	\$856,861,890
Scenario 2: LNB with OFA, upgrade wet FGD, polishing fabric filter	\$9,759,059	Mt. Zirkel WA	1,099	0.576	15	\$17,742,891	\$813,255	\$106,110,315
Scenario 3: LNB with OFA and Selective Catalytic Reduction (SCR), upgrade wet FGD, FGC for enhanced ESP performance	\$24,460,555	Bridger WA	0,876	0.279	3	\$31,745,002	\$1,644,901	\$89,222,116
Scenario 4: LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	\$24,460,555	Fitzpatrick WA	0,875	0.127	1	\$62,178,405	\$3,015,653	\$93,224,485
		Mt. Zirkel WA	0,756	0.453	5	\$23,108,449	\$822,451	\$833,486
Baseline: Current Operation with Wet FGD, ESP		Bridger WA	0,654	0.125	1	\$51,172,657	\$2,223,685	\$578,783,537
Scenario 1: LNB with OFA, upgrade wet FGD, polishing fabric filter	\$24,460,555	Fitzpatrick WA	0,654	0.436	2	\$30,572,688	\$978,421	n/a
Scenario 2: LNB with OFA, upgrade wet FGD, polishing fabric filter	\$24,460,555	Mt. Zirkel WA	0,129			\$374,506,984	\$2,122,206	
<b>2002</b>								
Baseline: Current Operation with Wet FGD, ESP		Bridger WA	4,104	1.448	26			
Scenario 1: LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	\$3,392,440	Fitzpatrick WA	1,684	0.704	11			
Scenario 2: LNB with OFA, upgrade wet FGD, polishing fabric filter	\$3,392,440	Mt. Zirkel WA	2,801	1.956	34			
Scenario 3: LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance	\$18,083,916	Bridger WA	1,078	0.378	5	\$10,405,258	\$565,407	
Scenario 4: LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	\$18,083,916	Fitzpatrick WA	1,544	0.516	13	\$4,986,882	\$161,545	
		Mt. Zirkel WA	2,326	0.780	13	\$14,605,370	\$750,687	\$282,703
Baseline: Current Operation with Wet FGD, ESP		Bridger WA	1,002	0.347	6	\$27,336,300	\$1,951,812	\$205,374,803
Scenario 1: LNB with OFA, upgrade wet FGD, polishing fabric filter	\$9,759,059	Fitzpatrick WA	1,495	0.777	13	\$13,573,100	\$684,717	\$163,246,539
Scenario 2: LNB with OFA, upgrade wet FGD, polishing fabric filter	\$9,759,059	Mt. Zirkel WA	1,321	0.519	9	\$19,476,766	\$1,054,348	\$1,934,317
Scenario 3: LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance	\$24,460,555	Bridger WA	0,599	0.226	1	\$37,853,380	\$1,808,392	\$61,883,114
Scenario 4: LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	\$24,460,555	Fitzpatrick WA	0,887	0.473	4	\$17,687,112	\$603,131	\$21,417,292
		Mt. Zirkel WA	1,295	0.500	8	\$25,802,252	\$1,355,919	\$335,085,205
Baseline: Current Operation with Wet FGD, ESP		Bridger WA	0,539	0.223	1	\$50,853,502	\$2,448,053	\$2,122,206,301
Scenario 1: LNB with OFA, upgrade wet FGD, polishing fabric filter	\$24,460,555	Fitzpatrick WA	0,589	0,465	4	\$23,725,058	\$815,351	\$795,827,363
Scenario 2: LNB with OFA, upgrade wet FGD, polishing fabric filter	\$24,460,555	Mt. Zirkel WA						n/a

**TABLE 4-4**  
Costs and Visibility Modeling Results<sup>a</sup> for Baseline vs. Post-control Scenarios at Class I Areas  
Jim Bridger 1

2003	Scenario	Modeling Results						Incremental Cost per Reduction In No. of Days Above 0.5 dV
		Total First Year Annualized Cost	Class I Area	Highest Data Ditchview (dCV)	95th Percentile (adv)	Number (No. of Days Above 0.5 dV)	Cost per Reduction In No. of Days Above 0.5 dV	
	<b>Baseline: Current Operation with wet FGD, ESP</b>							
		\$3,392,440	Bridger WA	1,708	0.761	16	—	—
			Fitzpatrick WA	1,933	0.373	7	—	—
			Mt. Zirkel WA	1,958	1,232	35	—	—
	<b>Scenario 1: LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance</b>	\$3,392,440	Bridger WA	0.897	0.411	5	\$8,632,688	\$308,404
			Fitzpatrick WA	1,112	0.159	2	\$19,985,782	\$678,488
			Mt. Zirkel WA	1,042	0.736	16	\$17,954,848	\$178,549
	<b>Scenario 2: LNB with OFA, upgrade fabric filter</b>	\$9,759,059	Bridger WA	0.955	0.408	5	\$2,7345,059	\$897,167
			Fitzpatrick WA	1,057	0.186	2	\$52,187,481	\$1,951,812
			Mt. Zirkel WA	1,057	0.686	15	\$17,975,734	\$487,953
	<b>Scenario 3: LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance</b>	\$18,053,916	Bridger WA	0.853	0.258	3	\$35,077,986	\$1,391,840
			Fitzpatrick WA	0.681	0.118	2	\$70,956,532	\$855,985,712
			Mt. Zirkel WA	0.659	0.433	5	\$22,645,702	\$815,131
	<b>Scenario 4: LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter</b>	\$18,053,916	Bridger WA	0.810	0.248	3	\$47,981,354	\$1,881,580
			Fitzpatrick WA	0.662	0.114	2	\$41,442,219	\$81,892,197
			Mt. Zirkel WA	0.656	0.422	5	\$40,198,191	\$815,351
	<b>2-year Averages</b>							
	<b>Baseline: Current Operation with wet FGD, ESP</b>							
		\$3,392,440	Bridger WA	0.985	18.7			
			Fitzpatrick WA	0.498	8.3			
			Mt. Zirkel WA	1.321	32.0			
	<b>Scenario 1: LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance</b>	\$3,392,440	Bridger WA	0.547	8.7	\$7,739,407	\$339,244	
			Fitzpatrick WA	0.268	3.3	\$14,981,607	\$678,488	
			Mt. Zirkel WA	0.763	15.0	\$6,072,387	\$199,555	
	<b>Scenario 2: LNB with OFA, upgrade wet FGD, polishing fabric filter</b>	\$9,759,059	Bridger WA	0.520	8.0	\$20,987,224	\$914,912	\$228,748,239
			Fitzpatrick WA	0.248	3.7	\$38,984,257	\$2,061,227	\$333,701,050
			Mt. Zirkel WA	0.713	14.3	\$15,042,288	\$552,400	\$128,186,958
	<b>Scenario 3: LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance</b>	\$18,053,916	Bridger WA	0.352	5.0	\$28,684,385	\$1,325,945	\$49,612,243
			Fitzpatrick WA	0.157	1.3	\$55,039,519	\$2,584,845	\$91,991,933
			Mt. Zirkel WA	0.453	4.7	\$20,837,523	\$681,973	\$32,057,141
	<b>Scenario 4: LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter</b>	\$24,460,555	Bridger WA	0.339	4.7	\$37,945,077	\$1,747,181	\$477,486,418
			Fitzpatrick WA	0.154	1.3	\$71,037,371	\$2,494,362	\$2,122,206,301
			Mt. Zirkel WA	0.441	3.7	\$27,785,537	\$863,313	\$50,551,575

**NOTES:**

Sample Calculations: Cost per dV Reduction for Scenario 1 for 2001 = \$2,392,440 / (0.7964 - 0.427) = \$9,183,905

Sample Calculations: Cost per Reduction in No. of Days Exceeding 0.5 dV for 2001 = (\$3,392,440 / [20 - 7]) = \$460,657

## **5.0 Preliminary Assessment and Recommendations**

---

As a result of the completed technical and economic evaluations, and consideration of the modeling analysis for Jim Bridger 1, the preliminary recommended BART controls for NO<sub>x</sub>, SO<sub>2</sub>, and PM are as follows:

- New LNBs and modifications to the OFA system for NO<sub>x</sub> control
- Upgrade wet sodium FGD for SO<sub>2</sub> control
- Add flue gas conditioning upstream of existing ESPs for PM control

The above recommendations were identified as Scenario 1 for the modeling analysis described in Section 4. Visibility improvements for all emission control scenarios were analyzed, and the results are compared below, utilizing a least-cost envelope; as outlined in the *New-Source Review Workshop Manual* (EPA, 1990, hereafter referred to as the NSR Manual).

### **5.1 Least-cost Envelope Analysis**

The total annualized cost, cost per dV reduction, and cost per reduction in number of days above 0.5 dV for the scenarios modeled in Section 4 to determine the impact on the three Class I areas are listed in Tables 5-1 through 5-3. A comparison of the incremental costs between relevant scenarios is shown in Tables 5-4 through 5-6. The total annualized cost versus number of days above 0.5 dV, and the total annualized cost versus 98<sup>th</sup> percentile  $\Delta dV$  reduction are shown in Figures 5-1 to 5-6 for the three Class I areas.

#### **5.1.1 Analysis Methodology**

On page B-41 of the NSR Manual, EPA states that "Incremental cost-effectiveness comparisons should focus on annualized cost and emission reduction differences between dominant alternatives. Dominant set of control alternatives are determined by generating what is called the envelope of least-cost alternatives. This is a graphical plot of total annualized costs for a total emissions reductions for all control alternatives identified in the BACT analysis..."

An analysis of incremental cost effectiveness has been conducted. This analysis was performed in the following way. First, the control option scenarios are ranked in ascending order of annualized total costs as shown in Tables 5-1 through 5-3. The incremental cost-effectiveness data, expressed per day and per dV, represents a comparison of the different scenarios, and is summarized in Tables 5-4 through 5-6 for each of the three wilderness areas. Then the most reasonable smooth curve of least-cost control option scenarios is plotted for each analysis. Figures 5-1 through 5-6 present the two analyses (cost per dV reduction and cost per reduction in number of days above 0.5 dV) for each of the three Class I areas impacted by the operation of Jim Bridger 1.

In Figure 5-1, the four scenarios are compared as a graph of total annualized cost versus number of days above 0.5 dV. EPA states that "In calculating incremental costs, the analysis should only be conducted for control options that are dominant among all possible options." In Figure 5-1, the dominant set of control options, Scenarios 1, 3, and 4, represent the least-cost envelope depicted by the curvilinear line connecting them. Scenario 2 is an inferior option and should not be considered in the derivation of incremental cost effectiveness. Scenario 2 represents an inferior control, because Scenario 1 provides approximately the same amount of visibility impact reduction for less cost than Scenario 2. The incremental cost effectiveness is determined by the difference in total annual costs between two contiguous scenario's divided by the difference in emissions reduction.

TABLE 5-1  
Control Scenario Results for the Bridger Class I Wilderness Area  
*Jim Bridger 1*

Scenario	Controls	98 <sup>th</sup> Percentile deciview (dV) Reduction	Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet Flue Gas Desulfurization (FGD), and Electrostatic Precipitator (ESP)	0.00	0.0	\$0.0	\$0.0	\$0.0
1	Low-NO <sub>x</sub> Burners (LNBS) with Over-fire Air (OFA), Upgrade Wet FGD, and Flue Gas Conditioning (FGC) for Enhanced ESP Performance	0.44	10.0	\$3.4	\$7.7	\$0.3
2	LNB with OFA, Upgrade Wet FGD, New Fabric Filter	0.47	10.7	\$9.8	\$21.0	\$0.9
3	LNB with OFA and Selective Catalytic Reduction (SCR), Upgrade Wet FGD, and FGC for Enhanced ESP Performance	0.63	13.7	\$18.1	\$28.6	\$1.3
4	LNB with OFA and SCR, Upgrade Wet FGD, New Fabric Filter	0.65	14.0	\$24.5	\$37.8	\$1.7

**TABLE 5-2**  
**Control Scenario Results for the Fitzpatrick Class I Wilderness Area**  
*Jim Bridger 1*

Scenario	Controls	98 <sup>th</sup> Percentile deciView (dV) Reduction	Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet Flue Gas Desulfurization (FGD) and Electrostatic Precipitator (ESP)	0.00	0.0	\$0.0	\$0.0	\$0.0
1	Low-NO <sub>x</sub> Burner (LNB) with Over-fire Air (OFA), Upgrade Wet FGD, and Flue Gas Conditioning (FGC) for Enhanced ESP Performance	0.23	5.0	\$3.4	\$14.6	\$0.7
2	LNB with OFA, Upgrade Wet FGD, New Fabric Filter	0.25	4.7	\$9.8	\$39.0	\$2.1
3	LNB with OFA and Selective Catalytic Reduction (SCR), Upgrade Wet FGD, and FGC for Enhanced ESP Performance	0.34	7.0	\$18.1	\$53.0	\$2.6
4	LNB with OFA and SCR, Wet FGD, Fabric Filter	0.34	7.0	\$24.5	\$71.0	\$3.5

**TABLE 5-3**  
**Control Scenario Results for the Mt. Zirkel Class I Wilderness Area**  
*Jim Bridger 1*

Scenario	Controls	98 <sup>th</sup> Percentile deciview (dV) Reduction	Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet Flue Gas Desulfurization (FGD) and Electrostatic Precipitator (ESP)	0.00	0.0	\$0.0	\$0.0	\$0.0
1	Low-NO <sub>x</sub> Burner (LNB) with Over-fire Air (OFA), Upgrade Wet FGD, and Flue Gas Conditioning (FGC) for Enhanced ESP Performance	0.56	17.0	\$3.4	\$6.1	\$0.2
2	LNB with OFA, Upgrade Wet FGD, New Fabric Filter	0.61	17.7	\$9.8	\$16.0	\$0.6
3	LNB with OFA and Selective Catalytic Reduction (SCR), Upgrade Wet FGD, and FGC for Enhanced ESP Performance	0.87	27.3	\$18.1	\$20.8	\$0.7
4	LNB with OFA and SCR, Upgrade Wet FGD, New Fabric Filter	0.88	28.3	\$24.5	\$27.8	\$0.9

**TABLE 5-4**  
**Bridger Class I Wilderness Area Incremental Analysis Data**  
*Jim Bridger 1*

Options Compared	Incremental Reduction in Days Above 0.5 deciview (dV) (Days)	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	10.0	0.44	\$0.3	\$7.7
Scenario 1 and Scenario 2	0.7	0.03	\$9.5	\$238.7
Scenario 1 and Scenario 3	3.7	0.19	\$4.0	\$75.6
Scenario 1 and Scenario 4	4.0	0.21	\$5.3	\$101.3


**TABLE 5-5**  
**Fitzpatrick Class I Wilderness Area Incremental Analysis Data**  
*Jim Bridger 1*

Options Compared	Incremental Reduction in Days Above 0.5 deciview (dV) (Days)	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	5.0	0.23	\$0.7	\$14.6
Scenario 1 and Scenario 2	n/a	0.02	n/a	\$353.7
Scenario 1 and Scenario 3	2.0	0.11	\$7.4	\$134.9
Scenario 1 and Scenario 4	2.0	0.11	\$10.5	\$188.1

**TABLE 5-6**  
**Mt. Zirkel Class I Wilderness Area Incremental Analysis Data**  
*Jim Bridger 1*

Options Compared	Incremental Reduction in Days Above 0.5 deciview (dV) (Days)	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	17.0	0.56	\$0.2	\$6.1
Scenario 1 and Scenario 2	0.7	0.05	\$9.5	\$128.2
Scenario 1 and Scenario 3	10.3	0.31	\$1.4	\$47.5
Scenario 1 and Scenario 4	11.3	0.32	\$1.9	\$65.5

**FIGURE 5-1**  
Least-cost Envelope Bridger Class I WA Days Reduction  
*Jim Bridger 1*



**FIGURE 5-2**  
Least-cost Envelope Bridger Class I WA 98<sup>th</sup> Percentile Reduction  
*Jim Bridger 1*




FIGURE 5-3  
Least-cost Envelope Fitzpatrick Class I WA Days Reduction  
*Jim Bridger 1*




FIGURE 5-4  
Least-cost Envelope Fitzpatrick Class I WA 98<sup>th</sup> Percentile Reduction  
*Jim Bridger 1*




FIGURE 5-5  
Least-cost Envelope Mt. Zirkel Class I WA Days Reduction  
*Jim Bridger 1*





FIGURE 5-6  
Least-cost Envelope Mt. Zirkel Class I WA 98<sup>th</sup> Percentile Reduction  
*Jim Bridger 1*



### 5.1.2 Analysis Results

Results of the least-cost analysis, shown in Tables 5-1 through 5-6 and Figures 5-1 through 5-6 on the preceding pages, confirm the selection of Scenario 1, based on incremental cost and visibility improvements. Scenario 2 is eliminated because it is to the left of the curve formed by the dominant control alternative scenarios, which indicates a scenario with lower improvement and/or higher costs. Scenario 3 is not selected due to very high incremental costs on the basis of both a cost per day of improvement and a cost per dV reduction. While Scenario 4 provides some potential visibility advantage over Scenario 1, the projected improvement is less than half a dV, and the projected costs are excessive.

Analysis of the results for the Jim Bridger WA Class I Area in Tables 5-1 and 5-4 and Figures 5-1 and 5-2 illustrates the conclusions stated above. The greatest reduction in 98<sup>th</sup> percentile dV and number of days exceeding 0.5 dV is between the Baseline and Scenario 1. The average incremental cost effectiveness for Scenario 1 compared to the Baseline for the Bridger Wilderness area (Table 5-4) is reasonable at \$300,000 per day and \$7.7 million per dV. However, the incremental cost effectiveness for Scenario 3 compared to Scenario 1 is excessive at \$4 million per day and \$75.5 million per dV. Therefore, Scenario 1 represents BART for Jim Bridger 1.

## 5.2 Recommendations

### 5.2.1 NO<sub>x</sub> Emission Control

The BART presumptive NO<sub>x</sub> limit assigned by EPA for tangentially-fired boilers burning sub-bituminous coal is 0.15 lb per MMBtu. However, as documented in Section 3.2.1, the characteristics of the Jim Bridger coals are more closely aligned with bituminous coals, with a presumptive BART NO<sub>x</sub> limit of 0.28 lb per MMBtu.

CH2M HILL recommends the existing low-NO<sub>x</sub> burners with over-fire air (LNB with OFA) as BART for Jim Bridger 1, based on the projected significant reduction in NO<sub>x</sub> emissions, reasonable control costs, and the advantages of no additional power requirements or non-air quality environmental impacts. Nitrogen oxide reductions are expected to be similar to those realized at Jim Bridger 2. CH2M HILL recommends that the unit be permitted at a rate of 0.26 lb per MMBtu.

### 5.2.2 SO<sub>2</sub> Emission Control

CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 1, based on the significant reduction in SO<sub>2</sub> emissions, reasonable control costs, and the advantages of minimal additional power requirements and minimal non-air quality environmental impacts. This upgrade approach will meet the BART presumptive SO<sub>2</sub> limit of 0.15 lb per MMBtu.

### 5.2.3 PM<sub>10</sub> Emission Control

CH2M HILL recommends finalizing the permitting of the FGC system to enhance the performance of the existing ESP as BART for Jim Bridger 1, based on the significant reduction

in PM<sub>10</sub> emissions, reasonable control costs, and the advantages of minimal additional power requirements and no non-air quality environmental impacts.

### 5.3 Just-Noticeable Differences in Atmospheric Haze

Conclusions reached in the reference document "Just-Noticeable Differences in Atmospheric Haze" by Dr. Ronald Henry of the University of Southern California (Henry, 2002), state that only dV differences of approximately 1.5 to 2.0 dV, or more are perceivable by the human eye. Deciview changes of less than 1.5 cannot be distinguished by the average person. Therefore, the modeling analysis results indicate that only minimal, if any, observable visibility improvements at the Class I areas studied would be expected under any of the scenarios. Thus the results indicate that even though many millions of dollars will be spent, only minimal if any noticeable visibility improvements may result.

Finally, it should be noted that none of the data were corrected for natural obscuration where water in various forms (fog, clouds, snow or rain) or other naturally caused aerosols obscure the atmosphere. During the period of 2001 through 2003, there were several mega-wildfires that lasted for many days and could have had a significant impact on background visibility in these Class I areas. If natural obscuration were to reduce the reduction in visibility impacts modeled for the Jim Bridger 1 facility, the effect would be to increase the costs per dV reduction that are presented in this report.

## 6.0 References

---

- 40 CFR Part 51. *Regional Haze Regulations and Guidelines for Best Available Retrofit Technology Determinations; Final Rule.* July 6, 2005.
- Energy Information Administration, 2006. *Official Energy Statistics from the U.S. Government: Coal.* <http://www.eia.doe.gov/fuelcoal.html>. Accessed October 2006.
- EPA, 1990. *New Source Review Workshop Manual—Prevention of Significant Deterioration and Nonattainment Area Permitting.* Draft. October 1990.
- EPA, 2003. *Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule.* Environmental Protection Agency. EPA-454/8-03-005. September 2003.
- Henry, Ronald, 2002. "Just-Noticeable Differences in Atmospheric Haze," *Journal of the Air & Waste Management Association.* Volume 52, p. 1238.
- National Oceanic and Atmospheric Administration, 2006. U.S. Daily Weather Maps Project. [http://docs.lib.noaa.gov/rescue/dwm/data\\_rescue\\_daily\\_weather\\_maps.html](http://docs.lib.noaa.gov/rescue/dwm/data_rescue_daily_weather_maps.html). Accessed October 2006.
- North Dakota Department of Health, 2005. *Protocol for BART-Related Visibility Improvement Modeling Analysis in North Dakota.* North Dakota Department of Health. October 26, 2005.
- Sargent & Lundy, 2002. *Multi-Pollutant Control Report.* October 2002.
- Sargent & Lundy, 2006. *Multi-Pollutant Control Report.* Revised. October 2006.
- WDEQ-AQD, 2006. *BART Air Modeling Protocol—Individual Source Visibility Assessments for BART Control Analyses.* Wyoming Department of Environmental Quality – Air Quality Division. September 2006.

**APPENDIX A**

**Economic Analysis**

## PaciCorp BART Analysis Scenarios

Select Unit		3	Jim Bridger Unit 1
Index No.	Name of Unit		
1	Dave Johnston Unit 3		
2	Dave Johnston Unit 4		
3	Jim Bridger Unit 1		
4	Jim Bridger Unit 2		
5	Jim Bridger Unit 3		
6	Jim Bridger Unit 4		
7	Naughton Unit 1		
8	Naughton Unit 2		
9	Naughton Unit 3		
10	Wyodak Unit 1		

Dave Johnston		NTN Unit 1		NTN Unit 2		NTN Unit 3	
DJ Unit 3		DJ Unit 4		First Year Cost		First Year Cost	
Scenario	Baseline - Current Operation with ESP	Scenario	Baseline - Current Operation with Venturi Scrubber	Scenario	Baseline - Current Operation with ESP	Scenario	Baseline - Current Operation with Wet FGD and ESP
Baseline 1 - LNB with OFA, Dry FGD, Existing ESP	N/A	Baseline 1 - LNB with OFA, Dry FGD, Fabric Filter	N/A	Baseline 1 - LNB with OFA, Dry FGD, ESP	N/A	Scenario 1 - LNB with OFA, Wet FGD, N/A	Scenario 1 - LNB with OFA, Wet FGD, N/A
Scenario 2 - LNB with OFA, Dry FGD, New/Fabric Filter	N/A	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	N/A
Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	N/A	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	N/A	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	N/A	Scenario 3 - LNB with OFA and SCR, Wet FGD, N/A	Scenario 3 - LNB with OFA and SCR, Wet FGD, N/A
Scenario 4 - LNB with OFA and SCR, Wet FGD, Existing ESP, New Stack	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, ESP, New Stack	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A
Jim Bridger		JB Unit 1		JB Unit 2		JB Unit 3	
Scenario	First Year Cost	Scenario	First Year Cost	Scenario	First Year Cost	Scenario	First Year Cost
Baseline - Current Operation with Wet FGD and ESP		Baseline - Current Operation with Wet FGD and ESP		Baseline - Current Operation with Wet FGD and ESP		Baseline - Current Operation with Wet FGD and ESP	
Scenario 1 - LNB with OFA, Wet FGD, ESP	\$ 3,392,440	Scenario 1 - LNB with OFA, Wet FGD, ESP	N/A	Scenario 1 - LNB with OFA, Wet FGD, ESP	N/A	Scenario 1 - LNB with OFA, Dry FGD, Fabric Filter	N/A
Scenario 2 - LNB with OFA, Wet FGD, New/Fabric Filter	\$ 9,759,058	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA and SCR, Dry FGD, Fabric Filter	N/A
Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	\$ 18,093,916	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	N/A	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	N/A	Scenario 3 - LNB with OFA and SCR, Wet FGD, New Stack	N/A
Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	\$ 24,460,535	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A

EY102007001SLQAPP ALPCorp JB1 BART Economic Analysis\_01-11-07.xls

1 of 1

ECONOMIC ANALYSIS SUMMARY

ECONOMIC ANALYSIS SUMMARY									
Jim Bridger Unit 1		Tangential Fired PC							
Boiler Design:		NOx Control				SO2 Control			
Parameter	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter	
<u>Case</u>		1 LNCFS-1 & Windbox Mods.	2 LNB w/OFA, Wet FGD, ESP	3 ROFA, Wet FGD, ESP	4 LNB w/OFA & SNCR, Wet FGD, ESP	5 LNB w/OFA & SCR, Wet FGD, ESP	6 Upgraded Wet FGD, ESP	7 LNCFS-1 & Windbox Mods., Wet FGD, Fabric Filter	10
NOx Emission Control System									Windbox Mods., Wet FGD, Fabric Filter
SO2 Emission Control System									
PM Emission Control System									
<b>TOTAL INSTALLED CAPITAL COST (\$)</b>	<b>0</b>	<b>8,700,001</b>	<b>20,628,122</b>	<b>22,127,239</b>	<b>129,575,455</b>	<b>129,999,900</b>	<b>0</b>	<b>48,386,333</b>	
<b>FIRST YEAR O&amp;M COST (\$)</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>
Operating Labor (\$)	0	28,000	42,000	123,000	150,000	25,550	0	0	51,059
Maintenance Material (\$)	0	42,000	63,000	184,500	285,000	17,033	10,000	10,000	76,445
Maintenance Labor (\$)	0	0	0	0	0	0	0	0	0
Administrative Labor (\$)	0	0	0	0	0	0	0	0	0
<b>TOTAL: FIXED &amp; M COST</b>	<b>0</b>	<b>70,000</b>	<b>105,000</b>	<b>307,500</b>	<b>475,000</b>	<b>42,583</b>	<b>10,000</b>	<b>10,000</b>	<b>127,749</b>
Makeup Water Cost	0	0	0	0	0	30,503	0	0	0
Reagent Cost	0	0	0	1,005,811	912,848	533,206	145,854	0	0
SCF Catalyst / FF Bag Cost	0	0	0	0	594,000	0	0	0	300,040
Waste Disposal Cost	0	0	0	0	0	442,988	0	0	0
Electric Power Cost	0	0	0	2,528,012	2,08,926	208,926	19,710	19,710	1,355,944
<b>TOTAL VARIABLE O&amp;M COST</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>2,528,012</b>	<b>1,214,737</b>	<b>2,297,853</b>	<b>121,593</b>	<b>121,593</b>	<b>1,653,944</b>
<b>TOTAL FIRST YEAR O&amp;M COST</b>	<b>0</b>	<b>70,000</b>	<b>2,633,012</b>	<b>1,522,237</b>	<b>3,272,553</b>	<b>1,255,176</b>	<b>175,564</b>	<b>175,564</b>	<b>1,753,732</b>
<b>FIRST YEAR DEBT SERVICE (\$)</b>	<b>0</b>	<b>827,612</b>	<b>1,952,796</b>	<b>2,104,916</b>	<b>12,326,235</b>	<b>1,236,652</b>	<b>0</b>	<b>0</b>	<b>4,602,887</b>
<b>TOTAL FIRST YEAR COST (\$)</b>	<b>0</b>	<b>837,612</b>	<b>4,385,808</b>	<b>3,227,153</b>	<b>15,599,088</b>	<b>2,494,323</b>	<b>175,564</b>	<b>175,564</b>	<b>6,356,619</b>
Power Consumption (MW)	0.0	0.0	6.4	0.5	3.3	0.5	0.1	0.1	3.4
Annual Power Usage (Million kWh/yr)	0.0	0.0	50.6	4.2	25.3	4.2	0.1	0.1	26.7
<b>CONTROL COST (\$/ton Removed)</b>	<b>0.0%</b>	<b>46.7%</b>	<b>51.1%</b>	<b>55.6%</b>	<b>84.4%</b>	<b>0.0%</b>	<b>0.0%</b>	<b>0.0%</b>	<b>0.0%</b>
Nox Removal Rate (%)	0	4,987	5,440	5,913	8,987	0	0	0	0
Nox Removed (tons/yr)	0	181	843	613	1,735	0	0	0	0
First Year Average Control Cost (\$/Ton NOx Removed)	0	181	7,797	2,885	3,894	0	0	0	0
Incremental Control Cost (\$/Ton NOx Removed)	0	2-1	3.2	4-2	5-4	0	0	0	0
SO2 Removal Rate (%)	77.8%	0.0%	0.0%	0.0%	0.0%	62.5%	0.0%	0.0%	0.0%
SO2 Removed (Tons/yr)	0	0	0	0	0	3,950	0	0	0
First Year Average Control Cost (\$/Ton SO2 Removed)	0	0	0	0	0	632	0	0	0
Incremental Control Cost (\$/Ton SO2 Removed)	0	0	0	0	0	632	0	0	0
PM Removal Rate (%)	99.47%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
PM Removed (Tons/yr)	0	0	0	0	0	0	0	0	0
First Year Average Control Cost (\$/Ton PM Removed)	0	0	0	0	0	0	0	0	0
Incremental Control Cost (\$/Ton PM Removed)	0	0	0	0	0	0	0	0	0
<b>PRESENT WORTH COST (\$)</b>	<b>0</b>	<b>9,655,250</b>	<b>52,657,883</b>	<b>40,725,706</b>	<b>169,652,733</b>	<b>28,372,107</b>	<b>2,145,015</b>	<b>2,145,015</b>	<b>69,955,356</b>

## INPUT CALCULATIONS

### Jim Bridger Unit 1

### Boiler Design:

### Tangential-Fired PC

Parameter	Current Operation	NOx Control				SO2 Control				PM Control		Comments
		LNB w/OfA	ROFA	LNB w/OfA & SNCR	LNB w/OfA	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter				
Case	1 LNGFS-1 & Windbox Mds. Wet FGd	2 LNB w/OfA Wet FGd	3 ROFA Wet FGd	4 LNB w/OfA & SNCR	5 LNB w/OfA & Wet FGd	6 LNB w/OfA & SNCR	7 Upgraded Wet FGD	8 LNGFS-1 & Windbox Mds.	9 LNGFS-1 & Windbox Mds. Wet FGd	10 LNGFS-1 & Windbox Mds. Wet FGd		
NDx Emission Control System												
SC2 Emission Control System												
PM Emission Control System												
Unit Design and Coal Characteristics												
Type of Unit												
Net Power Output (kW)	550,000	550,000	PC	PC	PC	PC	PC	PC	PC	PC	550,000	
Net Plant Heat Rate (Btu/kWh- $\eta$ )	11,320	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000	11,320	
Boiler Fuel												
Coal Heating Value (Btu/lb)												
Coal Sulfur Content (wt %)	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	
Coal Ash Content (wt %)	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	
Boiler Heat Input, each (MMBtu/h)	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	
Coal Flow Rate (LB/Hr)	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	
(Ton/Yr)	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	
Emissions												
Uncontrolled SO2 (LB/Hr)												
(Lb/MMBtu)												
(Lb/Mole/ft <sup>3</sup> )												
(Tons/Yr)												
SO2 Removal Rate (%)	71.87%	0.0%	63.15	6.315	6.315	6.315	6.315	6.315	6.315	6.315	6.315	
(Lb/Hr)												
(Ton/Yr)												
SO2 Emission Rate (LB/Hr)	22,106	0	0	0	0	0	0	0	0	0	0	
(Lb/MMBtu)	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	
(Ton/YC)	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	
Uncontrolled NOx (LB/Hr)	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	
(Lb/Mole/ft <sup>3</sup> )												
(Tons/Yr)												
NOx Removal Rate (%)	0.0%	48.7%	51.1%	55.6%	58.4%	62.5%	65.7%	68.0%	70.6%	73.1%	76.4%	
(Lb/Hr)												
(Ton/Yr)												
NOx Emission Rate (LB/Hr)	0	0	0	0	0	0	0	0	0	0	0	
(Lb/MMBtu)	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	
(Ton/YC)	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	
Uncontrolled Fly Ash (LB/Hr)	61,177	270	270	270	270	270	270	270	270	270	270	
(Lb/MMBtu)	8,350	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045	
(Lb/Mole/ft <sup>3</sup> )	1,705.3	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	
(Tons/Yr)	201,739	1,084	1,084	1,084	1,084	1,084	1,084	1,084	1,084	1,084	1,084	
Fly Ash Removal Rate (%)	99.47%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
(Lb/Hr)												
(Ton/Yr)												
Fly Ash Emission Rate (LB/Hr)	200,674	0	0	0	0	0	0	0	0	0	0	
(Lb/MMBtu)	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045	
(Ton/YC)	1,084	1,084	1,084	1,084	1,084	1,084	1,084	1,084	1,084	1,084	1,084	

EY102007001SLOApp\_A\_PCorp JEB1 BART Economic Analysis\_01-11-07.xls

1 of 2

Parameter	Current Operation	NOx Control				SO2 Control		PM Control		Comments
		LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	Upgraded Wet FGD	Fine Gas Conditioning	Fabric Filter		
Case	1	2	3	4	5	8	9			10
General Plant Data										
Annual Operation (Hours/Year)	7,884	7,884	7,884	7,884	7,884	7,884	7,884			
Annual On-Site Power Plant Capacity Factor	0.90	0.90	0.90	0.90	0.90	0.90	0.90			
Economic Factors										
Intrinsic Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%			
Discount Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%			
Plant Economic Life (Years)	20	20	20	20	20	20	20			
Installed Capital Costs										
NOx Emission Control System (\$2006)	0	8,700,001	20,628,122	22,127,239	129,575,495	0	0	0	0	
SO2 Emission Control System (\$2006)	0	0	0	0	0	12,999,900	0	0	0	
PM Emission Control System (\$2006)	0	0	0	0	0	0	0	0	0	
Total Emission Control Systems (\$2006)	0	8,700,001	20,628,122	22,127,239	129,575,495	12,999,900	0	0	0	
NOx Emission Control System (\$kW)	0	16	39	42	244	0	0	0	0	
SO2 Emission Control System (\$kW)	0	0	0	0	0	25	0	0	0	
PM Emission Control System (\$kW)	0	0	0	0	0	25	0	0	0	
Total Emission Control Systems (\$kW)	0	16	39	42	244	25	0	0	0	
Total Fixed Operating & Maintenance Costs										
Operating Labor (\$)	0	0	0	0	0	0	0	0	0	
Maintenance Material (\$)	0	25,000	42,000	123,000	190,000	26,650	0	0	0	
Maintenance Labor (\$)	0	42,000	63,000	184,600	285,000	17,033	10,000	0	0	
Administrative Labor (\$)	0	0	0	0	0	0	0	0	0	
Total Fixed O&M Cost (\$)	0	70,000	106,000	307,600	475,000	42,583	10,000	0	0	
Annual Fixed O&M Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Water Cost										
Makeup Water Usage (Gpm)	0	0	0	0	0	0	0	0	0	
Unit Price (\$/1000 Gallons)	1.22	1.22	1.22	0.00	0.00	1.22	1.22	1.22	1.22	
Annual Water Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Resident Cost										
Unit Cost (\$/Ton) (\$LB)	None	None	None	Urea	Anhydrous NH3	Soda Ash	Elemental Sulfur	None	None	
Molar Stoichiometry	0.00	0.00	0.00	0.00	0.185	0.200	0.040	0.185	0.000	
Reagent Purity (Wt %)	0.00	0.00	0.00	0.45	1.00	1.02	0.00	0.00	0.000	
Reagent Use (g/Lbf)	100%	100%	100%	100%	100%	100%	100%	100%	90%	
First Year Reagent Cost (\$)	0	0	0	690	573	1,691	1,691	1,691	0	
Annual Reagent Cost Escalation Rate (%)	0	0	0	1,005,311	912,648	631,206	145,354	145,354	0	
SCR Catalyst/FF Bag Replacement Cost										
Annual SCR Catalyst (m3) / No. FF Bags	0	0	0	0	0	0	0	0	0	
SCR Catalyst Cost (\$/m3) / Bag Cost (\$/Bag)	3,000	3,000	3,000	3,000	3,000	554,000	0	0	0	
First Year SCR Catalyst / Bag Replacement Cost (\$)	0	0	0	0	0	0	0	0	0	
Annual SCR Catalyst / Bag Cost Esc. Rate (%)	-2.00%	-2.00%	-2.00%	-2.00%	-2.00%	-2.00%	-2.00%	-2.00%	-2.00%	
FFD Waste Disposal Cost										
FFD Waste Disposal Unit Cost (\$/Dry Ton)	0	0	0	0	0	0	0	0	0	
First Year FGD Waste Disposed Cost (\$)	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	
Annual FGD Waste Disposed Cost Esc. Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Auxiliary Power Cost										
Auxiliary Power Requirement (% of Plant Output) (MW)	0.00%	0.00%	1.21%	0.10%	0.62%	0.10%	0.01%	0.64%		
Unit Cost (\$/2006/MWh)	50.00	60.00	6.41	0.53	3.28	0.53	0.05	3.39		
First Year Auxiliary Power Cost (\$)	0	0	50.00	50.00	50.00	50.00	50.00	50.00	50.00	
Annual Power Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	

## Input Tables

Table 1 - Cases

Index No.	Name of Unit   Case -->	Existing	Nox Control	4	5	6	7	8	9	10
1	Dave Johnston Unit 3	Current Operation	LNB w/OFA	ROFA	LNB w/OFAs & SCR	LNB w/OFAs & SCR	Dry FGD w/ESP	Dry FGD w/Fabric Filter	Wet FGD w/ESP	Fabric Filter
2	Dave Johnston Unit 4	Current Operation	LNB w/OFAs	ROFA	LNB w/OFAs & SCR	LNB w/OFAs & SCR	Dry FGD w/ESP	Dry FGD w/Fabric Filter	Wet FGD w/Fabric Filter	Fabric Filter
3	Jim Bridger Unit 1	Current Operation	LNB w/OFAs	ROFA	LNB w/OFAs & SCR	LNB w/OFAs & SCR	N/A	N/A	Upgraded Wet FGD	Fabric Filter
4	Jim Bridger Unit 2	Current Operation	LNB w/OFAs	ROFA	SNCR	LNB w/OFAs & SCR	N/A	N/A	Upgraded Wet FGD	Fabric Filter
5	Jim Bridger Unit 3	Current Operation	LNB w/OFAs	ROFA	LNB w/OFAs & SCR	LNB w/OFAs & SCR	N/A	N/A	Upgraded Wet FGD	Fabric Filter
6	Jim Bridger Unit 4	Current Operation	LNB w/OFAs	ROFA	LNB w/OFAs & SCR	LNB w/OFAs & SCR	N/A	N/A	Upgraded Wet FGD	Fabric Filter
7	Naughton Unit 1	Current Operation	LNB w/OFAs	ROFA	LNB w/OFAs & SCR	LNB w/OFAs & SCR	Dry FGD w/ESP	Dry FGD w/Fabric Filter	Wet FGD w/ESP	Fabric Filter
8	Naughton Unit 2	Current Operation	LNB w/OFAs	ROFA	LNB w/OFAs & SCR	LNB w/OFAs & SCR	Dry FGD w/ESP	Dry FGD w/Fabric Filter	Wet FGD w/ESP	Fabric Filter
9	Naughton Unit 3	Current Operation	LNB w/OFAs	ROFA	SNCR	LNB w/OFAs & SCR	N/A	N/A	Upgraded Wet FGD	Fabric Filter
10	Wyodak Unit 1	Current Operation	LNB w/OFAs	ROFA	LNB w/OFAs & SCR	LNB w/OFAs & SCR	N/A	N/A	Wet FGD	Fabric Filter

Table 2 - Unit Design and Coal Characteristics

Index No.	Name of Unit	Current Emission Control Systems				Unit Design	Net Plant Heat Rate (Btu/kW-hr)	Coal	Coal Quality	
		NOx	SO2	PM	Burner Design				Heating Value, HHV (Btu/lb)	Sulfur Content (wt %)
1	Dave Johnston Unit 3	None	None	ESP	3-call Burner, Opposed Wall-Fired PC	250,000	11,200	Dry Fork PRB	7,784	0.47%
2	Dave Johnston Unit 4	Line Added to Venturi Scrubber	Venturi Scrubber	Tangential-Fired PC	380,000	11,390	Dry Fork PRB	7,784	0.47%	5.01%
3	Jim Bridger Unit 1	Windbox Mode, LNCFs-1 & Windbox Mode..	WE FGD	Tangential-Fired PC	530,000	11,320	Underground Bridger Mine	9,660	0.53%	5.01%
4	Jim Bridger Unit 2	LNBFs-2 & Windbox Mode..	WE FGD	Tangential-Fired PC	530,000	11,320	Underground Bridger Mine	9,660	0.53%	10.30%
5	Jim Bridger Unit 3	LNCFs-1 & Windbox Mode..	WE FGD	Tangential-Fired PC	630,000	11,320	Underground Bridger Mine	9,660	0.53%	10.30%
6	Jim Bridger Unit 4	LNCFs-1 & Windbox Mode..	WE FGD	Tangential-Fired PC	630,000	11,320	Underground Bridger Mine	9,660	0.53%	10.30%
7	Naughton Unit 1	None	None	ESP	Tangential-Fired PC	173,000	10,694	Kemmerer Mine	9,970	0.60%
8	Naughton Unit 2	None	None	ESP	Tangential-Fired PC	226,000	10,674	Kemmerer Mine	9,970	0.60%
9	Naughton Unit 3	LNCFs II NBB	WE FGD	Tangential-Fired PC	356,000	10,636	Kemmerer Mine	9,970	0.60%	4.64%
10	Wyodak Unit 1	LNB	Dg FGD	Opposed Wall-Fired PC	335,000	12,087	Clover Point Mine	7,977	0.65%	7.46%

Table 3 - Emissions

Index No.	Name of Unit	Current Emission Rates (LB/MMBTU)		NOx Control Emission Rates (LB/MMBTU)				SO2 Control Emission Rates (LB/MMBTU)				PM Emission Rates (LB/MMBTU)			
		Controlled SO2	Controlled NOx	Pm	Case 2	Case 3	Case 4	Case 5	Case 6	Case 7	Case 8	Case 9	Case 10		
1	Dave Johnston Unit 3	1.20	0.70	0.200	0.27	0.21	0.20	0.21	0.21	0.15	0.10	N/A	0.015		
2	Dave Johnston Unit 4	0.33	0.48	0.061	0.15	0.19	0.12	0.12	0.12	0.15	0.10	N/A	0.015		
3	Jim Bridger Unit 1	0.27	0.45	0.045	0.24	0.22	0.20	0.20	0.20	N/A	0.10	0.030	0.015		
4	Jim Bridger Unit 2	0.27	0.45	0.074	0.24	0.22	0.20	0.22	0.22	N/A	0.10	0.030	0.015		
5	Jim Bridger Unit 3	0.27	0.45	0.057	0.24	0.22	0.20	0.22	0.22	N/A	0.10	0.030	0.015		
6	Jim Bridger Unit 4	0.17	0.45	0.030	0.24	0.22	0.20	0.22	0.22	N/A	0.10	0.030	0.015		
7	Naughton Unit 1	..	..	..	..	..	..	..	..	..	..	..	..		
8	Naughton Unit 2	1.20	0.54	0.056	0.24	0.28	0.18	0.18	0.18	0.16	0.10	0.040	0.015		
9	Naughton Unit 3	0.50	0.45	0.054	0.24	0.28	0.18	0.18	0.18	0.16	0.10	0.040	0.015		
10	Wyodak Unit 1	0.50	0.30	0.030	0.23	0.25	0.25	0.25	0.25	N/A	0.10	0.025	0.015		

Table 4 - Case 1 O&amp;M Costs (Current Operation)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent Use (Gpm)	Reagent Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 1	\$ 1	\$ 1	\$ 1	-	-	-	-
2	Dave Johnston Unit 4	\$ 1	\$ 1	\$ 1	\$ 1	-	-	-	-
3	Jim Bridger Unit 1	\$ 1	\$ 1	\$ 1	\$ 1	-	-	-	-
4	Jim Bridger Unit 2	\$ 1	\$ 1	\$ 1	\$ 1	-	-	-	-
5	Jim Bridger Unit 3	\$ 1	\$ 1	\$ 1	\$ 1	-	-	-	-
6	Jim Bridger Unit 4	\$ 1	\$ 1	\$ 1	\$ 1	-	-	-	-
7	Naughton Unit 1	\$ 1	\$ 1	\$ 1	\$ 1	-	-	-	-
8	Naughton Unit 2	\$ 1	\$ 1	\$ 1	\$ 1	-	-	-	-
9	Naughton Unit 3	\$ 1	\$ 1	\$ 1	\$ 1	-	-	-	-
10	Wyodak Unit 1	\$ 1	\$ 1	\$ 1	\$ 1	-	-	-	-

Table 5 - Case 2 O&amp;M Costs (LNB w/OFA)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent Use (Gpm)	Reagent Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 1	\$ 1	\$ 1	\$ 1	-	-	-	-
2	Dave Johnston Unit 4	\$ 1	\$ 1	\$ 1	\$ 1	-	-	-	-
3	Jim Bridger Unit 1	\$ 1	\$ 1	\$ 1	\$ 1	-	-	-	-
4	Jim Bridger Unit 2	\$ 1	\$ 1	\$ 1	\$ 1	-	-	-	-
5	Jim Bridger Unit 3	\$ 1	\$ 1	\$ 1	\$ 1	-	-	-	-
6	Jim Bridger Unit 4	\$ 1	\$ 1	\$ 1	\$ 1	-	-	-	-
7	Naughton Unit 1	\$ 1	\$ 1	\$ 1	\$ 1	-	-	-	-
8	Naughton Unit 2	\$ 1	\$ 1	\$ 1	\$ 1	-	-	-	-
9	Naughton Unit 3	\$ 1	\$ 1	\$ 1	\$ 1	-	-	-	-
10	Wyodak Unit 1	\$ 1	\$ 1	\$ 1	\$ 1	-	-	-	-

Table 6 - Case 3 O&amp;M Costs (Mobotac ROFA)

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoichi.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 60,000	\$ 90,000	\$ 81,000	\$ 63,000	-	None	-	4.33
2	Dave Johnston Unit 4	\$ 64,000	\$ 42,000	\$ 63,000	\$ 63,000	-	None	-	6.41
3	Jim Bridger Unit 1	\$ 55,000	\$ 42,000	\$ 63,000	\$ 63,000	-	None	-	6.41
4	Jim Bridger Unit 2	\$ 55,000	\$ 42,000	\$ 63,000	\$ 63,000	-	None	-	6.41
5	Jim Bridger Unit 3	\$ 55,000	\$ 42,000	\$ 63,000	\$ 63,000	-	None	-	6.41
6	Jim Bridger Unit 4	\$ 55,000	\$ 42,000	\$ 63,000	\$ 63,000	-	None	-	6.41
7	Naughton Unit 1	\$ 48,000	\$ 48,000	\$ 72,000	\$ 72,000	-	None	-	1.42
8	Naughton Unit 2	\$ 48,000	\$ 48,000	\$ 72,000	\$ 72,000	-	None	-	2.61
9	Naughton Unit 3	\$ 35,000	\$ 35,000	\$ 54,000	\$ 54,000	-	None	-	4.47
10	Wyodak Unit 1	\$ -	\$ -	\$ -	\$ -	-	None	-	6.22

Table 7 - Case 4 O&amp;M Costs (LNB w/OFA &amp; SNCR))

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoichi.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 98,000	\$ 105,000	\$ 147,000	\$ 157,500	-	Urea	0.41	0.33
2	Dave Johnston Unit 4	\$ 98,000	\$ 123,000	\$ 184,500	\$ 184,500	-	Urea	0.45	0.35
3	Jim Bridger Unit 1	\$ 95,000	\$ 122,000	\$ 142,500	\$ 183,000	-	Urea	0.45	0.53
4	Jim Bridger Unit 2	\$ 95,000	\$ 123,000	\$ 184,000	\$ 184,000	-	Urea	0.45	0.53
5	Jim Bridger Unit 3	\$ 95,000	\$ 123,000	\$ 184,000	\$ 184,000	-	Urea	0.45	0.52
6	Jim Bridger Unit 4	\$ 95,000	\$ 123,000	\$ 184,000	\$ 184,000	-	Urea	0.45	0.53
7	Naughton Unit 1	\$ 83,000	\$ 93,000	\$ 124,500	\$ 139,500	-	Urea	0.45	0.16
8	Naughton Unit 2	\$ 83,000	\$ 93,000	\$ 124,500	\$ 139,500	-	Urea	0.51	0.22
9	Naughton Unit 3	\$ 75,000	\$ 93,000	\$ 122,500	\$ 139,500	-	Urea	0.45	0.33
10	Wyodak Unit 1	\$ -	\$ -	\$ -	\$ -	-	Urea	0.45	0.34

Table 8 - Case 5 O&amp;M Costs (LNB w/OFA &amp; SCR))

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoichi.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 155,000	\$ 232,500	\$ 249,000	\$ 285,000	-	Anhydrous NH3	1.00	1.57
2	Dave Johnston Unit 4	\$ 166,000	\$ 190,000	\$ 285,000	\$ 243,000	-	Anhydrous NH3	1.00	2.29
3	Jim Bridger Unit 1	\$ 162,000	\$ 285,000	\$ 243,000	\$ 285,000	-	Anhydrous NH3	1.00	3.28
4	Jim Bridger Unit 2	\$ 162,000	\$ 190,000	\$ 285,000	\$ 243,000	-	Anhydrous NH3	1.00	3.26
5	Jim Bridger Unit 3	\$ 162,000	\$ 190,000	\$ 285,000	\$ 243,000	-	Anhydrous NH3	1.00	3.22
6	Jim Bridger Unit 4	\$ 162,000	\$ 190,000	\$ 285,000	\$ 243,000	-	Anhydrous NH3	1.00	3.26
7	Naughton Unit 1	\$ 132,000	\$ 198,000	\$ 285,000	\$ 249,000	-	Anhydrous NH3	1.00	0.98
8	Naughton Unit 2	\$ 160,000	\$ 249,000	\$ 249,000	\$ 249,000	-	Anhydrous NH3	1.00	1.34
9	Naughton Unit 3	\$ 156,000	\$ 234,000	\$ 271,500	\$ 271,500	-	Anhydrous NH3	1.00	1.99
10	Wyodak Unit 1	\$ -	\$ -	\$ -	\$ -	-	Anhydrous NH3	1.00	2.42

**Table 9 - Case 6 O&M Costs (Dry FGD)**

		Annual Fixed O&M Costs				Variable Operating Requirements				
Index No.	Name of Unit	Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoichi.	Annual FF Bag Replace.	Aux. Power Usage (MW)
1	Dave Johnson Unit 3	\$ 506,128	\$ 714,775	\$ 476,928	\$ -	-	173	Lime	1.15	2.49
2	Dave Johnson Unit 4	\$ -	\$ -	\$ -	\$ -	-	-	-	-	-
3	Jim Bridger Unit 1	\$ -	\$ -	\$ -	\$ -	-	-	-	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	-	-	-	-	-
5	Jim Bridger Unit 3	\$ -	\$ -	\$ -	\$ -	-	-	-	-	-
6	Jim Bridger Unit 4	\$ -	\$ -	\$ -	\$ -	-	-	-	-	-
7	Naughton Unit 1	\$ 506,128	\$ 687,643	\$ 394,762	\$ -	-	120	Lime	1.40	1.64
8	Naughton Unit 2	\$ 506,128	\$ 850,174	\$ 573,044	\$ -	-	165	Lime	1.40	2.25
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	-	-	-	-	-
10	Wyodak Unit 1	\$ -	\$ 21,300	\$ 14,600	\$ -	-	25	Lime	1.10	0.11

**Table 10 - Case 7 O&M Costs (Dry FGD w/Fabric Filter)**

		Annual Fixed O&M Costs				Variable Operating Requirements				
Index No.	Name of Unit	Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoichi.	Annual FF Bag Replace.	Aux. Power Usage (MW)
1	Dave Johnson Unit 3	\$ 506,128	\$ 714,775	\$ 476,928	\$ -	-	173	Lime	1.15	3.88
2	Dave Johnson Unit 4	\$ 506,128	\$ 1,102,288	\$ 734,958	\$ -	-	248	Lime	1.10	4.54
3	Jim Bridger Unit 1	\$ -	\$ -	\$ -	\$ -	-	-	-	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	-	-	-	-	-
5	Jim Bridger Unit 3	\$ -	\$ -	\$ -	\$ -	-	-	-	-	-
6	Jim Bridger Unit 4	\$ -	\$ -	\$ -	\$ -	-	-	-	-	-
7	Naughton Unit 1	\$ 506,128	\$ 682,680	\$ 459,286	\$ -	-	120	Lime	1.15	2.66
8	Naughton Unit 2	\$ 506,128	\$ 905,190	\$ 640,568	\$ -	-	165	Lime	1.15	3.63
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	-	-	-	-	-
10	Wyodak Unit 1	\$ -	\$ -	\$ -	\$ -	-	-	-	-	-

**Table 11 - Case 8 O&M Costs (Wet FGD)**

		Annual Fixed O&M Costs				Variable Operating Requirements				
Index No.	Name of Unit	Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoichi.	Annual FF Bag Replace.	Aux. Power Usage (MW)
1	Dave Johnson Unit 3	\$ 809,804	\$ 1,182,687	\$ 789,391	\$ -	-	230	Lime	1.02	3.45
2	Dave Johnson Unit 4	\$ 809,804	\$ 1,430,784	\$ 952,856	\$ -	-	330	Soda Ash	1.02	6.29
3	Jim Bridger Unit 1	\$ -	\$ 25,650	\$ 17,033	\$ -	-	63	Soda Ash	1.02	0.63
4	Jim Bridger Unit 2	\$ -	\$ 25,650	\$ 17,033	\$ -	-	52	Soda Ash	1.02	0.53
5	Jim Bridger Unit 3	\$ -	\$ 25,650	\$ 17,033	\$ -	-	27	Soda Ash	1.02	0.52
6	Jim Bridger Unit 4	\$ -	\$ 25,650	\$ 17,033	\$ -	-	160	Soda Ash	1.02	0.53
7	Naughton Unit 1	\$ 809,804	\$ 965,369	\$ 642,393	\$ -	-	220	Lime	1.05	2.40
8	Naughton Unit 2	\$ 809,804	\$ 1,226,386	\$ 877,591	\$ -	-	66	Soda Ash	1.02	3.30
9	Naughton Unit 3	\$ -	\$ 21,300	\$ 14,600	\$ -	-	62	Lime	1.02	0.33
10	Wyodak Unit 1	\$ 303,677	\$ 328,496	\$ 218,998	\$ -	-	-	-	-	1.76

Table 12 - Case 9 O&amp;M Costs (Flue Gas Conditioning)

		Annual Fixed O&M Costs						Variable Operating Requirements					
Index No.	Name of Unit	Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Annual FF Bag Replace.	Aux. Power Usage (MW)				
1	Dave Johnston Unit 3	\$ -	\$ -	\$ -	\$ -	-	None	-	-	-	-	-	-
2	Dave Johnston Unit 4	\$ -	\$ -	\$ -	\$ -	10,000	Elemental Sulfur	100	0.06	-	-	-	-
3	Jim Bridger Unit 1	\$ -	\$ -	\$ -	\$ -	10,000	Elemental Sulfur	100	0.06	-	-	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	10,000	Elemental Sulfur	100	0.06	-	-	-	-
5	Jim Bridger Unit 3	\$ -	\$ -	\$ -	\$ -	10,000	Elemental Sulfur	100	0.06	-	-	-	-
6	Jim Bridger Unit 4	\$ -	\$ -	\$ -	\$ -	10,000	Elemental Sulfur	100	0.06	-	-	-	-
7	Naughton Unit 1	\$ -	\$ -	\$ -	\$ -	10,000	Elemental Sulfur	43	0.05	-	-	-	-
8	Naughton Unit 2	\$ -	\$ -	\$ -	\$ -	10,000	Elemental Sulfur	67	0.05	-	-	-	-
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	10,000	Elemental Sulfur	63	0.05	-	-	-	-
10	Wyodak Unit 1	\$ -	\$ -	\$ -	\$ -	10,000	Elemental Sulfur	-	-	-	-	-	-

Table 13 - Case 10 O&amp;M Costs (Fabric Filter)

		Annual Fixed O&M Costs						Variable Operating Requirements					
Index No.	Name of Unit	Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Annual FF Bag Replace.	Aux. Power Usage (MW)				
1	Dave Johnston Unit 3	\$ 45,016	\$ 67,524	\$ -	\$ -	-	None	-	1,457	1.33	-	-	-
2	Dave Johnston Unit 4	\$ 68,133	\$ 102,193	\$ -	\$ -	-	None	-	1,738	2.35	-	-	-
3	Jim Bridger Unit 1	\$ 51,039	\$ 76,449	\$ -	\$ -	-	None	-	2,885	3.39	-	-	-
4	Jim Bridger Unit 2	\$ 51,039	\$ 76,449	\$ -	\$ -	-	None	-	2,885	3.37	-	-	-
5	Jim Bridger Unit 3	\$ 51,039	\$ 76,449	\$ -	\$ -	-	None	-	2,827	3.33	-	-	-
6	Jim Bridger Unit 4	\$ 51,039	\$ 76,449	\$ -	\$ -	-	None	-	2,825	3.39	-	-	-
7	Naughton Unit 1	\$ 45,016	\$ 67,524	\$ -	\$ -	-	None	-	865	1.01	-	-	-
8	Naughton Unit 2	\$ 45,016	\$ 67,524	\$ -	\$ -	-	None	-	1,193	1.38	-	-	-
9	Naughton Unit 3	\$ 48,666	\$ 72,999	\$ -	\$ -	-	None	-	1,739	2.06	-	-	-
10	Wyodak Unit 1	\$ 48,666	\$ 72,999	\$ -	\$ -	-	None	-	1,738	2.06	-	-	-

Table 14 - Major Materials Design and Supply Costs

		NOx Control						SO2 Control						PM Control
Index No.	Name of Unit [Case →]	2	3	4	5	6	7	8	9	10				
1	Dave Johnston Unit 3	\$ 3,221,912	\$ 3,566,617	\$ 5,773,000	\$ 49,355,000	\$ 83,871,000	\$ 142,077,000	\$ 108,866,689	\$ -	\$ 18,359,000	-	-	-	-
2	Dave Johnston Unit 4	\$ 2,673,501	\$ 4,343,132	\$ 7,171,085	\$ 66,200,000	\$ 80,920,000	\$ 137,267,000	\$ 178,174,334	\$ -	\$ 30,853,530	-	-	-	-
3	Jim Bridger Unit 1	\$ 2,981,982	\$ 6,056,965	\$ 9,528,000	\$ -	\$ 80,920,000	\$ -	\$ -	\$ 8,010,033	\$ -	\$ 29,814,000	-	-	-
4	Jim Bridger Unit 2	\$ -	\$ 6,056,955	\$ 9,526,000	\$ -	\$ 80,920,000	\$ -	\$ -	\$ 8,010,033	\$ -	\$ 29,814,000	-	-	-
5	Jim Bridger Unit 3	\$ 2,981,982	\$ 6,056,965	\$ 9,419,000	\$ -	\$ 80,920,000	\$ -	\$ -	\$ 8,010,033	\$ -	\$ 29,814,000	-	-	-
6	Jim Bridger Unit 4	\$ 2,981,982	\$ 6,056,965	\$ 9,628,000	\$ -	\$ 80,920,000	\$ -	\$ -	\$ 8,010,033	\$ -	\$ 29,814,000	-	-	-
7	Naughton Unit 1	\$ 2,502,123	\$ 2,675,732	\$ 7,257,000	\$ 37,299,000	\$ 26,879,000	\$ 42,301,000	\$ 44,000,000	\$ 800,000	\$ 15,482,000	-	-	-	-
8	Naughton Unit 2	\$ 2,570,674	\$ 3,123,533	\$ 8,784,000	\$ 47,931,000	\$ 39,262,000	\$ 57,621,000	\$ 56,000,000	\$ 800,000	\$ 18,359,000	-	-	-	-
9	Naughton Unit 3	\$ 3,187,636	\$ 4,381,377	\$ 11,203,578	\$ 67,375,000	\$ 59,000,000	\$ 72,471,000	\$ 72,471,000	\$ 800,000	\$ 20,106,000	-	-	-	-
10	Wyodak Unit 1	\$ 3,187,636	\$ 4,500,246	\$ 7,234,860	\$ 998,100	\$ -	\$ 178,174,334	\$ 1,247,061	\$ 1,247,061	\$ 1,247,061	-	-	-	-

## **CAPITAL COST**

LNB w/OFA											
Jim Bridger Unit 1											
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$Ton NOx Removed)
0	2013	70,000	-	-	-	-	-	-	627,612	697,612	181
1	2014	71,400	-	-	-	-	-	-	627,612	698,012	181
2	2015	72,828	-	-	-	-	-	-	627,612	699,440	181
3	2016	74,285	-	-	-	-	-	-	627,612	701,887	182
4	2017	75,770	-	-	-	-	-	-	627,612	703,382	182
5	2018	77,286	-	-	-	-	-	-	627,612	704,888	182
6	2019	78,831	-	-	-	-	-	-	627,612	706,443	183
7	2020	80,403	-	-	-	-	-	-	627,612	708,020	183
8	2021	82,016	-	-	-	-	-	-	627,612	709,628	183
9	2022	83,656	-	-	-	-	-	-	627,612	911,259	183
10	2023	85,330	-	-	-	-	-	-	627,612	912,942	184
11	2024	87,036	-	-	-	-	-	-	627,612	914,648	184
12	2025	88,777	-	-	-	-	-	-	627,612	916,349	185
13	2026	90,522	-	-	-	-	-	-	627,612	918,165	185
14	2027	92,364	-	-	-	-	-	-	627,612	919,976	185
15	2028	94,211	-	-	-	-	-	-	627,612	921,823	186
16	2029	96,095	-	-	-	-	-	-	627,612	923,707	186
17	2030	98,017	-	-	-	-	-	-	627,612	925,629	186
18	2031	99,977	-	-	-	-	-	-	627,612	927,559	187
19	2032	101,977	-	-	-	-	-	-	627,612	929,500	187
20	2033	103,977	-	-	-	-	-	-	627,612	931,550	187
Present Worth (%)		855,250	-	9.0%	-	0.0%	-	0.0%	-	8,700,001	9,685,250
(% of PW)											98

ROFA											
Jim Bridger Unit 1											
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$Ton NOx Removed)
0	2013	105,000	-	-	-	-	-	528,012	1,952,796	4,585,808	843
1	2014	107,100	-	-	-	-	-	528,012	1,952,796	4,638,468	853
2	2015	108,242	-	-	-	-	-	528,012	1,952,796	4,692,182	863
3	2016	111,427	-	-	-	-	-	528,012	1,952,796	4,746,970	873
4	2017	114,647	-	-	-	-	-	528,012	1,952,796	4,802,853	883
5	2018	118,855	-	-	-	-	-	528,012	1,952,796	4,869,854	893
6	2019	123,100	-	-	-	-	-	528,012	1,952,796	4,937,985	904
7	2020	124,247	-	-	-	-	-	528,012	1,952,796	4,977,299	915
8	2021	120,612	-	-	-	-	-	528,012	1,952,796	5,037,789	926
9	2022	123,024	-	-	-	-	-	528,012	1,952,796	5,099,499	937
10	2023	125,495	-	-	-	-	-	528,012	1,952,796	5,162,423	949
11	2024	127,984	-	-	-	-	-	528,012	1,952,796	5,226,616	961
12	2025	130,554	-	-	-	-	-	528,012	1,952,796	5,292,092	973
13	2026	133,165	-	-	-	-	-	528,012	1,952,796	5,358,978	985
14	2027	135,829	-	-	-	-	-	528,012	1,952,796	5,427,000	998
15	2028	138,545	-	-	-	-	-	528,012	1,952,796	5,496,184	1,010
16	2029	141,316	-	-	-	-	-	528,012	1,952,796	5,567,558	1,023
17	2030	144,142	-	-	-	-	-	528,012	1,952,796	5,639,649	1,037
18	2031	147,025	-	-	-	-	-	528,012	1,952,796	5,713,386	1,054
19	2032	149,966	-	-	-	-	-	528,012	1,952,796	5,786,598	1,074
20	2033	152,965	-	-	-	-	-	528,012	1,952,796	58,616	484
Present Worth (%)		1,282,875	-	2.4%	-	0.0%	-	0.0%	-	30,886,886	30,886,886
(% of PW)											39.0%

LNB w/OFA & SNCR										
Jim Bridger Unit 1		Control Cost (\$/Ton NOx Removed)								
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Batch Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST
0	2013	307,500	-	1,005,811	-	-	208,926	1214,737	2,104,916	3,327,453
1	2014	315,850	-	1,025,927	-	-	213,105	1,129,032	2,104,916	3,657,598
2	2015	319,923	-	1,046,146	-	-	217,387	1,283,812	2,104,916	3,688,651
3	2016	-	-	1,067,375	-	-	221,714	1,289,088	2,104,916	3,720,326
4	2017	326,321	-	1,088,722	-	-	226,148	1,414,870	2,104,916	3,752,334
5	2018	332,848	-	1,110,496	-	-	230,671	1,341,168	2,104,916	3,785,389
6	2019	338,505	-	1,132,706	-	-	235,285	1,367,981	2,104,916	3,819,202
7	2020	346,295	-	1,155,361	-	-	240,950	1,395,351	2,104,916	3,853,498
8	2021	353,221	-	1,178,486	-	-	244,730	1,423,258	2,104,916	3,888,459
9	2022	360,285	-	1,202,037	-	-	249,586	1,451,723	2,104,916	3,924,130
10	2023	367,491	-	1,226,078	-	-	254,880	1,480,757	2,104,916	3,960,514
11	2024	374,841	-	1,250,599	-	-	259,773	1,510,373	2,104,916	4,007,226
12	2025	382,338	-	1,275,811	-	-	264,969	1,540,580	2,104,916	4,045,481
13	2026	389,984	-	1,301,124	-	-	270,683	1,571,392	2,104,916	4,074,992
14	2027	397,784	-	1,327,146	-	-	275,673	1,602,816	2,104,916	4,113,475
15	2028	405,740	-	1,353,889	-	-	281,187	1,634,876	2,104,916	4,153,846
16	2029	413,855	-	1,380,763	-	-	286,811	1,667,573	2,104,916	4,194,521
17	2030	422,132	-	1,408,574	-	-	292,547	1,700,925	2,104,916	4,236,415
18	2031	430,574	-	1,436,546	-	-	298,398	1,732,943	2,104,916	4,279,045
19	2032	439,186	-	1,465,576	-	-	304,956	1,763,642	2,104,916	4,322,528
20	2033	447,965	-	1,493,590	-	-	310,626	1,794,347	2,104,916	4,365,506
Present Worth		3,756,930	9.2%	-	12,886,949	-	-	2,355,327	14,841,477	22,271,539
% of PW		-	-	-	30.2%	-	0.0%	6.3%	35.4%	54.3%
										100.0%
344										

LNB w/OFA & SCR										
Jim Bridger Unit 1		Control Cost (\$/Ton NOx Removed)								
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Batch Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST
0	2013	475,000	-	912,848	-	-	1,291,005	2,787,853	12,326,235	15,598,088
1	2014	484,500	-	931,105	-	-	1,316,826	2,853,810	12,326,235	15,684,445
2	2015	494,190	-	946,727	-	-	1,343,162	2,910,888	12,326,235	15,771,311
3	2016	504,074	-	968,722	-	-	1,370,025	2,968,104	12,326,235	15,879,013
4	2017	514,074	-	980,996	-	-	1,399,725	3,028,466	12,326,235	15,988,676
5	2018	514,155	-	1,002,858	-	-	1,428,374	3,089,056	12,326,235	16,099,728
6	2019	524,938	-	1,026,015	-	-	1,453,881	3,150,837	12,326,235	16,211,599
7	2020	534,927	-	1,048,575	-	-	1,482,859	3,213,854	12,326,235	16,325,714
8	2021	545,626	-	1,068,547	-	-	1,512,616	3,278,131	12,326,235	16,440,004
9	2022	556,538	-	1,080,936	-	-	1,542,370	3,343,983	12,326,235	16,537,997
10	2023	567,669	-	1,102,757	-	-	1,572,726	3,410,557	12,326,235	16,615,024
11	2024	579,022	-	1,135,012	-	-	1,605,202	3,474,779	12,326,235	16,695,816
12	2025	590,603	-	1,168,566	-	-	1,633,736	3,545,854	12,326,235	16,770,004
13	2026	602,415	-	1,177,712	-	-	1,670,053	3,619,321	12,326,235	16,850,019
14	2027	614,463	-	1,180,666	-	-	1,705,454	3,691,708	12,326,235	16,944,995
15	2028	626,752	-	1,204,484	-	-	1,737,523	3,785,542	12,326,235	17,035,064
16	2029	638,287	-	1,228,573	-	-	1,772,273	3,840,953	12,326,235	17,129,161
17	2030	652,073	-	1,253,145	-	-	1,807,719	3,917,570	12,326,235	17,208,675
18	2031	663,115	-	1,273,208	-	-	1,848,873	3,986,023	12,326,235	17,287,498
19	2032	678,417	-	1,305,777	-	-	1,880,751	4,075,944	12,326,235	17,364,164
20	2033	691,985	-	1,329,847	-	-	1,912,510	4,153,944	12,326,235	17,439,164
Present Worth		5,803,480	3.4%	11,153,043	7,257,405	-	15,773,310	34,183,758	12,326,235	18,527,498
% of PW		-	-	6.6%	4.3%	-	0.0%	9.3%	20.2%	76.4%
943										

Upgraded Wet FGD											
Jim Bridger Unit 1											
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/ton SO2 Removed)
0	2013	42,583	30,503	533,206	442,858	268,926	1,215,583	1,238,652	2,484,828	632	
1	2014	43,435	31,113	543,870	451,818	213,105	1,238,905	1,238,652	2,519,891	638	
2	2015	43,303	31,735	554,747	460,854	217,387	1,238,703	1,238,652	2,545,858	645	
3	2016	45,189	32,370	565,842	470,071	221,714	1,238,987	1,238,652	2,571,838	651	
4	2017	45,189	32,017	577,159	478,472	226,148	1,315,737	1,238,652	2,589,542	658	
5	2018	45,093	33,876	588,702	480,982	230,671	1,312,113	1,238,652	2,605,780	665	
6	2019	47,015	34,351	600,476	498,843	235,285	1,358,985	1,238,652	2,633,562	672	
7	2020	47,955	35,038	612,486	508,820	239,890	1,358,334	1,238,652	2,661,901	679	
8	2021	48,914	35,793	624,735	518,886	244,780	1,424,261	1,238,652	2,710,806	686	
9	2022	49,893	36,454	637,230	528,376	249,686	1,452,746	1,238,652	2,740,289	694	
10	2023	50,890	37,183	649,975	538,964	254,680	1,481,801	1,238,652	2,770,381	701	
11	2024	51,908	37,183	662,274	550,763	265,773	1,511,457	1,238,652	2,801,636	709	
12	2025	52,946	37,225	676,234	567,177	267,983	1,541,686	1,238,652	2,832,323	717	
13	2026	54,005	38,685	689,758	573,014	270,288	1,572,459	1,238,652	2,864,237	725	
14	2027	55,085	39,459	703,554	584,474	275,873	1,603,949	1,238,652	2,895,788	733	
15	2028	55,187	40,248	717,625	586,164	281,187	1,636,028	1,238,652	2,929,891	742	
16	2029	57,311	41,053	731,977	608,087	286,811	1,668,748	1,238,652	2,963,858	750	
17	2030	58,457	41,874	746,617	620,249	292,547	1,702,123	1,238,652	2,998,402	759	
18	2031	59,326	42,711	751,549	632,654	298,398	1,736,166	1,238,652	3,035,637	768	
19	2032	60,119	43,556	767,628	645,307	304,365	1,770,889	1,238,652	3,070,577	777	
20	2033	62,035	372,879	814,628	54,12,000	2,552,627	14,851,985	12,989,900	28,372,107	359	
Present Worth (%)		520,271	1.8%	372,879	54,12,000	0.0%	5,12,000	52,3%	45.8%	100.0%	


Flue Gas Conditioning											
Jim Bridger Unit 1											
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/ton PM Removed)
0	2013	10,000		145,854			19,710	165,564		175,564	485
1	2014	10,200		148,771			20,104	158,875		179,075	505
2	2015	10,404		151,147			20,508	172,233		182,657	515
3	2016	10,612		154,781			20,916	175,688		186,310	525
4	2017	10,824		157,877			21,335	179,212		190,036	536
5	2018	11,041		164,055			21,751	182,756		193,837	546
6	2019	11,262		167,540			22,167	185,452		197,714	557
7	2020	11,487		170,981			22,641	189,181		201,568	568
8	2021	11,717		174,308			23,093	193,985		205,701	580
9	2022	11,951		177,785			23,555	197,884		209,815	591
10	2023	12,190		181,351			24,026	201,822		214,012	603
11	2024	12,434		184,978			24,507	205,858		218,282	615
12	2025	12,682		188,678			24,987	209,975		222,656	628
13	2026	12,936		192,451			25,497	214,175		227,111	640
14	2027	13,185		196,300			26,007	218,458		231,953	653
15	2028	13,435		200,226			26,527	222,827		236,286	665
16	2029	13,783		204,231			27,038	227,284		241,012	679
17	2030	14,102		208,315			27,599	231,830		245,832	693
18	2031	14,262		212,482			28,151	236,465		250,749	707
19	2032	14,468		216,645			28,714	241,195		255,764	721
20	2033	14,779	0.0%	1,782,023		0.0%	240,814	2,022,537		2,145,015	302
Present Worth (%)		122,779	5.7%	83,156		0.0%	121,126	51,3%	0.0%	100.0%	

Jim Bridger Unit 1

Fabric Filter

EY102007001SLCApp\_A\_PCorp\_JB1 BART Economic Analysis\_01-11-07.xls


### **First Year Cost for Air Pollution Control Options**



EY102007001SLC\app A\_PCorp JB1 BART Economic Analysis\_01-11-07.xls

1 of 1

### Present Worth Cost for Air Pollution Control Options



EY102007001SLC\app A\_PCorp JB1 BART Economic Analysis\_01-11-07.xls

1 of 1

**APPENDIX B**

**2006 Wyoming BART Protocol**

## **BART Air Modeling Protocol**

### **Individual Source Visibility Assessments for BART Control Analyses**

**September, 2006**

**State of Wyoming  
Department of Environmental Quality  
Air Quality Division  
Cheyenne, WY 82002**

## Table of Contents

1.0	INTRODUCTION .....	3
2.0	OVERVIEW .....	4
3.0	EMISSIONS DATA FOR MODELING .....	7
3.1	Baseline Modeling .....	7
3.2	Post-Control Modeling.....	8
4.0	METEOROLOGICAL DATA.....	9
5.0	CALPUFF MODEL APPLICATION.....	12
6.0	POST PROCESSING .....	15
7.0	REPORTING .....	19

## **1.0 INTRODUCTION**

The U.S. EPA has issued final amendments to the Regional Haze Regulations, along with Guidelines for Best Available Retrofit Technology (BART) Determinations.<sup>(1)</sup> The guidelines address the methodology for determining which facilities must apply BART (sources subject-to-BART) and the evaluation of control options.

The State of Wyoming used air quality modeling in accordance with the EPA Guidelines to determine the Wyoming sources which are subject-to-BART. This Protocol defines the specific methodology to be used by those sources for determining the improvement in visibility to be achieved by BART controls.

The methodology presented in this Protocol is consistent with EPA guidance and the Air Quality Division (AQD) determination of subject-to-BART sources. It is intended that all Wyoming sources that must conduct BART analyses will use this Protocol for their evaluation of control technology visibility improvement. Any deviations from the procedures described herein must be approved by the Division prior to implementation.

---

<sup>(1)</sup> 40 CFR Part 51: Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations; Final Rule. 70 Federal Register, 39103-39172, July 6, 2005.

## 2.0 OVERVIEW

Wyoming AQD determined that eight facilities (sources) in the state are subject-to-BART. The sources are listed in Table 1. Division modeling indicated that each of these sources causes or contributes to visibility impairment in one or more Class I areas. Each source must conduct a BART analysis to define Best Available Retrofit Technology (BART) applicable to that source, and quantify the improvement in Class I visibility associated with BART controls. This Protocol sets out the procedures for quantifying visibility improvement. Other aspects of the full BART analysis are not addressed here.

There are many Class I areas within and surrounding Wyoming (See Figure 1). On the basis of distance from subject-to-BART sources, topography, meteorology, and prior modeling, the AQD has determined that only five Class I areas need be addressed in BART individual source analyses. These are Badlands and Wind Cave National Parks in South Dakota, Mt. Zirkel Wilderness Area in Colorado, and Bridger and Fitzpatrick Wilderness Areas in Wyoming. Sources in eastern Wyoming have been shown to have greatest visibility impacts at the two South Dakota Class I areas, and western Wyoming sources have maximum impacts at Bridger and Fitzpatrick Wilderness Areas, and Mt. Zirkel. Visibility improvement at these highest impact areas will provide the best measure of the effectiveness of BART controls.

Each facility should carry out modeling with the CALPUFF modeling system for the Class I areas specified in Table 2. The AQD will provide meteorological input for CALMET for the years 2001, 2002, and 2003. The model domain covered by the AQD meteorological data is centered in southwest Wyoming, and extends roughly from Twin Falls, ID in the west to the Missouri River in the east, and from Denver in the south to Helena, MT in the north. The domain is shown, along with Class I areas, in Figure 1.

Sources may wish to utilize a smaller domain for CALPUFF modeling. Smaller domains are acceptable if they provide adequate additional area beyond the specific source and Class I areas being addressed. Figure 1 includes a "southwest Wyoming" domain which represents the minimum acceptable area for sources impacting the Bridger and Fitzpatrick Wilderness Areas, and the Mt. Zirkel Wilderness Area, and a "northeast Wyoming" domain as a minimum area for Badlands and Wind Cave National Parks modeling.

The CALPUFF model should be used with each of the three years of meteorological data to calculate visibility impacts for a baseline (existing emissions) case, and for cases reflecting BART controls. The control scenarios are to include individual scenarios for proposed BART controls for each pollutant ( $\text{SO}_2$ ,  $\text{NO}_x$ , and particulate matter), and a combined scenario representing application of all proposed BART controls. If desired, additional modeling may be performed for controls that are not selected as BART. This might be done, for example, to provide data useful in identifying the control technologies that represent BART. However, visibility modeling is required only for the proposed BART controls.

Table 1. Wyoming Sources Subject-to-BART

Basin Electric	Laramie River Power Plant	Boilers #1,2,3
FMC Corporation	Granger Soda Ash Plant	Boilers #1,2
FMC Corporation	Green River Sodium Plant	Three boilers
General Chemical Co.	Green River Soda Ash	Two boilers
PacifiCorp	Dave Johnson Power Plant	Boilers #3,4
PacifiCorp	Jim Bridger Power Plant	Boilers #1-4
PacifiCorp	Naughton Power Plant	Boilers #1,2,3
PacifiCorp	Wyodak Power Plant	Boiler

Results of visibility modeling will be presented as a comparison between baseline impacts and those calculated for the BART control scenarios. Quantitative measures of impact will be the 98<sup>th</sup> percentile deciview change ( $\Delta dv$ ) relative to the 20% best days natural background, and the number of days with deciview change exceeding 0.5 (EPA Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations, 70 FR 39103). Results should be presented for each year.

Table 2. Source-Specific Class I Areas to be Addressed

Source	Class I Areas to be Evaluated
Basin Electric Laramie River	Wind Cave NP; Badlands NP
FMC Corporation Granger Soda Ash	Bridger WA, Fitzpatrick WA
FMC Corporation Sodium Products	Bridger WA, Fitzpatrick WA
General Chemical Green River Soda Ash	Bridger WA, Fitzpatrick WA
Pacificorp Dave Johnston	Wind Cave NP, Badlands NP
Pacificorp Jim Bridger	Bridger WA, Fitzpatrick WA, Mt. Zirkel WA
Pacificorp Naughton Plant	Bridger WA, Fitzpatrick WA
Pacificorp Wyodak	Wind Cave NP, Badlands NP

### 3.0 EMISSIONS DATA FOR MODELING

CALPUFF model input requires source (stack) – specific emission rates for each pollutant, and stack parameters (height, diameter, exit gas temperature, and exit gas velocity). Per EPA BART guidance, these parameters must be representative of maximum actual 24-hour average emitting conditions for baseline (existing) operation, and maximum proposed 24-hour average emissions for future (BART) operations.

#### 3.1 Baseline Modeling

Sources are required to utilize representative baseline emission conditions if data are available; baseline emissions must be documented. Possible sources of emission data are stack tests, CEM data, fuel consumption data, etc. Remember that emissions should represent maximum 24-hour rates. EPA BART guidance states that you should “Use the 24-hour average actual emission rate from the highest-emitting day of the meteorological period modeled (for the pre-control scenario).” Thus, baseline conditions should reference data from 2001 through 2003 (or 2004).

As a minimum, modeled emissions must include:

SO <sub>2</sub>	sulfur dioxide
NO <sub>x</sub>	oxides of nitrogen
PM <sub>2.5</sub>	particles with diameter less than 2.5µm
PM <sub>10-2.5</sub>	particles with diameters greater than 2.5µm but less than or equal to 10 µm

If the fraction of PM<sub>10</sub> in the PM<sub>2.5</sub> (fine) and PM<sub>10-2.5</sub> (coarse) categories cannot be determined all particulate matter should be assumed to be PM<sub>2.5</sub>.

In addition, direct emissions of sulfate (SO<sub>4</sub>) should be included where possible. Sulfate can be emitted as sulfuric acid (H<sub>2</sub>SO<sub>4</sub>), sulfur trioxide (SO<sub>3</sub>), or as sulfate compounds; emissions should be quantified as the equivalent mass of SO<sub>4</sub>.

When test or engineering data are not available to specify SO<sub>4</sub> emissions or the relative fractions of fine and coarse particles, use can be made of speciation profiles available from Federal Land Managers at the website <http://ww2.nature.nps.gov/air/permits/ect/index.cfm>. Profiles are available for a number of source type and control technology combinations. The FLM speciation factors are acceptable if data are available for the appropriate source type.

Emissions of VOC (volatile organic compounds), condensable organics measured in stack tests, and elemental carbon components of PM<sub>10</sub> do not need to be included for BART modeling. The only other pollutant noted in EPA BART guidance is ammonia (NH<sub>3</sub>). Though ammonia is not believed to be a significant contributor to visibility

impairment in most cases in Wyoming, it could be important for sources with significant ammonia emissions – for example from some NO<sub>x</sub> control systems. Sources that are expected to emit ammonia (in pre-or post-control configurations) should include ammonia emissions in their model input.

If quantitative baseline emissions data are unavailable and sources believe that the maximum 24-hour emission rates estimated by the Division (presented in the Subject-to-BART final report) are representative of baseline conditions for their facility, they may be used for baseline modeling. However, emissions of sulfate and ammonia (if applicable) should be included based on the best available test information or speciation factors from current literature.

### 3.2 Post-Control Modeling

All pollutants described above should be included for each post-control scenario. Post-control emissions (maximum 24-hour average) will generally be the baseline emissions multiplied by a control factor appropriate to the BART control. However, some proposed controls may simply increase the efficiency of existing controls; others may result in an increase in emissions of one pollutant while controlling another. These factors must all be considered in defining emission rates for post-control modeling. Any changes in stack parameters resulting from control application must also be included.

The required visibility assessment will include the effect of each proposed BART control. For example, if a source proposes to add a scrubber for SO<sub>2</sub> control, low NO<sub>x</sub> burners for NO<sub>x</sub> control, and a baghouse for particulate control, four sets of visibility results should be developed:

- Use of SO<sub>2</sub> control alone
- Use of NO<sub>x</sub> control alone
- Use of particulate control alone
- Use of proposed combination of all three controls

All pollutants should be modeled in each CALPUFF model run, but the modeled emissions should reflect only the specific controls or combination of controls addressed in that run.

Additional modeling could be necessary in situations where a facility is comprised of more than one subject-to-BART source, and different BART controls are applicable to different sources. Excessive modeling to address multiple control combinations is not necessary; however, visibility modeling should quantify the effect of BART controls on all affected sources for each pollutant, and of all facility BART controls combined.

#### 4.0 METEOROLOGICAL DATA

Wyoming AQD will provide MM5 meteorological data fields for years 2001, 2002, and 2003 that can be utilized as input to CALMET. The MM5 output will have 12 kilometer resolution and cover the full domain shown in Figure 1.

Mesoscale meteorological data (MM5) were developed and evaluated as part of the AQD's southwest Wyoming NO<sub>2</sub> increment analysis. Three years of MM5 data at 36 km resolution were used to initialize 12 km MM5 simulations. The 12km MM5 modeling used identical physics options to the original 36 km runs. CALMM5 was then used as a preprocessor to produce CALMET - ready MM5 data input files. Quality assurance was performed by comparing the original MM5 output on the 36km national RPO grid to the 12 km MM5 output and observations.

The CALMET model (version 5.53a, level 040716) should be used to prepare meteorological input for CALPUFF. The user may select a domain smaller than the MM5 domain for CALMET and CALPUFF modeling if desired. Figure 1 shows minimum domain areas for modeling of western and eastern Wyoming BART sources. Four kilometer resolution should be specified for CALMET output.

CALMET processing should use the AQD MM5 data, and appropriate surface, upper air, and precipitation data. Figure 2 shows the locations of surface and upper air stations within the MM5 model domain. The MM5 data are used as the initial guess wind field; this wind field is then adjusted by CALMET for terrain and land use to generate a step 1 wind field, and refined using surface and upper air data to create the final step 2 wind field.

Surface, upper air, and precipitation data can be obtained from the National Climatic Data Center. Land use and terrain data are available from the U.S. Geological Survey. Data can be formatted for use in CALMET with standard conversion and processing programs available with the CALMET/CALPUFF software.

Table 3 provides a listing of applicable CALMET input variables for BART meteorological processing. The table includes inputs that are specific to Wyoming BART modeling. Inputs not shown in Table 3 are not relevant to the present application, are dependent on the specific model domain of the user, use model default values, or are obvious from the context.

Table 3. CALMET Control File Inputs

Variable	Description	Value
Input Group 1		
IBYR	Year	2001
		2002
		2003
IBTZ	Base time zone	7
IRTYPE	Run type	1
LCALGRD	Compute data fields for CALGRID	T
Input Group 2		
PMAP	Map projection	LCC
DGRIDKM	Grid spacing (km)	4
NZ	Number of layers	10
ZFACE	Cell face heights (m)	0
		20
		40
		100
		140
		320
		580
		1020
		1480
		2220
		3500
Input Group 4		
NOOBS	No observation Mode	0
Input Group 5		
IWFCOD	Model selection variable	1
IFRADJ	Froude number adjustment	1
IKINE	Kinematic effects	0
IOBR	Use O'Brien procedure	0
ISLOPE	Slope flow effects	1
IEXTRP	Extrapolate surface wind observations	-4
ICALM	Extrapolate calm surface winds	0
BIAS	Biases for weights of surface and upper air stations	All 0
RMIN2	Minimum distance for extrapolation	-1
IPROG	Use gridded prognostic model output	14
ISTEPPG	Time Step (hours)	1
LVARY	Use varying radius of influence	F

Table 3. CALMET Control File Inputs (continued)

Variable	Description	Value
RMAX 1	Maximum radius of influence (km)	30
RMAX 2	Maximum radius of influence (km)	50
RMIN	Minimum radius of influence (km)	0.1
TERRAD	Radius of influence for terrain (km)	15
R1	Relative weighting of first guess wind field and observations (km)	5
R2	Relative weighting aloft (km)	25
IDIOPT 1	Surface temperature	0
IDIOPT 2	Upper air lapse rate	0
ZUPT	Lapse rate depth (m)	200
IDIOPT 3	Average wind components	0
IUPWND	Upper air station	-1
ZUPWND (1)	Bottom and top of layer for domain scale winds (m)	1, 1000
ZUPWND (2)		1, 1000
IDIOPT4	Surface wind components	0
IDIOPT5	Upper air wind components	0
Input Group 6		
IAVEZI	Spatial averaging	1
MNMMDAV	Max search radius	1
HAFANG	Half angle for averaging (deg)	30
ILEVZI	Layer of winds in averaging	1
ZIMAX	Maximum overland mixing height (m)	3500
ITPROG	3D temperature source	1
IRAD	Interpolation type	1
TRADKM	Radius of influence - temperature (km)	500
NUMTS	Maximum number of Stations	5
IAVET	Spatial averaging of temperatures	1
NFLAGP	Precipitation interpolation	2

## 5.0 CALPUFF MODEL APPLICATION

The CALPUFF model (version 5.711a, level 040716) will be used to calculate pollutant concentrations at receptors in each Class I area. Application of CALPUFF should, in general, follow the guidance presented in the Interagency Workgroup on Air Quality Modeling (IWAQM) Phase 2 report (EPA - 454/R98-019) and the EPA Regional Haze Regulations and Guidelines for BART Determinations (70 FR 39103).

Appropriate CALPUFF control file inputs are in Table 4. Note should be taken of the basis for several of the recommended CALPUFF inputs.

- Building downwash effects need not be included. Because of the transport distances involved and the fact that most sources have tall stacks, building downwash is unlikely to have a significant effect on model-predicted concentrations
- Puff splitting is not required. The additional computation time necessary for puff splitting is not justified for purposes of BART analyses.
- Hourly ozone files should be used to define background ozone concentration. Data are available from the following sites within the model domain.

Rocky Mountain NP, CO  
Craters of the Moon NP, ID  
AIRS - Highland UT  
Mountain Thunder, WY  
Yellowstone NP, WY  
Centennial, WY  
Pinedale, WY

The background ozone concentration shown in Table 4 is used only when hourly data are missing.

- A constant background ammonia concentration of 2.0 ppb is specified. This value is based upon monitoring data from nearby states and IWAQM guidance. Experience suggests that 2.0 ppb is conservative in that it is unlikely to significantly limit nitrate formation in the model computations.
- MESOPUFF II chemical transformation rates should be used.
- The species to be modeled should be the seven identified in CALPUFF:  $\text{SO}_2$ ,  $\text{SO}_4$ ,  $\text{NO}_x$ ,  $\text{HNO}_3$ ,  $\text{NO}_3$ ,  $\text{PM}_{2.5}$ , and  $\text{PM}_{10-2.5}$ . If ammonia ( $\text{NH}_3$ ) is emitted it should be added to the species list. In most cases, all pollutants modeled will also be emitted, except for  $\text{HNO}_3$  and  $\text{NO}_3$ .

Concentration calculations should be made for receptors covering the areas of the Class I areas being addressed. Receptors in each Class I area will be those designated by the Federal Land Managers and available from the National Park Service website.

Table 4. CALPUFF Control File Inputs

Variable	Description	Value
	Input Group 1	
METRUN	Control parameter for running all periods in met file	1
IBYR	Starting year	2001 2002 2003
XBTZ	Base time zone	7
NSPEC	Number of chemical species modeled	7 (or 8)
NSE	Number of species emitted	5 (or 6)
METFM	Meteorological data format	1
	Input Group 2	
MGAUSS	Vertical distribution in near field	1
MCTADJ	Terrain adjustment method	3
MCTS	Subgrid scale complex terrain	0
MSLUG	Elongated puffs	0
MTRANS	Transitional plume rise	1
MTIP	Stack tip downwash	1
MSHEAR	Vertical wind shear	0
MSPLIT	Puff splitting allowed?	0
MCHEM	Chemical mechanism	1
MAQCHEM	Aqueous phase transformation	0
MWET	Wet removal	1
MDRY	Dry deposition	1
MDISP	Dispersion Coefficients	3
MROUGH	Adjust sigma for roughness	0
MPARTL	Partial plume penetration of inversions	1
MPDF	PDF for convective conditions	0
	Input Group 4	
PMAP	Map projection	LCC
DGRIDKM	Grid spacing	4

Table 4. CALPUFF Control File Inputs (continued)

ZFACE	Cell face heights (m)	0 20 40 100 140 320 580 1020 1480 2220 3500
		Input Group 6
NHILL	Number of terrain features	0
		Input Group 7
Dry Gas Depo	Chemical parameters for dry gas deposition	Defaults
		Input Group 8
Dry Part. Depo	Size parameters for dry particle deposition SO <sub>4</sub> , NO <sub>3</sub> , PM25 PM10	Defaults 6.5, 1.0
		Input Group 11
MOZ	Ozone Input option	1
BCK03	Background ozone – all months (ppb)	44.0
BCKNH3	Background ammonia – all months (ppb)	2.0
		Input Group 12
XMAXZI	Maximum mixing height (m)	3500
XMINZI	Minimum mixing height (m)	50

## 6.0 POST PROCESSING

Visibility impacts are calculated from the CALPUFF concentration results using CALPOST. CALPOST version 5.51, level 030709 should be used; the output from CALPOST will provide the highest deciview impact on each day from all receptors within each Class I area modeled.

For some CALPUFF applications such as deposition calculations, the POSTUTIL program is used prior to CALPOST. POSTUTIL is also used to repartition total nitrate by accounting for ammonia limiting. The ammonia limiting calculation in POSTUTIL should not be applied for Wyoming BART modeling. If you believe that ammonia limiting is appropriate for a specific BART analysis, justification should be discussed with the Division prior to its used.

Visibility calculations by CALPOST for BART purposes use Method 6. This method requires input of monthly relative humidity factors, f(RH), for each Class I area. The EPA guidance document provides appropriate data for each area. Table 5 lists monthly f(RH) factors to use for the Wyoming, Colorado, and South Dakota areas to be addressed in BART modeling. The factors shown in Table 5 include averages for the adjacent Class I areas, and are within 0.2 units of the Guideline table values for the individual Class I areas.

Natural background conditions as a reference for determination of the delta-dv change due to a source should be representative of the 20% best natural visibility days. EPA BART guidance provides the 20% best days deciview values for each Class I area on an annual basis, but does not provide species concentration data for the 20% best background conditions. These concentrations are needed for input to CALPOST.

Annual species concentrations corresponding to the 20% best days were calculated for each Class I area to be addressed, by scaling back the annual average concentrations given in Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule (Table 2-1). A separate scaling factor was derived for each Class I area such that, when multiplied by the Guidance table annual concentrations, the 20% best days deciview value for that area would be calculated. The scaled aerosol concentrations were averaged for the Bridger and Fitzpatrick WAs, and for Wind Cave and Badlands NPs, because of their geographical proximity and similar annual background visibility. The 20% best days aerosol concentrations to be used for each month for Wyoming BART evaluations are listed in Table 6.

Table 7 is a list of inputs for CALPOST. These inputs should be used for all BART visibility calculations. Output from CALPOST should be configured to provide a ranked list of the highest delta-deciview values in each Class I area. The 98<sup>th</sup> percentile delta-deciview value and the number of values exceeding 0.5 can then be determined directly from the CALPOST output.

Table 5. Monthly f(RH) Factors for Class I Areas

Month	Wind Cave NP Badlands NP	Bridger WA Fitzpatrick WA	Mt. Zirkel WA
January	2.65	2.50	2.20
February	2.65	2.30	2.20
March	2.65	2.30	2.00
April	2.55	2.10	2.10
May	2.70	2.10	2.20
June	2.60	1.80	1.80
July	2.30	1.50	1.70
August	2.30	1.50	1.80
September	2.20	1.80	2.00
October	2.25	2.00	1.90
November	2.75	2.50	2.10
December	2.65	2.40	2.10

Table 6. Natural Background Concentrations of Aerosol Components for 20% Best Days for BART Analyses ( $\mu\text{g}/\text{m}^3$ )

Aerosol Component	Wind Cave NP Badlands NP	Fitzpatrick WA Bridger WA	Mt. Zirkel WA
Ammonium Sulfate	.047	.045	.046
Ammonium Nitrate	.040	.038	.038
Organic Carbon	.186	.178	.179
Elemental Carbon	.008	.008	.008
Soil	.198	.189	.190
Coarse Mass	1.191	1.136	1.141

Table 7. CALPOST Control File Inputs

Variable	Description	Value
	Input Group 1	
ASPEC	Species to Process	VISIB
ILAYER	Layer/deposition code	1
A,B	Scaling factors	0,0
LBACK	Add background concentrations?	F
BTZONE	Base time zone	7
LVSO4	Species to be included in extinction	T
LVNO3		T
LVOC		F
LVPMC		T
LVPMF		T
LVEC		F
LVBK	Include background?	T
SPECPMC	Species name for particulates	PM10
SPECPMF		PM25
EPMC	Extinction efficiencies	0.6
EPMF		1.0
EPMCBK		0.6
EESO4		3.0
EENO3		3.0
EBOC		4.0
EESOIL		1.0
EEEC		10.0
MVISBK	Visibility calculation method	6
RHFAC	Monthly RH adjustment factors	Table 5
BKSO4	Background concentrations	Table 6
BKNO3		Table 6
BKPMC		Table 6
BK OC		Table 6
BKSOL		Table 6
BKEC		Table 6
BEXTRAY	Extinction due to Rayleigh scattering	10.0

## 7.0 REPORTING

A report on the BART visibility analysis should be submitted that clearly compares impacts for post-control emissions to those for baseline emissions. Data for baseline and BART scenarios should include both the 98<sup>th</sup> percentile values and the number of days with delta-deciview values exceeding 0.5. Results should be given for each model year.

Table 8 is an example of a recommended format for presentation of model input and model results. The example is for baseline conditions; similar tables should be provided for each control scenario (SO<sub>2</sub>, NO<sub>x</sub>, and PM10) and for the combination of all BART controls. Your report tables need not follow the exact format shown in Table 8; but the same information should be provided in a concise and clear form. If additional scenarios were modeled or you wish to present supplemental information, they should be provided in an appendix or separate from the specified final results.

Table 8. Example Format for Presentation of Model Input and Results

## Baseline Visibility Modeling Results

*Final Report*

# BART Analysis for Jim Bridger Unit 2



Prepared For:

**PaciFiCorp**

1407 West North Temple  
Salt Lake City, Utah 84116

December 2007

Prepared By:

**CH2MHILL**

215 South State Street, Suite 1000  
Salt Lake City, Utah 84111

---

*Final Report*

# BART Analysis for Jim Bridger Unit 2

Submitted to  
**PacifiCorp**

December 2007

---

**CH2MHILL**

# **Executive Summary**

---

## **Background**

In response to the Regional Haze Rule and Best Available Retrofit Technology (BART) regulations and guidelines, CH2M HILL was requested to perform a BART analysis for PacifiCorp's Jim Bridger Unit 2 (hereafter referred to as Jim Bridger 2). A Best Available Retrofit Technology analysis has been conducted for the following criteria pollutants: oxides of nitrogen oxide ( $\text{NO}_x$ ), sulfur dioxide ( $\text{SO}_2$ ), and particulate matter less than 10 micrometers in aerodynamic diameter ( $\text{PM}_{10}$ ). The Jim Bridger Station consists of four 530-megawatt (MW) units with a total generating capacity of 2,120 MW. Because the total generating capacity of the Jim Bridger Station exceeds 750 MW, presumptive BART limits apply to Jim Bridger 2, based on the United States Environmental Protection Agency's (EPA) guidelines. BART emissions limits must be achieved within 5 years after the State Implementation Plan (SIP) is approved by the EPA. A compliance date of 2014 was assumed for this analysis.

In completing the BART analysis, technology alternatives were investigated and potential reductions in  $\text{NO}_x$ ,  $\text{SO}_2$ , and  $\text{PM}_{10}$  emissions rates were identified. The following technology alternatives were investigated, listed below by pollutant:

- $\text{NO}_x$  emission controls:
  - Low- $\text{NO}_x$  burners (LNBs) with over-fire air (OFA)
  - LNBs with rotating opposed fire air (ROFA)
  - LNBs with selective non-catalytic reduction (SNCR) system
  - LNBs with selective catalytic reduction (SCR) system
- $\text{SO}_2$  emission controls:
  - Optimize current operation of existing wet sodium flue gas desulfurization (FGD) system
  - Upgrade wet sodium FGD system to achieve an  $\text{SO}_2$  emission rate of 0.10 pound per million British thermal unit (pounds [lbs] per MMBtu)
  - New dry FGD system
- $\text{PM}_{10}$  emission controls:
  - Sulfur trioxide ( $\text{SO}_3$ ) injection flue gas conditioning system on existing electrostatic precipitator (ESP)
  - Polishing fabric filter

## BART Engineering Analysis

The specific steps in a BART engineering analysis are identified in the Code of Federal Regulations (CFR) at 40 CFR 51 Appendix Y, Section IV. The evaluation must include:

- The identification of available, technically feasible, retrofit control options
- Consideration of any pollution control equipment in use at the source (which affects the availability of options and their impacts)
- The costs of compliance with the control options
- The remaining useful life of the facility
- The energy and non-air quality environmental impacts of compliance
- The degree of visibility improvement that may reasonably be anticipated from the use of BART

The following steps are incorporated into the BART analysis:

- Step 1 – Identify All Available Retrofit Control Technologies
- Step 2 – Eliminate Technically Infeasible Options
  - The identification of available, technically feasible, retrofit control options
  - Consideration of any pollution control equipment in use at the source (which affects the applicability of options and their impacts)
- Step 3 – Evaluate Control Effectiveness of Remaining Control Technologies
- Step 4 – Evaluate Impacts and Document the Results
  - The costs of compliance with the control options
  - The remaining useful life of the facility
  - The energy and non-air quality environmental impacts of compliance
- Step 5 – Evaluate Visibility Impacts
  - The degree of visibility improvement that may reasonably be anticipated from the use of BART

Separate analyses have been conducted for NO<sub>x</sub>, SO<sub>2</sub>, and PM<sub>10</sub> emissions. All costs included in the BART analyses are in 2006 dollars, and costs have not been escalated to the assumed 2014 BART implementation date.

## Coal Characteristics

The main source of coal burned at Jim Bridger 2 will be the Bridger Underground Mine. Secondary sources are the Bridger Surface Mine, the Bridger Highwall Mine, the Black Butte Mine, and the Leucite Hills Mine. These coals are ranked as sub-bituminous, but are closer in

characteristics to bituminous coal in many of the parameters influencing NO<sub>x</sub> formation. These coals have higher nitrogen content than coals from the Powder River Basin (PRB), which represent the bulk of sub-bituminous coal use in the United States. This BART analysis has considered the higher nitrogen content and different combustion characteristics of PRB coals, as compared with those coals used at Jim Bridger 2, and has evaluated the effect of these qualities on NO<sub>x</sub> formation and achievable emission rates.

## Recommendations

CH2M HILL recommends installing the following control devices, which include LNBs with OFA, dry FGD system, and the existing ESP. This combination of control devices is identified as Scenario 1 throughout this report.

### NO<sub>x</sub> Emission Control

The BART presumptive NO<sub>x</sub> limit assigned by EPA for tangentially fired boilers burning sub-bituminous coal is 0.15 lb per MMBtu. However, as documented in this analysis, the characteristics of the Jim Bridger 2 coals are more closely aligned with bituminous coals, with a presumptive BART NO<sub>x</sub> limit of 0.28 lb per MMBtu.

CH2M HILL recommends the existing LNBs with OFA (LNB with an OFA) as BART for Jim Bridger 2, based on the projected significant reduction in NO<sub>x</sub> emissions, reasonable control costs, and the advantages of no additional power requirements or non-air quality environmental impacts. NO<sub>x</sub> reductions have been realized at Jim Bridger 2. CH2M HILL recommends that the unit be permitted at a rate of 0.26 lb per MMBtu.

### SO<sub>2</sub> Emission Control

CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 2, based on the significant reduction in SO<sub>2</sub> emissions, reasonable control costs, and the advantages of minimal additional power requirements and minimal non-air quality environmental impacts. This upgrade approach will meet the BART presumptive SO<sub>2</sub> limit of 0.15 lb per MMBtu.

### PM<sub>10</sub> Emission Control

CH2M HILL recommends finalizing the permitting of the flue gas conditioning (FGC) system to enhance the performance of the existing ESP as BART for Jim Bridger 2, based on the significant reduction in PM<sub>10</sub> emissions, reasonable control costs, and the advantages of minimal additional power requirements and no non-air quality environmental impacts.

### Control Scenario 1

These BART selections, which include maintaining the existing low NO<sub>x</sub> burners with OFA, upgrading the existing FGD system, and operating the existing electrostatic precipitator with an SO<sub>3</sub> FGC system, are identified as Scenario 1 throughout this report.

## BART Modeling Analysis

CH2M HILL used the CALPUFF modeling system (Gaussian puff dispersion model) to assess the visibility impacts of emissions from Jim Bridger 2 at Class I areas. The Class I areas potentially affected are located more than 50 kilometers (km), but less than 300 km, from the Jim Bridger Plant.

The Class I areas include the following wilderness areas (WAs):

- Bridger WA
- Fitzpatrick WA
- Mt. Zirkel WA

Because Jim Bridger 2 will simultaneously control NO<sub>x</sub>, SO<sub>2</sub>, and PM<sub>10</sub> emissions, four post-control atmospheric dispersion modeling scenarios were developed to cover the range of effectiveness for combining the individual NO<sub>x</sub>, SO<sub>2</sub> and PM<sub>10</sub> control technologies under evaluation. These modeling scenarios, and the controls assumed, are as follows:

- Scenario 1: Existing LNB with OFA, upgraded wet FGD system, and FGC for enhanced ESP performance. As indicated previously, this scenario represents CH2M HILL's preliminary BART recommendation.
- Scenario 2: Existing LNB with OFA, upgraded wet FGD system, and new polishing fabric filter.
- Scenario 3: Existing LNB with OFA and SCR, upgraded wet FGD system, and FGC for enhanced ESP performance.
- Scenario 4: Existing LNB with OFA and SCR, upgraded wet FGD system, and new polishing fabric filter.

Visibility improvements for all emission control scenarios were analyzed, and the results were compared utilizing a least-cost envelope, as outlined in the draft EPA 1990 *New Source Review Workshop Manual* (NSR Manual).

## Least-cost Envelope Analysis

EPA has adopted the least-cost envelope analysis methodology as an accepted methodology for selecting the most reasonable, cost-effective controls. Incremental cost-effectiveness comparisons focus on annualized cost and emission reduction differences between dominant alternatives. The dominant set of control alternatives is determined by generating what is called the envelope of least-cost alternatives. This is a graphical plot of total annualized costs for a total emissions reductions for all control alternatives identified in the BART analysis.

To evaluate the impacts of the modeled control scenarios on the three Class I areas, the total annualized cost, cost per deciview (dV) reduction, and cost per reduction in number of days above 0.5 dV were analyzed. This report provides a comparison of the average incremental costs between relevant scenarios for the three Class I areas; the total annualized cost versus number of

days above 0.5 dV, and the total annualized cost versus 98<sup>th</sup> percentile delta-deciview ( $\Delta$ dV) reduction.

Results of the least-cost envelope analysis validate the selection of Scenario 1, based on incremental cost and visibility improvements. Scenario 2 (LNB with OFA, upgraded wet FGD, and polishing fabric filter) is eliminated, because it is to the left of the curve formed by the dominant control alternative scenario, which indicates a scenario with lower improvement and/or higher costs. Scenario 3 (LNB with OFA and SCR, upgraded wet FGD, and FGC for enhanced ESP performance) is not selected due to very high incremental costs, based on cost per day of improvement and cost per dV reduction. While Scenario 4 (LNB with OFA and SCR, upgraded wet FGD, and polishing fabric filter) provides some potential visibility advantage over Scenario 1, the projected improvement is less than half a dV, and the projected costs are excessive. Therefore, Scenario 1 represents BART for Jim Bridger 2.

## Just-Noticeable Differences in Atmospheric Haze

Studies have been conducted that demonstrate only dV differences of approximately 1.5 to 2.0 dV or more are perceptible by the human eye. Deciview changes of less than 1.5 cannot be distinguished by the average person. Therefore, the modeling analysis results indicate that only minimal, if any, observable visibility improvements at the Class I areas studied would be expected under any of the control scenarios. Thus, the results indicate that only minimal discernable visibility improvements may result, even though PacifiCorp will be spending many millions of dollars at this single unit, and over a billion dollars when considering its entire fleet of coal-fired power plants.

# Contents

---

1.0	Introduction .....	1-1
2.0	Present Unit Operation .....	2-1
3.0	BART Engineering Analysis .....	3-1
3.1	Applicability .....	3-1
3.2	BART Process .....	3-1
3.2.1	BART NO <sub>x</sub> Analysis .....	3-2
3.2.2	BART SO <sub>2</sub> Analysis .....	3-14
3.2.3	BART PM <sub>10</sub> Analysis .....	3-16
4.0	BART Modeling Analysis .....	4-1
4.1	Model Selection .....	4-1
4.2	CALMET Methodology .....	4-1
4.2.1	Dimensions of the Modeling Domain .....	4-1
4.2.2	CALMET Input Data .....	4-3
4.2.3	Validation of CALMET Wind Field .....	4-6
4.3	CALPUFF Modeling Approach .....	4-6
4.3.1	Background Ozone and Ammonia .....	4-6
4.3.2	Stack Parameters .....	4-6
4.3.3	Emission Rates .....	4-7
4.3.4	Post-control Scenarios .....	4-7
4.3.5	Modeling Process .....	4-8
4.3.6	Receptor Grids .....	4-8
4.4	CALPOST .....	4-10
4.5	Presentation of Modeling Results .....	4-11
4.5.1	Visibility Changes for Baseline vs. Preferred Scenario .....	4-11
5.0	Preliminary Assessment and Recommendations .....	5-1
5.1	Least-cost Envelope Analysis .....	5-1
5.1.1	Analysis Methodology .....	5-1
5.1.2	Analysis Results .....	5-8
5.2	Recommendations .....	5-8
5.2.1	NO <sub>x</sub> Emission Control .....	5-8
5.2.2	SO <sub>2</sub> Emission Control .....	5-8
5.2.3	PM <sub>10</sub> Emission Control .....	5-8
5.3	Just-Noticeable Differences in Atmospheric Haze .....	5-9
6.0	References .....	6-1

**Tables**

- 2-1 Unit Operation and Study Assumptions
- 2-2 Coal Sources and Characteristics
- 3-1 Coal Characteristics Comparison
- 3-2 NO<sub>x</sub> Control Technology Projected Emission Rates
- 3-3 NO<sub>x</sub> Control Cost Comparison
- 3-4 SO<sub>2</sub> Control Technology Emission Rates
- 3-5 SO<sub>2</sub> Control Cost Comparison (Incremental to Existing Wet FGD System)
- 3-6 PM<sub>10</sub> Control Technology Emission Rates
- 3-7 PM<sub>10</sub> Control Cost Comparison
- 4-1 User-Specified CALMET Options
- 4-2 BART Model Input Data
- 4-3 Average Natural Levels of Aerosol Components
- 4-4 Costs and Visibility Modeling Results for Baseline vs. Post-control Scenarios at Class I Areas
- 5-1 Control Scenario Results for the Bridger Class I Wilderness Area
- 5-2 Control Scenario Results for the Fitzpatrick Class I Wilderness Area
- 5-3 Control Scenario Results for the Mt. Zirkel Class I Wilderness Area
- 5-4 Bridger Class I Wilderness Area Incremental Analysis Data
- 5-5 Fitzpatrick Class I Wilderness Area Incremental Analysis Data
- 5-6 Mt. Zirkel Class I Wilderness Area Incremental Analysis Data

**Figures**

- 3-1 Illustration of the Effect of Agglomeration on the Speed of Coal Combustion
- 3-2 Plot of Typical Nitrogen Content of Various Coals and Applicable Presumptive BART NO<sub>x</sub> Limits
- 3-3 Plot of Typical Oxygen Content of Various Coals and Applicable Presumptive BART NO<sub>x</sub> Limits
- 3-4 First Year Control Cost for NO<sub>x</sub> Air Pollution Control Options
- 3-5 First Year Control Cost for PM Air Pollution Control Options
- 4-1 Jim Bridger Source-specific Class I Areas to be Addressed
- 4-2 Surface and Upper Air Station Used in the Jim Bridger BART Analysis
- 5-1 Least-cost Envelope Bridger Class I Wilderness Area Days Reduction
- 5-2 Least-cost Envelope Bridger Wilderness Area Class I Area 98<sup>th</sup> Percentile Reduction
- 5-3 Least-cost Envelope Fitzpatrick Class I Wilderness Area Days Reduction
- 5-4 Least-cost Envelope Fitzpatrick Class I Wilderness Area 98<sup>th</sup> Percentile Reduction
- 5-5 Least-cost Envelope Mt. Zirkel Class I Wilderness Area Days Reduction
- 5-6 Least-cost Envelope Mt. Zirkel Class I Wilderness Area 98<sup>th</sup> Percentile Reduction

**Appendices**

- A Economic Analysis
- B 2006 Wyoming BART Protocol

## **Acronyms and Abbreviations**

---

°C	Degrees Celsius
°F	Degrees Fahrenheit
ASOS	Automated Surface Observing System
BACT	Best Available Control Technology
BART	Best Available Retrofit Technology
CALMET	Meteorological Data Preprocessing Program for CALPUFF
CALPOST	Post-processing Program for Calculating Visibility Impacts
CALPUFF	Gaussian Puff Dispersion Model
CFR	Code of Federal Regulations
CO	Carbon Monoxide
COHPAC	Compact Hybrid Particulate Collector
ΔV	Delta Deciview, Change in Deciview
DCS	Distributed Control System
dV	Deciview
EIA	Energy Information Administration
EPA	United States Environmental Protection Agency
ESP	Electrostatic Precipitator
f(RH)	Relative Humidity Factors
FGC	Flue Gas Conditioning
FGD	Flue Gas Desulfurization
Fuel NO <sub>x</sub>	Oxidation of Fuel-bound Nitrogen
hp	Horsepower
ID	Internal Diameter
km	Kilometer
kW	Kilowatts
kW-Hr	Kilowatt-hour
LAER	Lowest Achievable Emission Rate
lb	Pound(s)
LNB	Low-NO <sub>x</sub> Burner
LOI	Loss on Ignition
MM5	Mesoscale Meteorological Model, Version 5
MMBtu	Million British Thermal Units

ACRONYMS AND ABBREVIATIONS (CONTINUED)

MW	Megawatt(s)
N <sub>2</sub>	Nitrogen
NO	Nitric Oxide
NO <sub>x</sub>	Nitrogen Oxide
NP	National Park(s)
NSR Manual	<i>New Service Review Workshop Manual</i> (EPA, 1990)
NWS	National Weather Service
OFA	Over-fire Air
PM	Particulate Matter
PM <sub>10</sub>	Particulate Matter less than 10 Micrometers in Aerodynamic Diameter
PM <sub>2.5</sub>	Particulate Matter less than 2.5 Micrometers in Aerodynamic Diameter
PRB	Powder River Basin
ROFA	Rotating Opposed Fire Air
S&L Study	Multi-pollutant Control Report dated October 2002
S&L	Sargent & Lundy
SCR	Selective Catalytic Reduction
SIP	State Implementation Plan
SNCR	Selective Non-catalytic Reduction System
SO <sub>2</sub>	Sulfur Dioxide
SO <sub>3</sub>	Sulfur Trioxide
TRC	TRC Companies, Inc.
USGS	U.S. Geological Survey
WA	Wilderness Area
WDEQ	Wyoming Department of Environmental Quality
WDEQ-AQD	Wyoming Department of Environmental Quality – Air Quality Division

## 1.0 Introduction

---

Best Available Retrofit Technology (BART) guidelines were established as a result of United States Environmental Protection Agency (EPA) regulations intended to reduce the occurrence of regional haze in national parks (NPs) and other Class I protected air quality areas in the United States (40 CFR Part 51). These guidelines provide guidance for states when determining which facilities must install additional controls, and the type of controls that must be used. Facilities eligible for BART installation were built between 1962 and 1977, and have the potential to emit more than 250 tons per year of visibility-impairing pollutants.

The Wyoming Department of Environmental Quality (WDEQ) BART regulations state that each source subject to BART must submit a BART application for a construction permit by December 15, 2006. PacifiCorp received an extension from the WDEQ to submit the BART report for Jim Bridger Unit 2 (hereafter referred to as Jim Bridger 2) by January 12, 2007. The BART report that was submitted to the WDEQ in January 2007 included a BART analysis, and a proposal and justification for BART at the source. This revised report, submitted in October 2007, incorporates editorial revisions and new model runs since the January 2007 version.

The State of Wyoming has identified those eligible in-state facilities that are required to reduce emissions under BART, and will set BART emissions limits for those facilities. This information will be included in the State of Wyoming State Implementation Plan (SIP), which the State has estimated will be formally submitted to the EPA by early 2008. The EPA BART guidelines also state that the BART emission limits must be fully implemented within 5 years of EPA's approval of the SIP.

Five elements related to BART address the issue of emissions for the identified facilities:

- Any existing pollution control technology in use at the source
- The cost of the controls
- The remaining useful life of the source
- The energy and non-air quality environmental impacts of compliance
- The degree of improvement in visibility that may reasonably be anticipated from the use of such technology

This report documents the BART analysis that was performed on Jim Bridger 2 by CH2M HILL for PacifiCorp. The analysis was performed for the pollutants nitrogen oxide ( $\text{NO}_x$ ), sulfur dioxide ( $\text{SO}_2$ ), and particulate matter less than 10 micrometers in aerodynamic diameter ( $\text{PM}_{10}$ ), because they are the primary criteria pollutants that affect visibility.

Section 2 of this report provides a description of the present unit operation, including a discussion of coal sources and characteristics. The BART Engineering Analysis is provided in Section 3, by pollutant type. Section 4 provides the methodology and results of the BART Modeling Analysis, followed by recommendations in Section 5 and references in Section 6. Appendices provide more detail on the economic analysis and the 2006 Wyoming BART Protocol.

## 2.0 Present Unit Operation

---

The Jim Bridger Station consists of four units with a total generating capacity of 2,120 megawatts (MW). Jim Bridger 2 is a nominal 530-net-MW unit located approximately 35 miles northeast of Rock Springs, Wyoming. Unit 2 is equipped with a tangentially fired pulverized coal boiler. Low-NO<sub>x</sub> burner (LNB) TFS 2000 LNBs with over-fire air (OFA) were installed in 2005. The unit was constructed with a Flakt wire frame electrostatic precipitator (ESP). The unit contains a Babcock & Wilcox wet sodium flue gas desulfurization (FGD) system with three absorber towers installed in 1986. An Emerson Ovation distributed control system (DCS) was installed in 2005.

Jim Bridger 2 was placed in service in 1975. Its current economic depreciation life is through 2040; however, this analysis is based on a 20-year life for BART control technologies. Assuming a BART implementation date of 2014, this will result in an approximate remaining useful life for Jim Bridger 2 of 20 years from the installation date of any new or modified BART-related equipment. This report does not attempt to quantify any additional life extension costs needed to allow the unit and these control devices at Jim Bridger 2 to operate until 2040.

Table 2-1 lists additional unit information and study assumptions for this analysis.

The BART presumptive NO<sub>x</sub> limit for tangentially fired boilers burning sub-bituminous coal is 0.15 pound per British thermal unit (lb per MMBtu) and the BART presumptive NO<sub>x</sub> limit for burning bituminous coal is 0.28 lb per MMBtu. The main sources of coal burned at Jim Bridger 2 are the Bridger Mine, and secondarily, the Black Butte Mine and Leucite Hills Mine. These coals are ranked as sub-bituminous, but are closer in characteristics to bituminous coal in many of the parameters influencing NO<sub>x</sub> formation. These coals have higher nitrogen content than coals from the Powder River Basin (PRB), which represent the bulk of sub-bituminous coal used in the United States. This BART analysis has considered the higher nitrogen content and different combustion characteristics of PRB coals, as compared with those coals used at Jim Bridger 2, and has evaluated the effect of these qualities on NO<sub>x</sub> formation and achievable emission rates. Coal sources and characteristics are summarized in Table 2-2. The primary source of coal will be the Bridger Underground Mine; and data on coal from this source were used in the modeling analysis. For the coal analysis that is presented in Section 3.2.1, the data from all the coal sources were used.

**TABLE 2-1**  
**Unit Operation and Study Assumptions**  
*Jim Bridger 2*

<b>General Plant Data</b>	
Site Elevation (feet above mean sea level)	6669
Stack Height (feet)	500
Stack Exit Internal Diameter (feet) /Exit Area (square feet)	24 / 452.4
Stack Exit Temperature °F (degrees Fahrenheit)	140
Stack Exit Velocity (feet per second)	84.0
Stack Flow (actual cubic feet per minute)	2,281,182
Latitude (degree: minute : second)	41:44:16.42 north
Longitude (degree: minute : second)	108:47:10.59 west
Annual Unit Capacity Factor (percentage)	90
Net Unit Output (megawatts)	530
Net Unit Heat Rate (British thermal unit [Btu]/kilowatt-hour [kW-Hr])(100% load)	10,400 (as measured by fuel throughput)
Boiler Heat Input (million British thermal units [MMBtu] per hour)(100% load)	6,000 (as measured by continuous emission monitoring)
Type of Boiler	Tangentially fired
Boiler Fuel	Coal
Coal Sources	Bridger Mine, Black Butte Mine, Leucite Hills Mine
Coal Heating Value (Btu per pound [lb]) <sup>a</sup>	9,660
Coal Sulfur Content (percentage by weight [wt. %]) <sup>a</sup>	0.58
Coal Ash Content (wt. %) <sup>a</sup>	10.3
Coal Moisture Content (wt. %) <sup>a</sup>	19.3
Coal Nitrogen Content (wt. %) <sup>a</sup>	0.98
Current Nitrogen Oxide (NO <sub>x</sub> ) Controls	Low NO <sub>x</sub> burners
NO <sub>x</sub> Emission Rate (lb/MMBtu)	0.24
Current Sulfur Oxide (SO <sub>2</sub> ) Controls	Sodium based wet scrubber
SO <sub>2</sub> Emission Rate (lb/MMBtu)	0.267
Current PM <sub>10</sub> Controls	Electrostatic Precipitator
PM <sub>10</sub> Emission Rate (lb/MMBtu) <sup>b</sup>	0.074

**NOTES:**<sup>a</sup> Coal characteristics based on Bridger Underground Mine (primary coal source)<sup>b</sup> Based on maximum historic emission rate from 1999 – 2001, before installation of the sulfur trioxide (SO<sub>3</sub>) injection system.

**TABLE 2-2**  
**Coal Sources and Characteristics**  
*Jim Bridger 2*

	Mines	Ultimate Analysis (% dry basis)										
		Moist (%)	Ash (%)	Volatile Matter (%)	Fixed Carbon (%)	Btu/lb	Sulfur (%)	Hydrogen	Carbon	Sulfur	Nitrogen	Oxygen
<b>Brider Mine Underground</b>	19.3	10.3	32.2	38.3	9660	0.58	13712	4.66	69.2	0.72	1.22	11.8
Maximum												12.4
Minimum												
<b>Brider Mine Surface</b>	19.1	10.6	32.3	38.0	9390	0.57	13340	4.38	37.4	0.71	1.26	13.2
Maximum	20.5	12.5	35.5	41.9	9800	0.72	13500	4.69	4.0	0.90	1.43	14.8
Minimum	17.5	9.0	31.0	36.0	9000	0.49	13100	4.00	64.3	0.60	1.14	11.7
<b>Brider Mine Highwall</b>	18.0	9.5	33.0	39.5	9700	0.58	13500					11.2
Maximum												
Minimum												
<b>Black Butte Mine</b>	20.0	9.2	33.3	35.6	9450	0.45	13330	4.43	68.7	0.56	1.47	13.4
Maximum	21.1	10.8	35.4	41.9	10275	0.62	13500	4.66	70.5	0.78	1.69	14.8
Minimum	18.0	7.6	29.9	36.8	9180	0.33	13140	4.21	66.1	0.41	1.25	11.6
<b>Leucite Hills Mine (through 2009)</b>	19.4	11.5	30.7	38.3	9080	0.64	13140	4.20	66.0	0.81	1.48	13.2
Maximum	23.0	15.0	33.0	43.0	10250	0.90	13800	4.70	70.0	1.20	1.64	17.1
Minimum	17.0	8.0	28.3	33.6	8900	0.40	12300	3.70	61.0	0.50	1.32	10.5
												10.0

## **3.0 BART Engineering Analysis**

---

This section presents the required BART engineering analysis.

### **3.1 Applicability**

In compliance with regional haze requirements, the State of Wyoming must prepare and submit visibility SIPs to the EPA for Class I areas. The State has estimated that the formal submittal of the SIPs will occur by early 2008. The first phase of the regional haze program is the implementation of BART emission controls on all BART eligible units, within 5 years after EPA approval of the SIP.

### **3.2 BART Process**

The specific steps in a BART engineering analysis are identified in the Code of Federal Regulations (CFR) at 40 CFR 51 Appendix Y, Section IV. The evaluation must include:

- The identification of available, technically feasible, retrofit control options
- Consideration of any pollution control equipment in use at the source (which affects the availability of options and their impacts)
- The costs of compliance with the control options
- The remaining useful life of the facility
- The energy and non-air quality environmental impacts of compliance
- The degree of visibility improvement that may reasonably be anticipated from the use of BART.

The following steps are incorporated into the BART analysis:

- Step 1 – Identify All Available Retrofit Control Technologies
- Step 2 – Eliminate Technically Infeasible Options
  - The identification of available, technically feasible, retrofit control options
  - Consideration of any pollution control equipment in use at the source (which affects the applicability of options and their impacts)
- Step 3 – Evaluate Control Effectiveness of Remaining Control Technologies
- Step 4 – Evaluate Impacts and Document the Results
  - The costs of compliance with the control options
  - The remaining useful life of the facility
  - The energy and non-air quality environmental impacts of compliance

- Step 5 – Evaluate Visibility Impacts
  - The degree of visibility improvement that may reasonably be anticipated from the use of BART

In order to minimize costs in the BART analysis, consideration was made of any pollution control equipment in use at the source, the costs of compliance associated with the control options, and the energy and non-air quality environmental impacts of compliance using these existing control devices. In some cases, enhancing the performance of the existing control equipment was considered. Other scenarios with new control equipment were also developed.

Separate analyses have been conducted for NO<sub>x</sub>, SO<sub>2</sub>, and PM<sub>10</sub> emissions. All costs included in the BART analyses are in 2006 dollars, and costs have not been escalated to the assumed 2014 BART implementation date.

### 3.2.1 BART NO<sub>x</sub> Analysis

Nitrogen oxide formation in coal-fired boilers is a complex process that is dependent on a number of variables, including operating conditions, equipment design, and coal characteristics.

#### Formation of NO<sub>x</sub>

During coal combustion, NO<sub>x</sub> is formed in three different ways. The dominant source of NO<sub>x</sub> formation is the oxidation of fuel-bound nitrogen (fuel NO<sub>x</sub>). During combustion, part of the fuel NO<sub>x</sub> is released from the coal with the volatile matter, and part of it is retained in the solid portion (char). The nitrogen chemically bound in the coal is partially oxidized to nitrogen oxide and nitrogen dioxide) and partially reduced to molecular nitrogen (N<sub>2</sub>). A smaller part of NO<sub>x</sub> formation is due to high temperature fixation of atmospheric nitrogen in the combustion air (thermal NO<sub>x</sub>). A very small amount of NO<sub>x</sub> is called “prompt” NO<sub>x</sub>. Prompt NO<sub>x</sub> results from an interaction of hydrocarbon radicals, nitrogen, and oxygen.

In a conventional pulverized coal burner, air is introduced with turbulence to promote good mixing of fuel and air, which provides stable combustion. However, not all of the oxygen in the air is used for combustion. Some of the oxygen combines with the fuel nitrogen to form NO<sub>x</sub>.

Coal characteristics directly and significantly affect NO<sub>x</sub> emissions from coal combustion. Coal ranking is a means of classifying coals according to their degree of metamorphism in the natural series, from lignite to sub-bituminous to bituminous and on to anthracite. Lower-rank coals, such as the sub-bituminous coals from the PRB, produce lower NO<sub>x</sub> emissions than higher rank bituminous coals, due to their higher reactivity and lower nitrogen content. The fixed carbon to volatile matter ratio (fuel ratio), coal oxygen content, and rank are good relative indices of the reactivity of a coal. Lower-rank coals release more organically bound nitrogen earlier in the combustion process than do higher rank bituminous coals. When used with LNBs, sub-bituminous coals create a longer time for the kinetics to promote more stable molecular nitrogen and, hence, result in lower NO<sub>x</sub> emissions.

Coals from the PRB are classified as sub-bituminous C and demonstrate the high reactivity and low NO<sub>x</sub> production characteristics described above. Based on data from the Energy Information Administration (EIA), PRB coals currently represent 88 percent of total United States sub-bituminous production and 73 percent of western coal production. Most references to western coal and sub-bituminous coal infer PRB origin and characteristics. Emissions

standards differentiating between bituminous and sub-bituminous coals are presumed to use PRB coal as the basis for the sub-bituminous standards, due to their dominant market presence and unique characteristics.

There are a number of western coals that are classified as sub-bituminous; however, they border on being ranked as bituminous and do not display many of the qualities of PRB coals, including most of the low NO<sub>x</sub> forming characteristics. Coals from the Bridger, Black Butte, and Leucite Hills Mines fall into this category.

As defined by the American Society for Testing and Materials, the only distinguishing characteristic that classifies the coals used at Jim Bridger 2 as sub-bituminous rather than bituminous – that is, they are “agglomerating” as compared with “non-agglomerating.” Agglomerating as applied to coal is “the property of softening when it is heated to above about 400 degrees Celsius (°C) in a non-oxidizing atmosphere, and then appearing as a coherent mass after cooling to room temperature.” Because the agglomerating property of coals is the result of particles transforming into a plastic or semi-liquid state when heated, it reflects a change in surface area of the particle. Thus, with the application of heat, agglomerating coals would tend to develop a non-porous surface, while the surface of non-agglomerating coals would become even more porous with combustion. As shown on Figure 3-1, the increased porosity provides more particle surface area, resulting in more favorable combustion conditions. This non-agglomerating property assists in making sub-bituminous coals more amenable to controlling NO<sub>x</sub> by allowing less air to be introduced during the initial ignition portion of the combustion process. The coals from the Bridger, Black Butte and Leucite Hills Mines just barely fall into the category of non-agglomerating coals. While each of these coals is considered non-agglomerating, they either do not exhibit those properties of non-agglomerating coals or exhibit them to only a minor degree. The conditions during combustion of typical non-agglomerating coals that make it easier to control NO<sub>x</sub> emissions do not exist during combustion of the Bridger blends of coals.

**FIGURE 3-1**  
Illustration of the Effect of Agglomeration on the Speed of Coal Combustion  
*Jim Bridger 2*




Table 3-1 shows key characteristics of a typical PRB coal, compared with coals from the Bridger, Black Butte, and Leucite Hills Mines, as well as coal from Twentymile, which is a representative western bituminous coal.

**TABLE 3-1**  
Coal Characteristics Comparison  
*Jim Bridger 2*

Parameter	Typical PRB	Bridger Mine	Black Butte	Leucite Hills	Twentymile
Nitrogen (% dry)	1.10	1.26	1.47	1.48	1.85
Oxygen (% dry)	16.2	13.2	13.4	13.2	7.19
Coal rank	Sub C	Sub B	Sub B	Sub B	Bituminous high-volatility B


As shown in Table 3-1, although Bridger, Black Butte, and Leucite Hills coals are classified as sub-bituminous, they all exhibit higher nitrogen content and lower oxygen content than the PRB coal. The higher nitrogen content is an indication that more nitrogen is available to the combustion process and higher NO<sub>x</sub> emissions are likely. Oxygen content can be correlated to the reactivity of the coal, with more reactive coals generally containing higher levels of oxygen. More reactive coals tend to produce lower NO<sub>x</sub> emissions, and are more conducive to reduction of NO<sub>x</sub> emissions through the use of combustion control measures, such as LNBs and OFA. These characteristics indicate that higher NO<sub>x</sub> formation is likely with coal from the Bridger, Black Butte, and Leucite Hills Mines, rather than with PRB coal. The Bridger, Black Butte, and Leucite Hills coals all contain quality characteristics that fall between a typical PRB coal and Twentymile. Twentymile is a clearly bituminous coal that produces higher NO<sub>x</sub>, as has been demonstrated at power plants that burn this fuel.

Figures 3-2 and 3-3 show the relationship of nitrogen and oxygen content to the BART presumptive NO<sub>x</sub> limits for the coals listed in Table 3-1. Each chart identifies the presumptive BART limit associated with a typical bituminous and sub-bituminous coal, and demonstrates how the Jim Bridger 2 coal falls between these two general coal classifications.


The Bridger blend data point represents a combination of coals from the Bridger, Black Butte, and Leucite Hills Mines that has been used at Jim Bridger 2, and indicates the average NO<sub>x</sub> emission rate achieved during the years 2003 through 2005. The Jim Bridger 2 data point represents the NO<sub>x</sub> emission rate achieved after installation of Alstom's current state-of-the art TFS2000 LNB and OFA System. The long-term sustainable emission rate for this system is expected to be 0.24 lb per MMBtu.

Figures 3-2 and 3-3 both demonstrate that for the Jim Bridger 2 units with the TFS2000 low-NO<sub>x</sub> emission system installed and burning a combination of the Bridger, Black Butte, and Leucite Hill coals, the likely NO<sub>x</sub> emission rate (0.28) will be closer to the bituminous end of the BART presumptive NO<sub>x</sub> limit range, rather than the BART presumptive NO<sub>x</sub> limit of 0.15 lb per MMBtu for sub-bituminous coal. All these factors are consistent with the observed sustainable rate of 0.24 lb per MMBtu.

**FIGURE 3-2**  
**Plot of Typical Nitrogen Content of Various Coals and Applicable Presumptive BART NO<sub>x</sub> Limits**  
*Jim Bridger 2*



**FIGURE 3-3**  
**Plot of Typical Oxygen Content of Various Coals and Applicable Presumptive BART NO<sub>x</sub> Limits**  
*Jim Bridger 2*



Coal quality characteristics also affect the design and operation of the boiler and associated auxiliary equipment. Minor changes in quality can sometimes be accommodated through operational adjustments or changes to equipment. However, consistent variations in quality or assumptions of "average" quality for performance projections can be problematic. This is particularly troublesome when dealing with performance issues that are very sensitive to both coal quality and combustion conditions, such as NO<sub>x</sub> formation. There is significant variability in the quality of coals burned at Jim Bridger 2. In addition to burning coal from Black Butte and Leucite Hills Mines, Jim Bridger 2 burns coal supplied from the Bridger Mine consisting of three sources: underground, surface, and highwall operations. Each of these coal sources has different quality characteristics, as well as inherent variability in the composition of coal within the mine.

Several of the coal quality characteristics and their effect on NO<sub>x</sub> formation have been previously discussed. There are some additional considerations that illustrate the complexity of achieving and maintaining consistent low NO<sub>x</sub> emissions with pulverized coal on a shorter term, such as a 30-day rolling average basis.

Good combustion is based on the "three Ts": time, temperature, and turbulence. These parameters, along with a "design" coal, are taken into consideration when designing a boiler and associated firing equipment such as fans, burners, and pulverizers. If a performance requirement such as NO<sub>x</sub> emission limits is subsequently changed, conflicts with and between other performance issues can result.

Jim Bridger 2 is located at an altitude of 6,669 feet above mean sea level. At this elevation, atmospheric pressure is lower (11.5 pounds per square inch) as compared with sea level pressure of 14.7 pounds per square inch. This lower pressure means that less oxygen is available for combustion for each volume of air. In order to provide adequate oxygen to meet the requirements for efficient combustion, larger volumes of air are required. When adjusting air flows and distribution to reduce NO<sub>x</sub> emissions, using low NO<sub>x</sub> burners and OFA, original boiler design restrictions again limit the modifications that can be made and still achieve satisfactory combustion performance.

Another significant factor in controlling NO<sub>x</sub> emissions is the fineness of the coal entering the burners. Fineness is influenced by the grindability index (Hardgrove) of the coal. Finer coal particles promote release of volatiles and assist char burnout due to more surface area exposed to air. Nitrogen oxide reduction with high-volatile coals is improved with greater fineness and with proper air staging. The lower rank sub-bituminous coals such as PRB coals are quite friable and easy to grind. Coals with lower Hardgrove Grindability Index values, such as those used at Jim Bridger 2, are more difficult to grind and can contribute to higher NO<sub>x</sub> levels. In addition, coal fineness can deteriorate over time periods between pulverizer maintenance and service, as pulverizer grinding surfaces undergo wear.

In summary, when all the factors of agglomeration versus non-agglomeration, nitrogen and oxygen content of the coals, and the grindability index are taken into account, this analysis demonstrates that for the coal used at Jim Bridger 2, the more applicable presumptive BART limit for NO<sub>x</sub> emissions is 0.28 lb per MMBtu. The BART analysis for NO<sub>x</sub> emissions from Jim Bridger 2 is further described below.

### Step 1: Identify All Available Retrofit Control Technologies

The first step of the BART process is to evaluate NO<sub>x</sub> control technologies with practical potential for application to Jim Bridger 2, including those control technologies identified as Best Available Control Technology (BACT) or lowest achievable emission rate (LAER) by permitting agencies across the United States. A broad range of information sources have been reviewed in an effort to identify potentially applicable emission control technologies. NO<sub>x</sub> emissions at Jim Bridger 2 are currently controlled through the use of good combustion practices and OFA.

The following potential NO<sub>x</sub> control technology options were considered:

- New/modified LNB with advanced OFA
- Mobotec rotating opposed fire air (ROFA)
- LNB with OFA and conventional selective non-catalytic reduction (SNCR) system
- LNB with OFA and selective catalytic reduction (SCR) system

### Step 2: Eliminate Technically Infeasible Options

For Jim Bridger 2, a tangentially fired configuration burning sub-bituminous coal, technical feasibility will primarily be determined by physical constraints, boiler configuration, and the ability to achieve the regulatory presumptive limit (used as a guide) of 0.28 lb of NO<sub>x</sub> per MMBtu. Jim Bridger 2 has a current NO<sub>x</sub> emission rate of 0.24 lb per MMBtu.

For this BART analysis, information pertaining to LNBs, OFA, SNCR, and SCR were based on the Multi-pollutant Control Report dated October 2002 (Sargent & Lundy [S&L], 2002, hereafter referred to as S&L Study). Updated cost estimates for SCR and SNCR were used. PacifiCorp provided additional emissions data and costs developed by boiler vendors for LNBs and OFA. Also, CH2M HILL solicited a proposal from Mobotec for its ROFA technology.

With SNCR, an amine-based reagent such as ammonia, or more commonly urea, is injected into the furnace within a temperature range of 1,600 to 2,100°F, where it reduces NO<sub>x</sub> to nitrogen and water. NO<sub>x</sub> reductions of up to 40 to 60 percent have been achieved, although 15 to 30 percent is more realistic for most applications. SNCR is typically applied on smaller units.

Table 3-2 summarizes the control technology options evaluated in this BART analysis, along with projected NO<sub>x</sub> emission rates. All of the evaluated technologies are projected to meet the applicable presumptive BART limit of 0.28 lb per MMBtu.

**TABLE 3-2**  
**NO<sub>x</sub> Control Technology Projected Emission Rates**  
*Jim Bridger 2*

Technology	Projected Emission Rate (lb per MMBtu)
Presumptive BART Limit	0.28
LNB with OFA	0.24
ROFA	0.22
LNB with OFA and SNCR	0.20
LNB with OFA and SCR	0.07

### Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

Preliminary vendor proposals, such as those used to support portions of this BART analysis, may be technically feasible and provide expected or guaranteed emission rates; however, the proposals include inherent uncertainties. These proposals are usually prepared in a limited timeframe, may be based on incomplete information, may contain over-optimistic conclusions, and are non-binding. Therefore, emission rate values obtained in such preliminary proposals must be qualified, and it must be recognized that contractual guarantees are established only after more detailed analysis has been completed. The following subsections describe the control technologies and the control effectiveness evaluated in this BART analysis.

**LNBs with OFA System.** The mechanism used to lower NO<sub>x</sub> with LNBs is to stage the combustion process and provide a fuel rich condition initially; this is so oxygen needed for combustion is not diverted to combine with nitrogen and form NO<sub>x</sub>. Fuel-rich conditions favor the conversion of fuel nitrogen to N<sub>2</sub> instead of NO<sub>x</sub>. Additional air (or OFA) is then introduced downstream in a lower temperature zone to burn out the char.

Both LNBs and OFA are considered to be a capital cost, combustion technology retrofit. For LNB retrofits to units configured with tangential-firing such as Jim Bridger 2, it is generally necessary to increase the burner spacing; this prevents interaction of the flames from adjacent burners and reduces burner zone heat flux. These modifications usually require boiler waterwall tube replacement. However, Jim Bridger 2 has already been modified with the installation of a TFS-2000 LNB with OFA system.

Information provided to CH2M HILL by PacifiCorp, based on the S&L Study and data from boiler vendors, indicates that the existing TFS-2000 LNB with and OFA system at Jim Bridger 2 could be more finely tuned to result in an expected NO<sub>x</sub> emission rate of 0.24 lb per MMBtu. PacifiCorp has indicated that this rate corresponds to a vendor guarantee, not a vendor prediction, and they believe that this emission rate can be sustained as an average between overhauls. This emission rate represents a significant reduction from the current NO<sub>x</sub> emission rate, and is below the more applicable presumptive NO<sub>x</sub> emission rate of 0.28 lb per MMBtu.

**ROFA.** Mobotec markets ROFA as an improved second generation OFA system. Mobotec states that "the flue gas volume of the furnace is set in rotation by asymmetrically placed air nozzles. Rotation is reported to prevent laminar flow, so that the entire volume of the furnace can be

used more effectively for the combustion process. In addition, the swirling action reduces the maximum temperature of the flames and increases heat absorption. The combustion air is also mixed more effectively." A typical ROFA installation would have a booster fan(s) to supply the high velocity air to the ROFA boxes, and Mobotec would propose two 4,000- to 4,300-horsepower (hp) fans for Jim Bridger 2.

Mobotec proposes to achieve a NO<sub>x</sub> emission rate of 0.18 lb per MMBtu using ROFA technology. An operating margin of 0.04 lb per MMBtu was added to the expected rate due to Mobotec's limited ROFA experience with western sub-bituminous coals. Under the Mobotec proposal, which is primarily based on ROFA equipment, the operation of existing LNB and OFA ports would be analyzed. While a typical installation does not require modification to the existing LNB system and the existing OFA ports are not used, results of computational fluid dynamics modeling would determine the quantity and location of new ROFA ports. The Mobotec proposal includes bent tube assemblies for OFA port installation.

Mobotec would not provide installation services because the Owner could more cost effectively contract for these services. However, it would provide one onsite construction supervisor during installation and startup.

**SNCR.** Selective non-catalytic reduction is generally utilized to achieve modest NO<sub>x</sub> reductions on smaller units. With SNCR, an amine-based reagent such as ammonia, or more commonly urea, is injected into the furnace within a temperature range of 1,600 to 2,100°F, where it reduces NO<sub>x</sub> to nitrogen and water. NO<sub>x</sub> reductions of up to 60 percent have been achieved, although 20 to 40 percent is more realistic for most applications.

Reagent utilization, which is a measure of the efficiency with which the reagent reduces NO<sub>x</sub>, can range from 20 to 60 percent, depending on the amount of reduction, unit size, operating conditions, and allowable ammonia slip. With low reagent utilization, low temperatures, or inadequate mixing, ammonia slip occurs, allowing unreacted ammonia to create problems downstream. The ammonia may render fly ash unsaleable, react with sulfur to foul heat exchange surfaces, and/or create a visible stack plume. Reagent utilization can have a significant impact on economics, with higher levels of NO<sub>x</sub> reduction generally resulting in lower reagent utilization and higher operating cost.

Reductions from higher baseline concentrations (inlet NO<sub>x</sub>) are lower in cost per ton, but result in higher operating costs, due to greater reagent consumption. Unit 2 has already had combustion modifications including LNBs and advanced OFA, capable of achieving a projected NO<sub>x</sub> emission rate of 0.24 lb per MMBtu. At a further reduction of 15 percent in NO<sub>x</sub> emission rates for SNCR would result in a projected emission rate of 0.20 lb per MMBtu.

**SCR.** Selective catalytic reduction works on the same chemical principle as SNCR, but SCR uses a catalyst to promote the chemical reaction. Ammonia is injected into the flue gas stream, where it reduces NO<sub>x</sub> to nitrogen and water. Unlike the high temperatures required for SNCR, in SCR, the reaction takes place on the surface of a vanadium/titanium-based catalyst at a temperature range between 580 to 750°F. Due to the catalyst, the SCR process is more efficient than SNCR and results in lower NO<sub>x</sub> emissions. The most common type of SCR is the high-dust configuration, where the catalyst is located downstream from the boiler economizer, and upstream of the air heater and any particulate control equipment. In this location, the SCR is

exposed to the full concentration of fly ash in the flue gas that is leaving the boiler. The high-dust configuration is assumed for Jim Bridger 2.

In a full-scale SCR, the flue ducts are routed to a separate large reactor containing the catalyst. With in-duct SCR, the catalyst is located in the existing gas duct, which may be expanded in the area of the catalyst to reduce flue gas flow velocity and increase flue gas residence time. Due to the higher removal rate, a full-scale SCR was used as the basis for analysis at Jim Bridger 2.

Sargent and Lundy prepared the design conditions and cost estimates for SCR at Jim Bridger 2. Unit 2 has already had combustion modifications including LNBs and advanced OFA, capable of achieving a projected NO<sub>x</sub> emission rate of 0.24 lb per MMBtu. The S&L design basis for LNB with OFA and SCR results in a projected NO<sub>x</sub> emission rate of 0.07 lb per MMBtu. Additional catalyst surface was included in the SCR design to accommodate the characteristics of the coal used at Jim Bridger 2.

**Level of Confidence for Vendor Post-control Emissions Estimates.** In order to determine the level of NO<sub>x</sub> emissions needed to consistently achieve compliance with an established goal, a review of typical NO<sub>x</sub> emissions from coal-fired generating units was completed. As a result of this review, it was noted that NO<sub>x</sub> emissions can vary significantly around an average emissions level. Variations may result for many reasons, including coal characteristics, unit load, boiler operation including excess air, boiler slagging, burner equipment condition, and coal mill fineness.

The steps utilized for determining a level of confidence for the vendor expected values are as follows:

1. Establish expected NO<sub>x</sub> emissions value from vendor.
2. Evaluate vendor experience and historical basis for meeting expected values.
3. Review and evaluate unit physical and operational characteristics and restrictions. The fewer variations there are in operations, coal supply, etc., the more predictable and less variant the NO<sub>x</sub> emissions.
4. For each technology expected value, there is a corresponding potential for actual NO<sub>x</sub> emissions to vary from this expected value. From the vendor information presented, along with anticipated unit operational data, an adjustment to the expected value can be made.

#### **Step 4: Evaluate Impacts and Document the Results**

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

**Energy Impacts.** Installation of LNBs and modification to the existing OFA systems are not expected to significantly affect the boiler efficiency or forced draft fan power usage. Therefore, these technologies will not have energy impacts.

The Mobotec ROFA system would require installation and operation of two 4,000- to 4,300-hp ROFA fans (6,410 kilowatts [kW] total). The SNCR system would require approximately 530 kW of additional power.

SCR retrofit impacts the existing flue gas fan systems, due to the additional pressure drop associated with the catalyst, which is typically a 6- to 8-inch water gage increase. Total additional power requirements for SCR installation at Jim Bridger 2 are estimated at approximately 3,250 kW, based on the S&L Study.

**Environmental Impacts.** Mobotec has predicted that carbon monoxide (CO) emissions, and unburned carbon in the ash, commonly referred to as LOI (loss on ignition), would be the same or lower than prior levels for the ROFA system.

The installation of SNCR and SCR could affect the saleability and disposal of fly ash due to ammonia levels, and could potentially create a visible stack plume, which may negate other visibility improvements. Other environmental impacts involve the storage of ammonia, especially if anhydrous ammonia is used, and the transportation of the ammonia to the power plant site.

**Economic Impacts.** Costs and schedules for the LNBs and OFA, SNCR, and SCR were furnished to CH2M HILL by PacifiCorp, developed using S&L's internal proprietary database, and supplemented (as needed) by vendor-obtained price quotes. The relative accuracy of these cost estimates is stated by S&L to be in the range of plus or minus 20 percent. Cost for the ROFA system was obtained from Mobotec.

A comparison of the technologies on the basis of costs, design control efficiencies, and tons of NO<sub>x</sub> removed is summarized in Table 3-3, and the first-year control costs are presented in Figure 3-4. The complete economic analysis is contained in Appendix A.

**TABLE 3-3**  
**NO<sub>x</sub> Control Cost Comparison**  
*Jim Bridger 2*


Factor	Low-NO <sub>x</sub> Burners (LNBS) with Over-fire Air (OFA) (Existing)	Mobotec Rotating Opposed Fire Air (ROFA)	Selective Non-Catalytic Reduction (SNCR)	Selective Catalytic Reduction (SCR)
Total Installed Capital Costs	\$0	\$20.5 million	13.4 million	\$120.9 million
Total First Year Fixed and Variable Operation and Maintenance Costs	\$0	\$2.6 million	\$1.0 million	\$3.2 million
Total First Year Annualized Cost	\$0	\$4.6 million	\$2.3 million	\$14.7 million
Power Consumption (megawatts)	0	6.4	0.5	3.3
Annual Power Usage (1,000 million kilowatt-hours per year)	0	50.6	4.2	25.6
NO <sub>x</sub> Design Control Efficiency	0.0%	8.3%	16.7%	70.8%
NO <sub>x</sub> Removed per Year (Tons)	0	473	946	4,021
First Year Average Control Cost (\$/Ton of NO <sub>x</sub> Removed)	\$0/ton	\$9,695/ton	\$2,389/ton	\$3,654/ton
Incremental Control Cost (\$/Ton of NO <sub>x</sub> Removed)	\$0/ton	\$9,695/ton	\$2,389/ton	\$4,044/ton

**Preliminary BART Selection.** CH2M HILL recommends selection of the existing LNBS with OFA as BART for Jim Bridger 2, based on the projected significant reduction in NO<sub>x</sub> emissions, reasonable control costs, and the advantages of no additional power requirements or non-air quality environmental impacts. Low-NO<sub>x</sub> burner with OFA does not meet the EPA presumptive limit of 0.15 lb per MMBtu for sub-bituminous coal; however, it meets an emission rate that falls between the presumptive limit of 0.28 lb per MMBtu for bituminous coal and the limit of 0.15 lb per MMBtu for sub-bituminous coal. As discussed in the section on coal quality, the recommended technology and the achieved emission rate are deemed appropriate as BART for NO<sub>x</sub> emissions from the coals combusted at Jim Bridger 2.

#### Step 5: Evaluate Visibility Impacts

See Section 4, BART Modeling Analysis.

FIGURE 3-4  
First Year Control Cost for NO<sub>x</sub> Air Pollution Control Options  
*Jim Bridger 2*



### 3.2.2 BART SO<sub>2</sub> Analysis

Sulfur dioxide forms in the boiler during the combustion process, and is primarily dependent on coal sulfur content. The BART analysis for SO<sub>2</sub> emissions on Jim Bridger 2 is described below.

#### Step 1: Identify All Available Retrofit Control Technologies

A broad range of information sources were reviewed, in an effort to identify potentially applicable emission control technologies for SO<sub>2</sub> at Jim Bridger 2. This included control technologies identified as BACT or LAER by permitting agencies across the United States.

The following potential SO<sub>2</sub> control technology options were considered:

- Optimize current operation of existing wet sodium FGD system
- Upgrade wet sodium FGD system to meet SO<sub>2</sub> emission rate of 0.10 lb per MMBtu
- New dry FGD system

#### Step 2: Eliminate Technically Infeasible Options

Technical feasibility will primarily be based on the regulatory presumptive limit (used as a guideline) of 95 percent reduction in SO<sub>2</sub> emissions, or 0.15 lb per MMBtu. Based on the coal that Jim Bridger 2 currently burns, the unit would be required to achieve an 87.5 percent SO<sub>2</sub> removal efficiency to meet the presumptive limit of 0.15 lb per MMBtu.

Table 3-4 summarizes the control technology options evaluated in this BART analysis, along with projected SO<sub>2</sub> emission rates. Only one technology option can meet the applicable presumptive BART limit of 0.15 lb per MMBtu.

TABLE 3-4  
SO<sub>2</sub> Control Technology Emission Rates  
*Jim Bridger 2*

Technology	Projected Emission Rate (lb per MMBtu)
Presumptive BART Limit	0.15
Upgrade Existing Wet Sodium System	0.10
Optimize Existing Wet Sodium System	0.20
New Dry FGD System	0.21

**Wet Sodium FGD System.** Wet sodium FGD systems operate by treating the flue gas in large scrubber vessels with a soda ash solution. The scrubber mixes the flue gas and alkaline reagent using a series of spray nozzles to distribute the reagent across the scrubber vessel. The sodium in the reagent reacts with the SO<sub>2</sub> in the flue gas to form sodium sulfite and sodium bisulfite, which are removed from the scrubber and disposed.

The wet sodium FGD system at Jim Bridger 2 currently achieves approximately 78 percent SO<sub>2</sub> removal to achieve an SO<sub>2</sub> outlet emission rate of 0.27 lb per MMBtu. Optimizing the existing wet FGD system is projected to achieve an SO<sub>2</sub> outlet emission rate of 0.20 lb per MMBtu (83.3 percent SO<sub>2</sub> removal). Optimization would be accomplished by partially closing

the bypass damper to reduce the routine bypass flue gas flow used to reheat the treated flue gas from the scrubber, relocating the opacity monitor, and modifying the system to minimize scaling problems.

Upgrading the wet FGD system is projected to achieve an SO<sub>2</sub> outlet emission rate of 0.10 lb per MMBtu (91.7 percent SO<sub>2</sub> removal). Upgrading the system would involve closing the bypass damper to eliminate the routine bypass flue gas flow used to reheat the treated flue gas from the scrubber, relocating the opacity monitor, adding new fans, adding a stack liner and drains for wet operation, and using a refined soda ash reagent. It is considered to be technically infeasible for the present wet FGD system to achieve a 95 percent SO<sub>2</sub> removal rate (0.06 lb per MMBtu) on a continuous basis because this high level of removal must be incorporated into the original design of the scrubber.

Optimizing the existing wet sodium scrubbing FGD system is projected to achieve an outlet emission rate of 0.20 lb per MMBtu, which would not meet the presumptive limit of 0.15 lb of SO<sub>2</sub> per MMBtu. Therefore, this option is eliminated as technically infeasible for this analysis. An upgraded wet sodium scrubbing FGD system is projected to achieve an outlet emission rate of 0.10 lb per MMBtu (91.7 percent SO<sub>2</sub> removal), which would meet the presumptive limit of 0.15 lb of SO<sub>2</sub> per MMBtu for Jim Bridger 2.

**New Dry FGD System.** The lime spray dryer typically injects lime slurry in the top of the absorber vessel with a rapidly rotating atomizer wheel. The rapid speed of the atomizer wheel causes the lime slurry to separate into very fine droplets that intermix with the flue gas. The SO<sub>2</sub> in the flue gas reacts with the calcium in the lime slurry to form dry calcium sulfate particles. At Jim Bridger 2, this dry particulate matter (PM) would be captured downstream in the existing ESP, along with the fly ash. A lime spray dryer system typically produces a dry waste product suitable for landfill disposal.

The dry FGD system with the existing ESP is projected to achieve 82.5 percent SO<sub>2</sub> removal at Jim Bridger 2. This would result in a controlled SO<sub>2</sub> emission rate of 0.21 lb per MMBtu, based on an uncontrolled SO<sub>2</sub> emission rate of 1.20 lb per MMBtu. Therefore, this option cannot meet the presumptive limit of 0.15 lb SO<sub>2</sub> per MMBtu, and is eliminated from further analysis as technically infeasible.

### Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

When evaluating the control effectiveness of SO<sub>2</sub> reduction technologies, each option can be compared against benchmarks of performance. One such benchmark is the presumptive BART emission limit because Jim Bridger 2 is required to meet this limit. As indicated previously, the presumptive limit for SO<sub>2</sub> on a BART-eligible coal burning unit is 95 percent removal, or 0.15 lb per MMBtu.

The projected emission rate for an upgraded wet sodium FGD system for Jim Bridger 2 would be 0.10 lb per MMBtu. This option would meet the presumptive SO<sub>2</sub> limit of 0.15 lb per MMBtu.

#### Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

**Energy Impacts.** Upgrading the existing wet sodium FGD system would require an additional 530 kW of power.

**Environmental Impacts.** There will be incremental additions to scrubber waste disposal and makeup water requirements, and a reduction of the stack gas temperature from 140 to 120°F, due to elimination of reheating by the bypassed flue gas.

**Economic Impacts.** A summary of the costs and amount of SO<sub>2</sub> removed for the upgraded wet sodium FGD system is provided in Table 3-5. The complete economic analysis is contained in Appendix A.

TABLE 3-5  
SO<sub>2</sub> Control Cost Comparison (Incremental to Existing Wet FGD System)  
*Jim Bridger 2*

Factor	Upgraded Wet Flue Gas Desulfurization
Total Installed Capital Costs	\$13.0 million
Total First Year Fixed & Variable Operation and Maintenance Costs	\$1.3 million
Total First Year Annualized Cost	\$2.5 million
Additional Power Consumption (megawatt)	0.5
Additional Annual Power Usage (1000 megawatt-hour per year)	4.2
Incremental SO <sub>2</sub> Design Control Efficiency	62.5% (91.7% based on Uncontrolled SO <sub>2</sub> )
Incremental Tons SO <sub>2</sub> Removed per Year	3,950
First Year Average Control Cost (dollars per ton [ $\$/\text{Ton}$ ] of SO <sub>2</sub> Removed)	632
Incremental Control Cost (\$/Ton of SO <sub>2</sub> Removed)	632

**Preliminary BART Selection:** CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 2, based on significant reduction in SO<sub>2</sub> emissions (meeting presumptive limit of 0.15 lb per MMBtu), reasonable control costs, and the advantages of minimal additional power requirements and environmental impacts.

#### Step 5: Evaluate Visibility Impacts

See Section 4, BART Modeling Analysis.

#### 3.2.3 BART PM<sub>10</sub> Analysis

Jim Bridger 2 is currently equipped with an ESP. Electrostatic precipitators remove PM from the flue gas stream by charging fly ash particles with a very high direct current voltage, and

attracting these charged particles to grounded collection plates. A layer of collected PM forms on the collecting plates and is removed by periodically rapping the plates. The collected ash particles drop into hoppers below the precipitator and are removed periodically by the fly ash-handling system. Historically, the ESP at Jim Bridger 2 has controlled PM<sub>10</sub> emissions to levels below 0.074 lb per MMBtu.

The BART analysis for PM<sub>10</sub> emissions at Jim Bridger 2 is described below. For the modeling analysis in Section 4, PM<sub>10</sub> was used as an indicator for PM, and PM<sub>10</sub> includes particulate matter less than 2.5 micrometers in aerodynamic diameter (PM<sub>2.5</sub>) as a subset.

#### **Step 1: Identify All Available Retrofit Control Technologies**

The following two retrofit control technologies have been identified for additional PM control:

- Flue gas conditioning
- Polishing fabric filter (baghouse) downstream of existing ESP

Another available control technology is replacing the existing ESP with a new fabric filter. However, because the environmental benefits that would be achieved by a replacement fabric filter are also achieved by installing a polishing fabric filter downstream of the existing ESP at lower costs, installation of a full fabric filter was not considered in the analysis.

#### **Step 2: Eliminate Technically Infeasible Options**

**Flue Gas Conditioning.** If the fly ash from coal has high resistivity, such as fly ash from sub-bituminous coal, the ash is not collected effectively in an ESP. This is because the high resistivity makes the particles less willing to accept an electrical charge. Adding flue gas conditioning (FGC), which is typically accomplished by injection of sulfur trioxide (SO<sub>3</sub>), will lower the resistivity of the particles so that they will accept more charge and allow the ESP to collect the ash more effectively. Flue gas conditioning systems can account for large improvements in collection efficiency for small ESPs.

**Polishing Fabric Filter.** A polishing fabric filter could be added downstream of the existing ESP at Jim Bridger 2. One such technology is licensed by the Electric Power Research Institute, and referred to as a COHPAC (Compact Hybrid Particulate Collector). The COHPAC collects the ash that is not collected by the ESP, thus acting as a polishing device. The ESP needs to be kept in service for the COHPAC fabric filter to operate effectively.

The COHPAC fabric filter is about one-half to two-thirds the size of a full size fabric filter, because the COHPAC has a higher air-to-cloth ratio (7 to 9:1), compared with a full-size pulse jet fabric filter (3.5 to 4:1).

#### **Step 3: Evaluate Control Effectiveness of Remaining Control Technologies**

The existing ESP at Jim Bridger 2 is achieving a controlled PM emission rate of 0.074 lb per MMBtu. Utilizing FGC upstream of the existing ESP is projected to reduce PM emissions to approximately 0.030 lb per MMBtu. Adding a COHPAC fabric filter downstream of the existing ESP is projected to reduce PM emissions to approximately 0.015 lb per MMBtu.

The PM<sub>10</sub> control technology emission rates are summarized in Table 3-6.

**TABLE 3-6**  
**PM<sub>10</sub> Control Technology Emission Rates**  
*Jim Bridger 2*

Control Technology	Short-term Expected PM <sub>10</sub> Emission Rate (lb per MMBtu)
Flue Gas Conditioning	0.030
Polishing Fabric Filter	0.015

#### **Step 4: Evaluate Impacts and Document the Results**

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

**Energy Impacts.** Energy is required to overcome the additional pressure drop from the COHPAC fabric filter and associated ductwork. Therefore, a COHPAC retrofit will require an internal diameter (ID) fan upgrade and upgrade of the auxiliary power supply system.

A COHPAC fabric filter at Jim Bridger 2 would require approximately 3.4 MW of power, equating to an annual power usage of approximately 26.5 million kilowatt-hour (kW-Hr).

There is only a small power requirement of approximately 50 kW associated with FGC.

**Environmental Impacts.** There are no negative environmental impacts from the addition of a COHPAC polishing fabric filter or FGC system.

**Economic Impacts.** A summary of the costs and PM removed for COHPAC and FGC is recorded in Table 3-7, and the first-year control costs for FGC and fabric filters are shown on Figure 3-5. The complete economic analysis is contained in Appendix A.

**TABLE 3-7**  
**PM<sub>10</sub> Control Cost Comparison**  
*Jim Bridger 2*


Factor	Flue Gas Conditioning	Polishing Fabric Filter
Total Installed Capital Costs	\$0	\$48.4 million
Total First Year Fixed and Variable Operations and Maintenance Costs	\$0.2 million	\$1.8 million
Total First Year Annualized Cost	\$0.2 million	\$ 6.4 million
Additional Power Consumption (megawatts)	0.05	3.4
Additional Annual Power Usage (million kilowatt-hours per year)	0.4	26.5
Incremental Particulate Matter (PM) Design Control Efficiency	59.5%	79.7%
Incremental Tons PM Removed per Year	1,041	1,395
First Year Average Control Cost (dollars per ton [\$/Ton] of PM Removed)	169	4,556
Incremental Control Cost (\$/Ton of SO <sub>2</sub> PM Removed)	169	17,426

**Preliminary BART Selection.** CH2M HILL recommends selection of flue gas conditioning upstream of the existing ESP as BART for Jim Bridger 2, based on the significant reduction in PM emissions, reasonable control costs, and advantages of minimal additional power requirements and no environmental impacts.

#### Step 5: Evaluate Visibility Impacts

See Section 4, BART Modeling Analysis.

FIGURE 3-5  
First Year Control Cost for PM Air Pollution Control Options  
*Jim Bridger 2*



## **4.0 BART Modeling Analysis**

---

### **4.1 Model Selection**

CH2M HILL used the CALPUFF modeling system (Gaussian puff dispersion model) to assess the visibility impacts of emissions from Jim Bridger 2 at nearby Class I areas. The Class I areas potentially affected are located more than 50 kilometers (km) but less than 300 km from the Jim Bridger 2 facility. The Class I areas include the following wilderness areas (WAs):

- Bridger WA
- Fitzpatrick WA
- Mt. Zirkel WA

The CALPUFF modeling system includes the CALMET meteorological model, CALPUFF modeling system with algorithms for chemical transformation and deposition, and a post processor capable of calculating concentrations, visibility impacts, and deposition (CALPOST). The CALPUFF modeling system was applied in a full, refined mode. Version numbers of the various programs in the CALPUFF modeling system used by CH2M HILL were as follows:

- CALMET Version 5.53a, Level 040716
- CALPUFF Version 5.711a, Level 040716
- CALPOST Version 5.51, Level 030709

### **4.2 CALMET Methodology**


#### **4.2.1 Dimensions of the Modeling Domain**

CH2M HILL used the CALMET model to generate a three-dimensional wind field and other meteorological parameters suitable for use by the CALPUFF modeling system. A modeling domain was established to encompass the Jim Bridger 2 facility and allow for a 50-km buffer around the Class I areas that were within 300 km of the facility. Grid resolution was 4 km. Figure 4-1 shows the extent of the modeling domain. Except when specifically instructed otherwise by the Wyoming Department of Environmental Quality-Air Quality Division (WDEQ-AQD), CH2M HILL followed the methodology spelled out in the WDEQ-AQD BART Modeling Protocol, a copy of which is included in this report as Appendix B.

CH2M HILL used the Lambert Conformal Conic map projection for the analysis because of the large extent of the domain. The latitude of the projection origin and the longitude of the central meridian were chosen at the approximate center of the domain. Standard parallels were drawn to represent one-sixth and five-sixths of the north-south extent of the domain to minimize distortion in the north-south direction.

# CH2MHILL

Figure 4-1  
Jim Bridger Source-Specific  
Class I Areas to be Addressed



S:\C\SLCD\BIS\PROJECTS\HUNTERMAP\FILE\JIM\_BRIDGER\_CLASSI.MXD 11/6/2006 \MSLAYDEN



The default technical options listed in TRC Companies, Inc.'s (TRC) current example CALMET.inp file were used for CALMET. Vertical resolution of the wind field included ten layers, with vertical face heights as follows (in meters):

- 0, 20, 40, 100, 140, 320, 580, 1020, 1480, 2220, 3500

Other user-specified model options were set to values established by WDEQ-AQD, which appear in Table 3 of Appendix B. Table 4-1 lists the key user-specified options used for this analysis.

**TABLE 4-1**  
User-Specified CALMET Options  
*Jim Bridger 2*

CALMET Input Parameter	Value
<b>CALMET Input Group 2</b>	
Map projection (PMAP)	Lambert Conformal
Grid spacing (DGRIDKM)	4
Number vertical layers (NZ)	10
Top of lowest layer (m)	20
Top of highest layer (m)	3500
<b>CALMET Input Group 4</b>	
Observation mode (NOOBS)	0
<b>CALMET Input Group 5</b>	
Prog. Wind data (IPROG)	14
(RMAX1)	30
(RMAX2)	50
Terrain influence (TERRAD)	15
(R1)	5
(R2)	25
<b>CALMET Input Group 6</b>	
Max mixing ht (ZIMAX)	3500

#### 4.2.2 CALMET Input Data

CH2M HILL ran the CALMET model to produce 3 years of analysis: 2001, 2002, and 2003. WDEQ-AQD provided 12-km resolution Mesoscale Meteorological Model, Version 5 (MM5) meteorological data fields that covered the entire modeling domain for each study year.

These three data sets were chosen because they are current and have been evaluated for quality. The MM5 data were used as input to CALMET as the "initial guess" wind field. The initial guess wind field was adjusted by CALMET for local terrain and land use effects to generate a

Step 1 wind field, and further refined using local surface observations to create a final Step 2 wind field.

Surface data for 2001 through 2003 were obtained from the National Climatic Data Center. CH2M HILL processed the data from the National Weather Service's Automated Surface Observing System (ASOS) network for all stations that are in the domain. The surface data were obtained in abbreviated DATSAV3 format. A conversion routine available from the TRC website was used to convert the DATSAV3 files to CD-144 format for input into the SMERGE preprocessor and CALMET.


Land use and terrain data were obtained from the U.S. Geological Survey (USGS). Land use data were obtained in Composite Theme Grid format from the USGS, and the Level I USGS land use categories were mapped into the 14 primary CALMET land use categories. Surface properties such as albedo, Bowen ratio, roughness length, and leaf area index were computed from the land use values. Terrain data were taken from USGS 1-degree Digital Elevation Model data, which primarily derive from USGS 1:250,000 scale topographic maps. Missing land use data were filled with values that were assumed appropriate for the missing area.

Precipitation data were obtained from the National Climatic Data Center. All available data in fixed-length, TD-3240 format were obtained for the modeling domain. The list of available stations that have collected complete data varies by year, but CH2M HILL processed all available stations/data within the domain for each year. Precipitation data were prepared with the PTRACT/PMERGE processors in preparation for use within CALMET.


Upper-air data were prepared for the CALMET model with the READ62 preprocessor for the following stations:

- Denver, Colorado
- Salt Lake City, Utah
- Riverton, Wyoming
- Rapid City, South Dakota

Figure 4-2 shows the locations of surface and upper air stations within the MM5 modeling domain.



**Figure 4-2**  
**Surface and Upper Air Stations Used in the**  
**Jim Bridger BART Analysis**



SIC NSLCBGS/PROJECTS/HUNTERMAPS/JIM\_BRIDGER\_ASOS.MXD 11/9/2006 MSLAYDEN

**CH2MHILL**

#### 4.2.3 Validation of CALMET Wind Field

CH2M HILL used the CALDESK data display and analysis system (v2.97, Enviromodeling Ltd.) to view plots of wind vectors and other meteorological parameters to evaluate the CALMET wind fields. The CALDESK displays were compared with observed weather conditions, as depicted in surface and upper-air weather maps from the National Oceanic and Atmospheric Administration Central Library U.S. Daily Weather Maps Project ([National Oceanic Atmospheric Administration, 2006](#)).

### 4.3 CALPUFF Modeling Approach

For the BART control technology visibility improvement modeling, CH2M HILL followed WDEQ-AQD guidance provided in the document titled *BART Air Modeling Protocol-Individual Source Visibility Assessments for BART Control Analyses* (WDEQ-AQD, 2006).

CH2M HILL drove the CALPUFF model with the meteorological output from CALMET over the modeling domain described in this report. The CALPUFF modeling system was used to predict visibility impacts for the pre-control (baseline) scenario for comparison to the predicted impacts for post-control scenarios for Jim Bridger 2.

#### 4.3.1 Background Ozone and Ammonia

Hourly values of background ozone concentrations were used by CALPUFF for the calculation of SO<sub>2</sub> and NO<sub>x</sub> transformation with the MESOPUFF II chemical transformation scheme. CH2M HILL obtained hourly ozone data from the following stations located within the modeling domain for 2001, 2002, and 2003:

- Rocky Mountain National Park, Colorado
- Craters of the Moon National Park, Idaho
- Highland, Utah
- Thunder Basin National Grasslands, Wyoming
- Yellowstone National Park, Wyoming
- Centennial, Wyoming
- Pinedale, Wyoming

For periods of missing hourly ozone data, the chemical transformation relied on a monthly default value of 44 parts per billion. Background ammonia was set to 2 parts per billion. Both of these background values were taken from the guidance document (WDEQ-AQD, 2006).

#### 4.3.2 Stack Parameters

The stack parameters used for the baseline modeling reflect those that are in place under the current permit for Jim Bridger 2, except for the NO<sub>x</sub> emission rate where 0.24 lb per MMBtu (achieved with the new LNB with OFA system) was used in lieu of the permit limit of 0.45 lb per MMBtu. Post-control stack parameters reflect the anticipated changes associated with installation of the control technology alternatives that are being evaluated. The maximum heat input rate of 6,000 MMBtu per hour was used to calculate a maximum emission rate. Measured velocities and stack flow rates were used in the modeling to represent a worst-case situation.

#### 4.3.3 Emission Rates

Pre-control emission rates for Jim Bridger 2 reflect peak 24-hour average emissions that could occur under the source's current permit. The emission rates reflect actual emissions under normal operating conditions, as described by the EPA in the *Regional Haze Regulations and Guidelines for Best Available Retrofit Technology Determinations; Final Rule* (40 CFR Part 51).

CH2M HILL used available continuous emission monitoring data to determine peak 24-hour emission rates. Data reflected operations from the most recent 3- to 5-year period, unless a more recent period was more representative. Allowable short-term (24-hour or shorter period) emissions or short-term emission limits were used if continuous emission monitoring data were not available.

Emissions were modeled for the following pollutants:

- SO<sub>2</sub>
- NO<sub>x</sub>
- Coarse particulate (PM<sub>2.5</sub><diameter<PM<sub>10</sub>)
- Fine particulate (diameter<PM<sub>2.5</sub>)
- Sulfates

Post-control emission rates reflect the effects of the emissions control scenario under consideration. Modeled pollutants were the same as those listed for the pre-control scenario.

#### 4.3.4 Post-control Scenarios

Four post-control modeling scenarios were developed to cover the range of effectiveness for the combination of the individual NO<sub>x</sub>, SO<sub>2</sub>, and PM control technologies being evaluated. The selection of each control device was made based on the engineering analyses described in Section 3 for reasonable technologies that would meet or exceed the presumptive BART levels for each pollutant.

- Scenario 1: Existing LNB with OFA, upgraded wet FGD system, and FGC for enhanced ESP performance. As indicated previously, this scenario represents CH2M HILL's preliminary BART recommendation.
- Scenario 2: Existing LNB with OFA, upgraded wet FGD system, and new polishing fabric filter.
- Scenario 3: Existing LNB with OFA and SCR, upgraded wet FGD system, and flue gas conditioning for enhanced ESP performance.
- Scenario 4: Existing LNB with OFA and SCR, upgraded wet FGD system, and new polishing fabric filter.

The ROFA and SNCR options for NO<sub>x</sub> control were not included in the modeling scenarios because their control effectiveness is between the existing LNB with OFA option and the SCR option. Modeling of NO<sub>x</sub>, SO<sub>2</sub>, and PM controls alone was not performed because any final BART solution will include a combination of control technologies for NO<sub>x</sub>, SO<sub>2</sub>, and PM.

Table 4-2 presents the stack parameters and emission rates used for the Jim Bridger 2 analysis for baseline and post-control modeling. In accordance with the WDEQ BART modeling protocol, elemental carbon stack emissions and organic aerosol emissions were not modeled.

#### 4.3.5 Modeling Process

The CALPUFF modeling system for the control technology options for Jim Bridger 2 followed this sequence:

- Model pre-control (baseline) emissions
- Model preferred post-control scenario (if applicable)
- Determine degree of visibility improvement
- Model other control scenarios
- Determine degree of visibility improvement
- Factor visibility results into BART five-step evaluation

#### 4.3.6 Receptor Grids

Discrete receptors for the CALPUFF modeling system were placed at uniform receptor spacing along the boundary and in the interior of each area of concern. Class I area receptors were taken from the National Park Service database for Class I area modeling receptors. The TRC COORDS program was used to convert all latitude/longitude coordinates to Lambert Conformal Conic coordinates, including receptors, meteorological stations, and source locations.

TABLE 4-2  
BART Model Input Data  
*Jim Bridger 2*

	Baseline	Post-control Scenario 1	Post-control Scenario 2	Post-control Scenario 3	Post-control Scenario 4
Sulfur Dioxide (SO <sub>2</sub> ) Stack Emissions (pounds per hour [lb/hr])	1,602	600	600	600	600
Nitrogen Oxide (NO) Stack Emissions (lb/hr)					
PM <sub>10</sub> Stack Emissions (lb/hr)	1,440	1,440	1,440	1,440	1,440
Coarse Particulate (PM <sub>2.5</sub> < diameter < PM <sub>10</sub> ) Stack Emissions (lb/hr) <sup>a</sup>	444	180	90.0	180	90.0
Fine Particulate (diameter < PM <sub>2.5</sub> ) Stack Emissions (lb/hr) <sup>b</sup>	191	77.4	51.3	77.4	51.3
Sulfuric Acid (H <sub>2</sub> SO <sub>4</sub> ) Stack Emissions (lb/hr)	253	103	38.7	103	38.7
H <sub>2</sub> SO <sub>4</sub> as Sulfate (SO <sub>4</sub> ) Stack Emissions (lb/hr)	55.2	55.2	55.2	55.2	55.2
Ammonium Sulfate ((NH <sub>4</sub> ) <sub>2</sub> SO <sub>4</sub> ) Stack Emissions (lb/hr)	54.1	54.1	54.1	54.1	54.1
(NH <sub>4</sub> ) <sub>2</sub> SO <sub>4</sub> as SO <sub>4</sub> Stack Emissions (lb/hr)					
(NH <sub>4</sub> ) <sub>2</sub> SO <sub>4</sub> Stack Emissions (lb/hr)					
(NH <sub>4</sub> ) <sub>2</sub> SO <sub>4</sub> as SO <sub>4</sub> Stack Emissions (lb/hr)	54.1	54.1	54.1	54.1	54.1
Total Sulfate (SO <sub>4</sub> ) (lb/hr)					
Stack Conditioner					
Stack Height (meters)					
Stack Exit Diameter (meters)	152	152	152	152	152
Stack Exit Temperature (Kelvin)	732	732	732	732	732
Stack Exit Velocity (meters per second)	333	322	333	333	333
Total Sulfate (SO <sub>4</sub> ) (lb/hr)	27.4	24.7	27.4	27.4	27.4

NOTES:

Scenarios 2, 3, and 4 were not remodeled at the lower, correct velocity of 81.24 feet per second due to lack of time and the fact that the conclusions to select Scenario 1 would not have changed.

<sup>a</sup> Based on AP-42, Table 1-1-G, the coarse particulates are counted as a percentage of PM<sub>10</sub>. This equates to 43 percent ESP and 57 percent baghouse.

<sup>b</sup> Based on AP-42, Table 1-1-G, the fine particulates are counted as a percentage of PM<sub>10</sub>. This equates to 57 percent ESP and 43 percent baghouse.

Total Sulfate (SO<sub>4</sub>) (lb/hr) = H<sub>2</sub>SO<sub>4</sub> as Sulfate (SO<sub>4</sub>) Stack Emissions (lb/hr) + (NH<sub>4</sub>)<sub>2</sub>SO<sub>4</sub> as SO<sub>4</sub> Stack Emissions (lb/hr).

**TABLE A-2**  
BART Modis Input Data  
*Jim Bridger 2*

	Baseline	Post-control Scenario 1	Post-control Scenario 2	Post-control Scenario 3	Post-control Scenario 4
Sulfur Dioxide (SO <sub>2</sub> ) Stack Emissions (pounds per hour [lb/hr])	1,602	600	600	600	600
Nitrogen Oxide (NO) Stack Emissions (lb/hr)					
PM <sub>10</sub> Stack Emissions (lb/hr)	1,440	1,440	1,440	1,440	1,440
Coarse Particulate (PM <sub>10</sub> > diameter < PM <sub>2.5</sub> ) Stack Emissions (lb/hr) <sup>a</sup>	444	180	90.0	180	90.0
Fine Particulate (diameter < PM <sub>2.5</sub> ) Stack Emissions (lb/hr) <sup>b</sup>	191	77.4	51.3	77.4	51.3
Sulfuric Acid (H <sub>2</sub> SO <sub>4</sub> ) Stack Emissions (lb/hr)					
H <sub>2</sub> SO <sub>4</sub> as Sulfate (SO <sub>4</sub> ) Stack Emissions (lb/hr)	253	103	38.7	103	38.7
Ammonium Sulfate ((NH <sub>4</sub> ) <sub>2</sub> SO <sub>4</sub> ) Stack Emissions (lb/hr)	55.2	55.2	55.2	55.2	55.2
(NH <sub>4</sub> )HSO <sub>4</sub> Stack Emissions (lb/hr)	54.1	54.1	54.1	54.1	54.1
(NH <sub>4</sub> ) <sub>2</sub> SO <sub>4</sub> as SO <sub>4</sub> Stack Emissions (lb/hr)					
Total Sulfate (SO <sub>4</sub> ) (lb/hr)	54.1	54.1	54.1	54.1	54.1
<b>Stack Conditions</b>					
Stack Height (meters)					
Stack Exit Diameter (meters)	152	152	152	152	152
Stack Exit Temperature (Kahn)	7.32	7.32	7.32	7.32	7.32
Stack Exit Velocity (meters per second)	333	322	333	333	333
Total Sulfate (SO <sub>4</sub> ) (lb/hr) = H <sub>2</sub> SO <sub>4</sub> as Sulfate (SO <sub>4</sub> ) Stack Emissions (lb/hr) + (NH <sub>4</sub> )HSO <sub>4</sub> as SO <sub>4</sub> Stack Emissions (lb/hr)	27.4	24.7	27.4	27.4	27.4

**NOTES:**

Scenarios 2, 3, and 4 were not remodeled at the lower, corrected velocity of 81.24 feet per second due to lack of time and the fact that the conclusions to select Scenario 1 would not have changed.

<sup>a</sup> Based on A-P-42, Table 1-1-6, the coarse particulates are counted as a percentage of PM<sub>10</sub>. This equates to 43 percent ESP and 57 percent baghouse.

<sup>b</sup> Based on A-P-42, Table 1-1-6, the fine particulates are counted as a percentage of PM<sub>10</sub>. This equates to 57 percent ESP and 43 percent baghouse.

Total Sulfate (SO<sub>4</sub>) (lb/hr) = H<sub>2</sub>SO<sub>4</sub> as Sulfate (SO<sub>4</sub>) Stack Emissions (lb/hr) + (NH<sub>4</sub>)HSO<sub>4</sub> as SO<sub>4</sub> Stack Emissions (lb/hr)

## 4.4 CALPOST

The CALPOST processor was used to determine 24-hour average visibility results with output specified in deciview (dV) units. Calculations of light extinction were made for each pollutant modeled. The sum of all extinction values were used to calculate the delta-dV ( $\Delta$  dV) change relative to natural background. The following default light extinction coefficients for each pollutant were used:

- Ammonium sulfate 3.0
- Ammonium nitrate 3.0
- PM coarse (PM<sub>10</sub>) 0.6
- PM fine (PM<sub>2.5</sub>) 1.0
- Organic carbon 4.0
- Elemental carbon 10.0

CALPOST visibility Method 6 was used to determine the visibility impacts. Monthly relative humidity factors [ $f(RH)$ ] were used in the light extinction calculations to account for the hygroscopic characteristics of nitrate and sulfate particles. Table 5 of the Wyoming BART Air Modeling Protocol (Appendix B) lists the monthly  $f(RH)$  factors for the Class I areas. These values were used for the particular Class I area being modeled.

The natural background conditions as a reference for determining the  $\Delta$  dV change represented the 20 percent best natural visibility days. The EPA BART guidance document provided dV values for the 10 percent best days for each Class I area, but did not provide individual species concentration data for the 20 percent best days. Species concentrations corresponding to the 20 percent best days were calculated for each Class I area by scaling back the annual average species concentrations given in Table 2-1 of *Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule* (EPA, 2003). A separate scaling factor was derived for each Class I area such that, when multiplied by the guidance table annual concentrations, the 20 percent best days dV value for that area would be calculated. This procedure was taken from *Protocol for BART-Related Visibility Improvement Modeling Analysis in North Dakota* (North Dakota Department of Health, 2005). The Wyoming BART Air Modeling Protocol (see Appendix B) provided natural background concentrations of aerosol components to use in the BART analysis. Table 4-3 lists the annual average species concentrations from the BART protocol.

**TABLE 4-3**  
**Average Natural Levels of Aerosol Components**  
*Jim Bridger 2*

Aerosol Component	Average Natural Concentration (micrograms per cubic meter) for Mt. Zirkel Class I Wilderness Area	Average Natural Concentration (micrograms per cubic meter) for Fitzpatrick and Bridger Class I Wilderness Areas
Ammonium Sulfate	0.046	0.045
Ammonium Nitrate	0.038	0.038
Organic Carbon	0.179	0.178
Elemental Carbon	0.008	0.008
Soil	0.190	0.189
Coarse Mass	1.141	1.136

**NOTES:**

Data in this table was taken from Table 6 of the Wyoming BART Air Modeling Protocol.

## 4.5 Presentation of Modeling Results

This section presents the results of the CALPUFF visibility improvement modeling analysis for Jim Bridger 2.

### 4.5.1 Visibility Changes for Baseline vs. Preferred Scenario

CH2M HILL modeled Jim Bridger 2 for the baseline conditions and post-control scenarios. The post-control scenarios included emission rates for NO<sub>x</sub>, SO<sub>2</sub>, and PM<sub>10</sub> that would be achieved if BART technology were installed on Unit 2.

Baseline (and post-control) 98<sup>th</sup> percentile results were greater than 0.5 ΔdV for the Bridger, Fitzpatrick, and Mt. Zirkel WAs. The 98<sup>th</sup> percentile results for each Class I area are presented in Table 4-4.

**TABLE 4-4**  
**Costs and Visibility Modeling Results for Baseline vs. Post-control Scenarios at Class I Areas**  
*Jim Bridger 2*

Scenario	Total First Year Annualized Cost	Class I Area	Modeling Results				Cost per Reduction in No. of Days Above 0.5 dV	Incremental Cost per dV Reduction	Incremental Cost per dV Reduction in No. of Days Above 0.5 dV	Incremental Cost per Reduction in No. of Days Above 0.5 dV
			Highest Delta- (dV)	85th Percentile Delta- (dV)	Number (No.) of Days Above 0.5 dV	Cost per dV Reduction				
<b>Baseline: current operation with wet FGD, ESP</b>										
Scenario 1: Existing LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	\$2,484,828	Bridger WA	1,730	0.530	10					
		Fitzpatrick WA	1,358	0.288	4					
		Mt. Zirkel WA	1,384	0.842	23					
Scenario 2: Existing LNB with OFA, upgrade wet FGD, polishing fabric filter	\$2,484,828	Bridger WA	1,370	0.385	7	\$17,025,710	\$831,609	\$2,494,828		
		Fitzpatrick WA	1,388	0.223	3	\$33,284,373				
		Mt. Zirkel WA	1,463	0.733	16	\$22,688,330	\$356,404			
Scenario 3: Existing LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance	\$2,484,828	Bridger WA	1,386	0.375	6	\$57,112,131	\$635,75,230	\$6,357,552		
		Fitzpatrick WA	1,177	0.210	3	\$100,595,250	\$489,04,2,485	NA		
		Mt. Zirkel WA	1,103	0.681	15	\$54,985,728	\$1,105,548	\$122,280,821	\$6,357,552	
Scenario 4: Existing LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance	\$2,484,828	Bridger WA	0.876	0.279	3	\$88,475,618	\$2,455,376	\$86,522,531	\$2,77,417	
		Fitzpatrick WA	0.678	0.127	1	\$100,512,463	\$5,259,210	\$100,442,711	\$4,187,626	
		Mt. Zirkel WA	0.758	0.455	5	\$44,412,484	\$954,868	\$36,981,641	\$833,525	
Scenario 5: Existing LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	\$23,545,184	Bridger WA	0.838	0.268	3	\$89,987,113	\$3,363,598	\$57,859,300	NA	
		Fitzpatrick WA	0.957	0.125	1	\$136,089,327	\$7,648,395	\$3,178,776,151	NA	
		Mt. Zirkel WA	0.731	0.439	2	\$58,524,773	\$1,121,199	\$397,347,019	\$2,119,184	
<b>2001</b>										
Scenario 1: Existing LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	\$2,484,828	Bridger WA	2,838	0.990	20					
		Fitzpatrick WA	1,273	0.534	8					
		Mt. Zirkel WA	1,975	1.008	18					
Scenario 2: Existing LNB with OFA, upgrade wet FGD, polishing fabric filter	\$2,484,828	Bridger WA	2,442	0.847	14	\$17,446,349	\$415,805			
		Fitzpatrick WA	1,073	0.377	5	\$15,990,624	\$881,609			
		Mt. Zirkel WA	1,545	0.815	13	\$12,228,570	\$498,966			
Scenario 3: Existing LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance	\$2,484,828	Bridger WA	2,317	0.764	13	\$42,972,720	\$1,264,626	\$100,913,529	\$6,357,552	
		Fitzpatrick WA	0.987	0.348	6	\$47,595,442	\$4,428,190	\$19,225,941	NA	
		Mt. Zirkel WA	1,487	0.777	13	\$38,321,592	\$1,170,476	\$16,340,008	NA	
Scenario 4: Existing LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance	\$2,484,828	Bridger WA	1,316	0.516	9	\$30,260,825	\$1,562,512	\$31,101,683	\$2,083,813	
		Fitzpatrick WA	0.546	0.226	1	\$53,005,987	\$2,465,376	\$68,321,729	\$1,687,050	
		Mt. Zirkel WA	0.884	0.474	5	\$32,186,575	\$1,322,125	\$27,505,079	\$1,041,906	
Scenario 5: Existing LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	\$23,545,184	Bridger WA	1,290	0.499	7	\$47,955,531	\$1,811,168	\$37,397,365	\$1,178,776	
		Fitzpatrick WA	0.538	0.222	1	\$75,465,332	\$3,363,598	\$1,599,386,076	\$706,994,700	
		Mt. Zirkel WA	0.865	0.485	4	\$45,361,296	\$1,681,799		\$6,357,552	
<b>2002</b>										
Scenario 1: Existing LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	\$2,484,828	Bridger WA	2,838	0.990	20					
		Fitzpatrick WA	1,273	0.534	8					
		Mt. Zirkel WA	1,975	1.008	18					
Scenario 2: Existing LNB with OFA, upgrade wet FGD, polishing fabric filter	\$2,484,828	Bridger WA	2,442	0.847	14	\$17,446,349	\$415,805			
		Fitzpatrick WA	1,073	0.377	5	\$15,990,624	\$881,609			
		Mt. Zirkel WA	1,545	0.815	13	\$12,228,570	\$498,966			
Scenario 3: Existing LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance	\$2,484,828	Bridger WA	2,317	0.764	13	\$42,972,720	\$1,264,626	\$100,913,529	\$6,357,552	
		Fitzpatrick WA	0.987	0.348	6	\$47,595,442	\$4,428,190	\$19,225,941	NA	
		Mt. Zirkel WA	1,487	0.777	13	\$38,321,592	\$1,170,476	\$16,340,008	NA	
Scenario 4: Existing LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance	\$2,484,828	Bridger WA	1,316	0.516	9	\$30,260,825	\$1,562,512	\$31,101,683	\$2,083,813	
		Fitzpatrick WA	0.546	0.226	1	\$53,005,987	\$2,465,376	\$68,321,729	\$1,687,050	
		Mt. Zirkel WA	0.884	0.474	5	\$32,186,575	\$1,322,125	\$27,505,079	\$1,041,906	
Scenario 5: Existing LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	\$23,545,184	Bridger WA	1,290	0.499	7	\$47,955,531	\$1,811,168	\$37,397,365	\$1,178,776	
		Fitzpatrick WA	0.538	0.222	1	\$75,465,332	\$3,363,598	\$1,599,386,076	\$706,994,700	
		Mt. Zirkel WA	0.865	0.485	4	\$45,361,296	\$1,681,799		\$6,357,552	

TABLE 4-4  
Costs and Viability Modeling Results for Baseline vs. Pre-control Scenarios at Class I Areas  
*Jim Bridger 2*

Scenario	Modeling Results						Cost per Reduction 0.5 dV	Incremental Cost per dV Reduction
	Total First Year Annualized Cost	Class I Area	Highest Delta- (dV)	% Percentage Delta- (dV)	Number (No.) of Days Above 0.5 dV	Cost per dV Reduction		
<b>2003</b>								
Baseline: current operation with wet FGD, ESP		Bridger WA	1,208	0.533	9			
		Fitzpatrick WA	1,348	0.283	3			
		Mt. Zirkel WA	1,364	0.803	20			
Scenario 1: Existing LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	\$2,494,828	Bridger WA	0.985	0.416	5	\$21,323,316	\$623,707	
		Fitzpatrick WA	1,118	0.200	2	\$39,600,444	\$2,494,828	
		Mt. Zirkel WA	1,043	0.735	16	\$10,385,116	\$623,707	
Scenario 2: Existing LNB with OFA, upgrade wet FGD, polishing fabric filter	\$8,852,380	Bridger WA	0.983	0.408	5	\$71,380,163	\$9,082,221,758	NA
		Fitzpatrick WA	1,090	0.188	2	\$11,031,737	\$8,852,380	NA
		Mt. Zirkel WA	1,054	0.688	15	\$76,977,220	\$1,352,677,070	\$6,357,582
Scenario 3: Existing LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance	\$17,187,631	Bridger WA	0.952	0.258	3	\$82,500,477	\$2,864,605	\$55,200,338
		Fitzpatrick WA	0.983	0.118	2	\$18,585,388	\$17,187,631	NA
		Mt. Zirkel WA	0.987	0.435	5	\$46,705,520	\$1,145,842	\$32,945,566
Scenario 4: Existing LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	\$25,545,184	Bridger WA	0.908	0.248	3	\$82,614,679	\$3,924,197	\$83,755,230
		Fitzpatrick WA	0.965	0.115	2	\$159,085,078	\$23,545,184	NA
		Mt. Zirkel WA	0.935	0.423	5	\$61,981,009	\$1,159,679	\$528,786,025
<b>3-year Averages</b>								
Baseline: current operation with wet FGD, ESP		Bridger WA	0.684	13.0				
		Fitzpatrick WA	0.385	5.0				
		Mt. Zirkel WA	0.884	20.3				
Scenario 1: Existing LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	\$2,494,828	Bridger WA	0.549	8.7		\$18,480,207	\$75,730	
		Fitzpatrick WA	0.287	3.3		\$25,371,132	\$1,486,897	
		Mt. Zirkel WA	0.781	15.0		\$20,228,335	\$467,780	
Scenario 2: Existing LNB with OFA, upgrade wet FGD, polishing fabric filter	\$8,852,380	Bridger WA	0.523	8.0		\$54,756,991	\$1,770,476	\$238,408,211
		Fitzpatrick WA	0.248	3.7		\$76,094,959	\$6,639,285	\$353,197,350
		Mt. Zirkel WA	0.715	14.3		\$82,380,948	\$1,475,397	\$138,216,474
Scenario 3: Existing LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance	\$17,187,631	Bridger WA	0.381	5.0		\$81,152,894	\$2,148,454	\$48,554,860
		Fitzpatrick WA	0.187	1.3		\$82,632,842	\$4,687,536	\$80,980,011
		Mt. Zirkel WA	0.455	5.0		\$49,002,245	\$1,120,982	\$31,976,566
Scenario 4: Existing LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	\$25,545,184	Bridger WA	0.338	4.3		\$88,049,663	\$2,716,752	\$501,912,024
		Fitzpatrick WA	0.154	1.3		\$111,585,548	\$6,421,414	\$2,119,84,101
		Mt. Zirkel WA	0.442	3.7		\$53,259,646	\$1,412,711	\$51,477,214

NOTES:  
Sample Calculations: Cost per dV Reduction for Scenario 1 for 2001 = \$2,494,828 / (0.814 - 0.424) = \$6,396,995  
Sample Calculations: Cost per Reduction in No. of Days Exceeding 0.5 dV for 2001 = \$2,494,828 / (20-7) = \$191,910.

## 5.0 Preliminary Assessment and Recommendations

---

As a result of the completed technical and economic evaluations, and consideration of the modeling analysis for Jim Bridger 2, the preliminary recommended BART controls for NO<sub>x</sub>, SO<sub>2</sub>, and PM are as follows:

- Existing LNBs and OFA system for NO<sub>x</sub> control
- Upgrade the existing wet sodium FGD for SO<sub>2</sub> control
- Add flue gas conditioning upstream of the existing ESP for PM control

The above recommendations were identified as Scenario 1 for the modeling analysis described in Section 4. Visibility improvements for all emission control scenarios were analyzed, and the results are compared below, utilizing a least-cost envelope, as outlined in the draft EPA 1990 *New Source Review Workshop Manual* (EPA, 1990, hereafter referred to as NSR Manual). The purpose of this analysis is to use an objective, EPA-approved methodology to evaluate and make the final recommendation of BART control technology.

### 5.1 Least-cost Envelope Analysis

For the control scenarios modeled in Section 4, Tables 5-1 through 5-3 list the total annualized cost, cost per dV reduction, and cost per reduction in number of days above 0.5 dV for each of the three Class I areas. A comparison of the incremental results between selected scenarios is provided in Tables 5-4 through 5-6. Figures 5-1 to 5-6 show the total annualized cost versus number of days above 0.5 dV, and the total annualized cost versus 98<sup>th</sup> percentile ΔdV reduction, for the three Class I areas.

#### 5.1.1 Analysis Methodology

On page B-41 of the New Source Manual, EPA states that "incremental cost-effectiveness comparisons should focus on annualized cost and emission reduction differences between dominant alternatives. Dominant set of control alternatives are determined by generating what is called the envelope of least-cost alternatives. This is a graphical plot of total annualized costs for a total emissions reductions for all control alternatives identified in the BACT analysis..."

An analysis of incremental cost effectiveness has been conducted. This analysis was performed in the following way. First, the control option scenarios are ranked in ascending order of annualized total costs, as shown in Tables 5-1 through 5-3. The incremental cost effectiveness data, expressed per day and per dV, represents a comparison of the different scenarios, and is summarized in Tables 5-4 through 5-6 for each of the three wilderness areas. Then the most reasonable smooth curve of least-cost control option scenarios is plotted for each analysis. Figures 5-1 through 5-6 present the two analyses (cost per dV reduction and cost per reduction in number of days above 0.5 dV) for each of the three Class I areas affected by the operation of Jim Bridger 2.

In Figure 5-1, the four scenarios are compared as a graph of total annualized cost versus number of days above 0.5 dV. EPA states that "in calculating incremental costs, the analysis should only be conducted for control options that are dominant among all possible options." In Figure 5-1, the dominant set of control options, Scenarios 1, 3 and 4, represent the least-cost envelope depicted by the curvilinear line connecting them. Scenario 2 is an inferior option and should not be considered in the derivation of incremental cost effectiveness. Scenario 2 represents inferior controls, because Scenario 1 provides approximately the same amount of visibility impact reduction for less cost than Scenario 2. The incremental cost effectiveness is determined by the difference in total annual costs between two contiguous scenarios divided by the difference in emissions reduction.

**TABLE 5-1**  
Control Scenario Results for the Bridger Class 1 Wilderness Area  
*Jim Bridger 2*

Scenario	Controls	98 <sup>th</sup> Percentile deciview (dV) Reduction	Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet Flue Gas Desulfurization (FGD), Electrostatic Precipitator (ESP)	0.00	0.0	\$0.0	\$0.0	\$0.0
1	Existing Low-NOx burner (LNB) with OFA; upgraded wet FGD system, and Flue Gas Conditioning (FGC) for enhanced ESP performance	0.14	4.3	\$2.5	\$18.5	\$0.6
2	LNB with OFA, upgraded wet FGD system, and new polishing fabric filter	0.16	5.0	\$8.9	\$54.8	\$1.8
3	LNB with OFA and SCR, upgraded wet FGD system, FGC for enhanced ESP performance	0.33	8.0	\$17.2	\$51.6	\$2.1
4	LNB with OFA and SCR, upgraded wet FGD system, new polishing fabric filter	0.35	8.7	\$23.5	\$68.0	\$2.7

**TABLE 5-2**  
**Control Scenario Results for the Fitzpatrick Class I Wilderness Area**  
*Jim Bridger 2*

Scenario	Controls	98 <sup>th</sup> Percentile dV Reduction	Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet FGD and ESP	0.00	0.0	\$0.0	\$0.0	\$0.0
1	Existing LNB with OFA, upgraded wet FGD system, and FGC for enhanced ESP performance	0.10	1.7	\$2.5	\$25.4	\$1.5
2	LNB with OFA, upgraded wet FGD system, and new polishing fabric filter	0.12	1.3	\$8.9	\$76.1	\$6.6
3	LNB with OFA and SCR, upgraded wet FGD system, FGC for enhanced ESP performance	0.21	3.7	\$17.2	\$82.6	\$4.7
4	LNB with OFA and SCR, upgraded wet FGD system, new polishing fabric filter.	0.21	3.7	\$23.5	\$111.6	\$6.4

**TABLE 5-3**  
**Control Scenario Results for the Mt. Zirkel Class I Wilderness Area**  
*Jim Bridger 2*

Scenario	Controls	98 <sup>th</sup> Percentile dV Reduction	Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet FGD and ESP	0.00	0.0	\$0.0	\$0.0	\$0.0
1	Existing LNB with OFA, upgraded wet FGD system, and FGC for enhanced ESP performance	0.12	5.3	\$2.5	\$20.2	\$0.5
2	LNB with OFA, upgraded wet FGD system, and new polishing fabric filter.	0.17	6.0	\$8.9	\$52.4	\$1.5
3	LNB with OFA and SCR, upgraded wet FGD system, FGC for enhanced ESP performance	0.43	15.3	\$17.2	\$40.0	\$1.1
4	LNB with OFA and SCR, upgraded wet FGD system, new polishing fabric filter.	0.44	16.7	\$23.5	\$53.3	\$1.4

**TABLE 5-4**  
**Brider Class I Wilderness Area Incremental Analysis Data**  
Jim Bridger 2

Options Compared	Incremental Reduction in Days Above 0.5 deciview (dV) (Days)	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	4.3	0.14	\$0.58	\$18.5
Scenario 1 and Scenario 2	0.7	0.03	\$9.5	\$238.4
Scenario 1 and Scenario 3	3.7	0.20	\$4.0	\$74.1
Scenario 1 and Scenario 4	4.3	0.21	\$4.9	\$99.8


**TABLE 5-5**  
**Fitzpatrick Class I Wilderness Area Incremental Analysis Data**  
Jim Bridger 2

Options Compared	Incremental Reduction in Days Above 0.5 deciview (dV) (Days)	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	1.7	0.10	\$1.50	\$25.4
Scenario 1 and Scenario 2	NA	0.02	NA	\$353.2
Scenario 1 and Scenario 3	2.0	0.11	\$7.3	\$134.0
Scenario 1 and Scenario 4	2.0	0.11	\$10.5	\$186.8


**TABLE 5-6**  
**Mt. Zirkel Class I Wilderness Area Incremental Analysis Data**  
Jim Bridger 2

Options Compared	Incremental Reduction in Days Above 0.5 dV (Days)	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	5.3	0.12	\$0.47	\$20.23
Scenario 1 and Scenario 2	0.7	0.05	\$9.5	\$139.2
Scenario 1 and Scenario 3	10.0	0.31	\$1.5	\$48.0
Scenario 1 and Scenario 4	11.3	0.32	\$1.9	\$66.1


**FIGURE 5-1**  
**Least-cost Envelope Bridger Class I Wilderness Area Days Reduction**  
*Jim Bridger 2*




**FIGURE 5-2**  
**Least-cost Envelope Bridger Wilderness Area Class I Area 98<sup>th</sup> Percentile Reduction**  
*Jim Bridger 2*




**FIGURE 5-3**  
Least-cost Envelope Fitzpatrick Class I Wilderness Area Days Reduction  
*Jim Bridger 2*




**FIGURE 5-4**  
Least-cost Envelope Fitzpatrick Class I Wilderness Area 98<sup>th</sup> Percentile Reduction  
*Jim Bridger 2*



**FIGURE 5-5**  
Least-cost Envelope Mt. Zirkel Class I Wilderness Area Days Reduction  
*Jim Bridger 2*



**FIGURE 5-6**  
Least-cost Envelope Mt. Zirkel Class I Wilderness Area 98<sup>th</sup> Percentile Reduction  
*Jim Bridger 2*



### 5.1.2 Analysis Results

Results of the least-cost analysis, shown in Tables 5-1 through 5-6 and Figures 5-1 through 5-6 on the preceding pages, confirm the selection of Scenario 1, based on incremental cost and visibility improvements. Scenario 2 is eliminated because it is to the left of the curve formed by the dominant control alternative scenarios, which indicates a scenario with lower improvement and/or higher costs. Scenario 3 is not selected due to very high incremental costs for both a cost per day of improvement and a cost per dV reduction. While Scenario 4 provides some potential visibility advantage over Scenario 1, the projected improvement is less than half a dV, and the projected costs are excessive.

Analysis of the results for the Jim Bridger Class 1WA in Tables 5-1 and 5-4 and Figures 5-1 and 5-2 illustrates the conclusions stated above. The greatest reduction in 98<sup>th</sup> percentile dV and number of days above 0.5 dV is between the baseline and Scenario 1. The incremental cost effectiveness for Scenario 1 compared with the baseline for the Bridger WA, for example, is reasonable at \$580,000 per day and \$18.5 million per deciview. However, the incremental cost effectiveness for Scenario 3 compared with Scenario 1 is excessive at \$4.0 million per day and \$71.1 million per deciview. The same conclusions are reached for each of the three WAs studied. Therefore, Scenario 1 represents BART for Jim Bridger 2.

## 5.2 Recommendations

### 5.2.1 NO<sub>x</sub> Emission Control

The BART presumptive NO<sub>x</sub> limit assigned by EPA for tangentially fired boilers burning sub-bituminous coal is 0.15 lb per MMBtu. However, as documented in Section 3.2.1, the characteristics of the Jim Bridger coals are more closely aligned with bituminous coals, with a presumptive BART NO<sub>x</sub> limit of 0.28 lb per MMBtu:

CH2M HILL recommends the existing LNBs with OFA (LNB with OFA) as BART for Jim Bridger 2, based on the projected significant reduction in NO<sub>x</sub> emissions, reasonable control costs, and the advantages of no additional power requirements or non-air quality environmental impacts. NO<sub>x</sub> reductions have been realized at Jim Bridger 2. CH2M HILL recommends that the unit be permitted at a rate of 0.26 lb per MMBtu.

### 5.2.2 SO<sub>2</sub> Emission Control

CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 2, based on the significant reduction in SO<sub>2</sub> emissions, reasonable control costs, and the advantages of minimal additional power requirements and minimal non-air quality environmental impacts. This upgrade approach will meet the BART presumptive SO<sub>2</sub> limit of 0.15 lb per MMBtu.

### 5.2.3 PM<sub>10</sub> Emission Control

CH2M HILL recommends finalizing the permitting of the FGC system to enhance the performance of the existing ESP as BART for Jim Bridger 2, based on the significant reduction in PM<sub>10</sub> emissions, reasonable control costs, and the advantages of minimal additional power requirements and no non-air quality environmental impacts.

### 5.3 Just-Noticeable Differences in Atmospheric Haze

Conclusions reached in the reference document "Just-Noticeable Differences in Atmospheric Haze" by Dr. Ronald Henry (2002), state that only dV differences of approximately 1.5 to 2.0 dV, or more are perceptible by the human eye. Deciview changes of less than 1.5 cannot be distinguished by the average person. Therefore, the modeling analysis results indicate that only minimal, if any, observable visibility improvements at the Class I areas studied would be expected under any of the scenarios. Thus the results indicate that even though many millions of dollars will be spent, only minimal, if any, visibility improvements could result.

None of the data were corrected for natural obscuration. Water in various forms (fog, clouds, snow, or rain) or other naturally caused aerosols can obscure the atmosphere and reduce visibility. During the period of 2001 through 2003, there were several mega-wildfires that lasted for many days, with a significant impact on background visibility in these Class 1 areas. If natural obscuration lessens the achievable reduction in visibility impacts modeled for BART controls at the Jim Bridger 2 facility, the overall effect would be to increase the costs per dV reduction that are presented in this report.

## 6.0 References

---

- 40 CFR Part 51. *Regional Haze Regulations and Guidelines for Best Available Retrofit Technology Determinations; Final Rule.* July 6, 2005.
- Energy Information Administration, 2006. *Official Energy Statistics from the U.S. Government: Coal.* <http://www.eia.doe.gov/fuelcoal.html>. Accessed October 2006.
- EPA, 1990. *New Source Review Workshop Manual—Prevention of Significant Deterioration and Nonattainment Area Permitting.* Draft. October 1990.
- EPA, 2003. *Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule.* Environmental Protection Agency. EPA-454/8-03-005. September 2003.
- Henry, Ronald, 2002. "Just-Noticeable Differences in Atmospheric Haze," *Journal of the Air & Waste Management Association.* Volume 52, p. 1238.
- 
- National Oceanic and Atmospheric Administration, 2006. U.S. Daily Weather Maps Project. [http://docs.lib.noaa.gov/rescue/dwm/data\\_rescue\\_daily\\_weather\\_maps.html](http://docs.lib.noaa.gov/rescue/dwm/data_rescue_daily_weather_maps.html). Accessed October 2006.
- North Dakota Department of Health, 2005. *Protocol for BART-Related Visibility Improvement Modeling Analysis in North Dakota.* North Dakota Department of Health. October 26, 2005.
- Sargent & Lundy, 2002. *Multi-Pollutant Control Report.* October 2002.
- Sargent & Lundy, 2006. *Multi-Pollutant Control Report.* Revised. October 2006.
- WDEQ-AQD, 2006. *BART Air Modeling Protocol—Individual Source Visibility Assessments for BART Control Analyses.* Wyoming Department of Environmental Quality – Air Quality Division. September 2006.

**APPENDIX A**  
**Economic Analysis**

---

Pacific BART Analysis Scenarios

Select Unit:		Jim Bridger/Unit 2	
Index No.	Name of Unit:	4	
1	Dave Johnston Unit 3		
2	Dave Johnston Unit 4		
3	Jim Bridger Unit 1		
4	Jim Bridger Unit 2		
5	Jim Bridger Unit 3		
6	Jim Bridger Unit 4		
7	Naughton Unit 1		
8	Naughton Unit 2		
9	Naughton Unit 3		
10	Wyodak Unit 1		

Dave Johnston		Naughton			
DJ Unit 3	DJ Unit 4	NTN Unit 1		NTN Unit 2	
First Year Cost	Scenario Baseline - Current Operation with ESP	First Year Cost	Scenario Baseline - Current Operation with ESP	First Year Cost	Scenario Baseline - Current Operation with ESP
N/A	Scenario 1 - LNB with OFA, Dry FGD, Existing ESP	N/A	Scenario 1 - LNB with OFA, Dry FGD, Fabric Filter	N/A	Scenario 1 - LNB with OFA, Wet FGD, Existing ESP
N/A	Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter
N/A	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	N/A	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	N/A	Scenario 3 - LNB with OFA and SCR, Wet FGD, Existing ESP
N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, Existing ESP, New Stack	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter

JB Unit 1		JB Unit 2		JB Unit 3		JB Unit 4		WDK Unit 1		WDK Unit 2	
Scenario	First Year Cost	Scenario	First Year Cost								
Baseline - Current Operation with Wet FGD and ESP	\$ 2,484,828	Baseline - Current Operation with Wet FGD and ESP	\$ 2,484,828	Baseline - Current Operation with Wet FGD and ESP	\$ 2,484,828	Baseline - Current Operation with Wet FGD and ESP	\$ 2,484,828	Baseline - Current Operation with Wet FGD and ESP	\$ 2,484,828	Baseline - Current Operation with Wet FGD and ESP	\$ 2,484,828
Scenario 1 - LNB with OFA, Wet FGD, ESP	N/A	Scenario 1 - LNB with OFA, Wet FGD, ESP	\$ 2,484,828	Scenario 1 - LNB with OFA, Wet FGD, ESP	\$ 2,484,828	Scenario 1 - LNB with OFA, Wet FGD, ESP	\$ 2,484,828	Scenario 1 - LNB with OFA, Wet FGD, Fabric Filter	\$ 2,484,828	Scenario 1 - LNB with OFA, Dry FGD, Fabric Filter	N/A
Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	\$ 8,882,380	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	\$ 8,882,380	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	\$ 8,882,380	Scenario 2 - LNB with OFA, Wet FGD, Fabric Filter	\$ 8,882,380	Scenario 2 - LNB with OFA, and SCR, Dry FGD, Fabric Filter	N/A
Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	N/A	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	\$ 17,187,631	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	\$ 17,187,631	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	\$ 17,187,631	Scenario 3 - LNB with OFA and SCR, Wet FGD, Fabric Filter	\$ 17,187,631	Scenario 3 - LNB with OFA and SCR, Wet FGD, and SCR, Dry FGD, Fabric Filter	N/A
Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	\$ 23,545,184	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	\$ 23,545,184	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	\$ 23,545,184	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	\$ 23,545,184	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A

## ECONOMIC ANALYSIS SUMMARY

Jim Bridger Unit 2

Boiler Design:

Tangential-Fired PC

Parameter	Current Operation	NOX Control				SO2 Control		PM Control	
		Exist. LNB w/o FA	ROFA	SNCR	SCR	Upgraded Wet FGD	LNB - TFS 2000 Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
Case	1	2	3	4	5	6	7	8	9
NOx Emission Control System	LNB-TFS 2000 Exist. LNB w/o FA Wet FGD ESP	ROFA Wet FGD ESP	SNCR Wet FGD ESP	SCR Wet FGD ESP	LNB - TFS 2000 Upgraded Wet FGD	Flue Gas Conditioning	LNB - TFS 2000 Wet FGD	LNB - TFS 2000 Wet FGD	10
SO2 Emission Control System									
PM Emission Control System									
<b>TOTAL INSTALLED CAPITAL COST (\$)</b>	<b>0</b>	<b>0</b>	<b>20,529,122</b>	<b>13,427,239</b>	<b>120,875,494</b>	<b>12,989,900</b>	<b>0</b>	<b>48,386,333</b>	
<b>FIRST YEAR O&amp;M COST (\$)</b>									
Operating Labor (\$)	0	0	0	0	0	0	0	0	0
Maintenance Material (\$)	0	0	42,000	95,000	142,500	243,000	25,550	0	51,098
Maintenance Labor (\$)	0	0	63,000	0	0	0	17,033	10,000	76,649
Administrative Labor (\$)	0	0	0	0	0	0	0	0	0
<b>TOTAL FIXED O&amp;M COST</b>	<b>0</b>	<b>0</b>	<b>105,000</b>	<b>237,500</b>	<b>405,000</b>	<b>42,583</b>	<b>10,000</b>	<b>121,749</b>	
Makeup Water Cost	0	0	0	0	0	30,503	0	0	0
Reagent Cost	0	0	0	536,432	912,848	533,206	145,854	0	0
SCR Catalyst / FF Bag Cost	0	0	0	0	584,000	0	0	300,040	0
Waste Disposal Cost	0	0	0	0	0	442,958	0	18,710	1,326,877
Electric Power Cost	0	0	2,528,012	208,926	1,282,338	208,926	1,215,593	165,564	1,526,971
<b>TOTAL VARIABLE O&amp;M COST</b>	<b>0</b>	<b>0</b>	<b>2,538,012</b>	<b>745,358</b>	<b>2,783,181</b>	<b>1,268,176</b>	<b>175,564</b>	<b>1,754,666</b>	
<b>TOTAL FIRST YEAR O&amp;M COST</b>	<b>0</b>	<b>0</b>	<b>2,633,012</b>	<b>982,858</b>	<b>3,194,181</b>	<b>1,268,176</b>	<b>175,564</b>	<b>1,754,666</b>	
<b>FIRST YEAR DEBT SERVICE (\$)</b>	<b>0</b>	<b>0</b>	<b>1,932,798</b>	<b>1,277,304</b>	<b>11,983,623</b>	<b>1,236,652</b>	<b>0</b>	<b>4,602,887</b>	
<b>TOTAL FIRST YEAR COST (\$)</b>	<b>0</b>	<b>0</b>	<b>4,565,808</b>	<b>2,260,162</b>	<b>14,592,803</b>	<b>2,494,828</b>	<b>175,564</b>	<b>6,357,552</b>	
Power Consumption (MW)	0.0	0.0	6.4	0.5	3.3	0.5	0.1	3.4	
Annual Power Usage (Million kW-Hr/Yr)	0.0	0.0	60.6	4.2	25.6	4.2	0.4	26.5	
<b>CONTROL COST (\$/Ton Removed)</b>									
NOx Removal Rate (%)	0.0%	0.0%	8.3%	16.7%	70.8%	0.0%	0.0%	0.0%	0.0%
NOx Removed (Tons/Yr)	0	0	473	946	4,021	0	0	0	0
First Year Average Control Cost (\$/Ton NOx Rem.)	0	0	9,895	2,388	3,654	0	0	0	0
Incremental Control Cost (\$/Ton NOx Removed)	0	0	9,695	2,389	4,044	0	0	0	0
SO2 Removal Rate (%)	77.3%	0.0%	0.0%	0.0%	0.0%	62.5%	0.0%	0.0%	0.0%
SO2 Removed (Tons/Yr)	0	0	0	0	0	3,950	0	0	0
First Year Average Control Cost (\$/Ton SO2 Rem.)	0	0	0	0	0	632	0	0	0
Incremental Control Cost (\$/Ton SO2 Removed)	0	0	0	0	0	632	0	0	0
PM Removal Rate (%)	99.13%	-0.00%	0.00%	0.00%	0.00%	0.00%	59.45%	79.75%	
PM Removed (Tons/Yr)	0	0	0	0	0	0	1,041	1,395	
First Year Average Control Cost (\$/Ton PM Rem.)	0	0	0	0	0	0	169	4,556	
Incremental Control Cost (\$/Ton PM Removed)	0	0	0	0	0	0	169	17,446	
<b>PRESENT WORTH COST (\$)</b>	<b>0</b>	<b>0</b>	<b>52,697,833</b>	<b>25,435,659</b>	<b>159,901,524</b>	<b>28,372,107</b>	<b>2,145,015</b>	<b>69,824,582</b>	

## INPUT CALCULATIONS

Jim Bridger Unit 2

Boiler Design:

Tangential-Fired PC

Parameter	Current Operation	NOx Control				SO2 Control				PM Control		Comments
		Exist. LNB w/OFA	ROFA	SNCR	SCR	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter	10			
Case	1	2	3	4	5	8	9					
Net Emission Control System	LNB-TFS 2000 Wet FGD ESP	Exist. LNB w/OFA Wet FGD ESP	ROFA Wet FGD ESP	SNCR Wet FGD ESP	SCR Wet FGD ESP	LNB - TFS 2000 Upgraded Wet FGD ESP	LNB - TFS 2000 Wet FGD Flue Gas Conditioning					
SC2 Emission Control System												
PM Emission Control System												
Unit Design and Coal Characteristics												
Type of Unit	PC	PC	PC	PC	PC	PC	PC					
Net Power Output (kW)	650,000	530,000	650,000	530,000	650,000	650,000	650,000					
Net Plant Heat Rate (Btu/kWh-ft)	11,320	11,320	11,320	11,320	11,320	11,320	11,320					
Boiler Fuel	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground					
Coal Heating Value (Btu/lb)	9,650	9,650	9,650	9,650	9,650	9,650	9,650					
Coal Sulfur Content (wt. %)	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%					
Coal Ash Content (wt. %)	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%					
Boiler Heat Input, each (MMBtu/hr)	6,000	6,000	6,000	6,000	6,000	6,000	6,000					
Coal Flow Rate (Lb/hr)	621,077	621,077	621,077	621,077	621,077	621,077	621,077					
(Ton/Yr) (MMBtu/hr)(yr)	2,448,284 47,300,846	2,448,284 47,300,846	2,448,284 47,300,846	2,448,284 47,300,846	2,448,284 47,300,846	2,448,284 47,300,846	2,448,284 47,300,846					
Emissions												
Uncontrolled SO2 (Lb/hr)	7,210	1,602	1,602	1,602	1,602	1,602	1,602					
(Lb/MMBtu)	1.20	0.27	0.27	0.27	0.27	0.27	0.27					
(Lb/Mole/hr)	112.54	25.00	25.00	25.00	25.00	25.00	25.00					
(Tons/hr)	28,421	6,315	6,315	6,315	6,315	6,315	6,315					
SO2 Removal Rate (%)	77.8%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%					
SO2 Removal Rate (%) (Lb/Hr)	6,608	0	0	0	0	0	0					
SO2 Emission Rate (Lb/Hr)	22,016	0	0	0	0	0	0					
(Lb/MMBtu)	1,602	1,602	1,602	1,602	1,602	1,602	1,602					
(Ton/hr)	0.27	0.27	0.27	0.27	0.27	0.27	0.27					
Uncontrolled NOx (Lb/hr)	6,315	6,315	6,315	6,315	6,315	6,315	6,315					
(Lb/MMBtu)	1.24	1,440	1,440	1,440	1,440	1,440	1,440					
(Lb/Mole/hr)	47.98	47.98	47.98	47.98	47.98	47.98	47.98					
(Tons/hr)	5,676	5,676	5,676	5,676	5,676	5,676	5,676					
NOx Removal Rate (%)	0.0%	0.0%	8.3%	16.7%	25.0%	33.3%	41.7%					
(Lb/Hr)	0	0	120	240	360	480	600					
(Lb/Mole/hr)	0	0	4,000	8,000	12,000	16,000	20,000					
(Ton/hr)	0	0	473	946	1,320	1,693	2,066					
NOx Emission Rate (Lb/Hr)	1,440	1,440	1,440	1,440	1,440	1,440	1,440					
(Lb/MMBtu)	0.24	0.24	0.24	0.24	0.24	0.24	0.24					
(Ton/hr)	5,676	5,676	5,676	5,676	5,676	5,676	5,676					
Uncontrolled Fly Ash (Lb/hr)	51,177	444	444	444	444	444	444					
(Lb/MMBtu)	8,330	0.074	0.074	0.074	0.074	0.074	0.074					
(Lb/Mole/hr)	1,705.3	14.8	14.8	14.8	14.8	14.8	14.8					
(Tons/hr)	201,759	1,750	1,750	1,750	1,750	1,750	1,750					
Fly Ash Removal Rate (%)	99.13%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%					
(Lb/Hr)	50,733	0	0	0	0	0	0					
(Ton/Hr)	199,988	0	0	0	0	0	0					
Fly Ash Emission Rate (Lb/hr)	444	444	444	444	444	444	444					
(Lb/MMBtu)	-0.074	0.074	0.074	0.074	0.074	0.074	0.074					
(Ton/hr)	1,750	1,750	1,750	1,750	1,750	1,750	1,750					

E1020207001SLCApp\_A\_PComp\_JB2 BART Economic Analysis\_01-12-07.xls

1-of 2

Parameter	Current Operation	NOx Control				SO2 Control		PM Control		Comments
		Exist. LNB w/OFA	ROFA	SNCR	SCR	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter		
Case	1	2	3	4	5	6	7	8	9	10
General Plant Data										
Annual On-Site Power Plant Capacity Factor	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90
Inherent Failure Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%
Discount Rate (%)	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0
Installed Capital Costs										
NOx Emission Control System (\$2006)	0	0	20,528,122	13,427,239	120,875,484	0	0	0	0	0
SO2 Emission Control System (\$2006)	0	0	0	0	0	12,939,300	0	0	48,386,333	48,386,333
PM Emission Control Systems (\$2006)	0	0	20,528,122	13,427,239	120,875,484	12,939,300	0	0	0	0
Total Emission Control Systems (\$2006)	0	0	0	0	0	228	0	0	0	0
PM Emission Control System (\$kW)	0	0	0	0	0	0	25	0	0	0
Total Emission Control Systems (\$kW)	0	0	0	0	0	0	0	0	0	0
Operating Labor (\$)	0	0	0	0	0	0	0	0	0	0
Maintenance Material (\$)	0	0	42,000	95,000	162,000	0	0	0	0	0
Administrative Labor (\$)	0	0	65,000	142,500	243,000	0	0	0	51,039	51,039
Total Fixed O&M Cost (\$)	0	0	0	0	0	0	0	0	76,649	76,649
Annual Fixed O&M Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%
Water Cost										
Market Water Usage (Gpm)	0	0	0	0	0	0	0	0	0	0
Unit Price (\$/1000 Gallons)	1.22	1.22	1.22	1.22	1.22	0.00	1.12	1.12	1.22	1.22
First Year Water Cost (\$)	0	0	0	0	0	0	0	0	0	0
Annual Water Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%
Reagent Cost										
Unit Cost (\$/ton)	None	None	None	None	None	Anhydrous NH3	Soda Ash	Elemental Sulfur	None	None
Unit Price (\$/LB)	0.00	0.00	0.00	0.00	0.00	400	80.00	370	0.00	0.00
Motor Sleichmetry	0.00	0.00	0.00	0.00	0.00	0.200	0.040	0.185	0.000	0.000
Reagent Purity (W%)	100%	100%	100%	100%	100%	0.45	1.02	0.00	0.00	0.00
Reagent Usage (L/batch)	0	0	0	0	0	100%	100%	100%	0	0
First Year Reagent Cost (\$)	0	0	0	0	0	579	1,631	145,854	0	0
Annual Reagent Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	584,432	53,206	2,00%	2.00%	2.00%
SER Catalyst / FF Bag Replacement Cost	0	0	0	0	0	0	0	0	Bigis	Bigis
Annual SER Catalyst / FF Bag Replacement Cost	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	2,00%	2,00%
Annual SER Catalyst / FF Bag Replace. Cost (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%
FF/EDD Solid Waste Disposal Cost	0	0	24.33	24.33	24.33	0	0	0	0	0
Annual FF/EDD Solid Waste Disposal Unit Cost (\$/Ton)	24.33	0	0	0	0	24.33	24.33	24.33	24.33	24.33
Annual FF/EDD Solid Waste Disposal Cost (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%
Annual Animal Waste Disposal Cost Esc. Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%
Auxiliary Power Cost										
Auxiliary Power Requirement (% of Plant Output)	0.00%	0.00%	0.00%	0.00%	0.00%	1.21%	0.10%	0.10%	0.01%	0.64%
Init. Aux. Power (\$/MMBtu)	0.00	0.00	50.00	50.00	50.00	6.41	0.53	3.25	0.05	3.37
Annual Aux. Power Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2,528,012	50,000	50,000	60,000	50,000
Annual Aux. Power Cost (\$/MMBtu)	0.00	0.00	0.00	0.00	0.00	2,528,012	208,936	1,222,333	19,710	12,677

## Input Tables

Table 1 - Cases

Index No.	Name of Unit   Case →	Existing		NOx Control		SO2 Control		PM Control		
		1	2	3	4	5	6	7	8	9
1	Dave Johnston Unit 3	Current Operation	LNB w/FOA	ROFA	LNB w/FOA & SNCR	LNB w/FOA & SCR	Dry FGD w/ESP	Dry FGD w/Fabric Filter	Wet FGD w/ESP	N/A
2	Dave Johnston Unit 4	Current Operation	LNB w/FOA	ROFA	LNB w/FOA & SNCR	LNB w/FOA & SCR	Dry FGD w/ESP	Dry FGD w/Fabric Filter	Wet FGD w/Fabric Filter	N/A
3	Jim Bridger Unit 1	Current Operation	LNB w/FOA	ROFA	LNB w/FOA & SNCR	LNB w/FOA & SCR	N/A	N/A	Upgraded Wet FGD	Fabric Filter
4	Jim Bridger Unit 2	Current Operation	East LNB w/FOA	ROFA	LNB w/FOA & SNCR	LNB w/FOA & SCR	N/A	N/A	Upgraded Wet FGD	Fabric Filter
5	Jim Bridger Unit 3	Current Operation	LNB w/FOA	ROFA	LNB w/FOA & SNCR	LNB w/FOA & SCR	N/A	N/A	Upgraded Wet FGD	Fabric Filter
6	Jim Bridger Unit 4	Current Operation	LNB w/FOA	ROFA	LNB w/FOA & SNCR	LNB w/FOA & SCR	N/A	N/A	Upgraded Wet FGD	Fabric Filter
7	Naughton Unit 1	Current Operation	LNB w/FOA	ROFA	LNB w/FOA & SNCR	LNB w/FOA & SCR	Dry FGD w/ESP	Dry FGD w/Fabric Filter	Wet FGD w/ESP	Fabric Filter
8	Naughton Unit 2	Current Operation	LNB w/FOA	ROFA	LNB w/FOA & SNCR	LNB w/FOA & SCR	Dry FGD w/ESP	Dry FGD w/Fabric Filter	Wet FGD w/ESP	Fabric Filter
9	Naughton Unit 3	Current Operation	East LNB w/FOA	ROFA	SNCR	LNB w/FOA & SCR	N/A	N/A	Upgraded Wet FGD	Fabric Filter
10	Wyodak Unit 1	Current Operation	LNB w/FOA	ROFA	LNB w/FOA & SNCR	LNB w/FOA & SCR	N/A	N/A	Wet FGD	Fabric Filter

Table 2 - Unit Design and Coal Characteristics

Index No.	Name of Unit	Current Emission Control Systems			Unit Design		Coal Quality			
		NOx	SO2	PM	Boiler Design	Net Power Output (kW)	Net Plant Heat Rate (Btu/kWh)	Coal	Heating Value HHV (Btu/lb)	Sulfur Content (Wt %)
1	Dave Johnston Unit 3	None	None	ESP	3-Call Burner, Opposed Wall-Fired PC	260,000	11,120	Dry Fork PRB	7,784	0.47%
2	Dave Johnston Unit 4	Line Added to Venturi Scrubber	Linebox Mod., LNCFs-1 & Windbox Mod.	Venturi Scrubber	Tangential-Fired PC	360,000	11,390	Dry Fork PRB	7,784	0.47%
3	Jim Bridger Unit 1	None	None	ESP	Tangential-Fired PC	630,000	11,320	Bridger Mine, Underground	9,660	0.53%
4	Jim Bridger Unit 2	LNCFs-2000	Wet FGD	ESP	Tangential-Fired PC	630,000	11,320	Bridger Mine, Underground	9,660	0.53%
5	Jim Bridger Unit 3	LNCFs-1 & Windbox Mod.	Wet FGD	ESP	Tangential-Fired PC	630,000	11,320	Bridger Mine, Underground	9,660	0.53%
6	Jim Bridger Unit 4	LNCFs-1 & Windbox Mod.	Wet FGD	ESP	Tangential-Fired PC	630,000	11,320	Bridger Mine, Underground	9,660	0.53%
7	Naughton Unit 1	None	None	ESP	Tangential-Fired PC	173,000	10,954	Kemmerer Mine	9,970	0.60%
8	Naughton Unit 2	None	None	ESP	Tangential-Fired PC	226,000	10,374	Kemmerer Mine	9,970	0.60%
9	Naughton Unit 3	LNCFs II LNB	Wet FGD	ESP	Tangential-Fired PC	356,000	10,336	Kemmerer Mine	9,970	0.60%
10	Wyodak Unit 1	LNB	Dry FGD	ESP	Opposed Wall-Fired PC	335,000	12,087	Cliod's Point Mine	7,977	0.65%

**Table 3 - Emissions**

Index No.	Name of Unit	Current Emission Rates (LB/MMBtu)		NOx Control Emission Rates (LB/MMBtu)				SO2 Control Emission Rates (LB/MMBtu)				PM Emission Rates (LB/MMBtu)	
		Controlled SO2	Controlled NOx	PM	Case 2	Case 3	Case 4	Case 5	Case 6	Case 7	Case 8	Case 9	Case 10
1	Dave Johnston Unit 3	1.20	0.70	0.200	0.27	0.21	0.20	0.07	0.21	0.16	0.10	N/A	0.015
2	Dave Johnston Unit 4	0.33	0.48	0.051	0.16	0.19	0.12	0.07	N/A	0.15	0.10	N/A	0.015
3	Jim Bridger Unit 1	0.27	0.45	0.046	0.24	0.22	0.20	0.07	N/A	0.10	0.10	0.030	0.015
4	Jim Bridger Unit 2	0.27	0.24	0.074	0.24	0.22	0.20	0.07	N/A	0.10	0.10	0.030	0.015
5	Jim Bridger Unit 3	0.27	0.45	0.087	0.24	0.22	0.20	0.07	N/A	0.10	0.10	0.030	0.015
6	Jim Bridger Unit 4	0.17	0.46	0.030	0.24	0.22	0.20	0.07	N/A	0.10	0.10	0.030	0.015
7	Naughton Unit 1	1.20	0.58	0.056	0.24	0.28	0.18	0.07	0.18	0.15	0.10	0.040	0.015
8	Naughton Unit 2	1.20	0.54	0.064	0.24	0.28	0.18	0.07	0.18	0.15	0.10	0.040	0.015
9	Naughton Unit 3	0.50	0.45	0.084	0.35	0.30	0.26	0.07	N/A	0.10	0.10	0.040	0.015
10	Wyodak Unit 1	0.60	0.50	0.030	0.23	0.22	0.18	0.07	0.25	0.25	0.10	0.025	0.015

**Table 4 - Case 1 O&M Costs (Current Operation)**

Index No.	Name of Unit	Annual Fixed O&M Costs			Variable Operating Requirements		
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent
1	Dave Johnston Unit 3	\$	\$	\$	\$	-	None
2	Dave Johnston Unit 4	\$	\$	\$	\$	-	None
3	Jim Bridger Unit 1	\$	\$	\$	\$	-	None
4	Jim Bridger Unit 2	\$	\$	\$	\$	-	None
5	Jim Bridger Unit 3	\$	\$	\$	\$	-	None
6	Jim Bridger Unit 4	\$	\$	\$	\$	-	None
7	Naughton Unit 1	\$	\$	\$	\$	-	None
8	Naughton Unit 2	\$	\$	\$	\$	-	None
9	Naughton Unit 3	\$	\$	\$	\$	-	None
10	Wyodak Unit 1	\$	\$	\$	\$	-	None

**Table 5 - Case 2 O&M Costs (LNB w/OFA)**

Index No.	Name of Unit	Annual Fixed O&M Costs			Variable Operating Requirements		
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent
1	Dave Johnston Unit 3	\$	\$	\$	\$	-	None
2	Dave Johnston Unit 4	\$	\$	\$	\$	-	None
3	Jim Bridger Unit 1	\$	\$	\$	\$	-	None
4	Jim Bridger Unit 2	\$	\$	\$	\$	-	None
5	Jim Bridger Unit 3	\$	\$	\$	\$	-	None
6	Jim Bridger Unit 4	\$	\$	\$	\$	-	None
7	Naughton Unit 1	\$	\$	\$	\$	-	None
8	Naughton Unit 2	\$	\$	\$	\$	-	None
9	Naughton Unit 3	\$	\$	\$	\$	-	None
10	Wyodak Unit 1	\$	\$	\$	\$	-	None

Table 6 - Case 3 O&amp;M Costs (Mobiletec ROFA)

Annual Fixed O&M Costs				Variable Operating Requirements			
Index No.	Name of Unit	Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent Stoich.
1	Dave Johnson Unit 3	\$ 90,000	\$ 60,000	\$ 90,000	\$ 42,000	-	-
2	Dave Johnson Unit 4	\$ 90,000	\$ 60,000	\$ 90,000	\$ 42,000	-	-
3	Jim Bridger Unit 1	\$ 63,000	\$ 42,000	\$ 63,000	\$ 42,000	-	-
4	Jim Bridger Unit 2	\$ 63,000	\$ 42,000	\$ 63,000	\$ 42,000	-	-
5	Jim Bridger Unit 3	\$ 63,000	\$ 42,000	\$ 63,000	\$ 42,000	-	-
6	Jim Bridger Unit 4	\$ 63,000	\$ 42,000	\$ 63,000	\$ 42,000	-	-
7	Naughton Unit 1	\$ 72,000	\$ 48,000	\$ 72,000	\$ 48,000	-	-
8	Naughton Unit 2	\$ 72,000	\$ 48,000	\$ 72,000	\$ 48,000	-	-
9	Naughton Unit 3	\$ 72,000	\$ 48,000	\$ 72,000	\$ 48,000	-	-
10	Wyodak Unit 1	\$ 64,000	\$ 36,000	\$ 64,000	\$ 36,000	-	-

Table 7 - Case 4 O&amp;M Costs (LNB w/OFA &amp; SNCR)

Annual Fixed O&M Costs				Variable Operating Requirements			
Index No.	Name of Unit	Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent Stoich.
1	Dave Johnson Unit 3	\$ 98,000	\$ 105,000	\$ 147,000	\$ 123,000	-	Urea
2	Dave Johnson Unit 4	\$ 98,000	\$ 105,000	\$ 147,000	\$ 123,000	-	Urea
3	Jim Bridger Unit 1	\$ 98,000	\$ 105,000	\$ 147,000	\$ 123,000	-	Urea
4	Jim Bridger Unit 2	\$ 98,000	\$ 105,000	\$ 147,000	\$ 123,000	-	Urea
5	Jim Bridger Unit 3	\$ 98,000	\$ 105,000	\$ 147,000	\$ 123,000	-	Urea
6	Jim Bridger Unit 4	\$ 98,000	\$ 105,000	\$ 147,000	\$ 123,000	-	Urea
7	Naughton Unit 1	\$ 83,000	\$ 124,500	\$ 83,000	\$ 124,500	-	Urea
8	Naughton Unit 2	\$ 93,000	\$ 139,500	\$ 93,000	\$ 139,500	-	Urea
9	Naughton Unit 3	\$ 75,000	\$ 112,500	\$ 75,000	\$ 112,500	-	Urea
10	Wyodak Unit 1	\$ 93,000	\$ 93,000	\$ 135,500	\$ 93,000	-	Urea

Table 8 - Case 5 O&amp;M Costs (LNB w/OFA &amp; SCR)

Annual Fixed O&M Costs				Variable Operating Requirements			
Index No.	Name of Unit	Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent Stoich.
1	Dave Johnson Unit 3	\$ 165,000	\$ 166,000	\$ 249,000	\$ 190,000	-	Anhydrous NH3
2	Dave Johnson Unit 4	\$ 165,000	\$ 166,000	\$ 249,000	\$ 162,000	-	Anhydrous NH3
3	Jim Bridger Unit 1	\$ 165,000	\$ 166,000	\$ 249,000	\$ 190,000	-	Anhydrous NH3
4	Jim Bridger Unit 2	\$ 165,000	\$ 166,000	\$ 249,000	\$ 190,000	-	Anhydrous NH3
5	Jim Bridger Unit 3	\$ 165,000	\$ 166,000	\$ 249,000	\$ 190,000	-	Anhydrous NH3
6	Jim Bridger Unit 4	\$ 165,000	\$ 166,000	\$ 249,000	\$ 190,000	-	Anhydrous NH3
7	Naughton Unit 1	\$ 132,000	\$ 198,000	\$ 160,000	\$ 246,000	-	Anhydrous NH3
8	Naughton Unit 2	\$ 132,000	\$ 198,000	\$ 160,000	\$ 246,000	-	Anhydrous NH3
9	Naughton Unit 3	\$ 155,000	\$ 234,000	\$ 181,000	\$ 271,500	-	Anhydrous NH3
10	Wyodak Unit 1	\$ 155,000	\$ 234,000	\$ 181,000	\$ 271,500	-	Anhydrous NH3

**Table 9 - Case 6 O&M Costs (Dry FGD)**

		Annual Fixed O&M Costs				Variable Operating Requirements			
Index No.	Name of Unit	Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 505,128	\$ 714,775	\$ 476,328	\$	173	Lime	1.15	2.49
2	Dave Johnston Unit 4	\$	\$	\$	\$	-	Lime	-	-
3	Jim Bridger Unit 1	\$	\$	\$	\$	-	Lime	-	-
4	Jim Bridger Unit 2	\$	\$	\$	\$	-	Lime	-	-
5	Jim Bridger Unit 3	\$	\$	\$	\$	-	Lime	-	-
6	Jim Bridger Unit 4	\$	\$	\$	\$	-	Lime	-	-
7	Naughton Unit 1	\$ 505,128	\$ 587,643	\$ 391,762	\$	120	Lime	1.40	1.64
8	Naughton Unit 2	\$ 606,128	\$ 860,174	\$ 573,044	\$	165	Lime	1.40	2.25
9	Naughton Unit 3	\$	\$	\$	\$	-	Lime	-	-
10	Wyodak Unit 1	\$	\$ 21,900	\$ 14,600	\$	25	Lime	1.10	0.11

**Table 10 - Case 7 O&M Costs (Dry FGD w/Fabric Filter)**

		Annual Fixed O&M Costs				Variable Operating Requirements			
Index No.	Name of Unit	Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 505,128	\$ 714,775	\$ 476,928	\$	173	Lime	1.15	3.88
2	Dave Johnston Unit 4	\$ 505,128	\$ 1,102,288	\$ 734,958	\$	248	Lime	1.10	1,738
3	Jim Bridger Unit 1	\$	\$	\$	\$	-	Lime	-	4.54
4	Jim Bridger Unit 2	\$	\$	\$	\$	-	Lime	-	-
5	Jim Bridger Unit 3	\$	\$	\$	\$	-	Lime	-	-
6	Jim Bridger Unit 4	\$	\$	\$	\$	-	Lime	-	-
7	Naughton Unit 1	\$ 505,128	\$ 632,680	\$ 459,286	\$	120	Lime	1.15	2.66
8	Naughton Unit 2	\$ 606,128	\$ 905,190	\$ 640,568	\$	165	Lime	1.15	3.63
9	Naughton Unit 3	\$	\$	\$	\$	-	Lime	-	-
10	Wyodak Unit 1	\$	\$	\$	\$	-	Lime	-	-

**Table 11 - Case 8 O&M Costs (Wet FGD)**

		Annual Fixed O&M Costs				Variable Operating Requirements			
Index No.	Name of Unit	Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Molar Stoich.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 809,804	\$ 1,182,587	\$ 785,391	\$	250	Lime	1.02	3.46
2	Dave Johnston Unit 4	\$ 809,804	\$ 1,430,784	\$ 953,856	\$	330	Soda Ash	1.02	6.23
3	Jim Bridger Unit 1	\$	\$ 25,860	\$ 17,033	\$	63	Soda Ash	1.02	0.53
4	Jim Bridger Unit 2	\$	\$ 25,860	\$ 17,033	\$	63	Soda Ash	1.02	0.53
5	Jim Bridger Unit 3	\$	\$ 25,550	\$ 17,033	\$	52	Soda Ash	1.02	0.52
6	Jim Bridger Unit 4	\$	\$ 25,550	\$ 17,033	\$	27	Soda Ash	1.02	0.53
7	Naughton Unit 1	\$ 809,804	\$ 963,598	\$ 642,393	\$	160	Lime	1.05	2.44
8	Naughton Unit 2	\$ 809,804	\$ 1,226,386	\$ 811,591	\$	220	Lime	1.05	3.30
9	Naughton Unit 3	\$	\$ 21,900	\$ 14,600	\$	66	Soda Ash	1.02	0.33
10	Wyodak Unit 1	\$ 303,677	\$ 328,496	\$ 216,998	\$	82	Lime	1.02	1.75

Table 12 - Case 9 O&amp;M Costs (Flue Gas Conditioning)

		Annual Fixed O&M Costs						Variable Operating Requirements					
Index No.	Name of Unit	Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent Use (L/hr)	Reagent Usage (L/hr)	Annual FF Bag Replace.	Aux. Power Usage (MW)			
1	Dave Johnson Unit 3	\$ -	\$ -	\$ -	\$ -	-	-	-	-	-	-	-	-
2	Dave Johnson Unit 4	\$ -	\$ -	\$ -	\$ -	\$ 10,000	\$ -	-	-	-	-	-	0.05
3	Jim Bridger Unit 1	\$ -	\$ -	\$ -	\$ -	\$ 10,000	\$ -	-	-	-	-	-	0.05
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	\$ 10,000	\$ -	-	-	-	-	-	0.05
5	Jim Bridger Unit 3	\$ -	\$ -	\$ -	\$ -	\$ 10,000	\$ -	-	-	-	-	-	0.05
6	Jim Bridger Unit 4	\$ -	\$ -	\$ -	\$ -	\$ 10,000	\$ -	-	-	-	-	-	0.05
7	Naughton Unit 1	\$ -	\$ -	\$ -	\$ -	\$ 10,000	\$ -	-	-	-	-	-	0.05
8	Naughton Unit 2	\$ -	\$ -	\$ -	\$ -	\$ 10,000	\$ -	-	-	-	-	-	0.05
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	\$ 10,000	\$ -	-	-	-	-	-	0.05
10	Wyodak Unit 1	\$ -	\$ -	\$ -	\$ -	\$ 10,000	\$ -	-	-	-	-	-	0.05

Table 13 - Case 10 O&amp;M Costs (Fabric Filter)

		Annual Fixed O&M Costs						Variable Operating Requirements					
Index No.	Name of Unit	Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent Use (Gpm)	Reagent Molar Stoch.	Annual FF Bag Replace.	Aux. Power Usage (MW)			
1	Dave Johnson Unit 3	\$ 45,016	\$ 67,524	\$ -	\$ -	-	-	-	-	-	1,457	-	1.38
2	Dave Johnson Unit 4	\$ 68,133	\$ 102,193	\$ 51,039	\$ 76,849	-	-	-	-	-	1,798	-	2.35
3	Jim Bridger Unit 1	\$ -	\$ 51,039	\$ -	\$ 76,849	-	-	-	-	-	2,885	-	3.39
4	Jim Bridger Unit 2	\$ -	\$ 51,039	\$ -	\$ 76,849	-	-	-	-	-	2,885	-	3.37
5	Jim Bridger Unit 3	\$ -	\$ 51,039	\$ -	\$ 76,849	-	-	-	-	-	2,827	-	3.33
6	Jim Bridger Unit 4	\$ -	\$ 51,039	\$ -	\$ 76,849	-	-	-	-	-	2,885	-	3.39
7	Naughton Unit 1	\$ -	\$ 45,016	\$ 67,524	\$ -	-	-	-	-	-	1,193	-	1.38
8	Naughton Unit 2	\$ -	\$ 45,016	\$ 67,524	\$ -	-	-	-	-	-	1,799	-	2.06
9	Naughton Unit 3	\$ -	\$ 48,666	\$ 72,999	\$ -	-	-	-	-	-	1,798	-	2.06
10	Wyodak Unit 1	\$ -	\$ 48,666	\$ 72,999	\$ -	-	-	-	-	-	1,798	-	2.06

Table 14 - Major Materials Design and Supply Costs

		NOx Control						SO2 Control						PM Control	
Index No.	Name of Unit [Case -->	2	3	4	5	6	7	8	9	10					
1	Dave Johnson Unit 3	\$ 3,221,912	\$ 5,773,000	\$ 5,556,617	\$ 5,773,000	\$ 49,465,000	\$ 83,871,000	\$ 142,077,000	\$ 108,865,659	\$ -	\$ 18,359,000	\$ -	\$ -	\$ 30,853,530	
2	Dave Johnson Unit 4	\$ 2,673,501	\$ 4,343,192	\$ 7,171,686	\$ 68,200,000	\$ 80,923,000	\$ -	\$ 137,287,000	\$ 178,174,314	\$ -	\$ -	\$ -	\$ -	\$ 29,814,000	
3	Jim Bridger Unit 1	\$ 2,981,932	\$ 6,056,965	\$ 9,528,000	\$ 86,923,000	\$ 86,923,000	\$ -	\$ -	\$ 8,010,033	\$ -	\$ -	\$ -	\$ -	\$ 29,814,000	
4	Jim Bridger Unit 2	\$ -	\$ 6,056,955	\$ 9,526,000	\$ 86,923,000	\$ -	\$ -	\$ -	\$ 8,010,033	\$ -	\$ -	\$ -	\$ -	\$ 29,814,000	
5	Jim Bridger Unit 3	\$ -	\$ 2,981,982	\$ 6,056,955	\$ 9,449,000	\$ 80,923,000	\$ -	\$ -	\$ 8,010,033	\$ -	\$ -	\$ -	\$ -	\$ 29,814,000	
6	Jim Bridger Unit 4	\$ -	\$ 2,981,982	\$ 6,056,955	\$ 9,449,000	\$ 80,923,000	\$ -	\$ -	\$ 8,010,033	\$ -	\$ -	\$ -	\$ -	\$ 29,814,000	
7	Naughton Unit 1	\$ 2,602,123	\$ 2,675,732	\$ 7,257,000	\$ 37,293,000	\$ 26,819,000	\$ 42,301,000	\$ 44,000,000	\$ 800,000	\$ -	\$ 15,482,000	\$ -	\$ -	\$ 16,359,000	
8	Naughton Unit 2	\$ 2,570,674	\$ 3,123,533	\$ 8,784,000	\$ 47,934,000	\$ 39,282,000	\$ 57,621,000	\$ 56,000,000	\$ 800,000	\$ -	\$ 16,359,000	\$ -	\$ -	\$ 20,106,000	
9	Naughton Unit 3	\$ 3,187,638	\$ 4,600,246	\$ 7,234,860	\$ 72,471,000	\$ 986,100	\$ -	\$ 2,953,000	\$ 800,000	\$ -	\$ 1,247,061	\$ 1,781,174,314	\$ 1,781,174,314	\$ 1,781,174,314	
10	Wyodak Unit 1	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	

## CAPITAL COST

Jim Bridger Unit 2

Parameter

	Parameter	NOx Control				SO2 Control				PM Control			
		Exist LNB w/ROFA	ROFA	SNCR	N/A	LNB	LNB-TRSI	Upgraded Wet FGD	LNB	Wet FGD	Upgraded Wet FGD	LNB-TRSI	Fabric Filter
LNB Emission Control System	Exist LNB w/ROFA	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
PM Emission Control System	Exist LNB w/ROFA	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
<b>CAPITAL COST COMPONENT</b>													
LNB w/ROFA or ROFA	Vendor	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Major Materials Design and Supply	Vendor	65.3%	65.3%	65.3%	65.3%	65.3%	65.3%	65.3%	65.3%	65.3%	65.3%	65.3%	\$0
Construction	Vendor	61.7%	61.7%	61.7%	61.7%	61.7%	61.7%	61.7%	61.7%	61.7%	61.7%	61.7%	\$0
Balanced of Plant	Vendor	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	\$0
Electrical (Allowance)	Vendor	13.2%	13.2%	13.2%	13.2%	13.2%	13.2%	13.2%	13.2%	13.2%	13.2%	13.2%	\$0
Surcharge	Vendor	16.4%	16.4%	16.4%	16.4%	16.4%	16.4%	16.4%	16.4%	16.4%	16.4%	16.4%	\$0
A-FUDCC	Vendor	12.2%	12.2%	12.2%	12.2%	12.2%	12.2%	12.2%	12.2%	12.2%	12.2%	12.2%	\$0
Subtotal	Vendor	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Contingency	Vendor	12.0%	12.0%	12.0%	12.0%	12.0%	12.0%	12.0%	12.0%	12.0%	12.0%	12.0%	\$0
Total Capital Cost for LNB w/ROFA or ROFA	Vendor	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
SNCR or SCR	SLR Report	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Major Materials Design and Supply	SLR Report	20.0%	20.0%	20.0%	20.0%	20.0%	20.0%	20.0%	20.0%	20.0%	20.0%	20.0%	\$0
Labor Premium	SLR Report	6.8%	5.8%	5.8%	5.8%	5.8%	5.8%	5.8%	5.8%	5.8%	5.8%	5.8%	\$0
EPIC Premium	SLR Report	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	\$0
Sales Tax	SLR Report	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	\$0
Escalation	SLR Report	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	\$0
Surcharge on A-FUDCC	SLR Report	2.0%	2.0%	2.0%	2.0%	2.0%	2.0%	2.0%	2.0%	2.0%	2.0%	2.0%	\$0
Subtotal	SLR Report	\$11.4%	\$11.4%	\$11.4%	\$11.4%	\$11.4%	\$11.4%	\$11.4%	\$11.4%	\$11.4%	\$11.4%	\$11.4%	\$0
<b>TOTAL CAPITAL COST</b>	SLR Report	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
<b>dry or wet FGD, or fabric filter</b>	SLR Report	20.7%	20.7%	20.7%	20.7%	20.7%	20.7%	20.7%	20.7%	20.7%	20.7%	20.7%	\$0
Major Materials Design and Supply	SLR Report	5.5%	5.5%	5.5%	5.5%	5.5%	5.5%	5.5%	5.5%	5.5%	5.5%	5.5%	\$0
Construction	SLR Report	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	\$0
EPIC Premium	SLR Report	2.8%	2.8%	2.8%	2.8%	2.8%	2.8%	2.8%	2.8%	2.8%	2.8%	2.8%	\$0
Sales Tax	SLR Report	1.1%	1.1%	1.1%	1.1%	1.1%	1.1%	1.1%	1.1%	1.1%	1.1%	1.1%	\$0
Escalation	SLR Report	10.0%	10.0%	10.0%	10.0%	10.0%	10.0%	10.0%	10.0%	10.0%	10.0%	10.0%	\$0
Surcharge and A-FUDCC	SLR Report	14.4%	14.4%	14.4%	14.4%	14.4%	14.4%	14.4%	14.4%	14.4%	14.4%	14.4%	\$0
<b>Total Capital Cost for Dry/Wet FGD, Fabric Filter</b>	SLR Report	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0

Jim Bridger Unit 2									Exist. LNB w/o FA								
Year	Date	Total Fixed O&M Cost	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	Total Variable O&M Cost	Debt Service	Total Annual Cost	Control Cost (\$/ton NOx Removed)						
0	2013	-	-	-	-	-	-	-	-	-	-						
1	2014	165,000	-	-	-	-	-	-	-	-	-						
2	2015	107,100	-	-	-	-	-	-	-	-	-						
3	2016	108,242	-	-	-	-	-	-	-	-	-						
4	2017	111,427	-	-	-	-	-	-	-	-	-						
5	2018	113,655	-	-	-	-	-	-	-	-	-						
6	2019	115,928	-	-	-	-	-	-	-	-	-						
7	2020	118,247	-	-	-	-	-	-	-	-	-						
8	2021	120,612	-	-	-	-	-	-	-	-	-						
9	2022	123,024	-	-	-	-	-	-	-	-	-						
10	2023	125,485	-	-	-	-	-	-	-	-	-						
11	2024	127,994	-	-	-	-	-	-	-	-	-						
12	2025	130,554	-	-	-	-	-	-	-	-	-						
13	2026	133,165	-	-	-	-	-	-	-	-	-						
14	2027	135,828	-	-	-	-	-	-	-	-	-						
15	2028	138,545	-	-	-	-	-	-	-	-	-						
16	2029	141,316	-	-	-	-	-	-	-	-	-						
17	2030	147,142	-	-	-	-	-	-	-	-	-						
18	2031	147,025	-	-	-	-	-	-	-	-	-						
19	2032	148,956	-	-	-	-	-	-	-	-	-						
20	2033	152,955	-	-	-	-	-	-	-	-	-						
Present Worth		0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%						
% of PWI		2.4%															

Jim Bridger Unit 2									ROFA								
Year	Date	Total Fixed O&M Cost	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	Total Variable O&M Cost	Debt Service	Total Annual Cost	Control Cost (\$/ton NOx Removed)						
0	2013	-	-	-	-	-	-	-	-	-	-						
1	2014	165,000	-	-	-	-	-	2,528,012	1,952,798	4,555,908	9,885						
2	2015	107,100	-	-	-	-	-	2,578,573	1,952,798	4,638,168	9,808						
3	2016	108,242	-	-	-	-	-	2,630,144	1,952,798	4,692,182	9,820						
4	2017	111,427	-	-	-	-	-	2,682,747	1,952,798	4,746,970	10,036						
5	2018	113,655	-	-	-	-	-	2,735,402	1,952,798	4,802,453	10,154						
6	2019	115,928	-	-	-	-	-	2,791,130	1,952,798	4,859,954	10,274						
7	2020	118,247	-	-	-	-	-	2,846,955	1,952,798	4,917,955	10,397						
8	2021	120,612	-	-	-	-	-	2,903,892	1,952,798	4,977,959	10,523						
9	2022	123,024	-	-	-	-	-	2,961,870	1,952,798	5,037,789	10,651						
10	2023	125,485	-	-	-	-	-	3,021,209	1,952,798	5,109,348	10,781						
11	2024	127,994	-	-	-	-	-	3,081,633	1,952,798	5,162,423	10,914						
12	2025	130,554	-	-	-	-	-	3,143,196	1,952,798	5,226,516	11,050						
13	2026	133,165	-	-	-	-	-	3,205,131	1,952,798	5,292,992	11,188						
14	2027	135,828	-	-	-	-	-	3,270,254	1,952,798	5,358,876	11,329						
15	2028	138,545	-	-	-	-	-	3,335,659	1,952,798	5,427,100	11,473						
16	2029	141,316	-	-	-	-	-	3,402,372	1,952,798	5,496,184	11,620						
17	2030	147,142	-	-	-	-	-	3,470,419	1,952,798	5,567,358	11,770						
18	2031	147,025	-	-	-	-	-	3,538,324	1,952,798	5,639,349	11,923						
19	2032	148,956	-	-	-	-	-	3,610,624	1,952,798	5,713,386	12,079						
20	2033	152,955	-	-	-	-	-	3,682,937	1,952,798	5,785,956	12,235						
Present Worth		1,282,875	0.0%	0.0%	0.0%	0.0%	0.0%	30,886,986	58,6%	30,886,986	58,6%						
% of PWI		2.4%															

EY10200701SLAPP A PCap JBC2 BART Economic Analysis 01-12-07.xls

1 of 4


Jim Bridger Unit 2										SNCR				SCR			
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst/FF Bd Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton NOx Removed)						
0	2013	237,500	-	536,432	-	-	208,926	745,358	1,277,304	2,260,162	2,359						
1	2014	242,250	-	547,161	-	-	213,105	760,266	1,277,304	2,279,320	2,410						
2	2015	247,095	-	551,104	-	-	217,357	775,471	1,277,304	2,289,370	2,431						
3	2016	252,037	-	569,266	-	-	221,714	780,980	1,277,304	2,320,321	2,453						
4	2017	257,078	-	580,452	-	-	226,148	805,800	1,277,304	2,341,182	2,475						
5	2018	262,219	-	592,365	-	-	230,671	822,836	1,277,304	2,362,459	2,487						
6	2019	-	-	604,110	-	-	235,285	839,395	1,277,304	2,384,162	2,520						
7	2020	267,484	-	616,192	-	-	239,990	855,183	1,277,304	2,406,298	2,544						
8	2021	272,813	-	623,316	-	-	244,790	873,306	1,277,304	2,428,073	2,567						
9	2022	278,269	-	641,086	-	-	249,686	890,772	1,277,304	2,451,181	2,592						
10	2023	283,834	-	653,948	-	-	254,680	908,688	1,277,304	2,475,403	2,617						
11	2024	289,511	-	666,986	-	-	259,730	926,760	1,277,304	2,499,365	2,642						
12	2025	295,301	-	680,326	-	-	264,865	945,255	1,277,304	2,523,006	2,668						
13	2026	301,207	-	693,933	-	-	270,263	964,201	1,277,304	2,548,736	2,684						
14	2027	307,232	-	707,811	-	-	275,673	983,485	1,277,304	2,574,165	2,721						
15	2028	313,376	-	721,987	-	-	281,187	1,003,154	1,277,304	2,601,02	2,748						
16	2029	319,644	-	736,407	-	-	286,811	1,023,217	1,277,304	2,626,558	2,776						
17	2030	326,037	-	751,135	-	-	292,547	1,043,682	1,277,304	2,653,543	2,805						
18	2031	332,557	-	762,158	-	-	298,388	1,064,655	1,277,304	2,681,068	2,834						
19	2032	339,208	-	781,481	-	-	304,365	1,085,847	1,277,304	2,709,43	2,864						
20	2033	345,933	-	800,053	-	-	309,327	9,108,880	13,427,239	25,435,559	1,344						
Present Worth		-2,901,740	-	0.0%	6,954,053	-	0.0%	-	2,552,627	9,108,880	13,427,239	25,435,559	1,344				
% of PW		-11.4%	-	0.0%	25.8%	-	0.0%	-	10.0%	35.8%	52.8%	100.0%					

Upgraded Wet FGD											
Jim Bridger Unit 2											
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/ton SO2 Removed)
0	2013	42,583	30,503	533,206	-	-	442,988	208,926	1,215,593	1,238,652	2,494,928
1	2014	43,435	31,118	545,870	-	-	451,818	213,105	1,239,905	1,236,652	2,519,991
2	2015	44,303	31,735	557,747	-	-	460,854	217,367	1,254,703	1,236,652	2,545,658
3	2016	45,169	32,370	568,842	-	-	470,071	227,714	1,269,387	1,236,652	2,577,138
4	2017	46,033	33,017	580,159	-	-	478,472	228,443	1,284,797	1,236,652	2,598,442
5	2018	47,015	33,678	598,102	-	-	489,082	230,671	1,302,113	1,236,652	2,625,780
6	2019	47,995	34,351	600,476	-	-	498,843	233,288	1,328,955	1,236,652	2,655,562
7	2020	48,914	35,038	612,488	-	-	508,620	231,980	1,342,261	1,236,652	2,681,801
8	2021	49,893	35,739	624,735	-	-	518,986	240,790	1,352,746	1,236,652	2,710,106
9	2022	50,890	36,454	637,230	-	-	528,376	249,988	1,368,191	1,236,652	2,740,289
10	2023	51,908	37,183	646,975	-	-	539,764	256,680	1,384,891	1,236,652	2,770,361
11	2024	52,946	37,926	662,974	-	-	550,763	265,773	1,401,437	1,236,652	2,801,036
12	2025	54,005	38,685	676,234	-	-	561,778	264,968	1,418,186	1,236,652	2,832,323
13	2026	55,085	39,459	689,758	-	-	573,014	270,988	1,437,893	1,236,652	2,864,237
14	2027	56,187	40,248	703,554	-	-	584,474	275,873	1,456,349	1,236,652	2,895,783
15	2028	57,311	41,063	717,625	-	-	598,164	281,187	1,483,628	1,236,652	2,929,991
16	2029	58,457	41,874	731,977	-	-	608,087	288,811	1,518,749	1,236,652	2,965,858
17	2030	59,626	42,711	746,617	-	-	620,249	292,547	1,552,102	1,236,652	3,000,402
18	2031	60,819	43,568	761,548	-	-	632,654	298,396	1,576,166	1,236,652	3,035,637
19	2032	62,035	44,437	777,989	-	-	645,307	304,568	1,601,989	1,236,652	3,070,577
20	2033	520,271	3,72,679	6,514,628	-	-	5,412,000	2,55,627	14,365,185	12,989,900	28,372,107
Present Worth (\$ of PW)		1.8%	1.3%	23.0%	-	-	0.0%	18.1%	9.0%	52.3%	100.0%

Flue Gas Conditioning											
Jim Bridger Unit 2											
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/ton SO2 Removed)
0	2013	10,000	-	145,854	-	-	-	18,710	165,564	-	175,564
1	2014	10,200	-	148,771	-	-	-	20,104	168,075	-	178,075
2	2015	10,404	-	151,747	-	-	-	20,508	172,553	-	182,657
3	2016	10,612	-	154,781	-	-	-	20,916	175,988	-	185,310
4	2017	10,824	-	157,877	-	-	-	21,338	179,212	-	189,046
5	2018	11,041	-	161,035	-	-	-	21,761	182,766	-	192,337
6	2019	11,262	-	164,255	-	-	-	22,197	186,452	-	197,714
7	2020	11,487	-	167,540	-	-	-	22,641	190,181	-	201,668
8	2021	11,717	-	170,891	-	-	-	23,083	193,985	-	205,101
9	2022	11,951	-	174,309	-	-	-	23,525	197,864	-	209,815
10	2023	12,180	-	177,795	-	-	-	24,028	201,722	-	214,012
11	2024	12,434	-	181,351	-	-	-	24,507	205,958	-	218,292
12	2025	12,682	-	184,978	-	-	-	24,997	209,975	-	222,658
13	2026	12,936	-	188,675	-	-	-	25,497	214,755	-	227,111
14	2027	13,195	-	192,451	-	-	-	26,007	218,458	-	231,653
15	2028	13,459	-	196,300	-	-	-	26,527	222,927	-	235,286
16	2029	13,728	-	200,226	-	-	-	27,058	227,384	-	241,012
17	2030	14,002	-	204,231	-	-	-	27,598	233,930	-	245,832
18	2031	14,282	-	208,315	-	-	-	28,151	238,466	-	250,749
19	2032	14,568	-	212,482	-	-	-	28,714	241,185	-	255,764
20	2033	122,179	1.782,023	83.1%	0.0%	-	248,814	242,437	-	2,145,015	2,145,015
Present Worth (\$ of PW)		1.8%	1.3%	23.0%	-	-	0.0%	11.2%	64.3%	0.0%	100.0%

Jim Bridger Unit 2							Fabric Filter				
Year	Date	TOTAL FIXED O&M COST	Markup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton PM Removed)
0	2013	127,749	-	-	300,040.	-	1,326,977	1,326,917	4,602,887	6,957,652	4,556
1	2014	130,304	-	-	306,041	1,355,415	1,659,455	4,602,887	6,952,946	4,581	
2	2015	132,910	-	-	312,152	1,380,483	1,652,845	4,602,887	6,928,441	4,607	
3	2016	135,588	-	-	318,405	1,408,083	1,726,488	4,602,887	6,864,452	4,633	
4	2017	138,279	-	-	324,773	1,438,255	1,761,027	4,602,887	6,802,93	4,660	
5	2018	141,045	-	-	331,268	1,464,980	1,796,248	4,602,887	6,740,179	4,687	
6	2019	143,866	-	-	337,884	1,492,479	1,832,173	4,602,887	6,678,325	4,715	
7	2020	146,743	-	-	344,682	1,522,165	1,883,516	4,602,887	6,618,446	4,743	
8	2021	149,678	-	-	351,545	1,554,648	1,906,193	4,602,887	6,558,757	4,772	
9	2022	152,671	-	-	358,576	1,585,741	1,944,317	4,602,887	6,499,375	4,801	
10	2023	155,725	-	-	365,747	1,617,456	1,983,203	4,602,887	6,441,814	4,832	
11	2024	158,839	-	-	373,082	1,649,905	2,022,867	4,602,887	6,374,993	4,862	
12	2025	162,016	-	-	380,523	1,682,401	2,063,324	4,602,887	6,308,227	4,893	
13	2026	165,256	-	-	388,134	1,715,457	2,104,581	4,602,887	6,242,734	4,925	
14	2027	168,582	-	-	395,886	1,750,786	2,146,883	4,602,887	6,178,131	4,953	
15	2028	171,933	-	-	403,814	1,785,402	2,189,816	4,602,887	6,114,438	4,981	
16	2029	175,371	-	-	411,881	1,821,518	2,233,409	4,602,887	7,011,667	5,025	
17	2030	178,879	-	-	420,128	1,857,946	2,278,077	4,602,887	7,059,442	5,059	
18	2031	182,456	-	-	428,531	1,895,107	2,323,638	4,602,887	7,108,981	5,095	
19	2032	186,108	-	-	437,102	1,930,010	2,370,111	4,602,887	7,159,403	5,131	
20	2033	190,833	2.27%	0.0%	3,665,845	0.0%	16,217,381	19,677,436	49,388,383	69,243,882	2,502
Present Worth -		1,560,813	2.27%	0.0%	3,665,845	0.0%	16,217,381	23.2%	26.5%	69,339	100.0%


### First Year Cost for Air Pollution Control Options



EY102007001SLC\app A\_PCorp JB2 BART Economic Analysis\_01-12-07.xls

1 of 1

### Present Worth Cost for Air Pollution Control Options



EY102007001SLC\app A\_PCorp JB2 BART Economic Analysis\_01-12-07.xls

1 of 1

**APPENDIX B**  
**2006 Wyoming BART Protocol**

---

## **BART Air Modeling Protocol**

### **Individual Source Visibility Assessments for BART Control Analyses**

**September, 2006**

**State of Wyoming  
Department of Environmental Quality  
Air Quality Division  
Cheyenne, WY 82002**

## Table of Contents

1.0	INTRODUCTION .....	3
2.0	OVERVIEW .....	4
3.0	EMISSIONS DATA FOR MODELING .....	7
3.1	Baseline Modeling .....	7
3.2	Post-Control Modeling .....	8
4.0	METEOROLOGICAL DATA .....	9
5.0	CALPUFF MODEL APPLICATION .....	12
6.0	POST PROCESSING .....	15
7.0	REPORTING .....	19

## 1.0 INTRODUCTION

The U.S. EPA has issued final amendments to the Regional Haze Regulations, along with Guidelines for Best Available Retrofit Technology (BART) Determinations.<sup>(1)</sup> The guidelines address the methodology for determining which facilities must apply BART (sources subject-to-BART) and the evaluation of control options.

The State of Wyoming used air quality modeling in accordance with the EPA Guidelines to determine the Wyoming sources which are subject-to-BART. This Protocol defines the specific methodology to be used by those sources for determining the improvement in visibility to be achieved by BART controls.

The methodology presented in this Protocol is consistent with EPA guidance and the Air Quality Division (AQD) determination of subject-to-BART sources. It is intended that all Wyoming sources that must conduct BART analyses will use this Protocol for their evaluation of control technology visibility improvement. Any deviations from the procedures described herein must be approved by the Division prior to implementation.

<sup>(1)</sup> 40 CFR Part 51: Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations; Final Rule. 70 Federal Register, 39103-39172, July 6, 2005.

## 2.0 OVERVIEW

Wyoming AQD determined that eight facilities (sources) in the state are subject-to-BART. The sources are listed in Table 1. Division modeling indicated that each of these sources causes or contributes to visibility impairment in one or more Class I areas. Each source must conduct a BART analysis to define Best Available Retrofit Technology (BART) applicable to that source, and quantify the improvement in Class I visibility associated with BART controls. This Protocol sets out the procedures for quantifying visibility improvement. Other aspects of the full BART analysis are not addressed here.

There are many Class I areas within and surrounding Wyoming (See Figure 1). On the basis of distance from subject-to-BART sources, topography, meteorology, and prior modeling, the AQD has determined that only five Class I areas need be addressed in BART individual source analyses. These are Badlands and Wind Cave National Parks in South Dakota, Mt. Zirkel Wilderness Area in Colorado, and Bridger and Fitzpatrick Wilderness Areas in Wyoming. Sources in eastern Wyoming have been shown to have greatest visibility impacts at the two South Dakota Class I areas, and western Wyoming sources have maximum impacts at Bridger and Fitzpatrick Wilderness Areas, and Mt. Zirkel. Visibility improvement at these highest impact areas will provide the best measure of the effectiveness of BART controls.

Each facility should carry out modeling with the CALPUFF modeling system for the Class I areas specified in Table 2. The AQD will provide meteorological input for CALMET for the years 2001, 2002, and 2003. The model domain covered by the AQD meteorological data is centered in southwest Wyoming, and extends roughly from Twin Falls, ID in the west to the Missouri River in the east, and from Denver in the south to Helena, MT in the north. The domain is shown, along with Class I areas, in Figure 1.

Sources may wish to utilize a smaller domain for CALPUFF modeling. Smaller domains are acceptable if they provide adequate additional area beyond the specific source and Class I areas being addressed. Figure 1 includes a "southwest Wyoming" domain which represents the minimum acceptable area for sources impacting the Bridger and Fitzpatrick Wilderness Areas, and the Mt. Zirkel Wilderness Area, and a "northeast Wyoming" domain as a minimum area for Badlands and Wind Cave National Parks modeling.

The CALPUFF model should be used with each of the three years of meteorological data to calculate visibility impacts for a baseline (existing emissions) case, and for cases reflecting BART controls. The control scenarios are to include individual scenarios for proposed BART controls for each pollutant ( $\text{SO}_2$ ,  $\text{NO}_x$ , and particulate matter), and a combined scenario representing application of all proposed BART controls. If desired, additional modeling may be performed for controls that are not selected as BART. This might be done, for example, to provide data useful in identifying the control technologies that represent BART. However, visibility modeling is required only for the proposed BART controls.

Table 1. Wyoming Sources Subject-to-BART

Basin Electric	Laramie River Power Plant	Boilers #1,2,3
FMC Corporation	Granger Soda Ash Plant	Boilers #1,2
FMC Corporation	Green River Sodium Plant	Three boilers
General Chemical Co.	Green River Soda Ash	Two boilers
PacifiCorp	Dave Johnson Power Plant	Boilers #3,4
PacifiCorp	Jim Bridger Power Plant	Boilers #1-4
PacifiCorp	Naughton Power Plant	Boilers #1,2,3
PacifiCorp	Wyodak Power Plant	Boiler

Results of visibility modeling will be presented as a comparison between baseline impacts and those calculated for the BART control scenarios. Quantitative measures of impact will be the 98<sup>th</sup> percentile deciview change ( $\Delta dv$ ) relative to the 20% best days natural background, and the number of days with deciview change exceeding 0.5 (EPA Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations, 70 FR 39103). Results should be presented for each year.

Table 2. Source-Specific Class I Areas to be Addressed

Source	Class I Areas to be Evaluated
Basin Electric Laramie River	Wind Cave NP, Badlands NP
FMC Corporation Granger Soda Ash	Bridger WA, Fitzpatrick WA
FMC Corporation Sodium Products	Bridger WA, Fitzpatrick WA
General Chemical Green River Soda Ash	Bridger WA, Fitzpatrick WA
Pacificorp Dave Johnston	Wind Cave NP, Badlands NP
Pacificorp Jim Bridger	Bridger WA, Fitzpatrick WA, Mt. Zirkel WA
Pacificorp Naughton Plant	Bridger WA, Fitzpatrick WA
Pacificorp Wyodak	Wind Cave NP, Badlands NP

### **3.0 EMISSIONS DATA FOR MODELING**

CALPUFF model input requires source (stack) – specific emission rates for each pollutant, and stack parameters (height, diameter, exit gas temperature, and exit gas velocity). Per EPA BART guidance, these parameters must be representative of maximum actual 24-hour average emitting conditions for baseline (existing) operation, and maximum proposed 24-hour average emissions for future (BART) operations.

#### **3.1 Baseline Modeling**

Sources are required to utilize representative baseline emission conditions if data are available; baseline emissions must be documented. Possible sources of emission data are stack tests, CEM data, fuel consumption data, etc. Remember that emissions should represent maximum 24-hour rates. EPA BART guidance states that you should “Use the 24-hour-average actual emission rate from the highest emitting day of the meteorological period modeled (for the pre-control scenario).” Thus, baseline conditions should reference data from 2001 through 2003 (or 2004).

As a minimum, modeled emissions must include:

SO <sub>2</sub>	sulfur dioxide
NO <sub>x</sub>	oxides of nitrogen
PM <sub>2.5</sub>	particles with diameter less than 2.5 μm
PM <sub>10-2.5</sub>	particles with diameters greater than 2.5 μm but less than or equal to 10 μm

If the fraction of PM<sub>10</sub> in the PM<sub>2.5</sub> (fine) and PM<sub>10-2.5</sub> (coarse) categories cannot be determined all particulate matter should be assumed to be PM<sub>2.5</sub>.

In addition, direct emissions of sulfate (SO<sub>4</sub>) should be included where possible. Sulfate can be emitted as sulfuric acid (H<sub>2</sub>SO<sub>4</sub>), sulfur trioxide (SO<sub>3</sub>), or as sulfate compounds; emissions should be quantified as the equivalent mass of SO<sub>4</sub>.

When test or engineering data are not available to specify SO<sub>4</sub> emissions or the relative fractions of fine and coarse particles, use can be made of speciation profiles available from Federal Land Managers at the website <http://www.nature.nps.gov/air/permits/ect/index.cfm>. Profiles are available for a number of source type and control technology combinations. The FLM speciation factors are acceptable if data are available for the appropriate source type.

Emissions of VOC (volatile organic compounds), condensable organics measured in stack tests, and elemental carbon components of PM<sub>10</sub> do not need to be included for BART modeling. The only other pollutant noted in EPA BART guidance is ammonia (NH<sub>3</sub>). Though ammonia is not believed to be a significant contributor to visibility

impairment in most cases in Wyoming, it could be important for sources with significant ammonia emissions — for example from some NO<sub>x</sub> control systems. Sources that are expected to emit ammonia (in pre-or post-control configurations) should include ammonia emissions in their model input.

If quantitative baseline emissions data are unavailable and sources believe that the maximum 24-hour emission rates estimated by the Division (presented in the Subject-to-BART final report) are representative of baseline conditions for their facility, they may be used for baseline modeling. However, emissions of sulfate and ammonia (if applicable) should be included based on the best available test information or speciation factors from current literature.

### 3.2 Post-Control Modeling

All pollutants described above should be included for each post-control scenario. Post-control emissions (maximum 24-hour average) will generally be the baseline emissions multiplied by a control factor appropriate to the BART control. However, some proposed controls may simply increase the efficiency of existing controls; others may result in an increase in emissions of one pollutant while controlling another. These factors must all be considered in defining emission rates for post-control modeling. Any changes in stack parameters resulting from control application must also be included.

The required visibility assessment will include the effect of each proposed BART control. For example, if a source proposes to add a scrubber for SO<sub>2</sub> control, low NO<sub>x</sub> burners for NO<sub>x</sub> control, and a baghouse for particulate control, four sets of visibility results should be developed:

- Use of SO<sub>2</sub> control alone
- Use of NO<sub>x</sub> control alone
- Use of particulate control alone
- Use of proposed combination of all three controls

All pollutants should be modeled in each CALPUFF model run, but the modeled emissions should reflect only the specific controls or combination of controls addressed in that run.

Additional modeling could be necessary in situations where a facility is comprised of more than one subject-to-BART source, and different BART controls are applicable to different sources. Excessive modeling to address multiple control combinations is not necessary; however, visibility modeling should quantify the effect of BART controls on all affected sources for each pollutant, and of all facility BART controls combined.

#### 4.0 METEOROLOGICAL DATA

Wyoming AQD will provide MM5 meteorological data fields for years 2001, 2002, and 2003 that can be utilized as input to CALMET. The MM5 output will have 12 kilometer resolution and cover the full domain shown in Figure 1.

Mesoscale meteorological data (MM5) were developed and evaluated as part of the AQD's southwest Wyoming NO<sub>2</sub> increment analysis. Three years of MM5 data at 36 km resolution were used to initialize 12 km MM5 simulations. The 12km MM5 modeling used identical physics options to the original 36 km runs. CALMM5 was then used as a preprocessor to produce CALMET - ready MM5 data input files. Quality assurance was performed by comparing the original MM5 output on the 36km national RPO grid to the 12 km MM5 output and observations.

The CALMET model (version 5.53a, level 040716) should be used to prepare meteorological input for CALPUFF. The user may select a domain smaller than the MM5 domain for CALMET and CALPUFF modeling if desired. Figure 1 shows minimum domain areas for modeling of western and eastern Wyoming BART sources. Four kilometer resolution should be specified for CALMET output.

CALMET processing should use the AQD MM5 data, and appropriate surface, upper air, and precipitation data. Figure 2 shows the locations of surface and upper air stations within the MM5 model domain. The MM5 data are used as the initial guess wind field; this wind field is then adjusted by CALMET for terrain and land use to generate a step 1 wind field, and refined using surface and upper air data to create the final step 2 wind field.

Surface, upper air, and precipitation data can be obtained from the National Climatic Data Center. Land use and terrain data are available from the U.S. Geological Survey. Data can be formatted for use in CALMET with standard conversion and processing programs available with the CALMET/CALPUFF software.

Table 3 provides a listing of applicable CALMET input variables for BART meteorological processing. The table includes inputs that are specific to Wyoming BART modeling. Inputs not shown in Table 3 are not relevant to the present application, are dependent on the specific model domain of the user, use model default values, or are obvious from the context.

Table 3. CALMET Control File Inputs

Variable	Description	Value
Input Group 1		
IBYR	Year	2001
		2002
		2003
IBTZ	Base time zone	7
IRTYPE	Run type	1
LCALGRD	Compute data fields for CALGRID	T
Input Group 2		
PMAP	Map projection	LCC
DGRIDKM	Grid spacing (km)	4
NZ	Number of layers	10
ZFACE	Cell face heights (m)	0
		20
		40
		100
		140
		320
		580
		1020
		1480
		2220
		3500
Input Group 4		
NOOBS	No observation Mode	0
Input Group 5		
IWF COD	Model selection variable	1
IFRADJ	Froude number adjustment	1
IKINE	Kinematic effects	0
IOBR	Use O'Brien procedure	0
ISLOPE	Slope flow effects	1
IEXTRP	Extrapolate surface wind observations	-4
ICALM	Extrapolate calm surface winds	0
BIAS	Biases for weights of surface and upper air stations	All 0
RMIN2	Minimum distance for extrapolation	-1
IPROG	Use gridded prognostic model output	14
ISTEPPG	Time Step (hours)	1
LVARY	Use varying radius of influence	F

Table 3. CALMET Control File Inputs (continued)

Variable	Description	Value
RMAX 1	Maximum radius of influence (km)	30
RMAX 2	Maximum radius of influence (km)	50
RMIN	Minimum radius of influence (km)	0.1
TERRAD	Radius of influence for terrain (km)	15
R1	Relative weighting of first guess wind field and observations (km)	5
R2	Relative weighting aloft (km)	25
IDIOPT 1	Surface temperature	0
IDIOPT 2	Upper air lapse rate	0
ZUPT	Lapse rate depth (m)	200
IDIOPT 3	Average wind components	0
IUPWND	Upper air station	-1
ZUPWND (1)	Bottom and top of layer for domain scale winds (m)	1, 1000
ZUPWND (2)		1, 1000
IDIOPT4	Surface wind components	0
IDIOPT5	Upper air wind components	0
	Input Group 6.	
IAVEZI	Spatial averaging	1
MNMDAV	Max search radius	1
HAFANG	Half angle for averaging (deg)	30
ILEVZI	Layer of winds in averaging	1
ZIMAX	Maximum overland mixing height (m)	3500
ITPROG	3D temperature source	1
IRAD	Interpolation type	1
TRADKM	Radius of influence -- temperature (km)	500
NUMTS	Maximum number of Stations	5
IAVET	Spatial averaging of temperatures	1
NFLAGP	Precipitation interpolation	2

## 5.0 CALPUFF MODEL APPLICATION

The CALPUFF model (version 5.711a, level 040716) will be used to calculate pollutant concentrations at receptors in each Class I area. Application of CALPUFF should, in general, follow the guidance presented in the Interagency Workgroup on Air Quality Modeling (IWAQM) Phase 2 report (EPA - 454/R98-019) and the EPA Regional Haze Regulations and Guidelines for BART Determinations (70 FR 39103).

Appropriate CALPUFF control file inputs are in Table 4. Note should be taken of the basis for several of the recommended CALPUFF inputs.

- Building downwash effects need not be included. Because of the transport distances involved and the fact that most sources have tall stacks, building downwash is unlikely to have a significant effect on model-predicted concentrations
- Puff splitting is not required. The additional computation time necessary for puff splitting is not justified for purposes of BART analyses.
- Hourly ozone files should be used to define background ozone concentration. Data are available from the following sites within the model domain.

Rocky Mountain NP, CO  
Craters of the Moon NP, ID  
AIRS - Highland UT  
Mountain Thunder, WY  
Yellowstone NP, WY  
Centennial, WY  
Pinedale, WY

The background ozone concentration shown in Table 4 is used only when hourly data are missing.

- A constant background ammonia concentration of 2.0 ppb is specified. This value is based upon monitoring data from nearby states and IWAQM guidance. Experience suggests that 2.0 ppb is conservative in that it is unlikely to significantly limit nitrate formation in the model computations.
- MESOPUFF II chemical transformation rates should be used.
- The species to be modeled should be the seven identified in CALPUFF: SO<sub>2</sub>, SO<sub>4</sub>, NO<sub>x</sub>, HNO<sub>3</sub>, NO<sub>3</sub>, PM<sub>2.5</sub>, and PM<sub>10.2.5</sub>. If ammonia (NH<sub>3</sub>) is emitted it should be added to the species list. In most cases, all pollutants modeled will also be emitted; except for HNO<sub>3</sub> and NO<sub>3</sub>.

Concentration calculations should be made for receptors covering the areas of the Class I areas being addressed. Receptors in each Class I area will be those designated by the Federal Land Managers and available from the National Park Service website.

Table 4. CALPUFF Control File Inputs

Variable	Description	Value
	Input Group 1	
METRUN	Control parameter for running all periods in met file	1
IBYR	Starting year	2001 2002 2003
XBTZ	Base time zone	7
NSPEC	Number of chemical species modeled	7 (or 8)
NSE	Number of species emitted	5 (or 6)
METFM	Meteorological data format	1
	Input Group 2	
MGAUSS	Vertical distribution in near field	1
MCTADJ	Terrain adjustment method	3
MCTSG	Subgrid scale complex terrain	0
MSLUG	Elongated puffs	0
MTRANS	Transitional plume rise	1
MTIP	Stack tip downwash	1
MSHEAR	Vertical wind shear	0
MSPLIT	Puff splitting allowed?	0
MCHEM	Chemical mechanism	1
MAQCHEM	Aqueous phase transformation	0
MWET	Wet removal	1
MDRY	Dry deposition	1
MDISP	Dispersion Coefficients	3
MROUGH	Adjust sigma for roughness	0
MPARTL	Partial plume penetration of inversions	1
MPDF	PDF for convective conditions	0
	Input Group 4	
PMAP	Map projection	LCC
DGRIDKM	Grid spacing	4

Table 4. CALPUFF Control File Inputs (continued)

ZFACE	Cell face heights (m)	0 20 40 100 140 320 580 1020 1480 2220 3500
Input Group 6		
NHILL	Number of terrain features	0
Dry Gas Depo	Chemical parameters for dry gas deposition	Defaults
Input Group 7		
Dry Part. Depo	Size parameters for dry particle deposition  SO <sub>4</sub> , NO <sub>3</sub> , PM25 PM10	Defaults 6.5, 1.0
Input Group 8		
MOZ	Ozone Input option	1
BCK03	Background ozone – all months (ppb)	44.0
BCKNH3	Background ammonia – all months (ppb)	2.0
Input Group 11		
XMAXZI	Maximum mixing height (m)	3500
XMINZI	Minimum mixing height (m)	50
Input Group 12		

## 6.0 POST PROCESSING

Visibility impacts are calculated from the CALPUFF concentration results using CALPOST. CALPOST version 5.51, level 030709 should be used; the output from CALPOST will provide the highest deciview impact on each day from all receptors within each Class I area modeled.

For some CALPUFF applications such as deposition calculations, the POSTUTIL program is used prior to CALPOST. POSTUTIL is also used to repartition total nitrate by accounting for ammonia limiting. The ammonia limiting calculation in POSTUTIL should not be applied for Wyoming BART modeling. If you believe that ammonia limiting is appropriate for a specific BART analysis, justification should be discussed with the Division prior to its used.

Visibility calculations by CALPOST for BART purposes use Method 6. This method requires input of monthly relative humidity factors, f(RH), for each Class I area. The EPA guidance document provides appropriate data for each area. Table 5 lists monthly f(RH) factors to use for the Wyoming, Colorado, and South Dakota areas to be addressed in BART modeling. The factors shown in Table 5 include averages for the adjacent Class I areas, and are within 0.2 units of the Guideline table values for the individual Class I areas.

Natural background conditions as a reference for determination of the delta-dv change due to a source should be representative of the 20% best natural visibility days. EPA BART guidance provides the 20% best days deciview values for each Class I area on an annual basis, but does not provide species concentration data for the 20% best background conditions. These concentrations are needed for input to CALPOST.

Annual species concentrations corresponding to the 20% best days were calculated for each Class I area to be addressed, by scaling back the annual average concentrations given in Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule (Table 2-1). A separate scaling factor was derived for each Class I area such that, when multiplied by the Guidance table annual concentrations, the 20% best days deciview value for that area would be calculated. The scaled aerosol concentrations were averaged for the Bridger and Fitzpatrick WAs, and for Wind Cave and Badlands NPs, because of their geographical proximity and similar annual background visibility. The 20% best days aerosol concentrations to be used for each month for Wyoming BART evaluations are listed in Table 6.

Table 7 is a list of inputs for CALPOST. These inputs should be used for all BART visibility calculations. Output from CALPOST should be configured to provide a ranked list of the highest delta-deciview values in each Class I area. The 98<sup>th</sup> percentile delta-deciview value and the number of values exceeding 0.5 can then be determined directly from the CALPOST output.

Table 5. Monthly f(RH) Factors for Class I Areas

Month	Wind Cave NP Badlands NP	Bridger WA Fitzpatrick WA	Mt. Zirkel WA
January	2.65	2.50	2.20
February	2.65	2.30	2.20
March	2.65	2.30	2.00
April	2.55	2.10	2.10
May	2.70	2.10	2.20
June	2.60	1.80	1.80
July	2.30	1.50	1.70
August	2.30	1.50	1.80
September	2.20	1.80	2.00
October	2.25	2.00	1.90
November	2.75	2.50	2.10
December	2.65	2.40	2.10

Table 6. Natural Background Concentrations of Aerosol Components for 20% Best Days for BART Analyses ( $\mu\text{g}/\text{m}^3$ )

Aerosol Component	Wind Cave NP Badlands NP	Fitzpatrick WA Bridger WA	Mt. Zirkel WA
Ammonium Sulfate	.047	.045	.046
Ammonium Nitrate	.040	.038	.038
Organic Carbon	.186	.178	.179
Elemental Carbon	.008	.008	.008
Soil	.198	.189	.190
Coarse Mass	1.191	1.136	1.141

Table 7. CALPOST Control File Inputs

Variable	Description	Value
	Input Group 1	
ASPEC	Species to Process	VISIB
ILAYER	Layer/deposition code	1
A,B	Scaling factors	0,0
LBACK	Add background concentrations?	F
BTZONE	Base time zone	7
LVSO4	Species to be included in extinction	T
LVNO3		T
LVOC		F
LVPMC		T
LVPMF		T
LVEC		F
LVBK	Include background?	T
SPECPMC	Species name for particulates	PM10
SPECPMF		PM25
EPMC	Extinction efficiencies	0.6
EPMF		1.0
EPMCBK		0.6
EESO4		3.0
EENO3		3.0
EEOC		4.0
EESOIL		1.0
EEBC		10.0
MVISBK	Visibility calculation method	6
RHFAC	Monthly RH adjustment factors	Table 5
BKSO4	Background concentrations	Table 6
BKNO3		Table 6
BKPMC		Table 6
BK OC		Table 6
BKSOL		Table 6
BKEC		Table 6
BEXTRAY	Extinction due to Rayleigh scattering	10.0

## 7.0 REPORTING

A report on the BART visibility analysis should be submitted that clearly compares impacts for post-control emissions to those for baseline emissions. Data for baseline and BART scenarios should include both the 98<sup>th</sup> percentile values and the number of days with delta-deciview values exceeding 0.5. Results should be given for each model year.

Table 8 is an example of a recommended format for presentation of model input and model results. The example is for baseline conditions; similar tables should be provided for each control scenario (SO<sub>2</sub>, NO<sub>x</sub>, and PM10) and for the combination of all BART controls. Your report tables need not follow the exact format shown in Table 8; but the same information should be provided in a concise and clear form. If additional scenarios were modeled or you wish to present supplemental information, they should be provided in an appendix or separate from the specified final results.

Table 8. Example Format for Presentation of Model Input and Results

Source (Unit) Description And ID	Baseline Conditions Model Input Data										
	SO <sub>2</sub> Emission Rate (lb/day)	NO <sub>x</sub> Emission Rate (lb/day)	PM <sub>2.5</sub> Emission Rate (lb/day)	PM <sub>10-2.5</sub> Emission Rate (lb/day)	SO <sub>4</sub> Emission Rate (lb/day)	NH <sub>3</sub> Emission Rate (lb/day)	Location Northing	Stack Height (m)	Stack Diameter (m)	Exit Velocity (m/s)	Exit Gas Temp (deg K)

Name of Facility	Class I Area	Baseline Visibility Modeling Results			
		2001	2002	2003	
		98 <sup>th</sup> Percentile Value (dy)	No. of days exceeding 0.5 dy	98 <sup>th</sup> Percentile Value (dy)	No. of days exceeding 0.5 dy

*Final Report*

# BART Analysis for Jim Bridger Unit 3



Prepared For:

**PaciCorp**

1407 West North Temple  
Salt Lake City, Utah 84116

December 2007

Prepared By:

**CH2MHILL**

215 South State Street, Suite 1000  
Salt Lake City, Utah 84111

AQD Jim Bridger BART  
002309

---

*Final Report*

# BART Analysis for Jim Bridger Unit 3

Submitted to

**PacifiCorp**

December 2007

---

**CH2MHILL**

# Executive Summary

---

## Background

In response to the Regional Haze Rule and Best Available Retrofit Technology (BART) regulations and guidelines, CH2M HILL was requested to perform a BART analysis for PacifiCorp's Jim Bridger Unit 3 (hereafter referred to as Jim Bridger 3). Best Available Retrofit Technology analysis has been conducted for the following criteria pollutants: nitrogen oxide ( $\text{NO}_x$ ), sulfur dioxide ( $\text{SO}_2$ ), and particulate matter less than 10 micrometers in aerodynamic diameter ( $\text{PM}_{10}$ ). The Jim Bridger Station consists of four 530 megawatt (MW) units with a total generating capacity of 2,120 MW. Because the total generating capacity of the Jim Bridger Station exceeds 750 MW, presumptive BART emission limits apply to Jim Bridger 3, based on the United States Environmental Protection Agency's (EPA) guidelines. BART emissions limits must be achieved within five years after the State Implementation Plan (SIP) is approved by the EPA. A compliance date of 2014 was assumed for this analysis.

In completing the BART analysis, technology alternatives were investigated and potential reductions in  $\text{NO}_x$ ,  $\text{SO}_2$ , and  $\text{PM}_{10}$  emissions rates were identified. The following technology alternatives were investigated, listed below by pollutant:

- $\text{NO}_x$  emission controls:
  - Low- $\text{NO}_x$  burners (LNB) with over-fire air (OFA)
  - Rotating opposed fire air (ROFA)
  - LNB with selective non-catalytic reduction (SNCR) system
  - LNB with selective catalytic reduction (SCR) system
- $\text{SO}_2$  emission controls:
  - Optimize current operation of existing wet sodium flue gas desulfurization (FGD) system
  - Upgrade wet sodium FGD system to achieve an  $\text{SO}_2$  emission rate of 0.10 lb per MMBtu
  - New dry FGD system
- $\text{PM}_{10}$  emission controls:
  - Sulfur trioxide ( $\text{SO}_3$ ) injection flue gas conditioning system on existing electrostatic precipitator (ESP)
  - Polishing fabric filter

## BART Engineering Analysis

The specific steps in a BART engineering analysis are identified in the Code of Federal Regulations (CFR) at 40 CFR 51 Appendix Y, Section IV. The evaluation must include:

- The identification of available, technically feasible, retrofit control options
- Consideration of any pollution control equipment in use at the source (which affects the availability of options and their impacts)
- The costs of compliance with the control options
- The remaining useful life of the facility
- The energy and non-air quality environmental impacts of compliance
- The degree of visibility improvement that may reasonably be anticipated from the use of BART

The following steps are incorporated into the BART analysis:

- Step 1 – Identify All Available Retrofit Control Technologies
- Step 2 – Eliminate Technically Infeasible Options
  - The identification of available, technically feasible, retrofit control options
  - Consideration of any pollution control equipment in use at the source (which affects the applicability of options and their impacts)
- Step 3 – Evaluate Control Effectiveness of Remaining Control Technologies
- Step 4 – Evaluate Impacts and Document the Results
  - The costs of compliance with the control options
  - The remaining useful life of the facility
  - The energy and non-air quality environmental impacts of compliance
- Step 5 – Evaluate Visibility Impacts
  - The degree of visibility improvement that may reasonably be anticipated from the use of BART

Separate analyses have been conducted for NO<sub>x</sub>, SO<sub>2</sub>, and PM<sub>10</sub> emissions. All costs included in the BART analyses are in 2006 dollars, and costs have not been escalated to the assumed 2014 BART implementation date.

## Coal Characteristics

The main source of coal burned at Jim Bridger 3 will be the Bridger Underground Mine. Secondary sources are the Bridger Surface Mine, the Bridger Highwall Mine, the Black Butte Mine, and the Leucite Hills Mine. These coals are ranked as sub-bituminous, but are closer in characteristics to bituminous coal in many of the parameters influencing NO<sub>x</sub> formation. These coals have higher nitrogen content than coals from the Powder River Basin (PRB),

which represent the bulk of sub-bituminous coal use in the U.S. This BART analysis has considered the higher nitrogen content and different combustion characteristics of PRB coals, as compared to those coals used at Jim Bridger 3, and has evaluated the effect of these qualities on NO<sub>x</sub> formation and achievable emission rates.

## Recommendations

CH2M HILL recommends these BART selections, which include installing low NO<sub>x</sub> burners with over-fire air, upgrading the existing FGD system, and operating the existing electrostatic precipitator with an SO<sub>3</sub> flue gas conditioning system. This combination of control devices is identified as Scenario 1 throughout this report.

### NO<sub>x</sub> Emission Control

The BART presumptive NO<sub>x</sub> limit assigned by EPA for tangentially-fired boilers burning sub-bituminous coal is 0.15 lb per MMBtu. However, as documented in this analysis, the characteristics of the Jim Bridger coals are more closely aligned with bituminous coals, with a presumptive BART NO<sub>x</sub> limit of 0.28 lb per MMBtu.

CH2M HILL recommends low-NO<sub>x</sub> burners with over-fire air (LNB with OFA) as BART for Jim Bridger 3, based on the projected significant reduction in NO<sub>x</sub> emissions, reasonable control costs, and the advantages of no additional power requirements or non-air quality environmental impacts. NO<sub>x</sub> reductions are expected to be similar to those realized at Jim Bridger 2. CH2M HILL recommends that the unit be permitted at a rate of 0.26 lb per MMBtu.

### SO<sub>2</sub> Emission Control

CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 3, based on the significant reduction in SO<sub>2</sub> emissions, reasonable control costs, and the advantages of minimal additional power requirements and minimal non-air quality environmental impacts. This upgrade approach will meet the BART presumptive SO<sub>2</sub> limit of 0.15 lb per MMBtu.

### PM<sub>10</sub> Emission Control

CH2M HILL recommends finalizing the permitting of the flue gas conditioning system to enhance the performance of the existing ESP as BART for Jim Bridger 3, based on the significant reduction in PM<sub>10</sub> emissions, reasonable control costs, and the advantages of minimal additional power requirements and no non-air quality environmental impacts.

## BART Modeling Analysis

CH2M HILL used the CALPUFF modeling system to assess the visibility impacts of emissions from Jim Bridger 3 at Class I areas. The Class I areas potentially affected are located more than 50 kilometers, but less than 300 kilometers, from the Jim Bridger Plant.

The Class I areas include the following wilderness areas (WAs):

- Bridger WA
- Fitzpatrick WA
- Mt. Zirkel WA

Because Jim Bridger 3 will simultaneously control NO<sub>x</sub>, SO<sub>2</sub>, and PM<sub>10</sub> emissions, four post-control atmospheric dispersion modeling scenarios were developed to cover the range of effectiveness for combining the individual NO<sub>x</sub>, SO<sub>2</sub>, and PM<sub>10</sub> control technologies under evaluation. These modeling scenarios, and the controls assumed, are as follows:

- **Scenario 1:** New LNB with OFA modifications, upgraded wet FGD system, and flue gas conditioning for enhanced ESP performance. As indicated previously, this scenario represents CH2M HILL HILL's preliminary BART recommendation.
- **Scenario 2:** New LNB with OFA modifications, upgraded wet FGD system, and new polishing fabric filter.
- **Scenario 3:** New LNB with OFA modifications and SCR, upgraded wet FGD system, and flue gas conditioning for enhanced ESP performance.
- **Scenario 4:** New LNB with OFA modifications and SCR, upgraded wet FGD system, and new polishing fabric filter.

Visibility improvements for all emission control scenarios were analyzed, and the results were compared utilizing a least-cost envelope, as outlined in the *New Source Review Workshop Manual*.<sup>1</sup>

## Least-cost Envelope Analysis

EPA has adopted the least-cost envelope analysis methodology as an accepted methodology for selecting the most reasonable, cost-effective controls. Incremental cost-effectiveness comparisons focus on annualized cost and emission reduction differences between dominant alternatives. The dominant set of control alternatives is determined by generating what is called the envelope of least-cost alternatives. This is a graphical plot of total annualized costs for total emissions reductions for all control alternatives identified in the BART analysis.

To evaluate the impacts of the modeled control scenarios on the three Class I areas, the total annualized cost, cost per deciview (dV) reduction, and cost per reduction in number of days above 0.5 dV were analyzed. This report provides a comparison of the average incremental costs between relevant scenarios for the three Class I areas; the total annualized cost versus number of days above 0.5 dV, and the total annualized cost versus 98<sup>th</sup> percentile delta-deciview ( $\Delta dV$ ) reduction.

Results of the least-cost envelope analysis validate the selection of Scenario 1, based on incremental cost and visibility improvements. Scenario 2 (LNB with OFA, upgraded wet FGD, and polishing fabric filter) is eliminated, because it is to the left of the curve formed by the dominant control alternative scenario, which indicates a scenario with lower

<sup>1</sup> EPA, 1990. *New Source Review Workshop Manual*. Draft. Environmental Protection Agency. October, 1990.

improvement and/or higher costs. Scenario 3 (LNB with OFA and SCR, upgraded wet FGD, and flue gas conditioning for enhanced ESP performance) is not selected due to very high incremental costs, on the basis of both a cost per day of improvement and cost per dV reduction. While Scenario 4 (LNB with OFA and SCR, upgraded wet FGD, and polishing fabric filter) provides some potential visibility advantage over Scenario 1, the projected improvement is less than half a dV, and the projected costs are excessive. Therefore, Scenario 1 represents BART for Jim Bridger 3.

## Just-Noticeable Differences in Atmospheric Haze

Studies have been conducted that demonstrate only dV differences of approximately 1.5 to 2.0 dV or more are perceptible by the human eye. Deciview changes of less than 1.5 cannot be distinguished by the average person. Therefore, the modeling analysis results indicate that only minimal, if any, observable visibility improvements at the Class I areas studied would be expected under any of the control scenarios. Thus, the results indicate that only minimal discernable visibility improvements may result, even though PacifiCorp will be spending many millions of dollars at this single unit, and over a billion dollars when considering its entire fleet of coal-fired power plants.

# Contents

---

<b>1.0</b>	<b>Introduction.....</b>	<b>1-1</b>
<b>2.0</b>	<b>Present Unit Operation.....</b>	<b>2-1</b>
<b>3.0</b>	<b>BART Engineering Analysis.....</b>	<b>3-1</b>
3.1	Applicability.....	3-1
3.2	BART Process.....	3-1
3.2.1	BART NO <sub>x</sub> Analysis .....	3-2
3.2.2	BART SO <sub>2</sub> Analysis.....	3-14
3.2.3	BART PM <sub>10</sub> Analysis.....	3-17
<b>4.0</b>	<b>BART Modeling Analysis.....</b>	<b>4-1</b>
4.1	Model Selection.....	4-1
4.2	CALMET Methodology.....	4-1
4.2.1	Dimensions of the Modeling Domain .....	4-1
4.2.2	CALMET Input Data.....	4-4
4.2.3	Validation of CALMET Wind Field .....	4-6
4.3	CALPUFF Modeling Approach .....	4-6
4.3.1	Background Ozone and Ammonia .....	4-6
4.3.2	Stack Parameters .....	4-6
4.3.3	Emission Rates .....	4-7
4.3.4	Post-control Scenarios .....	4-7
4.3.5	Modeling Process .....	4-8
4.3.6	Receptor Grids.....	4-8
4.4	CALPOST .....	4-10
4.5	Presentation of Modeling Results.....	4-11
4.5.1	Visibility Changes for Baseline vs. Preferred Scenario .....	4-11
<b>5.0</b>	<b>Preliminary Assessment and Recommendations .....</b>	<b>5-1</b>
5.1	Least-cost Envelope Analysis .....	5-1
5.1.1	Analysis Methodology.....	5-1
5.1.2	Analysis Results .....	5-9
5.2	Recommendations .....	5-9
5.2.1	NO <sub>x</sub> Emission Control.....	5-9
5.2.2	SO <sub>2</sub> Emission Control .....	5-9
5.2.3	PM <sub>10</sub> Emission Control .....	5-9
5.3	Just-Noticeable Differences in Atmospheric Haze .....	5-10
<b>6.0</b>	<b>References.....</b>	<b>6-1</b>

**Tables**

- 2-1 Unit Operation and Study Assumptions
- 2-2 Coal Sources and Characteristics
- 3-1 Coal Characteristics Comparison
- 3-2 NO<sub>x</sub> Control Technology Projected Emission Rates
- 3-3 NO<sub>x</sub> Control Cost Comparison
- 3-4 SO<sub>2</sub> Control Technology Emission Rates
- 3-5 SO<sub>2</sub> Control Cost Comparison (Incremental to Existing FGD System)
- 3-6 PM<sub>10</sub> Control Technology Emission Rates
- 3-7 PM<sub>10</sub> Control Cost Comparison (Incremental to Existing ESP)
- 4-1 User-specified CALMET Options
- 4-2 BART Model Input Data
- 4-3 Average Natural Levels of Aerosol Components
- 4-4 Costs and Visibility Modeling Results for Baseline vs. Post-Control Scenarios at Class I Areas
  - 5-1 Control Scenario Results for the Bridger Class I Wilderness Area
  - 5-2 Control Scenario Results for the Fitzpatrick Class I Wilderness Area
  - 5-3 Control Scenario Results for the Mt. Zirkel Class I Wilderness Area
  - 5-4 Bridger Class I Wilderness Area Incremental Analysis Data
  - 5-5 Fitzpatrick Class I Wilderness Area Incremental Analysis Data
  - 5-6 Mt. Zirkel Class I Wilderness Area Incremental Analysis Data

**Figures**

- 3-1 Illustration of the Effect of Agglomeration on the Speed of Coal Combustion
- 3-2 Plot of Typical Nitrogen Content of Various Coals and Applicable Presumptive BART NO<sub>x</sub> Limits
- 3-3 Plot of Typical Oxygen Content of Various Coals and Applicable Presumptive BART NO<sub>x</sub> Limits
- 3-4 First Year Control Cost for NO<sub>x</sub> Air Pollution Control Options
- 3-5 First Year Control Cost for PM Air Pollution Control Options
- 4-1 Jim Bridger Source-Specific Class I Areas to be Addressed
- 4-2 Surface and Upper Air Stations Used in the Jim Bridger BART Analysis
- 5-1 Least-cost Envelope Bridger Class I WA Days Reduction
- 5-2 Least-cost Envelope Bridger Class I WA 98<sup>th</sup> Percentile Reduction
- 5-3 Least-cost Envelope Fitzpatrick Class I WA Days Reduction
- 5-4 Least-cost Envelope Fitzpatrick Class I WA 98<sup>th</sup> Percentile Reduction
- 5-5 Least-cost Envelope Mt. Zirkel Class I WA Days Reduction
- 5-6 Least-cost Envelope Mt. Zirkel Class I WA 98<sup>th</sup> Percentile Reduction

**Appendices**

- A Economic Analysis
- B 2006 Wyoming BART Protocol

## **Acronyms and Abbreviations**

---

°F	Degree Fahrenheit
BACT	Best Available Control Technology
BART	Best Available Retrofit Technology
CALDESK	Program to Display Data and Results
CALMET	Meteorological Data Preprocessing Program for CALPUFF
CALPOST	Post-processing Program for Calculating Visibility Impacts
CALPUFF	Gaussian Puff Dispersion Model
COHPAC	Compact Hybrid Particulate Collector
dV	Deciview
ΔdV	Delta Deciview, Change in Deciview
DEQ	Department of Environmental Quality
ESP	Electrostatic Precipitator
EPA	United States Environmental Protection Agency
FGC	Flue Gas Conditioning
FGD	Flue Gas Desulfurization
kW	Kilowatt
kW-Hr	Kilowatt-hour
LNB	Low-NO <sub>x</sub> Burner
lb	Pound
MMBtu	Million British Thermal Units
MM5	Mesoscale Meteorological Model, Version 5
MW	Megawatts
NO <sub>x</sub>	Nitrogen Oxides
OFA	Over Fire Air
PM	Particulate Matter
PM <sub>2.5</sub>	Particulate Matter less than 2.5 Micrometers in Aerodynamic Diameter
PM <sub>10</sub>	Particulate Matter less than 10 Micrometers in Aerodynamic Diameter
PRB	Powder River Basin
ROFA	Rotating Opposed Fire Air
S&L	Sargent & Lundy
SCR	Selective Catalytic Reduction
SIP	State Implementation Plan

ACRONYMS AND ABBREVIATIONS (CONTINUED)

SNCR	Selective Non-catalytic Reduction
SO <sub>2</sub>	Sulfur Dioxide
SO <sub>3</sub>	Sulfur Trioxide
USGS	U.S. Geological Survey
WA	Wilderness Area
WDEQ-AQD	Wyoming Department of Environmental Quality – Air Quality Division

## 1.0 Introduction

---

Best Available Retrofit Technology (BART) guidelines were established as a result of United States Environmental Protection Agency (EPA) regulations intended to reduce the occurrence of regional haze in national parks and other Class I protected air quality areas in the United States (40 CFR Part 51). These guidelines provide guidance for states when determining which facilities must install additional controls, and the type of controls that must be used. Facilities eligible for BART installation were built between 1962 and 1977, and have the potential to emit more than 250 tons per year of visibility-impairing pollutants.

The Wyoming Department of Environmental Quality (DEQ) BART regulations state that each source subject to BART must submit a BART application for a construction permit by December 15, 2006. PacifiCorp received an extension from the Wyoming DEQ to submit the BART report for Jim Bridger Unit 3 (hereafter referred to as Jim Bridger 3) by January 12, 2007. The BART Report that was submitted to WDEQ in January 2007 included a BART analysis, and a proposal and justification for BART at the source. This revised report—submitted in October 2007—incorporates editorial revisions and new model runs since the January 2007 version.

The State of Wyoming has identified those eligible, in-state facilities that are required to reduce emissions under BART, and will set BART emissions limits for those facilities. This information will be included in the State of Wyoming State Implementation Plan (SIP), which the State has estimated will be formally submitted to the EPA by early 2008. The EPA BART guidelines also state that the BART emission limits must be fully implemented within 5 years of EPA's approval of the SIP.

Five elements related to BART address the issue of emissions for the identified facilities:

- Any existing pollution control technology in use at the source
- The cost of the controls
- The remaining useful life of the source
- The energy and non-air quality environmental impacts of compliance
- The degree of improvement in visibility that may reasonably be anticipated from the use of such technology

This report documents the BART analysis that was performed on Jim Bridger 3 by CH2M HILL for PacifiCorp. The analysis was performed for the pollutants nitrogen oxide ( $\text{NO}_x$ ), sulfur dioxide ( $\text{SO}_2$ ), and particulate matter less than 10 micrometers in aerodynamic diameter ( $\text{PM}_{10}$ ), because they are the primary criteria pollutants that affect visibility.

Section 2 of this report provides a description of the present unit operation, including a discussion of coal sources and characteristics. The BART Engineering Analysis is provided in Section 3, by pollutant type. Section 4 provides the methodology and results of the BART Modeling Analysis, followed by recommendations in Section 5. References are provided in Section 6. Appendices provide more detail on the economic analysis and the 2006 Wyoming BART Protocol.

## **2.0 Present Unit Operation**

---

The Jim Bridger Station consists of four units with a total generating capacity of 2,120 megawatts (MW). Jim Bridger 3 is a nominal 530 net MW unit located approximately 35 miles northeast of Rock Springs, Wyoming. It is equipped with a tangentially fired pulverized coal boiler with low NO<sub>x</sub> burners manufactured by Combustion Engineering. The unit was constructed with a Flakt wire frame electrostatic precipitator (ESP). The unit contains a Babcock & Wilcox wet sodium flue gas desulfurization (FGD) system with three absorber towers installed in 1988. An Emerson Ovation distributed control system (DCS) was installed in 2003.

Jim Bridger 3 was placed in service in 1976. Its current economic depreciation life is through 2040; however, this analysis is based on a 20-year life for BART control technologies. Assuming a BART implementation date of 2014, this will result in an approximate remaining useful life for Jim Bridger 3 of 20 years from the installation date of any new or modified BART-related equipment. This report does not attempt to quantify any additional life extension costs needed to allow the unit and these control devices at Jim Bridger 3 to operate until 2040.

Table 2-1 lists additional unit information and study assumptions for this analysis.

The BART presumptive NO<sub>x</sub> limit for tangential-fired boilers burning sub-bituminous coal is 0.15 lb per MMBtu and the BART presumptive NO<sub>x</sub> limit for burning bituminous coal is 0.28 lb per MMBtu. The main sources of coal burned at Jim Bridger 3 are the Bridger Mine and secondarily the Black Butte Mine and Leucite Hills Mine. These coals are ranked as sub-bituminous, but are closer in characteristics to bituminous coal in many of the parameters influencing NO<sub>x</sub> formation. These coals have higher nitrogen content than coals from the Powder River Basin (PRB), which represent the bulk of sub-bituminous coal use in the U.S. This BART analysis has considered the higher nitrogen content and the different combustion characteristics of PRB coals, as compared to those coals used at Jim Bridger 3, and has evaluated the effect of these qualities on NO<sub>x</sub> formation and achievable emission rates. Coal sources and characteristics are summarized in Table 2-2. The primary source of coal will be the Bridger Underground Mine, and data on coal from this source were used in the modeling analysis. For the coal analysis that is presented in Section 3.2.1, the data from all the coal sources were used.

**TABLE 2-1**  
**Unit Operation and Study Assumptions**  
*Jim Bridger 3*

<b>General Plant Data</b>	
Site Elevation feet above MSL	6669
Stack Height (feet)	500
Stack Exit Internal Diameter (feet) /Exit Area (square feet)	24 /452.4
Stack Exit Temperature (degrees Fahrenheit)	140
Stack Exit Velocity (feet per second)	84.04
Stack Flow (actual cubic feet per minute)	2,281,182
Latitude (degree: minute: second)	41:44:18.54 north
Longitude (degree: minute: second)	108:47:12.82 west
Annual Unit Capacity Factor (percentage)	90
Net Unit Output (megawatts)	.530
Net Unit Heat Rate (British thermal unit [Btu]/kilowatt-hour)(100% load)	10,400 (as measured by fuel throughput)
Boiler Heat Input (million British thermal units [MMBtu] per hour)(100% load)	6,000 (as measured by continuous emission monitoring)
Type of Boiler	Tangentially fired
Boiler Fuel	Coal
Coal Sources	Bridger Mine, Black Butte Mine, Leucite Hills Mine
Coal Heating Value (Btu/ per pound [lb]) <sup>(a)</sup>	9,660
Coal Sulfur Content (percentage by weight [wt. %]) <sup>(a)</sup>	0.58
Coal Ash Content (wt. %) <sup>(a)</sup>	10.3
Coal Moisture Content (wt. %) <sup>(a)</sup>	19.3
Coal Nitrogen Content (wt. %) <sup>(a)</sup>	0.98
Current Nitrogen Oxide (NO <sub>x</sub> ) Controls	Low NO <sub>x</sub> burners
NO <sub>x</sub> Emission Rate (lb per MMBtu)	0.45
Current Sulfur Dioxide (SO <sub>2</sub> ) Controls	Sodium-based wet scrubber
SO <sub>2</sub> Emission Rate (lb per MMBtu)	0.267
Current PM <sub>10</sub> Controls	Electrostatic Precipitator
PM <sub>10</sub> <sup>(c)</sup> Emission Rate (lb per MMBtu) <sup>(b)</sup>	0.057

**NOTES:**<sup>(a)</sup> Coal characteristics based on Bridger Underground Mine (primary coal source)<sup>(b)</sup> Based on maximum historic emission rate from 1999-2001, prior to installation of the SO<sub>3</sub> injection system.<sup>(c)</sup> PM<sub>10</sub> refers to particulate matter less than 10 micrometers in aerodynamic diameter

**TABLE 2-2**  
**Coal Sources and Characteristics**  
*Jim Bridger 3*

Mines	Moisture (%)	Volatile Matter (%)	Fixed Carbon (%)	British thermal units per pound (Btu/lb)	Sulfur (%)	Moisture and Ash Free (Btu/lb)	Ultimate Analysis (% dry basis)						
							Hydrogen	Carbon	Sulfur	Nitrogen	Oxygen	Ash	
Bridger Mine Underground	19.3	10.3	32.2	38.3	9660	0.58	13712	4.66	69.2	0.72	1.22	11.8	12.4
Maximum	Not enough data yet to run statistical analysis for variability												
Minimum	Not enough data yet to run statistical analysis for variability												
Bridger Mine Surface	19.1	10.6	32.3	38.0	9390	0.57	13340	4.38	37.4	0.71	1.26	13.2	13.0
Maximum	20.5	12.5	35.5	41.9	9800	0.72	13500	4.69	4.0	0.90	1.43	14.8	15.8
Minimum	17.5	9.0	31.0	36.0	9000	0.49	13100	4.00	64.3	0.60	1.14	11.7	11.2
Bridger Mine Highwall	18.0	9.5	33.0	39.5	9700	0.58	13500	No samples of separate highwall coal					
Maximum	Not enough data yet to run statistical analysis for variability												
Minimum	Not enough data yet to run statistical analysis for variability												
Black Butte Mine	20.0	9.2	33.3	35.6	9450	0.45	13330	4.43	68.7	0.56	1.47	13.4	11.5
Maximum	21.1	10.8	35.4	41.9	10275	0.62	13500	4.66	70.5	0.78	1.69	14.8	13.6
Minimum	18.0	7.6	29.9	36.8	9180	0.33	13140	4.21	66.1	0.41	1.25	11.6	9.7
Leucite Hills Mine (through 2009)	19.4	11.5	30.7	38.3	9050	0.64	13140	4.20	66.0	0.81	1.48	13.2	14.4
Maximum	23.0	15.0	33.0	43.0	10250	0.90	13800	4.70	70.0	1.20	1.64	17.1	19.0
Minimum	17.0	8.0	28.3	33.6	8000	0.40	12300	3.70	61.0	0.50	1.32	10.5	10.0

## **3.0 BART Engineering Analysis**

---

This section presents the required BART engineering analysis.

### **3.1 Applicability**

In compliance with regional haze requirements, the State of Wyoming must prepare and submit visibility SIPs to the EPA for Class I areas. The State has estimated that the formal submittal of the SIPs will occur by early 2008. The first phase of the regional haze program is the implementation of BART emission controls on all BART eligible units, within 5 years after EPA approval of the SIP.

### **3.2 BART Process**

The specific steps in a BART engineering analysis are identified in the Code of Federal Regulations (CFR) at 40 CFR 51 Appendix Y, Section IV. The evaluation must include:

- The identification of available, technically feasible, retrofit control options
- Consideration of any pollution control equipment in use at the source (which affects the availability of options and their impacts)
- The costs of compliance with the control options
- The remaining useful life of the facility
- The energy and non-air quality environmental impacts of compliance, and
- The degree of visibility improvement that may reasonably be anticipated from the use of BART

The following steps are incorporated into the BART analysis:

- Step 1 – Identify All Available Retrofit Control Technologies
- Step 2 – Eliminate Technically Infeasible Options
  - The identification of available, technically feasible, retrofit control options
  - Consideration of any pollution control equipment in use at the source (which affects the applicability of options and their impacts)
- Step 3 – Evaluate Control Effectiveness of Remaining Control Technologies
- Step 4 – Evaluate Impacts and Document the Results
  - The costs of compliance with the control options
  - The remaining useful life of the facility
  - The energy and non-air quality environmental impacts of compliance

- Step 5 – Evaluate Visibility Impacts
  - The degree of visibility improvement that may reasonably be anticipated from the use of BART

In order to minimize costs in the BART analysis, consideration was made of any pollution control equipment in use at the source, the costs of compliance associated with the control options, and the energy and non-air quality environmental impacts of compliance using these existing control devices. In some cases, enhancing the performance of the existing control equipment was considered. Other scenarios with new control equipment were also developed.

All costs included in the BART analysis are in 2006 dollars (not escalated to 2014 BART implementation date).

### 3.2.1 BART NO<sub>x</sub> Analysis

Nitrogen oxide formation in coal-fired boilers is a complex process that is dependent on a number of variables, including operating conditions, equipment design, and coal characteristics.

#### Formation of NO<sub>x</sub>

During coal combustion, NO<sub>x</sub> is formed in three different ways. The dominant source of NO<sub>x</sub> formation is the oxidation of fuel-bound nitrogen. During combustion, part of the fuel-bound nitrogen is released from the coal with the volatile matter, and part is retained in the solid portion (char). The nitrogen chemically bound in the coal is partially oxidized to nitrogen oxides (nitric oxide and nitrogen dioxide) and partially reduced to molecular nitrogen. A smaller part of NO<sub>x</sub> formation is due to high temperature fixation of atmospheric nitrogen in the combustion air. A very small amount of NO<sub>x</sub> is called "prompt" NO<sub>x</sub>. Prompt NO<sub>x</sub> results from an interaction of hydrocarbon radicals, nitrogen, and oxygen.

In a conventional pulverized coal burner, air is introduced with turbulence to promote good mixing of fuel and air, which provides stable combustion. However, not all of the oxygen in the air is used for combustion. Some of the oxygen combines with the fuel nitrogen to form NO<sub>x</sub>.

Coal characteristics directly and significantly affect NO<sub>x</sub> emissions from coal combustion. Coal ranking is a means of classifying coals according to their degree of metamorphism in the natural series, from lignite to sub-bituminous to bituminous and on to anthracite. Lower rank coals, such as the sub-bituminous coals from the PRB, produce lower NO<sub>x</sub> emissions than higher rank bituminous coals, due to their higher reactivity and lower nitrogen content. The fixed carbon to volatile matter ratio (fuel ratio), coal oxygen content, and rank are good relative indices of the reactivity of a coal. Lower rank coals release more organically bound nitrogen earlier in the combustion process than do higher rank bituminous coals. When used with low-NO<sub>x</sub> burners (LNBs), sub-bituminous coals create a longer time for the kinetics to promote more stable molecular nitrogen, and hence result in lower NO<sub>x</sub> emissions.

Coals from the PRB are classified as sub-bituminous C and demonstrate the high reactivity and low NO<sub>x</sub> production characteristics described above. Based on data from the Energy Information Administration, PRB coals currently represent 88 percent of total U.S. sub-bituminous production and 73 percent of western coal production (Energy Information Administration, 2006). Most references to "western" coal and sub-bituminous coal infer PRB origin and characteristics. Emissions standards differentiating between bituminous and sub-

bituminous coals are presumed to use PRB coal as the basis for the sub-bituminous standards, due to its dominant market presence and unique characteristics.

There are a number of western coals that are classified as sub-bituminous, however, they border on being ranked as bituminous and do not display many of the qualities of PRB coals, including most of the low NO<sub>x</sub> forming characteristics. Coals from the Bridger, Black Butte, and Leucite Hills mines fall into this category.

As defined by the American Society for Testing and Materials, the only distinguishing characteristic that classifies the coals used at Jim Bridger 3 as sub-bituminous rather than bituminous – that is, they are “agglomerating” as compared to “non-agglomerating”.

Agglomerating as applied to coal is “the property of softening when it is heated to above about 400°C in a non-oxidizing atmosphere, and then appearing as a coherent mass after cooling to room temperature.” Because the agglomerating property of coals is the result of particles transforming into a plastic or semi-liquid state when heated, it reflects a change in surface area of the particle. Thus, with the application of heat, agglomerating coals would tend to develop a non-porous surface while the surface of non-agglomerating coals would become even more porous with combustion. As shown by Figure 3-1, the increased porosity provides more particle surface area resulting in more favorable combustion conditions. This non-agglomerating property assists in making sub-bituminous coals more amenable to controlling NO<sub>x</sub> by allowing less air to be introduced during the initial ignition portion of the combustion process. The coals from the Bridger, Black Butte and Leucite Hills mines just barely fall into the category of non-agglomerating coals. While each of these coals is considered non-agglomerating, they either do not exhibit those properties of non-agglomerating coals or exhibit them to only a minor degree. The conditions during combustion of typical non-agglomerating coals that make it easier to control NO<sub>x</sub> emissions do not exist for the Bridger blends of coals.

**FIGURE 3-1**  
Illustration of the Effect of Agglomeration on the Speed of Coal Combustion  
*Jim Bridger 3*




Table 3-1 shows key characteristics of a typical PRB coal compared to coals from the Bridger Mine, Black Butte, and Leucite Hills, as well as Twentymile, which is a representative western bituminous coal.

**TABLE 3-1**  
Coal Characteristics Comparison  
*Jim Bridger 3*

Parameter	Typical Powder River Basin	Bridger Mine	Black Butte	Leucite Hills	Twentymile
Nitrogen (percentage dry)	1.10	1.26	1.47	1.48	1.85
Oxygen (percentage dry)	16.2	13.2	13.4	13.2	7.19
Coal rank	Sub C	Sub B	Sub B	Sub B	Bituminous high volatility B

As shown in Table 3-1, although Bridger, Black Butte, and Leucite Hills are classified as sub-bituminous, they all exhibit higher nitrogen content and lower oxygen content than the PRB coal. The higher nitrogen content is an indication that more nitrogen is available to the combustion process and higher NO<sub>x</sub> emissions are likely. Oxygen content can be correlated to the reactivity of the coal, with more reactive coals generally containing higher levels of oxygen. More reactive coals tend to produce lower NO<sub>x</sub> emissions, and they are also more conducive to reduction of NO<sub>x</sub> emissions through the use of combustion control measures, such as low NO<sub>x</sub> burners and over-fire air (OFA). These characteristics indicate that higher NO<sub>x</sub> formation is likely with coal from the Bridger, Black Butte, and Leucite Hills mines, rather than with PRB coal. The Bridger, Black Butte, and Leucite Hills coals all contain quality characteristics that fall between a typical PRB coal and Twentymile. Twentymile is a clearly bituminous coal that produces higher NO<sub>x</sub>, as has been demonstrated at power plants burning this fuel.


Figures 3-2 and 3-3 graphically illustrate the relationship of nitrogen and oxygen content to the BART presumptive NO<sub>x</sub> limits for the coals listed in Table 3-1. Each chart identifies the presumptive BART limit associated with a typical bituminous and sub-bituminous coal, and demonstrates how the Jim Bridger coal falls between these two general coal classifications.

The Bridger blend data point represents a combination of coals from the Bridger Mine, Black Butte, and Leucite Hills that has been used at Jim Bridger 3, and indicates the average NO<sub>x</sub> emission rate achieved during the years 2003-2005. The Jim Bridger 2 data point consists of the same blend of coals as Jim Bridger 3, and represents the NO<sub>x</sub> emission rate achieved after installation of Alstom's current state-of-the-art TFS2000 LNB and OFA system. The long-term sustainable emission rate for this system is expected to be 0.24 lb per MMBtu. All four units at Jim Bridger consist of identical boilers; while there may be some differences in performance among them, installation of the TFS2000 firing system at Jim Bridger 3 would likely result in performance and NO<sub>x</sub> emission rates comparable to those at Jim Bridger 2.


Figures 3-2 and 3-3 both demonstrate that for the Jim Bridger units—with the TFS2000 low NO<sub>x</sub> emission system installed, and burning a combination of the Bridger, Black Butte, and

Leucite Hill coals—the likely NO<sub>x</sub> emission rate will be closer to the bituminous end (0.28) of the BART presumptive NO<sub>x</sub> limit range, rather than the BART presumptive NO<sub>x</sub> limit of 0.15 lb per MMBtu for sub-bituminous coal. All of these factors are consistent with the observed sustainable rate of 0.24 lb per MMBtu.

FIGURE 3-2  
Plot of Typical Nitrogen Content of Various Coals and Applicable Presumptive BART NO<sub>x</sub> Limits  
*Jim Bridger 3*



**FIGURE 3-3**  
 Plot of Typical Oxygen Content of Various Coals and Applicable Presumptive BART NO<sub>x</sub> Limits  
*Jim Bridger 3*



Coal quality characteristics also impact the design and operation of the boiler and associated auxiliary equipment. Minor changes in quality can sometimes be accommodated through operational adjustments or equipment changes. It is important to note, however, that consistent variations in quality or assumptions of "average" quality for performance projections can be problematic. This is particularly troublesome when dealing with performance issues that are very sensitive to both coal quality and combustion conditions, such as NO<sub>x</sub> formation. There is significant variability in the quality of coals burned at Jim Bridger 3. In addition to burning coal from Black Butte and Leucite Hills, Jim Bridger 3 burns coal supplied from the Bridger Mine consisting of three sources: underground, surface, and highwall operations. Each of these coal sources has different quality characteristics, as well as inherent variability in composition of the coal within the mine.

Several of the coal quality characteristics and their effect on NO<sub>x</sub> formation have been previously discussed. There are some additional considerations that illustrate the complexity of achieving and maintaining consistent low NO<sub>x</sub> emissions with pulverized coal on a shorter term, such as a 30-day rolling average basis.

Good combustion is based on the "three Ts": time, temperature, and turbulence. These parameters along with a "design" coal are taken into consideration when designing a boiler and associated firing equipment such as fans, burners, and pulverizers. If a performance requirement such as NO<sub>x</sub> emission limits is subsequently changed, conflicts with and between other performance issues can result.

Jim Bridger 3 is located at an altitude of 6,669 feet above sea level. Atmospheric pressure is lower at this elevation, 11.5 pounds per square inch, as compared with sea level pressure of 14.7 pounds per square inch. This lower pressure means that less oxygen is available for combustion for each volume of air. In order to provide adequate oxygen to meet the requirements for efficient combustion, larger volumes of air are required. When adjusting air flows and distribution to reduce NO<sub>x</sub> emissions using LNB and OFA, original boiler design restrictions again limit the modifications that can be made while still achieving satisfactory combustion performance.

Another significant factor in controlling NO<sub>x</sub> emissions is the fineness of the coal entering the burners. Fineness is influenced by the Hardgrove Grindability Index of the coal. Finer coal particles promote release of volatiles and assist char burnout due to more surface area being exposed to air. NO<sub>x</sub> reduction with high volatile coals is improved with greater fineness and with proper air staging. The lower rank sub-bituminous coals such as PRB coals are quite friable and easy to grind. Coals with lower Hardgrove Grindability Index values, such as those used at Jim Bridger 3, are more difficult to grind and can contribute to higher NO<sub>x</sub> levels. In addition, coal fineness can deteriorate over time periods between pulverizer maintenance and service as pulverizer grinding surfaces wear.

In summary, when all the factors of agglomeration versus non-agglomeration, nitrogen and oxygen content of the coals, and the grindability index are taken into account, this analysis demonstrates that, for the coal used at Jim Bridger 3, the more applicable presumptive BART limit for NO<sub>x</sub> emissions is 0.28 lb per MMBtu. The BART analysis for NO<sub>x</sub> emissions from Jim Bridger 3 is further described below.

#### **Step 1: Identify All Available Retrofit Control Technologies**

The first step of the BART process is to evaluate NO<sub>x</sub> control technologies with practical potential for application to Jim Bridger 3, including those control technologies identified as Best Available Control Technology (BACT) or lowest achievable emission rate (LAER) by permitting agencies across the United States. A broad range of information sources have been reviewed in an effort to identify potentially applicable emission control technologies. NO<sub>x</sub> emissions at Jim Bridger 3 are currently controlled through the use of good combustion practices and OFA.

The following potential NO<sub>x</sub> control technology options were considered:

- New/modified LNBs with advanced OFA
- Rotating Opposed Fire Air (ROFA)
- Conventional selective non-catalytic reduction (SNCR) system
- Selective catalytic reduction (SCR) system

#### **Step 2: Eliminate Technically Infeasible Options**

For Jim Bridger 3, a tangential-fired configuration burning sub-bituminous coal, technical feasibility will primarily be determined by physical constraints, boiler configuration, and on the ability to achieve the regulatory presumptive limit (used as a guide) of 0.28 lb NO<sub>x</sub> per MMBtu. Jim Bridger 3 has an uncontrolled NO<sub>x</sub> emission rate of 0.45 lb per MMBtu.

For this BART analysis, information pertaining to LNBs, OFA, SNCR, and SCR were based on the *Multi-Pollutant Control Report* (Sargent and Lundy, 2002, hereafter referred to as the S&L Study). Updated cost estimates for SCR and SNCR were used (Sargent & Lundy, 2006). PacifiCorp provided additional emissions data and costs developed by boiler vendors for LNBs and OFA. Also, CH2M HILL solicited a proposal from Mobotec for their ROFA technology.

With SNCR, an amine-based reagent such as ammonia, or more commonly urea, is injected into the furnace within a temperature range of 1,600 degrees Fahrenheit ( $^{\circ}$ F) to 2,100 $^{\circ}$ F, where it reduces NO<sub>x</sub> to nitrogen and water. NO<sub>x</sub> reductions of up to 40 to 60 percent have been achieved; although 15 to 30 percent is more realistic for most applications. SNCR is typically applied on smaller units. Adequate reagent distribution in the furnaces of large units can be problematic.

Table 3-2 summarizes the control technology options evaluated in this BART analysis, along with projected NO<sub>x</sub> emission rates. All technologies can meet the applicable presumptive BART limit of 0.28 lb per MMBtu.

**TABLE 3-2**  
**NO<sub>x</sub> Control Technology Projected Emission Rates**  
*Jim Bridger 3*

Technology	Projected Emission Rate (pounds per million British thermal units)
Presumptive Best Available Retrofit Technology (BART) Limit	0.28
Low-NO <sub>x</sub> burners (LNBs) with over-fire air (OFA)	0.24
Rotating Opposed Fire Air	0.22
LNB with OFA and Selective Non-catalytic Reduction (SNCR)	0.20
LNB with OFA and Selective Catalytic Reduction (SCR)	0.07

### Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

Preliminary vendor proposals, such as those used to support portions of this BART analysis, may be technically feasible and provide expected or guaranteed emission rates; however, the proposals include inherent uncertainties. These proposals are usually prepared in a limited time frame, may be based on incomplete information, may contain over-optimistic conclusions, and are non-binding. Therefore, emission rate values obtained in such preliminary proposals must be qualified, and it must be recognized that contractual guarantees are established only after more detailed analysis has been completed. The following subsections describe the control technologies and the control effectiveness evaluated in this BART analysis.

**New LNBs with OFA System.** The mechanism used to lower NO<sub>x</sub> with LNBs is to stage the combustion process and provide a fuel rich condition initially; this is so oxygen needed for combustion is not diverted to combine with nitrogen and form NO<sub>x</sub>. Fuel-rich conditions favor

the conversion of fuel nitrogen to nitrogen instead of NO<sub>x</sub>. Additional air (or OFA) is then introduced downstream in a lower temperature zone to burn out the char.

Both LNBs and OFA are considered to be a capital cost, combustion technology retrofit. For LNB retrofits to units configured with tangential-firing such as Jim Bridger 3, it is generally necessary to increase the burner spacing; this prevents interaction of the flames from adjacent burners and reduces burner zone heat flux. These modifications usually require boiler waterwall tube replacement.

Information provided to CH2M HILL by PacifiCorp—based on the S&L Study and data from boiler vendors—indicates that a new LNB and OFA retrofit at Jim Bridger 3 would result in an expected NO<sub>x</sub> emission rate of 0.24 lb per MMBtu. PacifiCorp has indicated that this rate corresponds to a vendor guarantee, not a vendor prediction, and they believe that this emission rate can be sustained as an average between overhauls. This emission rate represents a significant reduction from the current NO<sub>x</sub> emission rate, and is below the more applicable presumptive NO<sub>x</sub> emission rate of 0.28 lb per MMBtu.

**Rotating Opposed Fire Air.** Mobotec markets ROFA as an improved second generation OFA system. Mobotec states that “the flue gas volume of the furnace is set in rotation by asymmetrically placed air nozzles. Rotation is reported to prevent laminar flow, so that the entire volume of the furnace can be used more effectively for the combustion process. In addition, the swirling action reduces the maximum temperature of the flames and increases heat absorption. The combustion air is also mixed more effectively.” A typical ROFA installation would have a booster fan(s) to supply the high velocity air to the ROFA boxes, and Mobotec would propose two 4,000 to 4,300 horsepower fans for Jim Bridger 3.

Mobotec proposes to achieve a NO<sub>x</sub> emission rate of 0.18 lb per MMBtu using ROFA technology. An operating margin of 0.04 lb per MMBtu was added to the expected rate due to Mobotec’s limited ROFA experience with western sub-bituminous coals. Under the Mobotec proposal, which is primarily based on ROFA equipment, the operation of existing LNB and OFA ports would be analyzed. While a typical installation does not require modification to the existing LNB system and the existing OFA ports are not used, results of computational fluid dynamics modeling would determine the quantity and location of new ROFA ports. The Mobotec proposal includes bent tube assemblies for OFA port installation.

Mobotec would not provide installation services, because they believe that the Owner can more cost effectively contract for these services. However, they would provide one onsite construction supervisor during installation and startup.

**Selective Non-catalytic Reduction.** With SNCR—a process generally utilized to achieve modest NO<sub>x</sub> reductions on smaller units—an amine-based reagent such as ammonia, or more commonly urea, is injected into the furnace within a temperature range of 1,600°F to 2,100°F, where it reduces NO<sub>x</sub> to nitrogen and water. NO<sub>x</sub> reductions of up to 60 percent have been achieved, although 20 to 40 percent is more realistic for most applications.

Reagent utilization, which is a measure of the efficiency with which the reagent reduces NO<sub>x</sub>, can range from 20 to 60 percent, depending on the amount of reduction, unit size, operating conditions, and allowable ammonia slip. With low reagent utilization, low temperatures, or inadequate mixing, ammonia slip occurs, allowing unreacted ammonia to create problems

downstream. The ammonia may render fly ash unsaleable, react with sulfur to foul heat exchange surfaces, and/or create a visible stack plume. Reagent utilization can have a significant impact on economics, with higher levels of NO<sub>x</sub> reduction generally resulting in lower reagent utilization and higher operating cost.

Reductions from higher baseline concentrations (inlet NO<sub>x</sub>) are lower in cost per ton, but result in higher operating costs, due to greater reagent consumption. To reduce reagent costs, S&L has assumed that combustion modifications including LNBs and advanced OFA, capable of achieving a projected NO<sub>x</sub> emission rate of 0.24 lb per MMBtu. At a further reduction of 15 percent in NO<sub>x</sub> emission rates for SNCR would result in a projected emission rate of 0.20 lb per MMBtu.

**Selective Catalytic Reduction.** While working on the same chemical principle as SNCR, SCR uses a catalyst to promote the chemical reaction. Ammonia is injected into the flue-gas stream, where it reduces NO<sub>x</sub> to nitrogen and water. Unlike the high temperatures required for SNCR, in SCR the reaction takes place on the surface of a vanadium/titanium-based catalyst at a temperature range between 580°F to 750°F. Due to the catalyst, the SCR process is more efficient than SNCR and results in lower NO<sub>x</sub> emissions. The most common type of SCR is the high-dust configuration, where the catalyst is located downstream from the boiler economizer and upstream of the air heater and any particulate control equipment. In this location, the SCR is exposed to the full concentration of fly ash in the flue gas that is leaving the boiler. The high-dust configuration is assumed for Jim Bridger 3. In a full-scale SCR, the flue ducts are routed to a separate large reactor containing the catalyst. With in-duct SCR, the catalyst is located in the existing gas duct, which may be expanded in the area of the catalyst to reduce flue gas flow velocity and increase flue gas residence time. Due to the higher removal rate, a full-scale SCR was used as the basis for analysis at Jim Bridger 3.

S&L prepared the design conditions and cost estimates for SCR at Jim Bridger 3. As with SNCR, it is generally more cost effective to reduce NO<sub>x</sub> emission levels as much as possible through combustion modifications, in order to minimize the catalyst surface area and ammonia requirements of the SCR. The S&L design basis for LNB with OFA and SCR results in a projected NO<sub>x</sub> emission rate of 0.07 lb per MMBtu. Additional catalyst surface was included in the SCR design to accommodate the characteristics of the coal used at Jim Bridger 3.

**Level of Confidence for Vendor Post-control Emissions Estimates.** In order to determine the level of NO<sub>x</sub> emissions needed to consistently achieve compliance with an established goal, a review of typical NO<sub>x</sub> emissions from coal-fired generating units was completed. As a result of this review, it was noted that NO<sub>x</sub> emissions can vary significantly around an average emissions level. Variations may result for many reasons, including coal characteristics, unit load, boiler operation including excess air, boiler slagging, burner equipment condition, coal mill fineness, and so forth.

The steps utilized for determining a level of confidence for the vendor expected value are as follows:

- Establish expected NO<sub>x</sub> emissions value from vendor.
- Evaluate vendor experience and historical basis for meeting expected values.

- Review and evaluate unit physical and operational characteristics and restrictions. The fewer variations there are in operations, coal supply, etc., the more predictable and less variant the NO<sub>x</sub> emissions are.
- For each technology expected value, there is a corresponding potential for actual NO<sub>x</sub> emissions to vary from this expected value. From the vendor information presented, along with anticipated unit operational data, an adjustment to the expected value can be made.

#### **Step 4: Evaluate Impacts and Document the Results**

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

**Energy Impacts.** Installation of LNBs and modification to the existing OFA systems are not expected to significantly impact the boiler efficiency or forced draft fan power usage. Therefore, these technologies will not have energy impacts.

The Mobotec ROFA system would require installation and operation of two 4,000 to 4,300 horsepower ROFA fans (6,410 kW total). The SNCR system would require approximately 520 kW of additional power.

Selective catalytic reduction retrofit impacts the existing flue gas fan systems, due to the additional pressure drop associated with the catalyst, which is typically a 6- to 8-inch water gage increase. Total additional power requirements for SCR installation at Jim Bridger 3 are estimated at approximately 3,220 kW, based on the S&L Study.

**Environmental Impacts.** Mobotec has predicted that carbon monoxide emissions, and unburned carbon in the ash, commonly referred to as loss on ignition, would be the same or lower than prior levels for the ROFA system.

The installation of SNCR or SCR systems could impact the saleability and disposal of fly ash due to ammonia levels, and could potentially create a visible stack plume, which may negate other visibility improvements. Other environmental impacts involve the storage of ammonia (especially if anhydrous ammonia is used), and the transportation of the ammonia to the power plant site.

**Economic Impacts.** Costs and schedules for the LNBs and OFA, SNCR, and SCR were furnished to CH2M HILL by PacifiCorp, developed using S&L's internal proprietary database, and supplemented (as needed) by vendor-obtained price quotes. The relative accuracy of these cost estimates is stated by S&L to be in the range of plus or minus 20 percent. Cost for the ROFA system was obtained from Mobotec.

A comparison of the technologies on the basis of costs, design control efficiencies, and tons of NO<sub>x</sub> removed is summarized in Table 3-3, and the first year control costs are presented in Figure 3-4. The complete economic analysis is contained in Appendix A.

**TABLE 3-3**  
**NO<sub>x</sub> Control Cost Comparison**  
*Jim Bridger 3*


Factor	Low-NO <sub>x</sub> Burners (LNBs) with Over-fire Air (OFA)	Mobotec Rotating Opposed Fire Air (ROFA)	LNB with OFA and Selective Non- Catalytic Reduction (SNCR)	LNB with OFA and Selective Catalytic Reduction (SCR)
Total Installed Capital Costs	\$8.7 million	\$20.5 million	22.0 million	\$129.6 million
Total First Year Fixed and Variable Operation and Maintenance Costs	\$0.1 million	\$2.6 million	\$1.5 million	\$3.3 million
Total First Year Annualized Cost	\$0.9 million	\$4.6 million	\$3.6 million	\$15.6 million
Power Consumption (megawatts [MW])	0	6.4	0.5	3.3
Annual Power Usage (million-MW-hours per year)	0	50.6	4.1	25.4
NO <sub>x</sub> Design Control Efficiency	46.7%	51.1%	55.6%	84.4%
NO <sub>x</sub> Removed per Year (Tons)	4,967	5,440	5,913	8,987
Nitrogen Oxide (NO <sub>x</sub> ) Design Control Efficiency	\$181/ton	\$843/ton	\$610/ton	\$1,734/ton
Incremental Control Cost (dollars per ton [\$/ton] of NO <sub>x</sub> Removed)	\$181/ton	\$7,797/ton	\$2,863/ton	\$3,896/ton

**Preliminary BART Selection.** CH2M HILL recommends selection of LNBs with OFA as BART for Jim Bridger 3 based on its significant reduction in NO<sub>x</sub> emissions, reasonable control cost, and no additional power requirements or environmental impacts. Low-NO<sub>x</sub> burners with OFA does not meet the EPA presumptive limit of 0.15 lb per MMBtu for sub-bituminous coal, but it does meet an emission rate that falls between the presumptive limit of 0.28 lb per MMBtu for bituminous coal and the limit of 0.15 lb per MMBtu for sub-bituminous coal. As discussed in the section on coal quality, the recommended technology and the achieved emission rate are deemed appropriate as BART for NO<sub>x</sub> emissions from the coals combusted at Jim Bridger 3.

#### Step 5: Evaluate Visibility Impacts

Please see Section 4, BART Modeling Analysis.

FIGURE 3-4  
First Year Control Cost for NO<sub>x</sub> Air Pollution Control Options  
*Jim Bridger 3*



### 3.2.2 BART SO<sub>2</sub> Analysis

Sulfur dioxide forms in the boiler during the combustion process, and is primarily dependent on coal sulfur content. The BART analysis for SO<sub>2</sub> emissions on Jim Bridger 3 is described below.

#### Step 1: Identify All Available Retrofit Control Technologies

A broad range of information sources were reviewed, in an effort to identify potentially applicable emission control technologies for SO<sub>2</sub> at Jim Bridger 3. This included control technologies identified as BACT or LAER by permitting agencies across the United States.

The following potential SO<sub>2</sub> control technology options were considered:

- Optimize current operation of existing wet sodium FGD system
- Upgrade wet sodium FGD system to meet SO<sub>2</sub> emission rate of 0.10 lb per MMBtu
- New dry FGD system

#### Step 2: Eliminate Technically Infeasible Options

Technical feasibility will primarily be based on the regulatory presumptive limit (used as a guideline) of 95 percent reduction in SO<sub>2</sub> emissions, or 0.15 lb per MMBtu. Based on the coal that Jim Bridger 3 currently burns, the unit would be required to achieve an 87.5 percent SO<sub>2</sub> removal efficiency to meet the presumptive limit of 0.15 lb per MMBtu.

Table 3-4 summarizes the control technology options evaluated in this BART analysis, along with projected SO<sub>2</sub> emission rates. Only one technology option can meet the applicable presumptive BART limit of 0.15 lb per MMBtu.

TABLE 3-4  
SO<sub>2</sub> Control Technology Emission Rates  
*Jim Bridger 3*

Technology	Projected Sulfur Dioxide (SO <sub>2</sub> ) Emission Rate (pound per-million British thermal units)
Presumptive Best Available Retrofit Technology Limit	0.15
Upgrade Existing Wet Sodium System	0.10
Optimize Existing Wet Sodium System	0.20
New Dry Flue Gas Desulfurization System	0.21

**Wet Sodium FGD System.** Wet sodium FGD systems operate by treating the flue gas in large scrubber vessels with a soda ash solution. The scrubber mixes the flue gas and alkaline reagent using a series of spray nozzles to distribute the reagent across the scrubber vessel. The sodium in the reagent reacts with the SO<sub>2</sub> in the flue gas to form sodium sulfite and sodium bisulfite, which are removed from the scrubber and disposed.

The wet sodium FGD system at Jim Bridger 3 currently achieves approximately 78 percent SO<sub>2</sub> removal to achieve an SO<sub>2</sub> outlet emission rate of 0.27 lb per MMBtu. Optimizing the existing wet FGD system would achieve an SO<sub>2</sub> outlet emission rate of 0.20 lb per MMBtu (83.3 percent SO<sub>2</sub> removal) by partially closing the bypass damper to reduce routine bypass flue gas flow used to reheat the treated flue gas from the scrubber, relocating the opacity monitor, and modifying the system to minimize scaling problems.

Upgrading the wet FGD system would achieve an SO<sub>2</sub> outlet emission rate of 0.10 lb per MMBtu (91.7 percent SO<sub>2</sub> removal) by closing the bypass damper to eliminate routine bypass flue gas flow used to reheat the treated flue gas from the scrubber, relocating the opacity monitor, adding new fans, adding a stack liner and drains for wet operation, and using a refined soda ash reagent. It is considered technically infeasible for the present wet FGD system to achieve 95 percent SO<sub>2</sub> removal (0.06 lb per MMBtu) on a continuous basis, since this high level of removal must be incorporated into the original design of the scrubber.

Optimizing the existing wet sodium scrubbing FGD system is projected to achieve an outlet emission rate of 0.20 lb per MMBtu which would not meet the presumptive limit of 0.15 lb SO<sub>2</sub> per MMBtu. Therefore, this option is eliminated as technically infeasible for this analysis. An upgraded wet sodium scrubbing FGD system is projected to achieve an outlet emission rate of 0.10 lb per MMBtu (91.7 percent SO<sub>2</sub> removal) which would meet the presumptive limit of 0.15 lb SO<sub>2</sub> per MMBtu for Jim Bridger 3.

**New Dry FGD System.** The lime spray dryer typically injects lime slurry in the top of the absorber vessel with a rapidly rotating atomizer wheel. The rapid speed of the atomizer wheel causes the lime slurry to separate into very fine droplets that intermix with the flue gas. The SO<sub>2</sub> in the flue gas reacts with the calcium in the lime slurry to form dry calcium sulfate particles. At Jim Bridger 3, this dry particulate matter would be captured downstream in the existing ESP, along with the fly ash. A lime spray dryer system typically produces a dry waste product suitable for landfill disposal.

The dry FGD system with the existing ESP is projected to achieve 82.5 percent SO<sub>2</sub> removal at Jim Bridger 3. This would result in a controlled SO<sub>2</sub> emission rate of 0.21 lb per MMBtu, based on an uncontrolled SO<sub>2</sub> emission rate of 1.20 lb per MMBtu. Therefore, this option cannot meet the presumptive limit of 0.15 lb SO<sub>2</sub> per MMBtu, and is eliminated from further analysis as technically infeasible.

### Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

When evaluating the control effectiveness of SO<sub>2</sub> reduction technologies, each option can be compared against benchmarks of performance. One such benchmark is the presumptive BART emission limit because Jim Bridger 3 is required to meet this limit. As indicated previously, the presumptive limit for SO<sub>2</sub> on a BART-eligible coal burning unit is 95 percent removal, or 0.15 lb per MMBtu.

The projected emission rate for an upgraded wet sodium FGD system for Jim Bridger 3 would be 0.10 lb per MMBtu. This option would meet the presumptive SO<sub>2</sub> limit of 0.15 lb per MMBtu.

#### Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

**Energy Impacts.** Upgrading the existing wet sodium FGD system would require an additional 520 kW of power.

**Environmental Impacts.** There will be incremental additions to scrubber waste disposal and makeup water requirements. Another environmental impact is a reduction of the stack gas temperature from 140°F to 120°F due to elimination of the bypassed flue gas which had provided approximately 20°F of reheat.

**Economic Impacts.** A summary of the costs and amount of SO<sub>2</sub> removed for the upgraded wet sodium FGD system is provided in Table 3-5. The complete economic analysis is contained in Appendix A.

TABLE 3-5  
SO<sub>2</sub> Control Cost Comparison (Incremental to Existing FGD System)  
Jim Bridger Unit 3

Factor	Upgraded Wet Flue Gas Desulfurization (FGD)
Total Installed Capital Costs	\$13.0 million
Total First Year Fixed and Variable Operation and Maintenance Costs	\$1.3 million
Total First Year Annualized Cost	\$2.5 million
Additional Power Consumption (megawatts [MW])	0.5
Additional Annual Power Usage (1000 MW-hours per year)	4.1
Incremental Sulfur Dioxide (SO <sub>2</sub> ) Design Control Efficiency	62.5% (91.7% based on Uncontrolled SO <sub>2</sub> )
Incremental Tons SO <sub>2</sub> Removed per Year	3,950
First Year Average Control Cost (dollars per ton [ $\$/\text{Ton}$ ] of SO <sub>2</sub> Removed)	632
Incremental Control Cost ( $\$/\text{Ton}$ of SO <sub>2</sub> Removed)	632

**Preliminary BART Selection.** CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 3 based on its significant reduction in SO<sub>2</sub> emissions (meeting presumptive limit of 0.15 lb per MMBtu), reasonable control costs, and the advantages of minimal additional power requirements and environmental impacts.

#### Step 5: Evaluate Visibility Impacts

Please see Section 4, BART Modeling Analysis.

### 3.2.3 BART PM<sub>10</sub> Analysis

Jim Bridger 3 is currently equipped with an ESP. Electrostatic precipitators remove particulate matter (PM) from the flue gas stream by charging fly ash particles with a very high direct current voltage, and attracting these charged particles to grounded collection plates. A layer of collected PM forms on the collecting plates and is removed by periodically rapping the plates. The collected ash particles drop into hoppers below the precipitator and are removed periodically by the fly ash-handling system. Historically, the ESP at Jim Bridger 3 has controlled PM<sub>10</sub> emissions to levels below 0.057 lb per MMBtu.

The BART analysis for PM<sub>10</sub> emissions at Jim Bridger 3 is described in this section. For the modeling analysis in Section 4, PM<sub>10</sub> was used as an indicator for PM, and PM<sub>10</sub> includes particulate matter less than 2.5 micrometers in aerodynamic diameter (PM<sub>2.5</sub>) as a subset.

#### Step 1: Identify All Available Retrofit Control Technologies

Two retrofit control technologies have been identified for additional PM control:

- Flue gas conditioning
- Polishing fabric filter (baghouse) downstream of existing ESP

Another available control technology is replacing the existing ESP with a new fabric filter. Because the environmental benefits of replacing the fabric filter are also achieved by the lower-cost option of installing a polishing fabric filter downstream of the existing ESP, installation of a full fabric filter was not considered in the analysis.

#### Step 2: Eliminate Technically Infeasible Options

**Flue Gas Conditioning.** If the fly ash from coal has high resistivity, such as fly ash from sub-bituminous coal, the ash is not collected effectively in an ESP. This is because the high resistivity makes the particles less willing to accept an electrical charge. Adding flue gas conditioning (FGC), which is typically accomplished by injection of sulfur trioxide (SO<sub>3</sub>), will lower the resistivity of the particles so that they will accept more charge and allow the ESP to collect the ash more effectively. Flue gas conditioning systems can account for large improvements in collection efficiency for small ESPs.

**Polishing Fabric Filter.** A polishing fabric filter could be added downstream of the existing ESP at Jim Bridger 3. One such technology is licensed by the Electric Power Research Institute, and referred to as a COHPAC (Compact Hybrid Particulate Collector). The COHPAC collects the ash that is not collected by the ESP, thus acting as a polishing device. The ESP needs to be kept in service for the COHPAC fabric filter to operate effectively.

The COHPAC fabric filter is about one-half to two-thirds the size of a full-size fabric filter, because the COHPAC has a higher air-to-cloth ratio (7 to 9:1), compared to a full-size pulse jet fabric filter (3.5 to 4:1).

#### Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

The existing ESP at Jim Bridger 3 is achieving a controlled PM emission rate of 0.057 lb per MMBtu. Utilizing flue conditioning upstream of the existing ESP is projected to reduce PM emissions to approximately 0.030 lb per MMBtu. Adding a COHPAC fabric filter downstream of the existing ESP is projected to reduce PM emissions to approximately 0.015 lb per MMBtu.

The PM<sub>10</sub> control technology emission rates are summarized in Table 3-6.

**TABLE 3-6**  
PM<sub>10</sub> Control Technology Emission Rates  
*Jim Bridger 3*

Control Technology	Short-term Projected PM <sub>10</sub> <sup>(a)</sup> Emission Rate (pound per million British thermal units)
Flue Gas Conditioning	0.030
Polishing Fabric Filter	0.015

**NOTES:**

<sup>(a)</sup> PM<sub>10</sub> refers to particulate matter less than 10 micrometers in aerodynamic diameter

#### Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

**Energy Impacts.** Energy is required to overcome the additional pressure drop from the COHPAC fabric filter and associated ductwork. Therefore, a COHPAC retrofit will require an internal diameter fan upgrade and upgrade of the auxiliary power supply system.

The COHPAC fabric filter at Jim Bridger 3 would require approximately 3.3 MW of power, equating to an annual power usage of approximately 26.3 million kW-Hr.

There is only a small power requirement of approximately 50 kW associated with flue gas conditioning.

**Environmental Impacts.** There are no negative environmental impacts from the addition of a COHPAC polishing fabric filter or flue gas conditioning system.

**Economic Impacts.** A summary of the costs and PM removed for COHPAC and flue gas conditionings are recorded in Table 3-7, and the first-year control costs for flue gas conditioning and fabric filters are shown in Figure 3-5. The complete economic analysis is contained in Appendix A.

**TABLE 3-7.**  
**PM<sub>10</sub> Control Cost Comparison (Incremental to Existing ESP)**  
**Jim Bridger 3**


Factor	Flue Gas Conditioning	Polishing Fabric Filter
Total Installed Capital Costs	\$0	\$48.4 million
Total First Year Fixed and Variable Operations and Maintenance Costs	\$0.2 million	\$1.7 million
Total First Year Annualized Cost	\$0.2 million	\$ 6.3 million
Additional Power Consumption (MW)	0.05	3.43
Annual Power Usage (million kilowatt-hours per year)	0.4	26.3
Incremental Particulate Matter (PM) Design Control Efficiency	47.4%	73.7%
Incremental Tons PM Removed per Year	639	993
First Year Average Control Cost (dollars per ton [\$/Ton] of PM Removed)	275	6,381
Incremental Control Cost (\$/Ton of PM Removed)	275	17,371

**Preliminary BART Selection.** CH2M HILL recommends selection of flue-gas conditioning upstream of the existing ESP as BART for Jim Bridger 3 based on the significant reduction in PM emissions, reasonable control costs, and advantages of minimal additional power requirements and no environmental impacts.

#### Step 5: Evaluate Visibility Impacts

Please see Section 4, BART Modeling Analysis.

**FIGURE 3-5**  
First Year Control Cost for PM Air Pollution Control Options  
*Jim Bridger 3*



## **4.0 BART Modeling Analysis**

---

### **4.1 Model Selection**

CH2M HILL used the CALPUFF modeling system to assess the visibility impacts of emissions from Jim Bridger 3 at nearby Class I areas. The Class I areas potentially affected are located more than 50 kilometers but less than 300 kilometers from the Jim Bridger 3 facility. The Class I areas include the following wilderness areas (WA):

- Bridger WA
- Fitzpatrick WA
- Mt. Zirkel WA

The CALPUFF modeling system includes the CALMET meteorological model, a Gaussian puff dispersion model (CALPUFF) with algorithms for chemical transformation and deposition, and a post processor capable of calculating concentrations, visibility impacts, and deposition (CALPOST). The CALPUFF modeling system was applied in a full, refined mode. Version numbers of the various programs in the CALPUFF system used by CH2M HILL were as follows:


- CALMET Version 5.53a, Level 040716
- CALPUFF Version 5.711a, Level 040716
- CALPOST Version 5.51, Level 030709

### **4.2 CALMET Methodology**

#### **4.2.1 Dimensions of the Modeling Domain**

CH2M HILL used the CALMET model to generate a three-dimensional wind field and other meteorological parameters suitable for use by the CALPUFF model. A modeling domain was established to encompass the Jim Bridger 3 facility and allow for a 50-kilometer buffer around the Class I areas that were within 300 kilometers of the facility; the grid resolution was 4 kilometers. Figure 4-1 shows the extent of the modeling domain. Except when specifically instructed otherwise by the Wyoming Department of Environmental Quality – Air Quality Division (WDEQ-AQD), CH2M HILL followed the methodology spelled out in the WDEQ-AQD BART Modeling Protocol, a copy of which is included as Appendix B.

CH2M HILL used the Lambert Conformal Conic map projection for the analysis due to the large extent of the domain. The latitude of the projection origin and the longitude of the central meridian were chosen at the approximate center of the domain. Standard parallels were drawn to represent one-sixth and five-sixths of the north-south extent of the domain to minimize distortion in the north-south direction.



**Figure 4-1**  
**Jim Bridger Source-Specific**  
**Class I Areas to be Addressed**

**PACIFICORP**

**CH2MHILL**

The default technical options listed in TRC Companies, Inc.'s (TRC) current example CALMET.inp file were used for CALMET. Vertical resolution of the wind field included ten layers, with vertical face heights as follows (in meters):

- 0, 20, 40, 100, 140, 320, 580, 1020, 1480, 2220, 3500

Other user-specified model options were set to values established by WDEQ-AQD which appear in Table 3 of Appendix B. Table 4-1 lists the key user-specified options used for this analysis.

TABLE 4-1  
User-specified CALMET Options  
*Jim Bridger 3*

CALMET Input Parameter	Value
<b>CALMET Input Group 2</b>	
Map projection (PMAP)	Lambert Conformal
Grid spacing (DGRIDKM)	4
Number vertical layers (NZ)	10
Top of lowest layer (m)	20
Top of highest layer (m)	3500
<b>CALMET Input Group 4</b>	
Observation mode (NOOBS)	0
<b>CALMET Input Group 5</b>	
Prog. Wind data (IPROG)	14
(RMAX1)	30
(RMAX2)	50
Terrain influence (TERRAD)	15
(R1)	5
(R2)	25
<b>CALMET Input Group 6</b>	
Max mixing ht (ZIMAX)	3500

#### 4.2.2 CALMET Input Data

CH2M HILL ran the CALMET model to produce three years of analysis: 2001, 2002, and 2003. WDEQ-AQD provided 12-km resolution Mesoscale Meteorological Model, Version 5 (MM5) meteorological data fields that covered the entire modeling domain for each study year.

These three data sets were chosen because they are current and have been evaluated for quality. The MM5 data were used as input to CALMET as the "initial guess" wind field. The initial guess wind field was adjusted by CALMET for local terrain and land use effects to generate a Step 1 wind field, and further refined using local surface observations to create a final Step 2 wind field.

Surface data for 2001 through 2003 were obtained from the National Climatic Data Center. CH2M HILL processed the data from the National Weather Service's Automated Surface Observing System network for all stations that are in the domain. The surface data were obtained in abbreviated DATSAV3 format. A conversion routine available from the TRC Web site was used to convert the DATSAV3 files to CD-144 format for input into the SMERGE preprocessor and CALMET.


Land use and terrain data were obtained from the U.S. Geological Survey (USGS). Land use data were obtained in Composite Theme Grid format from the USGS, and the Level 1 USGS land use categories were mapped into the 14 primary CALMET land use categories. Surface properties such as albedo, Bowen ratio, roughness length, and leaf area index were computed from the land use values. Terrain data were taken from USGS 1-degree Digital Elevation Model data, which primarily derive from USGS 1:250,000 scale topographic maps. Missing land use data were filled with values that were assumed appropriate for the missing area.

Precipitation data were obtained from the National Climatic Data Center. All available data in fixed-length, TD-3240 format were obtained for the modeling domain. The list of available stations that have collected complete data varies by year, but CH2M HILL processed all available stations/data within the domain for each year. Precipitation data were prepared with the PXTRACT/PMERGE processors in preparation for use within CALMET.

Upper-air data were prepared for the CALMET model with the READ62 preprocessor for the following stations:

- Denver, Colorado
- Salt Lake City, Utah
- Riverton, Wyoming
- Rapid City, South Dakota

Figure 4-2 shows the locations of surface and upper air stations within the MM5 modeling domain.



**Figure 4-2**  
**Surface and Upper Air Stations Used in the Jim Bridger BART Analysis**

#### 4.2.3 Validation of CALMET Wind Field

CH2M HILL used the CALDESK data display and analysis system (v2.97, Enviromodeling Ltd.) to view plots of wind vectors and other meteorological parameters to evaluate the CALMET wind fields. The CALDESK displays were compared to observed weather conditions, as depicted in surface and upper-air weather maps (National Oceanic and Atmospheric Administration, 2006).

### 4.3 CALPUFF Modeling Approach

For the BART control technology visibility improvement modeling, CH2M HILL followed WDEQ-AQD guidance provided (WDEQ-AQD, 2006).

CH2M HILL drove the CALPUFF model with the meteorological output from CALMET over the modeling domain described earlier. The CALPUFF model was used to predict visibility impacts for the pre-control (baseline) scenario for comparison to the predicted impacts for post-control scenarios for Jim Bridger 3.

#### 4.3.1 Background Ozone and Ammonia

Hourly values of background ozone concentrations were used by CALPUFF for the calculation of SO<sub>2</sub> and NO<sub>x</sub> transformation with the MESOPUFF II chemical transformation scheme. CH2M HILL obtained hourly ozone data from the following stations located within the modeling domain for 2001, 2002, and 2003:

- Rocky Mountain National Park, Colorado
- Craters of the Moon National Park, Idaho
- Highland, Utah
- Thunder Basin National Grasslands, Wyoming
- Yellowstone National Park, Wyoming
- Centennial, Wyoming
- Pinedale, Wyoming

For periods of missing hourly ozone data, the chemical transformation relied on a monthly default value of 44 parts per billion. Background ammonia was set to 2 parts-per billion. Both of these background values were taken from the guidance document (WDEQ-AQD, 2006).

#### 4.3.2 Stack Parameters

The stack parameters used for the baseline modeling reflect those that are in place under the current permit for Jim Bridger 3. Post-control stack parameters reflect the anticipated changes associated with installation of the control technology alternatives that are being evaluated. The maximum heat input rate of 6,000 MMBtu per hour was used to calculate a maximum emission rate. Measured velocities and stack flow rates were used in the modeling to represent a worst-case situation.

#### 4.3.3 Emission Rates

Pre-control emission rates for Jim Bridger 3 reflect peak 24-hour average emissions that may occur under the source's current permit. The emission rates reflect actual emissions under normal operating conditions, as described by the EPA in the *Regional Haze Regulations and Guidelines for Best Available Retrofit Technology Determinations; Final Rule* (40 CFR Part 51).

CH2M HILL used available continuous emission monitoring data to determine peak 24-hour emission rates. Data reflected operations from the most recent 3- to 5-year period unless a more recent period was more representative. Allowable short-term (24-hour or shorter period) emissions or short-term emission limits were used if continuous emission monitoring data were not available.

Emissions were modeled for the following pollutants:

- SO<sub>2</sub>
- NO<sub>x</sub>
- Coarse particulate (PM<sub>2.5</sub><diameter<PM<sub>10</sub>)
- Fine particulate (diameter<PM<sub>2.5</sub>)
- Sulfates

Post-control emission rates reflect the effects of the emissions control scenario under consideration. Modeled pollutants were the same as those listed for the pre-control scenario.

#### 4.3.4 Post-control Scenarios

Four post-control modeling scenarios were developed to cover the range of effectiveness for the combination of the individual NO<sub>x</sub>, SO<sub>2</sub>, and PM control technologies being evaluated. The selection of each control device was made based on the engineering analyses described in Section 3 for reasonable technologies that would meet or exceed the presumptive BART levels for each pollutant.

- **Scenario 1:** New LNB with OFA modifications, upgraded wet FGD system and flue gas conditioning for enhanced ESP performance. As indicated previously, this scenario represents CH2M HILL's preliminary BART recommendation.
- **Scenario 2:** New LNB with OFA modifications, upgraded wet FGD system and new polishing fabric filter.
- **Scenario 3:** New LNB with OFA modifications and SCR, upgraded wet FGD system and flue gas conditioning for enhanced ESP performance.
- **Scenario 4:** New LNB with OFA modifications and SCR, upgraded wet FGD system and new polishing fabric filter.

The ROFA option and LNB with OFA & SCR option for NO<sub>x</sub> control were not included in the modeling scenarios because their control effectiveness is between the LNB with OFA option and the SCR option. Modeling of NO<sub>x</sub>, SO<sub>2</sub>, and PM controls alone was not performed because any final BART solution will include a combination of control technologies for NO<sub>x</sub>, SO<sub>2</sub>, and PM.

Table 4-2 presents the stack parameters and emission rates used for the Jim Bridger 3 analysis for baseline and post-control modeling. In accordance with the WDEQ BART modeling protocol, elemental carbon stack emissions and organic aerosol emissions were not modeled.

#### 4.3.5 Modeling Process

The CALPUFF modeling for the control technology options for Jim Bridger 3 followed this sequence:

- Model pre-control (baseline) emissions
- Model preferred post-control scenario (if applicable)
- Determine degree of visibility improvement
- Model other control scenarios
- Determine degree of visibility improvement
- Factor visibility results into the BART “five-step” evaluation

#### 4.3.6 Receptor Grids

Discrete receptors for the CALPUFF modeling were placed at uniform receptor spacing along the boundary and in the interior of each area of concern. Class I area receptors were taken from the National Park Service database for Class I area modeling receptors. The TRC COORDS program was used to convert all latitude/longitude coordinates to Lambert Conformal Conic coordinates, including receptors, meteorological stations, and source locations.

TABLE I-2  
BART Model Input Data  
Jim Bridger<sup>3</sup>

	Baseline	Post-control Scenario 1	Post-control Scenario 2	Post-control Scenario 3	Post-control Scenario 4
Model Input Data		LNB with wet Flue Gas Desulfurization (FGD) and Electrostatic Precipitator (ESP)	LNB with OFA and SCR, Upgrade Wet FGD & FGC for Enhanced ESP Performance	LNB with OFA and SCR, Upgrade Wet FGD & FGC for Enhanced ESP Performance	LNB with OFA and SCR, Upgrade Wet FGD, New Fabric Filter
Sulfur Dioxide (SO <sub>2</sub> ) Stack Emissions (pounds per hour [lb/hr])	1,802	600	600	600	600
Nitrogen Oxide (NO <sub>x</sub> ) Stack Emissions (lb/hr)	2,700	1,440	1,440	1,440	420
PM <sub>10</sub> Stack Emissions (lb/hr)	342	180	90.0	180	90.0
Coarse Particulates ( $\text{PM}_{2.5}$ -diameter < $\text{PM}_{10}$ ) Stack Emissions (lb/hr) <sup>(a)</sup>	147	77.4	51.3	77.4	51.3
Fine Particulates ( $\text{PM}_{2.5}$ -diameter < $\text{PM}_{10}$ ) Stack Emissions (lb/hr) <sup>(a)</sup>	195	103	38.7	103	38.7
Sulfuric Acid (H <sub>2</sub> SO <sub>4</sub> ) Stack Emissions (lb/hr)	55.2	55.2	55.2	94.8	94.8
H <sub>2</sub> SO <sub>4</sub> as Sulfate (SO <sub>4</sub> ) Stack Emissions (lb/hr)	54.1	54.1	54.1	92.9	92.9
Ammonium Sulfate ((NH <sub>4</sub> ) <sub>2</sub> SO <sub>4</sub> ) Stack Emissions (lb/hr)				7.02	7.02
(NH <sub>4</sub> ) <sub>2</sub> SO <sub>4</sub> as SO <sub>4</sub> Stack Emissions (lb/hr)				5.10	5.10
(NH <sub>4</sub> )HSO <sub>4</sub> Stack Emissions (lb/hr)				12.2	12.2
(NH <sub>4</sub> )HSO <sub>4</sub> as SO <sub>4</sub> Stack Emissions (lb/hr)				10.2	10.2
Total Sulfate (SO <sub>4</sub> ) (lb/hr)	54.1	54.1	54.1	108	108
Stack Conditions					
Stack Height (meters)	152	152	152	152	152
Stack Exit Diameter (meters)	7.32	7.32	7.32	7.32	7.32
Stack Exit Temperature (Kelsin)	333	322	333	333	333
Stack Exit Velocity (meters per second)	25.6	24.8	27.4	27.4	27.4

NOTES:

<sup>(a)</sup> Based on AP-42, Table 1-8 coarse particulates are counted as a percentage of PM<sub>10</sub>. This equates to 43 percent ESP and 57 percent baghouse. PM<sub>10</sub> and PM<sub>2.5</sub> refer to particulate matter less than 10 and 2.5 micrometers, respectively, in aerodynamic diameter.

<sup>(b)</sup> Based on AP-42, Table 1-6, fine particulates are counted as a percentage of PM<sub>10</sub>. This equates to 37 percent ESP and 43 percent baghouse. PM<sub>10</sub> and PM<sub>2.5</sub> refer to particulate matter less than 10 and 2.5 micrometers, respectively, in aerodynamic diameter.

Total Sulfate (SO<sub>4</sub>) (lb/hr) = H<sub>2</sub>SO<sub>4</sub> as Sulfate (SO<sub>4</sub>) Stack Emissions (lb/hr) + (NH<sub>4</sub>)<sub>2</sub>SO<sub>4</sub> as SO<sub>4</sub> Stack Emissions (lb/hr)

Scenarios 2, 3, and 4 were not remodeled at the lower, correct velocity of 81.24 fps due to lack of time and the fact that the conclusions to select Scenario 1 would not have changed.

## 4.4 CALPOST

The CALPOST processor was used to determine 24-hour average visibility results with output specified in deciview (dV) units. Calculations of light extinction were made for each pollutant modeled. The sum of all extinction values were used to calculate the delta-dV ( $\Delta$  dV) change relative to natural background. The following default light extinction coefficients for each pollutant were used:

- Ammonium sulfate      3.0
- Ammonium nitrate      3.0
- PM coarse (PM<sub>10</sub>)      0.6
- PM fine (PM<sub>2.5</sub>)      1.0
- Organic carbon      4.0
- Elemental carbon      10.0

CALPOST visibility Method 6 was used to determine the visibility impacts. Monthly relative humidity factors were used in the light extinction calculations to account for the hygroscopic characteristics of nitrate and sulfate particles. Table 5 of the Wyoming BART Air Modeling Protocol (Appendix B) lists the monthly relative humidity factors for the Class I areas. These values were used for the particular Class I area being modeled.

The natural background conditions as a reference for determining the delta-deciview ( $\Delta$ dV) change represented the 20 percent best natural visibility days. The EPA BART guidance document provided dV values for the 10 percent best days for each Class I area, but did not provide individual species concentration data for the 20 percent best days. Species concentrations corresponding to the 20 percent best days were calculated for each Class I area by scaling back the annual average species concentrations given in Table 2-1 of *Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule* (EPA, 2003). A separate scaling factor was derived for each Class I area such that, when multiplied by the Guidance table annual concentrations, the 20 percent best days dV value for that area would be calculated. This procedure was taken from *Protocol for BART-Related Visibility Improvement Modeling Analysis in North Dakota* (North Dakota Department of Health, 2005). The Wyoming BART Air Modeling Protocol (see Appendix B) did provide natural background concentrations of aerosol components to use in the BART analysis. Table 4-3 lists the annual average species concentrations from the BART protocol.

**TABLE 4-3**  
**Average Natural Levels of Aerosol Components**  
*Jim Bridger 3*

Aerosol Component	Average Natural Concentration (micrograms per cubic meter) for Mt. Zirkel Class I Wilderness Area	Average Natural Concentration (micrograms per cubic meter) for Fitzpatrick and Bridger Class I Wilderness Areas
Ammonium Sulfate	0.046	0.045
Ammonium Nitrate	0.038	0.038
Organic Carbon	0.179	0.178
Elemental Carbon	0.008	0.008
Soil	0.190	0.189
Coarse Mass	1.141	1.136

**NOTES:**

Source: Table 6 of the Wyoming BART Air Modeling Protocol

## 4.5 Presentation of Modeling Results

This section presents the results of the CALPUFF visibility improvement modeling analysis for Jim Bridger 3.

### 4.5.1 Visibility Changes for Baseline vs. Preferred Scenario

CH2M HILL modeled Jim Bridger 3 for the baseline conditions and post-control scenarios. The post-control scenarios included emission rates for NO<sub>x</sub>, SO<sub>2</sub>, and PM<sub>10</sub> that would be achieved if BART technology were installed on Jim Bridger 3.

Baseline (and post-control) 98<sup>th</sup> percentile results were greater than 0.5 ΔdV for the Bridger WA, Fitzpatrick WA, and Mt. Zirkel WA. The 98<sup>th</sup> percentile results for each Class I area are presented in Table 4-4.

TABLE 4  
Costs and Viability Modeling Results for Baseline vs. Post-Control Scenarios at Class I Areas  
Jim Bridger 3

Scenario	Total First Year Annualized Cost	Class I Windermere Area	Modeling Results				Cost per Reduction in No. of Days Above 0.5 dV	Incremental Cost per dV Reduction	Incremental Cost per Reduction in No. of Days Above 0.5 dV
			Highest Change in Decline (ΔdV)	95 <sup>th</sup> Percentile (ΔdV)	Number (No.) of Days Above 0.5 dV	Cost per dV Reduction			
<b>2001</b>									
Baseline; current operation with wet Flue Gas Desulfurization (FGD), Electrostatic Precipitator (ESP)	\$3,387,923	Bridger Fitzpatrick Mt. Zirkel	2.506	0.741	15	—	—	—	—
Scenario 1: Low-NO <sub>x</sub> Burner (LNBS) with Over Fire Air (OFA), upgrade wet FGD, Flue Gas Conditioning (FGC) for enhanced ESP performance	\$3,387,923	Bridger Fitzpatrick Mt. Zirkel	1.945	0.418	27	—	—	—	—
Scenario 2: LNB with OFA, upgrade wet FGD, polishing fabric filter	\$9,726,040	Bridger Fitzpatrick Mt. Zirkel	1.365	0.386	7	\$9,543,444	\$423,480	\$423,480	\$423,480
Scenario 3: LNB with OFA and Selective Catalytic Reduction (SCR), upgrade wet FGD, FCC for enhanced ESP performance	\$18,074,111	Bridger Fitzpatrick Mt. Zirkel	1.165	0.223	3	\$17,373,862	\$846,381	\$846,381	\$846,381
Scenario 4: LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	\$24,412,229	Bridger Fitzpatrick Mt. Zirkel	1.393	0.376	16	\$6,872,054	\$307,953	\$307,953	\$307,953
Baseline; current operation with wet FGD, "ESP"	\$3,387,923	Bridger Fitzpatrick Mt. Zirkel	2.178	0.228	—	—	—	—	—
Scenario 1: LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	\$3,387,923	Bridger Fitzpatrick Mt. Zirkel	1.365	0.386	7	\$9,543,444	\$423,480	\$423,480	\$423,480
Scenario 2: LNB with OFA, upgrade wet FGD, polishing fabric filter	\$9,726,040	Bridger Fitzpatrick Mt. Zirkel	1.165	0.223	3	\$17,373,862	\$846,381	\$846,381	\$846,381
Scenario 3: LNB with OFA and SCR, upgrade wet FGD, FCC for enhanced ESP performance	\$18,074,111	Bridger Fitzpatrick Mt. Zirkel	1.165	0.223	3	\$17,373,862	\$846,381	\$846,381	\$846,381
Scenario 4: LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	\$24,412,229	Bridger Fitzpatrick Mt. Zirkel	1.393	0.376	16	\$6,872,054	\$307,953	\$307,953	\$307,953
<b>2002</b>									
Baseline; current operation with wet FGD, "ESP"	\$3,387,923	Bridger Fitzpatrick Mt. Zirkel	2.506	0.741	27	—	—	—	—
Scenario 1: LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	\$3,387,923	Bridger Fitzpatrick Mt. Zirkel	1.945	0.418	34	—	—	—	—
Scenario 2: LNB with OFA, upgrade wet FGD, polishing fabric filter	\$9,726,040	Bridger Fitzpatrick Mt. Zirkel	1.365	0.386	14	\$5,713,191	\$260,609	\$260,609	\$260,609
Scenario 3: LNB with OFA and SCR, upgrade wet FGD, FCC for enhanced ESP performance	\$18,074,111	Bridger Fitzpatrick Mt. Zirkel	1.165	0.223	4	\$10,083,103	\$483,989	\$483,989	\$483,989
Scenario 4: LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	\$24,412,229	Bridger Fitzpatrick Mt. Zirkel	1.393	0.376	13	\$4,980,355	\$161,330	\$161,330	\$161,330

TABLE A-4  
Costs and Viability Modeling Results for Baseline vs. Post-Control Scenarios at Class I Areas  
Jim Bridger 3

Scenario	Total First Year Annualized Cost	Class I Wilderness Area	Modeling Results				Cost per Reduction in No. of Days Above 0.5 dV	Incremental Cost per dV Reduction
			Highest Change in Peckview (ΔdV)	98th Percentile (ΔdV)	Number (No.) of Days Above 0.5 dV	Cost per dV Reduction		
<b>2003</b>								
Baseline: current operation with wet FGD, ESP		Bridger Fitzpatrick Mt. Zirkel	1,703 1,943 1,952	0.759 0.378 1.228	16 7 35	— — —	—	—
Scenario 1: LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	\$3,387,923 \$3,387,923	Bridger Fitzpatrick Mt. Zirkel	0.983 1,105 1,041	0.414 0.192 0.734	5 2 18	\$9,820,065 \$18,244,537	\$207,993 \$677,585	
Scenario 2: LNB with OFA, upgrade wet FGD, polishing fabric filter	\$9,726,040 \$9,726,040	Bridger Fitzpatrick Mt. Zirkel	1,088 1,053	0.410 0.188 0.686	5 2 15	\$51,189,684 \$17,944,723	\$1,584,528,376 \$192,044,115	NA NA
Scenario 3: LNB with OFA and SCR, upgraded wet FGD, FGC for enhanced ESP performance	\$18,074,111 \$18,074,111	Bridger Fitzpatrick Mt. Zirkel	0.852 0.682	0.258 0.118	3 2	\$26,076,071 \$89,515,813	\$54,321,522 \$3,614,822	\$4,174,036 NA
Scenario 4: LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	\$24,412,229 \$24,412,229	Bridger Fitzpatrick Mt. Zirkel	0.808 0.663	0.432 0.115	5 2	\$22,708,170 \$92,822,163	\$802,470 \$4,882,446	\$854,807 NA
<b>3-year Average</b>								
Baseline: Current Operation with wet FGD, ESP		Bridger Fitzpatrick Mt. Zirkel	0.862 0.503	0.862 0.317	19,3 8,3	— —	—	—
Scenario 1: LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	\$3,387,923 \$3,387,923	Bridger Fitzpatrick Mt. Zirkel	0.551 0.264	8.7 3.0	8,7 \$14,175,408	\$7,850,609 \$635,235	\$37,618	
Scenario 2: LNB with OFA, upgrade wet FGD, polishing fabric filter	\$9,726,040 \$9,726,040	Bridger Fitzpatrick Mt. Zirkel	0.761 0.250	15.0 3.7	15.0 \$6,086,088	\$195,290		
Scenario 3: LNB with OFA and SCR, upgraded wet FGD, FGC for enhanced ESP performance	\$18,074,111 \$18,074,111	Bridger Fitzpatrick Mt. Zirkel	0.349 0.157	5.0 1.3	14.3 \$16,111,607	\$550,531	\$47,077,422	\$2,782,680
Scenario 4: LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	\$24,412,229 \$24,412,229	Bridger Fitzpatrick Mt. Zirkel	0.452 0.156	4.7 1.3	14.3 \$28,523,059	\$2,582,016	\$89,784,208	\$2,577,745
						\$61,248	\$3,193,457	\$883,554
						\$37,887,577	\$1,627,482	\$584,183,516
						\$70,015,853	\$3,487,461	\$2,112,705,834
						\$27,838,065	\$861,608	\$543,267,215

## NOTES:

Sample Calculations: Cost per dV Reduction for Scenario 1 for 2001: = \$3,387,923 / (0.968 - 0.492) = \$8,045,751  
Sample Calculations: Cost per Reduction in No. of Days Exceeding 0.5 dV for 2001: = \$3,387,923 / (20 - 7) = \$280,609

## **5.0 Preliminary Assessment and Recommendations**

---

As a result of the completed technical and economic evaluations, and consideration of the modeling analysis for Jim Bridger 3, the preliminary recommended BART controls for NO<sub>x</sub>, SO<sub>2</sub>, and PM are as follows:

- New LNBs and modifications to the OFA system for NO<sub>x</sub> control
- Upgrade wet sodium FGD for SO<sub>2</sub> control
- Add flue gas conditioning upstream of existing ESPs for PM control

The above recommendations were identified as Scenario 1 for the modeling analysis described in Section 4. Visibility improvements for all emission control scenarios were analyzed, and the results are compared below, utilizing a least-cost envelope, as outlined in the *New Source Review Workshop Manual* (EPA, 1990). The purpose of this analysis is to use an objective, EPA-approved methodology to evaluate and make the final recommendation of BART control technology.

### **5.1 Least-cost Envelope Analysis**

For the control scenarios modeled in Section 4, Tables 5-1 through 5-3 list the total annualized cost, cost per dV reduction, and cost per reduction in number of days above 0.5 dV for each of the three Class I areas. A comparison of the incremental results between selected scenarios is provided in Tables 5-4 through 5-6. Figures 5-1 to 5-6 show the total annualized cost versus number of days above 0.5 dV, and the total annualized cost versus 98<sup>th</sup> percentile ΔdV reduction, for the three Class I areas.

#### **5.1.1 Analysis Methodology**

On page B-41 of the *New Source Review Workshop Manual*, the EPA states that: "Incremental cost-effectiveness comparisons should focus on annualized cost and emission reduction differences between dominant alternatives. Dominant set of control alternatives are determined by generating what is called the envelope of least-cost alternatives. This is a graphical plot of total annualized costs for a total emissions reductions for all control alternatives identified in the BACT analysis..."

An analysis of incremental cost effectiveness has been conducted. This analysis was performed in the following way. First, the control option scenarios are ranked in ascending order of annualized total costs, as shown in Tables 5-1 through 5-3. The incremental cost effectiveness data, expressed per day and per dV, represents a comparison of the different scenarios, and is summarized in Tables 5-4 through 5-6 for each of the three wilderness areas. Then the most reasonable smooth curve of least-cost control option scenarios is plotted for each analysis. Figures 5-1 through 5-6 present the two analyses (cost per dV reduction and cost per reduction in number of days above 0.5 dV) for each of the three Class I areas impacted by the operation of Jim Bridger 3.

In Figure 5-1, the four scenarios are compared as a graph of total annualized cost versus number of days above 0.5 dV. EPA states that "in calculating incremental costs, the analysis should only be conducted for control options that are dominant among all possible options." In Figure 5-1, the dominant set of control options, Scenarios 1, 3 and 4, represent the least-cost envelope depicted by the curvilinear line connecting them. Scenario 2 is an inferior option and should not be considered in the derivation of incremental cost effectiveness. Scenario 2 represents inferior controls, because Scenario 1 provides approximately the same amount of visibility impact reduction for less cost than Scenario 2. The incremental cost effectiveness is determined by the difference in total annual costs between two contiguous scenarios, divided by the difference in emissions reduction.

**TABLE 5-1**  
Control Scenario Results for the Bridger Class I Wilderness Area  
*Jim Bridger 3*

Scenario	Controls	98 <sup>th</sup> Percentile Deciview (dV) Reduction	Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet Flue Gas Desulfurization (FGD), Electrostatic Precipitator (ESP)	0.00	0.0	0.0	0.0	0.0
1	Low-NO <sub>x</sub> Burners (LNBs) with Over Fire Air (OFA), upgraded wet FGD system, flue Gas Conditioning (FGC) for enhanced ESP performance	0.43	10.7	3.4	7.9	0.3
2	LNB with OFA, upgraded wet FGD system, and new polishing fabric filter	0.46	11.3	9.7	21.2	0.9
3	LNB with OFA and Selective Catalytic Reduction (SCR), upgraded wet FGD system, FGC for enhanced ESP performance	0.63	14.3	18.1	28.5	1.3
4	LNB with OFA and SCR, upgraded wet FGD system, new polishing fabric filter	0.64	15.0	24.4	37.9	1.6

**TABLE 5-2**  
**Control Scenario Results for the Fitzpatrick Class I Wilderness Area**  
*Jim Bridger 3*

Scenario	Controls	98 <sup>th</sup> Percentile dV Reduction	Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet Flue Gas Desulfurization (FGD), Electrostatic Precipitator (ESP)	0.00	0.0	0.0	0.0	0.0
1	Low-NO <sub>x</sub> Burners (LNBs) with Over Fire Air (OFA), upgraded wet FGD system, flue Gas Conditioning (FGC) for enhanced ESP performance	0.24	5.3	3.4	14.2	0.6
2	LNB with OFA, upgraded wet FGD system, and new polishing fabric filter	0.25	4.7	9.7	38.5	2.1
3	LNB with OFA and Selective Catalytic Reduction (SCR), upgraded wet FGD system, FGC for enhanced ESP performance	0.35	7.0	18.1	52.3	2.6
4.	LNB with OFA and SCR, upgraded wet FGD system, new polishing fabric filter	0.35	7.0	24.4	70.0	3.5

**TABLE 5-3**  
**Control Scenario Results for the Mt. Zirkel Class I Wilderness Area**  
*Jim Bridger 3*

Scenario	Controls	98 <sup>th</sup> Percentile dV Reduction	Average Number of Days Above 0.5 dV (Days)	Total Annualized Cost (Million\$)	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Reduction in No. of Days Above 0.5 dV (Million\$/Day Reduced)
Base	Current Operation with Wet Flue Gas Desulfurization (FGD), Electrostatic Precipitator (ESP)	0.00	0.0	\$0.0	\$0.0	\$0.0
1	Low-NO <sub>x</sub> Burners (LNBs) with Over Fire Air (OFA), upgraded wet FGD system, flue Gas Conditioning (FGC) for enhanced ESP performance	0.56	17.0	\$3.4	\$6.1	\$0.2
2	LNB with OFA, upgraded wet FGD system, and new polishing fabric filter	0.60	17.7	\$9.7	\$16.1	\$0.6
3	LNB with OFA and Selective Catalytic Reduction (SCR), upgraded wet FGD system, FGC for enhanced ESP performance	0.87	27.3	\$18.1	\$20.9	\$0.7
4	LNB with OFA and SCR, upgraded wet FGD system, new polishing fabric filter	0.88	28.3	\$24.4	\$27.8	\$0.9

**TABLE 5-4**  
**Brider Class I Wilderness Area Incremental Analysis Data**  
*Jim Bridger 3*

Options Compared	Incremental Reduction in Days Above 0.5 Deciview (dV) (Days)	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	10.7	0.43	\$0.32	\$7.9
Scenario 1 and Scenario 2	0.7	0.03	\$9.5	\$221.1
Scenario 1 and Scenario 3	3.7	0.20	\$4.0	\$72.5
Scenario 1 and Scenario 4	4.3	0.21	\$4.9	\$98.6

**TABLE 5-5**  
**Fitzpatrick Class I Wilderness Area Incremental Analysis Data**  
*Jim Bridger 3*

Options Compared	Incremental Reduction in Days Above 0.5 Deciview (dV) (Days))	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	5.3	0.24	\$0.64	\$14.2
Scenario 1 and Scenario 2	NA	0.01	NA	\$463.8
Scenario 1 and Scenario 3	1.7	0.11	\$8.8	\$137.7
Scenario 1 and Scenario 4	1.7	0.11	\$12.6	\$191.7

**TABLE 5-6**  
**Mt. Zirkel Class I Wilderness Area Incremental Analysis Data**  
*Jim Bridger 3*

Options Compared	Incremental Reduction in Days Above 0.5 Deciview (dV) (Days))	Incremental dV Reductions (dV)	Incremental Cost Effectiveness (Million\$/Days)	Incremental Cost Effectiveness (Million\$/dV)
Baseline and Scenario 1	17.0	0.56	\$0.20	\$6.09
Scenario 1 and Scenario 2	0.7	0.05	\$9.5	\$134.9
Scenario 1 and Scenario 3	10.3	0.31	\$1.4	\$47.6
Scenario 1 and Scenario 4	11.3	0.32	\$1.9	\$65.6

FIGURE 5-1  
Least-cost Envelope Bridger Class I WA Days Reduction  
*Jim Bridger 3*




FIGURE 5-2  
Least-cost Envelope Bridger Class I WA 98<sup>th</sup> Percentile Reduction  
*Jim Bridger 3*




FIGURE 5-3  
Least-cost Envelope Fitzpatrick Class I WA Days Reduction  
Jim Bridger 3







FIGURE 5-4  
Least-cost Envelope Fitzpatrick Class I WA 98<sup>th</sup> Percentile Reduction  
Jim Bridger 3



**FIGURE 5-5**  
Least-cost Envelope Mt. Zirkel Class I WA Days Reduction  
*Jim Bridger 3*



**FIGURE 5-6**  
Least-cost Envelope Mt. Zirkel Class I WA 98<sup>th</sup> Percentile Reduction  
*Jim Bridger 3*



### 5.1.2 Analysis Results

Results of the least-cost Analysis, shown in Tables 5-1 through 5-6 and Figures 5-1 through 5-6 on the preceding pages, confirm the selection of Scenario 1, based on incremental cost and visibility improvements. Scenario 2 is eliminated because it is to the left of the curve formed by the "dominant" control alternative scenarios, which indicates a scenario with lower improvement and/or higher costs. Scenario 3 is not selected due to very high incremental costs for both a cost per day of improvement and a cost per dV reduction. While Scenario 4 provides some potential visibility advantage over Scenario 1, the projected improvement is less than half a dV, and the projected costs are excessive.

Analysis of the results for the Jim Bridger Class I WA in Tables 5-1 and 5-4 and Figures 5-1 and 5-2 illustrates these conclusions. The greatest reduction in 98<sup>th</sup> percentile dV and number of days above 0.5 dV is between the Baseline and Scenario 1. The incremental cost-effectiveness for Scenario 1—compared to the Baseline for the Bridger WA, for example—is reasonable at \$320,000 per day and \$7.9 million/dV. However, the incremental cost effectiveness for Scenario 3 compared to Scenario 1, again for the Bridger WA, is excessive at \$4.0 million per day and \$72.5 million per dV. The same conclusions are reached for each of the three wilderness areas studied. Therefore, Scenario 1 represents BART for Jim Bridger 3.

## 5.2 Recommendations

### 5.2.1 NO<sub>x</sub> Emission Control

The BART presumptive NO<sub>x</sub> limit assigned by EPA for tangentially-fired boilers burning sub-bituminous coal is 0.15 lb per MMBtu. However, as documented in Section 3.2.1, the characteristics of the Jim Bridger coals are more closely aligned with bituminous coals, and have been assigned a presumptive BART NO<sub>x</sub> limit of 0.28 lb per MMBtu.

CH2M HILL recommends LNB with OFA as BART for Jim Bridger 3, based on the projected significant reduction in NO<sub>x</sub> emissions, reasonable control costs, and the advantages of no additional power requirements or non-air quality environmental impacts. NO<sub>x</sub> reductions are expected to be similar to those realized at Jim Bridger 2. CH2M HILL recommends that the unit be permitted at a rate of 0.26 lb per MMBtu.

### 5.2.2 SO<sub>2</sub> Emission Control

CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 3, based on the significant reduction in SO<sub>2</sub> emissions, reasonable control costs, and the advantages of both minimal additional power requirements and non-air quality environmental impacts. This upgrade approach will meet the BART presumptive SO<sub>2</sub> limit of 0.15 lb per MMBtu.

### 5.2.3 PM<sub>10</sub> Emission Control

CH2M HILL recommends finalizing the permitting of the FGC system to enhance the performance of the existing ESP as BART for Jim Bridger 3, based on the significant reduction in PM<sub>10</sub> emissions, reasonable control costs, and the advantages of minimal additional power requirements and no non-air quality environmental impacts.

### 5.3 Just-Noticeable Differences in Atmospheric Haze

Conclusions reached in the reference document "Just-Noticeable Differences in Atmospheric Haze" by Dr. Ronald Henry (2002), state that only dV differences of approximately 1.5 to 2.0 dV, or more are perceptible by the human eye. Deciview changes of less than 1.5 cannot be distinguished by the average person. Therefore, the modeling analysis results indicate that only minimal, if any, observable visibility improvements at the Class I areas studied would be expected under any of the scenarios. Thus the results indicate that even though many millions of dollars will be spent, only minimal if any visibility improvements may result.

Finally, it should be noted that none of the data were corrected for natural obscuration. Water in various forms (fog, clouds, snow, or rain) or other naturally caused aerosols may obscure the atmosphere and reduce visibility. During the period of 2001 through 2003, there were several mega-wildfires that lasted for many days, with a significant impact on background visibility in these Class I areas. If natural obscuration lessens the achievable reduction on visibility impacts modeled for BART controls at the Jim Bridger 3 facility, the overall effect would be to increase the costs per dV reduction that are presented in this report.

## 6.0 References

---

- 40 CFR Part 51. *Regional Haze Regulations and Guidelines for Best Available Retrofit Technology Determinations; Final Rule.* July 6, 2005.
- Energy Information Administration, 2006. *Official Energy Statistics from the U.S. Government: Coal.* <http://www.eia.doe.gov/fuelcoal.html>. Accessed October 2006.
- EPA, 2003. *Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule.* Environmental Protection Agency. EPA-454/8-03-005. September 2003.
- EPA, 1990. *New Source Review Workshop Manual—Prevention of Significant Deterioration and Nonattainment Area Permitting.* Draft. October 1990.
- Henry, Ronald, 2002. "Just-Noticeable Differences in Atmospheric Haze," *Journal of the Air & Waste Management Association.* Volume 52, p. 1238.
- National Oceanic and Atmospheric Administration, 2006. U.S. Daily Weather Maps Project. [http://docs.lib.noaa.gov/rescue/dwm/data\\_rescue\\_daily\\_weather\\_maps.html](http://docs.lib.noaa.gov/rescue/dwm/data_rescue_daily_weather_maps.html). Accessed October 2006.
- North Dakota Department of Health, 2005. *Protocol for BART-Related Visibility Improvement Modeling Analysis in North Dakota.* North Dakota Department of Health. October 26, 2005.
- Sargent & Lundy, 2002. *Multi-Pollutant Control Report.* October 2002.
- Sargent & Lundy, 2006. *Multi-Pollutant Control Report.* Revised. October 2006.
- WDEQ-AQD, 2006. *BART Air-Modeling Protocol—Individual Source Visibility Assessments for BART Control Analyses.* Wyoming Department of Environmental Quality – Air Quality Division. September 2006.

**APPENDIX A**

**Economic Analysis**

---

## PacifiCorp BART Analysis Scenarios

Select Unit		5	Jim Bridger Unit 3
Index No.	Name of Unit		
1	Dave Johnston Unit 3		
2	Dave Johnston Unit 4		
3	Jim Bridger Unit 1		
4	Jim Bridger Unit 2		
5	Jim Bridger Unit 3		
6	Jim Bridger Unit 4		
7	Naughton Unit 1		
8	Naughton Unit 2		
9	Naughton Unit 3		
10	Wyodak Unit 1		

Dave Johnston		Naughton		Wyodak	
DI Unit 3	DI Unit 4	NTN Unit 1	NTN Unit 2	NTN Unit 3	W/DK Unit 1
Scenario Baseline - Current Operation with ESP	First Year Cost Baseline - Current Operation with Venturi Scrubber'	Scenario Baseline - Current Operation with OFA, Dry FGD, Existing ESP,	First Year Cost Baseline - Current Operation with OFA, Dry FGD, Existing ESP,	First Year Cost Baseline - Current Operation with OFA, Dry FGD, Existing ESP,	First Year Cost Baseline - Current Operation with Dry FGD, Fabric Filter
Scenario 1 - LNB with OFA, Dry FGD, Existing ESP,	N/A N/A	Scenario 1 - LNB with OFA, Dry FGD, Fabric Filter	N/A N/A	Scenario 1 - LNB with OFA, Dry FGD, Existing ESP,	Scenario 1 - LNB with OFA, Wet FGD, ESP
Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	N/A N/A	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	N/A N/A	Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter
Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	N/A N/A	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	N/A N/A	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	Scenario 3 - LNB with OFA and SCR, Wet FGD, Existing ESP
Scenario 4 - LNB with OFA and SCR, Wet FGD, Existing ESP, New Stack	N/A N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, Existing ESP, New Stack	N/A N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, Existing ESP, New Stack	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter
Scenario Baseline - Current Operation with Wet FGD and ESP	First Year Cost Baseline - Current Operation with Wet FGD and ESP	Scenario Baseline - Current Operation with Wet FGD and ESP	Scenario Baseline - Current Operation with Wet FGD and ESP	Scenario Baseline - Current Operation with Wet FGD and ESP	Scenario Baseline - Current Operation with Wet FGD and ESP
Scenario 1 - LNB with OFA, Wet FGD, ESP	N/A N/A	Scenario 1 - LNB with OFA, Wet FGD, Existing ESP	N/A N/A	Scenario 1 - LNB with OFA, Wet FGD, Existing ESP	Scenario 1 - LNB with OFA, Dry FGD, Fabric Filter
Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	N/A N/A	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	N/A N/A	Scenario 2 - LNB with OFA, Wet FGD, Existing ESP	Scenario 2 - LNB with OFA and SCR, Dry FGD, Fabric Filter
Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	N/A N/A	Scenario 3 - LNB with OFA and SCR, Wet FGD, Existing ESP	N/A N/A	Scenario 3 - LNB with OFA and SCR, Wet FGD, Existing ESP	Scenario 3 - LNB with OFA and SCR, Wet FGD, Existing ESP
Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter

## ECONOMIC ANALYSIS SUMMARY

Jim Bridger Unit 3		Tangential-Fired PC						
Parameter	Current Operation	NOx Control			SO2 Control			PM Control
		LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	Upgraded Wet FGD	Flue Gas Conditioning	
Case	1. LNCFs-1 & Windbox Mods. Wet FGD ESP	2.	3.	4.	5.	8.	9.	10.
NOx Emission Control System	LNB w/OFA Wet FGD ESP	LNB w/OFA Wet FGD ESP	LNB w/OFA & SNCR Wet FGD ESP	LNB w/OFA & SCR Wet FGD ESP	LNCFs-1 & Windbox Mods. Wet FGD ESP	LNCFs-1 & Windbox Mods. Wet FGD ESP	LNCFs-1 & Windbox Mods. Wet FGD Fabric Filter	LNCFs-1 & Windbox Mods. Wet FGD Fabric Filter
SO2 Emission Control System								
PM Emission Control System								
<b>TOTAL INSTALLED CAPITAL COST (\$)</b>	<b>0.</b>	<b>8,700,001</b>	<b>20,528,122</b>	<b>21,973,632</b>	<b>129,575,495</b>	<b>12,989,900</b>	<b>0</b>	<b>48,386,333</b>
<b>FIRST YEAR O&amp;M COST (\$)</b>	<b>0.</b>	<b>0.</b>	<b>0.</b>	<b>0.</b>	<b>0.</b>	<b>0.</b>	<b>0.</b>	<b>0.</b>
Operating Labor (\$)	0.	28,000	42,000	122,000	190,000	25,550	0.	51,059
Maintenance Material (\$)	0.	42,000	63,000	183,000	255,000	17,033	10,000	76,649
Maintenance Labor (\$)	0.	0.	0.	0.	0.	0.	0.	0.
Administrative Labor (\$)	0.	0.	0.	0.	0.	0.	0.	0.
<b>TOTAL FIXED O&amp;M COST</b>	<b>0.</b>	<b>70,000</b>	<b>105,000</b>	<b>305,000</b>	<b>475,000</b>	<b>42,583</b>	<b>10,000</b>	<b>127,749</b>
Makeup Water Cost	0.	0.	0.	0.	0.	29,927	0.	0.
Reagent Cost	0.	0.	0.	1,005,911	912,848	533,206	145,854	0.
SCR Catalyst / FFF Bag Cost	0.	0.	0.	0.	0.	0.	0.	284,008
Waste Disposal Cost	0.	0.	0.	0.	0.	442,958	0.	0.
Electric Power Cost	0.	0.	2,528,012	2,04,984	1,269,718	204,984	19,710	1,313,474
<b>TOTAL VARIABLE O&amp;M COST</b>	<b>0.</b>	<b>0.</b>	<b>2,528,012</b>	<b>1,210,795</b>	<b>2,782,566</b>	<b>1,211,076</b>	<b>165,854</b>	<b>1,607,482</b>
<b>TOTAL FIRST YEAR O&amp;M COST</b>	<b>0.</b>	<b>70,000</b>	<b>2,533,012</b>	<b>1,515,795</b>	<b>3,257,566</b>	<b>1,253,658</b>	<b>175,554</b>	<b>1,735,231</b>
<b>FIRST YEAR DEBT SERVICE (\$)</b>	<b>0.</b>	<b>827,612</b>	<b>1,952,796</b>	<b>2,090,304</b>	<b>12,326,235</b>	<b>1,236,652</b>	<b>0.</b>	<b>4,602,687</b>
<b>TOTAL FIRST YEAR COST (\$)</b>	<b>0.</b>	<b>897,612</b>	<b>4,585,808</b>	<b>3,606,099</b>	<b>15,583,801</b>	<b>2,480,310</b>	<b>176,564</b>	<b>6,338,118</b>
Power Consumption (MW)	0.0	0.0	6.4	5.5	3.2	0.5	0.1	3.3
Annual Power Usage (Million kW-Hr/Yr)	0.0	0.0	50.6	4.1	25.4	4.1	0.4	26.3
<b>CONTROL COST (\$/ton Removed)</b>								
NOx Removal Rate (%)	0.0%	46.7%	51.1%	55.6%	84.4%	0.0%	0.0%	0.0%
NOx Removed (Tons/Yr)	0	4,867	5,440	5,913	8,987	0	0	0
First Year Average Control Cost (\$/Ton NOx Rem.)	0	181	843	610	1,734	0	0	0
Incremental Control Cost (\$/Ton NOx Removed)	0	181	7,797	2,663	3,986	0	0	0
SO2 Removal Rate (%)	77.8%	0.0%	0.0%	0.0%	0.0%	62.5%	0.0%	0.0%
SO2 Removed (Tons/Yr)	0	0	0	0	0	3,950	0	0
First Year Average Control Cost (\$/Ton SO2 Rem.)	0	0	0	0	0	631	0	0
Incremental Control Cost (\$/Ton SO2 Removed)	0	0	0	0	0	81	0	0
PM Removal Rate (%)	99.33%	0.00%	0.00%	0.00%	0.00%	0.00%	47.37%	73.68%
PM Removed (Tons/Yr)	0	0	0	0	0	639	983	983
First Year Average Control Cost (\$/Ton PM Rem.)	0	0	0	0	0	275	6,381	6,381
Incremental Control Cost (\$/Ton PM Removed)	0	0	0	0	0	275	17,371	17,371
<b>PRESENT WORTH COST (\$)</b>	<b>0.</b>	<b>9,556,250</b>	<b>52,687,883</b>	<b>40,493,391</b>	<b>169,375,951</b>	<b>28,376,912</b>	<b>2,145,016</b>	<b>69,587,130</b>

## INPUT CALCULATIONS

Jim Bridger Unit 3 Boiler Design:

Tangential Fired PC

Parameter	Current Operation				NOx Control				SO2 Control				PM Control		Comments
	LNB w/OFA	2	LNB w/OFA & ROFA	3	LNB w/OFA & SNCR	4	LNB w/OFA & SCR	5	Upgraded Wet FGD	8	Flue Gas Conditioning	9	Fabric Filter	10	
Case	1 LNGFS-1 & Wet FGD ESP	1 LNGFS-1 & Wet FGD Fabric Filter	1 LNGFS-1 & Wet FGD Fabric Filter												
Nox Emission Control System															
SOx Emission Control System															
PM Emission Control System															
Unit Design and Coal Characteristics															
Type of Unit	PC	PC													
Net Power Output (kW)	650,000	650,000	650,000	650,000	650,000	650,000	650,000	650,000	650,000	650,000	650,000	650,000	650,000	650,000	
Net Plant Heat Rate (Btu/kWh)	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	
Boiler Fuel	Bridger Mine Underground	Bridger Mine Underground													
Coal Heating Value (Btu/lb)	9,650	9,650	9,650	9,650	9,650	9,650	9,650	9,650	9,650	9,650	9,650	9,650	9,650	9,650	
Coal Sulfur Content (wt.%)	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	0.58%	
Coal Ash Content (wt.%)	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	
Boiler Heat Input, each (MMBtu/h)	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	
Coal Flow Rate (lb/hr)	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	
(Ton/Yr) (MMBtu/Yr)	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	
Emissions															
Uncontrolled SO2 (lb/hr)	7,210	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602
(lb/MMBtu)	1.20	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27
(lb/Mole/hr)	112.64	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	
(Ton/Yr)	28,421	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	
SO2 Removal Rate (%)	77.8%	0.07%	0.07%	0.07%	0.07%	0.07%	0.07%	0.07%	0.07%	0.07%	0.07%	0.07%	0.07%	0.07%	
(lb/hr)	5,608	0	0	0	0	0	0	0	0	0	0	0	0	0	
22,106	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
SO2 Emission Rate (lb/hr)	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	1,602	
(Ton/Yr)	1,602	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	
(lb/MMBtu)	5,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	6,315	
(GJ/Yr)	2,700	2,700	2,700	2,700	2,700	2,700	2,700	2,700	2,700	2,700	2,700	2,700	2,700	2,700	
Uncontrolled NOx (lb/hr)	0.45	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	
(lb/Mole/hr)	89.96	89.96	89.96	89.96	89.96	89.96	89.96	89.96	89.96	89.96	89.96	89.96	89.96	89.96	
(Ton/Yr)	10,643	10,643	10,643	10,643	10,643	10,643	10,643	10,643	10,643	10,643	10,643	10,643	10,643	10,643	
NOx Removal Rate (%)	0.0%	46.7%	51.1%	55.6%	59.4%	64.2%	68.0%	71.8%	75.6%	80.4%	84.2%	88.0%	91.8%	95.6%	
(lb/hr)	0	1,250	1,300	1,350	1,400	1,450	1,480	1,510	1,540	1,570	1,600	1,630	1,660	1,690	
(Ton/Yr)	0	4,987	5,440	5,893	6,346	6,800	7,253	7,706	8,159	8,612	9,065	9,518	9,971	10,424	
NOx Emission Rate (lb/hr)	2,700	1,440	1,320	1,200	1,080	960	840	720	600	480	360	240	120	0	
(Ton/Yr)	10,643	5,676	5,203	4,730	4,257	3,784	3,311	2,838	2,365	1,892	1,419	946	473	0	
Uncontrolled Fly Ash (lb/hr)	51,177	342	342	342	342	342	342	342	342	342	342	342	342	342	
(lb/MMBtu)	6,350	0.057	0.057	0.057	0.057	0.057	0.057	0.057	0.057	0.057	0.057	0.057	0.057	0.057	
(Ton/Yr)	201,759	11,4	11,4	11,4	11,4	11,4	11,4	11,4	11,4	11,4	11,4	11,4	11,4	11,4	
Fly Ash Removal Rate (%)	99.33%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
(lb/hr)	50,835	0	0	0	0	0	0	0	0	0	0	0	0	0	
200,394	342	342	342	342	342	342	342	342	342	342	342	342	342	342	
Fly Ash Emission Rate (lb/hr)	0.057	0.057	0.057	0.057	0.057	0.057	0.057	0.057	0.057	0.057	0.057	0.057	0.057	0.057	
(Ton/Yr)	1,348	1,348	1,348	1,348	1,348	1,348	1,348	1,348	1,348	1,348	1,348	1,348	1,348	1,348	

Parameter	Current Operation	NOx Control				PM Control		Comments
		LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	Upgraded Wet FGD	Fine Gas Conditioning	
Case	1	2	3	4	5	8	9	10
General Plant Data								
Annual Operation (Hours/Year)	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884
Annual On-Site Power Plant Capacity Factor	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50
Economic Factors								
Interest Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%
Discount Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%
Plant Economic Life (Years)	20	20	20	20	20	20	20	20
Installed Capital Costs								
NOx Emission Control System (\$2006)	0	8,700,001	20,628,122	21,973,632	129,575,495	0	0	0
SO2 Emission Control System (\$2006)	0	0	0	0	0	12,999,900	0	48,386,333
PM Emission Control System (\$2006)	0	0	0	0	0	0	0	48,386,333
Total Emission Control Systems (\$2006)	0	8,700,001	20,628,122	21,973,632	129,575,495	12,999,900	0	
NOx Emission Control System (\$kW)	0	16	39	41	244	0	0	0
SO2 Emission Control System (\$kW)	0	0	0	0	0	.25	0	0
Total Emission Control Systems (\$kW)	0	16	39	41	244	.25	0	0
Total Fixed Operating & Maintenance Costs								
Operating Labor (\$)	0	0	0	0	0	0	0	0
Maintenance Material (\$)	0	25,000	42,000	122,000	190,000	26,550	0	51,099
Maintenance Labor (\$)	0	42,000	63,000	183,000	285,000	17,033	16,000	76,649
Administrative Labor (\$)	0	0	0	0	0	0	0	0
Total Fixed O&M Cost (\$)	0	70,000	105,000	305,000	475,000	42,583	30,000	127,719
Annual Fixed O&M Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%
Water Cost								
Makeup Water Usage (Gpm)	0	0	0	0	0	52	0	0
Unit Price (\$/1000 Gallons)	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22
First Year Water Cost (\$)	0	0	0	0	0	0	0	0
Annual Water Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%
Resistant Costs								
Unit Cost (\$/Ton) (\$LB)	0.00	0.00	None	Urea	Anhydrous NH3	Soda Ash	Elemental Sulfur	None
Molar Stoichiometry	0.000	0.000	0.000	0.185	0.200	0.040	0.185	0.000
Reagent Purity (M %)	100%	100%	100%	0.46	1.00	1.02	0.00	0.00
Reagent Usage (L/bht)	0	0	0	100%	100%	100%	100%	90%
First Year Reagent Cost (\$)	0	0	0	680	573	1,681	145,154	0
Annual Reagent Cost Escalation Rate (%)	2.00%	2.00%	2.00%	1,005,311	912,648	635,206	2.00%	2.00%
SCR Catalyst/FF Bag Replacement Cost								
Annual SCR Catalyst (m3) / No. FF Bags	0	0	0	0	0	0	0	
SCR Catalyst (\$/m3) / Bag Cost (\$/ea)	3,000	3,000	3,000	3,000	3,000	3,000	0	
First Year SCR Catalyst / Bag Replaces. Cost (\$)	0	0	0	0	0	0	0	
Annual SCR Catalyst / Bag Cost Esc. Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
FFD Waste Disposal Cost								
FFD Waste Disposal Rate, Dry (L/bht)	0	0	0	0	0	0	0	
First Year FFD Waste Disposal Unit Costs (\$/Day/Ton)	24.33	24.33	24.33	24.33	24.33	24.33	24.33	
Annual Waste Disposal Costs Esc. Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Auxiliary Power Cost								
Auxiliary Power Requirement (% of Plant Output)	0.00%	0.00%	1.21%	0.10%	0.67%	0.10%	0.01%	0.63%
Unit Cost (\$/2006/MWh)	0.00	50.00	6.41	0.32	3.22	0.52	0.06	3.33
First Year Auxiliary Power Cost (\$)	0	0	50.00	50.00	50.00	50.00	50.00	50.00
Annual Power Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%

## Input Tables

Table 1 - Cases

Index No.	Name of Unit / Case →	Existing	2	3	NOx Control	4	5	6	SO2 Control	7	8	PM Control	9	10
1	Dave Johnston Unit 3	Current Operation	LNB w/oFA	ROFA	LNB w/oFA & SNCR	LNB w/oFA & SCR	Dry FGD w/EESP	Dry FGD w/Fabric Filter	Wet FGD w/EESP	Wet FGD w/Fabric Filter	N/A	Fabric Filter	N/A	Fabric Filter
2	Dave Johnston Unit 4	Current Operation	LNB w/oFA	ROFA	LNB w/oFA & SNCR	LNB w/oFA & SCR	N/A	N/A	Upgraded Wet FGD	Upgraded Wet FGD	N/A	Fabric Filter	N/A	Fabric Filter
3	Jim Bridger Unit 1	Current Operation	LNB w/oFA	ROFA	LNB w/oFA & SNCR	LNB w/oFA & SCR	N/A	N/A	Upgraded Wet FGD	Upgraded Wet FGD	N/A	Fabric Filter	N/A	Fabric Filter
4	Jim Bridger Unit 2	Current Operation	East LNB w/oFA	ROFA	LNB w/oFA & SNCR	LNB w/oFA & SCR	N/A	N/A	Upgraded Wet FGD	Upgraded Wet FGD	N/A	Fabric Filter	N/A	Fabric Filter
5	Jim Bridger Unit 3	Current Operation	LNB w/oFA	ROFA	LNB w/oFA & SNCR	LNB w/oFA & SCR	N/A	N/A	Upgraded Wet FGD	Upgraded Wet FGD	N/A	Fabric Filter	N/A	Fabric Filter
6	Jim Bridger Unit 4	Current Operation	LNB w/oFA	ROFA	LNB w/oFA & SNCR	LNB w/oFA & SCR	N/A	N/A	Upgraded Wet FGD	Upgraded Wet FGD	N/A	Fabric Filter	N/A	Fabric Filter
7	Naughton Unit 1	Current Operation	LNB w/oFA	ROFA	LNB w/oFA & SNCR	LNB w/oFA & SCR	Dry FGD w/EESP	Dry FGD w/Fabric Filter	Wet FGD w/EESP	Wet FGD w/Fabric Filter	N/A	Fabric Filter	N/A	Fabric Filter
8	Naughton Unit 2	Current Operation	LNB w/oFA	ROFA	LNB w/oFA & SNCR	LNB w/oFA & SCR	Dry FGD w/EESP	Dry FGD w/Fabric Filter	Wet FGD w/EESP	Wet FGD w/Fabric Filter	N/A	Fabric Filter	N/A	Fabric Filter
9	Naughton Unit 3	Current Operation	East LNB w/oFA	ROFA	LNB w/oFA & SNCR	LNB w/oFA & SCR	N/A	N/A	Upgraded Dry FGD	Upgraded Dry FGD	N/A	Fabric Filter	N/A	Fabric Filter
10	Wyodak Unit 1	Current Operation	LNB w/oFA	ROFA	LNB w/oFA & SNCR	LNB w/oFA & SCR	N/A	N/A	Upgraded Dry FGD	Upgraded Dry FGD	N/A	Fabric Filter	N/A	Fabric Filter

Table 2 - Unit Design and Coal Characteristics

Index No.	Name of Unit	Current Emission Control Systems			Boiler Design	Net Power Output (kW)	Net Plant Heat Rate (Btu/kW-Hr)	Coal Quality		
		NOx	SO2	PM				Heating Value, HHV (Btu/lb)	Sulfur Content (Wt.%)	Ash Content (Wt.%)
1	Dave Johnston Unit 3	None	None	ESP	Tangential-Fired PC	250,000	11,200	Dry Fork PRB Coal	7784	0.47%
2	Dave Johnston Unit 4	Wet Box Mod., LNCFPS-1 & Whirlbox Mod.	Lime Added to Venturi Scrubber	Venturi Scrubber	Tangential-Fired PC	350,000	11,350	Dry Fork PRB Coal	7784	0.47%
3	Jim Bridger Unit 1	None	None	ESP	Tangential-Fired PC	550,000	11,320	Bridger Mine Underground	9,660	0.58%
4	Jim Bridger Unit 2	LNB-TFS-2000 LNCFPS-1 & Whirlbox Mod.	Wet FGD	ESP	Tangential-Fired PC	550,000	11,320	Bridger Mine Underground	9,660	0.58%
5	Jim Bridger Unit 3	None	None	Wet FGD	ESP	550,000	11,320	Bridger Mine Underground	9,660	0.58%
6	Jim Bridger Unit 4	LNCFPS-1 & Whirlbox Mod.	Wet FGD	ESP	Tangential-Fired PC	550,000	11,320	Bridger Mine Underground	9,660	0.58%
7	Naughton Unit 1	None	None	ESP	Tangential-Fired PC	173,000	10,584	Kemmerer Mine	9,970	0.60%
8	Naughton Unit 2	None	None	ESP	Tangential-Fired PC	226,000	10,574	Kemmerer Mine	9,970	0.60%
9	Naughton Unit 3	LNCFPS-1 LNB	Wet FGD	ESP	Tangential-Fired PC	356,000	10,336	Kemmerer Mine	9,970	0.60%
10	Wyodak Unit 1	LNB	Dry FGD	ESP	Opposed Wall-Fired PC	335,000	12,087	Cheyenne Point Mine	7,977	0.65%

**Table 3 - Emissions**

Index No.	Name of Unit	Current Emission Rates (LB/MMBtu)		NOx Control Emission Rates (LB/MMBtu)				SO2 Control Emission Rates (LB/MMBtu)				PM Emission Rates (LB/MMBtu)			
		Controlled SO2	Controlled NOx	Case 1	Case 2	Case 3	Case 4	Case 5	Case 6	Case 7	Case 8	Case 9	Case 10		
1	Dave Johnson Unit 3	1.20	0.70	0.200	0.27	0.21	0.20	0.07	0.21	0.16	0.10	N/A	0.015		
2	Dave Johnson Unit 4	0.33	0.48	0.081	0.15	0.19	0.12	N/A	0.16	0.10	N/A	0.015			
3	Jim Bridger Unit 1	0.27	0.45	0.046	0.24	0.22	0.20	0.07	N/A	0.10	0.030	0.015			
4	Jim Bridger Unit 2	0.27	0.24	0.074	0.24	0.22	0.20	0.07	N/A	0.10	0.030	0.015			
5	Jim Bridger Unit 3	0.27	0.45	0.057	0.24	0.22	0.20	0.07	N/A	0.10	0.030	0.015			
6	Jim Bridger Unit 4	0.17	0.46	0.030	0.24	0.22	0.20	0.07	N/A	0.10	0.030	0.015			
7	Naughton Unit 1	1.20	0.58	0.066	0.24	0.28	0.18	0.07	0.18	0.16	0.10	0.040	0.015		
8	Naughton Unit 2	1.20	0.54	0.064	0.24	0.28	0.18	0.07	0.18	0.16	0.10	0.040	0.015		
9	Naughton Unit 3	0.50	0.45	0.084	0.35	0.30	0.25	0.07	N/A	0.10	0.040	0.015			
10	Wyodak Unit 1	0.50	0.50	0.030	0.23	0.22	0.18	0.07	0.25	0.25	N/A	0.10	0.025		

**Table 4 - Case 1 O&M Costs (Current Operation)**

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar	Aux. Power Usage (MW)
1	Dave Johnson Unit 3	\$	\$	\$	\$	-	-	-	None
2	Dave Johnson Unit 4	\$	\$	\$	\$	-	-	-	None
3	Jim Bridger Unit 1	\$	\$	\$	\$	-	-	-	None
4	Jim Bridger Unit 2	\$	\$	\$	\$	-	-	-	None
5	Jim Bridger Unit 3	\$	\$	\$	\$	-	-	-	None
6	Jim Bridger Unit 4	\$	\$	\$	\$	-	-	-	None
7	Naughton Unit 1	\$	\$	\$	\$	-	-	-	None
8	Naughton Unit 2	\$	\$	\$	\$	-	-	-	None
9	Naughton Unit 3	\$	\$	\$	\$	-	-	-	None
10	Wyodak Unit 1	\$	\$	\$	\$	-	-	-	None

**Table 5 - Case 2 O&M Costs (LNB w/OFA)**

Index No.	Name of Unit	Annual Fixed O&M Costs				Variable Operating Requirements			
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar	Aux. Power Usage (MW)
1	Dave Johnson Unit 3	\$	\$	\$	\$	-	-	-	None
2	Dave Johnson Unit 4	\$	\$	\$	\$	-	-	-	None
3	Jim Bridger Unit 1	\$	\$	\$	\$	-	-	-	None
4	Jim Bridger Unit 2	\$	\$	\$	\$	-	-	-	None
5	Jim Bridger Unit 3	\$	\$	\$	\$	-	-	-	None
6	Jim Bridger Unit 4	\$	\$	\$	\$	-	-	-	None
7	Naughton Unit 1	\$	\$	\$	\$	-	-	-	None
8	Naughton Unit 2	\$	\$	\$	\$	-	-	-	None
9	Naughton Unit 3	\$	\$	\$	\$	-	-	-	None
10	Wyodak Unit 1	\$	\$	\$	\$	-	-	-	None

Table 6 - Case 3 O&amp;M Costs (Mobotac ROFA)

Annual Fixed O&M Costs				Variable Operating Requirements			
Index No.	Name of Unit	Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Reagent	Reagent Molar Stoch.
1	Dave Johnson Unit 3	\$ 60,000	\$ 90,000	\$ 81,000	\$ 63,000	None	2.76
2	Dave Johnson Unit 4	\$ 54,000	\$ 42,000	\$ 63,000	\$ 63,000	None	4.33
3	Jim Bridger Unit 1	\$ 54,000	\$ 42,000	\$ 63,000	\$ 63,000	None	6.45
4	Jim Bridger Unit 2	\$ 42,000	\$ 42,000	\$ 63,000	\$ 63,000	None	6.41
5	Jim Bridger Unit 3	\$ 42,000	\$ 42,000	\$ 63,000	\$ 63,000	None	6.41
6	Jim Bridger Unit 4	\$ 42,000	\$ 42,000	\$ 63,000	\$ 63,000	None	6.41
7	Naughton Unit 1	\$ 48,000	\$ 72,000	\$ 72,000	\$ 72,000	None	1.42
8	Naughton Unit 2	\$ 48,000	\$ 72,000	\$ 72,000	\$ 72,000	None	2.61
9	Naughton Unit 3	\$ 48,000	\$ 72,000	\$ 72,000	\$ 72,000	None	4.47
10	Wyodak Unit 1...	\$ 36,000	\$ 54,000	\$ 54,000	\$ 54,000	None	5.22

Table 7 - Case 4 O&amp;M Costs (LNB w/OF&amp;A &amp; SNCR)

Annual Fixed O&M Costs				Variable Operating Requirements			
Index No.	Name of Unit	Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Reagent	Reagent Molar Stoch.
1	Dave Johnson Unit 3	\$ 98,000	\$ 105,000	\$ 147,000	\$ 157,500	Urea	0.41
2	Dave Johnson Unit 4	\$ 123,000	\$ 123,000	\$ 184,500	\$ 184,500	Urea	0.45
3	Jim Bridger Unit 1	\$ 65,000	\$ 142,500	\$ 183,000	\$ 183,000	Urea	0.45
4	Jim Bridger Unit 2	\$ 122,000	\$ 123,000	\$ 184,500	\$ 184,500	Urea	0.45
5	Jim Bridger Unit 3	\$ 123,000	\$ 123,000	\$ 184,500	\$ 184,500	Urea	0.45
6	Jim Bridger Unit 4	\$ 123,000	\$ 123,000	\$ 184,500	\$ 184,500	Urea	0.45
7	Naughton Unit 1	\$ 83,000	\$ 124,600	\$ 139,500	\$ 139,500	Urea	0.45
8	Naughton Unit 2	\$ 93,000	\$ 139,500	\$ 112,500	\$ 112,500	Urea	0.51
9	Naughton Unit 3	\$ 75,000	\$ 93,000	\$ 139,500	\$ 139,500	Urea	0.45
10	Wyodak Unit 1	\$ 139,500	\$ 139,500	\$ 139,500	\$ 139,500	Urea	0.33

Table 8 - Case 5 O&amp;M Costs (LNB w/OF&amp;A &amp; SCR))

Annual Fixed O&M Costs				Variable Operating Requirements			
Index No.	Name of Unit	Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Reagent	Reagent Molar Stoch.
1	Dave Johnson Unit 3	\$ 155,000	\$ 232,500	\$ 249,500	\$ 249,500	Anhydrous NH3	1.00
2	Dave Johnson Unit 4	\$ 166,000	\$ 190,000	\$ 245,000	\$ 245,000	Anhydrous NH3	1.00
3	Jim Bridger Unit 1	\$ 162,000	\$ 190,000	\$ 245,000	\$ 245,000	Anhydrous NH3	1.00
4	Jim Bridger Unit 2	\$ 190,000	\$ 190,000	\$ 245,000	\$ 245,000	Anhydrous NH3	1.00
5	Jim Bridger Unit 3	\$ 190,000	\$ 190,000	\$ 245,000	\$ 245,000	Anhydrous NH3	1.00
6	Jim Bridger Unit 4	\$ 190,000	\$ 190,000	\$ 245,000	\$ 245,000	Anhydrous NH3	1.00
7	Naughton Unit 1	\$ 132,000	\$ 160,000	\$ 198,000	\$ 198,000	Anhydrous NH3	1.00
8	Naughton Unit 2	\$ 160,000	\$ 160,000	\$ 240,000	\$ 240,000	Anhydrous NH3	1.00
9	Naughton Unit 3	\$ 156,000	\$ 181,000	\$ 241,500	\$ 241,500	Anhydrous NH3	1.00
10	Wyodak Unit 1	\$ 181,000	\$ 181,000	\$ 271,500	\$ 271,500	Anhydrous NH3	1.00

Table 9 - Case 6 O&amp;M Costs (Dry FGD)

		Annual Fixed O&M Costs						Variable Operating Requirements					
Index No.	Name of Unit	Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoch.	Annual FF Bag Replace.	Aux. Power Usage (MW)			
1	Dave Johnson Unit 3	\$ 506,128	\$ 714,175	\$ 476,928	\$	173	Lime	1.75	-	2.49	-	-	-
2	Dave Johnson Unit 4	\$	\$	\$	\$	-	Lime	-	-	-	-	-	-
3	Jim Bridger Unit 1	\$	\$	\$	\$	-	Lime	-	-	-	-	-	-
4	Jim Bridger Unit 2	\$	\$	\$	\$	-	Lime	-	-	-	-	-	-
5	Jim Bridger Unit 3	\$	\$	\$	\$	-	Lime	-	-	-	-	-	-
6	Jim Bridger Unit 4	\$	\$	\$	\$	-	Lime	-	-	-	-	-	-
7	Naughton Unit 1	\$ 506,128	\$ 880,174	\$ 597,643	\$ 391,762	120	Lime	1.40	-	1.64	-	-	-
8	Naughton Unit 2	\$ 506,128	\$	\$	\$	165	Lime	1.40	-	2.26	-	-	-
9	Naughton Unit 3	\$	\$	\$	\$	-	Lime	-	-	-	-	-	-
10	Wodak Unit 1	\$	\$	\$ 21,900	\$ 14,600	25	Lime	1.10	-	0.11	-	-	-

Table 10 - Case 7 O&amp;M Costs (Dry FGD w/Fabric Filter)

		Annual Fixed O&M Costs						Variable Operating Requirements					
Index No.	Name of Unit	Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoch.	Annual FF Bag Replace.	Aux. Power Usage (MW)			
1	Dave Johnson Unit 3	\$ 506,128	\$ 714,175	\$ 476,928	\$ 734,858	173	Lime	1.15	-	3.38	-	-	-
2	Dave Johnson Unit 4	\$	\$ 1,102,280	\$	\$	248	Lime	1.10	-	4.54	-	-	-
3	Jim Bridger Unit 1	\$	\$	\$	\$	-	Lime	-	-	-	-	-	-
4	Jim Bridger Unit 2	\$	\$	\$	\$	-	Lime	-	-	-	-	-	-
5	Jim Bridger Unit 3	\$	\$	\$	\$	-	Lime	-	-	-	-	-	-
6	Jim Bridger Unit 4	\$	\$	\$	\$	-	Lime	-	-	-	-	-	-
7	Naughton Unit 1	\$ 506,128	\$ 632,860	\$ 459,286	\$	120	Lime	1.15	-	2.66	-	-	-
8	Naughton Unit 2	\$ 506,128	\$ 905,150	\$ 640,668	\$	165	Lime	1.15	-	3.53	-	-	-
9	Naughton Unit 3	\$	\$	\$	\$	-	Lime	-	-	-	-	-	-
10	Wodak Unit 1	\$	\$	\$	\$	-	Lime	-	-	-	-	-	-

Table 11 - Case 8 O&amp;M Costs (Wet FGD)

		Annual Fixed O&M Costs						Variable Operating Requirements					
Index No.	Name of Unit	Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoch.	Annual FF Bag Replace.	Aux. Power Usage (MW)			
1	Dave Johnson Unit 3	\$ 809,804	\$ 1,162,687	\$ 788,391	\$	230	Lime	1.02	-	3.45	-	-	-
2	Dave Johnson Unit 4	\$	\$ 1,430,784	\$ 963,856	\$	330	Lime	1.02	-	6.28	-	-	-
3	Jim Bridger Unit 1	\$	\$ 25,850	\$ 11,033	\$	-	Soda Ash	1.02	-	0.53	-	-	-
4	Jim Bridger Unit 2	\$	\$ 25,650	\$ 17,033	\$	-	Soda Ash	1.02	-	0.53	-	-	-
5	Jim Bridger Unit 3	\$	\$ 25,650	\$ 17,033	\$	-	Soda Ash	1.02	-	0.52	-	-	-
6	Jim Bridger Unit 4	\$	\$	\$	\$	-	Soda Ash	-	-	0.53	-	-	-
7	Naughton Unit 1	\$ 809,804	\$ 983,689	\$ 642,933	\$	27	Soda Ash	1.02	-	2.10	-	-	-
8	Naughton Unit 2	\$ 809,804	\$ 1,226,386	\$ 617,991	\$	160	Lime	1.05	-	3.30	-	-	-
9	Naughton Unit 3	\$	\$	\$	\$	220	Lime	1.05	-	0.33	-	-	-
10	Wodak Unit 1	\$ 303,677	\$ 328,456	\$ 218,998	\$	82	Soda Ash	1.02	-	1.75	-	-	-

Table 12 - Case 9 O&amp;M Costs (Flue Gas Conditioning)

Index No.	Name of Unit	Annual Fixed O&M Costs			Variable Operating Requirements		
		Oper. Labor	Maint. Materials	Admin. Labor	Makewp Water Use (Gpm)	Reagent Usage (Lb/Hr)	Annual FF/Bg Replace.
1	Dave Johnson Unit 3	\$ 5	\$ 5	\$ 5	\$ 10,000	\$ 0	None
2	Dave Johnson Unit 4	\$ 5	\$ 5	\$ 5	\$ 10,000	\$ 0	None
3	Jim Bridger Unit 1	\$ 5	\$ 5	\$ 5	\$ 10,000	\$ 0	Elemental Sulfur
4	Jim Bridger Unit 2	\$ 5	\$ 5	\$ 5	\$ 10,000	\$ 0	Elemental Sulfur
5	Jim Bridger Unit 3	\$ 5	\$ 5	\$ 5	\$ 10,000	\$ 0	Elemental Sulfur
6	Jim Bridger Unit 4	\$ 5	\$ 5	\$ 5	\$ 10,000	\$ 0	Elemental Sulfur
7	Naughton Unit 1	\$ 5	\$ 5	\$ 5	\$ 10,000	\$ 0	Elemental Sulfur
8	Naughton Unit 2	\$ 5	\$ 5	\$ 5	\$ 10,000	\$ 0	Elemental Sulfur
9	Naughton Unit 3	\$ 5	\$ 5	\$ 5	\$ 10,000	\$ 0	Elemental Sulfur
10	Wyodak Unit 1	\$ 5	\$ 5	\$ 5	\$ 10,000	\$ 0	Elemental Sulfur

Table 13 - Case 10 O&amp;M Costs (Fabric Filter)

Index No.	Name of Unit	Annual Fixed O&M Costs			Variable Operating Requirements		
		Oper. Labor	Maint. Materials	Admin. Labor	Makewp Water Use (Gpm)	Reagent Usage (Lb/Hr)	Annual FF/Bg Replace.
1	Dave Johnson Unit 3	\$ 5	\$ 5	\$ 5	\$ 67,524	\$ 0	None
2	Dave Johnson Unit 4	\$ 5	\$ 5	\$ 5	\$ 67,524	\$ 0	None
3	Jim Bridger Unit 1	\$ 5	\$ 5	\$ 5	\$ 62,153	\$ 0	None
4	Jim Bridger Unit 2	\$ 5	\$ 5	\$ 5	\$ 61,099	\$ 0	None
5	Jim Bridger Unit 3	\$ 5	\$ 5	\$ 5	\$ 61,099	\$ 0	None
6	Jim Bridger Unit 4	\$ 5	\$ 5	\$ 5	\$ 61,099	\$ 0	None
7	Naughton Unit 1	\$ 5	\$ 5	\$ 5	\$ 45,016	\$ 0	None
8	Naughton Unit 2	\$ 5	\$ 5	\$ 5	\$ 45,016	\$ 0	None
9	Naughton Unit 3	\$ 5	\$ 5	\$ 5	\$ 48,656	\$ 0	None
10	Wyodak Unit 1	\$ 5	\$ 5	\$ 5	\$ 48,656	\$ 0	None

Table 14 - Major Materials Design and Supply Costs

Index No.	Name of Unit   Cases →	NOx Control			SO2 Control			PM Control	
		2	3	4	5	6	7	8	9
1	Dave Johnson Unit 3	\$ 3,222,912	\$ 3,556,617	\$ 3,773,000	\$ 49,355,000	\$ 93,371,000	\$ 132,077,000	\$ 108,385,069	\$ 13,359,000
2	Dave Johnson Unit 4	\$ 2,673,302	\$ 4,343,192	\$ 7,171,006	\$ 66,200,000	\$ 66,200,000	\$ 137,287,000	\$ 171,174,384	\$ 30,453,530
3	Jim Bridger Unit 1	\$ 2,987,582	\$ 6,056,956	\$ 9,528,000	\$ 80,923,000	\$ 80,923,000	\$ 137,287,000	\$ 30,453,530	\$ 25,814,000
4	Jim Bridger Unit 2	\$ 2,987,582	\$ 6,056,955	\$ 9,528,000	\$ 80,923,000	\$ 80,923,000	\$ 137,287,000	\$ 30,453,530	\$ 25,814,000
5	Jim Bridger Unit 3	\$ 2,987,582	\$ 6,056,955	\$ 9,528,000	\$ 80,923,000	\$ 80,923,000	\$ 137,287,000	\$ 30,453,530	\$ 25,814,000
6	Jim Bridger Unit 4	\$ 2,987,582	\$ 6,056,955	\$ 9,528,000	\$ 80,923,000	\$ 80,923,000	\$ 137,287,000	\$ 30,453,530	\$ 25,814,000
7	Naughton Unit 1	\$ 2,602,123	\$ 2,675,792	\$ 7,257,000	\$ 37,292,000	\$ 26,819,000	\$ 42,301,000	\$ 44,000,000	\$ 80,000,000
8	Naughton Unit 2	\$ 2,670,674	\$ 3,123,533	\$ 8,764,000	\$ 47,934,000	\$ 39,282,000	\$ 57,621,000	\$ 66,000,000	\$ 80,000,000
9	Naughton Unit 3	\$ 3,167,335	\$ 4,354,377	\$ 11,203,578	\$ 67,373,000	\$ 72,475,000	\$ 96,100	\$ 2,965,000	\$ 20,105,000
10	Wyodak Unit 1	\$ 3,167,335	\$ 4,500,245	\$ 7,254,856	\$ 72,475,000	\$ 96,100	\$ 1,247,061	\$ 1,247,061	\$ 20,105,000

## CAPITAL COST

Jim Bridger Unit 3

Parameter		NOx Control			SO2 Control			PM Control		
Case	LNB w/OFAs	ROFA	LNB w/OFAs	LNB w/OFAs & SCR	N/A	LNB w/OFAs & SCR	N/A	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter
Major Emission Control System	Wet FGD	3	LNB w/OFAs	4	LNB w/OFAs & SCR	6	LNB w/OFAs & SCR	7	LNCFE-1 & Wetbox Mod.	10
Submajor Emission Control System	Wet FGD	3	LNB w/OFAs	4	LNB w/OFAs & SCR	6	LNB w/OFAs & SCR	7	LNCFE-1 & Wetbox Mod.	10
<b>TOTAL COST COMPONENT</b>	<b>FactorSource</b>	<b>Cost</b>	<b>FactorSource</b>	<b>Cost</b>	<b>FactorSource</b>	<b>Cost</b>	<b>FactorSource</b>	<b>Cost</b>	<b>FactorSource</b>	<b>Cost</b>
Major Materials Design and Supply	LNB w/OFAs	\$1,491,042	LNB w/OFAs	\$2,049,092	LNB w/OFAs	\$2,049,092	LNB w/OFAs	\$2,049,092	Vendor	\$0
Construction	Vendor	\$1,491,042	Vendor	\$2,049,092	Vendor	\$2,049,092	Vendor	\$2,049,092	Vendor	\$0
Engineering (allowance)	5.7%	85,274	6.5%	115,459	6.5%	115,459	6.5%	115,459	5.7%	59
Owner's Cost	5.7%	51,541,41	5.7%	71,541,51	5.7%	71,541,51	5.7%	71,541,51	5.7%	39
Surcharge	13.7%	1,121	13.2%	1,785	13.2%	1,785	13.2%	1,785	13.2%	89
LEEDC	10.4%	548,844	10.4%	849,945	10.4%	849,945	10.4%	849,945	10.4%	50
Total	12.2%	\$740,087	12.2%	\$884,352	12.2%	\$884,352	12.2%	\$884,352	12.2%	\$0
Contingency	12.5%	\$8,317,295	12.5%	\$10,711,056	12.5%	\$10,711,056	12.5%	\$10,711,056	12.5%	\$0
Total Capital Cost for LNB w/OFAs or ROFA	\$8,790,001	\$20,628,122	\$8,790,001	\$20,628,122	\$8,790,001	\$20,628,122	\$8,790,001	\$20,628,122	\$8,790,001	\$0
<b>SCR or SCR</b>	<b>FactorSource</b>	<b>Cost</b>	<b>FactorSource</b>	<b>Cost</b>	<b>FactorSource</b>	<b>Cost</b>	<b>FactorSource</b>	<b>Cost</b>	<b>FactorSource</b>	<b>Cost</b>
Major Materials Design and Supply	SEL Report	\$0	SEL Report	\$0	SEL Report	\$0	SEL Report	\$0	SEL Report	\$0
Contingency	20.0%	\$0	20.0%	\$0	20.0%	\$0	20.0%	\$0	20.0%	\$0
Labor Premium	5.5%	\$0	5.5%	\$0	5.5%	\$0	5.5%	\$0	5.5%	\$0
EPIC Premium	0.5%	\$0	0.5%	\$0	0.5%	\$0	0.5%	\$0	0.5%	\$0
Easier Reinforcement (allowance)	0.0%	\$0	0.0%	\$0	0.0%	\$0	0.0%	\$0	0.0%	\$0
Sales Tax	1.1%	\$0	1.1%	\$0	1.1%	\$0	1.1%	\$0	1.1%	\$0
Escalation	0.0%	\$0	0.0%	\$0	0.0%	\$0	0.0%	\$0	0.0%	\$0
Guarantees and A-FUDC	2.0%	\$0	2.0%	\$0	2.0%	\$0	2.0%	\$0	2.0%	\$0
Total	11.4%	\$0	11.4%	\$0	11.4%	\$0	11.4%	\$0	11.4%	\$0
Total Capital Cost for SCR or SCR	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
<b>Dry or Wet FGD, FGD or Fabric Filter</b>	<b>FactorSource</b>	<b>Cost</b>	<b>FactorSource</b>	<b>Cost</b>	<b>FactorSource</b>	<b>Cost</b>	<b>FactorSource</b>	<b>Cost</b>	<b>FactorSource</b>	<b>Cost</b>
Major Materials Design and Supply	SEL Report	\$0	SEL Report	\$0	SEL Report	\$0	SEL Report	\$0	SEL Report	\$0
Contingency	20.0%	\$0	20.0%	\$0	20.0%	\$0	20.0%	\$0	20.0%	\$0
Labor Premium	5.5%	\$0	5.5%	\$0	5.5%	\$0	5.5%	\$0	5.5%	\$0
EPIC Premium	0.5%	\$0	0.5%	\$0	0.5%	\$0	0.5%	\$0	0.5%	\$0
Easier Reinforcement (allowance)	0.0%	\$0	0.0%	\$0	0.0%	\$0	0.0%	\$0	0.0%	\$0
Sales Tax	1.1%	\$0	1.1%	\$0	1.1%	\$0	1.1%	\$0	1.1%	\$0
Escalation	0.0%	\$0	0.0%	\$0	0.0%	\$0	0.0%	\$0	0.0%	\$0
Guarantees and A-FUDC	2.0%	\$0	2.0%	\$0	2.0%	\$0	2.0%	\$0	2.0%	\$0
Total	11.4%	\$0	11.4%	\$0	11.4%	\$0	11.4%	\$0	11.4%	\$0
Total Capital Cost for Dry or Wet FGD	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0

ENR20000101SLCNP-AJCP-BD-BART Element Analysis 01/10/2015

141

LNB w/OFA										
Jim Bridger Unit 3										
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Back Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST
0	2013	70,000								627,612
1	2014	71,400								627,612
2	2015	72,828								627,612
3	2016	74,285								627,612
4	2017	75,770								627,612
5	2018	77,295								627,612
6	2019	78,831								627,612
7	2020	80,408								627,612
8	2021	82,016								627,612
9	2022	83,656								627,612
10	2023	85,330								627,612
11	2024	87,036								627,612
12	2025	88,777								627,612
13	2026	90,552								627,612
14	2027	92,384								627,612
15	2028	94,211								627,612
16	2029	96,095								627,612
17	2030	98,017								627,612
18	2031	99,977								627,612
19	2032	101,977								627,612
20	2033	103,977								627,612
Present Worth		855,250		-0.0%		-0.0%		-0.0%		9,355,350
(% of PW)		9.0%								96
										100.0%

ROFA										
Jim Bridger Unit 3										
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Back Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST
0	2013	105,000								1,952,798
1	2014	107,100								1,952,798
2	2015	109,242								1,952,798
3	2016	111,427								1,952,798
4	2017	113,655								1,952,798
5	2018	115,928								1,952,798
6	2019	118,247								1,952,798
7	2020	120,612								1,952,798
8	2021	123,024								1,952,798
9	2022	125,495								1,952,798
10	2023	127,994								1,952,798
11	2024	130,554								1,952,798
12	2025	133,165								1,952,798
13	2026	135,829								1,952,798
14	2027	138,545								1,952,798
15	2028	141,316								1,952,798
16	2029	144,142								1,952,798
17	2030	147,025								1,952,798
18	2031	149,966								1,952,798
19	2032	152,965								1,952,798
20	2033	156,975		0.0%		0.0%		0.0%		1,952,798
Present Worth		1,282,875		0.0%		0.0%		0.0%		20,528,122
(% of PW)		2.4%								98.4%
										100.0%

LNB w/OFA & SNCR											
Year	Date	TOTAL FIXED COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/ton NOx Removed)
0	2013	305,000	-	1,005,811	-	-	204,884	1,210,785	2,080,304	3,606,099	610
1	2014	311,000	-	1,025,927	-	-	209,084	1,235,011	2,090,304	3,635,415	615
2	2015	317,322	-	1,046,446	-	-	213,265	1,259,711	2,090,304	3,667,337	620
3	2016	323,663	-	1,067,375	-	-	217,531	1,284,905	2,090,304	3,698,877	625
4	2017	330,142	-	1,086,722	-	-	221,861	1,310,603	2,090,304	3,731,048	631
5	2018	336,745	-	1,106,496	-	-	226,319	1,336,875	2,090,304	3,763,884	637
6	2019	343,480	-	1,132,706	-	-	230,845	1,363,552	2,090,304	3,797,335	642
7	2020	350,349	-	1,165,361	-	-	235,462	1,390,823	2,090,304	3,831,476	648
8	2021	357,356	-	1,178,668	-	-	240,471	1,413,639	2,090,304	3,866,269	654
9	2022	364,503	-	1,202,037	-	-	244,975	1,447,012	2,090,304	3,901,818	660
10	2023	371,783	-	1,226,078	-	-	249,374	1,475,952	2,090,304	3,938,048	666
11	2024	379,229	-	1,250,599	-	-	254,872	1,505,471	2,090,304	3,975,004	672
12	2025	386,814	-	1,283,124	-	-	265,989	1,535,581	2,090,304	4,012,888	678
13	2026	394,550	-	1,310,124	-	-	265,169	1,566,282	2,090,304	4,051,146	685
14	2027	402,441	-	1,327,446	-	-	270,472	1,597,618	2,090,304	4,089,363	692
15	2028	410,490	-	1,353,689	-	-	275,581	1,628,570	2,090,304	4,130,364	699
16	2029	418,700	-	1,380,763	-	-	281,389	1,652,182	2,090,304	4,171,655	715
17	2030	427,074	-	1,418,546	-	-	287,027	1,685,406	2,090,304	4,212,783	713
18	2031	435,615	-	1,456,546	-	-	292,768	1,729,313	2,090,304	4,255,232	720
19	2032	444,327	-	1,495,276	-	-	298,623	1,763,859	2,090,304	4,286,331	727
20	2033	3,726,445	9.2%	12,288,349	-	0.0%	2,504,464	14,753,314	21,975,632	40,493,391	342
Present Worth (%) of PWI		5,635,480	0.0%	12,288,349	-	0.0%	2,504,464	14,753,314	21,975,632	40,493,391	342

LNB w/OFA & SCR											
Year	Date	TOTAL FIXED COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/ton NOx Removed)
0	2013	600,000	-	-	-	-	1,369,718	2,782,568	12,235,235	15,583,301	1,734
1	2014	612,000	-	-	-	-	1,285,113	2,635,218	12,235,235	15,648,352	1,741
2	2015	649,190	-	591,105	649,190	-	1,321,015	2,894,982	12,235,235	15,715,407	1,749
3	2016	654,074	-	624,240	654,074	-	1,347,335	2,882,882	12,235,235	15,783,150	1,756
4	2017	659,155	-	688,722	659,155	-	1,374,884	3,011,938	12,235,235	15,852,329	1,764
5	2018	664,438	-	700,965	664,438	-	1,401,871	3,172,178	12,235,235	15,922,451	1,772
6	2019	670,927	-	707,458	670,927	-	1,429,987	3,131,622	12,235,235	15,994,783	1,780
7	2020	676,615	-	712,615	676,615	-	1,458,507	3,185,284	12,235,235	16,068,154	1,788
8	2021	545,626	-	1,049,375	689,211	-	1,487,677	3,260,220	12,235,235	16,142,193	1,796
9	2022	556,338	-	1,068,547	702,986	-	1,517,431	3,285,424	12,235,235	16,219,328	1,805
10	2023	567,669	-	1,080,938	717,036	-	1,547,779	3,391,883	12,235,235	16,297,190	1,813
11	2024	579,022	-	1,112,157	711,397	-	1,578,735	3,459,771	12,235,235	16,376,009	1,822
12	2025	590,603	-	1,135,012	716,025	-	1,616,945	3,528,957	12,235,235	16,457,616	1,831
13	2026	602,415	-	1,157,712	760,925	-	1,642,516	3,569,546	12,235,235	16,540,244	1,840
14	2027	614,463	-	1,180,985	776,184	-	1,675,866	3,671,537	12,235,235	16,624,224	1,850
15	2028	626,752	-	1,204,484	781,687	-	1,708,874	3,744,988	12,235,235	16,710,180	1,859
16	2029	633,287	-	1,228,573	807,521	-	1,743,051	3,819,887	12,235,235	16,798,756	1,869
17	2030	652,073	-	1,253,445	823,671	-	1,777,912	3,886,264	12,235,235	16,887,614	1,879
18	2031	663,115	-	1,278,208	840,145	-	1,813,970	3,974,190	12,235,235	16,978,942	1,889
19	2032	678,417	-	1,303,372	866,948	-	1,849,740	4,053,874	12,235,235	17,071,592	1,900
20	2033	691,985	3.4%	11,553,043	1,328,347	-	1,874,087	4,129,371	12,235,235	17,165,161	942
Present Worth (%) of PWI		5,635,480	0.0%	11,553,043	1,328,347	0.0%	1,874,087	4,129,371	12,235,235	17,165,161	942

Upgraded Wet FGD											
Jim Bridger Unit 3											
Year	Date	TOTAL FIXED OR&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton SO2 Removed)
0	2013	42,583	29,927	533,206	442,958	204,884	1,211,075	1,236,652	2,490,310	631	
1	2014	43,435	30,526	543,870	451,818	209,084	1,236,287	1,236,652	2,515,384	837	
2	2015	44,303	31,136	554,747	460,854	213,265	1,250,003	1,236,652	2,540,858	843	
3	2016	45,189	31,758	565,842	470,071	217,531	1,285,203	1,236,652	2,657,044	850	
4	2017	46,083	32,394	577,159	478,472	221,881	1,310,907	1,236,652	2,673,652	857	
5	2018	47,015	33,042	588,702	480,062	226,219	1,347,125	1,236,652	2,690,782	864	
6	2019	47,955	33,703	600,476	486,848	230,845	1,385,885	1,236,652	2,648,475	671	
7	2020	48,914	34,397	612,486	508,820	235,482	1,430,145	1,236,652	2,676,711	678	
8	2021	49,893	35,065	624,735	518,986	240,171	1,418,988	1,236,652	2,705,513	685	
9	2022	50,890	35,766	637,230	528,376	244,975	1,447,347	1,236,652	2,734,890	892	
10	2023	51,908	38,481	649,975	539,964	249,874	1,476,284	1,236,652	2,764,855	700	
11	2024	52,946	37,241	662,974	550,763	254,872	1,505,820	1,236,652	2,795,419	708	
12	2025	54,005	37,935	676,234	561,778	259,889	1,535,936	1,236,652	2,826,594	716	
13	2026	55,085	38,714	689,758	573,014	265,169	1,566,655	1,236,652	2,858,393	724	
14	2027	56,187	39,488	703,554	584,474	270,472	1,597,988	1,236,652	2,890,828	732	
15	2028	57,311	40,276	717,625	598,164	275,881	1,633,948	1,236,652	2,923,911	740	
16	2029	58,457	41,084	731,977	602,087	281,389	1,662,547	1,236,652	2,957,656	749	
17	2030	59,626	41,905	746,617	620,249	287,027	1,695,758	1,236,652	2,982,076	758	
18	2031	60,813	42,744	761,549	632,654	292,768	1,729,714	1,236,652	3,027,185	766	
19	2032	62,035	43,598	775,628	645,307	303,523	1,764,398	1,236,652	3,062,995	776	
20	2033	62,035	1.8%	385,648	56,148	5,417,000	2,504,484	14,786,741	12,989,900	28,316,912	
Present Worth (%) of PWI		\$20,271	1.8%	385,648	56,148	0.0%	19.1%	8.8%	52.3%	45.9%	
Present Worth (%) of PWI		\$20,333	5.7%	-	-	-	-	-	-	338	


  

Flue Gas Conditioning											
Jim Bridger Unit 3											
Year	Date	TOTAL FIXED OR&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/Ton PM Removed)
0	2013	10,000	-	145,954	-	-	19,710	165,584	-	175,584	275
1	2014	10,200	-	148,774	-	-	20,104	168,875	-	178,075	280
2	2015	10,404	-	151,147	-	-	20,506	172,253	-	182,857	286
3	2016	10,612	-	154,761	-	-	20,916	175,688	-	186,310	292
4	2017	10,824	-	157,877	-	-	21,335	179,212	-	190,036	298
5	2018	-	-	161,035	-	-	-	-	-	193,837	304
6	2019	11,041	-	164,255	-	-	22,197	186,452	-	197,714	310
7	2020	11,262	-	167,540	-	-	22,641	190,181	-	201,688	316
8	2021	11,487	-	170,891	-	-	23,093	193,985	-	205,701	322
9	2022	11,717	-	174,309	-	-	23,555	197,884	-	208,815	329
10	2023	11,951	-	177,795	-	-	24,026	201,822	-	214,012	335
11	2024	12,180	-	181,351	-	-	24,507	205,858	-	218,282	342
12	2025	12,334	-	184,978	-	-	24,987	209,975	-	222,658	349
13	2026	12,582	-	188,678	-	-	25,487	214,175	-	227,111	356
14	2027	12,836	-	192,451	-	-	26,007	218,458	-	231,853	363
15	2028	13,185	-	196,300	-	-	26,527	222,827	-	236,986	370
16	2029	13,539	-	200,228	-	-	27,058	227,224	-	241,012	377
17	2030	13,728	-	204,231	-	-	27,589	231,830	-	245,832	385
18	2031	14,002	-	208,315	-	-	28,151	236,466	-	250,749	393
19	2032	14,282	-	212,482	-	-	28,714	241,156	-	255,764	401
20	2033	14,568	-	217,023	-	-	24,0814	242,837	-	245,015	408
Present Worth (%) of PWI		122,739	5.7%	-	553,151%	0.0%	-	11,12%	54.3%	0.0%	100.0%

**Jim Bridger Unit 3****Fabric Filter**

Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$/ton PM Removed)
0	2013	127,749	-	-	284,008	-	1,313,474	1,607,482	4,602,887	6,398,118	6,381
1	2014	130,304	-	-	259,888	-	1,339,744	1,619,632	4,602,887	6,372,822	6,416
2	2015	132,910	-	-	305,686	-	1,365,539	1,612,425	4,602,887	6,408,221	6,451
3	2016	135,588	-	-	312,004	-	1,383,870	1,705,673	4,602,887	6,444,326	6,488
4	2017	138,279	-	-	318,244	-	1,421,747	1,739,991	4,602,887	6,481,156	6,525
5	2018	141,045	-	-	324,609	-	1,450,182	1,774,790	4,602,887	6,518,722	6,553
6	2019	-	-	-	331,101	-	1,479,186	1,810,286	4,602,887	6,557,038	6,601
7	2020	143,866	-	-	337,723	-	1,508,769	1,845,492	4,602,887	6,596,121	6,640
8	2021	146,743	-	-	344,477	-	1,538,845	1,883,422	4,602,887	6,655,986	6,681
9	2022	149,678	-	-	351,387	-	1,569,723	1,921,050	4,602,887	6,676,648	6,722
10	2023	152,671	-	-	358,394	-	1,601,118	1,959,512	4,602,887	6,718,123	6,763
11	2024	155,725	-	-	365,562	-	1,633,140	1,983,702	4,602,887	6,760,428	6,805
12	2025	158,839	-	-	372,873	-	1,665,803	2,023,676	4,602,887	6,803,579	6,849
13	2026	162,016	-	-	379,331	-	1,699,119	2,073,450	4,602,887	6,847,593	6,884
14	2027	165,256	-	-	387,937	-	1,723,102	2,121,039	4,602,887	6,892,487	6,929
15	2028	168,552	-	-	395,698	-	1,757,784	2,163,490	4,602,887	6,958,279	6,985
16	2029	171,933	-	-	403,610	-	1,783,119	2,205,729	4,602,887	6,984,987	7,032
17	2030	175,371	-	-	411,682	-	1,809,181	2,250,863	4,602,887	7,032,629	7,080
18	2031	178,879	-	-	419,816	-	1,875,965	2,295,881	4,602,887	7,031,224	7,128
19	2032	182,456	-	-	428,314	-	1,913,484	2,341,798	4,602,887	7,150,790	7,179
20	2033	186,106	-	-	437,016	-	1,950,919	2,389,616	4,602,887	7,179,553	7,226
Present Worth (%) of PVI		1,560,813	2.2%	0.0%	3,592,147	5.2%	0.0%	16,007,838	48,386,333	68,567,130	100.0%
											3,503


### First Year Cost for Air Pollution Control Options



EY102007001SHC\App A\_PCorp JB3 BART Economic Analysis\_01-11-07.xls

1 of 1

### **Present Worth Cost for Air Pollution Control Options**



EY102007001S1C\App A\_PCorp JB3 BART Economic Analysis\_01-11-07.xls

1 of 1

**APPENDIX B**

**2006 Wyoming BART Protocol**

**BART Air Modeling Protocol**

**Individual Source Visibility Assessments  
for BART Control Analyses**

**September, 2006**

**State of Wyoming  
Department of Environmental Quality  
Air Quality Division  
Cheyenne, WY 82002**

## Table of Contents

1.0	INTRODUCTION .....	3
2.0	OVERVIEW .....	4
3.0	EMISSIONS DATA FOR MODELING .....	7
3.1	Baseline Modeling .....	7
3.2	Post-Control Modeling.....	8
4.0	METEOROLOGICAL DATA.....	9
5.0	CALPUFF MODEL APPLICATION.....	12
6.0	POST PROCESSING .....	15
7.0	REPORTING .....	19

## 1.0 INTRODUCTION

The U.S. EPA has issued final amendments to the Regional Haze Regulations, along with Guidelines for Best Available Retrofit Technology (BART) Determinations.<sup>(1)</sup> The guidelines address the methodology for determining which facilities must apply BART (sources subject-to-BART) and the evaluation of control options.

The State of Wyoming used air quality modeling in accordance with the EPA Guidelines to determine the Wyoming sources which are subject-to-BART. This Protocol defines the specific methodology to be used by those sources for determining the improvement in visibility to be achieved by BART controls.

The methodology presented in this Protocol is consistent with EPA guidance and the Air Quality Division (AQD) determination of subject-to-BART sources. It is intended that all Wyoming sources that must conduct BART analyses will use this Protocol for their evaluation of control technology visibility improvement. Any deviations from the procedures described herein must be approved by the Division prior to implementation.

---

<sup>(1)</sup> 40 CFR Part 51: Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations; Final Rule. 70 Federal Register, 39103-39172, July 6, 2005.

## 2.0 OVERVIEW

Wyoming AQD determined that eight facilities (sources) in the state are subject-to-BART. The sources are listed in Table 1. Division modeling indicated that each of these sources causes or contributes to visibility impairment in one or more Class I areas. Each source must conduct a BART analysis to define Best Available Retrofit Technology (BART) applicable to that source, and quantify the improvement in Class I visibility associated with BART controls. This Protocol sets out the procedures for quantifying visibility improvement. Other aspects of the full BART analysis are not addressed here.

There are many Class I areas within and surrounding Wyoming (See Figure 1). On the basis of distance from subject-to-BART sources, topography, meteorology, and prior modeling, the AQD has determined that only five Class I areas need be addressed in BART individual source analyses. These are Badlands and Wind Cave National Parks in South Dakota, Mt. Zirkel Wilderness Area in Colorado, and Bridger and Fitzpatrick Wilderness Areas in Wyoming. Sources in eastern Wyoming have been shown to have greatest visibility impacts at the two South Dakota Class I areas, and western Wyoming sources have maximum impacts at Bridger and Fitzpatrick Wilderness Areas, and Mt. Zirkel. Visibility improvement at these highest impact areas will provide the best measure of the effectiveness of BART controls.

Each facility should carry out modeling with the CALPUFF modeling system for the Class I areas specified in Table 2. The AQD will provide meteorological input for CALMET for the years 2001, 2002, and 2003. The model domain covered by the AQD meteorological data is centered in southwest Wyoming, and extends roughly from Twin Falls, ID in the west to the Missouri River in the east, and from Denver in the south to Helena, MT in the north. The domain is shown, along with Class I areas, in Figure 1.

Sources may wish to utilize a smaller domain for CALPUFF modeling. Smaller domains are acceptable if they provide adequate additional area beyond the specific source and Class I areas being addressed. Figure 1 includes a "southwest Wyoming" domain which represents the minimum acceptable area for sources impacting the Bridger and Fitzpatrick Wilderness Areas, and the Mt. Zirkel Wilderness Area, and a "northeast Wyoming" domain as a minimum area for Badlands and Wind Cave National Parks modeling.

The CALPUFF model should be used with each of the three years of meteorological data to calculate visibility impacts for a baseline (existing emissions) case, and for cases reflecting BART controls. The control scenarios are to include individual scenarios for proposed BART controls for each pollutant ( $\text{SO}_2$ ,  $\text{NO}_x$ , and particulate matter), and a combined scenario representing application of all proposed BART controls. If desired, additional modeling may be performed for controls that are not selected as BART. This might be done, for example, to provide data useful in identifying the control technologies that represent BART. However, visibility modeling is required only for the proposed BART controls.

Table 1. Wyoming Sources Subject-to-BART

Basin Electric	Laramie River Power Plant	Boilers #1,2,3
FMC Corporation	Granger Soda Ash Plant	Boilers #1,2
FMC Corporation	Green River Sodium Plant	Three boilers
General Chemical Co.	Green River Soda Ash	Two boilers
PacifiCorp	Dave Johnson Power Plant	Boilers #3,4
PacifiCorp	Jim Bridger Power Plant	Boilers #1-4
PacifiCorp	Naughton Power Plant	Boilers #1,2,3
PacifiCorp	Wyodak Power Plant	Boiler

Results of visibility modeling will be presented as a comparison between baseline impacts and those calculated for the BART control scenarios. Quantitative measures of impact will be the 98<sup>th</sup> percentile deciview change ( $\Delta$ dv) relative to the 20% best days natural background, and the number of days with deciview change exceeding 0.5 (EPA Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations, 70 FR 39103). Results should be presented for each year.

Table 2. Source-Specific Class I Areas to be Addressed

Source	Class I Areas to be Evaluated
Basin Electric Laramie River	Wind Cave NP, Badlands NP
FMC Corporation Granger Soda Ash	Bridger WA, Fitzpatrick WA
FMC Corporation Sodium Products	Bridger WA, Fitzpatrick WA
General Chemical Green River Soda Ash	Bridger WA, Fitzpatrick WA
Pacificorp Dave Johnston	Wind Cave NP, Badlands NP
Pacificorp Jim Bridger	Bridger WA, Fitzpatrick WA, Mt. Zirkel WA
Pacificorp Naughton Plant	Bridger WA, Fitzpatrick WA
Pacificorp Wyodak	Wind Cave NP, Badlands NP

### **3.0 EMISSIONS DATA FOR MODELING**

CALPUFF model input requires source (stack) – specific emission rates for each pollutant, and stack parameters (height, diameter, exit gas temperature, and exit gas velocity). Per EPA BART guidance, these parameters must be representative of maximum actual 24-hour average emitting conditions for baseline (existing) operation, and maximum proposed 24-hour average emissions for future (BART) operations.

#### **3.1 Baseline Modeling**

Sources are required to utilize representative baseline emission conditions if data are available; baseline emissions must be documented. Possible sources of emission data are stack tests, CEM data, fuel consumption data, etc. Remember that emissions should represent maximum 24-hour rates. EPA BART guidance states that you should “Use the 24-hour average-actual emission rate from the highest emitting day of the meteorological period modeled (for the pre-control scenario).” Thus, baseline conditions should reference data from 2001 through 2003 (or 2004).

As a minimum, modeled emissions must include:

SO <sub>2</sub>	sulfur dioxide
NO <sub>x</sub>	oxides of nitrogen
PM <sub>2.5</sub>	particles with diameter less than 2.5 μm
PM <sub>10-2.5</sub>	particles with diameters greater than 2.5 μm but less than or equal to 10 μm

If the fraction of PM<sub>10</sub> in the PM<sub>2.5</sub> (fine) and PM<sub>10-2.5</sub> (coarse) categories cannot be determined all particulate matter should be assumed to be PM<sub>2.5</sub>.

In addition, direct emissions of sulfate (SO<sub>4</sub>) should be included where possible. Sulfate can be emitted as sulfuric acid (H<sub>2</sub>SO<sub>4</sub>), sulfur trioxide (SO<sub>3</sub>), or as sulfate compounds; emissions should be quantified as the equivalent mass of SO<sub>4</sub>.

When test or engineering data are not available to specify SO<sub>4</sub> emissions or the relative fractions of fine and coarse particles, use can be made of speciation profiles available from Federal Land Managers at the website <http://www2.nature.nps.gov/air/permits/ect/index.cfm>. Profiles are available for a number of source type and control technology combinations. The FLM speciation factors are acceptable if data are available for the appropriate source type.

Emissions of VOC (volatile organic compounds), condensable organics measured in stack tests, and elemental carbon components of PM<sub>10</sub> do not need to be included for BART modeling. The only other pollutant noted in EPA BART guidance is ammonia (NH<sub>3</sub>). Though ammonia is not believed to be a significant contributor to visibility

impairment in most cases in Wyoming, it could be important for sources with significant ammonia emissions – for example from some NO<sub>x</sub> control systems. Sources that are expected to emit ammonia (in pre-or post-control configurations) should include ammonia emissions in their model input.

If quantitative baseline emissions data are unavailable and sources believe that the maximum 24-hour emission rates estimated by the Division (presented in the Subject-to-BART final report) are representative of baseline conditions for their facility, they may be used for baseline modeling. However, emissions of sulfate and ammonia (if applicable) should be included based on the best available test information or speciation factors from current literature.

### 3.2 Post-Control Modeling

All pollutants described above should be included for each post-control scenario. Post-control emissions (maximum 24-hour average) will generally be the baseline emissions multiplied by a control factor appropriate to the BART control. However, some proposed controls may simply increase the efficiency of existing controls; others may result in an increase in emissions of one pollutant while controlling another. These factors must all be considered in defining emission rates for post-control modeling. Any changes in stack parameters resulting from control application must also be included.

The required visibility assessment will include the effect of each proposed BART control. For example, if a source proposes to add a scrubber for SO<sub>2</sub> control, low NO<sub>x</sub> burners for NO<sub>x</sub> control, and a baghouse for particulate control, four sets of visibility results should be developed:

- Use of SO<sub>2</sub> control alone
- Use of NO<sub>x</sub> control alone
- Use of particulate control alone
- Use of proposed combination of all three controls

All pollutants should be modeled in each CALPUFF model run, but the modeled emissions should reflect only the specific controls or combination of controls addressed in that run.

Additional modeling could be necessary in situations where a facility is comprised of more than one subject-to-BART source, and different BART controls are applicable to different sources. Excessive modeling to address multiple control combinations is not necessary; however, visibility modeling should quantify the effect of BART controls on all affected sources for each pollutant, and of all facility BART controls combined.

#### **4.0 METEOROLOGICAL DATA**

Wyoming AQD will provide MM5 meteorological data fields for years 2001, 2002, and 2003 that can be utilized as input to CALMET. The MM5 output will have 12 kilometer resolution and cover the full domain shown in Figure 1.

Mesoscale meteorological data (MM5) were developed and evaluated as part of the AQD's southwest Wyoming NO<sub>2</sub> increment analysis. Three years of MM5 data at 36 km resolution were used to initialize 12 km MM5 simulations. The 12km MM5 modeling used identical physics options to the original 36 km runs. CALMM5 was then used as a preprocessor to produce CALMET - ready MM5 data input files. Quality assurance was performed by comparing the original MM5 output on the 36km national RPO grid to the 12 km MM5 output and observations.

The CALMET model (version 5.53a, level 040716) should be used to prepare meteorological input for CALPUFF. The user may select a domain smaller than the MM5 domain for CALMET and CALPUFF modeling if desired. Figure 1 shows minimum domain areas for modeling of western and eastern Wyoming BART sources. Four kilometer resolution should be specified for CALMET output.

CALMET processing should use the AQD MM5 data, and appropriate surface, upper air, and precipitation data. Figure 2 shows the locations of surface and upper air stations within the MM5 model domain. The MM5 data are used as the initial guess wind field; this wind field is then adjusted by CALMET for terrain and land use to generate a step 1 wind field, and refined using surface and upper air data to create the final step 2 wind field.

Surface, upper air, and precipitation data can be obtained from the National Climatic Data Center. Land use and terrain data are available from the U.S. Geological Survey. Data can be formatted for use in CALMET with standard conversion and processing programs available with the CALMET/CALPUFF software.

Table 3 provides a listing of applicable CALMET input variables for BART meteorological processing. The table includes inputs that are specific to Wyoming BART modeling. Inputs not shown in Table 3 are not relevant to the present application, are dependent on the specific model domain of the user, use model default values, or are obvious from the context.

Table 3. CALMET Control File Inputs

Variable	Description	Value
Input Group 1		
IBYR	Year	2001
		2002
		2003
IBTZ	Base time zone	7
IRTYPE	Run type	1
LCALGRD	Compute data fields for CALGRID	T
Input Group 2		
PMAP	Map projection	LCC
DGRIDKM	Grid spacing (km)	4
NZ	Number of layers	10
ZFACE	Cell face heights (m)	0
		-20
		40
		100
		140
		320
		580
		1020
		1480
		2220
		3500
Input Group 4		
NOOBS	No observation Mode	0
Input Group 5		
IWF COD	Model selection variable	1
IFRADJ	Froude number adjustment	1
IKINE	Kinematic effects	0
IOBR	Use O'Brien procedure	0
ISLOPE	Slope flow effects	1
IEXTRP	Extrapolate surface wind observations	-4
ICALM	Extrapolate calm surface winds	0
BIAS	Biases for weights of surface and upper air stations	All 0
RMIN2	Minimum distance for extrapolation	-1
IPROG	Use gridded prognostic model output	14
ISTEPPG	Time Step (hours)	1
LVARY	Use varying radius of influence	F

Table 3. CALMET Control File Inputs (continued)

Variable	Description	Value
RMAX 1	Maximum radius of influence (km)	30
RMAX 2	Maximum radius of influence (km)	50
RMIN	Minimum radius of influence (km)	0.1
TERRAD	Radius of influence for terrain (km)	15
R1	Relative weighting of first guess wind field and observations (km)	5
R2	Relative weighting aloft (km)	25
IDIOPT 1	Surface temperature	0
IDIOPT 2	Upper air lapse rate	0
ZUPT	Lapse rate depth (m)	200
IDIOPT 3	Average wind components	0
IUPWND	Upper air station	-1
ZUPWND (1)	Bottom and top of layer for domain scale winds (m)	1, 1000
ZUPWND (2)		1, 1000
IDIOPT4	Surface wind components	0
IDIOPT5	Upper air wind components	0
Input Group 6		
IAVEZI	Spatial averaging	1
MNMMDAV	Max search radius	1
HAFANG	Half angle for averaging (deg)	30
ILEVZI	Layer of winds in averaging	1
ZIMAX	Maximum overland mixing height (m)	3500
ITPROG	3D temperature source	1
IRAD	Interpolation type	1
TRADKM	Radius of influence - temperature (km)	500
NUMTS	Maximum number of Stations	5
IAVET	Spatial averaging of temperatures	1
NFLAGP	Precipitation interpolation	2

## 5.0 CALPUFF MODEL APPLICATION

The CALPUFF model (version 5.711a, level 040716) will be used to calculate pollutant concentrations at receptors in each Class I area. Application of CALPUFF should, in general, follow the guidance presented in the Interagency Workgroup on Air Quality Modeling (IWAQM) Phase 2 report (EPA - 454/R98-019) and the EPA Regional Haze Regulations and Guidelines for BART Determinations (70 FR 39103).

Appropriate CALPUFF control file inputs are in Table 4. Note should be taken of the basis for several of the recommended CALPUFF inputs.

- Building downwash effects need not be included. Because of the transport distances involved and the fact that most sources have tall stacks, building downwash is unlikely to have a significant effect on model-predicted concentrations
- Puff splitting is not required. The additional computation time necessary for puff splitting is not justified for purposes of BART analyses.
- Hourly ozone files should be used to define background ozone concentration. Data are available from the following sites within the model domain.

Rocky Mountain NP, CO  
Craters of the Moon NP, ID  
AIRS - Highland UT  
Mountain Thunder, WY  
Yellowstone NP, WY  
Centennial, WY  
Pinedale, WY

The background ozone concentration shown in Table 4 is used only when hourly data are missing.

- A constant background ammonia concentration of 2.0 ppb is specified. This value is based upon monitoring data from nearby states and IWAQM guidance. Experience suggests that 2.0 ppb is conservative in that it is unlikely to significantly limit nitrate formation in the model computations.
- MESOPUFF II chemical transformation rates should be used.
- The species to be modeled should be the seven identified in CALPUFF: SO<sub>2</sub>, SO<sub>4</sub>, NO<sub>x</sub>, HNO<sub>3</sub>, NO<sub>3</sub>, PM<sub>2.5</sub>, and PM<sub>10-2.5</sub>. If ammonia (NH<sub>3</sub>) is emitted it should be added to the species list. In most cases, all pollutants modeled will also be emitted, except for HNO<sub>3</sub> and NO<sub>3</sub>.

Concentration calculations should be made for receptors covering the areas of the Class I areas being addressed. Receptors in each Class I area will be those designated by the Federal Land Managers and available from the National Park Service website.

Table 4. CALPUFF Control File Inputs

Variable	Description	Value
	Input Group 1	
METRUN	Control parameter for running all periods in met file	1
IBYR	Starting year	2001 2002 2003
XBTZ	Base time zone	7
NSPEC	Number of chemical species modeled	7 (or 8)
NSE	Number of species emitted	5 (or 6)
METFM	Meteorological data format	1
	Input Group 2	
MGAUSS	Vertical distribution in near field	1
MCTADJ	Terrain adjustment method	3
MCTSG	Subgrid scale complex terrain	0
MSLUG	Elongated puffs	0
MTRANS	Transitional plume rise	1
MTIP	Stack tip downwash	1
MSHEAR	Vertical wind shear	0
MSPLIT	Puff splitting allowed?	0
MCHEM	Chemical mechanism	1
MAQCHEM	Aqueous phase transformation	0
MWET	Wet removal	1
MDRY	Dry deposition	1
MDISP	Dispersion Coefficients	3
MROUGH	Adjust sigma for roughness	0
MPARTL	Partial plume penetration of inversions	1
MPDF	PDF for convective conditions	0
	Input Group 4	
PMAP	Map projection	LCC
DGRIDKM	Grid spacing	4

Table 4. CALPUFF Control File Inputs (continued)

ZFACE	Cell face heights (m)	0 20 40 100 140 320 580 1020 1480 2220 3500
	Input Group 6	
NHILL	Number of terrain features	0
	Input Group 7	
Dry Gas Depo	Chemical parameters for dry gas deposition	Defaults
	Input Group 8	
Dry Part. Depo	Size parameters for dry particle deposition SO <sub>4</sub> , NO <sub>3</sub> , PM25 PM10	Defaults 6.5, 1.0
	Input Group 11	
MOZ	Ozone Input option	1
BCK03	Background ozone – all months (ppb)	44.0
BCKNH3	Background ammonia – all months (ppb)	2.0
	Input Group 12	
XMAXZI	Maximum mixing height (m)	3500
XMINZI	Minimum mixing height (m)	50

## 6.0 POST PROCESSING

Visibility impacts are calculated from the CALPUFF concentration results using CALPOST. CALPOST version 5.51, level 030709 should be used; the output from CALPOST will provide the highest deciview impact on each day from all receptors within each Class I area modeled.

For some CALPUFF applications such as deposition calculations, the POSTUTIL program is used prior to CALPOST. POSTUTIL is also used to repartition total nitrate by accounting for ammonia limiting. The ammonia limiting calculation in POSTUTIL should not be applied for Wyoming BART modeling. If you believe that ammonia limiting is appropriate for a specific BART analysis, justification should be discussed with the Division prior to its used.

Visibility calculations by CALPOST for BART purposes use Method 6. This method requires input of monthly relative humidity factors,  $f(RH)$ , for each Class I area. The EPA guidance document provides appropriate data for each area. Table 5 lists monthly  $f(RH)$  factors to use for the Wyoming, Colorado, and South Dakota areas to be addressed in BART modeling. The factors shown in Table 5 include averages for the adjacent Class I areas, and are within 0.2 units of the Guideline table values for the individual Class I areas.

Natural background conditions as a reference for determination of the delta-dv change due to a source should be representative of the 20% best natural visibility days. EPA BART guidance provides the 20% best days deciview values for each Class I area on an annual basis, but does not provide species concentration data for the 20% best background conditions. These concentrations are needed for input to CALPOST.

Annual species concentrations corresponding to the 20% best days were calculated for each Class I area to be addressed, by scaling back the annual average concentrations given in Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule (Table 2-1). A separate scaling factor was derived for each Class I area such that, when multiplied by the Guidance table annual concentrations, the 20% best days deciview value for that area would be calculated. The scaled aerosol concentrations were averaged for the Bridger and Fitzpatrick WAs, and for Wind Cave and Badlands NPs, because of their geographical proximity and similar annual background visibility. The 20% best days aerosol concentrations to be used for each month for Wyoming BART evaluations are listed in Table 6.

Table 7 is a list of inputs for CALPOST. These inputs should be used for all BART visibility calculations. Output from CALPOST should be configured to provide a ranked list of the highest delta-deciview values in each Class I area. The 98<sup>th</sup> percentile delta-deciview value and the number of values exceeding 0.5 can then be determined directly from the CALPOST output.

Table 5. Monthly f(RH) Factors for Class I Areas

Month	Wind Cave NP Badlands NP	Bridger WA Fitzpatrick WA	Mt. Zirkel WA
January	2.65	2.50	2.20
February	2.65	2.30	2.20
March	2.65	2.30	2.00
April	2.55	2.10	2.10
May	2.70	2.10	2.20
June	2.60	1.80	1.80
July	2.30	1.50	1.70
August	2.30	1.50	1.80
September	2.20	1.80	2.00
October	2.25	2.00	1.90
November	2.75	2.50	2.10
December	2.65	2.40	2.10

Table 6. Natural Background Concentrations of Aerosol Components for 20% Best Days for BART Analyses ( $\mu\text{g}/\text{m}^3$ )

Aerosol Component	Wind Cave NP Badlands NP	Fitzpatrick WA Bridger WA	Mt. Zirkel WA
Ammonium Sulfate	.047	.045	.046
Ammonium Nitrate	.040	.038	.038
Organic Carbon	.186	.178	.179
Elemental Carbon	.008	.008	.008
Soil	.198	.189	.190
Coarse Mass	1.191	1.136	1.141

Table 7. CALPOST Control File Inputs

Variable	Description	Value
	Input Group 1	
ASPEC	Species to Process	VISIB
ILAYER	Layer/deposition code	1
A,B	Scaling factors	0,0
LBACK	Add background concentrations?	F
BTZONE	Base time zone	7
LVSO4	Species to be included in extinction	T
LVNO3		T
LVOC		F
LVPMC		T
LVPMF		T
LVEC		F
LVBK	Include background?	T
SPECPMC	Species name for particulates	PM10
SPECPMF		PM25
EPMC	Extinction efficiencies	0.6
EPMF		1.0
EPMCBK		0.6
EESO4		3.0
EENO3		3.0
EEOC		4.0
EESOIL		1.0
ESEC		10.0
MVISBK	Visibility calculation method	6
RHFAC	Monthly RH adjustment factors	Table 5
BKSO4	Background concentrations	Table 6
BKNO3		Table 6
BKPMC		Table 6
BK_OC		Table 6
BKSOL		Table 6
BKEC		Table 6
BEXTRAY	Extinction due to Rayleigh scattering	10.0

## **7.0 REPORTING**

A report on the BART visibility analysis should be submitted that clearly compares impacts for post-control emissions to those for baseline emissions. Data for baseline and BART scenarios should include both the 98<sup>th</sup> percentile values and the number of days with delta-deciview values exceeding 0.5. Results should be given for each model year.

Table 8 is an example of a recommended format for presentation of model input and model results. The example is for baseline conditions; similar tables should be provided for each control scenario (SO<sub>2</sub>, NO<sub>x</sub>, and PM10) and for the combination of all BART controls. Your report tables need not follow the exact format shown in Table 8; but the same information should be provided in a concise and clear form. If additional scenarios were modeled or you wish to present supplemental information, they should be provided in an appendix or separate from the specified final results.

Table 8. Example Format for Presentation of Model Input and Results

Source (Unit) Description And ID	Baseline Conditions Model Input Data						Stack Height (m)	Stack Diameter (m)	Exit Velocity (m/s)	Exit Gas Temp (deg K)
	SO <sub>2</sub> Emission Rate (lb/day)	NO <sub>x</sub> Emission Rate (lb/day)	PM <sub>2.5</sub> Emission Rate (lb/day)	PM <sub>10-2.5</sub> Emission Rate (lb/day)	SO <sub>4</sub> Emission Rate (lb/day)	NH <sub>3</sub> Emission Rate (lb/day)				
Source 1	100	150	50	200	100	80	100	100	100	100
Source 2	120	180	60	220	120	90	120	120	120	120
Source 3	140	200	70	240	140	100	140	140	140	140
Source 4	160	220	80	260	160	120	160	160	160	160
Source 5	180	240	90	280	180	140	180	180	180	180
Source 6	200	260	100	300	200	160	200	200	200	200
Source 7	220	280	110	320	220	180	220	220	220	220
Source 8	240	300	120	340	240	200	240	240	240	240
Source 9	260	320	130	360	260	220	260	260	260	260
Source 10	280	340	140	380	280	240	280	280	280	280
Source 11	300	360	150	400	300	260	300	300	300	300
Source 12	320	380	160	420	320	280	320	320	320	320
Source 13	340	400	170	440	340	300	340	340	340	340
Source 14	360	420	180	460	360	320	360	360	360	360
Source 15	380	440	190	480	380	340	380	380	380	380
Source 16	400	460	200	500	400	360	400	400	400	400
Source 17	420	480	210	520	420	380	420	420	420	420
Source 18	440	500	220	540	440	400	440	440	440	440
Source 19	460	520	230	560	460	420	460	460	460	460
Source 20	480	540	240	580	480	440	480	480	480	480
Source 21	500	560	250	600	500	460	500	500	500	500
Source 22	520	580	260	620	520	480	520	520	520	520
Source 23	540	600	270	640	540	500	540	540	540	540
Source 24	560	620	280	660	560	520	560	560	560	560
Source 25	580	640	290	680	580	540	580	580	580	580
Source 26	600	660	300	700	600	560	600	600	600	600
Source 27	620	680	310	720	620	580	620	620	620	620
Source 28	640	700	320	740	640	600	640	640	640	640
Source 29	660	720	330	760	660	620	660	660	660	660
Source 30	680	740	340	780	680	640	680	680	680	680
Source 31	700	760	350	800	700	660	700	700	700	700
Source 32	720	780	360	820	720	680	720	720	720	720
Source 33	740	800	370	840	740	700	740	740	740	740
Source 34	760	820	380	860	760	720	760	760	760	760
Source 35	780	840	390	880	780	740	780	780	780	780
Source 36	800	860	400	900	800	760	800	800	800	800
Source 37	820	880	410	920	820	780	820	820	820	820
Source 38	840	900	420	940	840	800	840	840	840	840
Source 39	860	920	430	960	860	820	860	860	860	860
Source 40	880	940	440	980	880	840	880	880	880	880
Source 41	900	960	450	1000	900	860	900	900	900	900
Source 42	920	980	460	1020	920	880	920	920	920	920
Source 43	940	1000	470	1040	940	900	940	940	940	940
Source 44	960	1020	480	1060	960	920	960	960	960	960
Source 45	980	1040	490	1080	980	940	980	980	980	980
Source 46	1000	1060	500	1100	1000	960	1000	1000	1000	1000
Source 47	1020	1080	510	1120	1020	980	1020	1020	1020	1020
Source 48	1040	1100	520	1140	1040	1000	1040	1040	1040	1040
Source 49	1060	1120	530	1160	1060	1020	1060	1060	1060	1060
Source 50	1080	1140	540	1180	1080	1040	1080	1080	1080	1080
Source 51	1100	1160	550	1200	1100	1060	1100	1100	1100	1100
Source 52	1120	1180	560	1220	1120	1080	1120	1120	1120	1120
Source 53	1140	1200	570	1240	1140	1100	1140	1140	1140	1140
Source 54	1160	1220	580	1260	1160	1120	1160	1160	1160	1160
Source 55	1180	1240	590	1280	1180	1140	1180	1180	1180	1180
Source 56	1200	1260	600	1300	1200	1160	1200	1200	1200	1200
Source 57	1220	1280	610	1320	1220	1200	1220	1220	1220	1220
Source 58	1240	1300	620	1340	1240	1220	1240	1240	1240	1240
Source 59	1260	1320	630	1360	1260	1240	1260	1260	1260	1260
Source 60	1280	1340	640	1380	1280	1260	1280	1280	1280	1280
Source 61	1300	1360	650	1400	1300	1280	1300	1300	1300	1300
Source 62	1320	1380	660	1420	1320	1300	1320	1320	1320	1320
Source 63	1340	1400	670	1440	1340	1320	1340	1340	1340	1340
Source 64	1360	1420	680	1460	1360	1340	1360	1360	1360	1360
Source 65	1380	1440	690	1480	1380	1360	1380	1380	1380	1380
Source 66	1400	1460	700	1500	1400	1380	1400	1400	1400	1400
Source 67	1420	1480	710	1520	1420	1400	1420	1420	1420	1420
Source 68	1440	1500	720	1540	1440	1420	1440	1440	1440	1440
Source 69	1460	1520	730	1560	1460	1440	1460	1460	1460	1460
Source 70	1480	1540	740	1580	1480	1460	1480	1480	1480	1480
Source 71	1500	1560	750	1600	1500	1480	1500	1500	1500	1500
Source 72	1520	1580	760	1620	1520	1500	1520	1520	1520	1520
Source 73	1540	1600	770	1640	1540	1520	1540	1540	1540	1540
Source 74	1560	1620	780	1660	1560	1540	1560	1560	1560	1560
Source 75	1580	1640	790	1680	1580	1560	1580	1580	1580	1580
Source 76	1600	1660	800	1700	1600	1580	1600	1600	1600	1600
Source 77	1620	1680	810	1720	1620	1600	1620	1620	1620	1620
Source 78	1640	1700	820	1740	1640	1620	1640	1640	1640	1640
Source 79	1660	1720	830	1760	1660	1640	1660	1660	1660	1660
Source 80	1680	1740	840	1780	1680	1660	1680	1680	1680	1680
Source 81	1700	1760	850	1800	1700	1680	1700	1700	1700	1700
Source 82	1720	1780	860	1820	1720	1700	1720	1720	1720	1720
Source 83	1740	1800	870	1840	1740	1720	1740	1740	1740	1740
Source 84	1760	1820	880	1860	1760	1740	1760	1760	1760	1760
Source 85	1780	1840	890	1880	1780	1760	1780	1780	1780	1780
Source 86	1800	1860	900	1900	1800	1780	1800	1800	1800	1800
Source 87	1820	1880	910	1920	1820	1800	1820	1820	1820	1820
Source 88	1840	1900	920	1940	1840	1820	1840	1840	1840	1840
Source 89	1860	1920	930	1960	1860	1840	1860	1860	1860	1860
Source 90	1880	1940	940	1980	1880	1860	1880	1880	1880	1880
Source 91	1900	1960	950	2000	1900	1880	1900	1900	1900	1900
Source 92	1920	1980	960	2020	1920	1900	1920	1920	1920	1920
Source 93	1940	2000	970	2040	1940	1920	1940	1940	1940	1940
Source 94	1960	2020	980	2060	1960	1940	1960	1960	1960	1960
Source 95	1980	2040	990	2080	1980	1960	1980	1980	1980	1980
Source 96	2000	2060	1000	2100	2000	1980	2000	2000	2000	2000
Source 97	2020	2080	1010	2120	2020	2000	2020	2020	2020	2020
Source 98	2040	2100	1020	2140	2040	2020	2040	2040	2040	2040
Source 99	2060	2120	1030	2160	2060	2040	2060	2060	2060	2060
Source 100	2080	2140	1040	2180	2080	2060	2080	2080	2080	2080

Baseline Visibility Modeling Results

Name of Facility	Class I Area	Baseline Visibility Monitoring Results				No. of days exceeding 0.5 dv	No. of days exceeding 0.5 dv
		2001	2002	98 <sup>th</sup> Percentile	No. of days exceeding 0.5 dv		

*Final Report*

# BART Analysis for Jim Bridger Unit 4



Prepared For:

**PacifiCorp**

1407 West North Temple,  
Salt Lake City, Utah 84116

December 2007

Prepared By:

**CH2MHILL**

215 South State Street, Suite 1000  
Salt Lake City, Utah 84111

*Final Report*

# BART Analysis for Jim Bridger Unit 4

Submitted to

**PacifiCorp**

December 2007

**CH2MHILL**

# Executive Summary

## Background

In response to the Regional Haze Rule and Best Available Retrofit Technology (BART) regulations and guidelines, CH2M HILL was requested to perform a BART analysis for PacifiCorp's Jim Bridger Unit 4 (hereafter referred to as Jim Bridger 4). A BART analysis has been conducted for the following criteria pollutants: nitrogen oxides ( $\text{NO}_x$ ), sulfur dioxide ( $\text{SO}_2$ ), and particulate matter less than 10 micrometers in aerodynamic diameter ( $\text{PM}_{10}$ ). The Jim Bridger Station consists of four 530-megawatt (MW) units with a total generating capacity of 2,120 MW. Because the total generating capacity of the Jim Bridger Station exceeds 750 MW, presumptive BART emission limits apply to Jim Bridger 4, based on the United States Environmental Protection Agency's (EPA) guidelines. BART emissions limits must be achieved within 5 years after the State Implementation Plan (SIP) is approved by the EPA. A compliance date of 2014 was assumed for this analysis.

In completing the BART analysis, technology alternatives were investigated and potential reductions in  $\text{NO}_x$ ,  $\text{SO}_2$ , and  $\text{PM}_{10}$  emissions rates were identified. The following technology alternatives were investigated, listed below by pollutant:

- $\text{NO}_x$  emission controls:
  - Low- $\text{NO}_x$  burners (LNBs) with over-fire air (OFA)
  - LNBs with rotating opposed fire air (ROFA)
  - LNBs with selective non-catalytic reduction (SNCR) system
  - LNBs with selective catalytic reduction (SCR) system
- $\text{SO}_2$  emission controls:
  - Dry flue gas desulfurization (FGD) system with existing electrostatic precipitator (ESP)
  - Dry FGD system with new polishing fabric filter
  - Wet FGD system and new stack with existing ESP
- $\text{PM}_{10}$  emission controls:
  - Sulfur trioxide ( $\text{SO}_3$ ) injection flue gas conditioning system on existing ESP
  - Polishing fabric filter

## BART Engineering Analysis

The specific steps in a BART engineering analysis are identified in the Code of Federal Regulations (CFR) at 40 CFR 51, Appendix Y, Section IV. The evaluation must include:

- The identification of available, technically feasible, retrofit control options
- Consideration of any pollution control equipment in use at the source (which affects the availability of options and their impacts)
- The costs of compliance with the control options
- The remaining useful life of the facility
- The energy and non-air quality environmental impacts of compliance
- The degree of visibility improvement that may reasonably be anticipated from the use of BART

The following steps are incorporated into the BART analysis:

- Step 1 – Identify All Available Retrofit Control Technologies
- Step 2 – Eliminate Technically Infeasible Options
  - The identification of available, technically feasible, retrofit control options
  - Consideration of any pollution control equipment in use at the source (which affects the applicability of options and their impacts)
- Step 3 – Evaluate Control Effectiveness of Remaining Control Technologies
- Step 4 – Evaluate Impacts and Document the Results
  - The costs of compliance with the control options
  - The remaining useful life of the facility
  - The energy and non-air quality environmental impacts of compliance
- Step 5 – Evaluate Visibility Impacts
  - The degree of visibility improvement that may reasonably be anticipated from the use of BART

Separate analyses have been conducted for NO<sub>x</sub>, SO<sub>2</sub>, and PM<sub>10</sub> emissions. All costs included in the BART analyses are in 2006 dollars, and costs have not been escalated to the assumed 2014 BART implementation date.

## Coal Characteristics

The main source of coal burned at Jim Bridger 4 will be the Bridger Underground Mine. Secondary sources are the Bridger Surface Mine, the Bridger Highwall Mine, the Black Butte Mine, and the Leucite Hills Mine. These coals are ranked as sub-bituminous, but are closer in

characteristics to bituminous coal in many of the parameters influencing NO<sub>x</sub> formation. These coals have higher nitrogen content than coals from the Powder River Basin (PRB), which represent the bulk of sub-bituminous coal use in the U.S. This BART analysis has considered the higher nitrogen content and different combustion characteristics of PRB coals as compared to those coals used at Jim Bridger 4, and has evaluated the effect of these qualities on NO<sub>x</sub> formation and achievable emission rates.

## Recommendations

CH2M HILL recommends installing the following control devices, which include LNBs with OFA, upgrading the existing FGD system, and operating the existing electrostatic precipitator with an SO<sub>3</sub> flue gas conditioning system. This combination of control devices is identified as Scenario 1 throughout this report.

### NO<sub>x</sub> Emission Control

The BART presumptive NO<sub>x</sub> limit assigned by the EPA for tangentially fired boilers burning sub-bituminous coal is 0.15 pound (lb) per million British thermal units (MMBtu). However, as documented in this analysis, the characteristics of the Jim Bridger coals are more closely aligned with bituminous coals, and have been assigned a presumptive BART NO<sub>x</sub> limit of 0.28 lb per MMBtu.

CH2M HILL recommends LNBs with OFA as BART for Jim Bridger 4, based on the projected significant reduction in NO<sub>x</sub> emissions, reasonable control costs, and the advantages of no additional power requirements or non-air quality environmental impacts. NO<sub>x</sub> reductions are expected to be similar to those realized at Jim Bridger 2. CH2M HILL recommends that the unit be permitted at a rate of 0.26 lb per MMBtu.

### SO<sub>2</sub> Emission Control

CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 4, based on the significant reduction in SO<sub>2</sub> emissions, reasonable control costs, and the advantages of minimal additional power requirements and minimal non-air quality environmental impacts. This upgrade approach will meet the BART presumptive SO<sub>2</sub> limit of 0.15 lb per MMBtu.

### PM<sub>10</sub> Emission Control

CH2M HILL recommends finalizing the permitting of the flue gas conditioning (FGC) system to enhance the performance of the existing ESP as BART for Jim Bridger 4, based on the significant reduction in PM<sub>10</sub> emissions, reasonable control costs, and the advantages of minimal additional power requirements and no non-air quality environmental impacts.

## BART Modeling Analysis

CH2M HILL used the CALPUFF modeling system to assess the visibility impacts of emissions from Jim Bridger 4 at Class I areas. The Class I areas potentially affected are located more than 50 kilometers, but less than 300 kilometers, from the Jim Bridger Plant.

The Class I areas include the following wilderness areas:

- Bridger Wilderness Area
- Fitzpatrick Wilderness Area
- Mt. Zirkel Wilderness Area

Because Jim Bridger 4 will simultaneously control NO<sub>x</sub>, SO<sub>2</sub>, and PM<sub>10</sub> emissions, four post-control atmospheric dispersion modeling scenarios were developed to cover the range of effectiveness for combining the individual NO<sub>x</sub>, SO<sub>2</sub>, and PM<sub>10</sub> control technologies under evaluation. These modeling scenarios, and the controls assumed, are as follows:

- **Scenario 1:** New LNB with OFA modifications, upgraded wet FGD system, and FGC for enhanced ESP performance. As indicated previously, this scenario represents CH2M HILL's preliminary BART recommendation.
- **Scenario 2:** New LNB with OFA modifications, upgraded wet FGD system, and new polishing fabric filter.
- **Scenario 3:** New LNB with OFA modifications and SCR, upgraded wet FGD system, and FGC for enhanced ESP performance.
- **Scenario 4:** New LNB with OFA modifications and SCR; upgraded wet FGD system, and new polishing fabric filter.

Visibility improvements for all emission control scenarios were analyzed, and the results were compared using a least-cost envelope, as outlined in the New Source Review Workshop Manual.<sup>1</sup>

## Least-cost Envelope Analysis

The EPA has adopted the least-cost envelope analysis methodology as an accepted methodology for selecting the most reasonable, cost-effective controls. Incremental cost-effectiveness comparisons focus on annualized cost and emission reduction differences between dominant alternatives. The dominant set of control alternatives is determined by generating the envelope of least-cost alternatives. This is a graphical plot of total annualized costs for a total emissions reductions for all control alternatives identified in the BART analysis.

To evaluate the impacts of the modeled control scenarios on the three Class I areas, the total annualized cost, cost per deciview (dV) reduction, and cost per reduction in number of days above 0.5 dV were analyzed. This report provides a comparison of the average incremental costs between relevant scenarios for the three Class I areas; the total annualized cost versus number of days above 0.5 dV, and the total annualized cost versus 98<sup>th</sup> percentile delta-deciview ( $\Delta dV$ ) reduction.

Results of the least-cost envelope analysis validate the selection of Scenario 1, based on incremental cost and visibility improvements. Scenario 2 (LNB with OFA; upgraded wet FGD, and polishing fabric filter) is eliminated, because it is to the left of the curve formed by

<sup>1</sup> EPA, 1990. *New Source Review Workshop Manual*. Draft. Environmental Protection Agency. October, 1990.

the dominant control alternative scenario, which indicates a scenario with lower improvement and/or higher costs. Scenario 3 (LNB with OFA and SCR, upgraded wet FGD, and FGC for enhanced ESP performance) is not selected due to very high incremental costs, on the basis of both a cost per day of improvement and cost per dV reduction. While Scenario 4 (LNB with OFA and SCR, upgraded wet FGD, and polishing fabric filter) provides some potential visibility advantage over Scenario 1, the projected improvement is less than 0.5 dV, and the projected costs are excessive. Therefore, Scenario 1 represents BART for Jim Bridger 4.

## Just-Noticeable Differences in Atmospheric Haze

Studies have been conducted that demonstrate only dV differences of approximately 1.5 to 2.0 dV or more are perceptible by the human eye. Deciview changes of less than 1.5 cannot be distinguished by the average person. Therefore, the modeling analysis results indicate that only minimal, if any, observable visibility improvements at the Class I areas studied would be expected under any of the control scenarios. Thus, the results indicate that only minimal discernable visibility improvements may result, even though PacifiCorp will be spending many millions of dollars at this single unit, and over a billion dollars when considering its entire fleet of coal-fired power plants.

# Contents

---

1.0	<b>Introduction.....</b>	1-1
2.0	<b>Present Unit Operation.....</b>	2-1
3.0	<b>BART Engineering Analysis.....</b>	3-1
3.1	<b>Applicability .....</b>	3-1
3.2	<b>BART Process.....</b>	3-1
3.2.1	<b>BART NO<sub>x</sub> Analysis.....</b>	3-2
3.2.2	<b>BART SO<sub>2</sub> Analysis.....</b>	3-14
3.2.3	<b>BART PM<sub>10</sub> Analysis .....</b>	3-16
4.0	<b>BART Modeling Analysis.....</b>	4-1
4.1	<b>Model Selection .....</b>	4-1
4.2	<b>CALMET Methodology.....</b>	4-1
4.2.1	<b>Dimensions of the Modeling Domain.....</b>	4-1
4.2.2	<b>CALMET Input Data .....</b>	4-3
4.2.3	<b>Validation of CALMET Wind Field.....</b>	4-6
4.3	<b>CALPUFF Modeling Approach.....</b>	4-6
4.3.1	<b>Background Ozone and Ammonia.....</b>	4-6
4.3.2	<b>Stack Parameters.....</b>	4-6
4.3.3	<b>Emission Rates.....</b>	4-7
4.3.4	<b>Post-control Scenarios .....</b>	4-7
4.3.5	<b>Modeling Process.....</b>	4-8
4.3.6	<b>Receptor Grids .....</b>	4-8
4.4	<b>CALPOST.....</b>	4-10
4.5	<b>Presentation of Modeling Results.....</b>	4-11
4.5.1	<b>Visibility Changes for Baseline vs. Preferred Scenario.....</b>	4-11
5.0	<b>Preliminary Assessment and Recommendations .....</b>	5-1
5.1	<b>Least-cost Envelope Analysis.....</b>	5-1
5.1.1	<b>Analysis Methodology .....</b>	5-1
5.1.2	<b>Analysis Results.....</b>	5-9
5.2	<b>Recommendations .....</b>	5-9
5.2.1	<b>NO<sub>x</sub> Emission Control .....</b>	5-9
5.2.2	<b>SO<sub>2</sub> Emission Control.....</b>	5-9
5.2.3	<b>PM<sub>10</sub> Emission Control .....</b>	5-9
5.3	<b>Just-Noticeable Differences in Atmospheric Haze.....</b>	5-10
6.0	<b>References.....</b>	6-1

**Tables**

- 2-1 Unit Operation and Study Assumptions
- 2-2 Coal Sources and Characteristics
- 3-1 Coal Characteristics Comparison
- 3-2 NO<sub>x</sub> Control Technology Projected Emission Rates
- 3-3 NO<sub>x</sub> Control Cost Comparison
- 3-4 SO<sub>2</sub> Control Technology Emission Rates
- 3-5 Sulfur Dioxide Control Cost Comparison (Incremental to Existing Flue Gas Desulfurization System)
- 3-6 PM<sub>10</sub> Control Technology Emission Rates
- 3-7 PM<sub>10</sub> Control Cost Comparison (Incremental to Existing ESP)
- 4-1 User-specified CALMET Options
- 4-2 BART Model Input Data
- 4-3 Average Natural Levels of Aerosol Components
- 4-4 Costs and Visibility Modeling Results for Baseline Vs. Post-Control Scenarios at Class I Areas
- 5-1 Control Scenario Results for the Bridger Class I Wilderness Area
- 5-2 Control Scenario Results for the Fitzpatrick Class I Wilderness Area
- 5-3 Control Scenario Results for the Mt. Zirkel Class I Wilderness Area
- 5-4 Bridger Class I Wilderness Area Incremental Analysis Data
- 5-5 Fitzpatrick Class I Wilderness Area Incremental Analysis Data
- 5-6 Mt. Zirkel Class I Wilderness Area Incremental Analysis Data

**Figures**

- 3-1 Illustration of the Effect of Agglomeration on the Speed of Coal Combustion
- 3-2 Plot of Typical Nitrogen Content of Various Coals and Applicable Presumptive BART NO<sub>x</sub> Limits
- 3-3 Plot of Typical Oxygen Content of Various Coals and Applicable Presumptive BART NO<sub>x</sub> Limits
- 3-4 First Year Control Cost for NO<sub>x</sub> Air Pollution Control Options
- 3-5 First Year Control Cost for PM Air Pollution Control Options
- 4-1 Jim Bridger Source-specific Class I Areas to be Addressed
- 4-2 Surface and Upper Air Stations Used in the Jim Bridger BART Analysis
- 5-1 Least-cost Envelope Bridger Class I WA Days Reduction
- 5-2 Least-cost Envelope Bridger Class I WA 98<sup>th</sup> Percentile Reduction
- 5-3 Least-cost Envelope Fitzpatrick Class I WA Days Reduction
- 5-4 Least-cost Envelope Fitzpatrick Class I WA 98<sup>th</sup> Percentile Reduction
- 5-5 Least-cost Envelope Mt. Zirkel Class I WA Days Reduction
- 5-6 Least-cost Envelope Mt. Zirkel Class I WA 98<sup>th</sup> Percentile Reduction

**Appendices**

- A Economic Analysis
- B 2006 Wyoming BART Protocol

## **Acronyms and Abbreviations**

---

BACT	Best Available Control Technology
BART	Best Available Retrofit Technology
CALDESK	Program to Display Data and Results
CALMET	Meteorological Data Preprocessing Program for CALPUFF
CALPOST	Post-Processing Program for Calculating Visibility Impacts
CALPUFF	Gaussian Puff Dispersion Model
COHPAC	Compact Hybrid Particulate Collector
°C	Degrees Celsius
°F	Degrees Fahrenheit
dV	Deciview
ΔV	Delta Deciview, Change in Deciview
DEQ	Department of Environmental Quality
ESP	Electrostatic Precipitator
EPA	United States Environmental Protection Agency
Fuel NO <sub>x</sub>	Oxidation of Fuel Bound Oxides of Nitrogen
FGC	Flue Gas Conditioning
FGD	Flue Gas Desulfurization
f(RH)	Relative Humidity Factors
ID	Internal Diameter or Induced Draft
kW	Kilowatts
kW-Hr	Kilowatt-Hour
LAER	Lowest Achievable Emission Rate
lb	Pound(s)
LNB	Low-NO <sub>x</sub> Burner
LOI	Loss on Ignition
MMBtu	Million British Thermal Units
MM5	Mesoscale Meteorological Model, Version 5
MW	Megawatts
N <sub>2</sub>	Nitrogen
NO	Nitric Oxide
NO <sub>x</sub>	Nitrogen Oxides
NWS	National Weather Service

ACRONYMS AND ABBREVIATIONS (CONTINUED)

OFA	Over-fire Air
PM <sub>10</sub>	Particulate Matter Less than 10 Micrometers in Aerodynamic Diameter
PRB	Powder River Basin
ROFA	Rotating Opposed Fire Air
S&L	Sargent & Lundy
SCR	Selective catalytic Reduction System
SIP	State Implementation Plan
SNCR	Selective Non-Catalytic Reduction System
SO <sub>2</sub>	Sulfur Dioxide
SO <sub>3</sub>	Sulfur Trioxide
Thermal NO <sub>x</sub>	High Temperature Fixation of Atmospheric Nitrogen in Combustion Air
USGS	U.S. Geological Survey
WA	Wilderness Area
WDEQ-AQD	Wyoming Department of Environmental Quality—Air Quality Division

## 1.0 Introduction

---

Best Available Retrofit Technology (BART) guidelines were established as a result of United States Environmental Protection Agency (EPA) regulations intended to reduce the occurrence of regional haze in national parks and other Class I protected air quality areas in the United States (40 CFR Part 51). These guidelines provide guidance for states when determining which facilities must install additional controls, and the type of controls that must be used. Facilities eligible for BART installation were built between 1962 and 1977, and have the potential to emit more than 250 tons per year of visibility-impairing pollutants.

The Wyoming Department of Environmental Quality (WDEQ) BART regulations state that each source subject to BART must submit a BART application for a construction permit by December 15, 2006. PacifiCorp received an extension from the WDEQ to submit the BART report for Jim Bridger Unit 4 (hereafter referred to as Jim Bridger 4) by January 12, 2007. The BART Report that was submitted to WDEQ in January 2007 included a BART analysis, and a proposal and justification for BART at the source. This revised report—submitted in October 2007—incorporates editorial revisions since the January 2007 version.

The State of Wyoming has identified those eligible in-state facilities that are required to reduce emissions under BART, and will set BART emissions limits for those facilities. This information will be included in the State of Wyoming State Implementation Plan (SIP), which the State has estimated will be formally submitted to the EPA by early 2008. The EPA BART guidelines also state that the BART emission limits must be fully implemented within 5 years of EPA's approval of the SIP.

Five elements related to BART address the issue of emissions for the identified facilities:

- Any existing pollution control technology in use at the source
- The cost of the controls
- The remaining useful life of the source
- The energy and non-air quality environmental impacts of compliance
- The degree of improvement in visibility that may reasonably be anticipated from the use of such technology

This report documents the BART analysis that was performed on Jim Bridger 4 by CH2M HILL for PacifiCorp. The analysis was performed for the pollutants nitrogen oxides, ( $\text{NO}_x$ ), sulfur dioxide ( $\text{SO}_2$ ), and particulate matter less than 10 micrometers in aerodynamic diameter ( $\text{PM}_{10}$ ), because they are the primary criteria pollutants that affect visibility.

Section 2 of this report provides a description of the present unit operation, including a discussion of coal sources and characteristics. The BART Engineering Analysis is provided in Section 3. Section 4 provides the methodology and results of the BART Modeling Analysis, followed by recommendations in Section 5 and references in Section 6. Appendices provide more detail on the economic analysis and the 2006 Wyoming BART Protocol.

## 2.0 Present Unit Operation

---

The Jim Bridger Station consists of four units with a total generating capacity of 2,120 megawatts (MW). Jim Bridger 4 is a nominal 530 net-MW unit located approximately 35 miles northeast of Rock Springs, Wyoming. Unit 4 is equipped with a tangentially-fired pulverized coal boiler with low NO<sub>x</sub> burners (LNBs) manufactured by Combustion Engineering. The unit was constructed with a Flakt wire frame electrostatic precipitator (ESP). The unit contains a Babcock & Wilcox wet sodium flue gas desulfurization (FGD) system with three absorber towers installed in 1982. An Emerson Ovation distributed control system was installed in 2004.

Jim Bridger 4 was placed in service in 1979. Its current economic depreciation life is through 2040; however, this analysis is based on a 20-year life for BART control technologies. Assuming a BART implementation date of 2014, this will result in an approximate remaining useful life for Jim Bridger 4 of 20 years from the installation date of any new or modified BART-related equipment. This report does not attempt to quantify any additional life extension costs needed to allow the unit and these control devices at Jim Bridger 4 to operate until 2040.

Table 2-1 lists additional unit information and study assumptions for this analysis.

The BART-presumptive NO<sub>x</sub> limit for tangential-fired boilers burning sub-bituminous coal is 0.15 lb per MMBtu and the BART-presumptive NO<sub>x</sub> limit for burning bituminous coal is 0.28 lb per MMBtu. The main sources of coal burned at Jim Bridger 4 are the Bridger Mine and secondarily the Black Butte Mine and Leucite Hills Mine. These coals are ranked as sub-bituminous, but are closer in characteristics to bituminous coal in many of the parameters influencing NO<sub>x</sub> formation. These coals have higher nitrogen content than coals from the Powder River Basin (PRB), which represent the bulk of sub-bituminous coal use in the U.S. This BART analysis has considered the higher nitrogen content and different combustion characteristics of PRB coals as compared to those coals used at Jim Bridger 4, and has evaluated the effect of these qualities on NO<sub>x</sub> formation and achievable emission rates. Coal sources and characteristics are summarized in Table 2-2. The primary source of coal will be the Bridger Underground Mine, and data on coal from this source were used in the modeling analysis. For the coal analysis that is presented in Section 3.2.1, the data from all the coal sources were used.

**TABLE 2-1**  
**Unit Operation and Study Assumptions**  
*Jim Bridger 4*

<b>General Plant Data</b>	
Site Elevation (feet above mean sea level)	6669
Stack Height (feet)	500
Stack Exit Inside Diameter (feet) and Exit Area (square feet)	31 / 755
Stack Exit Temperature (degrees Fahrenheit)	120
Stack Exit Velocity (feet per second)	42.4
Stack Flow (actual cubic feet per minute)	1,920,610
Latitude deg: min : sec	41:44:20.82 north
Longitude deg: min : sec	108:47:15.17 west
Annual Unit Capacity Factor (percentage)	90
Net Unit Output (megawatts)	530
Net Unit Heat Rate (British thermal units [Btu] per kilowatt-hour)(100% load)	10,400 (as measured by fuel throughout)
Boiler Heat Input (million Btu [MMBtu] per hour)(100% load)	6,000 (as measured by CEM)
Type of Boiler	Tangentially fired
Boiler Fuel	Coal
Coal Sources	Bridger Mine, Black Butte Mine, Leucite Hills Mine
Coal Heating Value (Btu per pound)*	9,660
Coal Sulfur Content (wt. %) <sup>(a)</sup>	0.58
Coal Ash Content (wt. %) <sup>(a)</sup>	10.3
Coal Moisture Content (wt. %) <sup>(a)</sup>	19.3
Coal Nitrogen Content (wt. %) <sup>(a)</sup>	0.98
Current NO <sub>x</sub> Controls	Low-NO <sub>x</sub> burners
NO <sub>x</sub> Emission Rate (pound per MMBtu)	0.45
Current Sulfur Dioxide Controls	Sodium based wet scrubber
Sulfur Dioxide Emission Rate (pound per MMBtu)	0.167
Current PM <sub>10</sub> Controls <sup>(b)</sup>	Electrostatic Precipitator
PM <sub>10</sub> Emission Rate (pound per MMBtu) <sup>(c)</sup>	0.030

**NOTES:**

(a) Coal characteristics based on Bridger Underground Mine (primary coal source)

(b) PM<sub>10</sub> refers to particulate matter less than 10 micrometers in aerodynamic diameter(c) Based on maximum historic emission rate from 1999 – 2001, prior to installation of the SO<sub>3</sub> injection system.

**TABLE 2-2**  
**Coal Sources and Characteristics**  
*Jim Bridger 4*

										Ultimate Analysis (% dry basis)				
										Hydrogen	Carbon	Sulfur	Nitrogen	Oxygen
Mines	Moisture (%)	Ash (%)	Volatile Matter (%)	Fixed Carbon (%)	British thermal units per pound (Btu/lb)	Sulfur (%)	Moisture and Ash Free (Btu/lb)	Hydrogen	Carbon	Sulfur	Nitrogen	Oxygen	Ash	
<b>Bridger Mine Underground</b>	19.3	10.3	32.2	38.3	9660	0.58	13712	4.66	69.2	0.72	1.22	11.8	12.4	
Maximum	Not enough data yet to run statistical analysis for variability													
Minimum	Not enough data yet to run statistical analysis for variability													
<b>Bridger Mine Surface</b>	19.1	10.6	32.3	38.0	9390	0.57	13340	4.38	37.4	0.71	1.26	13.2	13.0	
Maximum	20.5	12.5	35.5	41.9	9800	0.72	13500	4.69	4.0	0.90	1.43	14.8	15.8	
Minimum	17.5	9.0	31.0	36.0	9000	0.49	13100	4.00	64.3	0.60	1.14	11.7	11.2	
<b>Bridger Mine Highwall</b>	18.0	9.5	33.0	39.5	9700	0.58	13500	No samples of separate highwall coal						
Maximum	Not enough data yet to run statistical analysis for variability													
Minimum	Not enough data yet to run statistical analysis for variability													
<b>Black Butte Mine</b>	20.0	9.2	33.3	35.6	9450	0.45	13330	4.43	68.7	0.56	1.47	13.4	11.5	
Maximum	21.1	10.8	35.4	41.9	10275	0.62	13500	4.66	70.5	0.78	1.69	14.8	13.6	
Minimum	18.0	7.6	29.9	36.8	9180	0.33	13140	4.21	66.1	0.41	1.25	11.6	9.7	
<b>Leucite Hills Mine (through 2009)</b>	19.4	11.5	30.7	38.3	9080	0.64	13140	4.20	66.0	0.81	1.48	13.2	14.4	
Maximum	23.0	15.0	33.0	43.0	10250	0.90	13800	4.70	70.0	1.20	1.64	17.1	19.0	
Minimum	17.0	8.0	28.3	33.6	8000	0.40	12300	3.70	61.0	0.50	1.32	10.5	10.0	

## **3.0 BART Engineering Analysis**

---

This section presents the required BART engineering analysis.

### **3.1 Applicability**

In compliance with regional haze requirements, the State of Wyoming must prepare and submit visibility SIPs to the EPA for Class I areas. The State has estimated that the formal submittal of the SIPs will occur by early 2008. The first phase of the regional haze program is the implementation of BART emission controls on all BART eligible units, within 5 years after EPA approval of the SIP.

### **3.2 BART Process**

The specific steps in a BART engineering analysis are identified in the Code of Federal Regulations (CFR) at 40 CFR 51, Appendix Y, Section IV. The evaluation must include:

- The identification of available, technically feasible, retrofit control options
- Consideration of any pollution control equipment in use at the source (which affects the availability of options and their impacts)
- The costs of compliance with the control options
- The remaining useful life of the facility
- The energy and non-air quality environmental impacts of compliance
- The degree of visibility improvement that may reasonably be anticipated from the use of BART

The following steps are incorporated into the BART analysis:

- Step 1 – Identify All Available Retrofit Control Technologies
- Step 2 – Eliminate Technically Infeasible Options
  - The identification of available, technically feasible, retrofit control options
  - Consideration of any pollution control equipment in use at the source (which affects the applicability of options and their impacts)
- Step 3 – Evaluate Control Effectiveness of Remaining Control Technologies
- Step 4 – Evaluate Impacts and Document the Results
  - The costs of compliance with the control options
  - The remaining useful life of the facility
  - The energy and non-air quality environmental impacts of compliance

- Step 5 – Evaluate Visibility Impacts
  - The degree of visibility improvement that may reasonably be anticipated from the use of BART

To minimize costs in the BART analysis, consideration was made of any pollution control equipment in use at the source, the costs of compliance associated with the control options, and the energy and non-air quality environmental impacts of compliance using these existing control devices. In some cases, enhancing the performance of the existing control equipment was considered. Other scenarios with new control equipment were also developed.

Separate analyses have been conducted for NO<sub>x</sub>, SO<sub>2</sub>, and PM<sub>10</sub> emissions. All costs included in the BART analysis are in 2006 dollars, and costs have not been escalated to the assumed 2014 BART implementation date.

### 3.2.1 BART NO<sub>x</sub> Analysis

Nitrogen oxide formation in coal-fired boilers is a complex process that is dependent on a number of variables, including operating conditions, equipment design, and coal characteristics.

#### Formation of NO<sub>x</sub>

During coal combustion, NO<sub>x</sub> is formed in three different ways. The dominant source of NO<sub>x</sub> formation is the oxidation of fuel-bound nitrogen. During combustion, part of the fuel-bound nitrogen is released from the coal with the volatile matter, and part is retained in the solid portion (char). The nitrogen chemically bound in the coal is partially oxidized to nitrogen oxides (nitric oxide and nitrogen dioxide) and partially reduced to molecular nitrogen. A smaller part of NO<sub>x</sub> formation is due to high temperature fixation of atmospheric nitrogen in the combustion air. A very small amount of NO<sub>x</sub> is called prompt NO<sub>x</sub>. Prompt NO<sub>x</sub> results from an interaction of hydrocarbon radicals, nitrogen, and oxygen.

In a conventional pulverized coal burner, air is introduced with turbulence to promote good mixing of fuel and air, which provides stable combustion. However, not all of the oxygen in the air is used for combustion. Some of the oxygen combines with the fuel nitrogen to form NO<sub>x</sub>.

Coal characteristics directly and significantly affect NO<sub>x</sub> emissions from coal combustion. Coal ranking is a means of classifying coals according to their degree of metamorphism in the natural series, from lignite to sub-bituminous to bituminous and on to anthracite. Lower rank coals, such as the sub-bituminous coals from the PRB, produce lower NO<sub>x</sub> emissions than higher rank bituminous coals, due to their higher reactivity and lower nitrogen content. The fixed carbon to volatile matter ratio (fuel ratio), coal oxygen content, and rank are good relative indices of the reactivity of a coal. Lower rank coals release more organically bound nitrogen earlier in the combustion process than do higher rank bituminous coals. When used with LNBs, sub-bituminous coals create a longer time for the kinetics to promote more stable molecular nitrogen, and therefore result in lower NO<sub>x</sub> emissions.

Coals from the PRB are classified as sub-bituminous C and demonstrate the high reactivity and low NO<sub>x</sub> production characteristics described above. Based on data from the Energy Information Administration, PRB coals currently represent 88 percent of total U.S. sub-bituminous production and 73 percent of western coal production (Energy Information Administration, 2006). Most references to western coal and sub-bituminous coal infer PRB

origin and characteristics. Emissions standards differentiating between bituminous and sub-bituminous coals are presumed to use PRB coal as the basis for the sub-bituminous standards, due to its dominant market presence and unique characteristics.

There are a number of western coals that are classified as sub-bituminous, however, they border on being ranked as bituminous and do not display many of the qualities of PRB coals, including most of the low NO<sub>x</sub> forming characteristics. Coals from the Bridger, Black Butte, and Leucite Hills mines fall into this category.

As defined by the American Society for Testing and Materials, the only distinguishing characteristic that classifies the coals used at Jim Bridger 4 as sub-bituminous rather than bituminous—that is, they are “agglomerating” as compared to “non-agglomerating”. Agglomerating as applied to coal is “the property of softening when it is heated to above about 400 degrees Celsius (°C) in a non-oxidizing atmosphere, and then appearing as a coherent mass after cooling to room temperature.” Because the agglomerating property of coals is the result of particles transforming into a plastic or semi-liquid state when heated, it reflects a change in surface area of the particle. Thus, with the application of heat, agglomerating coals would tend to develop a non-porous surface, while the surface of non-agglomerating coals would become even more porous with combustion. As shown by Figure 3-1, the increased porosity provides more particle surface area, resulting in more favorable combustion conditions. This non-agglomerating property assists in making sub-bituminous coals more amenable to controlling NO<sub>x</sub>, by allowing less air to be introduced during the initial ignition portion of the combustion process. The coals from the Bridger, Black Butte, and Leucite Hills mines just barely fall into the category of non-agglomerating coals. While each of these coals is considered non-agglomerating, they either do not exhibit the properties of non-agglomerating coals or exhibit them to only a minor degree. The conditions during combustion of typical non-agglomerating coals that make it easier to control NO<sub>x</sub> emissions do not exist for the Bridger blends of coals.

**FIGURE 3-1**  
Illustration of the Effect of Agglomeration on the Speed of Coal Combustion  
Jim Bridger 4




Table 3-1 shows key characteristics of a typical PRB coal compared to coals from the Bridger Mine, Black Butte, and Leucite Hills, as well as Twentymile, which is a representative western bituminous coal.

TABLE 3-1  
Coal Characteristics Comparison  
*Jim Bridger 4*

Parameter	Typical PRB	Bridger Mine	Black Butte	Leucite Hills	Twentymile
Nitrogen (% dry)	1.10	1.26	1.47	1.48	1.85
Oxygen (% dry)	16.2	13.2	13.4	13.2	7.19
Coal rank	Sub C	Sub B	Sub B	Sub B	Bitum. high volatility B

As shown in Table 3-1, although Bridger, Black Butte, and Leucite Hills are classified as sub-bituminous, they all exhibit higher nitrogen content and lower oxygen content than the PRB coal. The higher nitrogen content is an indication that more nitrogen is available to the combustion process and higher NO<sub>x</sub> emissions are likely. Oxygen content can be correlated to the reactivity of the coal, with more reactive coals generally containing higher levels of oxygen. More reactive coals tend to produce lower NO<sub>x</sub> emissions, and they are also more conducive to reduction of NO<sub>x</sub> emissions through the use of combustion control measures, such as LNBs and over-fire air (OFA). These characteristics indicate that higher NO<sub>x</sub> formation is likely with coal from the Bridger, Black Butte, and Leucite Hills mines, rather than with PRB coal. The Bridger, Black Butte, and Leucite Hills coals all contain quality characteristics that fall between a typical PRB coal and Twentymile. Twentymile is a clearly bituminous coal that produces higher NO<sub>x</sub>, as has been demonstrated at power plants burning this fuel.


Figures 3-2 and 3-3 graphically illustrate the relationship of nitrogen and oxygen content to the BART-presumptive NO<sub>x</sub> limits for the coals listed in Table 3-1. Each chart identifies the presumptive BART limit associated with a typical bituminous and sub-bituminous coal, and demonstrates how the Jim Bridger coal falls between these two general coal classifications.

The Bridger blend data point represents a combination of coals from the Bridger Mine, Black Butte, and Leucite Hills that has been used at Jim Bridger 4, and indicates the average NO<sub>x</sub> emission rate achieved during the years 2003 through 2005. The Jim Bridger 2 data point consists of the same blend of coals as Jim Bridger 4, and represents the NO<sub>x</sub> emission rate achieved after installation of Alstom's current state of the art TFS2000 LNB and OFA system. The long-term sustainable emission rate for this system is expected to be 0.24 lb per MMBtu. All four units at Jim Bridger consist of identical boilers; and while there may be some differences in performance among them, installation of the TFS2000 firing system at Jim Bridger 4 would likely result in performance and NO<sub>x</sub> emission rates comparable to those at Jim Bridger 2.


Figures 3-2 and 3-3 both demonstrate that for the Jim Bridger units with the TFS2000 low-NO<sub>x</sub> emission system installed and burning a combination of the Bridger, Black Butte, and Leucite Hill coals, the likely NO<sub>x</sub> emission rate will be closer to the bituminous end (0.28) of the BART-presumptive NO<sub>x</sub> limit range, rather than the BART-presumptive NO<sub>x</sub> limit of 0.15 lb

per MMBtu for sub-bituminous coal. All these factors are consistent with the observed sustainable rate of 0.24 lb per MMBtu.

**FIGURE 3-2**  
Plot of Typical Nitrogen Content of Various Coals and Applicable Presumptive BART NO<sub>x</sub> Limits  
*Jim Bridger 4*



**FIGURE 3-3**  
Plot of Typical Oxygen Content of Various Coals and Applicable Presumptive BART NO<sub>x</sub> Limits  
*Jim Bridger 4*



Coal quality characteristics also impact the design and operation of the boiler and associated auxiliary equipment. Minor changes in quality can sometimes be accommodated through operational adjustments or changes to equipment. It is important to note, however, that consistent variations in quality or assumptions of "average" quality for performance projections can be problematic. This is particularly troublesome when dealing with performance issues that are very sensitive to both coal quality and combustion conditions, such as NO<sub>x</sub> formation. There is significant variability in the quality of coals burned at Jim Bridger 4. In addition to burning coal from Black Butte and Leucite Hills, Jim Bridger 4 burns coal supplied from the Bridger Mine consisting of three sources: underground, surface, and highwall operations. Each of these coal sources has different quality characteristics, as well as inherent variability in composition of the coal within the mine.

Several of the coal quality characteristics and their effect on NO<sub>x</sub> formation have been previously discussed. There are some additional considerations that illustrate the complexity of achieving and maintaining consistent low NO<sub>x</sub> emissions with pulverized coal on a shorter term, such as a 30-day rolling average basis.

Good combustion is based on the "three Ts": time, temperature, and turbulence. These parameters, along with a "design" coal, are taken into consideration when designing a boiler and associated firing equipment such as fans, burners, and pulverizers. If a performance requirement such as NO<sub>x</sub> emission limits is subsequently changed, conflicts with and between other performance issues can result.

Jim Bridger 4 is located at an altitude of 6,669 feet above sea level. At this elevation, atmospheric pressure is lower (11.5 lbs per square inch) as compared with sea level pressure of 14.7 lbs per square inch. This lower pressure means that less oxygen is available for combustion for each volume of air. In order to provide adequate oxygen to meet the requirements for efficient combustion, larger volumes of air are required. When adjusting air flows and distribution to reduce NO<sub>x</sub> emissions, using LNBs and OFA, original boiler design restrictions again limit the modifications that can be made and still achieve satisfactory combustion performance.

Another significant factor in controlling NO<sub>x</sub> emissions is the fineness of the coal entering the burners. Fineness is influenced by the grindability index (Hardgrove) of the coal. Finer coal particles promote release of volatiles and assist char burnout as a result of more surface area exposed to air. NO<sub>x</sub> reduction with high volatile coals is improved with greater fineness and with proper air staging. The lower rank sub-bituminous coals such as PRB coals are quite friable and easy to grind. Coals with lower Hardgrove Grindability Index values, such as those used at Jim Bridger 4, are more difficult to grind and can contribute to higher NO<sub>x</sub> levels. In addition, coal fineness can deteriorate over time periods between pulverizer maintenance and service as pulverizer grinding surfaces wear.

In summary, when all the factors of agglomeration versus non-agglomeration, nitrogen and oxygen content of the coals, and the grindability index are taken into account, this analysis demonstrates that, for the coal used at Jim Bridger 4, the more applicable presumptive BART limit for NO<sub>x</sub> emissions is 0.28 lb per MMBtu. The BART analysis for NO<sub>x</sub> emissions from Jim Bridger 4 is further described below.

### Step 1: Identify All Available Retrofit Control Technologies

The first step of the BART process is to evaluate NO<sub>x</sub> control technologies with practical potential for application to Jim Bridger 4, including those control technologies identified as Best Available Control Technology (BACT) or lowest achievable emission rate (LAER) by permitting agencies across the United States. Broad-ranging information sources were reviewed in an effort to identify potentially applicable emission control technologies. NO<sub>x</sub> emissions at Jim Bridger 4 are currently controlled through good combustion practices and OFA.

The following potential NO<sub>x</sub> control technology options were considered:

- New/modified LNBs with advanced OFA
- Rotating opposed fire air (ROFA)
- LNB with OFA and conventional selective non-catalytic reduction (SNCR) system
- LNB with OFA and selective catalytic reduction (SCR) system

### Step 2: Eliminate Technically Infeasible Options

For Jim Bridger 4, a tangential-fired configuration burning sub-bituminous coal, technical feasibility will primarily be determined by physical constraints, boiler configuration, and the ability to achieve the regulatory presumptive limit of 0.28 lb per MMBtu. Jim Bridger 4 has an uncontrolled NO<sub>x</sub> emission rate of 0.45 lb per MMBtu.

For this BART analysis, information pertaining to LNBs, OFA, SNCR, and SCR were based on the *Multi-Pollutant Control Report* (Sargent and Lundy, 2002, hereafter referred to as the S&L Study). Updated cost estimates for SCR and SNCR were used (Sargent & Lundy, 2006). PacifiCorp provided additional emissions data and costs developed by boiler vendors for LNBs and OFA. Also, CH2M HILL solicited a proposal from Mobotec for their ROFA technology.

With SNCR, an amine-based reagent such as ammonia, or more commonly urea, is injected into the furnace within a temperature range of 1,600 degrees Fahrenheit (°F) to 2,100°F, where it reduces NO<sub>x</sub> to nitrogen and water. NO<sub>x</sub> reductions of up to 40 to 60 percent have been achieved, although 15 to 30 percent is more realistic for most applications. SNCR is typically applied on smaller units. Adequate reagent distribution in the furnaces of large units can be problematic.

Table 3-2 summarizes the control technology options evaluated in this BART analysis, along with projected NO<sub>x</sub> emission rates. All technologies can meet the applicable presumptive BART limit of 0.28 lb per MMBTU.

TABLE 3-2  
NO<sub>x</sub> Control Technology Projected Emission Rates  
*Jim Bridger 4*

Technology	Projected Emission Rate (pounds per million British thermal units)
Presumptive Best Available Retrofit Technology Limit	0.28
Low NO <sub>x</sub> Blower (LNB) with Over-Fire Air (OFA)	0.24
Rotating Opposed Fire Air	0.22
LNB with OFA and Selective Non-Catalytic Reduction System	0.20
LNB with OFA and Selective Catalytic Reduction System	0.07

### Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

Preliminary vendor proposals, such as those used to support portions of this BART analysis, may be technically feasible and provide expected or guaranteed emission rates; however, the proposals include inherent uncertainties. These proposals are usually prepared in a limited timeframe, may be based on incomplete information, may contain over-optimistic conclusions, and are non-binding. Therefore, emission rate values obtained in such preliminary proposals must be qualified, and it must be recognized that contractual guarantees are established only after more detailed analysis has been completed. The following subsections describe the control technologies and the control effectiveness evaluated in this BART analysis.

**New LNBs with OFA System.** The mechanism used to lower NO<sub>x</sub> with LNBs is to stage the combustion process and provide a fuel-rich condition initially; this is so oxygen needed for combustion is not diverted to combine with nitrogen and form NO<sub>x</sub>. Fuel-rich conditions favor the conversion of fuel nitrogen to N<sub>2</sub> instead of NO<sub>x</sub>. Additional air (or OFA) is then introduced downstream in a lower temperature zone to burn out the char.

Both LNBs and OFA are considered to be capital cost, combustion technology retrofits. For LNB retrofits to units configured with tangential-firing such as Jim Bridger 4, it is generally necessary to increase the burner spacing; this prevents interaction of the flames from adjacent burners and reduces burner zone heat flux. These modifications usually require boiler waterwall tube replacement.

Information provided to CH2M HILL by PacifiCorp—based on the S&L Study and data from boiler vendors—indicates that new LNB and OFA retrofit at Jim Bridger 4 would result in an expected NO<sub>x</sub> emission rate of 0.24 lb per MMBtu. PacifiCorp has indicated that this rate corresponds to a vendor guarantee, not a vendor prediction, and they believe that this emission rate can be sustained as an average between overhauls. This emission rate represents a significant reduction from the current NO<sub>x</sub> emission rate, and is below the more applicable presumptive NO<sub>x</sub> emission rate of 0.28 lb per MMBtu.

ROFA. Mobotec markets ROFA as an improved second generation OFA system. Mobotec states that "the flue gas volume of the furnace is set in rotation by asymmetrically placed air nozzles. Rotation is reported to prevent laminar flow, so that the entire volume of the furnace can be used more effectively for the combustion process. In addition, the swirling action reduces the maximum temperature of the flames and increases heat absorption. The combustion air is also mixed more effectively." A typical ROFA installation would have a booster fan(s) to supply the high velocity air to the ROFA boxes, and Mobotec would propose two 4,000 to 4,300 horsepower fans for Jim Bridger 4.

Mobotec proposes to achieve a NO<sub>x</sub> emission rate of 0.18 lb per MMBtu using ROFA technology. An operating margin of 0.04 lb per MMBtu was added to the expected rate due to Mobotec's limited ROFA experience with western sub-bituminous coals. Under the Mobotec proposal, which is primarily based on ROFA equipment, the operation of existing LNB and OFA ports would be analyzed. While a typical installation does not require modification to the existing LNB system and the existing OFA ports are not used, results of computational fluid dynamics modeling would determine the quantity and location of new ROFA ports. The Mobotec proposal includes bent tube assemblies for OFA port installation.

Mobotec would not provide installation services, because they believe that the Owner can more cost-effectively contract for these services. However, they would provide one onsite construction supervisor during installation and startup.

**SNCR.** Selective non-catalytic reduction is generally used to achieve modest NO<sub>x</sub> reductions on smaller units. With SNCR, an amine-based reagent such as ammonia—or more commonly urea—is injected into the furnace within a temperature range of 1,600°F to 2,100°F, where it reduces NO<sub>x</sub> to nitrogen and water. NO<sub>x</sub> reductions of up to 60 percent have been achieved, although 20 to 40 percent is more realistic for most applications.

Reagent utilization, which is a measure of the efficiency with which the reagent reduces NO<sub>x</sub>, can range from 20 to 60 percent, depending on the amount of reduction, unit size, operating conditions, and allowable ammonia slip. With low reagent utilization, low temperatures, or inadequate mixing, ammonia slip occurs, allowing unreacted ammonia to create problems downstream. The ammonia may render fly ash unsaleable, react with sulfur to foul heat exchange surfaces, and/or create a visible stack plume. Reagent utilization can have a significant impact on economics, with higher levels of NO<sub>x</sub> reduction generally resulting in lower reagent utilization and higher operating cost.

Reductions from higher baseline concentrations (inlet NO<sub>x</sub>) are lower in cost per ton, but result in higher operating costs, due to greater reagent consumption. To reduce reagent costs, S&L has assumed that combustion modifications including LNBs and advanced OFA, capable of achieving a projected NO<sub>x</sub> emission rate of 0.24 lb per MMBtu. At a further reduction of 15 percent in NO<sub>x</sub> emission rates for SNCR would result in a projected emission rate of 0.20 lb per MMBtu.

**SCR.** SCR works on the same chemical principle as SNCR, but SCR uses a catalyst to promote the chemical reaction. Ammonia is injected into the flue-gas stream, where it reduces NO<sub>x</sub> to nitrogen and water. Unlike the high temperatures required for SNCR, in SCR the reaction takes place on the surface of a vanadium/titanium-based catalyst at a temperature range between 580°F to 750°F. As a result of the catalyst, the SCR process is more efficient than SNCR and

results in lower NO<sub>x</sub> emissions. The most common type of SCR is the high-dust configuration, where the catalyst is located downstream from the boiler economizer and upstream of the air heater and any particulate control equipment. In this location, the SCR is exposed to the full concentration of fly ash in the flue gas that leaves the boiler. The high-dust configuration is assumed for Jim Bridger 4. In a full-scale SCR, the flue ducts are routed to a separate large reactor containing the catalyst. With in-duct SCR, the catalyst is located in the existing gas duct, which may be expanded in the area of the catalyst to reduce flue gas flow velocity and increase flue gas residence time. Due to the higher removal rate, a full-scale SCR was used as the basis for analysis at Jim Bridger 4.

S&L prepared the design conditions and cost estimates for SCR at Jim Bridger 4. As with SNCR, it is generally more cost effective to reduce NO<sub>x</sub> emission levels as much as possible through combustion modifications, in order to minimize the catalyst surface area and ammonia requirements of the SCR. The S&L design basis for LNB with OFA and SCR results in a projected NO<sub>x</sub> emission rate of 0.07 lb per MMBtu. Additional catalyst surface was included in the SCR design to accommodate the characteristics of the coal used at Jim Bridger 4.

**Level of Confidence for Vendor Post-Control Emissions Estimates.** To determine the level of NO<sub>x</sub> emissions needed to consistently achieve compliance with an established goal, a review of typical NO<sub>x</sub> emissions from coal-fired generating units was completed. As a result of this review, it was noted that NO<sub>x</sub> emissions can vary significantly around an average emissions level. Variations may result for many reasons, including coal characteristics, unit load, boiler operation including excess air, boiler slagging, burner equipment condition, coal mill fineness, and so forth.

The steps used for determining a level of confidence for the vendor expected values are as follows:

1. Establish expected NO<sub>x</sub> emissions value from vendor.
2. Evaluate vendor experience and historical basis for meeting expected values.
3. Review and evaluate unit physical and operational characteristics and restrictions. The fewer variations there are in operations, coal supply, etc., the more predictable and less variant the NO<sub>x</sub> emissions are.
4. For each technology expected value, there is a corresponding potential for actual NO<sub>x</sub> emissions to vary from this expected value. From the vendor information presented, along with anticipated unit operational data, an adjustment to the expected value can be made.

#### **Step 4: Evaluate Impacts and Document the Results**

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

**Energy Impacts.** Installation of LNBs and modification to the existing OFA systems are not expected to significantly impact the boiler efficiency or forced-draft fan power usage. Therefore, these technologies will not have energy impacts.

The Mobotec ROFA system would require installation and operation of two 4,000 to 4,300 horsepower ROFA fans (6,410 kilowatts [kW] total). The SNCR system would require approximately 530 kW of additional power.

SCR retrofit impacts the existing flue gas fan systems, due to the additional pressure drop associated with the catalyst, which is typically a 6- to 8-inch water gage increase. Total additional power requirements for SCR installation at Jim Bridger 4 are estimated at approximately 3,360 kW, based on the S&L Study.

**Environmental Impacts.** Mobotec has predicted that carbon monoxide (CO) emissions, and unburned carbon in the ash, commonly referred to as loss on ignition (LOI), would be the same or lower than previous levels for the ROFA system.

SNCR and SCR installation could impact the saleability and disposal of fly ash due to ammonia levels, and could potentially create a visible stack plume, which may negate other visibility improvements. Other environmental impacts involve the storage of ammonia, especially if anhydrous ammonia is used, and the transportation of the ammonia to the power plant site.

**Economic Impacts.** Costs and schedules for the LNBs, OFA, SNCR, and SCR were furnished to CH2M HILL by PacifiCorp, developed using S&L's internal proprietary database, and supplemented (as needed) by vendor-obtained price quotes. The relative accuracy of these cost estimates is stated by S&L to be in the range of plus or minus 20 percent. Cost for the ROFA system was obtained from Mobotec.

A comparison of the technologies on the basis of costs, design control efficiencies, and tons of NO<sub>x</sub> removed is summarized in Table 3-3, and the first year control costs are presented in Figure 3-4. The complete economic analysis is contained in Appendix A.

**Preliminary BART Selection.** CH2M HILL recommends selection of LNBs with OFA as BART for Jim Bridger 4 based on its significant reduction in NO<sub>x</sub> emissions, reasonable control-cost, and no additional power requirements or environmental impacts. LNB with OFA does not meet the EPA-presumptive limit of 0.15 lb per MMBtu for sub-bituminous coal, but it does meet an emission rate that falls between the presumptive limit of 0.28 lb per MMBtu for bituminous coal and the limit of 0.15 lb per MMBtu for sub-bituminous coal. As discussed in the section on coal quality, the recommended technology and the achieved emission rate are deemed appropriate as BART for NO<sub>x</sub> emissions from the coals combusted at Jim Bridger 4.


#### Step 5: Evaluate Visibility Impacts

Please see Section 4, BART Modeling Analysis.

**TABLE 3-3**  
**NO<sub>x</sub> Control Cost Comparison**  
*Jim Bridger 4*

Factor	Low NO <sub>x</sub> Blower (LNB) with Over- Fire Air (OFA)	Rotating Opposed Fire Air	LNB with OFA & Selective Non- Catalytic Reduction System	LNB with OFA Selective Catalytic Reduction System
Total Installed Capital Costs	\$8.7 million	\$20.5 million	22.1 million	\$147.6 million
Total First Year Fixed & Variable Operation and Maintenance Costs	\$0.1 million	\$2.6 million	\$1.5 million	\$3.4 million
Total First Year Annualized Cost	\$0.9 million	\$4.6 million	\$3.6 million	\$17.4 million
Power Consumption (megawatts)	0	6.4	0.5	3.4
Annual Power Usage (1000 megawatt-hours per year)	0	50.6	4.2	26.5
Nitrogen Oxides Design Control Efficiency	46.7%	51.1%	55.6%	84.4%
Nitrogen Oxides Removed per Year (Tons)	4,967	5,440	5,913	8,987
First Year Average Control Cost (\$ per Ton of Nitrogen Oxides Removed)	\$181/ton	\$843/ton	\$613/ton	\$1,936/ton
Incremental Control Cost (\$ per Ton of Nitrogen Oxides Removed)	\$181/ton	\$7,797/ton	\$2,885/ton	\$4,479/ton

**FIGURE 3-4**  
First Year Control Cost for NO<sub>x</sub> Air Pollution Control Options  
*Jim Bridger 4*



### 3.2.2 BART SO<sub>2</sub> Analysis

Sulfur dioxide forms in the boiler during the combustion process, and is primarily dependent on coal sulfur content. The BART analysis for SO<sub>2</sub> emissions on Jim Bridger 4 is described below.

#### Step 1: Identify All Available Retrofit Control Technologies

A broad range of information sources were reviewed, in an effort to identify potentially applicable emission control technologies for SO<sub>2</sub> at Jim Bridger 4. This included control technologies identified as BACT or LAER by permitting agencies across the United States.

The following potential SO<sub>2</sub> control technology options were considered:

- Optimize current operation of existing wet sodium FGD system
- Upgrade wet sodium FGD system to meet SO<sub>2</sub> emission rate of 0.10 lb per MMBtu
- New dry FGD system

#### Step 2: Eliminate Technically Infeasible Options

Technical feasibility will primarily be based on the regulatory presumptive limit (used as a guideline) of 95 percent reduction in SO<sub>2</sub> emissions, or 0.15 lb per MMBtu. Based on the coal that Jim Bridger 4 currently burns, the unit would be required to achieve an 87.5 percent SO<sub>2</sub> removal efficiency to meet the presumptive limit of 0.15 lb per MMBtu.

Table 3-4 summarizes the control technology options evaluated in this BART analysis, along with projected SO<sub>2</sub> emission rates. Only one technology option can meet the applicable presumptive BART limit of 0.15 lb per MMBtu.

**TABLE 3-4**  
SO<sub>2</sub> Control Technology Emission Rates  
*Jim Bridger 4*

Technology	Projected Emission Rate (pounds per million British thermal units)
Presumptive Best Available Retrofit Technology Limit	0.15
Upgrade Existing Wet Sodium System	0.10
Optimize Existing Wet Sodium System	0.17
New Dry Flue Gas Desulfurization System	0.21

**Wet Sodium FGD System** Wet sodium FGD systems operate by treating the flue gas in large scrubber vessels with a soda ash solution. The scrubber mixes the flue gas and alkaline reagent using a series of spray nozzles to distribute the reagent across the scrubber vessel. The sodium in the reagent reacts with the SO<sub>2</sub> in the flue gas to form sodium sulfite and sodium bisulfite, which are removed from the scrubber and disposed.

The wet sodium FGD system at Jim Bridger 4 currently achieves approximately 86 percent SO<sub>2</sub> removal to achieve an SO<sub>2</sub> outlet emission rate of 0.17 lb per MMBtu. Upgrading the wet FGD system would achieve an SO<sub>2</sub> outlet emission rate of 0.10 lb per MMBtu (91.7 percent SO<sub>2</sub>

removal) by closing the bypass damper to eliminate routine bypass flue gas flow used to reheat the treated flue gas from the scrubber, relocating the opacity monitor, adding new fans, adding a stack liner and drains for wet operation, and using a refined soda ash reagent. It is considered to be technically infeasible for the present wet FGD system to achieve 95 percent SO<sub>2</sub> removal (0.06 lb per MMBtu) on a continuous basis since this high level of removal must be incorporated into the original design of the scrubber.

The wet FGD system is achieving an outlet SO<sub>2</sub> emission rate of 0.17 lb per MMBtu. It is not expected that any significant additional SO<sub>2</sub> reduction would occur with optimization of the wet sodium scrubbing FGD system. This option would not meet the presumptive limit of 0.15 lb per MMBtu. Therefore, this option is eliminated as technically infeasible for this analysis. An upgraded wet sodium scrubbing FGD system is projected to achieve an outlet emission rate of 0.10 lb per MMBtu (91.7 percent SO<sub>2</sub> removal), which would meet the presumptive limit of 0.15 lb per MMBtu for Jim Bridger 4.

**New Dry FGD System.** The lime spray dryer typically injects lime slurry in the top of the absorber vessel with a rapidly rotating atomizer wheel. The rapid speed of the atomizer wheel causes the lime slurry to separate into very fine droplets that intermix with the flue gas. The SO<sub>2</sub> in the flue gas reacts with the calcium in the lime slurry to form dry calcium sulfate particles. At Jim Bridger 4 this dry particulate matter would be captured downstream in the existing ESP, along with the fly ash. A lime spray dryer system typically produces a dry waste product suitable for landfill disposal.

The dry FGD system with the existing ESP is projected to achieve 82.5 percent SO<sub>2</sub> removal at Jim Bridger 4. This would result in a controlled SO<sub>2</sub> emission rate of 0.21 lb per MMBtu, based on an uncontrolled SO<sub>2</sub> emission rate of 1.20 lb per MMBtu. Therefore, this option cannot meet the presumptive limit of 0.15 lb per MMBtu, and is eliminated from further analysis as technically infeasible.

#### **Step 3: Evaluate Control Effectiveness of Remaining Control Technologies**

When evaluating the control effectiveness of SO<sub>2</sub> reduction technologies, each option can be compared against benchmarks of performance. One such benchmark is the presumptive BART emission limit because Jim Bridger 4 is required to meet this limit. As indicated previously, the presumptive limit for SO<sub>2</sub> on a BART-eligible coal burning unit is 95 percent removal, or 0.15 lb per MMBtu.

The projected emission rate for an upgraded wet sodium FGD system for Jim Bridger 4 would be 0.10 lb per MMBtu. This option would meet the presumptive SO<sub>2</sub> limit of 0.15 lb per MMBtu.

#### **Step 4: Evaluate Impacts and Document the Results**

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

**Energy Impacts.** Upgrading the existing wet sodium FGD system would require an additional 520 kW of power:

**Environmental Impacts.** There will be incremental additions to scrubber waste disposal and makeup water requirements.

**Economic Impacts.** A summary of the costs and amount of SO<sub>2</sub> removed for the upgraded wet sodium FGD system is provided in Table 3-5. The complete economic analysis is contained in Appendix A.

TABLE 3-5  
Sulfur Dioxide Control Cost Comparison (Incremental to Existing Flue Gas Desulfurization System)  
*Jim Bridger 4*

Factor	Upgraded Wet Flue Gas Desulfurization
Total Installed Capital Costs	\$5.8 Million
Total First Year Fixed & Variable O&M Costs	\$0.7 Million
Total First Year Annualized Cost	\$1.2 Million
Additional Power Consumption (megawatts)	0.5
Additional Annual Power Usage (1000 megawatt-hours per year)	4.2
Incremental Sulfur Dioxide Design Control Efficiency	40.1% (91.7% based on Uncontrolled Sulfur Dioxide)
Incremental Tons Sulfur Dioxide Removed per Year	1,585
First Year Average Control Cost (\$ per Ton of Sulfur Dioxide Removed)	761
Incremental Control Cost (\$ per Ton of Sulfur Dioxide Removed)	761

**Preliminary BART Selection.** CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 4 based on its significant reduction in SO<sub>2</sub> emissions (meeting presumptive limit of 0.15 lb per MMBtu), reasonable control costs, and the advantages of minimal additional power requirements, and environmental impacts.

#### Step 5: Evaluate Visibility Impacts

Please see Section 4, BART Modeling Analysis.

#### 3.2.3 BART PM<sub>10</sub> Analysis

Jim Bridger 4 is currently equipped with an ESP. ESPs remove particulate matter from the flue gas stream by charging fly ash particles with a very high direct current voltage, and attracting these charged particles to grounded collection plates. A layer of collected particulate matter forms on the collecting plates and is removed by periodically rapping the plates. The collected ash particles drop into hoppers below the precipitator and are removed periodically by the fly ash-handling system. Historically, the ESP at Jim Bridger 4 has controlled PM<sub>10</sub> emissions to levels below 0.030 lb per MMBtu.

The BART analysis for PM<sub>10</sub> emissions at Jim Bridger 4 is described below. For the modeling analysis in Section 4, PM<sub>10</sub> was used as an indicator for particulate matter, and PM<sub>10</sub> includes PM<sub>2.5</sub> as a subset.

### Step 1: Identify All Available Retrofit Control Technologies

Two retrofit control technologies have been identified for additional particulate matter control:

- Flue gas conditioning (FGC)
- Polishing fabric filter (baghouse) downstream of existing ESP

Another available control technology is replacing the existing ESP with a new fabric filter. However, because the environmental benefits that would be achieved by a replacement fabric filter are also achieved by installing a polishing fabric filter downstream of the existing ESP at lower costs, installation of a full fabric filter was not considered in the analysis.

### Step 2: Eliminate Technically Infeasible Options

**Flue Gas Conditioning.** If the fly ash from coal has high resistivity, such as fly ash from sub-bituminous coal, the ash is not collected effectively in an ESP. This is because the high resistivity makes the particles less willing to accept an electrical charge. Adding FGC, which is typically accomplished by injection of sulfur trioxide ( $\text{SO}_3$ ), will lower the resistivity of the particles so that they will accept more charge and allow the ESP to collect the ash more effectively. FGC systems can account for large improvements in collection efficiency for small ESPs.

**Polishing Fabric Filter.** A polishing fabric filter could be added downstream of the existing ESP at Jim Bridger 4. One such technology is licensed by the Electric Power Research Institute, and referred to as a Compact Hybrid Particulate Collector (COHPAC). The COHPAC collects the ash that is not collected by the ESP, thus acting as a polishing device. The ESP needs to be kept in service for the COHPAC fabric filter to operate effectively.

The COHPAC fabric filter is about one-half to two-thirds the size of a full size fabric filter, because the COHPAC has a higher air-to-cloth ratio (7 to 9:1), compared to a full size pulse jet fabric filter (3.5 to 4.1).

### Step 3: Evaluate Control Effectiveness of Remaining Control Technologies

The existing ESP at Jim Bridger 4 is achieving a controlled particulate matter emission rate of 0.030 lb per MMBtu. Using FGC upstream of the existing ESP is projected to not reduce particulate matter emissions, but it would help maintain long term operation at an emission level of 0.030 lb per MMBtu. Adding a COHPAC fabric filter downstream of the existing ESP is projected to reduce particulate matter emissions to approximately 0.015 lb per MMBtu.

The  $\text{PM}_{10}$  control technology emission rates are summarized in Table 3-6.

TABLE 3-6  
 $\text{PM}_{10}$  Control Technology Emission Rates  
*Jim Bridger 4*

Control Technology	Short-Term Expected $\text{PM}_{10}$ Emission Rate (pounds per million British thermal units)
Flue Gas Conditioning	0.030
Polishing Fabric Filter	0.015

#### Step 4: Evaluate Impacts and Document the Results

This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The remaining useful life of the plant is also considered during the evaluation.

**Energy Impacts.** Energy is required to overcome the additional pressure drop from the COHPAC fabric filter and associated ductwork. Therefore, a COHPAC retrofit will require an induced draft (ID) fan upgrade and upgrade of the auxiliary power supply system. A COHPAC fabric filter at Jim Bridger 4 would require approximately 3.4 MW of power, equating to an annual power usage of approximately 26.7 million kilowatt-hours (kW-Hr). There is only a small power requirement of approximately 50 kW associated with FGC.

**Environmental Impacts.** There are no negative environmental impacts from the addition of a COHPAC polishing fabric filter or flue gas conditioning system.

**Economic Impacts.** A summary of the costs and particulate matter removed for COHPAC and FGCs are recorded in Table 3-7, and the first-year control costs for FGC and fabric filters are shown in Figure 3-5. The complete economic analysis is contained in Appendix A.

TABLE 3-7  
PM<sub>10</sub> Control Cost Comparison (Incremental to Existing ESP)  
Jim Bridger 4


Factor	Flue Gas Conditioning	Polishing Fabric Filter
Total Installed Capital Costs	\$0	\$48.4 million
Total First Year Fixed & Variable O&M Costs	\$0.2 million	\$1.8 million
Total First Year Annualized Cost	\$0.2 million	\$ 6.4 million
Additional Power Consumption (megawatts)	0.05	3.39
Additional Annual Power Usage (Million kilowatt-hours per year)	0.4	26.7
Incremental Particulate Matter Design Control Efficiency	0.0%	50.0%
Incremental Tons Particulate Matter Removed per Year	0	355
First Year Average Control Cost (\$ per Ton of Particulate Matter Removed)	N/A	17,946
Incremental Control Cost (\$ per Ton of Particulate Matter Removed)	N/A	17,452

**Preliminary BART Selection.** CH2M HILL recommends selection of FGC upstream of the existing ESP as BART for Jim Bridger 4 based on the significant reduction in particulate matter emissions, reasonable control costs, and advantages of minimal additional power requirements and no environmental impacts.

#### Step 5: Evaluate Visibility Impacts

Please see Section 4, BART Modeling Analysis.

FIGURE 3-5  
First Year Control Cost for PM Air Pollution Control Options  
*Jim Bridger 4*



## **4.0 BART Modeling Analysis**

---

### **4.1 Model Selection**

CH2M HILL used the CALPUFF modeling system to assess the visibility impacts of emissions from Jim Bridger 4 at nearby Class I areas. The Class I areas potentially affected are located more than 50 kilometers but less than 300 kilometers from the Jim Bridger 4 facility. The Class I areas include the following wilderness areas:

- Bridger Wilderness Area
- Fitzpatrick Wilderness Area
- Mt. Zirkel Wilderness Area

The CALPUFF modeling system includes the CALMET meteorological model, a Gaussian puff dispersion model (CALPUFF) with algorithms for chemical transformation and deposition, and a post processor capable of calculating concentrations, visibility impacts, and deposition (CALPOST). The CALPUFF modeling system was applied in a full, refined mode. The following version numbers of the various programs in the CALPUFF system were used by CH2M HILL:


- CALMET Version 5.53a, Level 040716
- CALPUFF Version 5.711a, Level 040716
- CALPOST Version 5.51, Level 030709.

### **4.2 CALMET Methodology**

#### **4.2.1 Dimensions of the Modeling Domain**


CH2M HILL used the CALMET model to generate a three-dimensional wind field and other meteorological parameters suitable for use by the CALPUFF model. A modeling domain was established to encompass the Jim Bridger 4 facility and allow for a 50-km buffer around the Class I areas that were within 300 km of the facility. Grid resolution was 4 km. Figure 4-1 shows the extent of the modeling domain. Except when specifically instructed otherwise by the Wyoming Department of Environmental Quality-Air Quality Division (WDEQ-AQD), CH2M HILL followed the methodology spelled out in the WDEQ-AQD BART Modeling Protocol, a copy of which is included in this report as Appendix B.

CH2M HILL used the Lambert Conformal Conic map projection for the analysis due to the large extent of the domain. The latitude of the projection origin and the longitude of the central meridian were chosen at the approximate center of the domain. Standard parallels were drawn to represent one-sixth and five-sixths of the north-south extent of the domain to minimize distortion in the north-south direction.



**Figure 4-1**  
**Jim Bridger Source-Specific**  
**Class I Areas to be Addressed**

SIG:\\SICBDRG\\PROJECTS\\HUNTERMAP\\FILESUM\_BRIDGER\_CLASSI.MXD 11/9/2006 MSLAYDEN



The default technical options listed in TRC Companies, Inc.'s (TRC) current example CALMET.inp file were used for CALMET. Vertical resolution of the wind field included ten layers, with vertical face heights as follows (in meters):

- 0, 20, 40, 100, 140, 320, 580, 1020, 1480, 2220, 3500

Other user-specified model options were set to values established by WDEQ-AQD, which appear in Table 3 of Appendix B. Table 4-1 lists the key user-specified options used for this analysis.

TABLE 4-1  
User-specified CALMET Options  
*Jim Bridger 4*

CALMET Input Parameter	Value
<b>CALMET Input Group 2</b>	
Map projection (PMAP)	Lambert Conformal
Grid spacing (DGRIDKM)	4
Number vertical layers (NZ)	10
Top of lowest layer (m)	20
Top of highest layer (m)	3500
<b>CALMET Input Group 4</b>	
Observation mode (NOOBS)	0
<b>CALMET Input Group 5</b>	
Prog. Wind data (IPROG)	14
(RMAX1)	30
(RMAX2)	50
Terrain influence (TERRAD)	15
(R1)	5
(R2)	25
<b>CALMET Input Group 6</b>	
Max mixing ht (ZIMAX)	3500

#### 4.2.2 CALMET Input Data

CH2M HILL ran the CALMET model to produce 3 years of analysis: 2001, 2002, and 2003. WDEQ-AQD provided 12-km resolution Mesoscale Meteorological Model, Version 5 (MM5) meteorological data fields that covered the entire modeling domain for each study year.

These three data sets were chosen because they are current and have been evaluated for quality. The MM5 data were used as input to CALMET as the "initial guess" wind field. The initial guess wind field was adjusted by CALMET for local terrain and land use effects to generate a

Step 1 wind field, and further refined using local surface observations to create a final Step 2 wind field.

Surface data for 2001 through 2003 were obtained from the National Climatic Data Center. CH2M HILL processed the data from the National Weather Service's Automated Surface Observing System (ASOS) network for all stations that are in the domain. The surface data were obtained in abbreviated DATSAV3 format. A conversion routine available from the TRC Web site was used to convert the DATSAV3 files to CD-144 format for input into the SMERGE preprocessor and CALMET.

Land use and terrain data were obtained from the U.S. Geological Survey (USGS). Land use data were obtained in Composite Theme Grid format from the USGS, and the Level I USGS land use categories were mapped into the 14 primary CALMET land use categories. Surface properties such as albedo, Bowen ratio, roughness length, and leaf area index were computed from the land use values. Terrain data were taken from USGS 1-degree Digital Elevation Model data, which primarily derive from USGS 1:250,000 scale topographic maps. Missing land use data were filled with values that were assumed appropriate for the missing area.

Precipitation data were obtained from the National Climatic Data Center. All available data in fixed-length, TD-3240 format were obtained for the modeling domain. The list of available stations that have collected complete data varies by year, but CH2M HILL processed all available stations/data within the domain for each year. Precipitation data were prepared with the PXTRACT/PMERGE processors in preparation for use within CALMET.

Upper-air data were prepared for the CALMET model with the READ62 preprocessor for the following stations:

- Denver, Colorado
- Salt Lake City, Utah
- Riverton, Wyoming
- Rapid City, South Dakota

Figure 4-2 shows the locations of surface and upper air stations within the MM5 modeling domain.




Figure 4-2  
Surface and Upper Air Stations Used in the  
Jim Bridger BART Analysis



SLC\ISCD\GIS\PROJECTS\HUNTER\MAPFILES\JIM\_BRIDGER\_ASOS.MXD 11/9/2006 MSLAYDEN

**CH2MHILL**

#### 4.2.3 Validation of CALMET Wind Field

CH2M HILL used the CALDESK data display and analysis system (v2.97, Enviromodeling Ltd.) to view plots of wind vectors and other meteorological parameters to evaluate the CALMET wind fields. The CALDESK displays were compared to observed weather conditions, as depicted in surface and upper-air weather maps (National Oceanic and Atmospheric Administration, 2006).

### 4.3 CALPUFF Modeling Approach

For the BART control technology visibility improvement modeling, CH2M HILL followed WDEQ-AQD guidance provided in the document titled *BART Air Modeling Protocol-Individual Source Visibility Assessments for BART Control Analyses* (September, 2006).

CH2M HILL drove the CALPUFF model with the meteorological output from CALMET over the modeling domain described earlier. The CALPUFF model was used to predict visibility impacts for the pre-control (baseline) scenario for comparison to the predicted impacts for post-control scenarios for Jim Bridger 4.

#### 4.3.1 Background Ozone and Ammonia

Hourly values of background ozone concentrations were used by CALPUFF for the calculation of SO<sub>2</sub> and NO<sub>x</sub> transformation with the MESOPUFF II chemical transformation scheme. CH2M HILL obtained hourly ozone data from the following stations located within the modeling domain for 2001, 2002, and 2003:

- Rocky Mountain National Park, Colorado
- Craters of the Moon National Park, Idaho
- Highland, Utah
- Thunder Basin National Grasslands, Wyoming
- Yellowstone National Park, Wyoming
- Centennial, Wyoming
- Pinedale, Wyoming

For periods of missing hourly ozone data, the chemical transformation relied on a monthly default value of 44 parts per billion. Background ammonia was set to 2 parts per billion. Both of these background values were taken from the guidance document (WDEQ-AQD, 2006).

#### 4.3.2 Stack Parameters

The stack parameters used for the baseline modeling reflect those that are in place under the current permit for Jim Bridger 4. Post-control stack parameters reflect the anticipated changes associated with installation of the control technology alternatives that are being evaluated. The maximum heat input rate of 6,000 MMBtu per hour was used to calculate a maximum emission rate. Measured velocities and stack flow rates were used in the modeling to represent a worst-case situation.

#### 4.3.3 Emission Rates

Pre-control emission rates for Dave Johnston 3 reflect peak 24-hour average emissions that may occur under the source's current permit. The emission rates reflect actual emissions under normal operating conditions, as described by the EPA in the *Regional Haze Regulations and Guidelines for Best Available Retrofit Technology Determinations; Final Rule* (40 CFR Part 51).

CH2M HILL used available continuous emission monitoring data to determine peak 24-hour emission rates. Data reflected operations from the most recent 3- to 5-year period, unless a more recent period was more representative. Allowable short-term (24-hour or shorter period) emissions or short-term emission limits were used if continuous emission monitoring data were not available.

Emissions were modeled for the following pollutants:

- SO<sub>2</sub>
- NO<sub>x</sub>
- Coarse particulate (PM<sub>2.5</sub><diameter<PM<sub>10</sub>)
- Fine particulate (diameter<PM<sub>2.5</sub>)
- Sulfates

Post-control emission rates reflect the effects of the emissions control scenario under consideration. Modeled pollutants were the same as those listed for the pre-control scenario.

#### 4.3.4 Post-control Scenarios

Four post-control modeling scenarios were developed to cover the range of effectiveness for the combination of the individual NO<sub>x</sub>, SO<sub>2</sub>, and PM control technologies being evaluated. The selection of each control device was made based on the engineering analyses performed in Section 3 for reasonable technologies that would meet or exceed the presumptive BART levels for each pollutant.

- **Scenario 1:** New LNB with OFA Modifications, upgraded wet FGD system and FGC for enhanced ESP performance. As indicated previously, this scenario represents CH2M HILL's preliminary BART recommendation.
- **Scenario 2:** New LNB with OFA modifications, upgraded wet FGD system and new polishing fabric filter
- **Scenario 3:** New LNB with OFA modifications and SCR, upgraded wet FGD system and FGC for enhanced ESP performance.
- **Scenario 4:** New LNB with OFA modifications and SCR, upgraded wet FGD system and new polishing fabric filter.

The ROFA option and LNB with OFA and SCR option for NO<sub>x</sub> control were not included in the modeling scenarios because their control effectiveness is between the LNB with OFA option and the SCR option. Modeling of NO<sub>x</sub>, SO<sub>2</sub>, and particulate matter controls alone was not performed because any final BART solution will include a combination of control technologies for NO<sub>x</sub>, SO<sub>2</sub>, and particulate matter.

Table 4-2 presents the stack parameters and emission rates used for the Jim Bridger 4 analysis for baseline and post-control modeling. In accordance with the WDEQ BART modeling protocol, elemental carbon stack emissions and organic aerosol emissions were not modeled.

#### 4.3.5 Modeling Process

The CALPUFF modeling for the control technology options for Jim Bridger 4 followed this sequence:

- Model pre-control (baseline) emissions
- Model preferred post-control scenario (if applicable)
- Determine degree of visibility improvement
- Model other control scenarios
- Determine degree of visibility improvement
- Factor visibility results into the BART "five-step" evaluation

#### 4.3.6 Receptor Grids

Discrete receptors for the CALPUFF modeling were placed at uniform receptor spacing along the boundary and in the interior of each area of concern. Class I area receptors were taken from the National Park Service database for Class I area modeling receptors. The TRC COORDS program was used to convert all latitude/longitude coordinates to Lambert Conformal Conic coordinates, including receptors, meteorological stations, and source locations.

TABLE 42  
BART Model Input Data  
Jim Bridger 4

	Baseline	Post-control Scenario 1	Post-control Scenario 2	Post-control Scenario 3	Post-control Scenario 4
<b>Model Input Data:</b>					
Sulfur Dioxide (SO <sub>2</sub> ) Stack Emissions: (pounds per hour [lb/hr]).	1,002	600	600	600	600
Nitrogen Oxide (NO <sub>x</sub> ) Stack Emissions (lb/hr)	2,700	1,440	1,440	420	420
PM <sub>10</sub> Stack Emissions (lb/hr)	180	180	90.0	180	90.0
Coarse Particulate (PM <sub>2.5</sub> diameter < PM <sub>10</sub> ) Stack Emissions (lb/hr) <sup>a</sup>	77.4	77.4	51.3	77.4	51.3
Fine Particulate (diameter < PM <sub>2.5</sub> ) Stack Emissions (lb/hr) <sup>b</sup>	103	103	38.7	103	38.7
Sulfuric Acid (H <sub>2</sub> SO <sub>4</sub> ) Stack Emissions (lb/hr).	55.2	55.2	55.2	94.8	94.8
H <sub>2</sub> SO <sub>4</sub> as Sulfate (SO <sub>4</sub> ) Stack Emissions (lb/hr)	54.1	54.1	54.1	92.9	92.9
Ammonium Sulfate ((NH <sub>4</sub> ) <sub>2</sub> SO <sub>4</sub> ) Stack Emissions (lb/hr)				7.02	7.02
(NH <sub>4</sub> ) <sub>2</sub> SO <sub>4</sub> as SO <sub>4</sub> Stack Emissions (lb/hr)				5.10	5.10
(NH <sub>4</sub> ) <sub>2</sub> SO <sub>4</sub> Stack Emissions (lb/hr)				12.2	12.2
(NH <sub>4</sub> ) <sub>2</sub> SO <sub>4</sub> as SO <sub>4</sub> Stack Emissions (lb/hr)				10.2	10.2
Total Sulfate (SO <sub>4</sub> ) (lb/hr)	54.1	54.1	54.1	108	108
<b>Stack Conditions:</b>					
Stack Height (meters)	152	152	152	152	152
Stack Exit Diameter (meters)	9.45	9.45	9.45	9.45	9.45
Stack Exit Temperature (Kelvin)	322	322	322	322	322
Stack Exit Velocity (meters per second)	12.9	12.9	12.9	12.9	12.9

NOTES: Scenarios 2, 3, and 4 were not remodeled at the lower, correct velocity of 42.4 feet per second due to lack of time and the fact that the conclusions to select Scenario 1 would not have changed.

<sup>a</sup>Based on AP-42, Table 1-16, the coarse particulates are counted as a percentage of PM<sub>10</sub>. This equates to 43 percent ESP and 57 percent baghouse.

<sup>b</sup>Based on AP-42, Table 1-16, the fine particulates are counted as a percentage of PM<sub>10</sub>. This equates to 57 percent ESP and 43 percent baghouse.

Total Sulfate (SO<sub>4</sub>) (lb/hr) = H<sub>2</sub>SO<sub>4</sub> as Sulfate (SO<sub>4</sub>) Stack Emissions (lb/hr) + (NH<sub>4</sub>)<sub>2</sub>SO<sub>4</sub> as SO<sub>4</sub> Stack Emissions (lb/hr)

## 4.4 CALPOST

The CALPOST processor was used to determine 24-hour average visibility results with output specified in deciview (dV) units. Calculations of light extinction were made for each pollutant modeled. The sum of all extinction values were used to calculate the delta-dV ( $\Delta dV$ ) change relative to natural background. Default light extinction coefficients for each pollutant, as follows, were used.

- |   |      |
|---|------|
| • Ammonium sulfate                              | 3.0  |
| • Ammonium nitrate                              | 3.0  |
| • Particulate matter coarse (PM <sub>10</sub> ) | 0.6  |
| • Particulate matter fine (PM <sub>2.5</sub> )  | 1.0  |
| • Organic carbon                                | 4.0  |
| • Elemental carbon                              | 10.0 |

CALPOST Visibility Method 6 was used to determine the visibility impacts. Monthly relative humidity factors [ $f(RH)$ ] were used in the light extinction calculations to account for the hygroscopic characteristics of nitrate and sulfate particles. Table 5 of the Wyoming BART Air Modeling Protocol (Appendix B) lists the monthly  $f(RH)$  factors for the Class I areas. These values were used for the particular Class I area being modeled.

The natural background conditions as a reference for determining the delta-dV ( $\Delta dV$ ) change represented the 20 percent best natural visibility days. The EPA BART guidance document provided dV values for the 10 percent best days for each Class I area, but did not provide individual species concentration data for the 20 percent best background conditions. Species concentrations corresponding to the 20 percent best days were calculated for each Class I area by scaling back the annual average species concentrations given in Table 2-1 of *Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule* (EPA, 2003). A separate scaling factor was derived for each Class I area such that, when multiplied by the guidance table annual concentrations, the 20 percent best days dV value for that area would be calculated. This procedure was taken from *Protocol for BART-Related Visibility Improvement Modeling Analysis in North Dakota* (North Dakota Department of Health, 2005). However, the Wyoming BART Air Modeling Protocol (see Appendix B) provided natural background concentrations of aerosol components to use in the BART analysis. Table 4-3 lists the annual average species concentrations from the BART protocol.

**TABLE 4-3**  
**Average Natural Levels of Aerosol Components**  
*Jim Bridger 4*

Aerosol Component	Average Natural Concentration (micrograms per cubic meter) for Mt. Zirkel Class I Wilderness Area	Average Natural Concentration (micrograms per cubic meter) for Fitzpatrick and Bridger Class I Wilderness Areas
Ammonium Sulfate	0.046	0.045
Ammonium Nitrate	0.038	0.038
Organic Carbon	0.179	0.178
Elemental Carbon	0.008	0.008
Soil	0.190	0.189
Coarse Mass	1.141	1.136

**NOTE:**

Source: Table 6 of the Wyoming BART Air Modeling Protocol

## 4.5 Presentation of Modeling Results

This section presents the results of the CALPUFF visibility improvement modeling analysis for Jim Bridger 4.

### 4.5.1 Visibility Changes for Baseline vs. Preferred Scenario

CH2M HILL modeled Jim Bridger 4 for the baseline conditions and four post-control scenarios. The post-control scenarios included emission rates for NO<sub>x</sub>, SO<sub>2</sub>, and PM<sub>10</sub> that would be achieved if BART technology were installed on Unit 4.

Baseline (and post-control) 98<sup>th</sup> percentile results were greater than 0.5 ΔdV for the Bridger, Fitzpatrick, and Mt. Zirkel Wilderness Areas. The 98<sup>th</sup> percentile results for each Class I area are presented in Table 4-4.

TABLE 4-4  
Costs and Visibility Modeling Results for Baseline Vs. Post-Control Scenarios at Class I Areas  
Jim Bridger Unit 4

Scenario	Total First Year Annualized Cost	Class I Area	Modeling Results			Cost per Reduction in 0.5 dV	Incremental Cost per Reduction in No. of Days Above 0.5 dV
			Highest Delta-Viscview [AU]	98 <sup>th</sup> Percentile Delta-dHV	No. of Days Above 0.5 dV		
<b>2001</b>							
Baseline; current operation with wet Flue Gas Desulfurization (FGD), Electrostatic Precipitator (ESP)	\$2,104,213	Brigder WA	2,275	0.695	12	-	-
Mt. Zirkel WA	1,869	1,129	24	5	-	-	-
Scenario 1: Low-NO <sub>x</sub> Burner (LNB) with Over-F-Fite Air (OFA), upgrade wet FGD, Flue Gas Conditioning (FGC) for enhanced ESP performance	\$2,104,213	Brigder WA	1,356	0.386	7	\$8,809,752	\$420,843
Mt. Zirkel WA	1,338	0.223	3	\$1,486,434	\$1,052,107		
Scenario 2: LNB with OFA, upgrade wet FGD, polishing fabric filter	\$2,104,213	Mt. Zirkel WA	1,107	0.688	16	\$4,771,459	\$263,027
Brigder WA	1,340	0.383	7	\$2,150,104	\$1,684,166		
Scenario 3: LNB with OFA and Selective Catalytic Reduction (SCR) System, upgrade wet FGD, FGC for enhanced ESP performance	\$8,470,832	Brigder WA	1,317	0.232	3	\$48,682,944	\$4,235,416
Mt. Zirkel WA	1,084	0.671	15	\$16,395,287	\$341,204		
Scenario 4: LNB with OFA and SCR system, upgrade wet FGD, polishing fabric filter	\$18,603,354	Brigder WA	0.856	0.285	3	\$345,374,034	\$2,067,039
Mt. Zirkel WA	0.756	0.143	2	\$6,735,187	\$6,201,118		
Scenario 5: LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	\$18,603,354	Mt. Zirkel WA	0.722	0.428	4	\$28,462,808	\$430,168
Brigder WA	0.914	0.273	3	\$59,770,552	\$2,774,441		
Scenario 6: LNB with OFA and SCR system, upgrade wet FGD, polishing fabric filter	\$24,989,973	Brigder WA	0.732	0.138	1	\$92,481,381	\$6,242,493
Mt. Zirkel WA	0.598	0.410	3	\$34,728,752	\$1,169,046		
Scenario 7: LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	\$24,989,973	Brigder WA	0.889	0.615	11	\$99,516,985	\$6,366,619
Mt. Zirkel WA	2,530	1,380	25	\$34,728,752	\$1,169,046		
<b>2002</b>							
Baseline; current operation with wet FGD, ESP	\$2,104,213	Brigder WA	3,975	1,330	23	-	-
Mt. Zirkel WA	1,869	0.615	11	-	-	-	-
Scenario 1: LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	\$2,104,213	Brigder WA	2,435	0.821	14	\$4,154,015	\$283,801
Mt. Zirkel WA	1,082	0.379	3	\$8,916,158	\$263,027		
Scenario 2: LNB with OFA, upgrade wet FGD, polishing fabric filter	\$2,104,213	Mt. Zirkel WA	1,494	0.800	14	\$3,627,984	\$191,292
Brigder WA	2,412	0.802	14	\$16,043,243	\$941,204		
Scenario 3: LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	\$8,470,832	Brigder WA	1,082	0.361	3	\$38,348,733	\$1,058,854
Mt. Zirkel WA	1,477	0.780	13	\$14,357,343	\$705,903		
Scenario 4: LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance	\$18,603,354	Brigder WA	1,367	0.472	7	\$21,682,231	\$1,162,710
Mt. Zirkel WA	0.591	0.233	1	\$48,698,880	\$1,860,335		
Scenario 5: LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance	\$18,603,354	Mt. Zirkel WA	0.877	0.442	5	\$31,833,000	\$890,168
Brigder WA	1,341	0.406	7	\$24,989,432	\$1,150,623		
Scenario 6: LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	\$24,989,973	Brigder WA	0.581	0.230	1	\$84,857,073	\$2,498,987
Mt. Zirkel WA	0.857	0.434	5	\$25,395,320	\$1,248,499		
Scenario 7: LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	\$24,989,973	Brigder WA	0.889	0.615	11	\$99,516,985	\$6,366,619

TABLE 4-4  
Cost and Viability Modeling Results for Baseline Vs. Post-Control Scenarios at Class I Areas  
Jim Bridger Unit 4

Scenario	Total First Year Annualized Cost	Class I Area	Modeling Results			Cost per Reduction in 0.5 dV	No. of Days Above 0.5 dV	Incremental Cost per Reduction in No. of Days Above 0.5 dV
			Highest Delta- (dEV)	95 <sup>a</sup> Percentile Delta- (dEV)	No. of Days Above 0.5 dV			
<b>2003</b>								
Baseline: current operation with wet FGD, ESP	\$2,104,213	Brider WA	1.583	0.736	13			
		Fitzpatrick WA	1.825	0.346	7			
		Mt. Zirkel WA	1.785	1.201	33			
Scenario 1: LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	\$2,104,213	Brider WA	0.981	0.429	5	\$6,854,115	\$283,027	
		Fitzpatrick WA	1.088	0.267	2	\$15,138,226	\$420,843	
		Mt. Zirkel WA	1.036	0.688	17	\$4,101,781	\$131,513	
Scenario 2: LNB with OFA, upgrade wet FGD, polishing fabric filter	\$8,470,832	Brider WA	0.941	0.455	5	\$27,237,403	\$1,055,854	\$1,581,684,726
		Fitzpatrick WA	1.081	0.202	2	\$58,825,224	\$1,694,166	NA
		Mt. Zirkel WA	1.025	0.678	17	\$16,185,520	\$529,427	NA
Scenario 3: LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance	\$18,003,354	Brider WA	0.799	0.275	2	\$40,354,347	\$1,691,214	\$67,550,145
		Fitzpatrick WA	0.682	0.159	2	\$85,729,442	\$2,720,671	\$138,007,668
		Mt. Zirkel WA	0.769	0.469	5	\$23,489,083	\$664,406	NA
Scenario 4: LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	\$24,063,973	Brider WA	0.759	0.263	2	\$22,780,641	\$2,265,998	\$844,377
		Fitzpatrick WA	0.645	0.124	1	\$112,477,356	\$4,161,662	\$830,351,575
		Mt. Zirkel WA	0.731	0.389	4	\$31,134,830	\$881,034	\$636,611,890
<b>3-year Averages</b>								
Baseline: current operation with wet FGD, ESP		Brider WA	0.920	16.0				
		Fitzpatrick WA	0.498	7.7				
		Mt. Zirkel WA	1.237	27.3				
Scenario 1: LNB with OFA, upgrade wet FGD, FGC for enhanced ESP performance	\$2,104,213	Brider WA	0.545	8.7		\$5,611,236	\$286,898	
		Fitzpatrick WA	0.270	21.7		\$11,312,875	\$420,843	
		Mt. Zirkel WA	0.725	15.7		\$4,115,150	\$180,361	
Scenario 2: LNB with OFA, upgrade wet FGD, polishing fabric filter	\$8,470,832	Brider WA	0.537	8.7		\$22,078,625	\$1,155,113	\$734,609,873
		Fitzpatrick WA	0.265	2.7		\$44,427,442	\$1,694,166	NA
		Mt. Zirkel WA	0.713	15.0		\$16,176,001	\$666,824	\$316,213,343
Scenario 3: LNB with OFA and SCR, upgrade wet FGD, FGC for enhanced ESP performance	\$18,003,354	Brider WA	0.344	4.0		\$32,278,810	\$1,550,280	\$2,590,943
		Fitzpatrick WA	0.168	1.7		\$64,174,852	\$3,100,559	\$104,815,191
		Mt. Zirkel WA	0.426	4.7		\$22,338,784	\$820,736	\$35,263,997
Scenario 4: LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter	\$24,063,973	Brider WA	0.334	4.0		\$42,586,651	\$2,080,831	\$835,661,880
		Fitzpatrick WA	0.163	1.0		\$85,416,089	\$3,745,496	\$1,273,323,781
		Mt. Zirkel WA	0.414	4.0		\$30,384,783	\$1,070,142	\$56,176,481

NOTES:  
Scenario 4: LNB with OFA and SCR, upgrade wet FGD, polishing fabric filter  
Scenario Calculations: Cost per dV Reduction for Scenario 1 for 2001: = \$2,104,213 / (0.727, 0.415) = \$6,744,274.  
Scenario Calculations: Cost per Reduction in No. of Days Exceeding 0.5 dV for 2001: = \$2,104,213 / (15 - 7) = \$283,027

## **5.0 Preliminary Assessment and Recommendations**

---

As a result of the completed technical and economic evaluations, and consideration of the modeling analysis for Jim Bridger 4, the preliminary recommended BART controls for NO<sub>x</sub>, SO<sub>2</sub>, and PM<sub>10</sub> are as follows:

- New LNBs and modifications to the OFA system for NO<sub>x</sub> control
- Upgrade wet sodium FGD for SO<sub>2</sub> control
- Add flue gas conditioning upstream of existing ESPs for PM control

These recommendations were identified as Scenario 1 for the modeling analysis described in Section 4. Visibility improvements for all emission control scenarios were analyzed, and the results are compared below, utilizing a least-cost envelope, as outlined in the *New Source Review Workshop Manual* (EPA, 1990, hereafter referred to as NSR Manual).

### **5.1 Least-cost Envelope Analysis**

For the control scenarios modeled in Section 4, Tables 5-1 through 5-3 list the total annualized cost, cost per dV reduction, and cost per reduction in number of days above 0.5 dV for each of the three Class I areas. A comparison of the incremental results between selected scenarios is provided in Tables 5-4 through 5-6. Figures 5-1 to 5-6 show the total annualized cost versus number of days above 0.5 dV, and the total annualized cost versus 98<sup>th</sup> percentile AdV reduction, for the three Class I areas.

#### **5.1.1 Analysis Methodology**

On page B-41 of the New Source Review (NSR) Manual, EPA states that "Incremental cost-effectiveness comparisons should focus on annualized cost and emission reduction differences between dominant alternatives. Dominant set of control alternatives are determined by generating what is called the envelope of least-cost alternatives. This is a graphical plot of total annualized costs for a total emissions reductions for all control alternatives identified in the BACT analysis..."

An analysis of incremental cost effectiveness has been conducted. This analysis was performed in the following way. First, the control option scenarios are ranked in ascending order of annualized total costs, as shown in Tables 5-1 through 5-3. The incremental cost effectiveness data, expressed per day and per dV, represents a comparison of the different scenarios, and is summarized in Tables 5-4 through 5-6 for each of the three wilderness areas. Then the most reasonable smooth curve of least-cost control option scenarios is plotted for each analysis. Figures 5-1 through 5-6 present the two analyses (cost per dV reduction and cost per reduction in number of days above 0.5 dV) for each of the three Class I areas impacted by the operation of Jim Bridger 4.

In Figure 5-1, the four scenarios are compared as a graph of total annualized cost versus number of days above 0.5 dV. The EPA states that "In calculating incremental costs, the analysis should only be conducted for control options that are dominant among all possible options." In Figure 5-1, the dominant set of control options (Scenarios 1, 3, and 4) represent the least-cost envelope depicted by the curvilinear line connecting them. Scenario 2 is an inferior option and should not be considered in the derivation of incremental cost effectiveness. Scenario 2 represents inferior controls because Scenario 1 provides approximately the same amount of visibility impact reduction for less cost than Scenario 2. The incremental cost effectiveness is determined by the difference in total annual costs between two contiguous scenarios divided by the difference in emissions reduction.

**TABLE 5-1**  
Control Scenario Results for the Bridger Class I Wilderness Area  
*Jim Bridger Unit 4*

Scenario	Controls	98 <sup>th</sup> Percentile deciivew (dV) Reduction	Reduction in Average Number of Days Above 0.5 dV (days)	Total Annualized Cost (million\$)	Cost per dV Reduction (million\$ per dV reduced)	Cost per Reduction in No. of Days Above 0.5 dV (million\$ per day reduced)
Base	Current Operation with Wet Flue Gas Desulfurization (FGD), Electrostatic Precipitator (ESP)	0.00	0.0	\$0.0	\$0.0	\$0.0
1	Low-NO <sub>x</sub> Burner (LNB) with Over-Fire Air (OFA), upgrade wet FGD and Flue Gas Conditioning (FGC) for enhanced ESP performance	0.38	7.3	\$2.1	\$5.6	\$0.3
2	LNB with OFA, Upgrade Wet FGD, new polishing fabric filter	0.38	7.3	\$8.5	\$22.1	\$1.2
3	LNB with OFA and Selective Catalytic Reduction (SCR) System, upgrade wet FGD and FGC for enhanced ESP performance	0.58	12.0	\$18.6	\$32.3	\$1.6
4	LNB with OFA and SCR, upgrade wet FGD, new polishing fabric filter	1.25	20	\$25.0	\$19.9	\$1.2

**TABLE 5-2**  
**Control Scenario Results for the Fitzpatrick Class I Wilderness Area**  
*Jim Bridger Unit 4*

Scenario	Controls	98 <sup>th</sup> Percentile decileview (dV) Reduction	Reduction in Average Number of Days Above 0.5 dV (days)	Total Annualized Cost (million\$)	Cost per dV Reduction (million\$ per dV reduced)	Cost per Reduction in No. of Days Above 0.5 dV (million\$ per Day reduced)
Base	Current Operation with Wet Flue Gas Desulfurization (FGD), Electrostatic Precipitator (ESP)	0.00	0.0	\$0.0	\$0.0	\$0.0
1	Low-NO <sub>x</sub> Burner (LNB) with Over-Fire Air (OFA), upgrade wet FGD and Flue Gas Conditioning (FGC) for enhanced ESP performance	0.19	5.0	\$2.1	\$11.3	\$0.4
2	LNB with OFA, Upgrade Wet FGD, new polishing fabric filter	0.19	5.0	\$8.5	\$44.4	\$1.7
3	LNB with OFA and Selective Catalytic Reduction (SCR) System, upgrade wet FGD and FGC for enhanced ESP performance	0.29	6.0	\$18.6	\$64.7	\$3.1
4	LNB with OFA and SCR, upgrade wet FGD, new polishing fabric filter	0.29	6.7	\$25.0	\$85.4	\$3.7

**TABLE 5-3**  
**Control Scenario Results for the Mt. Zirkel Class I Wilderness Area**  
*Jim Bridger 4*

Scenario	Controls	98 <sup>th</sup> Percentile deciView (dV) Reduction	Reduction in Average Number of Days Above 0.5 dV (days)	Total Annualized Cost (million\$)	Cost per dV Reduction (million\$ per dV reduced)	Cost per Reduction in No. of Days Above 0.5 dV (million\$ per Day reduced)
Base	Current Operation with Wet Flue Gas Desulfurization (FGD), Electrostatic Precipitator (ESP)	0.00	0.0	\$0.0	\$0.0	\$0.0
1	Low-NO <sub>x</sub> Burner (LNB) with Over-Fire Air (OFA), upgrade wet FGD and Flue Gas Conditioning (FGC) for enhanced ESP performance	0.51	11.7	\$2.1	\$4.1	\$0.2
2.	LNB with OFA, Upgrade Wet FGD, new polishing fabric filter	0.52	12.3	\$8.5	\$16.2	\$0.7
3	LNB with OFA and Selective Catalytic Reduction (SCR) System, upgrade wet FGD and FGC for enhanced ESP performance	0.81	22.7	\$18.6	\$22.9	\$0.8
4	LNB with OFA and SCR, upgrade wet FGD, new polishing fabric filter	0.82	23.3	\$25.0	\$30.4	\$1.1

**TABLE 5-4**  
**Brider Class I Wilderness Area Incremental Analysis Data**  
*Jim Bridger Unit 4*

Options Compared	Incremental Reduction in Days Above 0.5 deciView (dV) (days)	Incremental dV Reductions (dV)	Incremental Cost-Effectiveness (million\$ per days)	Incremental Cost-Effectiveness (million\$ per dV)
Baseline and Scenario 1	7.3	0.38	\$0.29	\$5.61
Scenario 1 and Scenario 2	0.0	0.01	N/A	\$734.6
Scenario 1 and Scenario 3	4.7	0.20	\$3.5	\$81.9
Scenario 1 and Scenario 4	12.7	0.88	\$1.8	\$26.0


**TABLE 5-5**  
**Fitzpatrick Class I Wilderness Area Incremental Analysis Data**  
*Jim Bridger Unit 4*

Options Compared	Incremental Reduction in Days Above 0.5 deciview (dV) (days)	Incremental dV Reductions (dV)	Incremental Cost-Effectiveness (million\$ per days)	Incremental Cost-Effectiveness (million\$ per dV)
Baseline and Scenario 1	5.0	0.19	\$0.42	\$45.54
Scenario 1 and Scenario 2	0.0	0.00	NA	\$1,364.3
Scenario 1 and Scenario 3	1.0	0.10	\$16.5	\$162.8
Scenario 1 and Scenario 4	1.7	0.11	\$13.7	\$215.0


**TABLE 5-6**  
**Mt. Zirkel Class I Wilderness Area Incremental Analysis Data**  
*Jim Bridger Unit 4*

Options Compared	Incremental Reduction in Days Above 0.5 dV (days)	Incremental dV Reductions (dV)	Incremental Cost-Effectiveness (million\$/days)	Incremental Cost-Effectiveness (million\$ per dV)
Baseline and Scenario 1	11.7	0.51	\$0.18	\$4.12
Scenario 1 and Scenario 2	0.7	0.01	\$9.5	\$516.2
Scenario 1 and Scenario 3	11.0	0.30	\$1.5	\$55.1
Scenario 1 and Scenario 4	11.7	0.31	\$2.0	\$73.5


**FIGURE 5-1**  
Least-cost Envelope Bridger Class I WA-Days Reduction  
*Jim Bridger Unit 4*




**FIGURE 5-2**  
Least-cost Envelope Bridger Class I WA 98<sup>th</sup> Percentile Reduction  
*Jim Bridger Unit 4*




**FIGURE 5-3**  
Least-cost Envelope Fitzpatrick Class I WA Days Reduction  
Jim Bridger Unit 4




**FIGURE 5-4**  
Least-cost Envelope Fitzpatrick Class I WA 98<sup>th</sup> Percentile Reduction  
Jim Bridger Unit 4



**FIGURE 5-5**  
Least-cost Envelope Mt. Zirkel Class I WA Days Reduction  
*Jim Bridger Unit 4*



**FIGURE 5-6**  
Least-cost Envelope Mt. Zirkel Class I WA-98<sup>th</sup> Percentile Reduction  
*Jim Bridger Unit 4.*



### 5.1.2 Analysis Results

Results of the least-cost analysis, shown in Tables 5-1 through 5-6 and Figures 5-1 through 5-6 on the preceding pages, confirm the selection of Scenario 1, based on incremental cost and visibility improvements. Scenario 2 is eliminated because it is to the left of the curve formed by the "dominant" control alternative scenarios, which indicates a scenario with lower improvement and/or higher costs. Scenario 3 is not selected due to very high incremental costs for both a cost per day of improvement and a cost per dV reduction. While Scenario 4 provides some potential visibility advantage over Scenario 1, the projected improvement is less than 0.5 dV, and the projected costs are excessive.

Analysis of the results for the Jim Bridger Class I Wilderness Area in Tables 5-1 and 5-4 and Figures 5-1 and 5-2 illustrates the conclusions stated above. The greatest reduction in 98<sup>th</sup> percentile dV and number of days above 0.5 dV is between the Baseline and Scenario 1. The incremental cost effectiveness for Scenario 1 compared to the Baseline for the Bridger Wilderness Area, for example, is reasonable at \$290,000 per day and \$5.6 million per dV. However, the incremental cost effectiveness for Scenario 3 compared to Scenario 1, again for the Bridger Wilderness Area, is excessive at \$3.5 Million per day and \$81.9 million per dV. The same conclusions are reached for each of the three wilderness areas studied. Therefore, Scenario 1 represents BART for Jim Bridger 4.

## 5.2 Recommendations

### 5.2.1 NO<sub>x</sub> Emission Control

The BART presumptive NO<sub>x</sub> limit assigned by EPA for tangentially-fired boilers burning sub-bituminous coal is 0.15 lb per MMBtu. However, as documented in Section 3.2.1, the characteristics of the Jim Bridger coals are more closely aligned with bituminous coals, and have been assigned a presumptive BART NO<sub>x</sub> limit of 0.28 lb per MMBtu.

CH2M HILL recommends LNBs with OFA as BART for Jim Bridger 4, based on the projected significant reduction in NO<sub>x</sub> emissions, reasonable control costs, and the advantages of no additional power requirements or non-air quality environmental impacts. NO<sub>x</sub> reductions are expected to be similar to those realized at Jim Bridger 2. CH2M HILL recommends that the unit be permitted at a rate of 0.26 lb per MMBtu.

### 5.2.2 SO<sub>2</sub> Emission Control

CH2M HILL recommends upgrading the existing wet sodium FGD system as BART for Jim Bridger 4, based on the significant reduction in SO<sub>2</sub> emissions, reasonable control costs, and the advantages of minimal additional power requirements and minimal non-air quality environmental impacts. This upgrade approach will meet the BART presumptive SO<sub>2</sub> limit of 0.15 lb per MMBtu.

### 5.2.3 PM<sub>10</sub> Emission Control

CH2M HILL recommends finalizing the permitting of the FGC system to enhance the performance of the existing ESP as BART for Jim Bridger 4, based on the significant

reduction in PM<sub>10</sub> emissions, reasonable control costs, and the advantages of minimal additional power requirements and no non-air quality environmental impacts.

### 5.3 Just-Noticeable Differences in Atmospheric Haze

Conclusions reached in the reference document "Just-Noticeable Differences in Atmospheric Haze" by Dr. Ronald Henry of the University of Southern California (Henry, 2002), state that only dV differences of approximately 1.5 to 2.0 dV, or more are perceptible by the human eye. Deciview changes of less than 1.5 cannot be distinguished by the average person. Therefore, the modeling analysis results indicate that only minimal, if any, observable visibility improvements at the Class I areas studied would be expected under any of the scenarios. Thus the results indicate that even though many millions of dollars will be spent, only minimal if any visibility improvements may result.

Finally, it should be noted that none of the data were corrected for natural obscuration. Water in various forms (fog, clouds, snow, or rain) or other naturally caused aerosols may obscure the atmosphere and reduce visibility. During the period of 2001 through 2003, there were several mega-wildfires that lasted for many days, with a significant impact on background visibility in these Class I areas. If natural obscuration lessens the achievable reduction in visibility impacts modeled for BART controls at the Jim Bridger 4 facility, the overall effect would be to increase the costs per dV reduction that are presented in this report.

## **6.0 References**

---

- 40 CFR Part 51. *Regional Haze Regulations and Guidelines for Best Available Retrofit Technology Determinations; Final Rule.* July 6, 2005.
- Energy Information Administration, 2006. *Official Energy Statistics from the U.S. Government: Coal.* <http://www.eia.doe.gov/fuelcoal.html>. Accessed October 2006.
- EPA, 1990. *New Source Review Workshop Manual—Prevention of Significant Deterioration and Nonattainment Area Permitting.* Draft. October 1990.
- EPA, 2003. *Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule.* Environmental Protection Agency. EPA-454/8-03-005. September 2003.
- Henry, Ronald, 2002. "Just-Noticeable Differences in Atmospheric Haze," *Journal of the Air & Waste Management Association.* Volume 52, p. 1238.
- National Oceanic and Atmospheric Administration, 2006. U.S. Daily Weather Maps Project. [http://docs.lib.noaa.gov/rescue/dwm/data\\_rescue\\_daily\\_weather\\_maps.html](http://docs.lib.noaa.gov/rescue/dwm/data_rescue_daily_weather_maps.html). Accessed October 2006.
- North Dakota Department of Health, 2005. *Protocol for BART-Related Visibility Improvement Modeling Analysis in North Dakota.* North Dakota Department of Health. October 26, 2005.
- Sargent & Lundy, 2002. *Multi-Pollutant Control Report.* October 2002.
- Sargent & Lundy, 2006. *Multi-Pollutant Control Report.* Revised. October 2006.
- WDEQ-AQD, 2006. *BART Air Modeling Protocol—Individual Source Visibility Assessments for BART Control Analyses.* Wyoming Department of Environmental Quality – Air Quality Division. September 2006.

**APPENDIX A**

**Economic Analysis**

## PaciCorp BART Analysis Scenarios

Select Unit:	Name of Unit	6	Jim Bridger Unit 4
Index No.			
1	Dave Johnston Unit 3		
2	Dave Johnston Unit 4		
3	Jim Bridger Unit 1		
4	Jim Bridger Unit 2		
5	Jim Bridger Unit 3		
6	Jim Bridger Unit 4		
7	Naughton Unit 1		
8	Naughton Unit 2		
9	Naughton Unit 3		
10	Wyodak Unit 1		

Dave Johnston		NTN Unit 3		Naughton		NTN Unit 2		NTN Unit 3	
DJ Unit 3		DJ Unit 4		NTN Unit 1		NTN Unit 2		NTN Unit 3	
Scenario	First Year Cost	Scenario	First Year Cost	Scenario	First Year Cost	Scenario	First Year Cost	Scenario	First Year Cost
Baseline - Current Operation with ESP		Baseline - Current Operation with Venturi Scrubber		Baseline - Current Operation with ESP		Baseline - Current Operation with FGD and ESP		Baseline - Current Operation with FGD and ESP	
Scenario 1 - LNB with OFA, Dry FGD, Existing ESP	N/A	Scenario 1 - LNB with OFA, Dry FGD, Fabric Filter	N/A	Scenario 1 - LNB with OFA, Dry FGD, ESP	N/A	Scenario 1 - LNB with OFA, Dry FGD, ESP	N/A	Scenario 1 - LNB with OFA, Wet FGD, ESP	N/A
Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Dry FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	N/A
Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	N/A	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	N/A	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	N/A	Scenario 3 - LNB with OFA and SCR, Dry FGD, New Fabric Filter	N/A	Scenario 3 - LNB with OFA and SCR, Wet FGD, New Fabric Filter	N/A
Scenario 4 - LNB with OFA and SCR, Wet FGD, Existing ESP, New Stack	N/A	Scenario 4 - LNB with OFA and SCR, Dry FGD, Fabric Filter	N/A	Scenario 4 - LNB with OFA and SCR, Dry FGD, ESP, New Stack	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, ESP, New Stack	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A
Jim Bridger		JB Unit 2		JB Unit 3		JB Unit 4		WYDak	
Scenario	First Year Cost	Scenario	First Year Cost	Scenario	First Year Cost	Scenario	First Year Cost	Scenario	First Year Cost
Baseline - Current Operation with Wet FGD and ESP		Baseline - Current Operation with Wet FGD and ESP		Baseline - Current Operation with Wet FGD and ESP		Baseline - Current Operation with Wet FGD and Dry FGD, Fabric Filter		Baseline - Current Operation with Wet FGD and Dry FGD, Fabric Filter	
Scenario 1 - LNB with OFA, Wet FGD, ESP	N/A	Scenario 1 - LNB with OFA, Wet FGD, ESP	N/A	Scenario 1 - LNB with OFA, Wet FGD, ESP	N/A	Scenario 1 - LNB with OFA, Dry FGD, Fabric Filter	\$ 2,104,213	Scenarios 1 - LNB with OFA, Dry FGD, Fabric Filter	N/A
Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Wet FGD, New Fabric Filter	N/A	Scenario 2 - LNB with OFA, Dry FGD, Fabric Filter	\$ 2,104,213	Scenarios 2 - LNB with OFA and SCR, Dry FGD, Fabric Filter	N/A
Scenario 3 - LNB with OFA and SCR, Wet FGD, Existing ESP	N/A	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	N/A	Scenario 3 - LNB with OFA and SCR, Wet FGD, ESP	N/A	Scenario 3 - LNB with OFA and SCR, Wet FGD, Fabric Filter	\$ 8,470,832	Scenarios 3 - LNB with OFA and SCR, Wet FGD, Fabric Filter, New Stack	N/A
Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A	Scenario 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	\$ 8,470,832	Scenarios 4 - LNB with OFA and SCR, Wet FGD, Fabric Filter	N/A

## ECONOMIC ANALYSIS SUMMARY

### Jim Bridger Unit 4

#### Boiler Design:

#### Tangential-Fired PC

Parameter	Tangential-Fired PC						PM Control
	NOx Control			SO2 Control		Flue Gas Conditioning	
Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	Upgraded Wet FGD	LNCFs-1 & Windbox Mods.	LNCFs-1 & Windbox Mods. Wet FGD
<b>Case</b>	<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6</b>	<b>7</b>
NOx Emission Control System	LNCFs-1 & Windbox Mods.	LNB w/OFA & SCR	LNB w/OFA & SCR	LNB w/OFA & SCR	LNB w/OFA & SCR	LNCFs-1 & Windbox Mods.	LNCFs-1 & Windbox Mods. Wet FGD
SOx Emission Control System	Wet FGD	Wet FGD	Wet FGD	Wet FGD	Wet FGD	Upgraded Wet FGD	Upgraded Wet FGD
PM Emission Control System	ESP	ESP	ESP	ESP	ESP	ESP	Fabric Filter
<b>TOTAL INSTALLED CAPITAL COST (\$)</b>	<b>0</b>	<b>8,700,001</b>	<b>20,528,122</b>	<b>22,127,239</b>	<b>147,628,474</b>	<b>5,759,814</b>	<b>48,386,333</b>
<b>FIRST YEAR O&amp;M COST (\$)</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>
Operating Labor (\$)	0	28,000	42,000	123,000	190,000	0	0
Maintenance Material (\$)	0	42,000	63,000	154,500	285,000	25,550	51,099
Maintenance Labor (\$)	0	0	0	0	0	17,033	76,649.
<b>TOTAL FIXED O&amp;M COST</b>	<b>0</b>	<b>70,000</b>	<b>105,000</b>	<b>307,500</b>	<b>476,000</b>	<b>42,583</b>	<b>10,000</b>
Makeup Water Cost	0	0	0	0	0	16,539	0
Reagent Cost	0	0	0	1,05,811	912,848	213,921	145,854
SCR Catalyst / FFF Bag Cost	0	0	0	0	642,000	0	0
Waste Disposal Cost	0	0	0	0	0	177,714	0
Electric Power Cost	0	0	2,928,012	208,926	1,323,329	203,226	19,710
<b>TOTAL VARIABLE O&amp;M COST</b>	<b>0</b>	<b>0</b>	<b>2,928,012</b>	<b>1,214,737</b>	<b>2,878,177</b>	<b>616,100</b>	<b>1,335,944</b>
<b>TOTAL FIRST YEAR O&amp;M COST</b>	<b>0</b>	<b>70,000</b>	<b>2,653,012</b>	<b>1,522,237</b>	<b>3,313,177</b>	<b>658,683</b>	<b>176,732</b>
<b>FIRST YEAR DEBT SERVICE (\$)</b>	<b>0</b>	<b>827,612</b>	<b>1,952,796</b>	<b>2,114,916</b>	<b>14,048,375</b>	<b>547,919</b>	<b>0</b>
<b>TOTAL FIRST YEAR COST (\$)</b>	<b>0</b>	<b>887,612</b>	<b>4,585,808</b>	<b>3,627,163</b>	<b>17,395,753</b>	<b>1,206,601</b>	<b>175,564</b>
Power Consumption (MW)	0.0	0.0	6.4	0.5	3.4	0.5	0.1
Annual Power Usage (Million kWh/yr)	0.0	0.0	50.6	4.2	26.5	4.2	0.4
<b>CONTROL COST (\$/Ton Removed)</b>							
NOx Removal Rate (%)	0.0%	43.67	51.1%	55.6%	84.4%	0.0%	0.0%
NOx Removed (Tons/yr)	0	181	843	5,913	8,987	0	0
First Year Average Control Cost (\$/Ton NOx Rem.)	0	181	7,797	613	1,916	0	0
Incremental Control Cost (\$/Ton NOx Removed)	0	181	2-1	2,885	4,479	0	0
SO2 Removal Rate (%)	98.1%	0.0%	0.0%	0.0%	40.1%	0.0%	0.0%
SO2 Removed (Tons/yr)	0	0	0	0	1,585	0	0
First Year Average Control Cost (\$/Ton SO2 Rem.)	0	0	0	0	761	0	0
Incremental Control Cost (\$/Ton SO2 Removed)	0	0	0	0	8-1	0	0
PM Removal Rate (%)	99.65%	0.00%	0.00%	0.00%	0.00%	0.00%	50.00%
PM Removed (Tons/yr)	0	0	0	0	0	0	355
First Year Average Control Cost (\$/Ton PM Rem.)	0	0	0	0	0	#DIV/0!	17,496
Incremental Control Cost (\$/Ton PM Removed)	0	0	0	0	0	#DIV/0!	17,452
<b>PRESIDENT WORTH COST (\$)</b>	<b>0</b>	<b>9,355,250</b>	<b>52,697,883</b>	<b>40,725,706</b>	<b>188,957,104</b>	<b>13,887,503</b>	<b>2,145,015</b>

## INPUT CALCULATIONS

Jim Bridger Unit 4 Boiler Design: Tangential-Fired PC

Parameter	NOx Control			SO2 Control			PM Control			Comments
	Current Operation	LNB w/QFA	ROFA	LNB w/QFA & SNCR	LNB w/QFA	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter		
Case	1 LNGFS-1 & Windbox Wet FGD ESP	2 LNB w/QFA Wet FGD ESP	3 ROFA Wet FGD ESP	4 LNB w/QFA & SNCR Wet FGD ESP	5 LNB w/QFA & SNCR Wet FGD ESP	8 LNGFS-1 & Windbox Wet FGD Upgraded Wet FGD ESP	9 LNGFS-1 & Windbox Wet FGD Flue Gas Conditioning	10 LNGFS-1 & Windbox Wet FGD Fabric Filter		
NOx Emission Control System										
SC2 Emission Control System										
Unit Design and Coal Characteristics										
Type of Unit										
Net Power Output (kW)										
Net Plant Heat Rate (Btu/kWh- $r$ )										
Boiler Fuel										
Coal Heating Value (Btu/lb)										
Coal Sulfur Content (wt. %)										
Coal Ash Content (wt. %)										
Boiler Heat Input, each (MMBtu/hr)										
Coal Flow Rate (lb/hr)										
(Ton/Yr)										
(MMBtu/Yr)										
Emissions										
Uncontrolled SO2 (lb/hr)										
(lb/Mole/r)										
(Tons/Yr)										
SO2 Removal Rate (%)										
SC2 Removal Rate (%)										
SC2 Emission Rate (lb/hr)										
(Ton/Yr)										
SC2 Emission Rate (lb/MMBtu)										
(Ton/Yr)										
Uncontrolled NOX (lb/hr)										
(lb/Mole/r)										
(Tons/Yr)										
NOx Removal Rate (%)										
(lb/hr)										
(lb/Mole/r)										
(Ton/Yr)										
NOx Emission Rate (lb/hr)										
(Ton/Yr)										
Uncontrolled Fly Ash (lb/hr)										
(lb/Mole/r)										
(Tons/Yr)										
Fly Ash Removal Rate (%)										
(lb/hr)										
(Ton/Yr)										
Fly Ash Emission Rate (lb/hr)										
(MMBtu)										
(Ton/Yr)										

Parameter	Current Operation	NOx Control				SO2 Control		PM Control		Comments
		LNB w/OFA	ROFA	LNB w/OFA & SCR	LNB w/OFA & SCR	Upgraded Wet FGD	Flue Gas Conditioning	Fabric Filter	10	
Case	1	2	3	4	5	8	9			
General Plant Data										
Annual Operation Hours/Year	7,884	7,884	7,884	7,884	7,884	7,884	7,884			
Annual On-Site Power Plant Capacity Factor	0.90	0.90	0.90	0.90	0.90	0.90	0.90			
Economic Factors										
Inflation Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%			
Discount Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%			
Plant Economic Life (Years)	20	20	20	20	20	20	20			
Installed Capital Costs										
NOX Emission Control System (\$2006)	0	8,700,001	20,628,122	22,127,239	147,628,474	0	0	0	0	
SO2 Emission Control System (\$2006)	0	0	0	0	0	5,759,814	0	0	48,386,333	
PM Emission Control System (\$2006)	0	0	0	0	0	0	0	0	48,386,333	
Total Emission Control Systems (\$2006)	0	8,700,001	20,628,122	22,127,239	147,628,474	5,759,814	0	0	96,772,666	
NOX Emission Control System (\$kW)										
SC2 Emission Control System (\$kW)	0	16	39	42	279	0	11	0	0	
PM Emission Control System (\$kW)	0	16	39	42	279	11	0	0	91	
Total Fixed Operating & Maintenance Costs										
Operating Labor (\$)	0	0	0	0	0	0	0	0	0	
Maintenance Material (\$)	0	28,000	42,000	123,000	199,000	25,350	0	0	51,999	
Administrative Labor (\$)	0	42,000	63,000	184,600	285,000	17,033	10,000	0	76,949	
Total Fixed O&M Cost (\$)	0	70,000	105,000	307,500	476,000	42,383	10,000	0	127,749	
Annual Fixed O&M Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Water Cost										
Makeup Water Usage (Gpm)	0	0	0	0	0	0	1.22	1.22	0	
Unit Price (\$/1000 Gallons)	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	
First Year Water Cost (\$)	0	0	0	0	0	0	0	0	0	
Annual Water Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Resident Cost										
Unit Cost (\$/Ton) (\$/lb)	None	None	None	Urea	Anhydrous NH3	Soda Ash	Elemental Sulfur	None	None	
Molar Stoichiometry	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Reagent purity (Mt %)	0.00	0.00	0.00	0.45	1.00	0.02	0.00	0.00	0.00	
Reagent usage (Lb/Hr)	100%	100%	100%	100%	100%	100%	100%	100%	100%	
First Year Reagent Cost (\$)	0	0	0	650	673	673	145,854	0	0	
Annual Reagent Cost Escalation Rate (%)	2.00%	2.00%	2.00%	1,005,811	912,848	213,921	2,00%	2,00%	2,00%	
SCR Catalyst / FF Bag Replacement Cost										
Annual SCR Catalyst (m <sup>3</sup> ) / Non FF Bags	0	0	0	0	0	0	0	0	0	
SCR Catalyst (Sm <sup>3</sup> ) / Bag Cost (\$/Bag)	3,000	3,000	3,000	3,000	3,000	3,000	2,895	2,895	2,895	
First Year SCR Catalyst / Bag Replcns. Cost (\$)	0	0	0	0	0	0	104	104	104	
Annual SCR Catalyst / Bag Cost Esc. Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
FGD Waste Disposal Cost										
FGD Solid Waste Disposal Rate, Dry (Lb/Hr)	0	0	0	0	0	0	0	0	0	
First Year FGD Waste Disposal Cost (\$/Dry Ton)	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	24.33	
Annual Waste Disposal Cost Esc. Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Auxiliary Power Cost										
Auxiliary Power Requirement (% of Plant Output)	0.00%	0.00%	0.00%	1.21%	0.10%	0.63%	0.10%	0.01%	0.64%	
Unit Cost (\$/2006MMH)	0.00	50.00	50.00	6.41	0.53	3.36	0.53	0.06	3.39	
First Year Auxiliary Power Cost (\$)	50.00	50.00	50.00	50.00	50.00	50.00	50.00	50.00	50.00	
Annual Power Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	

EY102007001SLOApp A\_PCPo\_1B4 BART Economic Analysis\_01-11-07.xls

## Input Tables

Table 1 - Cases

Index No.	Name of Unit / Case →	Existing		NOx Control		SO2 Control		PM Control		
		1	2	3	4	5	6	7	8	9
1	Dave Johnson Unit 3	Current Operation	LNB w/oFA	ROFA	LNB w/oFA & SNCR	LNB w/oFA & LNB NOxFA & SCR	Dry FGD w/ESP	Dry FGD w/Fabric Filter	Wet FGD w/ESP	N/A
2	Dave Johnson Unit 4	Current Operation	LNB w/oFA	ROFA	LNB w/oFA & SNCR	LNB w/oFA & SCR	N/A	Dry FGD w/Fabric Filter	Wet FGD w/Fabric Filter	N/A
3	Jim Bridger Unit 1	Current Operation	LNB w/oFA	ROFA	LNB w/oFA & SNCR	LNB w/oFA & SCR	N/A	N/A	Upgraded Wet FGD	Fabric Filter
4	Jim Bridger Unit 2	Current Operation	Exst LNB w/oFA	ROFA	SNCR	LNB w/oFA & SNCR	N/A	N/A	Upgraded Wet FGD	Fabric Filter
5	Jim Bridger Unit 3	Current Operations	LNB w/oFA	ROFA	LNB w/oFA & SNCR	LNB w/oFA & SCR	N/A	N/A	Upgraded Wet FGD	Fabric Filter
6	Jim Bridger Unit 4	Current Operations	LNB w/oFA	ROFA	LNB w/oFA & SNCR	LNB w/oFA & SCR	N/A	N/A	Upgraded Wet FGD	Fabric Filter
7	Naughton Unit 1	Current Operation	LNB w/oFA	ROFA	LNB w/oFA & SNCR	LNB w/oFA & SCR	Dry FGD w/ESP	Dry FGD w/Fabric Filter	Wet FGD w/ESP	Fabric Filter
8	Naughton Unit 2	Current Operation	LNB w/oFA	ROFA	LNB w/oFA & SNCR	LNB w/oFA & SCR	Dry FGD w/ESP	Dry FGD w/Fabric Filter	Wet FGD w/ESP	Fabric Filter
9	Naughton Unit 3	Current Operation	Exst LNB w/oFA	ROFA	SNCR	LNB w/oFA & SCR	N/A	N/A	Upgraded Wet FGD	Fabric Filter
10	Wyodak Unit 1	Current Operation	LNB w/oFA	ROFA	LNB w/oFA & SNCR	LNB w/oFA & SCR	N/A	N/A	Wet FGD	Fabric Filter

Table 2 - Unit Design and Coal Characteristics

Index No.	Name of Unit	Current Emission Control Systems			Unit Design			Coal Quality		
		NOx	SO2	PM	Boiler Design	Net Power Output (kW)	Net Plant Heat Rate (Btu/kWh)	Coal	Heating Value (HHV (Btu/lb))	Sulfur Content (Wt. %)
1	Dave Johnson Unit 3	None	None	ESP	Tangential-Fired PC Wall-Fired PC	250,000	11,200	Dry Fork PRB	7,784	0.47%
2	Dave Johnson Unit 4	Wetbox Mod., LNGFS-1 & Windbox Mod., LNB-TFS 2000	Line Added to Venturi Scrubber	Venturi Scrubber Wet FGD	Tangential-Fired PC Wet FGD	360,000	11,350	Dry Fork PRB Underground	7,784	0.47%
3	Jim Bridger Unit 1	None	None	ESP	Tangential-Fired PC	530,000	11,320	Bridger Mine Underground	9,660	0.63%
4	Jim Bridger Unit 2	LNGFS-1 & Windbox Mod., LNB-TFS 2000	Wet FGD	ESP	Tangential-Fired PC	630,000	11,320	Bridger Mine Underground	9,660	0.63%
5	Jim Bridger Unit 3	Wet FGD	ESP	Tangential-Fired PC	530,000	11,320	Bridger Mine Underground	9,660	0.63%	10.30%
6	Jim Bridger Unit 4	Wet FGD	ESP	Tangential-Fired PC	530,000	11,320	Bridger Mine Underground	9,660	0.63%	10.30%
7	Naughton Unit 1	None	None	ESP	Tangential-Fired PC	173,000	10,594	Kemmerer Mine	9,970	0.60%
8	Naughton Unit 2	None	None	ESP	Tangential-Fired PC	226,000	10,574	Kemmerer Mine	9,970	0.60%
9	Naughton Unit 3	LNGFS II LNB	Wet FGD	ESP	Tangential-Fired PC Opposed Wall/Fired PC	386,000	10,536	Kemmerer Mine	9,970	0.60%
10	Wyodak Unit 1	Any FGD	ESP	Opposed Wall/Fired PC	385,000	12,087	Cheyenne Point Mine	7,977	0.65%	4.64%

**Table 3 - Emissions**

Index No.	Name of Unit	Current Emission Rates (lb/MMBtu)		NOx Control Emission Rates (lb/MMBtu)					SO2 Control Emission Rates (lb/MMBtu)			PM Emission Rates (lb/MMBtu)		
		Controlled SO2	Controlled NOx	Case 1	Case 2	Case 3	Case 4	Case 5	Case 6	Case 7	Case 8	Case 9	Case 10	
1.	Dave Johnston Unit 3	1.20	0.70	0.200	0.16	0.15	0.19	0.20	0.07	0.21	0.16	0.10	N/A	0.016
2.	Dave Johnston Unit 4	0.33	0.48	0.061	0.045	0.045	0.045	0.045	0.12	0.07	0.15	0.10	N/A	0.016
3.	Jim Bridger Unit 1	0.27	0.45	0.045	0.045	0.045	0.045	0.045	0.20	0.07	N/A	0.10	0.030	0.015
4.	Jim Bridger Unit 2	0.27	0.24	0.074	0.045	0.045	0.045	0.045	0.22	0.07	N/A	0.10	0.030	0.015
5.	Jim Bridger Unit 3	0.27	0.45	0.067	0.067	0.067	0.067	0.067	0.22	0.07	N/A	0.10	0.030	0.015
6.	Jim Bridger Unit 4	0.17	0.45	0.030	0.030	0.030	0.030	0.030	0.20	0.07	N/A	0.10	0.030	0.015
7.	Naughton Unit 1	1.20	0.58	0.056	0.056	0.056	0.056	0.056	0.16	0.07	0.48	0.10	0.040	0.016
8.	Naughton Unit 2	1.20	0.64	0.064	0.064	0.064	0.064	0.064	0.28	0.07	0.18	0.15	0.040	0.016
9.	Naughton Unit 3	0.50	0.46	0.094	0.094	0.094	0.094	0.094	0.28	0.07	N/A	0.10	0.040	0.015
10.	Wyodak Unit 1	0.50	0.50	0.030	0.030	0.030	0.030	0.030	0.22	0.07	0.25	0.10	0.025	0.015

**Table 4 - Case 1 O&M Costs (Current Operation)**

Index No.	Name of Unit	Annual Fixed O&M Costs					Variable Operating Requirements					
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoch.	Aux. Power Usage (MW)	Reagent	Reagent Molar Stoch.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$	\$	\$	\$	\$	None	None	-	None	None	-
2	Dave Johnston Unit 4	\$	\$	\$	\$	\$	None	None	-	None	None	-
3	Jim Bridger Unit 1	\$	\$	\$	\$	\$	None	None	-	None	None	-
4	Jim Bridger Unit 2	\$	\$	\$	\$	\$	None	None	-	None	None	-
5	Jim Bridger Unit 3	\$	\$	\$	\$	\$	None	None	-	None	None	-
6	Jim Bridger Unit 4	\$	\$	\$	\$	\$	None	None	-	None	None	-
7	Naughton Unit 1	\$	\$	\$	\$	\$	None	None	-	None	None	-
8	Naughton Unit 2	\$	\$	\$	\$	\$	None	None	-	None	None	-
9	Naughton Unit 3	\$	\$	\$	\$	\$	None	None	-	None	None	-
10.	Wyodak Unit 1.	\$	\$	\$	\$	\$	None	None	-	None	None	-

**Table 5 - Case 2 O&M Costs (LNB w/QFA)**

Index No.	Name of Unit	Annual Fixed O&M Costs					Variable Operating Requirements					
		Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoch.	Aux. Power Usage (MW)	Reagent	Reagent Molar Stoch.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$40,000	\$60,000	\$	\$	\$	None	None	-	None	None	-
2	Dave Johnston Unit 4	\$36,000	\$54,000	\$	\$	\$	None	None	-	None	None	-
3	Jim Bridger Unit 1	\$28,000	\$42,000	\$	\$	\$	None	None	-	None	None	-
4	Jim Bridger Unit 2	\$28,000	\$42,000	\$	\$	\$	None	None	-	None	None	-
5	Jim Bridger Unit 3	\$28,000	\$42,000	\$	\$	\$	None	None	-	None	None	-
6	Jim Bridger Unit 4	\$28,000	\$42,000	\$	\$	\$	None	None	-	None	None	-
7	Naughton Unit 1	\$32,000	\$48,000	\$	\$	\$	None	None	-	None	None	-
8	Naughton Unit 2	\$32,000	\$48,000	\$	\$	\$	None	None	-	None	None	-
9	Naughton Unit 3	\$24,000	\$36,000	\$	\$	\$	None	None	-	None	None	-
10.	Wyodak Unit 1.	\$	\$	\$	\$	\$	None	None	-	None	None	-

Table 6 - Case 3 O&amp;M Costs (Mohotec ROFA)

		Annual Fixed O&M Costs				Variable Operating Requirements			
Index No.	Name of Unit	Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoch.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 60,000	\$ 90,000	\$ 60,000	\$ 60,000	-	None	-	2.76
2	Dave Johnston Unit 4	\$ 64,000	\$ 81,000	\$ 42,000	\$ 63,000	-	None	-	4.33
3	Jim Bridger Unit 1	\$ 55,000	\$ 42,000	\$ 42,000	\$ 63,000	-	None	-	6.41
4	Jim Bridger Unit 2	\$ 55,000	\$ 42,000	\$ 42,000	\$ 63,000	-	None	-	6.41
5	Jim Bridger Unit 3	\$ 55,000	\$ 42,000	\$ 42,000	\$ 63,000	-	None	-	6.41
6	Jim Bridger Unit 4	\$ 55,000	\$ 42,000	\$ 42,000	\$ 63,000	-	None	-	6.41
7	Naughton Unit 1	\$ 48,000	\$ 72,000	\$ 48,000	\$ 72,000	-	None	-	1.42
8	Naughton Unit 2	\$ 48,000	\$ 72,000	\$ 48,000	\$ 72,000	-	None	-	2.61
9	Naughton Unit 3	\$ 48,000	\$ 72,000	\$ 36,000	\$ 54,000	-	None	-	4.47
10	Wyodak Unit 1	\$ 55,000	\$ 55,000	\$ 55,000	\$ 55,000	-	None	-	5.22

Table 7 - Case 4 O&amp;M Costs (LNB w/OFA &amp; SNCR)

		Annual Fixed O&M Costs				Variable Operating Requirements			
Index No.	Name of Unit	Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoch.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 98,000	\$ 147,000	\$ 105,000	\$ 167,500	-	Urea	0.41	0.23
2	Dave Johnston Unit 4	\$ 123,000	\$ 184,500	\$ 123,000	\$ 184,500	-	Urea	0.45	0.33
3	Jim Bridger Unit 1	\$ 95,000	\$ 142,500	\$ 122,000	\$ 183,000	-	Urea	0.45	0.53
4	Jim Bridger Unit 2	\$ 95,000	\$ 142,500	\$ 123,000	\$ 184,500	-	Urea	0.45	0.52
5	Jim Bridger Unit 3	\$ 95,000	\$ 142,500	\$ 93,000	\$ 133,500	-	Urea	0.45	0.53
6	Jim Bridger Unit 4	\$ 95,000	\$ 142,500	\$ 93,000	\$ 124,500	-	Urea	0.45	0.16
7	Naughton Unit 1	\$ 75,000	\$ 112,500	\$ 75,000	\$ 112,500	-	Urea	0.51	0.22
8	Naughton Unit 2	\$ 93,000	\$ 138,500	\$ 93,000	\$ 138,500	-	Urea	0.45	0.33
9	Naughton Unit 3	\$ 93,000	\$ 138,500	\$ 93,000	\$ 138,500	-	Urea	0.45	0.34
10	Wyodak Unit 1	\$ 55,000	\$ 55,000	\$ 55,000	\$ 55,000	-	Urea	-	-

Table 8 - Case 5 O&amp;M Costs (LNB w/OFA &amp; SCR)

		Annual Fixed O&M Costs				Variable Operating Requirements			
Index No.	Name of Unit	Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoch.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 155,000	\$ 232,500	\$ 166,000	\$ 249,000	-	Anhydrous NH <sub>3</sub>	1.00	1.57
2	Dave Johnston Unit 4	\$ 180,000	\$ 285,000	\$ 162,000	\$ 245,000	-	Anhydrous NH <sub>3</sub>	1.00	2.29
3	Jim Bridger Unit 1	\$ 155,000	\$ 232,500	\$ 190,000	\$ 285,000	-	Anhydrous NH <sub>3</sub>	1.00	3.23
4	Jim Bridger Unit 2	\$ 155,000	\$ 232,500	\$ 190,000	\$ 285,000	-	Anhydrous NH <sub>3</sub>	1.00	3.25
5	Jim Bridger Unit 3	\$ 155,000	\$ 232,500	\$ 190,000	\$ 285,000	-	Anhydrous NH <sub>3</sub>	1.00	200
6	Jim Bridger Unit 4	\$ 155,000	\$ 232,500	\$ 160,000	\$ 240,000	-	Anhydrous NH <sub>3</sub>	1.00	3.22
7	Naughton Unit 1	\$ 156,000	\$ 234,000	\$ 181,000	\$ 271,500	-	Anhydrous NH <sub>3</sub>	1.00	244
8	Naughton Unit 2	\$ 156,000	\$ 234,000	\$ 181,000	\$ 271,500	-	Anhydrous NH <sub>3</sub>	1.00	67
9	Naughton Unit 3	\$ 156,000	\$ 234,000	\$ 181,000	\$ 271,500	-	Anhydrous NH <sub>3</sub>	1.00	101
10	Wyodak Unit 1	\$ 156,000	\$ 234,000	\$ 181,000	\$ 271,500	-	Anhydrous NH <sub>3</sub>	1.00	167
							Anhydrous NH <sub>3</sub>	1.00	160

Table 9 - Case 6 O&amp;M Costs (Dry FGD)

		Annual Fixed O&M Costs				Variable Operating Requirements			
Index No.	Name of Unit	Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoch.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 506,128	\$ 714,175	\$ 476,928	\$ -	-	173	Lime	1.16
2	Dave Johnston Unit 4	\$ -	\$ -	\$ -	\$ -	-	-	-	-
3	Jim Bridger Unit 1	\$ -	\$ -	\$ -	\$ -	-	-	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	-	-	-	-
5	Jim Bridger Unit 3	\$ -	\$ -	\$ -	\$ -	-	-	-	-
6	Jim Bridger Unit 4	\$ -	\$ -	\$ -	\$ -	-	-	-	-
7	Naughton Unit 1	\$ 506,128	\$ 587,643	\$ 391,762	\$ -	-	120	Lime	1.40
8	Naughton Unit 2	\$ 506,128	\$ 860,174	\$ 573,044	\$ -	-	165	Lime	1.40
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	-	-	-	-
10	Wyodak Unit 1	\$ -	\$ 21,500	\$ 14,600	\$ -	-	25	Lime	1.10
									0.11

Table 10 - Case 7 O&amp;M Costs (Dry FGD w/Fabric Filter)

		Annual Fixed O&M Costs				Variable Operating Requirements			
Index No.	Name of Unit	Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoch.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 506,128	\$ 714,175	\$ 476,928	\$ -	-	173	Lime	1.16
2	Dave Johnston Unit 4	\$ 506,128	\$ 1,102,283	\$ 734,858	\$ -	-	248	Lime	1.10
3	Jim Bridger Unit 1	\$ -	\$ -	\$ -	\$ -	-	-	-	-
4	Jim Bridger Unit 2	\$ -	\$ -	\$ -	\$ -	-	-	-	-
5	Jim Bridger Unit 3	\$ -	\$ -	\$ -	\$ -	-	-	-	-
6	Jim Bridger Unit 4	\$ -	\$ -	\$ -	\$ -	-	-	-	-
7	Naughton Unit 1	\$ 506,128	\$ 632,660	\$ 459,286	\$ -	-	120	Lime	1.16
8	Naughton Unit 2	\$ 506,128	\$ 905,190	\$ 640,568	\$ -	-	165	Lime	1.15
9	Naughton Unit 3	\$ -	\$ -	\$ -	\$ -	-	-	-	-
10	Wyodak Unit 1	\$ -	\$ -	\$ -	\$ -	-	-	-	-

Table 11 - Case 8 O&amp;M Costs (Wet FGD)

		Annual Fixed O&M Costs				Variable Operating Requirements			
Index No.	Name of Unit	Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent	Reagent Molar Stoch.	Aux. Power Usage (MW)
1	Dave Johnston Unit 3	\$ 809,804	\$ 1,182,587	\$ 788,395	\$ -	-	230	Lime	1.02
2	Dave Johnston Unit 4	\$ 809,804	\$ 1,430,784	\$ 983,865	\$ -	-	330	Soda Ash	1.02
3	Jim Bridger Unit 1	\$ -	\$ 25,650	\$ 17,033	\$ -	-	63	Soda Ash	1.02
4	Jim Bridger Unit 2	\$ -	\$ 25,650	\$ 17,033	\$ -	-	53	Soda Ash	1.02
5	Jim Bridger Unit 3	\$ -	\$ 25,550	\$ 17,033	\$ -	-	62	Soda Ash	1.02
6	Jim Bridger Unit 4	\$ -	\$ 25,550	\$ 17,033	\$ -	-	27	Soda Ash	1.02
7	Naughton Unit 1	\$ 809,804	\$ 963,589	\$ 642,333	\$ -	-	160	Lime	1.05
8	Naughton Unit 2	\$ 809,804	\$ 1,225,386	\$ 817,581	\$ -	-	220	Lime	1.05
9	Naughton Unit 3	\$ -	\$ 21,900	\$ 14,600	\$ -	-	66	Soda Ash	1.02
10	Wyodak Unit 1	\$ 303,677	\$ 321,496	\$ 218,958	\$ -	-	82	Lime	1.02

Table 12 - Case 9 O&amp;M Costs (Flue Gas Conditioning)

Annual Fixed O&M Costs				Variable Operating Requirements			
Index No.	Name of Unit	Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent Usage (Lb/Hr)
1	Dave Johnston Unit 3	\$ 5	\$ 5	\$ 5	\$ 5	-	None
2	Dave Johnston Unit 4	\$ 5	\$ 5	\$ 10,000	\$ 5	-	Elemental Sulfur 100
3	Jim Bridger Unit 1	\$ 5	\$ 5	\$ 10,000	\$ 5	-	Elemental Sulfur 100
4	Jim Bridger Unit 2	\$ 5	\$ 5	\$ 10,000	\$ 5	-	Elemental Sulfur 100
5	Jim Bridger Unit 3	\$ 5	\$ 5	\$ 10,000	\$ 5	-	Elemental Sulfur 100
6	Jim Bridger Unit 4	\$ 5	\$ 5	\$ 10,000	\$ 5	-	Elemental Sulfur 33
7	Naughton Unit 1	\$ 5	\$ 5	\$ 10,000	\$ 5	-	Elemental Sulfur 43
8	Naughton Unit 2	\$ 5	\$ 5	\$ 10,000	\$ 5	-	Elemental Sulfur 67
9	Naughton Unit 3	\$ 5	\$ 5	\$ 10,000	\$ 5	-	Elemental Sulfur 63
10	Wyodak Unit 1	\$ 5	\$ 5	\$ 10,000	\$ 5	-	Elemental Sulfur 63

Table 13 - Case 10 O&amp;M Costs (Fabric Filter)

Annual Fixed O&M Costs				Variable Operating Requirements			
Index No.	Name of Unit	Oper. Labor	Maint. Materials	Maint. Labor	Admin. Labor	Makeup Water Use (Gpm)	Reagent Usage (Lb/Hr)
1	Dave Johnston Unit 3	\$ 45,016	\$ 67,524	\$ 67,524	\$ 67,524	-	None
2	Dave Johnston Unit 4	\$ 58,133	\$ 102,193	\$ 5	\$ 5	-	None
3	Jim Bridger Unit 1	\$ 61,039	\$ 78,649	\$ 78,649	\$ 78,649	-	None
4	Jim Bridger Unit 2	\$ 51,039	\$ 76,649	\$ 76,649	\$ 76,649	-	None
5	Jim Bridger Unit 3	\$ 51,039	\$ 76,649	\$ 76,649	\$ 76,649	-	None
6	Jim Bridger Unit 4	\$ 51,039	\$ 76,649	\$ 76,649	\$ 76,649	-	None
7	Naughton Unit 1	\$ 45,016	\$ 67,524	\$ 67,524	\$ 67,524	-	None
8	Naughton Unit 2	\$ 45,016	\$ 67,524	\$ 67,524	\$ 67,524	-	None
9	Naughton Unit 3	\$ 48,566	\$ 72,999	\$ 72,999	\$ 72,999	-	None
10	Wyodak Unit 1	\$ 48,566	\$ 72,999	\$ 72,999	\$ 72,999	-	None

Table 14 - Major Materials Design and Supply Costs

NOx Control				SO2 Control				PM Control			
Index No.	Name of Unit   Case →	2	3	4	5	6	7	8	9	10	
1	Dave Johnston Unit 3	\$ 3,221,912	\$ 5,556,617	\$ 5,773,000	\$ 43,365,000	\$ 83,871,000	\$ 142,077,000	\$ 108,385,669	\$ -	\$ 18,359,000	
2	Dave Johnston Unit 4	\$ 2,673,501	\$ 4,343,192	\$ 7,171,086	\$ 66,200,000	\$ 80,923,000	\$ 137,267,000	\$ 178,174,324	\$ -	\$ 30,853,530	
3	Jim Bridger Unit 1	\$ 2,981,902	\$ 6,056,955	\$ 9,328,000	\$ 80,923,000	\$ -	\$ 8,010,033	\$ -	\$ 29,814,000		
4	Jim Bridger Unit 2	\$ 6,056,955	\$ 9,328,000	\$ 80,923,000	\$ 80,923,000	\$ -	\$ 8,010,033	\$ -	\$ 29,814,000		
5	Jim Bridger Unit 3	\$ 2,981,902	\$ 6,056,955	\$ 9,419,000	\$ 80,923,000	\$ -	\$ 8,010,033	\$ -	\$ 29,814,000		
6	Jim Bridger Unit 4	\$ 2,981,902	\$ 6,056,955	\$ 9,528,000	\$ 93,008,000	\$ 26,819,000	\$ 42,301,000	\$ 34,949,000	\$ 800,000	\$ 15,482,000	
7	Naughton Unit 1	\$ 2,502,123	\$ 2,675,792	\$ 7,257,000	\$ 37,292,000	\$ 37,292,000	\$ 44,000,000	\$ 44,000,000	\$ 800,000	\$ 18,359,000	
8	Naughton Unit 2	\$ 2,570,674	\$ 3,123,533	\$ 8,784,000	\$ 47,934,000	\$ 39,262,000	\$ 67,521,000	\$ 56,000,000	\$ 800,000	\$ 20,105,000	
9	Naughton Unit 3	\$ 4,351,377	\$ 11,203,376	\$ 67,375,000	\$ 72,479,000	\$ 596,100	\$ -	\$ 2,983,000	\$ 800,000	\$ 1,247,061	
10	Wyodak Unit 1	\$ 3,187,636	\$ 4,680,245	\$ 7,234,080	\$ 72,479,000	\$ -	\$ 178,174,324	\$ 178,174,324	\$ 20,105,000	\$ 1,247,061	

## CAPITAL COST

Jim Bridger Unit 4

### Parameter

Case	NOx Control			SO2 Control			PM Control		
	LNB w/ROFA 2	LNB w/ROFA ESP	ROFA 3	LNB w/ROFA & SNCR 4	LNB w/ROFA & SCR Wet FGD ESP				
<b>CAPITAL COST COMPONENT</b>									
LNB w/ROFA or ROFA	\$2,941,982	\$2,941,982	\$2,941,982	\$2,941,982	\$2,941,982	\$2,941,982	\$2,941,982	\$2,941,982	\$2,941,982
Major Materials Design and Supply	\$2,544,638	\$2,544,638	\$2,544,638	\$2,544,638	\$2,544,638	\$2,544,638	\$2,544,638	\$2,544,638	\$2,544,638
Construction	\$1,541,451	\$1,541,451	\$1,541,451	\$1,541,451	\$1,541,451	\$1,541,451	\$1,541,451	\$1,541,451	\$1,541,451
Balance of Plant	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Electrical (Allowance)	\$395,043	\$395,043	\$395,043	\$395,043	\$395,043	\$395,043	\$395,043	\$395,043	\$395,043
Owner's Costs	\$18,226	\$18,226	\$18,226	\$18,226	\$18,226	\$18,226	\$18,226	\$18,226	\$18,226
Surcharge	\$489,905	\$489,905	\$489,905	\$489,905	\$489,905	\$489,905	\$489,905	\$489,905	\$489,905
AUDOC	\$12,256	\$12,256	\$12,256	\$12,256	\$12,256	\$12,256	\$12,256	\$12,256	\$12,256
Subtotal	\$3,834,552	\$3,834,552	\$3,834,552	\$3,834,552	\$3,834,552	\$3,834,552	\$3,834,552	\$3,834,552	\$3,834,552
Contingency	\$12.5%	\$12.5%	\$12.5%	\$12.5%	\$12.5%	\$12.5%	\$12.5%	\$12.5%	\$12.5%
Total Capital Cost for LNB w/ROFA or ROFA	\$37,700,001	\$37,700,001	\$37,700,001	\$37,700,001	\$37,700,001	\$37,700,001	\$37,700,001	\$37,700,001	\$37,700,001
SNCR or SCR									
Major Materials Design and Supply									
Contingency									
Labor Premium									
Electrical Reinforcement (Allowance)									
Sales Tax									
Escalation									
Change Order / Addendum									
Surcharge and AUDOC									
Capital Cost for SNCR or SCR									
Total Capital Cost for SNCR or SCR	\$3	\$3	\$3	\$3	\$3	\$3	\$3	\$3	\$3
<b>Capital Cost of Fabric Filter</b>									
Major Materials Design and Supply	\$1,045,600	\$1,045,600	\$1,045,600	\$1,045,600	\$1,045,600	\$1,045,600	\$1,045,600	\$1,045,600	\$1,045,600
Contingency	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Labor Premium	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Electrical Premium	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Basis Reinforcement (Allowance)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Sales Tax	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Escalation	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Change Order / Addendum	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Surcharge and AUDOC	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Capital Cost for Dry FGD, FBC or FF	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Total Capital Cost for Dry FGD, FBC or FF	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0

Jim Bridger Unit 4										
Year	Date	TOTAL FIXED O&M COST	Makup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST
0	2013	70,000	-	-	-	-	-	-	-	827,612
1	2014	71,400	-	-	-	-	-	-	-	899,012
2	2015	72,826	-	-	-	-	-	-	-	900,440
3	2016	74,245	-	-	-	-	-	-	-	901,497
4	2017	75,770	-	-	-	-	-	-	-	903,982
5	2018	77,295	-	-	-	-	-	-	-	904,998
6	2019	78,831	-	-	-	-	-	-	-	905,443
7	2020	80,408	-	-	-	-	-	-	-	908,020
8	2021	82,016	-	-	-	-	-	-	-	909,328
9	2022	83,658	-	-	-	-	-	-	-	911,659
10	2023	85,330	-	-	-	-	-	-	-	912,942
11	2024	87,036	-	-	-	-	-	-	-	914,546
12	2025	88,777	-	-	-	-	-	-	-	916,389
13	2026	90,552	-	-	-	-	-	-	-	918,165
14	2027	92,384	-	-	-	-	-	-	-	919,976
15	2028	94,211	-	-	-	-	-	-	-	921,823
16	2029	96,095	-	-	-	-	-	-	-	923,707
17	2030	98,017	-	-	-	-	-	-	-	925,629
18	2031	99,977	-	-	-	-	-	-	-	927,612
19	2032	101,977	-	-	-	-	-	-	-	927,599
20	2033	103,977	-	-	-	-	-	-	-	927,579
Present Worth		855,250	9,0%	0,0%	0,0%	0,0%	0,0%	0,0%	0,0%	8,700,001
(% of PW)										9,955,250
										96

LNB w/OFA										
Year	Date	TOTAL FIXED O&M COST	Makup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST
0	2013	-	-	-	-	-	-	-	-	897,612
1	2014	105,000	-	-	-	-	-	-	-	899,012
2	2015	107,100	-	-	-	-	-	-	-	900,440
3	2016	108,292	-	-	-	-	-	-	-	901,497
4	2017	111,427	-	-	-	-	-	-	-	903,982
5	2018	113,655	-	-	-	-	-	-	-	904,998
6	2019	115,928	-	-	-	-	-	-	-	905,443
7	2020	118,247	-	-	-	-	-	-	-	906,389
8	2021	120,612	-	-	-	-	-	-	-	908,020
9	2022	123,024	-	-	-	-	-	-	-	909,328
10	2023	125,465	-	-	-	-	-	-	-	911,659
11	2024	127,994	-	-	-	-	-	-	-	912,942
12	2025	130,554	-	-	-	-	-	-	-	914,546
13	2026	133,165	-	-	-	-	-	-	-	916,389
14	2027	135,828	-	-	-	-	-	-	-	918,165
15	2028	138,545	-	-	-	-	-	-	-	919,976
16	2029	141,316	-	-	-	-	-	-	-	921,823
17	2030	144,162	-	-	-	-	-	-	-	923,707
18	2031	147,025	-	-	-	-	-	-	-	925,629
19	2032	149,966	-	-	-	-	-	-	-	927,612
20	2033	152,965	-	-	-	-	-	-	-	927,599
Present Worth		855,250	9,0%	0,0%	0,0%	0,0%	0,0%	0,0%	0,0%	8,700,001
(% of PW)										9,955,250
										96

ROFA										
Year	Date	TOTAL FIXED O&M COST	Makup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST
0	2013	-	-	-	-	-	-	-	-	4,959,454
1	2014	105,000	-	-	-	-	-	-	-	4,959,454
2	2015	107,100	-	-	-	-	-	-	-	4,959,454
3	2016	108,292	-	-	-	-	-	-	-	4,959,454
4	2017	111,427	-	-	-	-	-	-	-	4,959,454
5	2018	113,655	-	-	-	-	-	-	-	4,959,454
6	2019	115,928	-	-	-	-	-	-	-	4,959,454
7	2020	118,247	-	-	-	-	-	-	-	4,959,454
8	2021	120,612	-	-	-	-	-	-	-	4,959,454
9	2022	123,024	-	-	-	-	-	-	-	4,959,454
10	2023	125,465	-	-	-	-	-	-	-	4,959,454
11	2024	127,994	-	-	-	-	-	-	-	4,959,454
12	2025	130,554	-	-	-	-	-	-	-	4,959,454
13	2026	133,165	-	-	-	-	-	-	-	4,959,454
14	2027	135,828	-	-	-	-	-	-	-	4,959,454
15	2028	138,545	-	-	-	-	-	-	-	4,959,454
16	2029	141,316	-	-	-	-	-	-	-	4,959,454
17	2030	144,162	-	-	-	-	-	-	-	4,959,454
18	2031	147,025	-	-	-	-	-	-	-	4,959,454
19	2032	149,966	-	-	-	-	-	-	-	4,959,454
20	2033	152,965	-	-	-	-	-	-	-	4,959,454
Present Worth		855,250	9,0%	0,0%	0,0%	0,0%	0,0%	0,0%	0,0%	8,700,001
(% of PW)										9,955,250
										96

LNB W/OFA & SNCR										
Jim Bridger Unit 4										
Year	Date	TOTAL FIXED OEM COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE OEM COST	DEBT SERVICE	TOTAL ANNUAL COST
0	2013	307,500	-	1,005,611	-	-	208,926	1,214,737	2,104,916	3,027,153
1	2014	313,650	-	1,025,927	-	-	213,105	1,239,032	2,104,916	3,057,958
2	2015	319,923	-	1,046,446	-	-	217,387	1,253,812	2,104,916	3,088,351
3	2016	326,321	-	1,067,375	-	-	222,714	1,289,088	2,104,916	3,120,326
4	2017	326,321	-	1,088,722	-	-	226,448	1,314,970	2,104,916	3,152,334
5	2018	332,848	-	1,110,496	-	-	231,074	1,341,168	2,104,916	3,185,589
6	2019	338,505	-	1,130,496	-	-	235,385	1,387,991	2,104,916	3,219,402
7	2020	346,288	-	1,152,006	-	-	239,960	1,423,258	2,104,916	3,253,188
8	2021	353,221	-	1,165,361	-	-	244,790	1,461,723	2,104,916	3,288,159
9	2022	360,285	-	1,178,468	-	-	249,886	1,480,757	2,104,916	3,324,130
10	2023	367,491	-	1,202,037	-	-	254,680	1,510,373	2,104,916	3,360,514
11	2024	374,841	-	1,228,078	-	-	259,773	1,540,580	2,104,916	3,397,526
12	2025	382,338	-	1,250,598	-	-	264,969	1,571,382	2,104,916	4,025,481
13	2026	389,984	-	1,273,611	-	-	270,388	1,602,818	2,104,916	4,074,992
14	2027	397,784	-	1,301,124	-	-	275,673	1,634,878	2,104,916	4,113,475
15	2028	405,740	-	1,327,146	-	-	281,187	1,667,573	2,104,916	4,153,846
16	2029	413,855	-	1,353,689	-	-	286,911	1,700,925	2,104,916	4,194,521
17	2030	422,132	-	1,380,763	-	-	292,547	1,734,943	2,104,916	4,236,415
18	2031	430,574	-	1,408,378	-	-	298,398	1,769,652	2,104,916	4,279,045
19	2032	438,188	-	1,436,546	-	-	304,365	1,804,352	2,104,916	4,322,526
20	2033	447,959	-	1,465,276	-	-	310,447	1,839,706	2,104,916	4,364,731
Present Worth			3,755,950	-	12,388,848	-	0.0%	2,852,527	14,841,477	22,127,238
% of PW			9.2%	-	0.0%	-	0.0%	2,852,527	14,841,477	40,725,706
						-	6.3%	38.4%	54.3%	100.0%

LNB W/OFA & SCR										
Jim Bridger Unit 4										
Year	Date	TOTAL FIXED OEM COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE OEM COST	DEBT SERVICE	TOTAL ANNUAL COST
0	2013	475,000	-	912,846	842,000	-	1,325,329	2,878,177	14,043,575	17,398,753
1	2014	484,150	-	931,105	854,840	-	1,348,796	2,835,741	14,043,575	17,465,616
2	2015	494,150	-	947,727	867,937	-	1,376,782	2,894,456	14,043,575	17,532,221
3	2016	504,074	-	965,722	881,296	-	1,405,328	3,024,545	14,043,575	17,601,594
4	2017	514,155	-	985,058	894,921	-	1,432,114	3,115,452	14,043,575	17,673,162
5	2018	524,438	-	1,007,858	907,820	-	1,461,063	3,177,740	14,043,575	17,747,754
6	2019	534,720	-	1,026,015	922,986	-	1,490,284	3,241,285	14,043,575	17,819,386
7	2020	545,626	-	1,048,575	737,456	-	1,520,090	3,306,121	14,043,575	17,895,322
8	2021	556,538	-	1,068,547	752,205	-	1,550,491	3,372,244	14,043,575	17,972,357
9	2022	567,668	-	1,080,938	767,249	-	1,581,501	3,438,988	14,043,575	18,050,933
10	2023	578,022	-	1,112,157	782,894	-	1,613,131	3,506,482	14,043,575	18,131,080
11	2024	589,603	-	1,135,012	798,246	-	1,645,394	3,578,652	14,043,575	18,219,830
12	2025	602,415	-	1,157,712	814,211	-	1,677,302	3,650,225	14,043,575	18,295,216
13	2026	614,463	-	1,180,865	830,495	-	1,711,868	3,723,228	14,043,575	18,381,566
14	2027	626,752	-	1,204,484	847,105	-	1,746,105	3,797,894	14,043,575	18,480,022
15	2028	639,287	-	1,228,573	864,047	-	1,784,027	3,873,548	14,043,575	18,585,511
16	2029	652,073	-	1,253,145	881,328	-	1,816,648	3,951,121	14,043,575	18,694,768
17	2030	665,115	-	1,278,208	901,985	-	1,852,981	4,030,143	14,043,575	18,810,883
18	2031	678,417	-	1,303,772	916,934	-	1,880,040	4,109,746	14,043,575	18,932,738
19	2032	691,985	-	1,328,847	935,273	-	1,927,841	4,189,361	14,043,575	19,052,522
20	2033	705,480	-	1,351,533	977,843	-	1,971,244	35,165,499	147,688,474	188,997,104
Present Worth			5,803,480	-	11,153,043	7,748,382	0.0%	16,161,244	35,165,499	18,656,783
% of PW			3.4%	-	5.9%	-	0.0%	8.6%	18.6%	100.0%


Upgraded Wet FGD										
Jim Bridger Unit 4										
Year	Date	TOTAL FIXED O&M COST	Makewp Water Cost	Reagent Cost	SCR Catalyst/FF Back Cast	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST
0	2013	42,583	15,539	213,921	177,714	208,826	616,100	547,918	1,206,604	761
1	2014	43,435	15,850	218,99	181,268	628,422	628,422	547,918	1,219,275	770
2	2015	44,303	16,167	222,963	184,893	640,990	547,918	1,233,212	778	
3	2016	45,168	16,480	227,014	188,591	221,714	547,918	1,245,918	787	
4	2017	46,093	16,820	231,565	192,363	230,148	547,918	1,260,968	796	
5	2018	47,015	17,157	236,166	195,210	230,571	547,918	1,275,158	805	
6	2019	47,955	17,500	245,918	200,135	235,285	547,918	1,288,702	814	
7	2020	48,914	17,850	245,728	204,137	239,960	547,918	1,304,438	823	
8	2021	49,883	18,207	250,642	208,230	244,780	547,918	1,319,370	833	
9	2022	50,850	18,587	255,855	212,384	248,886	547,918	1,335,105	843	
10	2023	51,908	18,942	260,768	216,682	254,980	547,918	1,350,149	852	
11	2024	52,946	19,321	265,384	220,855	259,773	547,918	1,365,108	863	
12	2025	54,005	19,707	271,303	225,384	264,969	547,918	1,383,288	873	
13	2026	55,085	20,102	276,729	229,882	270,268	547,918	1,399,995	884	
14	2027	55,187	20,504	282,664	234,490	275,573	547,918	1,417,136	894	
15	2028	57,311	20,914	287,909	238,178	281,187	547,918	1,434,119	905	
16	2029	56,457	21,332	293,987	243,963	284,811	547,918	1,452,149	916	
17	2030	56,626	21,759	298,341	248,842	289,547	547,918	1,470,338	928	
18	2031	56,819	22,194	302,942	253,819	298,398	547,918	1,488,880	939	
19	2032	62,035	22,638	311,642	258,895	304,365	547,918	1,507,955	951	
Present Worth		520,271	188,856	2,816,653	-	2,171,232	2,852,227	7,527,418	13,307,033	436
% of PW		3.8%	1.4%		0.0%	15.7%	18.5%	54.5%	41.7%	100.0%

Flue Gas Conditioning										
Jim Bridger Unit 4										
Year	Date	TOTAL FIXED O&M COST	Makewp Water Cost	Reagent Cost	SCR Catalyst/FF Back Cast	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST
0	2013	10,000	-	145,554	-	-	19,710	165,564	-	175,564
1	2014	10,200	-	148,574	151,747	20,506	188,875	172,253	179,075	182,657
2	2015	10,404	-	150,612	154,781	20,916	175,898	178,898	186,310	190,036
3	2016	10,612	-	157,677	161,035	21,335	179,212	182,756	189,937	197,714
4	2017	10,824	-	164,555	164,555	21,761	185,452	186,452	190,868	201,868
5	2018	11,041	-	167,540	170,981	22,197	189,181	197,854	205,701	214,012
6	2019	11,262	-	171,309	177,795	22,641	193,886	201,822	216,922	222,558
7	2020	11,487	-	176,345	181,351	23,555	197,854	201,822	222,827	228,286
8	2021	11,717	-	180,981	186,309	24,026	201,922	201,922	241,012	245,432
9	2022	11,951	-	184,230	187,351	24,407	205,958	205,958	250,749	255,764
10	2023	12,190	-	188,795	192,978	24,897	208,375	208,375	252,111	258,153
11	2024	12,434	-	193,451	197,451	25,487	214,175	214,175	258,837	263,837
12	2025	12,682	-	198,978	202,315	26,007	219,458	222,827	261,012	267,012
13	2026	12,936	-	204,545	206,231	26,527	227,989	227,989	271,830	278,830
14	2027	13,185	-	208,300	208,315	-	231,830	231,830	286,056	293,056
15	2028	13,459	-	210,226	208,315	-	236,151	236,151	297,764	304,764
16	2029	13,728	-	214,282	212,179	-	240,814	241,155	309,035	316,035
17	2030	14,002	-	218,179	212,179	-	242,887	243,132	319,006	326,006
18	2031	14,282	-	222,179	212,179	-	244,887	245,132	329,006	336,006
19	2032	14,568	-	226,179	212,179	-	246,887	247,132	339,006	346,006
20	2033	14,854	-	230,179	212,179	-	248,887	249,132	349,006	356,006
Present Worth		122,179	5.7%	0.0%	1,782,023	63.1%	0.0%	0.1%	11.2%	1,782,023
% of PW										

Jim Bridger Unit 4										Fabric Filter		
Year	Date	TOTAL FIXED O&M COST	Makeup Water Cost	Reagent Cost	SCR Catalyst / FF Bag Cost	Waste Disposal Cost	Electric Power Cost	TOTAL VARIABLE O&M COST	DEBT SERVICE	TOTAL ANNUAL COST	Control Cost (\$ton PM Removed)	
0	2013				300,040		1,335,944	1,655,984	4,602,887	6,366,619	17,946	
1	2014	127,749	130,304		305,041	1,362,663	1,658,703	4,602,887	5,401,994	18,046		
2	2015	130,304	32,910		312,162	1,389,516	1,702,078	4,602,887	5,437,974	18,147		
3	2016		135,568		318,405	1,417,714	1,736,119	4,602,887	5,474,573	18,251		
4	2017	135,568	138,279		324,773	1,446,059	1,770,841	4,602,887	5,512,007	18,356		
5	2018	141,045			331,268	1,474,980	1,806,258	4,602,887	5,550,190	18,454		
6	2019		143,886		337,884	1,504,950	1,842,983	4,602,887	5,589,136	18,574		
7	2020	146,743	8		344,652	1,534,579	1,879,231	4,602,887	5,628,951	18,686		
8	2021	148,743	149,978		351,545	1,565,271	1,916,816	4,602,887	5,669,380	18,800		
9	2022		152,671		358,576	1,595,577	1,955,152	4,602,887	5,710,710	18,916		
10	2023		155,725		365,747	1,628,508	1,984,255	4,602,887	5,752,986	19,035		
11	2024		158,839		373,062	1,661,078	2,034,140	4,602,887	5,795,365	19,156		
12	2025		162,016		380,523	1,694,900	2,074,823	4,602,887	6,839,726	19,280		
13	2026		165,256		388,134	1,728,186	2,116,319	4,602,887	6,884,462	19,406		
14	2027		169,562		395,896	1,762,749	2,156,546	4,602,887	6,930,091	19,535		
15	2028		171,933		403,814	1,795,004	2,201,819	4,602,887	6,976,938	19,666		
16	2029		175,371		411,891	1,833,985	2,245,885	4,602,887	7,024,113	19,800		
17	2030		178,879		420,126	1,870,844	2,280,772	4,602,887	7,072,538	19,936		
18	2031		182,456		428,531	1,908,057	2,336,588	4,602,887	7,121,351	20,076		
19	2032		186,106		437,102	1,946,218	2,383,319	4,602,887	7,172,312	20,218		
20	2033		189,813	2.2%	0.0%	3,665,845	19,988,210	48,386,333	69,325,556	100.0%	9,857	
Present Worth						0.0%	23.3%	55.2%	69.2%			


### First Year Cost for Air Pollution Control Options



EY102007001SLC\App A\_PCorp JB4 BART Economic Analysis\_01-11-07.xls

1 of 1

### **Present Worth Cost for Air Pollution Control Options**



EY\02007001\SLC\app A\_PCorp JB4 BART Economic Analysis\_01-11-07.xls

1 of 1

**APPENDIX B**

**2006 Wyoming BART Protocol**

## **BART Air Modeling Protocol**

### **Individual Source Visibility Assessments for BART Control Analyses**

**September, 2006**

**State of Wyoming  
Department of Environmental Quality  
Air Quality Division  
Cheyenne, WY 82002**

## Table of Contents

1.0	INTRODUCTION .....	3
2.0	OVERVIEW .....	4
3.0	EMISSIONS DATA FOR MODELING .....	7
3.1	Baseline Modeling .....	7
3.2	Post-Control Modeling.....	8
4.0	METEOROLOGICAL DATA.....	9
5.0	CALPUFF MODEL APPLICATION.....	12
6.0	POST PROCESSING .....	15
7.0	REPORTING .....	19

## 1.0 INTRODUCTION

The U.S. EPA has issued final amendments to the Regional Haze Regulations, along with Guidelines for Best Available Retrofit Technology (BART) Determinations.<sup>(1)</sup> The guidelines address the methodology for determining which facilities must apply BART (sources subject-to-BART) and the evaluation of control options.

The State of Wyoming used air quality modeling in accordance with the EPA Guidelines to determine the Wyoming sources which are subject-to-BART. This Protocol defines the specific methodology to be used by those sources for determining the improvement in visibility to be achieved by BART controls.

The methodology presented in this Protocol is consistent with EPA guidance and the Air Quality Division (AQD) determination of subject-to-BART sources. It is intended that all Wyoming sources that must conduct BART analyses will use this Protocol for their evaluation of control technology visibility improvement. Any deviations from the procedures described herein must be approved by the Division prior to implementation.

---

<sup>(1)</sup> 40 CFR Part 51; Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations; Final Rule. 70 Federal Register, 39103-39172, July 6, 2005.

## 2.0 OVERVIEW

Wyoming AQD determined that eight facilities (sources) in the state are subject-to-BART. The sources are listed in Table 1. Division modeling indicated that each of these sources causes or contributes to visibility impairment in one or more Class I areas. Each source must conduct a BART analysis to define Best Available Retrofit Technology (BART) applicable to that source, and quantify the improvement in Class I visibility associated with BART controls. This Protocol sets out the procedures for quantifying visibility improvement. Other aspects of the full BART analysis are not addressed here.

There are many Class I areas within and surrounding Wyoming (See Figure 1). On the basis of distance from subject-to-BART sources, topography, meteorology, and prior modeling, the AQD has determined that only five Class I areas need be addressed in BART individual source analyses. These are Badlands and Wind Cave National Parks in South Dakota, Mt. Zirkel Wilderness Area in Colorado, and Bridger and Fitzpatrick Wilderness Areas in Wyoming. Sources in eastern Wyoming have been shown to have greatest visibility impacts at the two South Dakota Class I areas, and western Wyoming sources have maximum impacts at Bridger and Fitzpatrick Wilderness Areas, and Mt. Zirkel. Visibility improvement at these highest impact areas will provide the best measure of the effectiveness of BART controls.

Each facility should carry out modeling with the CALPUFF modeling system for the Class I areas specified in Table 2. The AQD will provide meteorological input for CALMET for the years 2001, 2002, and 2003. The model domain covered by the AQD meteorological data is centered in southwest Wyoming, and extends roughly from Twin Falls, ID in the west to the Missouri River in the east, and from Denver in the south to Helena, MT in the north. The domain is shown, along with Class I areas, in Figure 1.

Sources may wish to utilize a smaller domain for CALPUFF modeling. Smaller domains are acceptable if they provide adequate additional area beyond the specific source and Class I areas being addressed. Figure 1 includes a "southwest Wyoming" domain which represents the minimum acceptable area for sources impacting the Bridger and Fitzpatrick Wilderness Areas, and the Mt. Zirkel Wilderness Area, and a "northeast Wyoming" domain as a minimum area for Badlands and Wind Cave National Parks modeling.

The CALPUFF model should be used with each of the three years of meteorological data to calculate visibility impacts for a baseline (existing emissions) case, and for cases reflecting BART controls. The control scenarios are to include individual scenarios for proposed BART controls for each pollutant ( $\text{SO}_2$ ,  $\text{NO}_x$ , and particulate matter); and a combined scenario representing application of all proposed BART controls. If desired, additional modeling may be performed for controls that are not selected as BART. This might be done, for example, to provide data useful in identifying the control technologies that represent BART. However, visibility modeling is required only for the proposed BART controls.

Table 1. Wyoming Sources Subject-to-BART

Basin Electric	Laramie River Power Plant	Boilers #1,2,3
FMC Corporation	Granger Soda Ash Plant	Boilers #1,2
FMC Corporation	Green River Sodium Plant	Three boilers
General Chemical Co.	Green River Soda Ash	Two boilers
PacifiCorp	Dave Johnson Power Plant	Boilers #3,4
PacifiCorp	Jim Bridger Power Plant	Boilers #1-4
PacifiCorp	Naughton Power Plant	Boilers #1,2,3
PacifiCorp	Wyodak Power Plant	Boiler

Results of visibility modeling will be presented as a comparison between baseline impacts and those calculated for the BART control scenarios. Quantitative measures of impact will be the 98<sup>th</sup> percentile deciview change ( $\Delta dv$ ) relative to the 20% best days natural background, and the number of days with deciview change exceeding 0.5 (EPA Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations, 70 FR 39103). Results should be presented for each year.

Table 2. Source-Specific Class I Areas to be Addressed

Source	Class I Areas to be Evaluated
Basin Electric Laramie River	Wind Cave NP, Badlands NP
FMC Corporation Granger Soda Ash	Bridger WA, Fitzpatrick WA
FMC Corporation Sodium Products	Bridger WA, Fitzpatrick WA
General Chemical Green River Soda Ash	Bridger WA, Fitzpatrick WA
Pacificorp Dave Johnston	Wind Cave NP, Badlands NP
Pacificorp Jim Bridger	Bridger WA, Fitzpatrick WA, Mt. Zirkel WA
Pacificorp Naughton Plant	Bridger WA, Fitzpatrick WA
Pacificorp Wyodak	Wind Cave NP; Badlands NP

### **3.0 EMISSIONS DATA FOR MODELING**

CALPUFF model input requires source (stack) – specific emission rates for each pollutant, and stack parameters (height, diameter, exit gas temperature, and exit gas velocity). Per EPA BART guidance, these parameters must be representative of maximum actual 24-hour average emitting conditions for baseline (existing) operation, and maximum proposed 24-hour average emissions for future (BART) operations.

#### **3.1 Baseline Modeling**

Sources are required to utilize representative baseline emission conditions if data are available; baseline emissions must be documented. Possible sources of emission data are stack tests, CEM data, fuel consumption data, etc. Remember that emissions should represent maximum 24-hour rates. EPA BART guidance states that you should “Use the 24-hour average-actual emission-rate from the highest emitting day of the meteorological period modeled (for the pre-control scenario).” Thus, baseline conditions should reference data from 2001 through 2003 (or 2004).

As a minimum, modeled emissions must include:

SO <sub>2</sub>	sulfur dioxide
NO <sub>x</sub>	oxides of nitrogen
PM <sub>2.5</sub>	particles with diameter less than 2.5µm
PM <sub>10-2.5</sub>	particles with diameters greater than 2.5µm but less than or equal to 10 µm

If the fraction of PM<sub>10</sub> in the PM<sub>2.5</sub> (fine) and PM<sub>10-2.5</sub> (coarse) categories cannot be determined all particulate matter should be assumed to be PM<sub>2.5</sub>.

In addition, direct emissions of sulfate (SO<sub>4</sub>) should be included where possible. Sulfate can be emitted as sulfuric acid (H<sub>2</sub>SO<sub>4</sub>), sulfur trioxide (SO<sub>3</sub>), or as sulfate compounds; emissions should be quantified as the equivalent mass of SO<sub>4</sub>.

When test or engineering data are not available to specify SO<sub>4</sub> emissions or the relative fractions of fine and coarse particles, use can be made of speciation profiles available from Federal Land Managers at the website <http://www2.nature.nps.gov/air/permits/ect/index.cfm>. Profiles are available for a number of source type and control technology combinations. The FLM speciation factors are acceptable if data are available for the appropriate source type.

Emissions of VOC (volatile organic compounds), condensable organics measured in stack tests, and elemental carbon components of PM<sub>10</sub> do not need to be included for BART modeling. The only other pollutant noted in EPA BART guidance is ammonia (NH<sub>3</sub>). Though ammonia is not believed to be a significant contributor to visibility

impairment in most cases in Wyoming, it could be important for sources with significant ammonia emissions — for example from some NO<sub>x</sub> control systems. Sources that are expected to emit ammonia (in pre-or post-control configurations) should include ammonia emissions in their model input.

If quantitative baseline emissions data are unavailable and sources believe that the maximum 24-hour emission rates estimated by the Division (presented in the Subject-to-BART final report) are representative of baseline conditions for their facility, they may be used for baseline modeling. However, emissions of sulfate and ammonia (if applicable) should be included based on the best available test information or speciation factors from current literature.

### 3.2 Post-Control Modeling

All pollutants described above should be included for each post-control scenario. Post-control emissions (maximum 24-hour average) will generally be the baseline emissions multiplied by a control factor appropriate to the BART control. However, some proposed controls may simply increase the efficiency of existing controls; others may result in an increase in emissions of one pollutant while controlling another. These factors must all be considered in defining emission rates for post-control modeling. Any changes in stack parameters resulting from control application must also be included.

The required visibility assessment will include the effect of each proposed BART control. For example, if a source proposes to add a scrubber for SO<sub>2</sub> control, low NO<sub>x</sub> burners for NO<sub>x</sub> control, and a baghouse for particulate control, four sets of visibility results should be developed:

- Use of SO<sub>2</sub> control alone
- Use of NO<sub>x</sub> control alone
- Use of particulate control alone
- Use of proposed combination of all three controls

All pollutants should be modeled in each CALPUFF model run, but the modeled emissions should reflect only the specific controls or combination of controls addressed in that run.

Additional modeling could be necessary in situations where a facility is comprised of more than one subject-to-BART source, and different BART controls are applicable to different sources. Excessive modeling to address multiple control combinations is not necessary; however, visibility modeling should quantify the effect of BART controls on all affected sources for each pollutant, and of all facility BART controls combined.

#### 4.0 METEOROLOGICAL DATA

Wyoming AQD will provide MM5 meteorological data fields for years 2001, 2002, and 2003 that can be utilized as input to CALMET. The MM5 output will have 12 kilometer resolution and cover the full domain shown in Figure 1.

Mesoscale meteorological data (MM5) were developed and evaluated as part of the AQD's southwest Wyoming NO<sub>2</sub> increment analysis. Three years of MM5 data at 36 km resolution were used to initialize 12 km MM5 simulations. The 12km MM5 modeling used identical physics options to the original 36 km runs. CALMM5 was then used as a preprocessor to produce CALMET - ready MM5 data input files. Quality assurance was performed by comparing the original MM5 output on the 36km national RPO grid to the 12 km MM5 output and observations.

The CALMET model (version 5.53a, level 040716) should be used to prepare meteorological input for CALPUFF. The user may select a domain smaller than the MM5 domain for CALMET and CALPUFF modeling if desired. Figure 1 shows minimum domain areas for modeling of western and eastern Wyoming BART sources. Four kilometer resolution should be specified for CALMET output.

CALMET processing should use the AQD MM5 data, and appropriate surface, upper air, and precipitation data. Figure 2 shows the locations of surface and upper air stations within the MM5 model domain. The MM5 data are used as the initial guess wind field; this wind field is then adjusted by CALMET for terrain and land use to generate a step 1 wind field, and refined using surface and upper air data to create the final step 2 wind field.

Surface, upper air, and precipitation data can be obtained from the National Climatic Data Center. Land use and terrain data are available from the U.S. Geological Survey. Data can be formatted for use in CALMET with standard conversion and processing programs available with the CALMET/CALPUFF software.

Table 3 provides a listing of applicable CALMET input variables for BART meteorological processing. The table includes inputs that are specific to Wyoming BART modeling. Inputs not shown in Table 3 are not relevant to the present application, are dependent on the specific model domain of the user, use model default values, or are obvious from the context.

Table 3. CALMET Control File Inputs

Variable	Description	Value
Input Group 1		
IBYR	Year	2001
		2002
		2003
IBTZ	Base time zone	7
IRTYPE	Run type	1
LCALGRD	Compute data fields for CALGRID	T
Input Group 2		
PMAP	Map projection	LCC
DGRIDKM	Grid spacing (km)	4
NZ	Number of layers	10
ZFACE	Cell face heights (m)	0
		20
		40
		100
		140
		320
		580
		1020
		1480
		2220
		3500
Input Group 4		
NOOBS	No observation Mode	0
Input Group 5		
IWFCD	Model selection variable	1
IFRADJ	Froude number adjustment	1
IKINE	Kinematic effects	0
IOBR	Use O'Brien procedure	0
ISLOPE	Slope flow effects	1
IEXTRP	Extrapolate surface wind observations	-4
ICALM	Extrapolate calm surface winds	0
BIAS	Biases for weights of surface and upper air stations	All 0
RMIN2	Minimum distance for extrapolation	-1
IPROG	Use gridded prognostic model output	14
ISTEPPG	Time Step (hours)	1
LVARY	Use varying radius of influence	F

Table 3. CALMET Control File Inputs (continued)

Variable	Description	Value
RMAX 1	Maximum radius of influence (km)	30
RMAX 2	Maximum radius of influence (km)	50
RMIN	Minimum radius of influence (km)	0.1
TERRAD	Radius of influence for terrain (km)	15
R1	Relative weighting of first guess wind field and observations (km)	5
R2	Relative weighting aloft (km)	25
IDIOPT 1	Surface temperature	0
IDIOPT 2	Upper air lapse rate	0
ZUPT	Lapse rate depth (m)	200
IDIOPT 3	Average wind components	0
IUPWND	Upper air station	-1
ZUPWND (1)	Bottom and top of layer for domain scale winds (m)	1, 1000
ZUPWND (2)		1, 1000
IDIOPT4	Surface wind components	0
IDIOPT5	Upper air wind components	0
Input Group 6		
IAVEZI	Spatial averaging	1
MNMMDAV	Max search radius	1
HAFANG	Half angle for averaging (deg)	30
ILEVZI	Layer of winds in averaging	1
ZIMAX	Maximum overland mixing height (m)	3500
ITPROG	3D temperature source	1
IRAD	Interpolation type	1
TRADKM	Radius of influence - temperature (km)	500
NUMTS	Maximum number of Stations	5
IAVET	Spatial averaging of temperatures	1
NFLAGP	Precipitation interpolation	2

## 5.0 CALPUFF MODEL APPLICATION

The CALPUFF model (version 5.711a, level 040716) will be used to calculate pollutant concentrations at receptors in each Class I area. Application of CALPUFF should, in general, follow the guidance presented in the Interagency Workgroup on Air Quality Modeling (IWAQM) Phase 2 report (EPA - 454/R98-019) and the EPA Regional Haze Regulations and Guidelines for BART Determinations (70 FR 39103).

Appropriate CALPUFF control file inputs are in Table 4. Note should be taken of the basis for several of the recommended CALPUFF inputs.

- Building downwash effects need not be included. Because of the transport distances involved and the fact that most sources have tall stacks, building downwash is unlikely to have a significant effect on model-predicted concentrations
- Puff splitting is not required. The additional computation time necessary for puff splitting is not justified for purposes of BART analyses.
- Hourly ozone files should be used to define background ozone concentration. Data are available from the following sites within the model domain.

Rocky Mountain NP, CO  
Craters of the Moon NP, ID  
AIRS - Highland UT  
Mountain Thunder, WY  
Yellowstone NP, WY  
Centennial, WY  
Pinedale, WY

The background ozone concentration shown in Table 4 is used only when hourly data are missing.

- A constant background ammonia concentration of 2.0 ppb is specified. This value is based upon monitoring data from nearby states and IWAQM guidance. Experience suggests that 2.0 ppb is conservative in that it is unlikely to significantly limit nitrate formation in the model computations.
- MBSOPUFF II chemical transformation rates should be used.
- The species to be modeled should be the seven identified in CALPUFF: SO<sub>2</sub>, SO<sub>4</sub>, NO<sub>x</sub>, HNO<sub>3</sub>, NO<sub>3</sub>, PM<sub>2.5</sub>, and PM<sub>10.2.5</sub>. If ammonia (NH<sub>3</sub>) is emitted it should be added to the species list. In most cases, all pollutants modeled will also be emitted, except for HNO<sub>3</sub> and NO<sub>3</sub>.

Concentration calculations should be made for receptors covering the areas of the Class I areas being addressed. Receptors in each Class I area will be those designated by the Federal Land Managers and available from the National Park Service website.

Table 4. CALPUFF Control File Inputs

Variable	Description	Value
	Input Group 1	
METRUN	Control parameter for running all periods in met file	1
IBYR	Starting year	2001 2002 2003
XBTZ	Base time zone	7
NSPEC	Number of chemical species modeled	7 (or 8)
NSE	Number of species emitted	5 (or 6)
METFM	Meteorological data format	1
	Input Group 2	
MGAUSS	Vertical distribution in near field	1
MCTADI	Terrain adjustment method	3
MCTSG	Subgrid scale complex terrain	0
MSLUG	Elongated puffs	0
MTRANS	Transitional plume rise	1
MTIP	Stack tip downwash	1
MSHEAR	Vertical wind shear	0
MSPLIT	Puff splitting allowed?	0
MCHEM	Chemical mechanism	1
MAQCHEM	Aqueous phase transformation	0
MWET	Wet removal	1
MDRY	Dry deposition	1
MDISP	Dispersion Coefficients	3
MROUGH	Adjust sigma for roughness	0
MPARTL	Partial plume penetration of inversions	1
MPDF	PDF for convective conditions	0
	Input Group 4	
PMAP	Map projection	LCC
DGRIDKM	Grid spacing	4

Table 4. CALPUFF Control File Inputs (continued)

ZFACE	Cell face heights (m)	0 20 40 100 140 320 580 1020 1480 2220 3500
Input Group 6		
NHILL	Number of terrain features	0
Dry Gas Depo	Chemical parameters for dry gas deposition	Defaults
Input Group 7		
Dry Part. Depo	Size parameters for dry particle deposition SO <sub>4</sub> , NO <sub>3</sub> , PM25 PM10	Defaults 6.5, 1.0
Input Group 8		
MOZ	Ozone Input option	1
BCK03	Background ozone – all months (ppb)	44.0
BCKNH3	Background ammonia – all months (ppb)	2.0
Input Group 11		
XMAXZI	Maximum mixing height (m)	3500
XMINZI	Minimum mixing height (m)	50
Input Group 12		

## 6.0 POST PROCESSING

Visibility impacts are calculated from the CALPUFF concentration results using CALPOST. CALPOST version 5.51, level 030709 should be used; the output from CALPOST will provide the highest deciview impact on each day from all receptors within each Class I area modeled.

For some CALPUFF applications such as deposition calculations, the POSTUTIL program is used prior to CALPOST. POSTUTIL is also used to repartition total nitrate by accounting for ammonia limiting. The ammonia limiting calculation in POSTUTIL should not be applied for Wyoming BART modeling. If you believe that ammonia limiting is appropriate for a specific BART analysis, justification should be discussed with the Division prior to its used.

Visibility calculations by CALPOST for BART purposes use Method 6. This method requires input of monthly relative humidity factors, f(RH), for each Class I area. The EPA guidance document provides appropriate data for each area. Table 5 lists monthly f(RH) factors to use for the Wyoming, Colorado, and South Dakota areas to be addressed in BART modeling. The factors shown in Table 5 include averages for the adjacent Class I areas, and are within 0.2 units of the Guideline table values for the individual Class I areas.

Natural background conditions as a reference for determination of the delta-dv change due to a source should be representative of the 20% best natural visibility days. EPA BART guidance provides the 20% best days deciview values for each Class I area on an annual basis, but does not provide species concentration data for the 20% best background conditions. These concentrations are needed for input to CALPOST.

Annual species concentrations corresponding to the 20% best days were calculated for each Class I area to be addressed; by scaling back the annual average concentrations given in Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Rule (Table 2-1). A separate scaling factor was derived for each Class I area such that, when multiplied by the Guidance table annual concentrations, the 20% best days deciview value for that area would be calculated. The scaled aerosol concentrations were averaged for the Bridger and Fitzpatrick WAs, and for Wind Cave and Badlands NPs, because of their geographical proximity and similar annual background visibility. The 20% best days aerosol concentrations to be used for each month for Wyoming BART evaluations are listed in Table 6.

Table 7 is a list of inputs for CALPOST. These inputs should be used for all BART visibility calculations. Output from CALPOST should be configured to provide a ranked list of the highest delta-deciview values in each Class I area. The 98<sup>th</sup> percentile delta-deciview value and the number of values exceeding 0.5 can then be determined directly from the CALPOST output.

Table 5. Monthly f(RH) Factors for Class I Areas

Month	Wind Cave NP Badlands NP	Bridger WA Fitzpatrick WA	Mt. Zirkel WA
January	2.65	2.50	2.20
February	2.65	2.30	2.20
March	2.65	2.30	2.00
April	2.55	2.10	2.10
May	2.70	2.10	2.20
June	2.60	1.80	1.80
July	2.30	1.50	1.70
August	2.30	1.50	1.80
September	2.20	1.80	2.00
October	2.25	2.00	1.90
November	2.75	2.50	2.10
December	2.65	2.40	2.10

Table 6. Natural Background Concentrations of Aerosol Components for 20% Best Days for BART Analyses ( $\mu\text{g}/\text{m}^3$ )

Aerosol Component	Wind Cave NP Badlands NP	Fitzpatrick WA Bridger WA	Mt. Zirkel WA
Ammonium Sulfate	.047	.045	.046
Ammonium Nitrate	.040	.038	.038
Organic Carbon	.186	.178	.179
Elemental Carbon	.008	.008	.008
Soil	.198	.189	.190
Coarse Mass	1.191	1.136	1.141

Table 7. CALPOST Control File Inputs

Variable	Description	Value
	Input Group 1	
ASPEC	Species to Process	VISIB
ILAYER	Layer/deposition code	1
A,B	Scaling factors	0,0
LBACK	Add background concentrations?	F
BTZONE	Base time zone	7
LVSO4	Species to be included in extinction	T
LVNO3		T
LVOC		F
LVPMC		T
LVPMF		T
LVEC		F
LVBK	Include background?	T
SPECPMC	Species name for particulates	PM10
SPECPMF		PM25
EPMC	Extinction efficiencies	0.6
EPMF		1.0
EPMCBK		0.6
EESO4		3.0
EENO3		3.0
EEOC		4.0
ERSOIL		1.0
EEEC		10.0
MVISBK	Visibility calculation method	6
RHFAC	Monthly RH adjustment factors	Table 5
BKSO4	Background concentrations	Table 6
BKNO3		Table 6
BKPMC		Table 6
BK OC		Table 6
BKSOIL		Table 6
BKEC		Table 6
BEXTRAY	Extinction due to Rayleigh scattering	10.0

## 7.0 REPORTING

A report on the BART visibility analysis should be submitted that clearly compares impacts for post-control emissions to those for baseline emissions. Data for baseline and BART scenarios should include both the 98<sup>th</sup> percentile values and the number of days with delta-deciview values exceeding 0.5. Results should be given for each model year.

Table 8 is an example of a recommended format for presentation of model input and model results. The example is for baseline conditions; similar tables should be provided for each control scenario (SO<sub>2</sub>, NO<sub>x</sub>, and PM10) and for the combination of all BART controls. Your report tables need not follow the exact format shown in Table 8; but the same information should be provided in a concise and clear form. If additional scenarios were modeled or you wish to present supplemental information, they should be provided in an appendix or separate from the specified final results.

Table 8. Example Format for Presentation of Model Input and Results

## Baseline Visibility Modeling Results