



Department of Environmental Quality

To protect, conserve, and enhance the Quality of Wyoming's environment for the benefit of current and future generations



Matthew H. Mead, Governor

Todd Parfitt, Director

February 25, 2016

City of Gillette
Evan Byrd
P.O. Box 3033
Gillette, WY 82717

RE: Letter of Compliance for Notice of Violation Docket Number 5624-15
City West Fueling Facility
Storage Tank Facility Number 0-004301

Dear Mr. Byrd

On November 9, 2015, Notice of Violation Docket (NOV) Number 5624-15 was issued to the City of Gillette for failure to perform a minimum site assessment (MSA) when an underground storage tank (UST) system is between 18 and 20 years of age. The NOV ordered the City of Gillette to perform an MSA.

An MSA report dated February 15, 2016, was submitted to the Department and it appears that City West Fueling Facility is now in compliance with WWQRR, Chapter 17. For these reasons, the DEQ Storage Tank Program now considers NOV Docket Number 5624-15 resolved.

If you have any questions regarding this matter, please feel free to contact me at (307)777-7097 or my email address is oma.gilbreth@wyo.gov.

Sincerely,

Oma K. Gilbreth IV
Storage Tank Program Compliance Supervisor
Solid and Hazardous Waste Division

cc. Facility File 0-004301
EQC

200 West 17th Street · 2nd Floor · Cheyenne, WY 82002 · [http:// deq.wyoming.gov/](http://deq.wyoming.gov/)

ADMIN/OUTREACH (307) 777-7758 FAX 635-1784	ABANDONED MINES (307) 777-6145 FAX 635-1784	AIR QUALITY (307) 777-7391 FAX 635-1784	INDUSTRIAL SITING (307) 777-7369 FAX 635-1784	LAND QUALITY (307) 777-7756 FAX 635-1784	SOLID & HAZ. WASTE (307) 777-7752 FAX 635-1784	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---

