

CHAPTER 25

SEPTIC TANKS, ~~AND/OR~~ SOIL ABSORPTION SYSTEMS, AND OTHER SMALL  
 WASTEWATER SYSTEMS

Section 1. ~~General~~ Authority.

This rule is promulgated pursuant to Wyoming Statutes (W.S.) 35-11-101 through 35-11-1904, specifically 35-11-302(a)(iii).

Section 2. ~~Definitions~~ Objective.

~~(formerly Section 1)~~ This ~~part~~ Chapter contains the minimum standards for the design and construction of ~~sewerage small wastewater systems, treatment works and disposal systems for domestic wastes and industrial wastes generated by facilities other than specifically covered by other parts of this Chapter~~ which that are defined by W.S. 35-11-103(c)(ix). In addition, this Chapter contains the minimum standards for the design and construction of Underground Injection Control (UIC) Class V facilities 5C1-5C3, 5C6, 5D1, 5E1, 5E3-5E5 as defined in Chapter ~~46-27, Appendices A and B-C and D.~~

The following situations will require the application package to be sealed, signed, and dated by a professional engineer (PE): non-domestic wastewater from commercial and industrial facilities, high strength wastewater, individual permits to construct, or standard soil absorption systems with a soil percolation rate ~~which that~~ is either less than 5 minutes per inch (mpi) or more than 60 minutes per inch (mpi).

These standards pertain to permits required pursuant to Chapters 3 and 25, Wyoming Water Quality Rules and Regulations. The installation of all components of a small wastewater system require a permit to construct. Permits to construct are specified throughout this chapter as general permits, described in Chapter 3, Section 7; permit by rule, described in Chapter 3, Section 8; or as individual permits to construct, described in Chapter 3, Section 6.

Section 3. ~~Design Flows~~ Timing of Compliance with These Regulations.

Any Chapter 3 permit-to-construct issued for facilities ~~otherwise~~ subject to this chapter prior to the effective date of these regulations, and any facility authorized under the Division's "General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility" shall remain covered under those permits. New construction following the effective date of this regulation must obtain authorization under a new permit or modification of existing permitted facilities.

Section 4. ~~Isolation~~ Definitions.

(a) ~~"Absorption system" means a system constructed under the surface of the ground which receives and distributes effluent from a pretreatment device effectively filtering the effluent through soil or media.~~ "100 year floodplain" means a tract of land throughout a watershed that has a one-in-one hundred chance or occurrence of flooding in any given year or a return period of once every 100 years, as determined by the United States Geological Survey (USGS), Federal Emergency Management Agency (FEMA) or a local planning and development authority.

51 (b) ~~“Aerobic unit” means a covered, watertight receptacle which receives wastewater.~~  
52 ~~The unit removes settleable solids, floatable material, and a part of soluble organic matter by the~~  
53 ~~use of aerobic biological treatment. “Absorption surface” means the interface where treated~~  
54 ~~effluent infiltrates into native or fill soil.~~

55 (c) ~~“Building drain” means the building drain is that part of the lowest piping of a~~  
56 ~~drainage system which receives the discharge from soil, waste and other drainage pipes inside the~~  
57 ~~walls of the building and conveys it to the building sewer beginning two feet (.6m) outside the~~  
58 ~~building wall. “Bed” means a soil treatment and dispersal system where the width is greater than~~  
59 ~~three (3) feet.~~

60  
61 (d) ~~“Bedrock” means geological layers, of which greater than 50 percent by volume~~  
62 ~~consist of unweathered in-place consolidated rock or rock fragments. Bedrock also means~~  
63 ~~weathered in-place rock which that cannot be hand augered or penetrated with a knife blade.~~

64  
65 (e) ~~“Bedroom” means any room that is or may be used for sleeping.~~

66  
67 (f) ~~“Dosing system” means the system of tanks, pumps or syphons, and piping located~~  
68 ~~between the septic tank and soil absorption system which is intended to apply a large quantity of~~  
69 ~~settled wastewater to the absorption system in a short period of time. “Blackwater” means water~~  
70 ~~containing fecal matter and/or urine~~

71  
72 (g) ~~“Hydrogeological study” means a study of the occurrence, distribution, quality and~~  
73 ~~movement of the shallowmost groundwater of the site and the potential impact of wastewaters on~~  
74 ~~the groundwater. . “Five day biochemical oxygen demand (BOD<sub>5</sub>)” means a measurement of~~  
75 ~~the dissolved oxygen used by microorganisms in the biochemical oxidation of organic matter~~  
76 ~~during a five (5) day period.~~

77  
78 (h) ~~“Impermeable soil” means any soil which has a percolation rate greater than 60~~  
79 ~~minutes per inch.~~

80  
81 ~~Previously 2(d) “Building sewer” means the building sewer is that part of the horizontal piping~~  
82 ~~the pipe of a drainage system which extends from the end of the building drain and conveys the~~  
83 ~~building drain discharge to the septic tank or other onsite sewage disposal facility that carries~~  
84 ~~wastewater from the building.~~

85  
86 (i) ~~“Pump Tank” means a tank in which the dosing pumps or syphons are installed.~~  
87 ~~“Chamber” means a domed open bottom structure that is used in lieu of perforated distribution~~  
88 ~~pipe and gravel media.~~

89  
90 (j) ~~“Delegated small wastewater program” means a local governmental entity,~~  
91 ~~delegated by the Administrator, with the authority to administer the provisions of W.S. 35-11-~~  
92 ~~301(a) (iii) for small wastewater systems pursuant to the provisions of W.S. 35-11-304.~~

93  
94 (k) ~~“Direct human consumption food crops” are crops consumed directly by humans.~~  
95 ~~These include, but are not limited to fruits, vegetables and grains grown for human consumption.~~

96  
97 (l) ~~“Domestic wastewater” means a combination of the liquid or water-carried wastes~~  
98 ~~from residences, business buildings, institutions, and other establishments arising from normal~~  
99 ~~living activities.~~

100

101 ~~Previously 2(e) (m) “Domestic sewage septage” “Domestic”~~ means the liquid ~~and~~  
102 ~~waterborne wastes or solid material derived removed from the ordinary living processes a waste~~  
103 ~~treatment vessel, free from industrial wastes, and of such character as to permit satisfactory~~  
104 ~~disposal without special treatment~~ that has received only wastes from residences, business  
105 buildings, institutions, and other establishments arising from normal living activities.  
106

107 (n) “Dosing tank” means a tank equipped with an automatic siphon or pump designed  
108 to discharge effluent on an intermittent basis.  
109

110 (o) “Effluent” means a liquid flowing out of a septic tank, other treatment vessel or  
111 system.  
112

113 (p) “Effluent filter” means a removable, cleanable device inserted into the outlet piping  
114 of a septic tank or other treatment vessel designed to trap solids that would otherwise be  
115 transported to the soil absorption system or other downstream treatment components.  
116

117 (q) “Evapotranspiration” means the combined loss of water from soil by evaporation  
118 from the soil or water surface and by transpiration from plants.  
119

120 (r) “Greywater” means untreated wastewater that has not been contaminated by any  
121 toilet discharge; ~~which that~~ is unaffected by infectious, contaminated, or unhealthy bodily wastes;  
122 and does not present a threat from contamination by unhealthful processing, manufacturing, or  
123 operating wastes. “Greywater” includes but is not limited to wastewater from bathtubs, showers,  
124 washbasins, clothes washing machines (unless soiled diapers are serviced), laundry tubs, and  
125 kitchen sinks.  
126

127 (s) “Grease interceptor” means a device designed to separate fats, oils, and grease  
128 from wastewater.  
129

130 (t) “Groundwater” means subsurface water that fills available openings in rock or soil  
131 materials such that they may be considered water saturated under hydrostatic pressure.  
132

133 (u) “High groundwater” means seasonally or periodically elevated levels of  
134 groundwater.  
135

136 (v) “High strength wastewater” means a wastewater stream with a BOD<sub>5</sub> higher than  
137 200 mg/L.  
138

139 (w) “Holding Tank” means a watertight receptacle designed to receive and store  
140 wastewater.  
141

142 (x) “Manifold” means a non-perforated pipe that distributes effluent to individual  
143 distribution pipes.  
144

145 (y) “Mound system” means an onsite wastewater system where ~~the bottom any part of~~  
146 the absorption surface is above the elevation of the existing site grade, and the absorption surface  
147 is contained in a mounded fill body above the grade.  
148

149 (z) “Mulch basin” means an excavated area that has been refilled with a highly  
150 permeable media, organic and inorganic materials intended to distribute greywater to irrigate  
151 vegetation.

152  
153 (aa) “Pathogens” are disease-causing organisms. These include, but are not limited to,  
154 certain bacteria, protozoa, viruses, and viable helminth ova.

155  
156 (bb) “Percolation rate” means the time expressed in minutes per inch required for water  
157 to seep into saturated soil at a constant rate.

158  
159 (cc) “Pipe invert” means the bottom ~~or lowest horizontal point~~ of the internal surface of  
160 the pipe.

161  
162 (dd) “Percolation test” means the method used to measure the percolation rate of water  
163 into soil as described in Appendix A.

164  
165 (ee) “Permit by rule” means an authorization included in these rules ~~which that~~ does not  
166 require either an individual permit or a general permit. A facility which is permitted by rule must  
167 meet the requirements found in this chapter, but is not required to apply for and obtain a permit to  
168 construct and operate the facility.

169  
170 (ff) “Pressure distribution” means a network of pipes in which effluent is forced  
171 through orifices under pressure.

172  
173 (gg) “Restrictive layer” means a nearly continuous layer that has one or more physical,  
174 chemical, or thermal properties that significantly impede the movement of water and air through  
175 the soil or that restrict roots or otherwise provide unfavorable root conditions. Examples are  
176 bedrock, cemented layers, dense layers, and frozen layers.

177  
178 (hh) “Septage” means liquid or solid material removed from a waste treatment vessel  
179 that has received wastes from residences, business buildings, institutions, and other  
180 establishments.

181  
182 (ii) “Septic tank” means a ~~buried,~~ watertight tank designed and constructed to receive  
183 and treat raw wastewater.

184  
185 (jj) “Serial distribution” means a group of trenches arranged so that the total effective  
186 absorption area of one trench is used before liquid flows into the next trench.

187  
188 (kk) “Service provider” means a person authorized and trained by a system  
189 manufacturer or their vendor to operate and maintain any proprietary system.

190  
191 (ll) “Soil absorption system” means a shallow, covered, excavation ~~surface, or mound~~  
192 made in unsaturated soil into which wastewater effluent from the septic tank is discharged  
193 through distribution piping for application onto absorption surfaces through porous media or  
194 manufactured components ~~placed in the excavations.~~

195  
196 (mm) “Trench” means an absorption surface with a width of three (3) feet or less.

197  
198 **Section 5. ~~Site Suitability~~ Design Flows.**

199  
200 ~~(formerly Section 3) The sewerage system, treatment works and disposal system shall have a~~  
201 ~~minimum absorption area based on the minimum peak design flows listed in Table 1 below. The~~  
202 ~~volume of wastewater shall be determined by one of the following:~~

203  
204  
205  
206  
207  
208  
209  
210  
211  
212  
213  
214  
215  
216  
217

- (a) Tables 1 and 2 provided in this section.
- (b) Metered water supply data from the facility.
- (c) Metered water supply data from another facility where similar water demands have been demonstrated.

**Table 1**

Quantities of Domestic Sewage Flows

Type of Establishment	Flow (gallons per day per _____)
<b>Residential Units</b>	
Single Family Dwellings	150/bedroom
Multiple Family Dwelling (with laundry capabilities)	150/bedroom
Multiple Family Dwelling (without laundry capabilities)	120/bedroom
Cottages	50/person
Mobile Home Parks	350/home*
<b>Commercial Facilities</b>	
Airports	4/passengers
Bar	3/patron
Bathhouses and swimming pools	10/person
Campgrounds (individual sewer outlets available)	100/site
Campgrounds (service building only)	75/site
Car or truck wash	200/vehicle
Church (no food preparation and/or dishwashing)	5/seat
Church (food preparation and/or dishwashing)	7/seat
Country Club	100/member
Factories	30/employee
Hospital	200/bed
Laundry (self-service)	600/machine or 50/cycle
Motels	80/double bed or 40/single bed
Office building	30/employee
Restaurant (toilet and kitchen wastes)	13/meal
Restaurant (kitchen wastes)	6/meal
Restaurant (additional for bars and lounges)	2/meal
Restaurant (kitchen wastes with disposable service)	2/meal
Rest Home	100/resident
<b>Schools</b> Boarding	100/resident student
Day, without gyms, cafeterias, or showers	15/student
Day, with cafeterias only	20/student
Day, with cafeteria, gym and showers	25/student
Service stations	10/vehicle served
Shopping Center	2/parking space
Store, Retail	30/employee

Theaters: <del>Movie Drive-In</del>	<del>5/seat</del> <del>15/vehicle space</del>
<del>Warehouses</del>	<del>30/employee</del>

218 \* ~~Must consider flow into the soil absorption system from mobile homes where taps are allowed~~  
219 ~~to run to prevent freezing.~~  
220  
221  
222  
223  
224

**Table 1. Residential Design Flow Rates per Bedroom (gallons per day, gpd)<sup>1</sup>**

<u>1 bedroom</u>	<u>150</u>
<u>2 bedrooms</u>	<u>280</u>
<u>3 bedrooms</u>	<u>390</u>
<u>4 bedrooms</u>	<u>470</u>
<u>5 bedrooms</u>	<u>550</u>
<u>6 bedrooms</u>	<u>630</u>

225 <sup>1</sup>An unfinished basement is considered two (2) additional bedrooms.

226 <sup>2</sup>The design flow shall be increased by eighty (80) gpd for each additional bedroom over six (6).

227

228

**Table 2. Non-Residential Wastewater Design Flow Rates<sup>1</sup>**

<b>Facility</b>	<b>Unit</b>	<b>Flow (gallons/unit/day)</b>
Airports	<u>person</u>	4
<u>Apartment</u>	<u>bedroom</u>	<u>120</u>
<u>Automobile</u> Service Station	vehicle served	10
<u>Bars</u>	<u>seat</u>	<u>20</u>
Bathhouses and swimming pools	person	10
Campgrounds ( <u>w/ toilets only</u> )	<u>person</u>	<u>25</u>
Campgrounds ( <u>w/shower facility</u> )	<u>person</u>	<u>45</u>
<u>Church</u>	<u>person</u>	4
Country Club	member	<u>25</u>
<u>Day School, Office Building, Retail Store, Warehouse (no showers)</u>	<u>person</u>	<u>15</u>
Hospital	bed	<u>250</u>
<u>Industrial Building (sanitary waste only)</u>	<u>employee</u>	<u>20</u>
Laundry (self-service)	<u>machine</u>	<u>450</u>

Mobile Home		<u>bedroom</u>	<u>See table 1</u>
Motel, <u>Hotel, Resort</u>		<u>bedroom</u>	<u>140</u>
<u>Recreational Vehicle</u>		<u>each</u>	<u>100</u>
Rest Home, <u>Care Facility, Boarding School</u>		bed	100
Restaurant		meal	<u>10</u>
<u>Restaurant (kitchen waste only)</u>		<u>meal</u>	<u>6</u>
Theater		<u>seat</u>	<u>3</u>

229 <sup>1</sup>Values shown in the above table are the typical flow rates from *Wastewater Engineering*  
230 *Treatment and Reuse*, Metcalf and Eddy, 2003 Edition.  
231

232 **Section 6. ~~Building Sewer Pipes~~ Systems not Specifically Covered by This Rule.**  
233

234 This section is provided to encourage new technology and equipment and provide a process for  
235 evaluating and permitting designs that deviate from this rule. The proposed construction of  
236 facilities and processes not in compliance with this rule may be permitted provided that the  
237 facility, when constructed and operated, meets the objective of these rules.  
238

239 (a) Each application for a permit to construct shall include an engineering design report,  
240 detailed construction plans, and technical specifications for all piping, tanks, and equipment. All  
241 of the documents shall have a suitable title showing the owner's name and the Wyoming  
242 registration number, seal, and signature of the engineer.  
243

244 (b) Each application for a permit to construct will be evaluated on a case-by-case basis  
245 using the best available technology. The application shall include at least one of the following:  
246

247 (i) Data obtained from a full scale, comparable installation that demonstrates the  
248 acceptability of the design.  
249

250 (ii) Data obtained from a pilot plant operated under the design condition for a  
251 sufficient length of time to demonstrate the acceptability of the design.  
252

253 (iii) Data obtained from the theoretical evaluation of the design that demonstrates a  
254 reasonable probability the facility will meet the design objectives.  
255

256 (iv) An evaluation of the flexibility of making corrective changes to the constructed  
257 facility in the event it does not function as planned.  
258

259 (c) If an applicant wishes to construct a pilot plant to provide data necessary to show the  
260 design will meet the purpose of the act, a permit to construct must be obtained.  
261

262 **Section 7. ~~Soil Absorption System Sizing~~ Site Suitability.**  
263

264 (a) ~~(Formerly 4(e) Location.~~ Small wastewater systems must be located where the  
265 surface drainage is sufficient to allow proper operation of the small wastewater system. ~~Formerly~~  
266 10 (a)(iii) Runoff. Surface runoff shall be diverted around or away from all soil absorption  
267 systems. Avoid depressions and bases of slopes and areas in the path of runoff from roofs, patios,

268 driveways, or other paved areas unless surface drainage is provided. ~~Formerly 4(e))Absorption~~  
269 systems Small wastewater systems shall not be located beneath buildings, parking lots, roadways,  
270 driveways, irrigated landscaping, or ~~other similarly~~ compacted areas.

271  
272 ~~(formerly 10(a)(i))(b) Replacement area.—An area shall be designated and shown on the~~  
273 ~~plans for future installation of a replacement absorption system.—The site must include area for~~  
274 both the proposed soil absorption system and a future replacement soil absorption system. Both  
275 the proposed and replacement soil absorption systems shall be sized to receive one-hundred  
276 (100%) percent of the wastewater flow. If a trench system is used, ~~the replacement-area soil~~  
277 absorption system may ~~include the area be located~~ between the trenches ~~of the proposed soil~~  
278 absorption system if ~~sufficient spacing has been provided~~ there is at least nine (9) feet of spacing  
279 between trench sidewalls. ~~At least three feet of undisturbed soil shall remain between the existing~~  
280 ~~and replacement trench side walls.~~

281  
282 ~~—— (formerly 5(e)) Groundwater protection and bedrock or impermeable soil separation.~~

283  
284 ~~(formerly 5(e)(i))~~ (c) For single family homes, For standard soil absorption systems the  
285 effective suitable soil depth to bedrock or impermeable soil must be shall extend at least four (4)  
286 feet ~~from below~~ the bottom of the absorption system ~~stone and the natural ground surface to any~~  
287 restrictive layer, fractured rock, or highly permeable material.

288  
289 ~~(formerly 5(e)(i))(d) ——~~ The depth to ~~seasonally high groundwater must shall~~ be at least  
290 four (4) feet ~~from below~~ the bottom of the absorption ~~system surface stone and at least two feet~~  
291 ~~from the natural ground surface. for all treatment systems except pressure distribution. (formerly~~  
292 ~~5(e)(ii)) ——~~ For all systems other than single family homes up to 2000 gallons per day, the depth  
293 to bedrock or impermeable soil must be at least four feet from the natural ground surface. The  
294 depth to seasonally high groundwater must be at least four feet from the bottom of the absorption  
295 system ~~stone and at least two feet from the natural ground surface. Also, For pressure distribution~~  
296 systems, the depth to high groundwater shall be a minimum of at least three (3) -feet of  
297 unsaturated soil shall be maintained between below the bottom of the absorption ~~system stone~~  
298 surface ~~and the estimated groundwater mound imposed on the seasonally high groundwater table.~~  
299 if the percolation rate of the soil is five (5) minutes per inch or greater (5-60 mpi). ~~The height of~~  
300 ~~the groundwater mound may be estimated from Figures 1 through 6. The average daily flow~~  
301 ~~should be used and may be estimated as 0.6 times the flow determined from Table.~~

302  
303 ~~(formerly 5(e) (iii))~~ For all systems larger than 2000 gallons per day, a minimum of  
304 ~~three feet of unsaturated soil shall be maintained between the bottom of the absorption system~~  
305 ~~stone and the estimated groundwater mound imposed on the seasonally high groundwater table.~~  
306 ~~The maximum height of the groundwater mound shall be estimated by the design engineer.~~

307  
308 ~~—— (formerly Section 5(e))(e) Sloping ground installations~~ Slope

309  
310 ~~(formerly Section 5(e)(i))(i)~~ Absorption systems shall not be located in an area  
311 where the natural slope is steeper than stated below. The following are Table 3 shows the  
312 maximum permissible slopes on which an absorption system may be constructed.

313



314  
315  
316

~~(formerly contained in Section 5(e)(i))~~ **Table 3. Slope and Percolation Rates for Absorption Systems**

<b>Percolation Rate (minutes/inch)</b>	<b>Maximum Slope<sup>1</sup></b>
<del>Faster than</del> 5	25%
6-45	20%
46-60	15%


317  
318  
319  
320  
321  
322  
323  
324  
325  
326  
327  
328

<sup>1</sup> Flatter slopes may be required where the effluent ~~may surface~~ surface downslope.


~~(formerly 5(e)(ii)) “Saturated thickness” Distance between the seasonally high groundwater table and the under lying impervious layer such as clay, bedrock or soils with significantly lower permeability.~~

~~(formerly 5 (e)(ii)) “Estimated Rise in Water Table”: The estimated distance the water table will rise at the center of the absorption system above the initial water table when the indicated flow is applied daily.~~

329




330  
331



BASED ON A SOIL PERCOLATION RATE = 20 min/inch


FIGURE 2



BASED ON A SOIL PERCOLATION RATE = 30 min/inch

FIGURE 3


332  
333  
334  
335  
336  
337  
338  
339  
340  
341  
342  
343  
344  
345  
346  
347  
348  
349  
350  
351  
352  
353  
354  
355  
356  
357  
358  
359  
360  
361  
362  
363  
364  
365  
366  
367  
368  
369  
370  
371  
372  
373  
374  
375  
376  
377  
378  
379  
380  
381  
382



BASED ON A SOIL PERCOLATION RATE = 40 min/inch

FIGURE 4


384  
385



BASED ON A SOIL PERCOLATION RATE = 50 min/inch

FIGURE 5

386  
387  
388



389 (ii) Serial distribution, with the use of drop boxes or approved fittings, is the  
390 preferred installation method for sloping terrain. The bottom of individual trenches shall be level  
391 and the trenches shall be constructed to follow the contours of the land.

392  
393 (iii) The placement of multiple trenches, with each subsequent trench down slope of  
394 the previous trench shall be avoided when the addition of effluent to the soil absorption system  
395 trenches may lead to either an unstable slope or seepage down slope.

396  
397 ~~(formerly 5(e)(ii))~~(iv) All absorption surfaces must be located at least 15  
398 horizontal feet from the top of any break in slope ~~which that~~ exceeds the maximum ~~allowed in~~  
399 ~~subsection (i) above~~ slope allowed.

400  
401 (f) Soil Exploration Pit and Percolation Tests

402  
403 (i) Delegated small wastewater programs shall require a percolation test in  
404 addition to the soil exploration pit.

405  
406 (ii) ~~(formerly 5(a))~~ ~~Soil exploration. Soil exploration~~ A minimum of one soil  
407 exploration pit within the proposed soil absorption system location shall be excavated to a  
408 minimum depth of four (4) feet below the bottom of the proposed soil absorption system ~~shall be~~  
409 ~~made to provide information on subsoil conditions~~ to evaluate the subsurface conditions.

410  
411 ~~(formerly 5(b))~~ ~~Soil evaluation.~~

412  
413 ~~(formerly 5(b)(i))~~ ~~No less than three percolation tests shall be run in the~~  
414 ~~proposed absorption system location. The percolation tests shall be performed in accordance with~~  
415 ~~Appendix A of this part. The type of soil encountered at the percolation test location shall be~~  
416 ~~specified.~~

417  
418 ~~((formerly 5b)(ii))~~ (iii) The percolation test shall be performed in accordance with  
419 Appendix A of this chapter. An evaluation of the soil texture, in the proposed soil absorption  
420 system location, by a person experienced in soils classification, may be used as an additional tool  
421 to confirm the percolation rate. ~~but at least one percolation test shall be performed.~~

422  
423 ~~(formerly Section 4)~~(g) Isolation Minimum horizontal setback distances (in feet) are as  
424 follows:

425  
426 ~~(formerly 4(a))~~ ~~Domestic wastewater. The isolation distances listed below apply when~~  
427 ~~domestic wastewater is the only wastewater present.~~

428  
429 ~~(formerly 4(a)(i))~~ ~~If the flow is less than 2000 gallons per day (gpd), the~~  
430 ~~minimum isolation distance (in feet) shown in Table 2 shall be maintained.~~

431  
432  
433  
434  
435  
436  
437  
438 ~~(formerly Table 2)~~ Table 4. Minimum Horizontal Setbacks for Domestic  
439 Wastewater in Feet<sup>1,2</sup>



440

From	To Septic Tank Or Equivalent	To Absorption System
Wells (includes neighboring wells)	50	100
<u>Public Water Supply Well</u>	<u>100<sup>2</sup></u>	<u>200<sup>2</sup></u>
Property Lines	10	10
Foundation Wall (w/o drains)	5	10
Foundation Wall (with drains)	5	25
Potable Water Pipes	25	25
Septic Tank	<u>N/A</u>	10
<del>Stream or</del> Surface <del>Body of</del> Water, <u>Spring</u> (including seasonal and intermittent)	50	50
<u>Cisterns</u>	<u>25</u>	<u>25</u>

441 <sup>1</sup> ~~(formerly 4(b)) Non-domestic wastewater.~~ For disposal of ~~wastewaters other than~~  
 442 ~~domestic non-domestic~~ wastewater, the ~~isolation setback~~ distance shall be determined by a  
 443 hydrogeological study in accordance with Section ~~15~~ 17(b) of Chapter 3, but shall not be less than  
 444 the distances shown in Table 4.

445  
 446 <sup>2</sup> Small wastewater systems that discharge to the same aquifer that supplies a public water  
 447 supply well and are located within Zone 1 or 2 (Attenuation) of the public water supply well, as  
 448 determined by Wyoming Department of Environmental Quality Source Water Assessment Project  
 449 (2004) or as established in Section 2 of the Wyoming Wellhead Protection Guidance Document  
 450 (1997), shall provide additional treatment. These systems will be required to obtain an individual  
 451 permit to construct and will require that a PE sign, stamp, and date the application, as stated in  
 452 Section 2 of this chapter. The additional treatment shall be in accordance with Chapter 3 Section  
 453 2(b)(ii). The treatment system shall be designed to reduce the nitrates to less than 10 mg/L of  
 454 NO<sub>3</sub>- as N and provide 4-log removal of pathogens before the discharge leaves the property  
 455 boundary of each small wastewater system.

457 **Section 8. ~~Pretreatment~~ Soil Absorption System Sizing.**

459 ~~(formerly Section 7(a)-(a) Trench, bed and seepage pit systems.~~ The total ~~infiltrative~~  
 460 ~~infiltration surface of a soil absorption system~~ area of a soil absorption system shall be calculated  
 461 ~~based on the flow rate as determined by the criteria stated in Section 3 and with the allowable~~  
 462 ~~loading rate as determined by using Figure 7.~~ by dividing the design flow rates (gpd) from Table  
 463 1 or Table 2 by the loading rate (gpd/ft<sup>2</sup>) found in Table 5. ~~The total infiltrative surface is the sum~~  
 464 ~~of the sidewall and bottom areas of the absorption system below the invert of the distribution~~  
 465 ~~pipe.~~

466  
467  
468  
469  
470  
471

472  
473  
474  
475  
476  
477  
478  
479  
480  
481  
482  
483  
484  
485  
486  
487  
488  
489  
490  
491  
492  
493  
494  
495  
496  
497  
498  
499  
500  
501  
502  
503  
504  
505  
506  
507  
508  
509  
510  
511  
512  
513  
514  
515  
516  
517  
518  
519  
520  
521




FIGURE 7

Table 5. Rates of Wastewater Application for Soil Absorption System Areas

<u>Percolation Rate (mpi)</u>	<u>Loading Rate (gpd/ft<sup>2</sup>)</u>	<u>Percolation Rate (mpi)</u>	<u>Loading Rate (gpd/ft<sup>2</sup>)</u>
<u>5</u>	<u>0.80</u>	<u>21</u>	<u>0.45</u>
<u>6</u>	<u>0.75</u>	<u>22</u>	<u>0.44</u>
<u>7</u>	<u>0.71</u>	<u>23-24</u>	<u>0.43</u>
<u>8</u>	<u>0.68</u>	<u>25</u>	<u>0.42</u>
<u>9</u>	<u>0.65</u>	<u>26-27</u>	<u>0.41</u>
<u>10</u>	<u>0.62</u>	<u>28-29</u>	<u>0.40</u>
<u>11</u>	<u>0.60</u>	<u>30-31</u>	<u>0.39</u>
<u>12</u>	<u>0.58</u>	<u>32-33</u>	<u>0.38</u>
<u>13</u>	<u>0.56</u>	<u>34-35</u>	<u>0.37</u>
<u>14</u>	<u>0.54</u>	<u>36-37</u>	<u>0.36</u>
<u>15</u>	<u>0.52</u>	<u>38-40</u>	<u>0.35</u>
<u>16</u>	<u>0.50</u>	<u>41-43</u>	<u>0.34</u>
<u>17</u>	<u>0.49</u>	<u>44-46</u>	<u>0.33</u>
<u>18</u>	<u>0.48</u>	<u>47-50</u>	<u>0.32</u>
<u>19</u>	<u>0.47</u>	<u>51-55</u>	<u>0.31</u>
<u>20</u>	<u>0.46</u>	<u>56-60</u>	<u>0.30</u>

522

523

524

(b) ~~Soils with a percolation rate of 60 minutes per inch or greater are unacceptable for standard absorption systems.~~ The total infiltration area shall be defined as follows:

525

526

527

(i) For standard trenches the total infiltration area shall be calculated based on the following formula:

528

529

\_\_\_\_\_

530

$$A = L(W + 2S)$$

531

\_\_\_\_\_

532

A = Total infiltration area

533

\_\_\_\_\_

534

L = Total length of trench

535

\_\_\_\_\_

536

W = Bottom width

537

\_\_\_\_\_

538

S = Sidewall height of 12 inches or less

539

\_\_\_\_\_

540

(A) The sidewall height is the depth below the flowline of the pipe to the bottom of the trench.

541

542

\_\_\_\_\_

543

(B) The maximum credit for sidewall height shall not exceed twelve (12) inches even if the actual sidewall height exceeds twelve inches.

544

545

546

(ii) For chamber trenches, the total infiltration area shall be calculated based on the following formula:

547

548

\_\_\_\_\_

549

$$A = L(E + 2S)$$

550

\_\_\_\_\_

551

A = Total infiltration area

552

\_\_\_\_\_

553

L = Total length of trench

554 \_\_\_\_\_  
555 E = Effective bottom width (Multiply width of the chamber by factor of 1.43 to  
556 get effective bottom width)

557 \_\_\_\_\_  
558 S = Sidewall height of 12 inches or less

559 \_\_\_\_\_  
560 (A) The factor of 1.43 incorporates a thirty percent (30%) reduction of the  
561 bottom area.

562 \_\_\_\_\_  
563 (B) The maximum credit for sidewall height shall not exceed twelve (12)  
564 inches even if the actual sidewall height exceeds twelve (12) inches.

565 \_\_\_\_\_  
566 (C) The sidewall height is the height of the slotted sidewall of the chamber or  
567 depth below the flow line of the inlet pipe, whichever is less.

568 \_\_\_\_\_  
569 (iii) For ~~standard~~ bed systems, the total infiltration area shall be calculated based  
570 on the following formula:

571 A = LW

572 \_\_\_\_\_  
573 A = Total infiltration area

574 \_\_\_\_\_  
575 L = Total length of bed

576 \_\_\_\_\_  
577 W = Width of the bed.

578 \_\_\_\_\_  
579 (A) The sidewall credit shall not be used in calculating the total infiltration area  
580 for a bed system.

581 \_\_\_\_\_  
582 (iv) For chamber bed systems, the total infiltration area shall be calculated based  
583 on the following formula:

584 A = L(E x R)

585 \_\_\_\_\_  
586 A = Total infiltration area

587 \_\_\_\_\_  
588 L = Total length of bed

589 \_\_\_\_\_  
590 E = Effective bottom width of the chamber (Multiply width of the chamber by  
591 factor of 1.43 to get effective bottom width)

592 \_\_\_\_\_  
593 R = Number of chamber rows (Multiply effective bottom width of chamber by  
594 number of chamber rows to get effective bottom width of bed.)

595 \_\_\_\_\_  
596 (A) The factor of 1.43 incorporates a thirty percent (30%) reduction of the  
597 bottom area.

598 \_\_\_\_\_  
599 \_\_\_\_\_  
600 ~~(formerly 5(d))(c) Excessively permeable soils. Coarse sand or soils having a~~  
601 ~~percolation rate of less than one (1) minute per inch (mpi) or less are unsuitable for subsurface~~  
602 ~~effluent-sewage disposal. These soils may be used if a six-inch a one (1) foot layer of soil-fine~~  
603 ~~sand or loamy sand having a percolation rate of five minutes per inch or greater is placed between~~

604 ~~the leach system stone and the existing soil below the constructed soil absorption system.~~ The  
605 soil absorption system shall be sized based on the percolation rate of the fill material.  
606

607 **Section 9. ~~(formerly Dosing Systems Following Septic Tanks)~~ Building Sewer Pipes.**

608 ~~(formerly 6(a))—Building drain pipe. All building drain pipe shall comply with the~~  
609 ~~standards published in the Uniform Plumbing Code 1982 or other locally approved, nationally~~  
610 ~~recognized plumbing code.~~

611  
612 ~~(formerly 6(b))—Building sewer pipe. All building sewers shall be installed in accordance~~  
613 ~~with the Uniform Plumbing Code 1982 or other locally approved, nationally recognized~~  
614 ~~plumbing code 2012 International Plumbing Code (IPC). In the absence of ~~an~~ a locally approved~~  
615 ~~plumbing code, and in addition to the IPC, the building sewer shall comply with the following:~~  
616

617  
618 ~~(formerly 6(b)(i)) (a) (Material) Suitable building sewer pipe materials are Ppolyvinyl C~~  
619 ~~chloride (PVC) or Acrylonitrile-Butadiene-Styrene (ABS) ~~cast or ductile iron, portland cement,~~~~  
620 ~~or vitrified clay pipe shall be used for sewer pipes.~~ The septic tank inlet and outlet pipes shall be  
621 ~~cast or ductile iron or schedule 40 PVC or ABS pipe and shall ~~extend past the septic tank~~~~  
622 ~~excavation to solid ground span the excavations for the septic tank and/or dosing chamber.~~  
623 ~~American Society for Testing and Materials (ASTM) D-3034 Standard Dimension Ratio (SDR)~~  
624 ~~35 plastic pipe may be used if the void at the tank's side is filled with material that is granular,~~  
625 ~~clean and compacted.~~  
626

627 ~~(formerly 6(b)(ii)) (b) Size. Building sewer pipes shall not be smaller than four inches in~~  
628 ~~diameter. They shall be sized to handle the peak hourly flow from the building.~~

629 Building sewer pipes shall be sized to handle the peak hourly flow from the building and shall  
630 not be smaller than four (4) inches in diameter. When two different sizes or types of sewer pipes  
631 are to be connected, a proper type of fitting or conversion adapter shall be used.  
632

633 (c) Sewer pipe shall not decrease in size flowing downstream.  
634

635 ~~(formerly 6(b)(iii))(d) Slope. Building sewer pipes ~~should~~ shall be laid at a ~~minimum~~~~  
636 ~~standard slope of 1/4 inch per foot, ~~but~~ and shall not be flatter than 1/8 inch per foot.~~  
637

638 ~~(formerly 6(b)(iv)) Alignment. Building sewer pipes ~~should~~ be laid in a straight~~  
639 ~~line. Any single change or cumulative change of alignment of 22 ½ degrees or greater shall be~~  
640 ~~served by a cleanout.~~  
641

642 ~~(formerly 6(b)(v))(e) Cleanouts. Cleanouts shall be provided at branch connections,~~  
643 ~~every change in alignment, and at least every 100 feet in straight runs ~~maximum.~~~~  
644

645 ~~(formerly 6(b)(vi))(f) Backfilling. All sewer piping shall be laid on a firm bed~~  
646 ~~throughout its entire length. It shall be protected from damage due to rocks, hard lumps of soil,~~  
647 ~~debris and the like.~~  
648

649 ~~(formerly 6(b)(vi))(g) Special care shall be ~~utilized~~ used to prevent lateral movement or~~  
650 ~~ovalation deformation during backfill. The backfill material shall be compacted to a density at~~  
651 ~~least equivalent to the trench walls. Backfill over the pipe shall be of sufficient depth to protect~~  
652 ~~the pipe from expected traffic loads and the wastewater from freezing.~~  
653

654 **Section 10. ~~Subsurface Treatment and Disposal Systems~~ Septic Tanks and Other**  
655 **Treatment Tanks.**

656 ~~(formerly 8(a))~~(a) Septic tanks:-

657 ~~(formerly 8(a)(i))~~ (i) ~~Material. The~~ Septic tanks shall be fabricated or  
658 constructed of  ~~durable concrete, fiberglass, thermoplastic or an approved material not subject~~  
659 ~~to excessive corrosion or decay and structurally capable of supporting the loads to which it~~  
660 ~~will be subjected.~~ ~~The~~ ~~†~~Tanks shall be water tight and fabricated to constitute an individual  
661 structure, and shall be designed and constructed to withstand anticipated loads. As part of the  
662 application review process, Department of Environmental Quality, Water Quality Division  
663 (DEQ/WQD) or the delegated small wastewater program shall review the design of  
664 prefabricated septic tanks for compliance with applicable construction standards.

665 ~~(formerly 8(a)(v))~~ (ii) ~~Installation.~~ The septic tank shall be placed on a level  
666 grade and a firm bedding to prevent settling. Where rock or other undesirable protruding  
667 obstructions are encountered, the opening for the septic tank shall be over excavated, as needed,  
668 and backfilled with sand, crushed stone, or gravel to the proper grade.

669 (A) Septic tanks shall not be buried deeper than the tank manufacturer's  
670 maximum designed depth for the tank. The minimum depth of soil cover over the top of the tank  
671 is six (6) inches.

672 (B) Backfill around and over the septic tank shall be placed in such a manner  
673 as to prevent undue strain or damage to the tank or connected pipes.

674 (C) Septic tanks shall not be placed in areas subject to vehicular traffic unless  
675 engineered for the anticipated load.

676 ~~(formerly 8(a)(ii))~~(iii) Size

677 ~~(formerly 8(a)(ii)(A))~~(A) ~~Residential units serving no more than 4 families.~~ ~~The~~  
678 minimum liquid volume of a septic tanks shall be 1000 gallons for residences ~~through four~~  
679 ~~bedroom capacity up to a four (4) bedroom capacity.~~ Additional capacity of ~~250~~ per bedroom  
680 shall be provided for each bedroom over four (4).

681 ~~(formerly 8(a)(ii)(B))~~(B) ~~Commercial/industrial units.~~ Septic tanks for high strength  
682 wastewater or non-residential units shall have a minimum effective liquid capacity sufficient to  
683 provide at least ~~36~~ 48 hour retention at peak flow or 1,000 gallons, whichever is greater.

684 ~~(formerly 8(a)(iii))~~(iv) Configuration

685 ~~(formerly 8(a)(iii)(A))~~(A) ~~The Single compartment~~ septic tanks shall have a length  
686 to width ratio of no less than two (2) to one (1), or be so partitioned ~~as to provide protection~~  
687 ~~protect~~ against short circuiting of flow. ~~The inlet pipe shall be at least three inches higher than the~~  
688 ~~outlet pipe.~~

689 ~~(formerly 8(a)(iii)(B))~~(B) ~~If the septic tank is partitioned,~~ For septic tanks with two  
690 (2) compartments or more the volume of the first compartment must be at least 50 percent of the  
691 total required volume, the inlet compartment shall not be less than one-half (1/2) of the total  
692 capacity of the tank.

705  
706 ~~(formerly 8(a)(iii)-(A)) (C)~~ The water depth shall be no less than  
707 ~~four feet nor greater than six feet.~~ The liquid depth shall not be less than three (3) feet nor greater  
708 than six (6) feet.

709  
710 ~~(formerly 8(a)(iii)(C))~~ The outlet elevation shall be designed to  
711 provide a distance of 20 percent of the liquid depth between the top of the liquid and the bottom  
712 of the septic tank cover for scum storage.

713  
714 ~~(formerly 8(a)(iii)-(B)) (D)~~ The partition shall allow venting of the  
715 tank. The tank partition shall allow the venting of gases between compartments and out through  
716 the vent stack on the plumbing system of the house. Gases generated during liquefaction of the  
717 solids are normally vented through the building's plumbing stack vent.

718  
719 ~~(formerly 8(a)(iii)(A)) (E)~~ The septic tank inlet and outlet on all  
720 tanks or tank compartments shall be provided with a open-ended sanitary tees or baffles. The  
721 outlet shall be provided with a tee or baffle that extends into the middle third of the water depth to  
722 prevent floating or settled solids from carrying over into the disposal field or bed. The inlet shall  
723 be provided with tee or baffle made of approved materials constructed to distribute flow and  
724 retain scum in the tank or compartments.

725  
726 (I) The tees or baffles shall extend above the liquid  
727 level a minimum distance of ~~six (6)~~ five (5) inches.

728  
729 (II) The inlet tees or baffles shall extend below the  
730 liquid level at least eight (8) inches but no more than a distance equal to thirty to forty 40%  
731 percent (~~30-40%~~) of the liquid depth level. The outlet tees or baffles shall extend below the liquid  
732 level at least ten (10) inches but no more than 45% of the liquid level.

733  
734 (III) A minimum of ~~three (3)~~ one (1) inches of clear  
735 space shall be provided over the top of the baffles or tees for venting.

736  
737 ~~(formerly 8(a)(iii)(A)) (IV)~~ The inlet pipe shall be at  
738 least ~~three two (2)~~ inches higher than the outlet pipe. ~~(formerly 8(a)(iii)(C))~~ The outlet elevation  
739 shall be designed to provide a minimum distance of nine (9) inches or twenty (20) percent of the  
740 liquid depth, whichever is greater, between the top of the liquid and the bottom of the septic tank  
741 cover for scum storage and the venting of gases.

742  
743 (v) If additional septic tank capacity over 1,000 gallons is needed, it may be  
744 obtained by joining tanks in series provided the following requirements are met:

745  
746 (A) The inlet of each successive tank shall be at least two (2) inches lower  
747 than the outlet of the preceding tank, and shall have no tee or baffle except for the inlet to the  
748 first tank and the outlet for the last tank.

749  
750 (B) The first tank or the first compartment of the first tank shall be equal to  
751 fifty percent (50%) or larger of the total septic tank system volume.

752  
753 ~~(formerly 8(a)(iv)) (vi)~~ Access. A manway An access riser opening shall be  
754 provided to each compartment of the septic tank for inspection and cleaning. ~~A cleanout having a~~

755 ~~minimum diameter of six inches shall be provided in each tank compartment and shall extend to~~  
756 ~~the ground surface and be capped.~~

757  
758 ~~(formerly 8(a)(iv))~~ (A) The ~~manway-access~~ opening(s) in the cover/lid of  
759 the tank shall have a minimum ~~opening diameter of twenty-(20) inches in the least dimension.~~  
760 Both inlet and outlet devices shall be accessible.

761  
762 (B) The riser from the access opening shall terminate at a maximum of six  
763 (6) inches below the ground surface. Riser covers terminating above grade shall have an  
764 approved locking device.

765  
766 (vii) Land application of domestic septage in remote areas that meet the conditions  
767 found in Appendix B will be permitted as a permit by rule. Delegated small wastewater programs  
768 may issue individual permits.

769  
770 (viii) An effluent filter with an opening of 1/8-inch or smaller shall be provided on  
771 the outlet of a septic tank or other tank that precedes a small diameter pressure distribution  
772 system.

773  
774 ~~(formerly 8(b))—Aerobic units.~~

775  
776 ~~(formerly 8(b)(i)) Residential units serving no more than four dwelling units.~~  
777 ~~Aerobic treatment units can be used as a pretreatment device for a single residential unit serving~~  
778 ~~no more than four families provided the unit carries the seal of testing and approval from the~~  
779 ~~National Sanitation Foundation (NSF) for the NSF Standard No. 40—1978. The unit shall be~~  
780 ~~sized based on the flow quantities stated in Section 3. No reduction in the sizing of soil absorption~~  
781 ~~systems or the final treatment systems shall be permitted if an aerobic unit is used instead of a~~  
782 ~~septic tank.~~

783  
784 ~~(formerly 8(b)(ii)) Commercial and residential units serving more than four families.~~  
785 ~~Aerobic units treating wastewater generated from other than a single residential unit serving four~~  
786 ~~families or less shall meet the design requirements of Part B or Part C of Chapter XI~~

787  
788 ~~(formerly 9(a))~~ (b) Pumping systems for flow up to 2000 gallons per day. Dosing Tanks

789  
790 ~~formerly 9(a)(i)) (i) Pump tank—Where only one pump is provided, the pump~~  
791 ~~tank shall have the minimum volume as required in Table 4 below. The Dosing tanks~~  
792 ~~shall comply with the meet the same material and installation requirements for as septic~~  
793 ~~tanks. The pump tank shall be vented. The vent shall have a downward turn that~~  
794 ~~terminates at least 12 inches above ground and be provided with a screen. The pump tank~~  
795 ~~shall have an access manhole provided with an opening at least 20 inches in least~~  
796 ~~dimension. Dosing tanks shall have a 20-inch diameter access riser opening and it shall~~  
797 ~~have a riser from the access opening be brought to the ground surface.~~

798  
799  
800  
801  
802  
803

**Table 4**

Pump Tank  
Volume (gallons) Required Between



<u>AVERAGE FLOWS</u> (gallons per day)	<u>“OFF” &amp; “ON” SWITCH</u>	<u>“ON” &amp; “ALARM” SWITCH</u>	<u>“ALARM” SWITCH &amp; TANK INLET</u>	<u>RECOMMENDED PUMP CAPACITY</u> (gpm)
0-499	100	50	200	10
500-999	200	100	400	20
1000-1499	300	100	600	30
1500-2000	400	100	800	40

805  
806  
807  
808

Table 6. Dosing Tank Volume (gallons)

<u>Average Design Flows (gpd)</u>	<u>0-499</u>	<u>500-999</u>	<u>1000-1499</u>	<u>1500-2000</u>
<u>Between Pump “off” and Tank Inlet</u>	<u>350</u>	<u>700</u>	<u>1000</u>	<u>1300</u>
<u>Between Tank Inlet and Alarm Switch</u>	<u>200</u>	<u>400</u>	<u>600</u>	<u>800</u>
<u>Between Alarm switch and Pump “on”</u>	<u>50</u>	<u>100</u>	<u>100</u>	<u>100</u>
<u>Between Pump “on” and Pump “off”</u>	<u>100</u>	<u>200</u>	<u>300</u>	<u>400</u>
<u>Recommended Pump Capacity (gpm)</u>	<u>10</u>	<u>20</u>	<u>30</u>	<u>40</u>

809  
810  
811  
812  
813  
814  
815  
816  
817  
818  
819  
820  
821

~~(formerly 9(a)(ii) — Pumps.~~

~~(formerly 9(a)(ii)(A) — Sizing. The pump shall have a flow rate of at least ten gallons per minute when installed. The pressure loss (feet of head) of the system can be calculated by adding: the elevation difference between the discharge outlet at the soil absorption system and the low water level in the pump tank; and the friction losses incurred in the pressure transfer pipe and distribution piping. Table 5 may be used to estimate the head loss of the pipe when pumping ten gallons per minute and using plastic pipe.~~

**Table 5**

<u>Diameter</u> (inches)	<u>Head Loss per 100</u> <u>feet of pipe (in feet)</u>
<u>1</u>	<u>12</u>
<u>1¼</u>	<u>4</u>
<u>1½</u>	<u>2</u>

822  
823  
824  
825  
826  
827  
828  
829  
830  
831  
832

~~(B) — Installation/removal. The pump shall be installed in the tank so that it can be removed without entering the tank. This can be accomplished by (1) looping the pipe up near the access manhole with a pipe union provided at the top of the loop, (2) using a quick disconnect sliding coupler, or (3) using a pitless adapter. Chains, cable, or piping can be used to lift the pump out of the tank if designed for this loading. Setting the pump on an 8-inch block minimizes the transfer of any solids that may enter the pump tank.~~

~~(iii) — Pressure transfer pipe. The pressure transfer piping between the tank and the leach system shall be designed to drain after each pump cycle to prevent freezing. This~~

833 can be accomplished by either eliminating the check valve at the pump or by providing a  
834 weep hole in the pipe in the tank. If the pipe is long, the tank shall be enlarged by the  
835 volume of the pipe to accommodate the volume of liquid drained from the pipe.

836  
837 (b) Syphons. Where automatic syphons are used, they shall be designed to empty the  
838 syphon tank in less than 20 minutes. The syphon tank shall be sized in accordance with Section  
839 9(a)(i) above.

840  
841 (c) For all systems exceeding 2000 gallons per day. The pumping system shall  
842 comply with the standards of Part B of Chapter XI.

843  
844 (formerly 9(a)(ii)(C)) (ii) Electrical controls. The electrical control system for the  
845 wastewater pump shall consist of a “pump off” switch, a “pump on” switch, and a “high water  
846 alarm” switch which shall be located to provide the necessary volumes as stated in Table 4.  
847 High water alarms shall be provided for all tanks that use pumps or siphons. The alarm device  
848 shall be an audible alarm or an indoor illuminated alarm or both. All electrical controls (pump  
849 electrical cord, switches, etc.) shall comply with the National Electrical Code—1981, Class 1,  
850 Group D, Division 1 locations. All openings around the cables or cords entering the tank shall  
851 be sealed.

852  
853 (iii) The minimum effluent level shall achieve complete submergence of the pump.

854  
855 (iv) Dosed systems using a siphon shall have a dose counter installed to check for  
856 continued function of the siphon.

857  
858 (formerly Section 12)-(c) Holding tanks

859  
860 (i) Holding tanks shall meet the same material requirements as septic tanks.  
861 Holding tanks shall have a twenty (20)-inch minimum diameter access riser opening. The A riser  
862 shall be brought to ground surface from the access opening.

863  
864 (formerly 12(a)) (ii) Uses. Holding tanks shall not be used for residential  
865 systems when other alternative systems are available, except on a temporary, seasonal or  
866 intermittent basis, or when used to correct a failed ~~subsurface disposal~~ soil absorption system  
867 when other alternatives are unavailable. ~~Use of holding tanks for new construction is~~  
868 ~~prohibited.~~

869  
870 (formerly 12(b)) ~~Acceptance.~~ A letter of verification from the local  
871 receiving agency, denoting acceptance of the wastewater generated shall be submitted with  
872 the plans.

873  
874 (formerly 12(c)) (iii) ~~Location.~~ The location and construction of  
875 holding tanks shall meet the requirements for septic tanks in Sections 4(a)(i) and Section  
876 8(a)(i) respectively. Holding tanks must be located in an area readily accessible to the  
877 pump truck and where the tank itself will not float due to a high groundwater. If seasonal  
878 high groundwater may be present, the tank shall be properly anchored.

879  
880 (formerly 12(a)) (iv) ~~Where holding tanks are allowed, they shall be sized on the basis~~  
881 ~~of seven days storage at the flow rate determined from Table 1. The minimum liquid volume shall~~  
882 ~~be the greater of 1,000 gallons or seven (7) days storage based upon flow rate determined from~~  
883 Section 5.

884  
885  
886  
887  
888  
889  
890  
891  
892  
893  
894  
895  
896  
897  
898  
899  
900  
901  
902  
903  
904  
905  
906  
907  
908  
909  
910  
911  
912  
913  
914  
915  
916  
917  
918  
919  
920  
921  
922  
923  
924  
925  
926  
927  
928  
929  
930  
931  
932  
933  
934

~~(formerly 12(d))~~ ~~Vent. Each holding tank shall be provided with a two-inch minimum diameter vent ending in a return elbow above final grade. The vent shall terminate at least 30 feet from any door, window, or fresh air inlet. The vent should be screened.~~

~~(formerly 12(e))~~ ~~(v) Alarm.~~ All holding tanks shall be equipped with a high water level alarm. The device shall be an audible alarm or an indoor illuminated alarm or both. The ~~alarm level shall be placed~~ device shall be installed so that the alarm is triggered when the water level reaches at 3/4 of the ~~depth of the~~ tank capacity.

~~(formerly 12(f))~~ ~~Pumpout. A six inch pump out pipe which extends to the surface shall be provided. It shall be capped at all times.~~

(vi) A design package for holding tanks is provided online at the Division's website to assist the applicant in submitting a completed application for coverage under the general permit for small wastewater systems. The worksheet and calculations were prepared by a registered professional engineer employed by the Wyoming Department of Environmental Quality, Water Quality Division. The general design requirements stated in this section are incorporated into the worksheets such that by properly completing the forms and installing the components, the system will comply with these requirements.

~~(formerly 8(e)(d)) Grease Interceptors~~ ~~grease, oil, silt and sand.~~

~~(formerly 8(e)(i)) (i) When required. Liquid wastes containing grease, oil, or silt and sand~~ A commercial or institutional food preparation facility with a waste stream containing fat, oil, and grease (FOG) in excess of 25 mg/L shall provide install an exterior grease interceptor or a device approved by the delegated health department or county before the septic tank. Waste streams from residential living units are exempt from this requirement. Facilities that typically have waste streams high in FOG are, but not limited to, restaurants, cafeterias, slaughterhouses, and institutional kitchens.

~~(formerly 8(e)(ii)) (ii) Material.~~ The interceptor shall meet the material requirements of Section 8(a)(i). ~~Waste streams high in FOG shall be plumbed separately and directly to a grease interceptor prior to the waste treatment process.~~

(iii) Waste streams from sanitary facilities such as bathrooms, toilets, urinals, or other similar fixtures shall not be discharged into the grease interceptor. These sources must be connected at least four to six (4-6) feet downstream of the grease interceptor's discharge. The design shall prevent any backflow from the sanitary sources into the grease interceptor.

(iv) Only one source facility per grease interceptor shall be allowed.

~~(formerly 8(e)(v)) Access.~~ The access shall meet the requirements of Section 8(a)(iv).

~~(formerly 8(e)(vi)) (v) Location.~~ Grease interceptors shall be located so that they are easily accessible for inspection, cleaning, and removal of the collected wastes. Interceptors shall be placed as close as practical to the fixture it serves. The wastewater from fixtures not producing grease, oil, or sand and silt shall bypass the interceptor. The interceptor shall not be closer than fifteen (15) feet from the last discharging fixture and no further away than thirty-five (35) feet.

935  
936  
937  
938  
939  
940  
941  
942  
943  
944  
945  
946  
947  
948  
949  
950  
951  
952  
953  
954  
955  
956  
957  
958  
959  
960  
961  
962  
963  
964  
965  
966  
967  
968  
969  
970  
971  
972  
973

(formerly 8(e)(iv)) (vi) Configuration. Grease interceptors shall have a minimum at least of two (2) compartments with the first compartment having at least 50 percent of the total required volume a 20-inch minimum diameter clean out riser access opening for each compartment for cleanout. Each compartment shall be vented. Each clean out riser access opening shall have a riser be brought to the surface and have a sealed lid that is rated for any anticipated load. There shall be a means provided to sample the effluent.

(vii) There shall be no internal cleanout tees or bypasses.

(viii) The inlet and outlet of the grease interceptor shall be vented. The vent pipe shall be at least two (2) inches in diameter. The inlet and outlet vents shall not be interconnected.

(ix) The outlet pipe invert shall be no more than two (2) inches lower than the inlet invert.

(x) The dividing wall between compartments shall be the same height as the other walls and the cover must should contact the top of the dividing wall. If the partition/dividing wall does not contact the cover, the outlet tee or baffle shall extend below the liquid level, 40-50% of the total liquid depth.

(xi) The effluent from each compartment shall be drawn from the bottom of a riser pipe that terminates at least eighteen (18) inches below the inlet pipe invert of that same compartment.

(xii) Grease interceptors shall be accessible during normal business hours without interrupting normal business operations.

(xiii) Grease interceptors shall be installed in accordance with the manufacturer's instructions and applicable requirements of this section. A copy of the manufacturer's instructions shall be submitted with every permit to construct application submitted to DEQ/WQD.

(formerly 8(e)(iii)) (xiv) Grease interceptors shall be sized using one of the according to the following formulas:

Commercial kitchens (grease, garbage)

Number of meals per peak hour	<del>X</del>	Waste Flow rate*	<del>X</del>	Retention time**	<del>X</del>	Storage factor***	=	Interceptor size (liquid capacity)
-------------------------------	--------------	------------------	--------------	------------------	--------------	-------------------	---	------------------------------------

Car wash (sand, silt, oil)

Total washer equipment flow rate (GPM)	<del>X</del>	60	<del>X</del>	Retention time	<del>X</del>	Storage factor	=	Interceptor size (liquid capacity)
--	--------------	----	--------------	----------------	--------------	----------------	---	------------------------------------

974  
975  
976  
977  
978  
979  
980  
  
981

982  
983  
984  
985  
986

Laundries (grease, lint, silt)

Number of 2-cycles machines X per hour	<u>X</u>	Waste flow rate	<u>X</u>	Retention time	<u>X</u>	Storage factor	=	Interceptor size (liquid capacity)
--	----------	-----------------	----------	----------------	----------	----------------	---	------------------------------------

987  
988  
989  
990  
991  
992

\*Waste flow rate—see Table 1.

\*\* Retention Times

Commercial kitchen waste:	
Dishwasher and/or disposal	2.5 hours
Single service kitchen:	
Single serving with disposal	1.5 hours
Car washers	2.0 hours
Laundries	2.0 hours

993  
994  
995

\*\*\*Storage Factors

Fully equipped commercial kitchen	8 hr. operation: 1 16 hr. operation: 2 24 hr. operation: 3
Single service kitchen	1.5
Carwashers	self-serve: 1.5 employee operated: 2
Laundries	1.5 (allows for rock filter)

996  
997  
998

Commercial Kitchens (grease, garbage)

<u>Number of meals per peak hour</u>	<u>X</u>	<u>Waste Flow rate*</u>	<u>X</u>	<u>Retention time**</u>	<u>X</u>	<u>Storage factor***</u>	=	<u>Interceptor size (liquid capacity)</u>
--------------------------------------	----------	-------------------------	----------	-------------------------	----------	--------------------------	---	---

999  
1000  
1001  
1002  
1003

\*Waste flow rate – see Table 2.

\*\*Retention times

<u>Kitchen waste:</u>	
<u>Dishwasher and/or disposal</u>	<u>2.5 hours</u>
<u>Single service kitchen:</u>	
<u>Single serving with disposal</u>	<u>1.5 hours</u>

1004  
1005  
1006

\*\*\*Storage factors

<u>Fully equipped commercial kitchen</u>	<u>8 hr. operation: 1</u> <u>16 hr. operation: 2</u> <u>24 hr. operation: 3</u>
--	---

<u>Single service kitchen:</u>	<u>1.5</u>

1007  
1008  
1009  
1010  
1011  
1012  
1013  
1014  
1015  
1016  
1017  
1018  
1019  
1020  
1021  
1022  
1023  
1024  
1025  
1026  
1027  
1028  
1029  
1030  
1031  
1032  
1033

(A) The minimum volume shall not be less than 750 gallons

(e) Other Interceptors

(i) Interceptors are required for oil, grease, sand and other substances harmful or hazardous to the building drainage system, or the small wastewater treatment system.

(A) Laundries

(I) Commercial laundries, laundromats, and dry-cleaners shall be equipped with an interceptor in order to reduce the quantity of lint and silt that enter the collection system.

(II) The system must be of adequate size and design to allow for cool-down of wastewater so that separation can be more readily achieved.

(III) The interceptor must be installed with a wire basket or similar device, removable for cleaning, that prevents passage into the drainage system of solids ½ inch (12.7 mm) or larger in size, string, rags, buttons, or other materials that are detrimental to the waste treatment system.

(IV) Sizing must be in accordance with the following formula:

Laundries (grease, lint, silt)

<u>Total gallons per cycle</u>	<u>X</u>	<u>Cycles per hour</u>	<u>X</u>	<u>Retention time*</u>	<u>X</u>	<u>Storage factor**</u>	<u>≡</u>	<u>Interceptor</u>
--------------------------------	----------	------------------------	----------	------------------------	----------	-------------------------	----------	--------------------

1034  
1035  
1036

\*Retention times

<u>Institutional laundries</u>	<u>2.5 hours</u>
<u>Standard commercial laundry</u>	<u>2.0 hours</u>
<u>Light commercial laundry</u>	<u>1.5 hours</u>

1037  
1038  
1039

\*\*Storage factors

<u>8 hours of operation</u>	<u>1.0</u>
<u>12 or more hours of operation</u>	<u>1.5</u>

1040  
1041  
1042  
1043  
1044  
1045  
1046  
1047  
1048

(B) Car Washes

(I) Where automobiles are washed (including detail shops utilizing hand-wash practices), separators shall have a minimum capacity of 1000 gallons for the first bay, with an additional 500 gallons of capacity for every other bay.

(II) Additionally, wash racks must be constructed to eliminate or minimize the impact of run-off from rain/storm events. Minimum requirements are roofed

1049 structures with at least two walls and appropriate grading to prevent stormwater infiltration into  
1050 the sanitary sewer.

1051  
1052 (III) An effluent sampling point is required.

1053  
1054 (f) Abandonment of Septic and Holding Tanks

1055  
1056 The following is the procedure to abandon septic tanks and holding tanks when the system is  
1057 upgraded, equipment replacement is necessary, or central sewer lines are made available.

1058  
1059 (i) The abandoned tank should be pumped and the septage hauled to a licensed  
1060 facility approved to receive the waste or the septage pumped into the newly constructed septic or  
1061 holding tank. Discharging to a central sewer requires coordination with, and the approval of, the  
1062 owner/operator of the sewer system.

1063  
1064 (ii) Once the abandoned tank is empty, it should be removed and the excavation  
1065 backfilled. As an alternative to removing the tank, the access covers can be removed; the bottom  
1066 drilled or broken up sufficient to drain; and the tank filled with native soil, pit run, or sand.

1067  
1068 (iii) If the abandoned tank is part of a Class V UIC facility, the abandonment must  
1069 also be in compliance with Chapter ~~16~~ 27, Section ~~12~~ 19.

1070  
1071 **Section 11. ~~Evapotranspiration Beds~~ Effluent Distribution Devices.**

1072  
1073 ~~Formerly Section 11(a) — Sizing. The area of evapotranspiration beds shall be determined using~~  
1074 ~~the following formula:~~

1075  
1076  
1077 ~~AREA = 586~~ 
$$\left[ \frac{Q}{PET - P} \right]$$

1078  
1079 where:

1080  
1081 ~~Area = Area of the evapotranspiration bed at the ground surface in square feet~~

1082  
1083 ~~Q = Average daily sewage flow, gallons per day, (0.6 times the flow determined from~~

1084 ~~Table 1) PET = Potential evapotranspiration rate in inches per year~~

1085 ~~P = Annual precipitation rate in inches per year.~~

1086  
1087 ~~Formerly 11 (b) — Construction.~~

1088  
1089 ~~Formerly 11 (b) (i) If an impervious barrier is necessary for the protection of~~  
1090 ~~groundwater it shall be installed between the evapotranspiration bed and the native soil. It shall~~  
1091 ~~be a polyvinyl chloride sheet with a minimum thickness of 20 mils or equivalent. A 3 inch~~  
1092 ~~layer of sand shall be placed under and over the liner.~~

1093  
1094 ~~Formerly 11 (b) (ii) — The bottom 12 inches of the bed shall be filled with clean~~  
1095 ~~stone 1/2 — 2 1/2 inches in~~

1096

1097                    ~~Formerly 11 (b) (iii) — Perforated pipe complying with Section 10(a)(v) shall be~~  
1098 ~~placed in the stone.~~

1099  
1100                    ~~Formerly 11 (b) (iv) — Four inches of pea gravel (less than 1/4 inch in~~  
1101 ~~diameter) or durable filter cloth shall be placed over the stone.~~

1102  
1103                    ~~Formerly 11 (b)(v) A 24 inch uniform sand layer in the size range of D50~~  
1104 ~~(0.10mm) shall be placed on top of the pea gravel or filter cloth.~~

1105  
1106                    ~~Formerly 11 (b) (vi) — A six inch layer of sandy topsoil shall be placed on top of~~  
1107 ~~the evapotranspiration bed.~~

1108  
1109                    ~~Formerly 11 (b) (vii) — The bed should be vegetated with small shrubs and/or grasses~~  
1110 ~~such as fescue, brome, or alfalfa.~~

1111  
1112                    ~~Formerly 11 (b) (viii) — The evapotranspiration bed shall be placed at a depth~~  
1113 ~~sufficient to prevent surcharging of the septic tank.~~

1114  
1115 Distribution boxes and flow divider tees are suitable for level or nearly level ground and are  
1116 installed before the soil absorption system with the goal of splitting flows equally between soil  
1117 absorption system laterals. Drop boxes are suitable for sloping ground and are installed to  
1118 achieve serial loading.

1119  
1120                    (a) Distribution Boxes

1121  
1122                    ~~(formerly 10(a)(vii)(i) Distribution box. If a The~~ distribution box is used, it shall  
1123 be installed to provide uniform distribution of the wastewater on a level, stable base to ensure  
1124 against tilting or settling and shall be placed so that it will not be subject to and to minimize  
1125 movement from frost heave.

1126  
1127                    (ii) Boxes shall be watertight and constructed of concrete or other durable material.

1128  
1129                    (iii) Boxes shall be designed to accommodate the inlet pipe and the necessary  
1130 distribution lines. The inlet piping to the distribution box shall be at least one (1) inch above the  
1131 outlet pipes and all pipes shall have a watertight connection to the distribution box.

1132  
1133                    (iv) The box shall be protected against freezing and made accessible for  
1134 observation and maintenance.

1135  
1136                    (v) Boxes shall have flow equalizers installed on each outflow.

1137  
1138                    (b) Flow divider tees may be used in place of distribution boxes.

1139  
1140                    (c) Drop boxes are suitable for sloping ground and are installed to achieve serial loading.  
1141 The drop boxes shall meet the requirements in paragraphs (a)(i through v) of this section.

1142  
1143                    **Section 12. ~~Holding Tanks~~ Standard Soil Absorption Systems.**

1144  
1145                    ~~(formerly 10(a) (a) General~~ Design ~~Requirements;~~

1146



1147 (i) All soil absorption systems shall be designed in such a manner that the  
1148 effluent is effectively filtered and retained below ground surface. The absorption surface accepts,  
1149 treats, and disperses wastewater as it percolates through the soil.

1150  
1151 ~~(formerly 10(a)(ii)(ii) Protection. Effort shall be made to protect the natural~~  
1152 ~~absorptive properties of the soil. Soil absorption systems shall not be installed during adverse~~  
1153 ~~weather or soil conditions. Rain, severely cold temperatures, or excessively moist soils are~~  
1154 ~~considered adverse weather or soil conditions. All smeared or compacted surfaces shall be~~  
1155 ~~restored to their original infiltrative conditions prior to placement of the stone. Soil absorption~~  
1156 systems shall not be excavated when the soil is wet enough to smear or compact easily. Open soil  
1157 absorption system excavations shall be protected from surface runoff to prevent the entrance of  
1158 silt and debris. All smeared or compacted surfaces shall be raked to a depth of one (1) inch, and  
1159 loose material removed before filter or filler material is placed in the soil absorption system  
1160 excavation.

1161  
1162 ~~(formerly 10(a)(iii) Runoff. Surface runoff shall be diverted around or away from all~~  
1163 ~~soil absorption systems.~~

1164  
1165 (iii) Soil absorption systems shall be designed to approximately follow the ground  
1166 surface contours so that variation in excavation depths will be minimized. The trenches may be  
1167 installed at different elevations, but the bottom of each individual trench shall be level throughout  
1168 its length.

1169  
1170 ~~(formerly 10(a)(ix) (iv) Earth cover. Shallow soil absorption system depths are~~  
1171 ~~encouraged to promote treatment and evapotranspiration. A minimum of 12 inches of earth shall~~  
1172 ~~be placed over the absorption system stone. The minimum soil cover depth over the soil~~  
1173 ~~absorption system is one (1) foot. The maximum depth to the bottom absorption surface of a soil~~  
1174 ~~absorption system is five (5) feet. The earth shall be permeable soil that will allow aeration of the~~  
1175 ~~system and will support the growth of grass. The earth cover shall be graded to insure that water~~  
1176 ~~will not pond on the surface. Finished grading shall prevent ponding and promote surface water~~  
1177 runoff.

1178  
1179 (v) Pipes, chambers or other products shall be bedded on firm, stable material.  
1180 Heavy equipment shall not be driven in or over soil absorption systems during construction or  
1181 backfilling.

1182  
1183 (vi) Standard trenches refer to perforated pipe embedded in aggregate-filled  
1184 trenches that shall conform to the following:

1185  
1186 ~~(formerly 10(a)(v))(A) Gravity pipe. All plastic gravity absorption system~~  
1187 The perforated pipes shall have a minimum diameter of four (4) inches and shall conform to ASTM  
1188 standard D2729. Suitable pipe materials include: ASTM D-2729-11 PVC, ASTM D-3034-08  
1189 PVC, Schedule 40 PVC ASTM d1784-11, and ASTM F810-07 PE. Piping in all horizontally  
1190 constructed absorption systems shall be layed with the holes centered around the vertical axis at

1191 ~~the bottom of the pipe. All field tile pipe shall be spaced 1/4 inch apart. Piping in horizontally~~  
1192 ~~constructed absorption systems shall have a maximum slope of three inches per 100 feet.~~

1193

1194 ~~(formerly 10(a)(vi)) Pressure pipe. All pressure distribution piping shall be~~  
1195 ~~designed to withstand the anticipated pressures with a safety factor of two, provide uniform~~  
1196 ~~application of the wastewater, and have non-clogging orifices.~~

1197

1198 ~~(formerly 10(a)(iv)) (B) — Stone. Soil absorption system stone.~~ The aggregate  
1199 shall be crushed rock, gravel or other acceptable, durable and inert material that is free of  
1200 finer, sized and has an effective diameter between 1/2-inch to 2 1/2 inches.

1201

1202 ~~(formerly 10(a)(viii)) (C) Stone cover. A suitable cover such as untreated~~  
1203 ~~building paper, filter cloth, or straw shall be placed over the stone prior to backfilling the system.~~  
1204 Prior to backfilling, the aggregate shall be covered throughout with a woven/non-woven  
1205 geotextile material or a three (3) inch layer of straw.

1206

1207 ~~((formerly 10(a)(iv)) (D) At least two inches of stone shall be placed over the~~  
1208 ~~distribution pipe, and at least six inches of stone shall be placed under and beside the distribution~~  
1209 ~~piping. A minimum of 12 inches of stone shall be placed between a seepage pit wall and~~  
1210 ~~structural liner. The stone shall be free from sand, silt, and clay. Aggregate shall extend the full~~  
1211 width and length of the soil absorption system to a depth of at least twelve (12) inches with at  
1212 least six (6) inches of drain gravel under the distribution pipe and at least two (2) inches over the  
1213 distribution pipe.

1214

1215 (E) Maximum width of trench excavation is three (3) feet.

1216

1217 ~~(formerly 10(d)) (F) Special requirements for trench systems. A Minimum~~  
1218 ~~separation spacing of trenches (wall to wall) of is three (3) feet or a horizontal distance equal to~~  
1219 ~~1.25 times the vertical depth of the trenches, whichever is greater, of undisturbed soil shall be~~  
1220 ~~maintained between adjacent trench sidewalls. Trench spacing shall be increased to nine (9) feet~~  
1221 when the area between each trench is considered as reserve area. For clay loam soils that have  
1222 percolation rates greater than 60 min/in., the nine (9) foot spacing shall also be required but it is  
1223 not considered as reserve area.

1224

1225 ~~(formerly 10(f)) (vii) Special requirement for bed systems. The distribution~~  
1226 ~~system piping shall be spaced no more than 10 feet apart. Standard beds shall conform to the~~  
1227 same pipe and aggregate requirements for trenches as found in subparagraphs (vi)(A through D)  
1228 of this section. Standard beds shall also conform to the following:

1229

1230 ~~(formerly 10(a)(x)) (A) Levelness. The soils shall have percolation rates~~  
1231 less than 60 minutes per inch (5-60 mpi). The bottom of soil absorption systems and each  
1232 segment of a sidehill system the bed shall must be level, therefore the site shall be relatively flat,  
1233 sloping no more than one (1) foot from the highest to the lowest point in the installation area.

1234

1235 (B) Distribution laterals within a bed must be spaced on not greater than six  
1236 (6) feet centers. Sidewalls shall not be more than three (3) feet from a distribution lateral.

1237  
1238 (C) Beds must not be wider than twenty-five (25) feet if gravity distribution  
1239 is used. Multiple beds must be spaced at one-half the bed width.

1240  
1241 (D) Rubber tired vehicles must not be driven on the bottom surface of any  
1242 bed excavation.

1243  
1244 (viii) Chambered trenches, when used in lieu of perforated pipe and aggregate, shall  
1245 be installed in conformance with the manufacturer recommendations. No cracked, weakened,  
1246 modified, or otherwise damaged chamber units shall be used in any installation.

1247  
1248 (A) All chambers shall be an open, arch-shaped structure of durable, non-  
1249 degradable design, suitable for distribution of effluent without filter material.

1250  
1251 (B) All chamber endplates shall be designed so that the bottom elevation of  
1252 the inlet pipe is at least six (6) inches from the bottom of the chamber.

1253  
1254 (C) Inlet and outlet effluent sewer pipes shall enter and exit the chamber  
1255 endplates. Inspection ports shall be installed at all outlet effluent sewer pipes.

1256  
1257 (D) All chambers shall have a splash plate under the inlet pipe or another  
1258 design feature to avoid unnecessary channeling into the trench bottom.

1259  
1260 (E) Maximum width of trench excavation is three (3) feet.

1261  
1262 (F) Minimum spacing of trenches (wall to wall) is three (3) feet. Trench  
1263 spacing shall be increased to nine (9) feet when the area between each trench is considered as  
1264 reserve area. For clay loam soils that have percolation rates more than 60 min/in., the nine (9)  
1265 foot spacing shall also be required but it is not considered as reserve area.

1266  
1267 (ix) Chambered beds shall conform to the same requirements for chambered  
1268 trenches as found in subparagraphs (viii)(A through D) of this section. Aggregate, as specified in  
1269 subparagraph (vi)(B) of this section, or native soil shall be used to fill the space between the  
1270 chambers.

1271  
1272 ~~(formerly 10(e)(x)) Special requirements for serial sidehill trench or bed systems.~~  
1273 Serial Sidehill Trench:

1274  
1275 ~~(formerly 10(e)(i)) (A) — Separation. —~~ A minimum of ~~three~~ six (6) feet of  
1276 undisturbed soil shall be maintained between adjacent trench or bed side walls.

1277

1278 ~~(formerly 10(e)(ii))(B)~~ Levelness. The bottom of each serial trench or bed  
1279 system shall be level.

1280  
1281 ~~(formerly 10(e)(iii))(C)~~ Overflow. The overflow pipe between serial soil  
1282 absorption systems shall be set no higher than the mid-point of the upstream distribution pipe.  
1283 The overflow pipe shall not be perforated.

1284  
1285 ~~(formerly 10(b) — Special requirements for seepage pits. If a structural lining is needed to~~  
1286 ~~support stone in a seepage pit, it shall be constructed of durable material not subject to excessive~~  
1287 ~~corrosion or decay and structurally capable of supporting the loads to which it will be subjected.~~  
1288 ~~The lining shall be perforated or otherwise designed to allow the passage of wastewater. Seepage~~  
1289 ~~pits shall be separated by a minimum distance equal to 3 times their diameter.~~

1290  
1291 (b) A design package for standard soil absorption systems is provided online at the  
1292 Division’s website to assist the applicant in submitting a completed application for coverage  
1293 under the general permit for small wastewater systems. The worksheet and calculations were  
1294 prepared by a registered professional engineer employed by the Wyoming Department of  
1295 Environmental Quality, Water Quality Division. The general design requirements stated in this  
1296 section are incorporated into the worksheets such that by properly completing the forms and  
1297 installing the components, the system will comply with these requirements.

1298  
1299 **Section 13. ~~Privies~~ Pressure Distribution Systems.**

1300  
1301 (a) General Design Requirements:

1302  
1303 (i) The basic elements of a pressure distribution system include a dosing tank,  
1304 filter, and a means to deliver specified doses to a small diameter pipe network within a soil  
1305 absorption system. Pressure distribution is required for mound systems or for bed systems with a  
1306 width greater than twenty-five (25) feet.

1307  
1308 (ii) Pumps must be sized to match the distribution system curve or demand.  
1309 Pumps shall be designed for sewage pumping applications and be accessible from the ground  
1310 surface.

1311  
1312 (iii) The control system for the pump and dosing tank shall, at a minimum, consist  
1313 of a “pump off” switch, a “pump on” switch, a “high liquid alarm”.

1314  
1315 (A) All electrical connections must be made outside of the chamber in either  
1316 an approved weatherproof box or an explosion-proof junction box.

1317  
1318 (B) The wiring from the junction box to the control box must pass through a  
1319 sealing fitting to prevent corrosive gases from entering the control panel.

1320  
1321 (C) All wires must be contained in solid conduit from the dosing chamber to  
1322 the control box.

1323  
1324 (iv) The pressure transport piping between the tank and the soil absorption system  
1325 shall be designed to prevent freezing.

1326  
1327                   (A) The ends of lateral piping shall be constructed with long sweep elbows or  
1328 an equivalent method to bring the end of the pipe to finished grade. The ends of the pipe shall be  
1329 provided with threaded plugs, caps, or other devices to allow for access and flushing of the  
1330 lateral.

1331  
1332                   (B) All joints in the manifold, lateral piping, and fittings shall be solvent-  
1333 welded using the appropriate joint compound for the pipe material. Pressure transport piping  
1334 may be solvent-welded or flexible gasket jointed.

1335  
1336                   (C) Where automatic siphons or other devices are used, they shall be  
1337 designed to empty the dosing tank in less than ten (10) minutes.

1338  
1339                   (v) The pressure distribution system shall have a combination of at least three (3)  
1340 vertical feet of filter sand and/or unsaturated native soil above the high groundwater level. The  
1341 filter sand shall conform to ASTM C-33, with less than 2% passing the #200 sieve.

1342  
1343                   (b) A design package for pressure distribution systems is provided online at the  
1344 Division’s website to assist the applicant in submitting a completed application for coverage  
1345 under the general permit for small wastewater systems. The worksheet and calculations were  
1346 prepared by a registered professional engineer employed by the Wyoming Department of  
1347 Environmental Quality, Water Quality Division. The general design requirements stated in this  
1348 section are incorporated into the worksheets such that by properly completing the forms and  
1349 installing the components, the system will comply with these requirements.

1350

1351                   **Section 14. ~~Chemical Toilets~~ Sand Mound Systems.**

1352

1353 ~~(formerly 14(a) — General requirements. Chemical toilets shall only be used in the containment~~  
1354 ~~of body wastes. These requirements apply only to the use of chemical toilets for permanent~~  
1355 ~~structures.~~

1356

1357 ~~— (formerly 14(b) — Greywater. If indoor plumbing is installed, a separate greywater~~  
1358 ~~disposal is required and shall meet the requirements of Section 3 through 12. The minimum~~  
1359 ~~design flows for greywater shall be obtained from Table 1 with a reduction of 33 percent~~  
1360 ~~allowed for the elimination of blackwater wastes.~~

1361

1362 ~~— (formerly 14(c) — Disposal. All chemical toilet wastes shall be disposed of at an~~  
1363 ~~approved wastewater facility. A letter of verification from the receiving agency, denoting~~  
1364 ~~acceptance of the wastewater generated shall be submitted with the plans. These wastes shall~~  
1365 ~~not be discharged into a soil absorption system.~~

1366

1367 ~~— (formerly 14(d) — Construction. Chemical toilets shall be constructed and installed to~~  
1368 ~~resist breakage or damage from routine usage. Outdoor chemical toilets shall be adequately~~  
1369 ~~stabilized and secured to prevent overturning. Materials used shall be resistant to the sewage~~  
1370 ~~wastes and the chemicals encountered. The holding compartment of the toilet shall be~~  
1371 ~~constructed to prevent accessibility to the public and to disease transmitting vectors.~~

1372

1373 ~~— (formerly 14(e) — Additives. No chemical or biological additive shall be placed in the~~  
1374 ~~toilet that may adversely affect the operation of a sewage treatment facility where the toilet~~  
1375 ~~waste will ultimately be disposed or that may adversely impact the quality of the groundwater~~

1376 ~~as specified in Chapter VIII, "Quality Standards for Groundwater of Wyoming."~~

1377

1378 The sand mound consists of a sand fill, an aggregate bed and a soil cap.

1379

1380 (a) Selection Criteria:

1381

1382 The high groundwater level, bedrock or impervious clay layer is less than four (4) feet below the  
1383 bottom of the soil absorption system excavation.

1384

1385 (b) Site Requirements:

1386

1387 (i) A minimum of one (1) foot of vertical separation of the native soil is required  
1388 between the bottom of the sand fill and the top of the high groundwater level, any restrictive  
1389 layer, or any highly permeable material.

1390

1391 (ii) The percolation rate of the native soil at the interface of the sand fill shall be  
1392 greater than five (5) and less than sixty (60) minutes per inch (5-60 mpi). The percolation shall  
1393 be measured in the top twelve (12) inches of native soil.

1394

1395 ~~(formerly 10(e)) (c) — Special requirements for mounded systems.~~ General Design  
1396 Requirements:

1397

1398 ~~(formerly 10(c)(i)) Sizing~~ (i) Sand Layer

1399

1400 ~~(A) The infiltrative surface between the stone and the fill material shall be~~  
1401 ~~sized based on the flow rate as determined by Section 3 and the allowable loading rate as~~  
1402 ~~determined by Figure 7 of Section 7 for the percolation rate of the fill. The total infiltrative~~  
1403 ~~surface is the sum of the sidewall and bottom areas of the stone-soil interface below the~~  
1404 ~~distribution pipe.~~

1405

1406 ~~(B) The interface area between the fill soil and the native soil shall be sized~~  
1407 ~~based on the infiltration rate of the native soil as determined by Figure 7 of Section 38 but shall~~  
1408 ~~not be smaller than a system designed to the requirements of subsection (ii) below.~~

1409

1410 (A) Filter sand shall conform to ASTM C-33, with less than 2% passing the  
1411 #200 sieve.

1412

1413 (B) The minimum depth of sand below the aggregate bed surface shall be  
1414 one (1) foot.

1415

1416 (C) The sand mound shall have a combination of at least four (4) vertical  
1417 feet of filter sand and unsaturated native soil above the high groundwater level.

1418

1419 (I) For sand mounds using pressure distribution systems, the depth  
1420 to high groundwater shall be three (3) feet below the bottom of the absorption surface if the  
1421 percolation rate of the soil is five (5) minutes per inch or greater (5-60 mpi).

1422  
1423 (D) The top of the sand layer under the aggregate bed shall be level in all  
1424 directions.

1425  
1426 (E) The sand layer shall fill around the perimeter of and to the top of the  
1427 aggregate bed.

1428  
1429 ~~(formerly 10(c)(ii))(F) Grade. The finished grade shall extend at~~  
1430 ~~least three feet horizontally beyond the stone and then be sloped to the parent soil at a grade no~~  
1431 ~~steeper than four horizontal to one vertical. The slope of all sides shall be three (3) horizontal to~~  
1432 ~~one (1) vertical or flatter.~~

1433  
1434 ~~(formerly 10(c)(i)(B))(G) The interface infiltration area between the fill soil~~  
1435 ~~and the native soil, which is the bottom of the sand fill, shall be sized calculated based on the~~  
1436 ~~infiltration rate of the native soil as determined by Figure 7 of Section 38 by dividing the design~~  
1437 ~~flowrates (gpd) from Table 1 or Table 2 by the loading rate (gpd/ft<sup>2</sup>) found in Table 5 but shall~~  
1438 ~~not be smaller than a system designed to the requirements of subsection (ii) below.~~

1439  
1440 (ii) Aggregate Bed

1441  
1442 (A) The aggregate shall be crushed rock, gravel or other acceptable, durable  
1443 and inert material that is free from fines, and has an effective diameter between one-half (1/2)  
1444 inch and two and one half (2 ½) inch.

1445  
1446 (B) The aggregate bed depth shall not be less than nine (9) inches with a  
1447 minimum of six (6) inches of clean aggregate placed below the distribution pipe and two (2)  
1448 inches above the distribution pipe. The aggregate shall be covered with an approved geotextile  
1449 material after installation and testing of the pressure distribution system.

1450  
1451 (C) The design shall be a long, narrow bed design with a maximum width of  
1452 twenty-five (25) feet.

1453  
1454 (D) The infiltration area, which is the bottom of the aggregate bed, shall be  
1455 calculated by dividing the design flowrates (gpd) from Table 1 and Table 2 by the loading rate of  
1456 0.8 gpd/ft<sup>2</sup>.

1457  
1458 (iii) Soil Cover

1459  
1460 (A) The soil cap shall be constructed of a sandy loam, loamy sand, or silt  
1461 loam. The depth of the soil cap shall be at least six (6) inches at the edges at twelve (12) inches  
1462 at the center. The slope of all sides shall be three (3) horizontal to one (1) vertical or flatter.

1463  
1464 ~~(formerly 10(c)(iii))(B) — Fill soil. The fill soil that is~~ A layer of top soil at  
1465 least six (6) inches thick shall be placed ~~between the native soil and the stone over the entire sand~~  
1466 mound area. shall have a minimum percolation rate of five minutes per inch. Topsoil shall be

1467 ~~placed over the mound to promote vegetative cover.~~ The sand mound should be planted with  
1468 vegetation that does not require watering and will not establish deep roots. Native grasses are  
1469 commonly used.

1470

1471 ~~(formerly 10(c)(iv)) — Preparation. All trees, roots, and other organic matter shall be~~  
1472 ~~removed from the area to be occupied by the mound.~~

1473

1474 (d) A design package for sand mound systems is provided online at the Division's  
1475 website to assist the applicant in submitting a completed application for coverage under the  
1476 general permit for small wastewater systems. The worksheet and calculations were prepared by a  
1477 registered professional engineer employed by the Wyoming Department of Environmental  
1478 Quality, Water Quality Division. The general design requirements stated in this section are  
1479 incorporated into the worksheets such that by properly completing the forms and installing the  
1480 components, the system will comply with these requirements.

1481

1482 **Section 15. ~~Small Non-discharging Waste Stabilization Ponds~~ Small Wastewater**  
1483 **Lagoons.**

1484

1485 (a) ~~General requirements.~~ Selection Criteria:

1486

1487 (i) ~~The use of this section for small nondischarging waste stabilization ponds~~  
1488 ~~applies only to those systems defined as small wastewater systems. All other treatment systems~~  
1489 ~~shall meet the requirements of Part B or Part C of Chapter XI as applicable.~~ Lagoons shall only  
1490 be considered in areas of Wyoming where the annual evaporation exceeds the annual  
1491 precipitation during the active use of the lagoon.

1492

1493 (ii) ~~Non discharging waste stabilization ponds Lagoons~~ shall only be constructed  
1494 in soils allowed where when the percolation rate exceeds sixty (60) minutes per inch and the soil  
1495 is at least 1 foot thick on both the sides and bottom of the pond extends vertically down at least  
1496 two (2) feet from the bottom of the lagoon to the seasonal high groundwater table or bedrock  
1497 formations. If the 60 minute per inch percolation rate cannot be obtained, a sufficient clay shall be  
1498 incorporated into the top foot of soil until the 60 minute per inch percolation rate is reached. An  
1499 impermeable artificial liner of 20 mils in thickness may be substituted.

1500

1501 (iii) A lagoon shall not be constructed within the 100 year ~~flood plain~~ floodplain.

1502

1503 (b) General Design Requirements:

1504

1505 ~~(formerly 15(b)) (i) Isolation. The isolation distances shall meet the requirements for~~  
1506 ~~absorption systems as specified in Section 4(a)(i). Beyond the horizontal setback distances~~  
1507 ~~requirements specified in Section 7(g) of this rule, the lagoon shall not be placed within one~~  
1508 ~~hundred (100) feet of the owner's property line.~~

1509

1510 (ii) The use of a septic tank that meets the specifications in Section 9 of this rule  
1511 shall be required before the small wastewater lagoon.

1512

1513 (iii) The lagoon shall be located and constructed so it will not receive surface runoff  
1514 water.



1515 (iv) The slope of the lagoon site shall not exceed five percent (5%).

1516 (v) The lagoon site must be located in an area of maximum exposure to sun and  
1517 wind.

1518  
1519 (vi) The lagoon shall be designed for complete retention.

1520  
1521 ~~(formerly 15(d)) Sizing.~~ (vii) The area of the lagoon shall be calculated based on  
1522 the following formula.

1523

1524 
$$A = \frac{584 \times Q}{(365 \times S) + (E - P)} \times 1.3$$

1525

1526 A = Area of the lagoon (in square feet) at the maximum operating depth of 5 feet feet  
1527 ~~water level in square feet~~

1528

1529 Q = Average daily sewage flow, gallons per day. ~~(0.6 times the flow determined from~~  
1530 ~~Table 1)~~ (Multiply values from Table 1 or 2 by 0.6 to get average daily flow.)

1531

1532 E = Average annual lake evaporation rate in inches per year. (Note: lake evaporation is  
1533 less than pan evaporation; lake evaporation equals pan evaporation times a pan coefficient of 0.7)

1534

1535 P = Average annual precipitation rate in inches per year.

1536

1537 S = Soil permeability in inches per day "S" cannot be greater than 0.25 inches per day  
1538 "S" shall equal zero for an artificial liner or for bedrock Seepage rate in decimal form, in inches  
1539 per day.

1540

1541 ~~(formerly 15(e)) Construction requirements.~~

1542

1543 ~~(formerly 15(e)(i)(viii))~~ (viii) The slopes of the ~~inside~~ dikes shall not be steeper than  
1544 three ~~(3)~~ horizontal to one (1) vertical ~~nor flatter than four horizontal to one vertical. The slopes~~  
1545 ~~of the outside dikes shall not be steeper than three horizontal to one vertical and shall not allow~~  
1546 ~~surface runoff to enter the pond. (formerly 15(e)(iv))~~ The minimum ~~top~~ width of the top of the  
1547 dike shall be ~~eight~~ four (4) feet.

1548

1549 ~~(formerly 15(e)(iii))~~ (ix) All fill ~~material~~ shall consist of impervious material that is  
1550 well compacted and free of rocks, frozen soil, or other large material.

1551

1552 ~~(x) (formerly 15(d)(ii))~~ (x) ~~A~~ The minimum ~~water level operating depth of at least two~~  
1553 ~~feet shall be two (2) feet maintained in the pond at all times, including start-up. (formerly~~  
1554 ~~15(d)(iii))~~ ~~A minimum free board of two feet shall be provided between the lowest embankment~~  
1555 ~~berm and the maximum water level. The maximum water level shall not be less than five feet. The~~  
1556 ~~dikes shall provide a minimum freeboard of two (2) feet.~~

1557

1558 ~~(formerly 15(e)(ii))~~ (xi) ~~All organic material and debris shall be removed from the~~  
1559 ~~pond site prior to construction. The floor of the lagoon shall be level and maintained free of all~~  
1560 ~~vegetation.~~

1561

1562 (xii) The influent line into the lagoon must discharge near the center.

1563  
1564 (xiii) A cleanout or manhole shall be provided in the influent line near the dike.

1565  
1566 (xiv) The area around the small wastewater lagoon shall be fenced to preclude the  
1567 entrance of livestock, pets, and humans. The fence shall be equipped with a locking gate. The  
1568 gate shall have a sign indicating “NO TRESPASSING – WASTEWATER LAGOON”.

1569  
1570 (c) A design package for a small wastewater lagoons is provided online at the Division’s  
1571 website to assist the applicant in submitting a completed application for coverage under the  
1572 general permit for small wastewater systems. The worksheet and calculations were prepared by a  
1573 registered professional engineer employed by the Wyoming Department of Environmental  
1574 Quality, Water Quality Division. The general design requirements stated in this section are  
1575 incorporated into the worksheets such that by properly completing the forms and installing the  
1576 components, the system will comply with these requirements.

1577  
1578 ~~(formerly 15(c))—Groundwater protection and bedrock or impermeable soil separation.~~

1579  
1580 ~~(formerly 15(c)(i))—For single family homes, the depth to seasonally high~~  
1581 ~~groundwater shall be at least four feet from the bottom of pond.~~

1582  
1583 ~~(formerly 15(c)(ii)) For all “small wastewater systems” other than single family~~  
1584 ~~homes, a minimum of three feet of unsaturated soil shall be maintained between the bottom of the~~  
1585 ~~pond and the estimated groundwater mound imposed on the seasonally high groundwater table.~~  
1586 ~~The height of the groundwater mound can be estimated from Figures 1-6, Section 5 in~~  
1587 ~~conjunction with the average daily sewage flow.~~

1588  
1589 **Section 16. ~~Commercial/Industrial Wastes~~ Privies or Outhouses.**

1590  
1591 Privies ~~and~~ or outhouses that meet the requirements of this section are permitted by rule. A permit  
1592 by rule requires the owner to submit the information contained in paragraph (g) of this section to  
1593 the Wyoming Department of Environmental Quality, Water Quality Division prior to constructing  
1594 or installing the facility. By submission of the required information, the owner acknowledges and  
1595 certifies they will comply with the requirements contained in this section.

1596  
1597 Pre-fabricated privies or outhouses shall be sealed, water-tight vaults and shall meet the following  
1598 conditions.

1599  
1600 ~~(formerly 13(a)) General requirements:~~

1601  
1602 ~~(formerly 13(a)(ii) If indoor plumbing is installed, the grey water disposal method~~  
1603 ~~shall meet the requirements of Section 3 through 12. The minimum design flow for grey water~~  
1604 ~~shall be obtained from Table 1 with a reduction of 33 percent allowed for the elimination of black~~  
1605 ~~wastes.~~

1606  
1607 ~~(formerly 13(a)(iii) The privy shall consist of a vault and an outhouse building.~~

1608  
1609 ~~(formerly 13(b)(a))—Isolation.~~ The ~~isolation~~ horizontal setback distance requirements  
1610 for ~~sealed~~ privies ~~and~~ or outhouses shall comply with Section 7(g) for septic tanks.

1611

1612 ~~(formerly 13(d)(ii))~~(b) The depth to seasonally high groundwater from the bottom of a  
1613 water tight vault shall be sufficient to prevent floatation of the empty vault.

1614  
1615 ~~(formerly 13(e))—Soil exploration.—Soil exploration to a minimum depth of 4 feet below~~  
1616 ~~the bottom of the proposed vault shall be made to provide information on subsoil condition.~~

1617  
1618 (c) The vault must have sufficient capacity for the dwelling served, and must have at  
1619 least 27 cubic feet or 200 gallons of capacity.

1620  
1621 ~~(formerly 13(a)(i))~~(d) ~~All privies shall be designed and constructed to prevent access~~  
1622 ~~by flies and rodents. Privies and or outhouses must be easily maintained and insect tight; must~~  
1623 ~~have a self-closing door; the privy or outhouse seat must include a cover; and all exterior~~  
1624 ~~openings, including vent openings, shall be screened. The door must be self closing. The privy~~  
1625 ~~seat must include a cover. All exterior openings, including vent openings, shall be screened.~~

1626  
1627 ~~(formerly 13(d))—Groundwater and bedrock separation.~~

1628  
1629 ~~(formerly 13(d)(i))—The depth to seasonally high groundwater and bedrock or~~  
1630 ~~impermeable soil shall be at least four feet from the bottom of an unlined vault.~~

1631  
1632 ~~(formerly 13(e))—Sizing.—Vaults shall have a minimum capacity of 500 gallons per riser~~  
1633 ~~and shall be a minimum of 4.5 feet deep.~~

1634  
1635 ~~(formerly 13(f))—Construction.~~

1636  
1637 ~~(formerly 13(f)(i))The vault shall be constructed and installed to resist breakage and~~  
1638 ~~damage imposed by frost heave, uplift pressures from a fluctuating water table, loads imposed by~~  
1639 ~~the outhouse building and soils, and damage that may be caused by vandalism or rough cleaning~~  
1640 ~~procedures. The vault shall be constructed~~  
1641 ~~to prevent access by flies.~~

1642  
1643 ~~(formerly 13(f)(ii))—Materials used for vault construction shall be resistant to alkali~~  
1644 ~~attack, hydrogen sulfide gas, and other corrosive elements associated with decomposing waste.~~

1645  
1646 ~~(formerly 13(f)(iii))—A clean-out manhole shall be installed and shall have a~~  
1647 ~~minimum opening of 20 inches in the least dimension. The manhole shall be located outside of~~  
1648 ~~the outhouse building and be equipped with a tightfitting secure cover.~~

1649  
1650 ~~(formerly 13(f)(iv))~~(e) Privies and or outhouses must be adequately vented.  
1651 ~~The vault shall be ventilated to a point outside and above the outhouse building. The outhouse~~  
1652 ~~building shall have a set of vents installed near the floor on two opposite sides of the building and~~  
1653 ~~a roof vent that has a rain cap. All vents shall be screened.~~

1654  
1655 ~~(formerly 13(g))—Vault additives.—No chemical or biological additive shall be placed in the~~  
1656 ~~vault that may adversely effect the operation of a sewage treatment facility where the vault waste~~  
1657 ~~will ultimately be disposed or that may adversely impact the quality of the groundwater as~~  
1658 ~~specified in Chapter VIII, “Quality Standards for Groundwater of Wyoming”.~~

1659  
1660 (f) Privies and or outhouses shall not be constructed within the 100 year flood plain  
1661 floodplain.

1662

1663 (g) A design package for privies is provided online at the Division's website to assist the  
1664 applicant in submitting a completed application for coverage under the general permit for small  
1665 wastewater systems. The worksheet and calculations were prepared by a registered professional  
1666 engineer employed by the Wyoming Department of Environmental Quality, Water Quality  
1667 Division. The general design requirements stated in this section are incorporated into the  
1668 worksheets such that by properly completing the forms and installing the components, the system  
1669 will comply with these requirements. Owner's name, address, phone number, legal description of  
1670 privy or outhouse (address, latitude/longitude, or ¼ ¼ section), and the date construction or  
1671 installation will begin.

### 1673 Section 17. Greywater Systems.

1674 It is the intent of this section to encourage and facilitate the productive and safe reuse of  
1675 greywater from domestic wastewater. Greywater systems that meet the requirements of this  
1676 section are permitted by rule. A permit by rule requires the owner to submit the information  
1677 contained in paragraph (e) of this section to the Wyoming Department of Environmental Quality,  
1678 Water Quality Division prior to constructing or installing the system. By submission of the  
1679 required information, the owner acknowledges and certifies they will comply with the  
1680 requirements contained in this section.

#### 1681 \_\_\_\_\_ (a) Applicability

1682 \_\_\_\_\_ (i) This section applies to any person who utilizes greywater for beneficial  
1683 irrigation uses.

1684 \_\_\_\_\_ (ii) This section is not applicable if the intent is to provide blackwater treatment.

1685 \_\_\_\_\_ (iii) A city, county, or other local government agency may, after a public hearing  
1686 and enactment of an ordinance or resolution, further restrict or prohibit the use of greywater  
1687 systems.

#### 1688 \_\_\_\_\_ (b) (a) Greywater Operation and Requirements

##### 1689 \_\_\_\_\_ (i) Restrictions

1690 \_\_\_\_\_ (A) Spray irrigation of greywater is not permitted.

1691 \_\_\_\_\_ (B) The installation of a greywater system shall not reduce or alter the  
1692 sizing requirements of the onsite wastewater system.

1693 \_\_\_\_\_ (C) Human, domestic pets, and animal contact with greywater and soil  
1694 irrigated with greywater shall be minimized.

1695 \_\_\_\_\_ (D)(A) Greywater shall not leave the property on which it is generated.  
1696 Ponding or runoff is prohibited.

1697 \_\_\_\_\_ (E) Water which has been used to wash diapers or similarly soiled or  
1698 infectious garments shall not enter the greywater system and shall be diverted into the sanitary  
1699 sewer or septic system.

1700 \_\_\_\_\_ (F) Water which contains hazardous materials such as paint, solvents,  
1701 petroleum products, oil, gasoline, antifreeze, solvents, pesticides and herbicides shall not enter the

1714 ~~greywater system. Greywater shall not contain hazardous chemicals derived from activities such~~  
1715 ~~as cleaning car parts, washing greasy or oily rags, or disposing of wastewater solutions from~~  
1716 ~~home photo labs or similar hobbyist or home occupational activities.~~

1717  
1718 ~~(G)(B) Greywater systems shall not be installed in a delineated~~  
1719 ~~floodplain.~~

1720  
1721 ~~(H)(C) The volume of greywater shall not exceed an average of 2000~~  
1722 ~~gallons per day.~~

1723  
1724 ~~(I)(D) Greywater shall not come in direct contact with or adversely~~  
1725 ~~impact surface or groundwater.~~

1726  
1727 ~~(J) Filter backwash water and flush water shall not be used for any~~  
1728 ~~purpose. The filter backwash and flush discharge shall be contained and disposed of into the~~  
1729 ~~building sewer system or septic tank with a design capacity to accept all the blackwater and~~  
1730 ~~greywater. Sanitary procedures shall be followed when handling filter backwash and flush~~  
1731 ~~discharge or greywater.~~

1732  
1733 ~~(ii) Odor control of the greywater system shall meet the requirement of~~  
1734 ~~Wyoming DEQ Air Quality Regulations Chapter 2, Section 11.~~

1735  
1736 ~~(iii) Stormwater~~

1737  
1738 ~~(A) The greywater system shall not be located in a drainage way.~~

1739  
1740 ~~(B) The greywater system shall prevent storm runoff from carrying the~~  
1741 ~~greywater off of the application site.~~

1742  
1743 ~~(iv)(iii) If the greywater system is to be used during the winter, the greywater~~  
1744 ~~system shall be designed to prevent freezing.~~

1745  
1746 ~~(e)(b) Estimating Greywater Discharge~~

1747  
1748 ~~(i) The greywater discharge for single family and multi-family dwellings shall be~~  
1749 ~~calculated by estimates of greywater use based on water use records, or the following procedure:~~

1750  
1751 ~~(A) The number of occupants of each dwelling unit shall be calculated as 2~~  
1752 ~~occupants per bedroom.~~

1753  
1754 ~~(B) The estimated greywater flows of each occupant shall be calculated in~~  
1755 ~~gallons per day (gpd) as follows:~~

1756  
1757 ~~Showers, bathtubs and wash basins – 25 gpd/occupant~~

1758  
1759 ~~Laundry – 15 gpd/occupant~~

1760  
1761 ~~(ii) The total number of occupants shall be multiplied by the applicable estimated~~  
1762 ~~greywater discharge as provided above and the type of fixtures connected to the greywater~~  
1763 ~~system.~~

1764

- 1765 ~~\_\_\_\_\_~~ ~~(d) (c)~~ Greywater System Components and Configurations
- 1766
- 1767 ~~\_\_\_\_\_~~ ~~(i)~~ Flow Diversion
- 1768
- 1769 ~~\_\_\_\_\_~~ ~~(A)(i)~~ All greywater systems shall have a flow diverter which directs means to
- 1770 direct greywater to either the blackwater system or the greywater system.
- 1771
- 1772 ~~\_\_\_\_\_~~ ~~(B)(ii)~~ Diverter valves shall not have the potential to allow backflow
- 1773 from the blackwater system into the greywater system.
- 1774
- 1775 ~~\_\_\_\_\_~~ ~~(C)~~ Pipe elbows with rotatable compression fittings or equivalent
- 1776 components may be used to connect greywater sources with the greywater system or blackwater
- 1777 system if the pipe can only be connected to one system at a time. A capping device such as a
- 1778 rubber slip cap with band clamp shall be used to seal the plumbing of the system that is not in
- 1779 use.
- 1780
- 1781 ~~\_\_\_\_\_~~ ~~(D)~~ The rubber discharge hose from a laundry washing machine may be
- 1782 moved between a vertical blackwater riser pipe and a vertical greywater riser pipe without the
- 1783 need for a diverter valve.
- 1784
- 1785 ~~\_\_\_\_\_~~ ~~(ii)~~ Greywater Collection Tank
- 1786
- 1787 ~~\_\_\_\_\_~~ ~~(A)~~ When the greywater system design includes a tank, specifications for
- 1788 the tank shall be submitted for approval. Such plans shall show all dimensions and other
- 1789 pertinent data.
- 1790
- 1791 ~~\_\_\_\_\_~~ ~~(B)~~ Shall be constructed of solid, durable materials not subject to excessive
- 1792 corrosion or decay and shall be water tight.
- 1793
- 1794 ~~\_\_\_\_\_~~ ~~(C)~~ Shall be structurally designed to withstand all anticipated earth or other
- 1795 loads. Tank covers shall be capable of supporting an earth load of not less than three hundred
- 1796 (300) pounds per square foot when the tank is installed underground.
- 1797
- 1798 ~~\_\_\_\_\_~~ ~~(D)~~ Shall be covered to prevent access by flying insects, rodents, domestic
- 1799 animals and people.
- 1800
- 1801 ~~\_\_\_\_\_~~ ~~(E)~~ Shall be vented with a suitable screen to keep animals and insects out
- 1802 of the system.
- 1803
- 1804 ~~\_\_\_\_\_~~ ~~(F)~~ Inside collection tank shall be installed in accordance with the
- 1805 International Building Code for internal plumbing for black water.
- 1806
- 1807 ~~\_\_\_\_\_~~ ~~(G)~~ Shall not hold greywater for more than 24 hours.
- 1808
- 1809 ~~\_\_\_\_\_~~ ~~(H)~~ Overflow Requirements:
- 1810
- 1811 ~~\_\_\_\_\_~~ ~~(I)~~ Each tank shall have an overflow drain. The overflow drain
- 1812 shall have a permanent connection to the building drain or building sewer, upstream of septic
- 1813 tanks, if any. The overflow drain shall not be equipped with a shutoff valve.
- 1814

1815 ~~\_\_\_\_\_ (II) The overflow drain shall not be less in diameter than the inlet~~  
1816 ~~pipe.~~

1817  
1818 ~~\_\_\_\_\_ (III) The overflow system must be designed so that the tank overflow~~  
1819 ~~will drain by gravity to the existing sewer line or septic tank. The tank shall be protected against~~  
1820 ~~sewer line backflow by a check valve.~~

1821 ~~\_\_\_\_\_~~  
1822 ~~\_\_\_\_\_ (iii) Piping~~

1823  
1824 ~~\_\_\_\_\_ (A) Greywater conveyance pipes shall be permanently labeled for~~  
1825 ~~Greywater or shall be colored purple. Non-paint marking pens are unacceptable as permanent~~  
1826 ~~labeling.~~

1827  
1828 ~~\_\_\_\_\_ (B) Gravity flow pipes shall be constructed to allow complete draining of~~  
1829 ~~the pipe.~~

1830  
1831 ~~\_\_\_\_\_ (C) Pressurized pipe systems shall be constructed and designed to be~~  
1832 ~~drained or the water evacuated by compressed air for winterization.~~

1833  
1834 ~~\_\_\_\_\_ (iv) Disinfection~~

1835  
1836 ~~\_\_\_\_\_ (A)(iii) All greywater Greywater to be used for surface irrigation shall~~  
1837 ~~should be disinfected. The disinfection should achieve a fecal coliform level of 200 cfu/100 mL~~  
1838 ~~or less.~~

1839  
1840 ~~\_\_\_\_\_ (B) Disinfection may be accomplished through chemical methods or~~  
1841 ~~ultraviolet disinfection systems.~~

1842  
1843 ~~\_\_\_\_\_ (I) Chemical disinfection~~

1844  
1845 ~~\_\_\_\_\_ (1.) Chemical disinfection methods include the use of iodine,~~  
1846 ~~chlorine, or bromine.~~

1847  
1848 ~~\_\_\_\_\_ (2.) Chemical disinfection shall provide the proper dosage of~~  
1849 ~~disinfection to achieve a fecal coliform level of 200/100 mL or less.~~

1850  
1851 ~~\_\_\_\_\_ (II) Ultraviolet disinfection systems~~

1852  
1853 ~~\_\_\_\_\_ (1.) Ultraviolet (UV) disinfection systems shall be designed~~  
1854 ~~and installed according to the manufacturer recommendations.~~

1855  
1856 ~~\_\_\_\_\_ (2.) Greywater disinfected by a UV disinfection system shall~~  
1857 ~~have a UV transmittance less than the UV transmittance rated by the manufacturer.~~

1858  
1859 ~~\_\_\_\_\_ (3.) The max flow rate of the UV disinfection system shall not~~  
1860 ~~be exceeded.~~

1861 ~~\_\_\_\_\_ (e)(d) Setbacks~~

1863

1864 (i) A 30 foot buffer zone is required between the greywater application site and  
1865 adjacent property lines and any public right-of-way. This buffer zone requirement may be met by  
1866 the use of a subsurface drip irrigation system.

1867 \_\_\_\_\_  
1868 (ii) A 30 foot separation distance is required between greywater application sites  
1869 and all surface waters.

1870 \_\_\_\_\_  
1871 (iii) A 100 foot separation distance is required between greywater application sites  
1872 and all potable water supply wells.

1873 \_\_\_\_\_  
1874 (f) ~~Greywater Applications.~~

1875 \_\_\_\_\_  
1876 (i) ~~General~~

1877 \_\_\_\_\_  
1878 (A) ~~Each zone of an irrigation field must be of adequate size to receive the~~  
1879 greywater anticipated in that zone.

1880 \_\_\_\_\_  
1881 (B) ~~No irrigation or disposal field shall extend within three (3) vertical feet~~  
1882 of the highest known seasonal groundwater, or to a depth where greywater contaminates the  
1883 groundwater or surface water.

1884 \_\_\_\_\_  
1885 (C) ~~Permeable pipe systems designed for greywater shall be installed~~  
1886 according to manufacturer's recommendations.

1887 \_\_\_\_\_  
1888 (ii) ~~Subsurface Irrigation~~

1889 \_\_\_\_\_  
1890 (A) ~~Subsurface irrigation with greywater may be used to irrigate land and~~  
1891 vegetation.

1892 \_\_\_\_\_  
1893 (B) ~~Food crops for direct human consumption shall not be harvested for 30~~  
1894 days after application of greywater.

1895 \_\_\_\_\_  
1896 (C) ~~Subsurface irrigation shall not overwhelm the absorption system~~  
1897 leading to overland flow.

1898 \_\_\_\_\_  
1899 (D) ~~Mulch Basins~~

1900 \_\_\_\_\_  
1901 (1.) ~~The total irrigation and/or mulch basin area required must be~~  
1902 equal to the estimated greywater discharge (gpd) divided by the absorption capacity (gpd/ft2).

1903 \_\_\_\_\_  
1904 (2.) ~~Shall be sized to provide sufficient depth, length and width to~~  
1905 prevent ponding or runoff during the greywater surge of a clothes washer, bathtub or shower.  
1906 Mulch shall be replenished as required due to decomposition of organic matter. Mulch basins  
1907 will require periodic maintenance, reshaping or removal of dirt to maintain surge capacity,  
1908 accommodate plant growth, and prevent ponding or runoff.

1909 \_\_\_\_\_  
1910 (3.) ~~Shall not be deeper than the root zone of the plants to be~~  
1911 irrigated.

1912 \_\_\_\_\_  
1913 (4.) ~~Free Flow Outlets~~

1914 \_\_\_\_\_



- 1915 ~~\_\_\_\_\_ a. \_\_\_\_\_ Greywater shall be applied at the top of the mulch.~~  
1916  
1917 ~~\_\_\_\_\_ b. \_\_\_\_\_ Application point(s) shall be protected from access by~~  
1918 ~~\_\_\_\_\_ flying insects, rodents, domestic animals and people. Protections shall be constructed to allow~~  
1919 ~~\_\_\_\_\_ easy access for cleaning and maintenance.~~  
1920  
1921 ~~\_\_\_\_\_ c. \_\_\_\_\_ Inlet piping to the mulch basin shall be no less than 1 inch~~  
1922 ~~\_\_\_\_\_ higher than the surface to which it is applied to allow for free fall of water.~~  
1923  
1924 ~~\_\_\_\_\_ (5.) \_\_\_\_\_ Sub mulch Outlets~~  
1925  
1926 ~~\_\_\_\_\_ a. \_\_\_\_\_ Greywater shall be applied below the surface of the mulch~~  
1927 ~~\_\_\_\_\_ into one or more distribution chambers constructed of perforated material.~~  
1928  
1929 ~~\_\_\_\_\_ b. \_\_\_\_\_ Inlet piping to distribution chamber of the mulch basin~~  
1930 ~~\_\_\_\_\_ shall be no less than 2 inches higher than the surface to which it is applied to allow for free fall of~~  
1931 ~~\_\_\_\_\_ water.~~  
1932 ~~\_\_\_\_\_ c. \_\_\_\_\_ Distribution chamber shall be constructed for easy~~  
1933 ~~\_\_\_\_\_ cleaning and maintenance.~~  
1934  
1935 ~~\_\_\_\_\_ (6.) \_\_\_\_\_ A compost pile shall meet the requirements of a mulch basin.~~  
1936  
1937 ~~\_\_\_\_\_ (E) \_\_\_\_\_ Drip Systems~~  
1938 ~~\_\_\_\_\_~~  
1939 ~~\_\_\_\_\_ (1.) \_\_\_\_\_ Shall be filtered prior to the point of application or shall be~~  
1940 ~~\_\_\_\_\_ designed to prevent frequent clogging.~~  
1941  
1942 ~~\_\_\_\_\_ (2.) \_\_\_\_\_ Discharge nozzles shall be specifically designed for the~~  
1943 ~~\_\_\_\_\_ application of greywater without clogging.~~  
1944  
1945 ~~\_\_\_\_\_ (3.) \_\_\_\_\_ Drilled pipe drip system holes shall be no smaller than ¼ inches~~  
1946 ~~\_\_\_\_\_ in diameter.~~  
1947  
1948 ~~\_\_\_\_\_ (4.) \_\_\_\_\_ Point of application flow shall be low enough to prevent any~~  
1949 ~~\_\_\_\_\_ surface flow of greywater.~~  
1950  
1951 ~~\_\_\_\_\_ (iii) \_\_\_\_\_ Surface Irrigation~~  
1952 ~~\_\_\_\_\_~~  
1953 ~~\_\_\_\_\_ (A) \_\_\_\_\_ Greywater used for surface irrigation shall receive a level of~~  
1954 ~~\_\_\_\_\_ disinfection so the maximum fecal coliform level is 200/100 mL or less.~~  
1955 ~~\_\_\_\_\_~~  
1956 ~~\_\_\_\_\_ (B) \_\_\_\_\_ Surface irrigation with greywater that has been treated by disinfection~~  
1957 ~~\_\_\_\_\_ may be used for irrigation of land and vegetation.~~  
1958  
1959 ~~\_\_\_\_\_ (C) \_\_\_\_\_ Flood irrigation~~  
1960  
1961 ~~\_\_\_\_\_ (1.) \_\_\_\_\_ Shall not cause channeling or erosion of the application site.~~  
1962  
1963 ~~\_\_\_\_\_ (2.) \_\_\_\_\_ Shall use a distribution system to evenly distribute flows across~~  
1964 ~~\_\_\_\_\_ the site.~~  
1965

1966 ~~\_\_\_\_\_ (3.) Shall not pond in excess of ¼ inch in depth.~~

1967

1968 ~~\_\_\_\_\_ (4.) Greywater shall not remain on the ground surface for more than~~  
1969 ~~15 minutes after source flow has stopped.~~

1970

1971 ~~\_\_\_\_\_ (g) A design package for greywater systems is provided online at the Division's website~~  
1972 ~~to assist the applicant in submitting a completed application for coverage under the general permit~~  
1973 ~~for small wastewater systems. The worksheet and calculations were prepared by a registered~~  
1974 ~~professional engineer employed by the Wyoming Department of Environmental Quality, Water~~  
1975 ~~Quality Division. The general design requirements stated in this section are incorporated into the~~  
1976 ~~worksheets such that by properly completing the forms and installing the components, the system~~  
1977 ~~will comply with these requirements.~~

1978

1979 ~~(e) Owner's name, address, phone number, legal description of greywater system~~  
1980 ~~(address, latitude/longitude, or ¼ ¼ section), and the date construction or installation will begin.~~

1981

1982

1983 **Section 18. Operation and Maintenance.**

1984

1985 ~~(a) For any system that disposes of wastewater through land application or subsurface~~  
1986 ~~filtration, the owner shall not add any chemical or biochemical additive to the system that would~~  
1987 ~~adversely affect the quality of the groundwater as stated in the WDEQ Water Quality Rules &~~  
1988 ~~Regulations, Chapter 8.~~

1989

1990 ~~(b) Septic tanks shall be pumped as needed to prevent solids carryover into the soil~~  
1991 ~~absorption system.~~

1992

1993 ~~(c) Holding tanks and sealed vaults shall be pumped prior to reaching their maximum~~  
1994 ~~capacity. It is preferable that these types of tanks be pumped before the wastewater volume~~  
1995 ~~exceeds 75% of the tank's capacity.~~

1996

1997 ~~(d) Any service provider that pumps septic tanks, holding tanks, or sealed vaults, shall~~  
1998 ~~dispose of the wastewater contents at a permitted wastewater treatment facility or in a manner~~  
1999 ~~approved by the Division or delegated authority.~~

2000

2001 ~~(e) Damaged fittings and broken, crushed or plugged piping associated with any small~~  
2002 ~~wastewater system shall be replaced in a timely manner.~~

2003

2004 ~~(f) Composting or non-discharging toilets where permitted shall have their waste~~  
2005 ~~disposed of at a permitted wastewater treatment facility or landfill, or in a manner approved by~~  
2006 ~~the Division or delegated authority.~~

2007

2008 **Section 19. Commercial and Industrial Wastes and/or Domestic Wastes Greater**  
2009 **Than 2000 Gallons per Day.**

2010

2011 ~~(formerly 16 (a)) (a) General requirements. Those Commercial/industrial wastewater systems or~~  
2012 ~~combination commercial/industrial and domestic wastewater systems are subject to applicable~~

2013 requirements listed in Section 1 through ~~12 and 15~~ 14-15 of this chapter, in addition to  
2014 requirements in this section.

2015  
2016 ~~(formerly 16(b)) (b) — Hydrogeologic investigation.~~ If the wastewater is classified as, or  
2017 determined to be hazardous and/or toxic and/or contain petroleum products, the applicant shall  
2018 demonstrate to the administrator that any discharge or seepage from the wastewater facility will  
2019 not cause a violation of the surface and/or groundwaters of the state in accordance with Chapter  
2020 1, “Quality Standards for Wyoming Surface Waters” and Chapter 8, “Quality Standards for  
2021 Wyoming Groundwaters.” Due to the wide variety of wastes, wastewater and site conditions, the  
2022 latest available scientific information shall be used to demonstrate that violation will not occur.

2023  
2024 ~~(formerly 16(c)) (c) — Impact.~~ If the impact of the hazardous and/or toxic substance  
2025 and/or petroleum products cannot be determined and mitigated, disposal of the wastewater using  
2026 a soil absorption system shall be prohibited.

2027  
2028 ~~(formerly 16(d)) (d) — Pre-treatment.~~ Pre-treatment of the wastewater to remove the  
2029 hazardous, ~~and/or toxic, substance(s)~~ and/or petroleum products shall be required prior to disposal  
2030 if deemed necessary to protect the groundwater and surface water(s) of the state .

2031  
2032 ~~(formerly 4(a)(ii)) (e) If the flow is greater than 2000 gpd but less than 10,000 gpd, the~~  
2033 ~~minimum isolation distances (in feet) shown in Table 3 shall be maintained.~~ The minimum  
2034 horizontal setback distances (in feet) shown in Table 7 shall be maintained for commercial and  
2035 industrial wastes and/or wastes greater than 2000 gallons per day but less than 10,000 gallons per  
2036 day.

2037  
2038 ~~(formerly Table 3)~~ **Table 7. Minimum Horizontal Setbacks for Commercial and**  
2039 **Industrial Wastes in Feet<sup>1</sup>**

From	To Septic Tank Or Equivalent	To Absorption System
Wells (includes neighboring wells)	50	200
<u>Public Water Supply Well</u>	<u>100</u> <sup>2</sup>	<u>500</u> <sup>2</sup>
Property Lines	10	10
Foundation Wall (w/o drains)	5	10
Foundation Wall (with drains)	5	50
Potable Water Pipes	25	50
Septic Tank	N/A	10
<del>Stream or</del> Surface <del>Body of</del> Water, <u>Spring</u> (including seasonal and intermittent)	50	100
<u>Cisterns</u>	<u>50</u>	<u>50</u>

2041 <sup>1</sup> ~~(formerly 4(a)(iii))~~ For systems larger than 10,000 gallons per day, the isolation distance shall be  
2042 determined by a hydrogeological study in accordance with ~~Section 15(b)~~ Section 17(b) of Chapter  
2043 III, but shall not be less than those ~~in subsection two above~~ shown in Table 7.

2044

2045 <sup>2</sup> Wastewater systems that discharge to the same aquifer that supplies a public water supply well and  
2046 are located within Zone 1 or 2 (Attenuation) of the public water supply well, as determined by  
2047 Wyoming Department of Environmental Quality Source Water Assessment Project (2004) or as  
2048 established in Section 2 of the Wyoming Wellhead Protection Guidance Document (1997), shall  
2049 provide additional treatment. These systems will be required to obtain an individual permit to  
2050 construct and will require that a PE sign, stamp, and date the application, as stated in Section 2 of  
2051 this chapter. The additional treatment shall be in accordance with Chapter III, Section 2(b)(ii). The  
2052 treatment shall reduce the nitrates to less than 10 mg/L of NO<sub>3</sub>- as N and provide 4-log removal of  
2053 pathogens before the discharge leaves the property boundary of each small wastewater system.  
2054  
2055

2056 **APPENDIX A**  
2057 **Percolation Test Procedure**  
2058

2059 **Section 1. Purpose**  
2060

2061 (a) Percolation tests are used to determine absorption system site suitability and to size  
2062 the absorption system.  
2063

2064 **Section 2. Procedure**  
2065

2066 ~~(formerly (a))~~ (a) ~~Location.~~ General Requirements:  
2067

2068 (i) Percolation tests shall not be conducted in test holes that extend into  
2069 groundwater, bedrock, or frozen ground.  
2070

2071 (ii) The percolation test shall be conducted only after the soil exploration pit has  
2072 been dug and examined.  
2073

2074 ~~(formerly (a))~~ (iii) A minimum of three (3) percolation test holes are required.  
2075

2076 ~~(formerly (a))~~ (iv) The percolation test holes shall be spaced uniformly over the  
2077 proposed soil absorption system site.  
2078

2079 ~~(formerly (b))~~ (b) Preparation.  
2080

2081 ~~(formerly (b))~~ (i) A ~~four (4) inch to~~ twelve (12) inch diameter hole shall be dug or  
2082 bored to the proposed depth of the soil absorption ~~field~~ system.  
2083

2084 (ii) The walls shall be vertical, with the natural soil surface exposed without  
2085 smearing.  
2086

2087 ~~(iii) To expose a natural soil surface~~ The sides and bottom shall be ~~seraped~~ scarified  
2088 with a sharp pointed instrument and the loose material shall be removed from the hole.  
2089

2090 (iv) Two (2) inches of ~~Coarse sand or gravel~~ gravel or coarse sand shall be placed  
2091 in the bottom of the hole to prevent it from scouring and sealing during water addition.  
2092

2093 (c) Presoaking  
2094

2095 ~~(formerly (c))~~ (i) ~~Presoaking.~~ The purpose of presoaking is to have the water  
2096 conditions in the soil reach a stable condition similar to that which exists during continual  
2097 wastewater application. The minimum time of presoaking varies with soil conditions but must  
2098 be sufficiently long so that the water seeps away at a constant rate. The following presoaking  
2099 instructions are usually sufficient to obtain a constant rate.  
2100

2101 ~~(formerly (c)(i))~~ (A) ~~In sandy soils, place 12 inches of water in the hole. Fill~~  
2102 each hole with clear water to a level at least eighteen (18) inches above the gravel or coarse  
2103 sand and allow it to seep away. Fill the hole again with 12 inches of water and if the water  
2104 seeps away in ten minutes or less, it indicates that the soil is excessively permeable and

2105 ~~requirements in Section 5(d) of these regulations shall be followed. If the eighteen (18) inches~~  
2106 ~~of water seeps away in eighteen (18) minutes or less, add eighteen (18) inches of water a~~  
2107 ~~second time. If the water remains after ten minutes, additional saturation is necessary. Refer to~~  
2108 ~~Appendix A(e)(ii) below. If the second filling of eighteen (18) inches of water seeps away in~~  
2109 ~~eighteen (18) minutes or less, this indicates the soil is sandy and is excessively permeable. The~~  
2110 ~~soil absorption system shall meet the requirements of Section 8 (c).~~

2111  
2112 ~~(formerly (e) (ii)) (B) In other soils, maintain 12 inches of water in the hole~~  
2113 ~~for at least four hours. If either the first or second fillings of eighteen (18) inches of water~~  
2114 ~~does not seep away in ninety (90) minutes, eighteen (18) inches of water must be~~  
2115 ~~maintained in the hole for at least four (4) hours to presoak the test hole. After the four (4)~~  
2116 ~~hours of water contact time, allow the soil to swell for wait at least twelve (12) hours before~~  
2117 ~~starting the percolation rate measurement as stated in Appendix A (d) below.~~

2118  
2119 ~~(formerly (d) (d) Percolation Rate Measurement The water level should be~~  
2120 ~~adjusted to six inches above the gravel initially and after each time interval measurement~~  
2121 ~~when necessary.~~

2122  
2123 ~~(formerly (i)) (i) In other soils, establish a fixed reference point and measure the~~  
2124 ~~drop in water level at constant intervals. The water level drop should be measured to the~~  
2125 ~~nearest 1/8 of an inch. The test may be terminated when the water drop is consistent for three~~  
2126 ~~consecutive measurements. Fill each test hole with twelve (12) inches of water and allow the~~  
2127 ~~soil to rehydrate for 15 minutes prior to any measurements~~

2128  
2129 (ii) Establish a fixed reference point to measure the incremental water level  
2130 drop at constant time intervals. The water level drop should be measured to the nearest 1/8 of  
2131 an inch and the minimum time interval is ten (10) minutes.

2132  
2133 (iii) Refill the test hole to twelve (12) inches above the gravel before starting  
2134 the measurements. Continue to measure the incremental water level drop at a constant time  
2135 interval until a consistent incremental water level drop is achieved. A consistent water level  
2136 drop is achieved when three (3) consecutive water level drops are within 1/8 inches of each  
2137 other.

2138 (iv) Before the water level drops below one (1) inch above the gravel, refill the  
2139 test hole to twelve (12) inches and continue to measure the incremental water level drop.

2140  
2141 ~~(formerly d(ii))(v) The percolation rate for each hole is calculated as follows~~  
2142 ~~for each hole using the following formula:~~  
2143

$$\begin{array}{l} \text{Time Interval (Minutes)} \\ \text{Final Water Level Drop (inches)} \end{array} = \begin{array}{l} \text{Percolation Rate} \\ \text{(minutes/inch)} \end{array}$$

2144 ~~(formerly d(ii)) (vi) If only three to five percolation tests are performed, the~~  
2145 ~~design percolation rate for the absorption system is the slowest rate from all the holes tested. If six~~  
2146 ~~or more percolation tests are performed, the design percolation rate for the absorption system is~~  
2147 ~~the average of all the holes tested as determined by the above formula.~~

2148  
2149 (e) The following information shall be recorded:  
2150

- 2151                    (i) Date(s) of test(s);
- 2152
- 2153                    (ii) Location, diameter, and depth of each test hole;
- 2154
- 2155                    (iii) Duration of presoak;
- 2156
- 2157                    (iv) Time of day for beginning and end of each water-level drop interval;
- 2158
- 2159                    (v) Each water-level drop measurement;
- 2160
- 2161                    (vi) Calculated percolation rate;
- 2162
- 2163                    (vii) Name and signature of person performing test;
- 2164
- 2165                    (viii) Name of owner or project name; and
- 2166
- 2167                    (ix) Certification that the percolation test was done in accordance with Wyoming
- 2168 Water Quality Rules and Regulations Chapter 25 Appendix A.
- 2169

2170  
2171  
2172  
2173  
2174  
2175  
2176  
2177  
2178  
2179  
2180  
2181  
2182  
2183  
2184  
2185  
2186  
2187  
2188  
2189  
2190  
2191  
2192  
2193  
2194  
2195  
2196  
2197  
2198  
2199  
2200  
2201  
2202  
2203  
2204  
2205  
2206  
2207  
2208  
2209  
2210  
2211  
2212  
2213  
2214  
2215  
2216  
2217

~~(Formerly Chapter 15, Appendix C)~~ **APPENDIX B**  
~~General Statewide Permit~~  
~~For~~ Land Application of Domestic Septage in Remote Areas

~~Department of Environmental Quality/Water Quality Division~~  
~~Septage Land Application Worksheet~~

Section 1. Restrictions and Requirements

To qualify for the land application of domestic septage (~~domestic septage being defined as either liquid or solid material removed from a septic tank result from normal household wastes~~) in remote areas, the following conditions must be met.

**DEFINITIONS**

\* ~~“Permanent waterbody” means perennial streams, lakes, wetlands, etc. that have water throughout the year~~

\* ~~“Intermittent stream” means a stream or part of a stream that is below the local water table for some part of the year but is not a perennial stream.~~

\* ~~“Ephemeral stream” means a stream which flows only in direct response to precipitation in the immediaste watershed or in response to snow melt, and has a channel bottom that is always above the prevailing water table.~~

\* ~~“Wetland” means those areas having all three essential characteristics:~~

~~—— (A) Hydrophytic vegetation;~~

~~—— (B) Hydric soils;~~

~~—— (C) Wetlands hydrology.~~

(a) Location restrictions

(i) Only domestic septage generated on the property owner's location may be land applied on the same property owner's location. Domestic septage generated on a specific property may be land applied on said property, and shall not be transported to another location for land application.

(ii) A minimum distance of at least 1,000 feet must be maintained from all adjacent properties. No land application of domestic septage shall occur within 1,000 feet of all adjacent properties.

(iii) No land application of domestic septage may occur within 300 feet of a permanent waterbody, intermittent stream, ephemeral stream or wetland.

~~—— No land application of domestic septage may occur within 300 feet of public road.~~



2218 ~~\_\_\_\_\_~~ No land application of domestic septage shall occur within 300 feet of a public road,  
2219 permanent surface water body, or intermittent stream.

2220  
2221 ~~\_\_\_\_\_~~ No land application of domestic sewage may occur within 1000 feet of a residence  
2222

2223 (b) Site restrictions;  
2224

2225 (i) The land application of domestic septage shall only occur on those sites with  
2226 established vegetation such as rangeland, pasture or hay meadows.  
2227

2228 (ii) No more than 5,000 gallons of domestic septage per acre per year shall be land  
2229 applied.  
2230

2231 (iii) ~~No land application of domestic septage may occur where the depth from the~~  
2232 ~~surface to groundwater is less than four (4) feet.~~  
2233

2234 ~~\_\_\_\_\_~~ No land application of domestic septage may occur where site slopes exceed five  
2235 percent (5%).  
2236

2237 ~~\_\_\_\_\_~~ No land application of domestic septage shall occur where the site's slope exceeds  
2238 five percent (5%) or where the depth to groundwater is less than four (4) feet.  
2239

2240 (iv) The land application of domestic septage shall not occur between November 1  
2241 and May 1, or any other time when frozen or saturated ground conditions exists.  
2242

2243 (v) No public access shall be allowed to any site where domestic septage has been  
2244 applied for at least one (1) year following application. ~~to any site where domestic septage has~~  
2245 ~~been applied.~~  
2246

2247 ~~\_\_\_\_\_~~ Lime stabilization of the septage to pH 12 for 30 minutes prior to land application is  
2248 optional

2249 (vi) No grazing animals shall be allowed access to any site where domestic septage  
2250 has been land applied for at least thirty (30) days following application. ~~to any site where~~  
2251 ~~domestic septage has been land applied.~~  
2252

2253 (c) Crop restrictions;  
2254

2255 (i) No root crops shall be harvested from soils where domestic septage has been  
2256 land applied for at least thirty-eight(38) months following application. ~~from soils where domestic~~  
2257 ~~septage has been land applied.~~  
2258

2259 (ii) No truck crops (harvested parts touch land surface) shall be harvested from  
2260 soils where domestic septage has been land applied for at least fourteen(14) months following  
2261 application. ~~from soils where domestic septage has been land applied.~~  
2262

2263 (iii) No commodity crops (other food, feed, and fiber crops whose harvested parts  
2264 do not touch land surface) shall be harvested from soils where domestic septage has been land  
2265 applied for at least thirty(30) days following application. ~~from soils where domestic septage has~~  
2266 ~~been land applied.~~

2267  
2268  
2269  
2270  
2271  
2272  
2273  
2274  
2275  
2276  
2277  
2278  
2279  
2280  
2281  
2282  
2283  
2284  
2285  
2286  
2287  
2288  
2289  
2290  
2291  
2292  
2293  
2294  
2295  
2296  
2297  
2298  
2299  
2300  
2301  
2302  
2303  
2304  
2305  
2306  
2307  
2308  
2309  
2310  
2311  
2312  
2313  
2314  
2315

(iv) No turf shall be harvested from soils where domestic septage has been land applied for at least one(1) year following application. ~~from soils where domestic septage has been land applied.~~

(d) Reporting Requirements:

(i) The property owner shall notify the appropriate Department of Environmental Quality, Water Quality Division (DEQ/WQD) District Office Engineer prior to the land application of domestic septage to confirm the requirements and to arrange a possible DEQ/WQD inspection of the land application.

(ii) All records concerned with each septage application will be maintained for at least five (5) years.

(iii) There is a worksheet provided online at the Division's website that must be completed, signed and returned to the DEQ/WQD or the appropriate delegated local permitting authority within 15 days of the land application.

~~————— This worksheet must be completed, signed, and returned to the Department of Environmental Quality, Water Quality Division or the appropriate delegated local permitting authority within 15 days of the land application.~~

~~————— Provide the following information concerning your site. Enter NA if not applicable.~~

- ~~1. Date of the application: \_\_\_\_\_~~
- ~~2. Number of acres receiving septage: \_\_\_\_\_~~
- ~~3. Number of gallons of septage land applied: \_\_\_\_\_~~
- ~~4. Type of vegetation receiving: \_\_\_\_\_~~
- ~~5. Name, address and telephone number of septage hauler:~~

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

~~6. If septage was optionally alkali stabilized, please indicate what material was used for stabilization and how pH was measured: \_\_\_\_\_~~

\_\_\_\_\_  
\_\_\_\_\_

~~7) Please indicate that the site sketch on the back of this sheet has been completed and complies with the site restriction distances yes/no:~~

\_\_\_\_\_  
\_\_\_\_\_

~~8) Please indicate if photos of the land application site will be sent to the appropriate District Office: Yes/no. \_\_\_\_\_~~

~~9) Please provide physical address or legal description of land application site: \_\_\_\_\_~~

\_\_\_\_\_  
\_\_\_\_\_

~~10) Please give the name of the DEQ/WQD representative contacted, and time and date. This contact needs to be made prior to the domestic septage land application: \_\_\_\_\_~~

2316  
2317  
2318  
2319  
2320  
2321  
2322  
2323  
2324  
2325

STRIKE  
SKETCH

2326  
2327  
2328  
2329  
2330  
2331  
2332  
2333  
2334  
2335  
2336  
2337  
2338  
2339  
2340  
2341  
2342  
2343

REQUIRED ISOLATION  
DISTANCE FROM LAND  
APPLICATION SITE

- ) 1,000 feet from adjacent property
- ) 1,000 feet from any dwelling
- ) 300 feet from any live water, into stream or drainage

~~I certify that the information provided in this worksheet is accurate and meets the requirements set forth~~  
here

~~Signature of landowner \_\_\_\_\_ Date~~

\_\_\_\_\_  
Name (printed)

2344  
2345  
2346  
2347  
2348  
2349  
2350  
2351  
2352  
2353  
2354  
2355  
2356  
2357  
2358  
2359

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
*signature of applicator* \_\_\_\_\_ *Date*  
*Name (printed)*