

BEFORE THE ENVIRONMENTAL QUALITY COUNCIL
STATE OF WYOMING

In the Matter of the Appeal)
And Petition for Review of:)
BART Permit No. MD-6040)
(Jim Bridger Power Plant); and) Docket No. 10-2801
BART Permit No. MD-6042)
(Naughton Power Plant).)

**RESPONSE TO PACIFICORP'S MOTION FOR PARTIAL SUMMARY
JUDGMENT**

PacifiCorp's BART App. Addendums for JB Units 1-4, 3/08

EXHIBIT 6

Addendum to Jim Bridger Unit 1 BART Report

PREPARED FOR: Wyoming Division of Air Quality
PREPARED BY: CH2M HILL
COPIES: Bill Lawson/PacifiCorp
DATE: March 26, 2008



Introduction

In compliance with the Regional Haze Rule (40 Code of Federal Regulations [CFR] 51), the Wyoming Division of Air Quality (WDAQ) required PacifiCorp Energy to conduct a detailed Best Available Retrofit Technology (BART) review to analyze the effects to visibility in nearby Class I areas from plant emissions, both for baseline and for reasonable control technology scenarios. PacifiCorp submitted these evaluations to WDAQ in January 2007. A revised report was submitted in October 2007.

On January 3, 2008, PacifiCorp Energy personnel met with WDAQ staff to discuss the status of the BART reviews. At that time, the state requested that additional modeling scenarios for several of the PacifiCorp facilities be performed to aid in their BART review. This memorandum presents the economics analysis for two scenarios modeled, referred to as Scenario A and Scenario B and described as follows:

- Scenario A: PacifiCorp committed controls at permitted rates—low nitrogen oxide (NO_x) burners (LNBS) with over-fire air (OFA), sodium based flue gas desulfurization (FGD), ESP with SO₂ injection
- Scenario B: PacifiCorp committed controls and selective catalytic reduction (SCR) at permitted rates

The CALPUFF modeling system (v. 5.711a) was used for this analysis. All technical options and model triggers used in CALMET, CALPUFF, and CALPOST are consistent with those used for the previous BART analyses and described in the BART report submitted in October 2007.

Stack Parameters, Emissions Information, and Capital Cost

Table 1 summarizes the control equipment for Scenarios A and B as well as the current equipment installed at the plant. The overall capital cost of installing these options is also shown.

TABLE 1
Control Scenario Summary
Jim Bridger Unit 1

	Equipment Type			Capital Cost
	NO _x	SO ₂	PM ₁₀	Million dollars
Baseline	LNB	Wet sodium FGD	ESP	—
Scenario A	LNB with OFA	Wet sodium FGD	ESP with SO ₃ injection	\$40.5
Scenario B	LNB with OFA and SCR	Wet sodium FGD	ESP with SO ₃ injection	\$207.0

Emissions were modeled for the following pollutants:

- Sulfur dioxide (SO₂)
- NO_x
- Coarse particulate (PM_{2.5}<diameter<PM₁₀)
- Fine particulate (diameter<PM_{2.5})
- Sulfates

Table 2 shows stack parameters and emission rates that were used for the Jim Bridger Unit 1 BART modeling and analysis.

TABLE 2
Calpuff Model Inputs
Jim Bridger Unit 1

Model Input Data	BART Comparison ^(d)		
	Baseline	Scenario A ^(e)	Scenario B ^(f)
Hourly Heat Input (mmBtu/hour)	6,000	6,000	6,000
Sulfur Dioxide (SO ₂) Stack Emissions (lb/hr)	1,602	900	900
Nitrogen Oxide (NO _x) Stack Emissions (lb/hr)	2,700	1,560	420
PM ₁₀ Stack Emissions (lb/hr)	270	180.0	180.0
Coarse Particulate (PM _{2.5} <diameter< PM ₁₀) Stack Emissions (lb/hr) ^(e)	116	77.4	77.4
Fine Particulate (diameter<PM _{2.5}) Stack Emissions (lb/hr) ^(b)	154	102.6	102.6
Sulfuric Acid (H ₂ SO ₄) Stack Emissions (lb/hr)	55.2	55.2	94.7
Ammonium Sulfate [(NH ₄) ₂ SO ₄] Stack Emissions (lb/hr)	—	—	7.0
(NH ₄)HSO ₄ Stack Emissions (lb/hr)	—	—	12.2
H ₂ SO ₄ as Sulfate (SO ₄) Stack Emissions (lb/hr)	54.1	54.1	92.8
(NH ₄) ₂ SO ₄ as SO ₄ Stack Emissions (lb/hr)	—	—	5.1
(NH ₄)HSO ₄ as SO ₄ Stack Emissions (lb/hr)	—	—	10.2

TABLE 2
Calpuff Model Inputs
Jim Bridger Unit 1

Model Input Data	BART Comparison ^(d)		
	Baseline	Scenario A ^(e)	Scenario B ^(f)
Total Sulfate (SO ₄) (lb/hr) ^(c)	54.1	54.1	108.1
Stack Conditions			
Stack Height (meters)	152	152	152
Stack Exit Diameter (meters)	7.32	7.32	7.32
Stack Exit Temperature (Kelvin)	333	328	328
Stack Exit Velocity (meters per second)	25.6	24.7	24.7

NOTES:

^(a) Based on AP-42, Table 1.1-6, the coarse particulates are counted as a percentage of PM₁₀. This equates to 43% ESP and 57% Baghouse. PM₁₀ and PM_{2.5} refer to particulate matter less than 10 and 2.5 micrometers, respectively, in aerodynamic diameter.

^(b) Based on AP-42, Table 1.1-6, the fine particulates are counted as a percentage of PM₁₀. This equates to 57% ESP and 43% Baghouse.

^(c) Total Sulfate (SO₄) (lb/hr) = H₂SO₄ as Sulfate (SO₄) Stack Emissions (lb/hr) + (NH₄)₂SO₄ as SO₄ Stack Emissions (lb/hr) + (NH₄)HSO₄ as SO₄ Stack Emissions (lb/hr)

^(d) SO₂, NO_x, and PM rates are expressed in terms of permitted emission rates. Actual emissions will be less than the permitted rates.

^(e) PacifiCorp Committed Controls @ permitted rates: LNB with OFA, Wet FGD, ESP with SO₃

^(f) PacifiCorp Committed Controls and SCR @ permitted rates

Economic Analysis

In completing this additional analysis to supplement the previous BART study, technology alternatives were investigated and potential reductions in NO_x, SO₂, and PM₁₀ emissions rates were identified.

A comparison of Scenarios A and B on the basis of costs, design control efficiencies, and tons of pollutant removed is summarized in Tables 3 through 5. Capital costs were provided by PacifiCorp. The complete economic analyses for these two scenarios are provided as Attachment 1.

TABLE 3
Scenario A Control Cost
Jim Bridger Unit 1

	NO _x Control		SO ₂ Control		PM ₁₀ Control		Scenario A	
	LNB with OFA	Wet FGD	ESP with Gas Conditioning	Control Cost	Control Cost	Control Cost	Control Cost	
Total Installed Capital Costs (million dollars)	\$11.3	\$25.3	\$3.9	\$40.50				
Annualized First-Year Capital Costs	\$1.07	\$2.41	\$0.37	\$3.85				
First Year Fixed & Variable O&M Costs (million dollars)	\$0.07	\$0.98	\$0.18	\$1.21				
Total First Year Annualized Costs (million dollars) ^(a)	\$1.15	\$3.39	\$0.55	\$5.08				
Power Consumption (MW)	—	0.53	0.05	0.58				
Annual Power Usage (Million kWh/Yr)	—	4.18	0.39	4.57				
Permitted Emission Rate (lb/mmBtu)	0.26	0.15	0.03	—				
Additional Tons of Pollutant Removed per Year over Baseline	4,494	2,838	355	7,687				
First Year Average Control Cost (\$/Ton of Pollutant Removed)	255	1,194	1,541	661				

NOTE:
^(a) First year annualized costs include power consumption costs.

TABLE 4
Scenario B Control Cost
Jim Bridger Unit 1

	NO _x Control		SO ₂ Control		PM ₁₀ Control		Scenario B	
	LNB with OFA & SCR	Wet FGD	Wet FGD	ESP with Gas Conditioning	Control Cost	Control Cost	Control Cost	Control Cost
Total Installed Capital Costs (million dollars)	\$177.8	\$25.3	\$25.3	\$3.9	\$207.0	\$207.0	\$207.0	\$207.0
Annualized First-Year Capital Costs	\$16.91	\$2.41	\$2.41	\$0.37	\$19.69	\$19.69	\$19.69	\$19.69
First Year Fixed & Variable O&M Costs (million dollars)	\$3.38	\$0.98	\$0.98	\$0.18	\$4.54	\$4.54	\$4.54	\$4.54
Total First Year Annualized Costs (million dollars) ^(a)	\$20.30	\$3.39	\$3.39	\$0.55	\$24.23	\$24.23	\$24.23	\$24.23
Power Consumption (MW)	3.28	0.53	0.53	0.05	3.86	3.86	3.86	3.86
Annual Power Usage (Million kWh/Yr)	25.86	4.18	4.18	0.39	30.46	30.46	30.46	30.46
Permitted Emission Rate (lb/mmBtu)	0.07	0.15	0.15	0.03	—	—	—	—
Additional Tons of Pollutant Removed per Year over Baseline	8,988	2,838	2,838	355	12,181	12,181	12,181	12,181
First Year Average Control Cost (\$/Ton of Pollutant Removed)	2,258	1,194	1,194	1,541	1,989	1,989	1,989	1,989

NOTE:
^(a) First year annualized costs include power consumption costs.

TABLE 5
Incremental Control Costs, Scenario B compared to Scenario A
Jim Bridger Unit 1

	NO _x Control	SO ₂ Control	PM ₁₀ Control	Total Control Cost
Incremental Installed Capital Costs (million dollars)	\$166.5	0	0	\$166.5
Incremental Annualized First-Year Capital Costs	\$15.84	0	0	\$15.84
Incremental First Year Fixed & Variable O&M Costs (million dollars)	\$3.31	0	0	\$3.31
Incremental First Year Annualized Costs (million dollars) ^(e)	\$19.15	0	0	\$19.15
Incremental Power Consumption (MW)	3.28	0	0	3.28
Incremental Annual Power Usage (Million kWh/Yr)	25.86	0	0	25.86
Incremental Improvement in Emission Rate (lb/mmBtu)	0.19	0	0	—
Incremental Tons of Pollutant Removed	4,494	0	0	4,494
Incremental First Year Average Control Cost (\$/Ton of Pollutant Removed)	4,262	0	0	4,262

NOTE:

^(e)Incremental first year annualized costs include power consumption costs.

Modeling Results and Least-Cost Envelope Analysis

CH2M HILL modeled Jim Bridger Unit 1 for two post-control scenarios. The results determine the change in deciview based on each alternative at the Class I areas specific to the project. The Class I areas potentially affected are Bridger Wilderness, Fitzpatrick Wilderness, and Mount Zirkel Wilderness for this unit.

Modeled Scenarios

Current operations (baseline) and two alternative control scenarios were modeled to cover the range of effectiveness for the combination of the individual NO_x, SO₂, and PM control technologies being evaluated. The modeled scenarios include the following:

- Baseline: Current operations with LNB, Wet sodium FGD, and ESP
- Scenario A: LNB with OFA, Wet sodium FGD, and ESP with SO₃ injection
- Scenario B: Scenario A with SCR

Summary of Visibility Analysis

Tables 6 through 8 present a summary of the modeling period (2001–2003) results for each scenario and Class I area.

TABLE 6
Costs and Visibility Modeling Results as Applicable to Bridger Wilderness
Jim Bridger Unit 1

Scenario	Controls	Total First Year Annualized Cost	Highest ΔdV	98 th Percentile ΔdV	Maximum Annual Number of Days Above 0.5 dV
Baseline	Current Operations with FGD and ESP	—	4.381	1.277	30
Scenario A	Scenario A: PacifiCorp Committed Controls	\$5,081,645	2.919	0.829	17
Scenario B	Scenario B: PacifiCorp Committed Controls and SCR	\$24,232,712	1.647	0.481	10

TABLE 7
Costs and Visibility Modeling Results as Applicable to Fitzpatrick Wilderness
Jim Bridger Unit 1

Scenario	Controls	Total First Year Annualized Cost	Highest AdV	98 th Percentile AdV	Maximum Annual Number of Days Above 0.5 dV
Baseline	Current Operations with FGD and ESP	—	2.538	0.637	13
Scenario A	Scenario A: PacifiCorp Committed Controls	\$5,081,645	1.747	0.379	7
Scenario B	Scenario B: PacifiCorp Committed Controls and SCR	\$24,232,712	0.959	0.232	4

TABLE 8
Costs and Visibility Modeling Results as Applicable to Mount Zirkel Wilderness
Jim Bridger Unit 1

Scenario	Controls	Total First Year Annualized Cost	Highest AdV	98 th Percentile AdV	Maximum Annual Number of Days Above 0.5 dV
Baseline	Current Operations with FGD and ESP	—	3.458	1.651	48
Scenario A	Scenario A: PacifiCorp Committed Controls	\$5,081,645	2.168	1.046	22
Scenario B	Scenario B: PacifiCorp Committed Controls and SCR	\$24,232,712	1.298	0.607	12

Results

Tables 9 through 11 present a summary of the costs and modeling results for each scenario and Class I area.

TABLE 9
Incremental Costs and Incremental Visibility Improvements Relative to Bridger Wilderness
Jim Bridger Unit 1

Scenario Comparison	Controls	Incremental Annualized Cost (Million\$)	Reduction in 98 th Percentile maximum dV	Reduction in Number of Days Above 0.5 dV	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Day to Achieve a Reduction in the Days above 0.5 dV (Million\$/Day)
Scenario A Compared to Baseline	Scenario A: PacifiCorp Committed Controls	\$5.08	0.448	13	\$11.34	\$0.39
Scenario B Compared to Baseline	Scenario B: PacifiCorp Committed Controls and SCR	\$24.23	0.796	20	\$30.44	\$1.21
Scenario B Compared To Scenario A	Addition of SCR	\$19.15	0.348	7	\$55.03	\$2.74

TABLE 10
Incremental Costs and Incremental Visibility Improvements Relative to Fitzpatrick Wilderness
Jim Bridger Unit 1

Scenario Comparison	Controls	Incremental Annualized Cost (Million\$)	Reduction in 98 th Percentile maximum dV	Reduction in Number of Days Above 0.5 dV	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Day to Achieve a Reduction in the Days above 0.5 dV (Million\$/Day)
Scenario A Compared to Baseline	Scenario A: PacifiCorp Committed Controls	\$5.08	0.258	6	\$19.70	\$0.85
Scenario B Compared to Baseline	Scenario B: PacifiCorp Committed Controls and SCR	\$24.23	0.405	9	\$59.83	\$2.69
Scenario B Compared To Scenario A	Addition of SCR	\$19.15	0.147	3	\$130.28	\$6.38

TABLE 11
 Incremental Costs and Incremental Visibility Improvements Relative to Mount Zirkel Wilderness
 Jim Bridger Unit 1

Scenario Comparison	Controls	Incremental Annualized Cost (Million\$)	Reduction in 98 th Percentile maximum dV	Reduction in Number of Days Above 0.5 dV	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Day to Achieve a Reduction in the Days above 0.5 dV (Million\$/Day)
Scenario A Compared to Baseline	Scenario A: PacifiCorp Committed Controls	\$5.08	0.605	26	\$8.40	\$0.20
Scenario B Compared to Baseline	Scenario B: PacifiCorp Committed Controls and SCR	\$24.23	1.044	36	\$23.21	\$0.67
Scenario B Compared To Scenario A	Addition of SCR	\$19.15	0.439	10	\$43.62	\$1.92

Least-Cost Envelope Analysis

The least-cost envelope graphs for Bridger Wilderness are shown in Figures 1 and 2, for Fitzpatrick Wilderness in Figures 3 and 4, and for Mount Zirkel Wilderness in Figures 5 and 6.

FIGURE 1




FIGURE 2




FIGURE 3




FIGURE 4




FIGURE 5





FIGURE 6



ATTACHMENT 1

**Complete Economic Analyses
for Scenarios A and B**

ECONOMIC ANALYSIS SUMMARY - FIRST YEAR COSTS

Jim Bridger 1

Boiler Design: Opposed Wall-Fired PC


Technology Label	TYPE OF EMISSIONS CONTROLS				NO _x Control				SO ₂ Control and PM				Scenario A	Scenario B
	BASE	A	B	C	D	E	F	G	A-F	D-F				
ECONOMIC FACTORS														
Interest Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%
Discount Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%
Plant Economic Life (Years)	20	20	20	20	20	20	20	20	20	20	20	20	20	20
CAPITAL INVESTMENT														
Total Installed Capital Costs (\$)	\$0	\$11,300,000	\$20,528,122	\$22,127,239	\$177,800,000	\$3,900,000	\$48,398,533	\$25,300,000	\$40,500,000	\$207,000,000				
FIRST YEAR DEBIT SERVICE (\$/Y)	\$0	\$1,074,944	\$1,952,796	\$2,104,916	\$16,913,727	\$370,999	\$4,602,887	\$2,406,734	\$3,852,677	\$18,691,459				
FIRST YEAR FIXED O&M COSTS (\$/Y)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0				
Operating Labor (\$/Y)	\$0	\$28,000	\$42,000	\$42,000	\$123,000	\$190,000	\$51,059	\$25,500	\$55,500	\$215,500				
Maintenance Material (\$/Y)	\$0	\$42,000	\$63,000	\$63,000	\$194,500	\$285,000	\$76,649	\$17,033	\$59,033	\$312,033				
Administrative Labor (\$/Y)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0				
Administrative Fixed Cost (\$/Y)	\$0	\$70,000	\$105,000	\$307,500	\$475,000	\$10,000	\$127,748	\$42,533	\$122,533	\$527,533				
TOTAL FIRST YEAR VARIABLE O&M COST	\$0	\$70,000	\$105,000	\$307,500	\$475,000	\$10,000	\$127,748	\$42,533	\$122,533	\$527,533				
FIRST YEAR VARIABLE O&M COSTS (\$/Y)	\$0	\$70,000	\$105,000	\$307,500	\$475,000	\$10,000	\$127,748	\$42,533	\$122,533	\$527,533				
Makeup Water Costs (\$/Y)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0				
Reagent Costs (\$/Y)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0				
SCR Catalyst/FF Bag Costs (\$/Y)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0				
Waste Disposal Costs (\$/Y)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0				
Electric Power Costs (\$/Y)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0				
TOTAL FIRST YEAR VARIABLE O&M COSTS (\$/Y)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0				
SUMMARY OF FIRST YEAR COSTS (\$/Y)														
First Year Debt Service (\$/Y)	\$0	\$1,074,944	\$1,952,796	\$2,104,916	\$16,913,727	\$370,999	\$4,602,887	\$2,406,734	\$3,852,677	\$18,691,459				
First Year Fixed O&M Costs (\$/Y)	\$0	\$70,000	\$105,000	\$307,500	\$475,000	\$10,000	\$127,748	\$42,533	\$122,533	\$527,533				
First Year Variable O&M Costs (\$/Y)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0				
Total First Year Costs (\$/Y)	\$0	\$1,144,944	\$2,057,796	\$2,412,416	\$17,388,727	\$380,999	\$4,730,635	\$2,449,268	\$3,975,210	\$19,218,952				
CONTROL COST COMPARISONS														
NO_x Technology Comparison														
Additional NO _x Removed From Base Case (Tons/Yr)	0	4,494	5,440	5,440	8,988									
First Year Average Control Cost (\$/Ton NO _x Removed)	\$0	\$255	\$843	\$488	\$2,258									
Technology Case Comparison														
Incremental NO _x Removed (Tons/Yr)	0	A-BASE	E-A	C-A	D-A									
Incremental Control Cost (\$/Ton NO _x Removed)	\$0	4,494	946	946	4,494									
SO₂ Technology Comparison														
Additional SO ₂ Removed From Base Case (Tons/Yr)	0	77.5%	77.5%	77.5%	77.5%	77.5%	77.5%	77.5%	77.5%	77.5%				
First Year Average Control Cost (\$/Ton SO ₂ Removed)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0				
Technology Case Comparison														
Incremental SO ₂ Removed (Tons/Yr)	0	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%				
Incremental Control Cost (\$/Ton SO ₂ Removed)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0				
PM Technology Comparison														
Additional PM Removed From Base Case (Tons/Yr)	0	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%				
First Year Average Control Cost (\$/Ton PM Removed)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0				
Technology Case Comparison														
Incremental PM Removed (Tons/Yr)	0	0	0	0	0	0	0	0	0	0				
Incremental Control Cost (\$/Ton PM Removed)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0				
SCENARIO A AND B COMPARISONS														
Additional NO _x , SO ₂ , & PM Removed From Base Case (Tons/Yr)	0	0	0	0	0	0	0	0	0	0				
First Year Average Control Cost Compared to Base Case (\$/Ton Removed)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0				
Incremental Costs - Scenario B vs Scenario A (Tons/Yr)	0	0	0	0	0	0	0	0	0	0				
Incremental Control Costs - Scenario B vs Scenario A (\$/Ton Removed)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0				

MS-ES20080202-CR17-15-ScenarioA181-Report.xls

INPUT CALCULATIONS		Opposed Wall-Fired PC													
PARAMETER	Current Operation	NO _x Control Technologies				SO ₂ and PM Control Technologies				Scenario A	Scenario B				
		Wd/FGD ESP	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	N/A ESP w/ Gas Conditioning	N/A Fabric Filter	Upgrade Wd/FGD ESP	LNB w/OFA Upgrade Wd/FGD ESP w/ Gas Conditioning	LNB w/OFA & SCR Upgrade Wd/FGD ESP w/ Gas Conditioning				
Control Technologies	LNCRS-1 & Window Mod.														
NO _x Emission Control System															
SO ₂ Emission Control System															
PM Emission Control System															
General Plant Design and Operating Data															
Type of Unit	PC	PC	PC	PC	PC	PC	PC	PC	PC	PC	PC	PC	PC	PC	PC
Annual Power Plant Capacity (Fwd)	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%
Annual Operation (Hours/Year)	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884
Net Power Output (MW)	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000
Net Plant Heat Rate (Btu/kWh)	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320
Boiler Heat Input, Measured by Fuel Input (MMBtu/Year)	47,200,846	47,200,846	47,200,846	47,200,846	47,200,846	47,200,846	47,200,846	47,200,846	47,200,846	47,200,846	47,200,846	47,200,846	47,200,846	47,200,846	47,200,846
Boiler Heat Input, Measured by CEI (MMBtu/Year)	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000
Boiler Heat Input, Measured by CEI (MMBtu/Year)	47,206,846	47,206,846	47,206,846	47,206,846	47,206,846	47,206,846	47,206,846	47,206,846	47,206,846	47,206,846	47,206,846	47,206,846	47,206,846	47,206,846	47,206,846
Plant Fuel Source															
Boiler Fuel Source	Bidger Mine Underground	Bidger Mine Underground	Bidger Mine Underground	Bidger Mine Underground	Bidger Mine Underground	Bidger Mine Underground	Bidger Mine Underground	Bidger Mine Underground	Bidger Mine Underground	Bidger Mine Underground	Bidger Mine Underground	Bidger Mine Underground	Bidger Mine Underground	Bidger Mine Underground	Bidger Mine Underground
Coal Heating Value (Btu/lb)	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660
Coal Sulfur Content (wt.%)	0.59%	0.59%	0.59%	0.59%	0.59%	0.59%	0.59%	0.59%	0.59%	0.59%	0.59%	0.59%	0.59%	0.59%	0.59%
Coal Ash Content (wt.%)	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%
Coal Flow Rate (Lb/hr)	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077
Coal Consumed (Tons/Year)	2,448,294	2,448,294	2,448,294	2,448,294	2,448,294	2,448,294	2,448,294	2,448,294	2,448,294	2,448,294	2,448,294	2,448,294	2,448,294	2,448,294	2,448,294
Nitrogen Oxide Emissions															
NO _x Emission Rate (Lb/MMBtu)	0.45	0.26	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22
NO _x Emission Rate (Lb/hr)	2,700	1,580	1,320	1,320	1,320	1,320	1,320	1,320	1,320	1,320	1,320	1,320	1,320	1,320	1,320
NO _x Emission Rate (Lb/MWd)	89.97	51.98	43.98	43.98	43.98	43.98	43.98	43.98	43.98	43.98	43.98	43.98	43.98	43.98	43.98
NO _x Emission Rate (Tons/Year)	10,645	6,150	5,203	5,203	5,203	5,203	5,203	5,203	5,203	5,203	5,203	5,203	5,203	5,203	5,203
NO _x Emission Rate (Tons/Day)	297	168	142	142	142	142	142	142	142	142	142	142	142	142	142
NO _x Emission Rate (Tons/Year)	0	1,140	1,380	1,380	1,380	1,380	1,380	1,380	1,380	1,380	1,380	1,380	1,380	1,380	1,380
NO _x Emission Rate (Tons/Day)	0	4.84	5.44	5.44	5.44	5.44	5.44	5.44	5.44	5.44	5.44	5.44	5.44	5.44	5.44
Sulfur Dioxide Emissions															
Uncontrolled SO ₂ (Lb/MMBtu)	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20
Uncontrolled SO ₂ (Lb/hr)	7,188	7,188	7,188	7,188	7,188	7,188	7,188	7,188	7,188	7,188	7,188	7,188	7,188	7,188	7,188
Uncontrolled SO ₂ (Lb/MWd)	112.35	112.35	112.35	112.35	112.35	112.35	112.35	112.35	112.35	112.35	112.35	112.35	112.35	112.35	112.35
Uncontrolled SO ₂ (Tons/Year)	28,374	28,374	28,374	28,374	28,374	28,374	28,374	28,374	28,374	28,374	28,374	28,374	28,374	28,374	28,374
Controlled SO ₂ Emission Rate (Lb/MMBtu)	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27
SO ₂ Removal Efficiency (%)	77.5%	77.5%	77.5%	77.5%	77.5%	77.5%	77.5%	77.5%	77.5%	77.5%	77.5%	77.5%	77.5%	77.5%	77.5%
Controlled SO ₂ Emissions (Lb/hr)	1,620	1,620	1,620	1,620	1,620	1,620	1,620	1,620	1,620	1,620	1,620	1,620	1,620	1,620	1,620
Controlled SO ₂ Emissions (Tons/Year)	6,385	6,385	6,385	6,385	6,385	6,385	6,385	6,385	6,385	6,385	6,385	6,385	6,385	6,385	6,385
SO ₂ Removal (Tons/Year)	5,578	5,578	5,578	5,578	5,578	5,578	5,578	5,578	5,578	5,578	5,578	5,578	5,578	5,578	5,578
SO ₂ Removal (Tons/Day)	21,985	21,985	21,985	21,985	21,985	21,985	21,985	21,985	21,985	21,985	21,985	21,985	21,985	21,985	21,985
SO ₂ Removal (Tons/Year)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SO ₂ Removal (Tons/Day)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Particulate Matter Emissions															
Uncontrolled Fly Ash (Lb/hr)	51,177	51,177	51,177	51,177	51,177	51,177	51,177	51,177	51,177	51,177	51,177	51,177	51,177	51,177	51,177
Uncontrolled Fly Ash (Lb/MMBtu)	8.528	8.528	8.528	8.528	8.528	8.528	8.528	8.528	8.528	8.528	8.528	8.528	8.528	8.528	8.528
Uncontrolled Fly Ash (Tons/Year)	201,735	201,735	201,735	201,735	201,735	201,735	201,735	201,735	201,735	201,735	201,735	201,735	201,735	201,735	201,735
Controlled Fly Ash Emission Rate (Lb/MMBtu)	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045
Controlled Fly Ash Emission Rate (Lb/hr)	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220
Controlled Fly Ash Emission Rate (Tons/Year)	1,580	1,580	1,580	1,580	1,580	1,580	1,580	1,580	1,580	1,580	1,580	1,580	1,580	1,580	1,580
Controlled Fly Ash Emission Rate (Tons/Day)	50,987	50,987	50,987	50,987	50,987	50,987	50,987	50,987	50,987	50,987	50,987	50,987	50,987	50,987	50,987
SO ₂ Removal (Tons/Year)	200,674	200,674	200,674	200,674	200,674	200,674	200,674	200,674	200,674	200,674	200,674	200,674	200,674	200,674	200,674
SO ₂ Removal (Tons/Day)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SO ₂ Removal (Tons/Year)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SO ₂ Removal (Tons/Day)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Economic Factors															
Interest Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%
Discount Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%
Plant Economic Life (Years)	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20

Addendum to Jim Bridger Unit 2 BART Report

PREPARED FOR: Wyoming Division of Air Quality
PREPARED BY: CH2M HILL
COPIES: Bill Lawson/PacifiCorp
DATE: March 26, 2008



Introduction

In compliance with the Regional Haze Rule (40 Code of Federal Regulations [CFR] 51), the Wyoming Division of Air Quality (WDAQ) required PacifiCorp Energy to conduct a detailed Best Available Retrofit Technology (BART) review to analyze the effects to visibility in nearby Class I areas from plant emissions, both for baseline and for reasonable control technology scenarios. PacifiCorp submitted these evaluations to WDAQ in January 2007. A revised report was submitted in October 2007.

On January 3, 2008, PacifiCorp Energy personnel met with WDAQ staff to discuss the status of the BART reviews. At that time, the state requested that additional modeling scenarios for several of the PacifiCorp facilities be performed to aid in their BART review. This memorandum presents the economics analysis for two scenarios modeled, referred to as Scenario A and Scenario B and described as follows:

- Scenario A: PacifiCorp committed controls at permitted rates—low nitrogen oxide (NO_x) burners (LNBS) with over-fire air (OFA), sodium based flue gas desulfurization (FGD), SO₃ injection
- Scenario B: PacifiCorp committed controls and selective catalytic reduction (SCR) at permitted rates

The CALPUFF modeling system (v. 5.711a) was used for this analysis. All technical options and model triggers used in CALMET, CALPUFF, and CALPOST are consistent with those used for the previous BART analyses and described in the BART report submitted in October 2007.

Stack Parameters, Emissions Information, and Capital Cost

Table 1 summarizes the control equipment for Scenarios A and B as well as the current equipment installed at the plant. The overall capital cost of installing these options is also shown.

TABLE 1
Control Scenario Summary
Jim Bridger Unit 2

	Equipment Type			Capital Cost
	NO _x	SO ₂	PM ₁₀	Million dollars
Baseline	LNB with OFA	Wet sodium FGD	ESP	—
Scenario A	LNB with OFA	Wet sodium FGD	ESP with SO ₃ injection	\$29.2
Scenario B	LNB with OFA and SCR	Wet sodium FGD	ESP with SO ₃ injection	\$195.7

Emissions were modeled for the following pollutants:

- Sulfur dioxide (SO₂)
- NO_x
- Coarse particulate (PM_{2.5}<diameter<PM₁₀)
- Fine particulate (diameter<PM_{2.5})
- Sulfates

Table 2 shows stack parameters and emission rates that were used for the Jim Bridger Unit 2 BART modeling and analysis.

TABLE 2
Calpuff Model Inputs
Jim Bridger Unit 2

Model Input Data	BART Comparison ^(d)		
	Baseline	Scenario A ^(e)	Scenario B ^(f)
Hourly Heat Input (mmBtu/hour)	6,000	6,000	6,000
Sulfur Dioxide (SO ₂) Stack Emissions (lb/hr)	1,602	900	900
Nitrogen Oxide (NO _x) Stack Emissions (lb/hr)	1,440	1,560	420
PM ₁₀ Stack Emissions (lb/hr)	444	180.0	180.0
Coarse Particulate (PM _{2.5} <diameter<PM ₁₀) Stack Emissions (lb/hr) ^(a)	191	77.4	77.4
Fine Particulate (diameter<PM _{2.5}) Stack Emissions (lb/hr) ^(b)	253	102.6	102.6
Sulfuric Acid (H ₂ SO ₄) Stack Emissions (lb/hr)	55.2	55.2	94.7
Ammonium Sulfate [(NH ₄) ₂ SO ₄] Stack Emissions (lb/hr)	—	—	7.0
(NH ₄)HSO ₄ Stack Emissions (lb/hr)	—	—	12.2
H ₂ SO ₄ as Sulfate (SO ₄) Stack Emissions (lb/hr)	54.1	54.1	92.8
(NH ₄) ₂ SO ₄ as SO ₄ Stack Emissions (lb/hr)	—	—	5.1
(NH ₄)HSO ₄ as SO ₄ Stack Emissions (lb/hr)	—	—	10.2

TABLE 2
Calpuff Model Inputs
Jim Bridger Unit 2

Model Input Data	BART Comparison ^(d)		
	Baseline	Scenario A ^(e)	Scenario B ^(f)
Total Sulfate (SO ₄) (lb/hr) ^(c)	54.1	54.1	108.1
Stack Conditions			
Stack Height (meters)	152	152	152
Stack Exit Diameter (meters)	7.32	7.32	7.32
Stack Exit Temperature (Kelvin)	333	328	328
Stack Exit Velocity (meters per second)	27.4	24.7	24.7

NOTES:

^(a) Based on AP-42, Table 1.1-6, the coarse particulates are counted as a percentage of PM₁₀. This equates to 43% ESP and 57% Baghouse. PM₁₀ and PM_{2.5} refer to particulate matter less than 10 and 2.5 micrometers, respectively, in aerodynamic diameter.

^(b) Based on AP-42, Table 1.1-6, the fine particulates are counted as a percentage of PM₁₀. This equates to 57% ESP and 43% Baghouse.

^(c) Total Sulfate (SO₄) (lb/hr) = H₂SO₄ as Sulfate (SO₄) Stack Emissions (lb/hr) + (NH₄)₂SO₄ as SO₄ Stack Emissions (lb/hr) + (NH₄)HSO₄ as SO₄ Stack Emissions (lb/hr)

^(d) SO₂, NO_x, and PM rates are expressed in terms of permitted emission rates. Actual emissions will be less than the permitted rates.

^(e) PacifiCorp Committed Controls @ permitted rates: LNB with OFA, Wet FGD, ESP with SO₃

^(f) PacifiCorp Committed Controls and SCR @ permitted rates

Economic Analysis

In completing this additional analysis to supplement the previous BART study, technology alternatives were investigated and potential reductions in NO_x, SO₂, and PM₁₀ emissions rates were identified.

A comparison of Scenarios A and B on the basis of costs, design control efficiencies, and tons of pollutant removed is summarized in Tables 3 through 5. Capital costs were provided by PacifiCorp. The complete economic analyses for these two scenarios are provided as Attachment 1.

TABLE 3
Scenario A Control Cost
Jim Bridger Unit 2

	NO _x Control Existing LNB with OFA	SO ₂ Control		PM ₁₀ Control ESP with Gas Conditioning	Scenario A Control Cost
		Wet FGD			
Total Installed Capital Costs (million dollars)	—	\$25.3		\$3.90	\$29.20
Annualized First-Year Capital Costs	—	\$2.41		\$0.37	\$2.78
First Year Fixed & Variable O&M Costs (million dollars)	—	\$0.98		\$0.18	\$1.16
Total First Year Annualized Costs (million dollars) ^(a)	—	\$3.39		\$0.55	\$3.94
Power Consumption (MW)	—	0.53		0.05	0.58
Annual Power Usage (Million kWh/Yr)	—	4.18		0.39	4.57
Permitted Emission Rate (lb/mmBtu)	0.26	0.15		0.03	—
Additional Tons of Pollutant Removed per Year over Baseline	—	2,838		1,041	3,879
First Year Average Control Cost (\$/Ton of Pollutant Removed)	—	1,194		525	1,015

NOTE:

^(a) First year annualized costs include power consumption costs.

TABLE 4
Scenario B Control Cost
Jim Bridger Unit 2

	NO _x Control		SO ₂ Control		PM ₁₀ Control		Scenario B	
	LNB with OFA & SCR		Wet FGD		ESP with Gas Conditioning		Control Cost	
Total Installed Capital Costs (million dollars)	\$166.5	\$25.3	\$2.41	\$3.90	\$195.70			
Annualized First-Year Capital Costs	\$15.84	\$2.41	\$0.37	\$0.37	\$18.62			
First Year Fixed & Variable O&M Costs (million dollars)	\$3.37	\$0.98	\$0.18	\$0.18	\$4.53			
Total First Year Annualized Costs (million dollars) ^(a)	\$19.21	\$3.39	\$0.55	\$0.55	\$23.15			
Power Consumption (MW)	3.25	0.53	0.05	0.05	3.83			
Annual Power Usage (Million kWh/Yr)	25.65	4.18	0.39	0.39	30.22			
Permitted Emission Rate (lb/mmBtu)	0.07	0.15	0.03	0.03	—			
Additional Tons of Pollutant Removed per Year over Baseline	4,494	2,838	1,041	1,041	8,373			
First Year Average Control Cost (\$/Ton of Pollutant Removed)	4.275	1.194	525	525	2.764			

NOTE:

^(a) First year annualized costs include power consumption costs.

TABLE 5
Incremental Control Costs, Scenario B compared to Scenario A
Jim Bridger Unit 2

	NO _x Control	SO ₂ Control	PM ₁₀ Control	Total Control Cost
Incremental Installed Capital Costs (million dollars)	\$166.5	0	0	\$166.5
Incremental Annualized First-Year Capital Costs	\$15.84	0	0	\$15.84
Incremental First Year Fixed & Variable O&M Costs (million dollars)	\$3.37	0	0	\$3.37
Incremental First Year Annualized Costs (million dollars) ^(a)	\$19.21	0	0	\$19.21
Incremental Power Consumption (MW)	3.25	0	0	3.25
Incremental Annual Power Usage (Million kWh/Yr)	25.62	0	0	25.62
Incremental Improvement in Emission Rate (lb/mmBtu)	0.19	0	0	—
Incremental Tons of Pollutant Removed	4,494	0	0	4,494
Incremental First Year Average Control Cost (\$/Ton of Pollutant Removed)	4,275	0	0	4,275

NOTE:

^(a) Incremental first year annualized costs include power consumption costs.

Modeling Results and Least-Cost Envelope Analysis

CH2M HILL modeled Jim Bridger Unit 2 for two post-control scenarios. The results determine the change in deciview based on each alternative at the Class I areas specific to the project. The Class I areas potentially affected are Bridger Wilderness, Fitzpatrick Wilderness, and Mount Zirkel Wilderness for this unit.

Modeled Scenarios

Current operations (baseline) and two alternative control scenarios were modeled to cover the range of effectiveness for the combination of the individual NO_x, SO₂, and PM control technologies being evaluated. The modeled scenarios include the following:

- Baseline: Current operations with LNB, Wet sodium FGD, and ESP
- Scenario A: LNB with OFA, Wet sodium FGD, and ESP with SO₃ injection
- Scenario B: Scenario A with SCR

Summary of Visibility Analysis

Tables 6 through 8 present a summary of the modeling period (2001–2003) results for each scenario and Class I area.

TABLE 6
Costs and Visibility Modeling Results as Applicable to Bridger Wilderness
Jim Bridger Unit 2

Scenario	Controls	Total First Year Annualized Cost	Highest ΔdV	98 th Percentile ΔdV	Maximum Annual Number of Days Above 0.5 dV
Baseline	Current Operations with FGD and ESP	—	3.074	0.935	23
Scenario A	Scenario A: PacifiCorp Committed Controls	\$3,936,700	2.919	0.829	17
Scenario B	Scenario B: PacifiCorp Committed Controls and SCR	\$23,145,945	1.647	0.481	10

TABLE 7
Costs and Visibility Modeling Results as Applicable to Fitzpatrick Wilderness
Jim Bridger Unit 2

Scenario	Controls	Total First Year Annualized Cost	Highest ΔV	98 th Percentile ΔV	Maximum Annual Number of Days Above 0.5 dV
Baseline	Current Operations with FGD and ESP	—	1.666	0.434	9
Scenario A	Scenario A: PacifiCorp Committed Controls	\$3,936,700	1.747	0.379	7
Scenario B	Scenario B: PacifiCorp Committed Controls and SCR	\$23,145,945	0.959	0.232	4

TABLE 8
Costs and Visibility Modeling Results as Applicable to Mount Zirkel Wilderness
Jim Bridger Unit 2

Scenario	Controls	Total First Year Annualized Cost	Highest ΔV	98 th Percentile ΔV	Maximum Annual Number of Days Above 0.5 dV
Baseline	Current Operations with FGD and ESP	—	2.475	1.154	25
Scenario A	Scenario A: PacifiCorp Committed Controls	\$3,936,700	2.168	1.046	22
Scenario B	Scenario B: PacifiCorp Committed Controls and SCR	\$23,145,945	1.298	0.607	12

Results

Tables 9 through 11 present a summary of the costs and modeling results for each scenario and Class I area.

TABLE 9
 Incremental Costs and Incremental Visibility Improvements Relative to Bridger Wilderness
Jim Bridger Unit 2

Scenario Comparison	Controls	Incremental Annualized Cost (Million\$)	Reduction in 98 th Percentile maximum dV	Reduction in Number of Days Above 0.5 dV	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Day to Achieve a Reduction in the Days above 0.5 dV (Million\$/Day)
Scenario A Compared to Baseline	Scenario A: PacifiCorp Committed Controls	\$3.94	0.106	6	\$37.14	\$0.66
Scenario B Compared to Baseline	Scenario B: PacifiCorp Committed Controls and SCR	\$23.15	0.454	13	\$50.98	\$1.78
Scenario B Compared To Scenario A	Addition of SCR	\$19.21	0.348	7	\$55.20	\$2.74

TABLE 10
 Incremental Costs and Incremental Visibility Improvements Relative to Fitzpatrick Wilderness
Jim Bridger Unit 2

Scenario Comparison	Controls	Incremental Annualized Cost (Million\$)	Reduction in 98 th Percentile maximum dV	Reduction in Number of Days Above 0.5 dV	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Day to Achieve a Reduction in the Days above 0.5 dV (Million\$/Day)
Scenario A Compared to Baseline	Scenario A: PacifiCorp Committed Controls	\$3.94	0.055	2	\$71.58	\$1.97
Scenario B Compared to Baseline	Scenario B: PacifiCorp Committed Controls and SCR	\$23.15	0.202	5	\$114.58	\$4.63
Scenario B Compared To Scenario A	Addition of SCR	\$19.21	0.147	3	\$130.68	\$6.40

TABLE 11
 Incremental Costs and Incremental Visibility Improvements Relative to Mount Zirkel Wilderness
 Jim Bridger Unit 2

Scenario Comparison	Controls	Incremental Annualized Cost (Million\$)	Reduction in 98 th Percentile maximum dV	Reduction in Number of Days Above 0.5 dV	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Day to Achieve a Reduction in the Days above 0.5 dV (Million\$/Day)
Scenario A Compared to Baseline	Scenario A: PacifiCorp Committed Controls	\$3.94	0.108	3	\$36.45	\$1.31
Scenario B Compared to Baseline	Scenario B: PacifiCorp Committed Controls and SCR	\$23.15	0.547	13	\$42.31	\$1.78
Scenario B Compared To Scenario A	Addition of SCR	\$19.21	0.439	10	\$43.76	\$1.92

Least-Cost Envelope Analysis

The least-cost envelope graphs for Bridger Wilderness are shown in Figures 1 and 2, for Fitzpatrick Wilderness in Figures 3 and 4, and for Mount Zirkel Wilderness in Figures 5 and 6.

FIGURE 1




FIGURE 2




FIGURE 3




FIGURE 4




FIGURE 5

Least Cost Envelope
PacifiCorp Jim Bridger Unit 2 - Mount Zirkel Wilderness





FIGURE 6

Least Cost Envelope
PacifiCorp Jim Bridger Unit 2 - Mount Zirkel Wilderness



ATTACHMENT 1

**Complete Economic Analyses
for Scenarios A and B**

INPUT CALCULATIONS
 Jim Bridger 2

PARAMETER	Boiler Design: Tangential-Fired PC				SO ₂ and PM Control Technologies				Scenario A				Scenario B			
	Current Operation	NO _x Control Technologies	NO _x Control Technologies	NO _x Control Technologies	NO _x Control Technologies	NO _x Control Technologies	NO _x Control Technologies	NO _x Control Technologies	NO _x Control Technologies	NO _x Control Technologies	NO _x Control Technologies	NO _x Control Technologies	NO _x Control Technologies	NO _x Control Technologies	NO _x Control Technologies	
Control Technologies	LNB - TFS 2000 Wet FGD ESP	Existing LNB w/FOFA	ROFA	LNB w/FOFA & SNCR	LNB w/FOFA & SCR	N/A ESP w/ Gas Conditioning	N/A Fabric-Filler	Upgrade Wet FGD ESP	Existing LNB w/FOFA Upgrade Wet FGD ESP w/ Gas Conditioning	LNB w/FOFA Upgrade Wet FGD ESP w/ Gas Conditioning	Upgrade Wet FGD ESP w/ Gas Conditioning	LNB w/FOFA Upgrade Wet FGD ESP w/ Gas Conditioning	LNB w/FOFA Upgrade Wet FGD ESP w/ Gas Conditioning	LNB w/FOFA Upgrade Wet FGD ESP w/ Gas Conditioning	LNB w/FOFA Upgrade Wet FGD ESP w/ Gas Conditioning	
Installed Capital Costs		\$0	\$20,526,122	\$13,427,239	\$166,500,000	\$0	\$48,395,353	\$25,300,000	\$0	\$0	\$48,395,353	\$25,300,000	\$0	\$0	\$166,500,000	
NO _x Emission Control System (#2012)															\$25,300,000	
SO ₂ Emission Control System (#2012)															\$166,500,000	
PM Emission Control System (#2012)															\$25,300,000	
Total Emission Control System Capital Costs (#2012)															\$191,100,000	
NO _x Emission Control System (SRW)															\$0	
SO ₂ Emission Control System (SRW)															\$0	
PM Emission Control System (SRW)															\$0	
Total Emission Control Capital Costs (SRW)															\$0	
Fixed Operating & Maintenance Costs																
Operating Labor (\$)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
Maintenance Material (\$)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
Maintenance Labor (\$)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
Administrative Labor (\$)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
Annual Fixed O&M Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Annual Fixed O&M Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Leveled Fixed O&M Cost (\$/Yr)	\$0	\$0	\$124,478	\$384,542	\$563,114	\$0	\$151,446	\$50,423	\$0	\$0	\$151,446	\$50,423	\$0	\$0	\$625,392	
Variable Operating & Maintenance Costs																
Water Cost	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
Makeup Water Usage (gpm)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
Unit Price (\$/1000 gallons)	\$1.22	\$1.22	\$1.22	\$1.22	\$1.22	\$1.22	\$1.22	\$1.22	\$1.22	\$1.22	\$1.22	\$1.22	\$1.22	\$1.22	\$1.22	
First Year Water Cost (\$)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
Annual Water Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Leveled Water Costs (\$/Yr)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
Reagent Costs																
Type of Reagent	None	None	None	Urea	Anhydrous NH ₃	Elemental Sulfur	Lime	Soda Ash	Soda Ash, Elemental Sulfur, Anhydrous NH ₃	Soda Ash	Soda Ash, Elemental Sulfur	Soda Ash, Elemental Sulfur	Soda Ash, Elemental Sulfur	Soda Ash, Elemental Sulfur	Soda Ash, Elemental Sulfur	
Unit Cost (\$/Ton)	\$0.00	\$0.00	\$0.00	\$370.00	\$400.00	\$370.00	\$81.25	\$80.00	\$80.00	\$81.25	\$80.00	\$80.00	\$80.00	\$80.00	\$80.00	
Unit Cost (\$/Lb)	\$0.00	\$0.00	\$0.00	\$0.185	\$0.200	\$0.185	\$0.046	\$0.046	\$0.046	\$0.046	\$0.046	\$0.046	\$0.046	\$0.046	\$0.046	
Reagent Purity (wt%)	100%	100%	100%	100%	100%	100%	90%	100%	100%	100%	100%	100%	100%	100%	100%	
Reagent Usage (Lb/HR)	\$0	\$0	\$0	\$89,411	\$1,020,310	\$145,654	\$0	\$383,167	\$529,021	\$383,167	\$529,021	\$383,167	\$529,021	\$383,167	\$529,021	
Annual Reagent Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Leveled Reagent Costs (\$/Yr)	\$0	\$0	\$0	\$105,997	\$1,269,590	\$172,910	\$0	\$454,246	\$627,158	\$454,246	\$627,158	\$454,246	\$627,158	\$454,246	\$627,158	
SCR Catalyst/Fabric Filler Bag Replacement Cost																
Material Replaced	Annual SCR Catalyst (m ³) / No. FF Bags	Annual SCR Catalyst (m ³) / No. FF Bags	Annual SCR Catalyst (m ³) / No. FF Bags	Annual SCR Catalyst (m ³) / No. FF Bags	Annual SCR Catalyst (m ³) / No. FF Bags	Annual SCR Catalyst (m ³) / No. FF Bags	Annual SCR Catalyst (m ³) / No. FF Bags	Annual SCR Catalyst (m ³) / No. FF Bags	Annual SCR Catalyst (m ³) / No. FF Bags	Annual SCR Catalyst (m ³) / No. FF Bags	Annual SCR Catalyst (m ³) / No. FF Bags	Annual SCR Catalyst (m ³) / No. FF Bags	Annual SCR Catalyst (m ³) / No. FF Bags	Annual SCR Catalyst (m ³) / No. FF Bags	Annual SCR Catalyst (m ³) / No. FF Bags	
Annual SCR Catalyst (\$/m ³) / Bag Cost (\$/Bag)	\$594,000	\$594,000	\$594,000	\$594,000	\$594,000	\$594,000	\$594,000	\$594,000	\$594,000	\$594,000	\$594,000	\$594,000	\$594,000	\$594,000	\$594,000	
First Year SCR Catalyst Replacement Cost (\$)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
Annual SCR Catalyst Replacement Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Leveled SCR Catalyst Replacement Costs (\$/Yr)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
FGD Waste Disposal Cost																
FGD Waste Disposal Cost	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
FGD Solid Waste Disposal Rate, Dry (Lb/HR)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
FGD Waste Disposal Unit Cost (\$/Dry Ton)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
First Year FGD Waste Disposal Cost (\$)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
Annual FGD Waste Disposal Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Leveled Waste Disposal Costs (\$/Yr)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
Auxiliary Power Cost																
Auxiliary Power Requirement (MW)	0.00	0.00	0.00	0.53	3.25	0.05	3.37	0.53	0.58	3.319	3.319	3.319	3.319	3.319	3.319	
Auxiliary Power Requirement (MW) of Plant Output	0.00%	0.00%	0.00%	0.10%	0.61%	0.01%	0.64%	0.10%	0.11%	0.10%	0.11%	0.10%	0.11%	0.10%	0.11%	
Annual Auxiliary Power Requirement (MWh)	\$0	\$0	\$0	\$50,536	\$25,623	\$94	\$28,568	\$50,536	\$50,536	\$50,536	\$50,536	\$50,536	\$50,536	\$50,536	\$50,536	
Unit Cost (\$/2000kWh)	\$0	\$0	\$0	\$50.00	\$50.00	\$50.00	\$50.00	\$50.00	\$50.00	\$50.00	\$50.00	\$50.00	\$50.00	\$50.00	\$50.00	
First Year Auxiliary Power Cost (\$)	\$0	\$0	\$0	\$2,526,822	\$1,281,150	\$4,710	\$1,428,454	\$2,526,822	\$2,526,822	\$2,526,822	\$2,526,822	\$2,526,822	\$2,526,822	\$2,526,822	\$2,526,822	
Annual Auxiliary Power Cost Escalation Rate (%)	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	
Leveled Auxiliary Power Costs (\$/Yr)	\$0	\$0	\$0	\$2,895,555	\$1,518,807	\$23,356	\$1,574,885	\$2,895,555	\$2,895,555	\$2,895,555	\$2,895,555	\$2,895,555	\$2,895,555	\$2,895,555	\$2,895,555	

Addendum to Jim Bridger Unit 3 BART Report

PREPARED FOR: Wyoming Division of Air Quality
PREPARED BY: CH2M HILL
COPIES: Bill Lawson/PacifiCorp
DATE: March 26, 2008



Introduction

In compliance with the Regional Haze Rule (40 Code of Federal Regulations [CFR] 51), the Wyoming Division of Air Quality (WDAQ) required PacifiCorp Energy to conduct a detailed Best Available Retrofit Technology (BART) review to analyze the effects to visibility in nearby Class I areas from plant emissions, both for baseline and for reasonable control technology scenarios. PacifiCorp submitted these evaluations to WDAQ in January 2007. A revised report was submitted in October 2007.

On January 3, 2008, PacifiCorp Energy personnel met with WDAQ staff to discuss the status of the BART reviews. At that time, the state requested that additional modeling scenarios for several of the PacifiCorp facilities be performed to aid in their BART review. This memorandum presents the economics analysis for two scenarios modeled, referred to as Scenario A and Scenario B and described as follows:

- Scenario A: PacifiCorp committed controls at permitted rates—low nitrogen oxide (NO_x) burners (LNBs) with over-fire air (OFA), sodium based flue gas desulfurization (FGD), SO₃ injection
- Scenario B: PacifiCorp committed controls and selective catalytic reduction (SCR) at permitted rates

The CALPUFF modeling system (v. 5.711a) was used for this analysis. All technical options and model triggers used in CALMET, CALPUFF, and CALPOST are consistent with those used for the previous BART analyses and described in the BART report submitted in October 2007.

Stack Parameters, Emissions Information, and Capital Cost

Table 1 summarizes the control equipment for Scenarios A and B as well as the current equipment installed at the plant. The overall capital cost of installing these options is also shown.

TABLE 1
Control Scenario Summary
Jim Bridger Unit 3

	Equipment Type			Capital Cost
	NO _x	SO ₂	PM ₁₀	Million dollars
Baseline	LNB	Wet sodium FGD	ESP	—
Scenario A	LNB with OFA	Wet sodium FGD	ESP with SO ₃ injection	\$40.5
Scenario B	LNB with OFA and SCR	Wet sodium FGD	ESP with SO ₃ injection	\$207.0

Emissions were modeled for the following pollutants:

- Sulfur dioxide (SO₂)
- NO_x
- Coarse particulate (PM_{2.5}<diameter<PM₁₀)
- Fine particulate (diameter<PM_{2.5})
- Sulfates

Table 2 shows stack parameters and emission rates that were used for the Jim Bridger Unit 3 BART modeling and analysis.

TABLE 2
Calpuff Model Inputs
Jim Bridger Unit 3

Model Input Data	BART Comparison ^(d)		
	Baseline	Scenario A ^(e)	Scenario B ^(f)
Hourly Heat Input (mmBtu/hour)	6,000	6,000	6,000
Sulfur Dioxide (SO ₂) Stack Emissions (lb/hr)	1,602	900	900
Nitrogen Oxide (NO _x) Stack Emissions (lb/hr)	2,700	1,560	420
PM ₁₀ Stack Emissions (lb/hr)	342	180.0	180.0
Coarse Particulate (PM _{2.5} <diameter<PM ₁₀) Stack Emissions (lb/hr) ^(a)	147	77.4	77.4
Fine Particulate (diameter<PM _{2.5}) Stack Emissions (lb/hr) ^(b)	195	102.6	102.6
Sulfuric Acid (H ₂ SO ₄) Stack Emissions (lb/hr)	55.2	55.2	94.7
Ammonium Sulfate [(NH ₄) ₂ SO ₄] Stack Emissions (lb/hr)	—	—	7.0
(NH ₄)HSO ₄ Stack Emissions (lb/hr)	—	—	12.2
H ₂ SO ₄ as Sulfate (SO ₄) Stack Emissions (lb/hr)	54.1	54.1	92.8
(NH ₄) ₂ SO ₄ as SO ₄ Stack Emissions (lb/hr)	—	—	5.1
(NH ₄)HSO ₄ as SO ₄ Stack Emissions (lb/hr)	—	—	10.2

TABLE 2
Calpuff Model Inputs
Jim Bridger Unit 3

Model Input Data	BART Comparison ^(d)		
	Baseline	Scenario A ^(e)	Scenario B ^(f)
Total Sulfate (SO ₄) (lb/hr) ^(c)	54.1	54.1	108.1
Stack Conditions			
Stack Height (meters)	152	152	152
Stack Exit Diameter (meters)	7.32	7.32	7.32
Stack Exit Temperature (Kelvin)	333	328	328
Stack Exit Velocity (meters per second)	25.6	24.7	24.7

NOTES:

^(a) Based on AP-42, Table 1.1-6, the coarse particulates are counted as a percentage of PM₁₀. This equates to 43% ESP and 57% Baghouse. PM₁₀ and PM_{2.5} refer to particulate matter less than 10 and 2.5 micrometers, respectively, in aerodynamic diameter.

^(b) Based on AP-42, Table 1.1-6, the fine particulates are counted as a percentage of PM₁₀. This equates to 57% ESP and 43% Baghouse.

^(c) Total Sulfate (SO₄) (lb/hr) = H₂SO₄ as Sulfate (SO₄) Stack Emissions (lb/hr) + (NH₄)₂SO₄ as SO₄ Stack Emissions (lb/hr) + (NH₄)HSO₄ as SO₄ Stack Emissions (lb/hr)

^(d) SO₂, NO_x, and PM rates are expressed in terms of permitted emission rates. Actual emissions will be less than the permitted rates.

^(e) PacifiCorp Committed Controls @ permitted rates: LNB with OFA, Wet FGD, ESP with SO₃

^(f) PacifiCorp Committed Controls and SCR @ permitted rates

Economic Analysis

In completing this additional analysis to supplement the previous BART study, technology alternatives were investigated and potential reductions in NO_x, SO₂, and PM₁₀ emissions rates were identified.

A comparison of Scenarios A and B on the basis of costs, design control efficiencies, and tons of pollutant removed is summarized in Tables 3 through 5. Capital costs were provided by PacifiCorp. The complete economic analyses for these two scenarios are provided as Attachment 1.

TABLE 3
Scenario A Control Cost
Jim Bridger Unit 3

	NO _x Control		SO ₂ Control		PM ₁₀ Control		Scenario A	
	LNB with OFA	Wet FGD	Wet FGD	Wet FGD	ESP with Gas Conditioning	Control Cost	Control Cost	
Total Installed Capital Costs (million dollars)	\$11.3	\$25.3	\$25.3	\$25.3	\$3.90	\$40.5	\$40.5	
Annualized First-Year Capital Costs	\$1.07	\$2.41	\$2.41	\$2.41	\$0.37	\$3.85	\$3.85	
First Year Fixed & Variable O&M Costs (million dollars)	\$0.07	\$0.98	\$0.98	\$0.98	\$0.18	\$1.22	\$1.22	
Total First Year Annualized Costs (million dollars) ^(a)	\$1.15	\$3.39	\$3.39	\$3.39	\$0.55	\$5.08	\$5.08	
Power Consumption (MW)	—	0.52	0.52	0.52	0.05	0.57	0.57	
Annual Power Usage (Million kWh/Yr)	—	4.10	4.10	4.10	0.39	4.49	4.49	
Permitted Emission Rate (lb/mmBtu)	0.26	0.15	0.15	0.15	0.03	—	—	
Additional Tons of Pollutant Removed per Year over Baseline	4,494	2,838	2,838	2,838	639	7,971	7,971	
First Year Average Control Cost (\$/Ton of Pollutant Removed)	255	1,193	1,193	1,193	856	637	637	

NOTE:
^(a) First year annualized costs include power consumption costs.

TABLE 4
Scenario B Control Cost
Jim Bridger Unit 3

	NO _x Control		SO ₂ Control		PM ₁₀ Control		Scenario B	
	LNB with OFA & SCR		Wet FGD		ESP with Gas Conditioning		Control Cost	
Total Installed Capital Costs (million dollars)	\$177.8	\$25.3	\$3.90	\$207.0				
Annualized First-Year Capital Costs	\$16.91	\$2.41	\$0.37	\$19.69				
First Year Fixed & Variable O&M Costs (million dollars)	\$3.36	\$0.98	\$0.18	\$4.52				
Total First Year Annualized Costs (million dollars) ^(a)	\$20.28	\$3.39	\$0.55	\$24.21				
Power Consumption (MW)	3.22	0.52	0.05	3.79				
Annual Power Usage (Million kWh/Yr)	25.39	4.10	0.39	29.89				
Permitted Emission Rate (lb/mmBtu)	0.07	0.15	0.03	—				
Additional Tons of Pollutant Removed per Year over Baseline	8,988	2,838	639	12,465				
First Year Average Control Cost (\$/Ton of Pollutant Removed)	2,256	1,193	856	1,942				

NOTE:

^(a) First year annualized costs include power consumption costs.

TABLE 5
Incremental Control Costs, Scenario B compared to Scenario A
Jim Bridger Unit 3

	NO _x Control	SO ₂ Control	PM ₁₀ Control	Total Control Cost
Incremental Installed Capital Costs (million dollars)	\$166.5	0	0	\$166.5
Incremental Annualized First-Year Capital Costs	\$15.84	0	0	\$15.84
Incremental First Year Fixed & Variable O&M Costs (million dollars)	\$3.30	0	0	\$3.30
Incremental First Year Annualized Costs (million dollars) ^(a)	\$19.13	0	0	\$19.13
Incremental Power Consumption (MW)	3.22	0	0	3.22
Incremental Annual Power Usage (Million kWh/Yr)	25.39	0	0	25.39
Incremental Improvement in Emission Rate (lb/mmBtu)	0.19	0	0	—
Incremental Tons of Pollutant Removed	4,494	0	0	4,494
Incremental First Year Average Control Cost (\$/Ton of Pollutant Removed)	4,258	0	0	4,258

NOTE:
^(a) Incremental first year annualized costs include power consumption costs.

Modeling Results and Least-Cost Envelope Analysis

CH2M HILL modeled Jim Bridger Unit 3 for two post-control scenarios. The results determine the change in deciview based on each alternative at the Class I areas specific to the project. The Class I areas potentially affected are Bridger Wilderness, Fitzpatrick Wilderness, and Mount Zirkel Wilderness for this unit.

Modeled Scenarios

Current operations (baseline) and two alternative control scenarios were modeled to cover the range of effectiveness for the combination of the individual NO_x, SO₂, and PM control technologies being evaluated. The modeled scenarios include the following:

- Baseline: Current operations with LNB, Wet sodium FGD, and ESP
- Scenario A: LNB with OFA, Wet sodium FGD, and ESP with SO₃ injection
- Scenario B: Scenario A with SCR

Summary of Visibility Analysis

Tables 6 through 8 present a summary of the modeling period (2001–2003) results for each scenario and Class I area.

TABLE 6
Costs and Visibility Modeling Results as Applicable to Bridger Wilderness
Jim Bridger Unit 3

Scenario	Controls	Total First Year Annualized Cost	Highest ΔdV	98 th Percentile ΔdV	Maximum Annual Number of Days Above 0.5 dV
Baseline	Current Operations with FGD and ESP	—	4.381	1.265	30
Scenario A	Scenario A: PacifiCorp Committed Controls	\$5,077,127	2.919	0.829	17
Scenario B	Scenario B: PacifiCorp Committed Controls and SCR	\$24,210,545	1.647	0.481	10

TABLE 7
 Costs and Visibility Modeling Results as Applicable to Fitzpatrick Wilderness
 Jim Bridger Unit 3

Scenario	Controls	Total First Year Annualized Cost	Highest ΔdV	98 th Percentile ΔdV	Maximum Annual Number of Days Above 0.5 dV
Baseline	Current Operations with FGD and ESP	—	2.542	0.615	13
Scenario A	Scenario A: PacifiCorp Committed Controls	\$5,077,127	1.747	0.379	7
Scenario B	Scenario B: PacifiCorp Committed Controls and SCR	\$24,210,545	0.959	0.232	4

TABLE 8
 Costs and Visibility Modeling Results as Applicable to Mount Zirkel Wilderness
 Jim Bridger Unit 3

Scenario	Controls	Total First Year Annualized Cost	Highest ΔdV	98 th Percentile ΔdV	Maximum Annual Number of Days Above 0.5 dV
Baseline	Current Operations with FGD and ESP	—	3.460	1.642	47
Scenario A	Scenario A: PacifiCorp Committed Controls	\$5,077,127	2.168	1.046	22
Scenario B	Scenario B: PacifiCorp Committed Controls and SCR	\$24,210,545	1.298	0.607	12

Results

Tables 9 through 11 present a summary of the costs and modeling results for each scenario and Class I area.

TABLE 9
Incremental Costs and Incremental Visibility Improvements Relative to Bridger Wilderness
Jim Bridger Unit 3

Scenario Comparison	Controls	Incremental Annualized Cost (Million\$)	Reduction in 98 th Percentile maximum dV	Reduction in Number of Days Above 0.5 dV	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Day to Achieve a Reduction in the Days above 0.5 dV (Million\$/Day)
Scenario A Compared to Baseline	Scenario A: PacifiCorp Committed Controls	\$5.08	0.436	13	\$11.64	\$0.39
Scenario B Compared to Baseline	Scenario B: PacifiCorp Committed Controls and SCR	\$24.21	0.784	20	\$30.88	\$1.21
Scenario B Compared To Scenario A	Addition of SCR	\$19.13	0.348	7	\$54.98	\$2.73

TABLE 10
Incremental Costs and Incremental Visibility Improvements Relative to Fitzpatrick Wilderness
Jim Bridger Unit 3

Scenario Comparison	Controls	Incremental Annualized Cost (Million\$)	Reduction in 98 th Percentile maximum dV	Reduction in Number of Days Above 0.5 dV	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Day to Achieve a Reduction in the Days above 0.5 dV (Million\$/Day)
Scenario A Compared to Baseline	Scenario A: PacifiCorp Committed Controls	\$5.08	0.236	6	\$21.51	\$0.85
Scenario B Compared to Baseline	Scenario B: PacifiCorp Committed Controls and SCR	\$24.21	0.383	9	\$63.21	\$2.69
Scenario B Compared To Scenario A	Addition of SCR	\$19.13	0.147	3	\$130.16	\$6.38

TABLE 11
Incremental Costs and Incremental Visibility Improvements Relative to Mount Zirkel Wilderness
Jim Bridger Unit 3

Scenario Comparison	Controls	Incremental Annualized Cost (Million\$)	Reduction in 98th Percentile maximum dV	Reduction in Number of Days Above 0.5 dV	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Day to Achieve a Reduction in the Days above 0.5 dV (Million\$/Day)
Scenario A Compared to Baseline	Scenario A: PacifiCorp Committed Controls	\$5.08	0.596	25	\$8.52	\$0.20
Scenario B Compared to Baseline	Scenario B: PacifiCorp Committed Controls and SCR	\$24.21	1.035	35	\$23.39	\$0.69
Scenario B Compared To Scenario A	Addition of SCR	\$19.13	0.439	10	\$43.58	\$1.91

Least-Cost Envelope Analysis

The least-cost envelope graphs for Bridger Wilderness are shown in Figures 1 and 2, for Fitzpatrick Wilderness in Figures 3 and 4, and for Mount Zirkel Wilderness in Figures 5 and 6.

FIGURE 1




FIGURE 2




FIGURE 3




FIGURE 4




FIGURE 5

Least Cost Envelope
PacifiCorp Jim Bridger Unit 3 - Mount Zirkel Wilderness





FIGURE 6

Least Cost Envelope
PacifiCorp Jim Bridger Unit 3 - Mount Zirkel Wilderness



ATTACHMENT 1

**Complete Economic Analyses
for Scenarios A and B**

ECONOMIC ANALYSIS SUMMARY - FIRST YEAR COSTS

Boiler Design: Tangential fired PC				NO _x Control							SO ₂ Control and PM					Scenario A		Scenario B	
				TYPE OF EMISSIONS CONTROLS							SCENARIO A					Scenario B		Scenario C	
Technology Label	BASE	A	B	C	D	E	F	G	A+F	G	LNE w/OFA, Upgrade Wet FGD and ESP w/ gas conditioning	A+H	LNE w/OFA, Upgrade Wet FGD and ESP w/ gas conditioning	D+F					
Technology Label	Current Operation	Low NO _x Burners with Overfire Air	Rotating Overfire Air	Low NO _x Burners with Overfire Air and Non-Selective Catalytic Reduction	Low NO _x Burners with Overfire Air and Non-Selective Catalytic Reduction	Low NO _x Burners with Overfire Air and Selective Catalytic Reduction	Fabric Filter	Upgrade Wet FGD	LNE w/OFA, Upgrade Wet FGD and ESP w/ gas conditioning	Upgrade Wet FGD	LNE w/OFA, Upgrade Wet FGD and ESP w/ gas conditioning	LNE w/OFA, Upgrade Wet FGD and ESP w/ gas conditioning	LNE w/OFA, Upgrade Wet FGD and ESP w/ gas conditioning	LNE w/OFA, Upgrade Wet FGD and ESP w/ gas conditioning					
ECONOMIC FACTORS																			
Interest Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%					
Discount Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%					
Plant Economic Life (Years)	20	20	20	20	20	20	20	20	20	20	20	20	20	20					
CAPITAL INVESTMENT																			
Total Installed Capital Costs (\$)	\$0	\$11,300,000	\$20,528,122	\$21,973,652	\$177,900,000	\$3,905,000	\$48,396,593	\$25,300,000	\$40,500,000	\$25,300,000	\$40,500,000	\$40,500,000	\$40,500,000	\$207,000,000					
FIRST YEAR DEBT SERVICE (\$/Yr)	\$0	\$1,074,844	\$1,952,798	\$2,980,394	\$16,913,727	\$689,411	\$4,602,887	\$2,406,734	\$3,952,677	\$2,406,734	\$3,952,677	\$3,952,677	\$3,952,677	\$19,691,459					
FIRST YEAR FIXED O&M COSTS (\$/Yr)	\$0	\$0	\$0	\$0	\$0	\$89,411	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0					
Operating Labor (\$/Yr)	\$0	\$28,000	\$42,000	\$122,000	\$190,000	\$0	\$51,099	\$25,500	\$55,500	\$25,500	\$55,500	\$55,500	\$55,500	\$215,500					
Maintenance Material (\$/Yr)	\$0	\$42,000	\$63,000	\$183,000	\$285,000	\$0	\$76,649	\$17,033	\$69,033	\$17,033	\$69,033	\$69,033	\$69,033	\$312,033					
Maintenance Labor (\$/Yr)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0					
Administrative Labor (\$/Yr)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0					
TOTAL FIRST YEAR FIXED O&M COST	\$0	\$70,000	\$105,000	\$305,000	\$475,000	\$89,411	\$127,748	\$42,533	\$122,533	\$42,533	\$122,533	\$122,533	\$122,533	\$527,533					
FIRST YEAR VARIABLE O&M COSTS (\$/Yr)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0					
Makeup Water Costs (\$/Yr)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0					
Reagent Costs (\$/Yr)	\$0	\$0	\$0	\$0	\$1,020,310	\$1,445,654	\$383,167	\$29,927	\$529,021	\$29,927	\$529,021	\$529,021	\$529,021	\$2,549,331					
SCR Catalyst / FF Bag Costs (\$/Yr)	\$0	\$0	\$0	\$0	\$600,000	\$0	\$294,008	\$0	\$0	\$0	\$0	\$0	\$0	\$600,000					
Waste Disposal Costs (\$/Yr)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0					
Electric Power Costs (\$/Yr)	\$0	\$0	\$0	\$294,395	\$2,893,634	\$19,710	\$1,312,895	\$204,984	\$3,918,275	\$204,984	\$3,918,275	\$3,918,275	\$3,918,275	\$3,918,275					
TOTAL FIRST YEAR VARIABLE O&M COSTS (\$/Yr)	\$0	\$0	\$0	\$294,395	\$2,893,634	\$19,710	\$1,312,895	\$204,984	\$5,936,353	\$204,984	\$5,936,353	\$5,936,353	\$5,936,353	\$11,494,018					
SUMMARY OF FIRST YEAR COSTS (\$/Yr)	\$0	\$1,074,844	\$1,952,798	\$2,980,394	\$16,913,727	\$89,411	\$4,602,887	\$2,406,734	\$3,952,677	\$2,406,734	\$3,952,677	\$3,952,677	\$3,952,677	\$19,691,459					
First Year Debt Service (\$/Yr)	\$0	\$70,000	\$105,000	\$305,000	\$475,000	\$89,411	\$127,748	\$42,533	\$122,533	\$42,533	\$122,533	\$122,533	\$122,533	\$527,533					
First Year Fixed O&M Costs (\$/Yr)	\$0	\$70,000	\$105,000	\$305,000	\$475,000	\$89,411	\$127,748	\$42,533	\$122,533	\$42,533	\$122,533	\$122,533	\$122,533	\$527,533					
First Year Variable O&M Costs (\$/Yr)	\$0	\$0	\$0	\$294,395	\$2,893,634	\$19,710	\$1,312,895	\$204,984	\$5,936,353	\$204,984	\$5,936,353	\$5,936,353	\$5,936,353	\$11,494,018					
Total First Year Costs (\$/Yr)	\$0	\$1,144,844	\$2,057,798	\$3,285,394	\$20,279,361	\$1,108,121	\$6,032,730	\$2,854,251	\$9,811,563	\$2,854,251	\$9,811,563	\$9,811,563	\$9,811,563	\$21,702,510					
CONTROL COST COMPARISONS																			
NO _x Technology Comparison																			
Additional NO _x Removed From Base Case (Tons/Yr)	0	4,494	5,440	5,440	8,988	5,440	8,988	5,440	8,988	5,440	8,988	8,988	8,988	8,988					
First Year Average Control Cost (\$/Ton NO _x Removed)	\$0	\$255	\$943	\$943	\$2,256	\$943	\$943	\$943	\$943	\$943	\$943	\$943	\$943	\$943					
Technology Case Comparison																			
Incremental NO _x Removed (Tons/Yr)	0	A-BASE	B-A	C-A	D-A	E-A	F-E	G-F											
Incremental Control Cost (\$/Ton NO _x Removed)	\$0	4,494	946	946	4,494	4,494	0	0	0	0	0	0	0	0					
SO ₂ Technology Comparison																			
Additional SO ₂ Removed From Base Case (Tons/Yr)	77.5%	77.5%	77.5%	77.5%	77.5%	77.5%	77.5%	77.5%	77.5%	77.5%	77.5%	77.5%	77.5%	77.5%					
First Year Average Control Cost (\$/Ton SO ₂ Removed)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0					
Technology Case Comparison																			
Incremental SO ₂ Removed (Tons/Yr)	0	0	0	0	0	0	0	0	0	0	0	0	0	0					
Incremental Control Cost (\$/Ton SO ₂ Removed)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0					
PM Technology Comparison																			
Additional PM Removed From Base Case (Tons/Yr)	0	0	0	0	0	0	0	0	0	0	0	0	0	0					
First Year Average Control Cost (\$/Ton PM Removed)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0					
Technology Case Comparison																			
Incremental PM Removed (Tons/Yr)	0	0	0	0	0	0	0	0	0	0	0	0	0	0					
Incremental Control Cost (\$/Ton PM Removed)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0					
SCENARIO A AND B COMPARISONS																			
Additional NO _x , SO ₂ , & PM Removed From Base Case (Tons/Yr)	0	0	0	0	0	0	0	0	0	0	0	0	0	0					
First Year Average Control Cost Compared to Base Case (\$/Ton Removed)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0					
Incremental Control Costs - Scenario B vs Scenario A (\$/Ton Removed)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0					
Incremental Control Costs - Scenario A (\$/Ton Removed)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0					
Incremental Control Costs - Scenario B vs Scenario A (\$/Ton Removed)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0					

INPUT CALCULATIONS		Tangential-Fined PC											
PARAMETER	Boiler Design: Current Operation	NO _x Control Technologies				SO ₂ and PM Control Technologies				Scenario A		Scenario B	
		LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	N/A ESP w/ Gas Conditioning	N/A Fabric Filter	Upgrade Wet FGD ESP	LNB w/OFA Upgrade Wet FGD ESP w/ Gas Conditioning	LNB w/OFA & SCR Upgrade Wet FGD ESP w/ Gas Conditioning			
General Plant Design and Operating Data													
Type of Unit	FC	FC	FC	FC	FC	FC	FC	FC	FC	FC	FC	FC	FC
Annual Power Plant Capacity Factor	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%
Annual Operation (Hours/Year)	7,920	7,920	7,920	7,920	7,920	7,920	7,920	7,920	7,920	7,920	7,920	7,920	7,920
Net Power Output (MW)	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000
Net Plant Heat Rate (Btu/kWh)	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320
Net Plant Heat Rate (MMBtu/yr)	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000
Annual Heat Input, Measured by Fuel Input (MMBtu/yr)	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846
Annual Heat Input, Measured by CEM (MMBtu/yr)	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000
Annual Heat Input, Measured by CEM (MMBtu/Year)	47,300,000	47,300,000	47,300,000	47,300,000	47,300,000	47,300,000	47,300,000	47,300,000	47,300,000	47,300,000	47,300,000	47,300,000	47,300,000
Plant Fuel Sources													
Boiler Fuel Source	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground	Bridger Mine Underground
Coal Heating Value (Btu/lb)	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660
Coal Sulfur Content (wt.%)	0.59%	0.59%	0.59%	0.59%	0.59%	0.59%	0.59%	0.59%	0.59%	0.59%	0.59%	0.59%	0.59%
Coal Ash Rate (lb/lbHr)	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%
Coal Consumption (Ton/yr)	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077
Coal Consumed (Ton/yr)	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284
Nitrogen Oxide Emissions													
NO _x Emission Rate (lb/MMBtu)	0.45	0.25	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22
NO _x Emission Rate (lb/Hr)	2,700	1,320	1,320	1,320	1,320	1,320	1,320	1,320	1,320	1,320	1,320	1,320	1,320
NO _x Emission Rate (lb/Moeshr)	89.37	51.98	43.99	43.99	43.99	43.99	43.99	43.99	43.99	43.99	43.99	43.99	43.99
NO _x Emission Rate (Ton/yr)	10,643	5,203	5,203	5,203	5,203	5,203	5,203	5,203	5,203	5,203	5,203	5,203	5,203
Add'l NO _x Removed from Current Operations (lb/Hr)	0	1,386	5,446	5,446	5,446	5,446	5,446	5,446	5,446	5,446	5,446	5,446	5,446
Add'l NO _x Removed from Current Operations (Ton/yr)	0	4,494	5,446	5,446	5,446	5,446	5,446	5,446	5,446	5,446	5,446	5,446	5,446
Sulfur Dioxide Emissions													
Uncontrolled SO ₂ (lb/MMBtu)	1.20												
Uncontrolled SO ₂ (lb/Hr)	7,198												
Uncontrolled SO ₂ (lb/Moeshr)	112.35												
Uncontrolled SO ₂ (Ton/yr)	28,374												
Controlled SO ₂ Emission Rate (lb/MMBtu)	0.27												
SO ₂ Removal Efficiency (%)	77.5%												
Controlled SO ₂ Emissions (lb/Hr)	1,820												
Controlled SO ₂ Emissions (Ton/yr)	6,366												
SO ₂ Removed (lb/Hr)	5,378												
SO ₂ Removed (Ton/yr)	21,988												
Add'l SO ₂ Removed from Current Operations (lb/Hr)	0												
Add'l SO ₂ Removed from Current Operations (Ton/yr)	0												
Particulate Matter Emissions													
Uncontrolled Fly Ash (lb/Hr)	51,177												
Uncontrolled Fly Ash (Ton/yr)	6,529												
Controlled Fly Ash Emission Rate (lb/MMBtu)	0.034												
Controlled Fly Ash Emission Rate (lb/Hr)	180												
Controlled Fly Ash Emission Rate (Ton/yr)	342												
Controlled Fly Ash Removal Efficiency (%)	98.3%												
Controlled Fly Ash Emissions (lb/Hr)	1,348												
Controlled Fly Ash Emissions (Ton/yr)	50,997												
Fly Ash Removed (lb/Hr)	207,165												
Fly Ash Removed (Ton/yr)	639												
Add'l Fly Ash Removed from Current Operations (lb/Hr)	0												
Add'l Fly Ash Removed from Current Operation (Ton/yr)	0												
Economic Factors													
Discal Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%
Discal Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%
Plant Economic Life (Years)	20	20	20	20	20	20	20	20	20	20	20	20	20

INPUT CALCULATIONS

Boiler Design: **Jim Bridgler 3** Tangential-Fired PC

PARAMETER	NO _x Control Technologies				SO ₂ and PM Control Technologies				Scenario A	Scenario B
	Current Operation	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	N/A ESP w/ Gas Conditioning	N/A Fabric Filter	Upgrade Wet FGD ESP		
Control Technologies	LNCF-1 & Windbox Mod. Wet FGD ESP									
Installed Capital Costs		\$11,300,000	\$20,528,122	\$21,973,632	\$177,800,000	\$3,900,000	\$48,265,333	\$25,300,000	\$11,300,000	\$25,300,000
NO _x Emission Control System (\$2012)										
SO ₂ Emission Control System (\$2012)										
PM Emission Control System (\$2012)										
Total Emission Control System Capital Costs (\$2012)		\$11,300,000	\$20,528,122	\$21,973,632	\$177,800,000	\$3,900,000	\$48,265,333	\$25,300,000	\$11,300,000	\$25,300,000
NO _x Emission Control System (\$AW)		\$21	\$39	\$41	\$335				\$21	\$39
SO ₂ Emission Control System (\$AW)										
PM Emission Control System (\$AW)										
Total Emission Control System (\$AW)		\$21	\$39	\$41	\$335				\$21	\$39
Fixed Operating & Maintenance Costs										
Operating Labor (\$)		\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Maintenance Material (\$)		\$42,000	\$42,000	\$122,000	\$180,000	\$0	\$51,000	\$25,000	\$42,000	\$25,000
Maintenance Labor (\$)		\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Total Fixed O&M Cost (\$/yr)		\$42,000	\$42,000	\$122,000	\$180,000	\$0	\$51,000	\$25,000	\$42,000	\$25,000
Levelized Fixed O&M Cost (\$/hr)		2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%
Variable Operating & Maintenance Costs										
Water Cost		\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Makeup Water Usage (gpm)		\$122	\$122	\$122	\$122	\$0	\$122	\$122	\$122	\$122
Unit Price (\$/1000 gallons)		2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%
First Year Water Cost (\$)		\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Annual Water Cost Escalation Rate (%)										
Levelized Water Costs (\$/hr)		\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Reagent Cost										
Type of Reagent		None	None	Urea	Anhydrous NH ₃	Elemental Sulfur	Lime	Soda Ash	Soda Ash & Elemental Sulfur	Soda Ash, Elemental Sulfur, Anhydrous NH ₃
Unit Cost (\$/Ton)		\$0.00	\$0.00	\$370.00	\$400.00	\$370.00	\$81.25	\$80.00	\$80.00	\$80.00
Unit Cost (\$/Lb)		\$0.00	\$0.00	\$0.165	\$0.200	\$0.165	\$0.046	\$0.046	\$0.046	\$0.046
Molar Stoichiometry		0.00	0.45	1.00	1.00	1.00	1.15	1.00	1.00	1.00
Reagent Purity (wt.%)		100%	100%	100%	100%	100%	90%	100%	100%	100%
Reagent Usage (Lb/hr)		\$0	\$0	\$89.01	\$1,095.847	\$1,095.847	\$127.19	\$32.00	\$32.00	\$32.00
Annual Reagent Cost (\$)		\$0	\$0	\$1,055.897	\$1,209,582	\$1,209,582	\$172,510	\$45,216	\$45,216	\$45,216
Annual Reagent Cost Escalation Rate (%)										
SCR Catalyst (Tons/yr) (\$/T)										
SCR Catalyst (Tons/yr) (\$/T)										
Annual SCR Catalyst (m3) / No. FF Bags					200					
SCR Catalyst (\$/m3) / Bag Cost (\$/bag)					\$3,000					
Annual SCR Catalyst / Bag Cost Escalation Rate (%)					2.00%					
Levelized Catalyst/Fabric Filter Bag Costs (\$/hr)					\$711.302					
FGD Waste Disposal Cost										
FGD Waste Disposal Unit Cost (\$/Ton)										
Annual FGD Waste Disposal Cost Esc. Rate (%)										
Levelized Waste Disposal Costs (\$/hr)										
Auxiliary Power Cost										
Auxiliary Power Requirement (MW)		0.00	6.41	0.57	3.22	0.05	3.35	0.57	0.57	0.57
Auxiliary Power Requirement (% of Plant Output)		0.00%	1.27%	0.10%	0.66%	0.01%	0.67%	0.10%	0.10%	0.10%
Auxiliary Power Usage (MWh)		\$0	\$50,000	\$50,000	\$50,000	\$50,000	\$50,000	\$50,000	\$50,000	\$50,000
Annual Auxiliary Power Cost (\$)		\$0	\$2,528,822	\$2,528,822	\$2,528,822	\$2,528,822	\$2,528,822	\$2,528,822	\$2,528,822	\$2,528,822
Annual Power Cost Escalation Rate (%)			2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%	2.00%
Levelized Auxiliary Power Costs (\$/hr)		\$0	\$2,895.555	\$2,895.555	\$2,895.555	\$2,895.555	\$2,895.555	\$2,895.555	\$2,895.555	\$2,895.555

Addendum to Jim Bridger Unit 4 BART Report

PREPARED FOR: Wyoming Division of Air Quality
PREPARED BY: CH2M HILL
COPIES: Bill Lawson/PacifiCorp
DATE: March 26, 2008



Introduction

In compliance with the Regional Haze Rule (40 Code of Federal Regulations [CFR] 51), the Wyoming Division of Air Quality (WDAQ) required PacifiCorp Energy to conduct a detailed Best Available Retrofit Technology (BART) review to analyze the effects to visibility in nearby Class I areas from plant emissions, both for baseline and for reasonable control technology scenarios. PacifiCorp submitted these evaluations to WDAQ in January 2007. A revised report was submitted in October 2007.

On January 3, 2008, PacifiCorp Energy personnel met with WDAQ staff to discuss the status of the BART reviews. At that time, the state requested that additional modeling scenarios for several of the PacifiCorp facilities be performed to aid in their BART review. This memorandum presents the economics analysis for two scenarios modeled, referred to as Scenario A and Scenario B and described as follows:

- Scenario A: PacifiCorp committed controls at permitted rates—low nitrogen oxide (NO_x) burners (LNBs) with over-fire air (OFA), sodium based flue gas desulfurization (FGD), SO₃ injection
- Scenario B: PacifiCorp committed controls and selective catalytic reduction (SCR) at permitted rates

The CALPUFF modeling system (v. 5.711a) was used for this analysis. All technical options and model triggers used in CALMET, CALPUFF, and CALPOST are consistent with those used for the previous BART analyses and described in the BART report submitted in October 2007.

Stack Parameters, Emissions Information, and Capital Cost

Table 1 summarizes the control equipment for Scenarios A and B as well as the current equipment installed at the plant. The overall capital cost of installing these options is also shown.

TABLE 1
Control Scenario Summary
Jim Bridger Unit 4

	Equipment Type			Capital Cost
	NO _x	SO ₂	PM ₁₀	Million dollars
Baseline	LNB	Wet sodium FGD	ESP with SO ₃ injection	—
Scenario A	LNB with OFA	Wet sodium FGD	ESP with SO ₃ injection	\$12.9
Scenario B	LNB with OFA and SCR	Wet sodium FGD	ESP with SO ₃ injection	\$179.4

Emissions were modeled for the following pollutants:

- Sulfur dioxide (SO₂)
- NO_x
- Coarse particulate (PM_{2.5}<diameter<PM₁₀)
- Fine particulate (diameter<PM_{2.5})
- Sulfates

Table 2 shows stack parameters and emission rates that were used for the Jim Bridger Unit 4 BART modeling and analysis.

TABLE 2
Calpuff Model Inputs
Jim Bridger Unit 4

Model Input Data	BART Comparison ^(d)		
	Baseline	Scenario A ^(e)	Scenario B ^(f)
Hourly Heat Input (mmBtu/hour)	6,000	6,000	6,000
Sulfur Dioxide (SO ₂) Stack Emissions (lb/hr)	1,002	900	900
Nitrogen Oxide (NO _x) Stack Emissions (lb/hr)	2,700	1,560	420
PM ₁₀ Stack Emissions (lb/hr)	180	180	180
Coarse Particulate (PM _{2.5} <diameter< PM ₁₀) Stack Emissions (lb/hr) ^(a)	77.4	77.4	77.4
Fine Particulate (diameter<PM _{2.5}) Stack Emissions (lb/hr) ^(b)	103	102.6	102.6
Sulfuric Acid (H ₂ SO ₄) Stack Emissions (lb/hr)	55.2	55.2	94.7
Ammonium Sulfate [(NH ₄) ₂ SO ₄] Stack Emissions (lb/hr)	—	—	7.0
(NH ₄)HSO ₄ Stack Emissions (lb/hr)	—	—	12.2
H ₂ SO ₄ as Sulfate (SO ₄) Stack Emissions (lb/hr)	54.1	54.1	92.8
(NH ₄) ₂ SO ₄ as SO ₄ Stack Emissions (lb/hr)	—	—	5.1
(NH ₄)HSO ₄ as SO ₄ Stack Emissions (lb/hr)	—	—	10.2

TABLE 2
Calpuff Model Inputs
Jim Bridger Unit 4

Model Input Data	BART Comparison ^(d)		
	Baseline	Scenario A ^(e)	Scenario B ^(f)
Total Sulfate (SO ₄) (lb/hr) ^(c)	54.1	54.1	108.1
Stack Conditions			
Stack Height (meters)	152	152	152
Stack Exit Diameter (meters)	9.45	9.45	9.45
Stack Exit Temperature (Kelvin)	322	322	322
Stack Exit Velocity (meters per second)	12.9	12.9	12.9

NOTES:

^(a) Based on AP-42, Table 1.1-6, the coarse particulates are counted as a percentage of PM₁₀. This equates to 43% ESP and 57% Baghouse. PM₁₀ and PM_{2.5} refer to particulate matter less than 10 and 2.5 micrometers, respectively, in aerodynamic diameter.

^(b) Based on AP-42, Table 1.1-6, the fine particulates are counted as a percentage of PM₁₀. This equates to 57% ESP and 43% Baghouse.

^(c) Total Sulfate (SO₄) (lb/hr) = H₂SO₄ as Sulfate (SO₄) Stack Emissions (lb/hr) + (NH₄)₂SO₄ as SO₄ Stack Emissions (lb/hr) + (NH₄)HSO₄ as SO₄ Stack Emissions (lb/hr)

^(d) SO₂, NO_x, and PM rates are expressed in terms of permitted emission rates. Actual emissions will be less than the permitted rates.

^(e) PacifiCorp Committed Controls @ permitted rates: LNB with OFA, Wet FGD, ESP with SO₃

^(f) PacifiCorp Committed Controls and SCR @ permitted rates

Economic Analysis

In completing this additional analysis to supplement the previous BART study, technology alternatives were investigated and potential reductions in NO_x, SO₂, and PM₁₀ emissions rates were identified.

A comparison of Scenarios A and B on the basis of costs, design control efficiencies, and tons of pollutant removed is summarized in Tables 3 through 5. Capital costs were provided by PacifiCorp. The complete economic analyses for these two scenarios are provided as Attachment 1.

TABLE 3
Scenario A Control Cost
Jim Bridger Unit 4

	NO _x Control		SO ₂ Control	PM ₁₀ Control	Scenario A	
	LNB with OFA	Wet FGD	Existing ESP with Gas Conditioning	Control Cost	Control Cost	
Total Installed Capital Costs (million dollars)	\$11.3	\$1.60	—	—	\$12.9	
Annualized First-Year Capital Costs	\$1.07	\$0.15	—	—	\$1.23	
First Year Fixed & Variable O&M Costs (million dollars)	\$0.07	\$0.38	\$0.17	—	\$0.62	
Total First Year Annualized Costs (million dollars) ^(a)	\$1.14	\$0.54	\$0.17	—	\$1.85	
Power Consumption (MW)	—	0.53	0.05	—	0.58	
Annual Power Usage (Million kWh/Yr)	—	4.18	0.39	—	4.57	
Permitted Emission Rate (lb/mmBtu)	0.26	0.15	0.03	—	—	
Additional Tons of Pollutant Removed per Year over Baseline	4,494	473	—	—	4,967	
First Year Average Control Cost (\$/Ton of Pollutant Removed)	255	1,113	—	—	372	

NOTE:

^(a) First year annualized costs include power consumption costs.

TABLE 4
Scenario B Control Cost
Jim Bridger Unit 4

	NO _x Control		SO ₂ Control		PM ₁₀ Control		Scenario B	
	LNB with OFA & SCR		Wet FGD		Existing ESP with Gas Conditioning		Control Cost	
Total Installed Capital Costs (million dollars)	\$177.8	\$1.60	—	—	—	—	\$179.4	
Annualized First-Year Capital Costs	\$16.91	\$0.15	—	—	—	—	\$17.07	
First Year Fixed & Variable O&M Costs (million dollars)	\$3.46	\$0.38	\$0.17	\$4.01	—	—	\$4.01	
Total First Year Annualized Costs (million dollars) ^(a)	\$20.37	\$0.54	\$0.17	\$21.07	—	—	\$21.07	
Power Consumption (MW)	3.36	0.53	0.05	3.94	—	—	3.94	
Annual Power Usage (Million kWh/Yr)	26.49	4.18	394	31.06	—	—	31.06	
Permitted Emission Rate (lb/mmBtu)	0.07	0.15	0.03	—	—	—	—	
Additional Tons of Pollutant Removed per Year over Baseline	8,988	473	—	9,461	—	—	9,461	
First Year Average Control Cost (\$/Ton of Pollutant Removed)	2,267	1,133	—	2,228	—	—	2,228	

NOTE:

^(a) First year annualized costs include power consumption costs.

TABLE 5
Incremental Control Costs, Scenario B compared to Scenario A
Jim Bridger Unit 4

	NO _x Control	SO ₂ Control	PM ₁₀ Control	Total Control Cost
Incremental Installed Capital Costs (million dollars)	\$166.5	0	0	\$166.5
Incremental Annualized First-Year Capital Costs	\$15.84	0	0	\$15.84
Incremental First Year Fixed & Variable O&M Costs (million dollars)	\$3.39	0	0	\$3.39
Incremental First Year Annualized Costs (million dollars) ^(e)	\$19.23	0	0	\$19.23
Incremental Power Consumption (MW)	3.36	0	0	3.36
Incremental Annual Power Usage (Million kWh/Yr)	26.49	0	0	26.49
Incremental Improvement in Emission Rate (lb/mmBtu)	0.19	0	0	—
Incremental Tons of Pollutant Removed	4,494	0	0	4,494
Incremental First Year Average Control Cost (\$/Ton of Pollutant Removed)	4,279	0	0	4,279

NOTE:
^(e)Incremental first year annualized costs include power consumption costs.

Modeling Results and Least-Cost Envelope Analysis

CH2M HILL modeled Jim Bridger Unit 4 for two post-control scenarios. The results determine the change in deciview based on each alternative at the Class I areas specific to the project. The Class I areas potentially affected are Bridger Wilderness, Fitzpatrick Wilderness, and Mount Zirkel Wilderness for this unit.

Modeled Scenarios

Current operations (baseline) and two alternative control scenarios were modeled to cover the range of effectiveness for the combination of the individual NO_x, SO₂, and PM control technologies being evaluated. The modeled scenarios include the following:

- Baseline: Current operations with LNB, Wet sodium FGD, and ESP with SO₃ injection
- Scenario A: LNB with OFA, Wet sodium FGD, and ESP with SO₃ injection
- Scenario B: Scenario A with SCR

Summary of Visibility Analysis

Tables 6 through 8 present a summary of the modeling period (2001–2003) results for each scenario and Class I area.

TABLE 6
Costs and Visibility Modeling Results as Applicable to Bridger Wilderness
Jim Bridger Unit 4

Scenario	Controls	Total First Year Annualized Cost	Highest ΔdV	98 th Percentile ΔdV	Maximum Annual Number of Days Above 0.5 dV
Baseline	Current Operations with FGD and ESP	—	4.247	1.203	30
Scenario A	Scenario A: PacifiCorp Committed Controls	\$1,846,618	2.899	0.819	18
Scenario B	Scenario B: PacifiCorp Committed Controls and SCR	\$21,077,225	1.632	0.490	11

TABLE 7
 Costs and Visibility Modeling Results as Applicable to Fitzpatrick Wilderness
 Jim Bridger Unit 4

Scenario	Controls	Total First Year Annualized Cost	Highest ΔV	98 th Percentile ΔV	Maximum Annual Number of Days Above 0.5 dV
Baseline	Current Operations with FGD and ESP	—	2.606	0.606	13
Scenario A	Scenario A: PacifiCorp Committed Controls	\$1,846,618	1.713	0.404	8
Scenario B	Scenario B: PacifiCorp Committed Controls and SCR	\$21,077,225	0.937	0.231	3

TABLE 8
 Costs and Visibility Modeling Results as Applicable to Mount Zirkel Wilderness
 Jim Bridger Unit 4

Scenario	Controls	Total First Year Annualized Cost	Highest ΔV	98 th Percentile ΔV	Maximum Annual Number of Days Above 0.5 dV
Baseline	Current Operations with FGD and ESP	—	3.134	1.541	38
Scenario A	Scenario A: PacifiCorp Committed Controls	\$1,846,618	2.139	1.030	23
Scenario B	Scenario B: PacifiCorp Committed Controls and SCR	\$21,077,225	1.278	0.606	12

Results

Tables 9 through 11 present a summary of the costs and modeling results for each scenario and Class I area.

TABLE 9
Incremental Costs and Incremental Visibility Improvements Relative to Bridger Wilderness
Jim Bridger Unit 4

Scenario Comparison	Controls	Incremental Annualized Cost (Million\$)	Reduction in 98 th Percentile maximum dV	Reduction in Number of Days Above 0.5 dV	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Day to Achieve a Reduction in the Days above 0.5 dV (Million\$/Day)
Scenario A Compared to Baseline	Scenario A: PacifiCorp Committed Controls	\$1.85	0.384	12	\$4.81	\$0.15
Scenario B Compared to Baseline	Scenario B: PacifiCorp Committed Controls and SCR	\$21.08	0.713	19	\$29.56	\$1.11
Scenario B Compared To Scenario A	Addition of SCR	\$19.23	0.329	7	\$58.45	\$2.75

TABLE 10
Incremental Costs and Incremental Visibility Improvements Relative to Fitzpatrick Wilderness
Jim Bridger Unit 4

Scenario Comparison	Controls	Incremental Annualized Cost (Million\$)	Reduction in 98 th Percentile maximum dV	Reduction in Number of Days Above 0.5 dV	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Day to Achieve a Reduction in the Days above 0.5 dV (Million\$/Day)
Scenario A Compared to Baseline	Scenario A: PacifiCorp Committed Controls	\$1.85	0.202	5	\$9.14	\$0.37
Scenario B Compared to Baseline	Scenario B: PacifiCorp Committed Controls and SCR	\$21.08	0.375	10	\$56.21	\$2.11
Scenario B Compared To Scenario A	Addition of SCR	\$19.23	0.173	5	\$111.16	\$3.85

TABLE 11
 Incremental Costs and Incremental Visibility Improvements Relative to Mount Zirkel Wilderness
 Jim Bridger Unit 4

Scenario Comparison	Controls	Incremental Annualized Cost (Million\$)	Reduction in 98 th Percentile maximum dV	Reduction in Number of Days Above 0.5 dV	Cost per dV Reduction (Million\$/dV Reduced)	Cost per Day to Achieve a Reduction in the Days above 0.5 dV (Million\$/Day)
Scenario A Compared to Baseline	Scenario A: PacifiCorp Committed Controls	\$1.85	0.511	15	\$3.61	\$0.12
Scenario B Compared to Baseline	Scenario B: PacifiCorp Committed Controls and SCR	\$21.08	0.935	26	\$22.54	\$0.81
Scenario B Compared To Scenario A	Addition of SCR	\$19.23	0.424	11	\$45.36	\$1.75

Least-Cost Envelope Analysis

The least-cost envelope graphs for Bridger Wilderness are shown in Figures 1 and 2, for Fitzpatrick Wilderness in Figures 3 and 4, and for Mount Zirkel Wilderness in Figures 5 and 6.

FIGURE 1




FIGURE 2




FIGURE 3




FIGURE 4




FIGURE 5

Least Cost Envelope
PacifiCorp Jim Bridger Unit 4 - Mount Zirkel Wilderness





FIGURE 6

Least Cost Envelope
PacifiCorp Jim Bridger Unit 4 - Mount Zirkel Wilderness



ATTACHMENT 1

**Complete Economic Analyses
for Scenarios A and B**

INPUT CALCULATIONS

PARAMETER	Boiler Design:		Tangential fired PC						Scenario A		Scenario B	
	Current Operation	NO _x Control Technologies	NO _x Control Technologies		SO ₂ and PM Control Technologies		Scenario A		Scenario B			
Control Technologies	LNCFS-1 & Window Inlets, Wet FGD	LNB w/COFA	ROFA	LNB w/COFA & SNCR	LNB w/COFA & SCR	Upgrade Wet FGD ESP	Upgrade Wet FGD ESP	LNB w/COFA Upgrade Wet FGD ESP w/ Gas Conditioning	LNB w/COFA Upgrade Wet FGD ESP w/ Gas Conditioning			
General Plant Design and Operating Data	PC	PC	PC	PC	PC	PC	PC	PC	PC			
Type of Unit	99%	99%	99%	99%	99%	99%	99%	99%	99%			
Plant Capacity Factor	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884			
Annual Operation (Hours/Year)	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000	530,000			
Net Power Output (kW)	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320	11,320			
Net Plant Heat Rate (lb/MWhH)	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000			
Boiler Heat Input, Measured by Fuel Input (MMBtu/Year)	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846	47,300,846			
Boiler Heat Input, Measured by CEM (MMBtu/Year)	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000			
Annual Heat Input, Measured by CEM (MMBtu/Year)	47,300,000	47,300,000	47,300,000	47,300,000	47,300,000	47,300,000	47,300,000	47,300,000	47,300,000			
PLANT FUEL SOURCE	Bidger Mine Underground	Bidger Mine Underground	Bidger Mine Underground	Bidger Mine Underground	Bidger Mine Underground	Bidger Mine Underground	Bidger Mine Underground	Bidger Mine Underground	Bidger Mine Underground			
Boiler Fuel Source	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660	9,660			
Coal Heating Value (Btu/Lb)	0.55%	0.55%	0.55%	0.55%	0.55%	0.55%	0.55%	0.55%	0.55%			
Coal Sulfur Content (wt%)	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%	10.30%			
Coal Flow Rate (Lb/Hr)	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077	621,077			
Coal Consumed (Ton/Yr)	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284	2,448,284			
Nitrogen Oxide Emissions	0.45	0.22	0.22	0.22	0.07	0.07	0.07	0.26	0.07			
NO _x Emission Rate (lb/MMBtu)	2,700	1,320	1,320	1,320	420	420	420	1,560	420			
NO _x Emission Rate (lb/MWhH)	86.87	43.96	43.96	43.96	14.00	14.00	14.00	51.86	14.00			
NO _x Emission Rate (Ton/Yr)	10,648	5,203	5,203	5,203	1,655	1,655	1,655	6,150	1,655			
NO _x Removed from Current Operations (Ton/Yr)	0	1,380	1,380	1,380	2,290	2,290	2,290	1,140	2,290			
NO _x Removed from Current Operations (Ton/Yr)	0	4,494	5,440	5,440	8,985	8,985	8,985	4,494	8,985			
Sulfur Dioxide Emissions	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20			
Uncontrolled SO ₂ (Lb/Hr)	7,198	7,198	7,198	7,198	7,198	7,198	7,198	7,198	7,198			
Uncontrolled SO ₂ (Lb/MWhH)	112.35	112.35	112.35	112.35	112.35	112.35	112.35	112.35	112.35			
Uncontrolled SO ₂ (Ton/Yr)	26,374	26,374	26,374	26,374	26,374	26,374	26,374	26,374	26,374			
Controlled SO ₂ Emission Rate (Lb/MMBtu)	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.15	0.15			
SO ₂ Removal Efficiency (%)	95.8%	85.8%	85.8%	85.8%	87.5%	87.5%	87.5%	87.5%	87.5%			
Controlled SO ₂ Emissions (Lb/Hr)	1,029	1,029	1,029	1,029	800	800	800	900	800			
Controlled SO ₂ Emissions (Ton/Yr)	4,021	4,021	4,021	4,021	3,548	3,548	3,548	3,548	3,548			
SO ₂ Removed (Lb/Hr)	6,178	6,178	6,178	6,178	6,178	6,298	6,298	6,298	6,298			
SO ₂ Removed (Ton/Yr)	24,353	24,353	24,353	24,353	24,828	24,828	24,828	24,828	24,828			
SO ₂ Removed from Current Operations (Lb/Hr)	0	0	0	0	0	0	0	120	0			
SO ₂ Removed from Current Operations (Ton/Yr)	0	0	0	0	0	0	0	473	0			
Particulate Matter Emissions	51,177	51,177	51,177	51,177	51,177	51,177	51,177	51,177	51,177			
Uncontrolled Fly Ash (Lb/Hr)	8,529	8,529	8,529	8,529	8,529	8,529	8,529	8,529	8,529			
Uncontrolled Fly Ash (Lb/MWhH)	201,723	201,723	201,723	201,723	201,723	201,723	201,723	201,723	201,723			
Uncontrolled Fly Ash (Ton/Yr)	0.032	0.032	0.032	0.032	0.032	0.032	0.032	0.032	0.032			
Controlled Fly Ash Emission Rate (Lb/MMBtu)	59.6%	59.6%	59.6%	59.6%	59.6%	59.6%	59.6%	59.6%	59.6%			
Controlled Fly Ash Removal Efficiency (%)	180	180	180	180	180	180	180	180	180			
Controlled Fly Ash Emissions (Lb/Hr)	30,897	30,897	30,897	30,897	30,897	30,897	30,897	30,897	30,897			
Controlled Fly Ash Emissions (Ton/Yr)	201,029	201,029	201,029	201,029	201,029	201,029	201,029	201,029	201,029			
Fly Ash Removed (Lb/Hr)	0	0	0	0	0	0	0	0	0			
Fly Ash Removed from Current Operations (Lb/Hr)	0	0	0	0	0	0	0	0	0			
Fly Ash Removed from Current Operations (Ton/Yr)	0	0	0	0	0	0	0	0	0			
Economic Factors	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%			
Interest Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%			
Discount Rate (%)	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%	7.10%			
Plant Economic Life (Years)	20	20	20	20	20	20	20	20	20			

INPUT CALCULATIONS
Jim Bridger 4
Boiler Design: Tangential fired PC

PARAMETER	Current Operation		NO _x Control Technologies				SO ₂ and PM Control Technologies				Scenario A	Scenario B
	Control Technologies	LNB w/OFA	ROFA	LNB w/OFA & SNCR	LNB w/OFA & SCR	N/A ESP w/ Gas Conditioning	N/A Fabric Filter	Upgrade Wet FGD ESP	LNB w/OFA Upgrade Wet FGD ESP w/ Gas Conditioning	LNB w/OFA Upgrade Wet FGD ESP w/ Gas Conditioning	LNB w/OFA Upgrade Wet FGD ESP w/ Gas Conditioning	LNB w/OFA Upgrade Wet FGD ESP w/ Gas Conditioning
Installed Capital Costs		\$11,300,000	\$20,829,122	\$22,127,239	\$177,800,000	\$0	\$0	\$1,600,000	\$11,300,000	\$11,300,000	\$177,800,000	
NO _x Emission Control System	LNCFS-1 & Windbox Mods. Wet FGD ESP											
SO ₂ Emission Control System												
PM Emission Control System												
Operating & Maintenance Costs (\$/Yr)		\$11,300,000	\$20,829,122	\$22,127,239	\$177,800,000	\$0	\$0	\$1,600,000	\$11,300,000	\$11,300,000	\$177,800,000	
NO _x Emission Control System (\$/Yr)		\$21	\$39	\$42	\$335				\$21	\$21	\$335	
SO ₂ Emission Control System (\$/Yr)												
PM Emission Control System (\$/Yr)												
Fixed Operating & Maintenance Costs		\$21	\$39	\$42	\$335				\$21	\$21	\$335	
Operating Labor (\$)		\$0	\$0	\$0	\$0				\$0	\$0	\$0	
Maintenance Materials (\$)		\$28,000	\$42,000	\$120,000	\$190,000				\$28,000	\$28,000	\$190,000	
Administrative Labor (\$)		\$44,000	\$63,000	\$194,000	\$285,000				\$44,000	\$44,000	\$285,000	
Total 1st Year O&M Cost (\$)		\$72,000	\$105,000	\$314,000	\$475,000				\$72,000	\$72,000	\$475,000	
Annual Fixed O&M Cost Escalation Rate (%)		2.00%	2.00%	2.00%	2.00%				2.00%	2.00%	2.00%	
Levelized Fixed O&M Cost (\$/Yr)		\$82,985	\$124,478	\$384,542	\$563,114				\$82,985	\$82,985	\$563,114	
Variable Operating & Maintenance Costs		\$0	\$0	\$0	\$0				\$0	\$0	\$0	
Water Cost		\$0	\$0	\$0	\$0				\$0	\$0	\$0	
Makeup Water Usage (gpm)		\$124	\$124	\$124	\$124				\$124	\$124	\$124	
Unit Price (\$/1000 gallons)		2.00%	2.00%	2.00%	2.00%				2.00%	2.00%	2.00%	
Annual Water Cost (\$/Yr)		\$0	\$0	\$0	\$0				\$0	\$0	\$0	
Levelized Water Cost (\$/Yr)		\$0	\$0	\$0	\$0				\$0	\$0	\$0	
Resonant Cost		\$0	\$0	\$0	\$0				\$0	\$0	\$0	
Type of Reagent		None	None	None	None	Elemental Sulfur	None	Soda Ash	Soda Ash & Elemental Sulfur	Soda Ash & Elemental Sulfur	Soda Ash, Elemental Sulfur, Anhydrous NH ₃	
Unit Cost (\$/Ton)		\$0.00	\$0.00	\$370.00	\$400.00	\$370.00		\$80.00	\$370.00	\$370.00	\$400.00	
Unit Cost (\$/Lb)		\$0.000	\$0.000	\$0.185	\$0.200	\$0.185		\$0.040	\$0.185	\$0.185	\$0.200	
Molar Stoichiometry		0.00	0.45	0.00	1.00	0.00		1.02	0.00	1.02	1.02	
Reagent Usage (Lb/HR)		100%	100%	100%	100%	100%		100%	100%	100%	100%	
First Year Reagent Cost (\$)		\$0	\$0	\$89,431	\$1,020,510	\$145,884		\$89,431	\$145,884	\$145,884	\$1,020,510	
Annual Reagent Cost Escalation Rate (%)		2.00%	2.00%	2.00%	2.00%	2.00%		2.00%	2.00%	2.00%	2.00%	
Levelized Reagent Cost (\$/Yr)		\$0	\$0	\$105,997	\$1,209,590	\$172,910		\$105,997	\$172,910	\$172,910	\$1,209,590	
SCR Catalyst / Fabric Filter Bag Replacement Cost												
Material Replaced												
Annual SCR Catalyst (lb)/Yr (FF Bags)												
SCR Catalyst (\$/lb) (FF Bags)												
First Year SCR Catalyst / Bag Cost Escalation Rate (%)												
Annual SCR Catalyst / Bag Cost Escalation Rate (%)												
Levelized SCR Catalyst / Bag Cost Escalation Rate (%)												
Levelized Catalyst/Fabric Filter Bag Costs (\$/Yr)												
FGD Waste Disposal Cost												
FGD Waste Disposal Cost (\$/Yr)												
Annual FGD Waste Disposal Cost Escalation Rate (%)												
Levelized FGD Waste Disposal Cost (\$/Yr)												
Levelized Lower Cost												
Levelized Lower Cost (\$/Yr)												
Annual Lower Cost Escalation Rate (%)												
Levelized Lower Cost Escalation Rate (%)												
Auxiliary Power Requirements (\$/Yr)												
Auxiliary Power Requirements (\$/Yr)												
Annual Auxiliary Power Requirements Escalation Rate (%)												
Levelized Auxiliary Power Requirements (\$/Yr)												
Levelized Annual Cost												
Levelized Annual Cost (\$/Yr)												
Annual Levelized Annual Cost Escalation Rate (%)												
Levelized Annual Cost Escalation Rate (%)												
Levelized Auxiliary												
Levelized Auxiliary (\$/Yr)												
Annual Levelized Auxiliary Escalation Rate (%)												
Levelized Auxiliary Escalation Rate (%)												