

DEQ EXHIBIT 18



Natrona County Fire Prevention Bureau

555 N Robertson Ro
Casper, Wyoming
307-234-4679

Mailing: PO Box 497
Mills, WY 82644
Email: dbaker@natronacounty-wy.gov



January 23, 2013

INBERG-MILLER ENGINEERS
Thad M. Hunter, P.E.
Civil Engineer
Casper Laboratory Manager

Thad,

I received your email and attached information dated 1-22-2013 concerning the proposed drilling mud recycling center located southwest of Gering Street and Hanley Street. The Natrona County Fire District (NCFD) has no concern with the proposed location. However, the proposed building (due to the size and its occupancy classification, F-1 or F-2) and/or the type chemicals being reclaimed could require an automatic sprinkler system, fire alarm system or other fire code requirements.

Thank you

Dave Baker

Digitally signed by Dave Baker
DN: cn=Dave Baker, o=Natrona County Fire District,
ou=Fire Inspector, email=dbaker@natronacounty-wy.
gov, c=US
Date: 2013.01.23 14:50:12 -0700

Dave Baker
NCFD Fire Inspector

DEQ Exhibit 18

EQC No. 13-5802